

DCS No.: 05000311
Date: July 19, 2011

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-I-11-002A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. Some of the information received may not yet be fully verified or evaluated by the Region Staff.

<u>Facility</u>	<u>Licensee Emergency Classification</u>
PSEG	<input checked="" type="checkbox"/> Notification of Unusual Event
Salem Generating Station	<input type="checkbox"/> Alert
Hancocks Bridge, NJ	<input type="checkbox"/> Site Area Emergency
Docket: 50-311	<input type="checkbox"/> General Emergency
	<input type="checkbox"/> Not Applicable

Subject: **UPDATE - SALEM GENERATING STATION NOTIFICATION OF UNUSUAL EVENT DUE TO REACTOR COOLANT SYSTEM LEAK GREATER THAN 10 GPM AND TECHNICAL SPECIFICATIONS REQUIRED SHUTDOWN**

This Preliminary Notification updates information discussed in PNO-I-11-002 in which Salem Unit Two declared an Unusual Event on July 14, 2011, based on Reactor Coolant System (RCS) leakage in excess of 10 gallon per minute (gpm). This update clarifies the sources of leakage contributing to the event, describes additional licensee follow up actions, and discusses restart activities.

The licensee's initial investigation of the event concluded that the majority of the noted leakage was from the crack on a weld associated with the boron injection tank (BIT) relief valve piping (1 ¼" piping, about 200 degrees around the weld's circumference). After additional review, the leak rate estimate from that source was revised downward to less than 1.0 gpm. The remaining RCS leakage (estimated to be about 15 gpm) was attributed to flow through the BIT relief valve which was later determined to have lifted during the event. The cracked piping and the relief valve have been replaced and post maintenance testing has been satisfactorily completed. The removed piping segment was sent offsite for analysis to determine the cause of the cracking. The licensee's preliminary conclusion is the crack was caused by transgranular corrosion. The licensee has completed extent of condition inspections of remaining welds within the BIT boundary for both units and identified no additional problems. NRC inspectors are continuing their review of the licensee's actions under the baseline inspection program.

The licensee initiated plant startup on July 18 and took the reactor critical at 10:19 p.m. with generator synchronization to the grid at 5:04 a.m., July 19. The resident inspectors monitored the licensee's restart activities.

ADAMS Accession Number: ML112000481

Contacts: Arthur Burritt
(610) 337-5069
Arthur.burritt@nrc.gov

DISTRIBUTION (PN Recipient List)

BY E-MAIL:

Chairman Jaczko
 Comm. Svinicki
 Comm. Magwood
 Comm. Apostolakis
 Comm. Ostendorff
 OIP
 OCA
 OGC
 OPA
 EDO
 OE
 NRR
 NMSS
 OIG
 SECY
 IRO
 RES
 ACRS
 FSME
 NSIR
 NRO
 PDR
 RSLO
 Regional Offices

BY FAX:
 DOT:Trans
 INPO
 NSAC
 RI Resident Office

1. NJ Dept of Environmental Protection
 Bureau of Nuclear Engineering
 ATTN: Patrick Mulligan
 FAX# : 609-984-7513

2. NJ Radiological Emergency Response
 Planning
 ATTN: Tom Scardino
 FAX# : 609-530-4593

3. Delaware Div of Natural Resources and
 Environmental Control
 ATTN: Dr. Harry Otto
 FAX# : 302-739-7864

4. Delaware Emergency Management
 Agency
 ATTN: Janet Chomiszak
 FAX# : 302-659-6855

Licensee: PSEG
Salem Generating Station
 Region I Form 83
 (Rev. Nov. 21, 2006)

ADAMS Accession Number: ML112000481

SUNSI Review Complete: ALB (Reviewer's Initials)

DOCUMENT NAME: G:\DRP\PNs\PNO-I-11-002A - Salem RCS Leak UE Update.docx

After declaring this document "An Official Agency Record" it will be released to the Public.

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE <i>mmt</i>	RI/DRP	RI/OR	RI/PAO	RI/SLO	RI/DRP	RI/RA
NAME	ABurritt /ALB	RBarkley/	DScrenci/DS	DTiff/MOrendi for	DRoberts/DJR	WDean/WMD
DATE	07/19/11	07/ /11	07/ 19 /11	07/ 19 /11	07/19 /11	07/ 19/11

OFFICIAL RECORD COPY