

Date: May 9, 2012

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-I-12-001A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. Some of the information received may not yet be fully verified or evaluated by the Region Staff.

<u>Facility</u>	<u>Licensee Emergency Classification</u>
PSEG	<u> X </u> Notification of Unusual Event
Salem Generating Station	<u>    </u> Alert
Hancocks Bridge, NJ	<u>    </u> Site Area Emergency
Docket: 50-272	<u>    </u> General Emergency
	<u>    </u> Not Applicable

Subject:        **UPDATE** - SALEM GENERATING STATION INADVERTENT SAFETY INJECTION AND NOTIFICATION OF UNUSUAL EVENT DUE TO FIRE ALARM IN CONTAINMENT

This Preliminary Notification updates information discussed in PNO-I-12-001 in which Salem Unit 1 reactor automatically tripped on April 30, 2012 following a safety injection (SI) signal. The Preliminary Notification also discussed a Notice of Unusual Event (NOUE) declaration based on receiving multiple fire alarms inside containment. This clarifies the cause of the safety injection actuation and containment fire alarms, describes PSEG's follow-up actions, and discusses restart activities.

PSEG's investigation of the event concluded that the SI actuation was from an invalid signal most likely the result of induced voltages or "noise" in the 15 volt logic circuit of the plant's solid state protection system (SSPS). To address the cause, PSEG replaced all cards in the logic train that could have caused the SI initiation, and replaced an additional card that was causing elevated noise generation. During testing before and after the card replacements, PSEG could not recreate the spurious trip signal that caused the SI actuation, and completed all SSPS testing satisfactorily. Therefore, PSEG concluded that there was reasonable assurance that the affected SSPS train remained capable of performing its design function.

PSEG also concluded that the cause of the containment fire alarms was low pressure in several pilot air systems that actuate the fire system deluge valves. The SI actuation caused isolation of control air to the containment's fire systems. The control air isolation is an expected system response as part of the containment isolation signal generated after the SI actuation. This isolation of makeup air coupled with pilot air system leakage caused the fire alarms in three separate zones. As corrective action, PSEG identified and repaired the leaks in accessible portions of system before plant start-up.

The resident inspectors monitored and independently assessed PSEG's actions to identify and correct the causes of both the inadvertent SI actuation and the containment fire alarms and did not identify any concerns. PSEG initiated plant startup on May 6 and took the reactor critical at 10:42 p.m. with generator synchronization to the grid at 1:32 p.m., May 7. The resident inspectors monitored the restart activities.

ADAMS Accession Number: ML12130A293

Contacts:        Arthur Burritt  
                      (610) 337-5069  
                      [Arthur.burritt@nrc.gov](mailto:Arthur.burritt@nrc.gov)

DISTRIBUTIONS:  
BY E-MAIL:

OWFN

Chairman Jaczko  
Comm. Svinicki  
Comm. Apostolakis  
Comm. Magwood  
Comm. Ostendorff  
OIP  
OCA  
OGC  
OPA  
EDO  
OE  
NRR  
SECY  
IRO  
ACRS  
NSIR  
SRO  
PDR  
RSLO  
SECY  
IRO  
ACRS  
NSIR  
NRO  
PDR  
RSLO  
Regional Offices

TWEN

NMSS  
OIG  
RES

By Fax:

INPO  
NSAC  
RI Resident Office  
Licensee: PSEG Nuclear LLC (Salem)

ADAMS Accession Number: ML12130A293

DOCUMENT NAME: G:\DRP\PNs\PNO-I-12-001A Update - SALEM U1 INADVERTENT SI AND NOUE DUE TO FIRE ALARM IN CONTAINMENT rev2 (3).docx  
ADAMS Accession No.:

<input checked="" type="checkbox"/> SUNSI Review		<input checked="" type="checkbox"/> Non-Sensitive <input type="checkbox"/> Sensitive		<input checked="" type="checkbox"/> Publicly Available <input type="checkbox"/> Non-Publicly Available	
OFFICE <i>mmt</i>	RI/DRP	RI/ORA	RI/PAO	RI/SLO	RI/DRP
NAME	ABurritt/ ALB	ADeFrancisco/ * AD	DScrenci/* DS	NMcNamara/*NM	DRoberts/DJR
DATE	05/08 /12	05/ 08/12	05/ 08 /12	05/08 /12	05/ 09 /12
OFFICE	RI/ORA				
NAME	WDean/* WMD				
DATE	05/09 /12				

\*via email

OFFICIAL RECORD COPY