



August 2, 2012

To Whom It May Concern:

**NOTICE: THIS IS A REVISION TO THE NOTIFICATION DATED JULY 31, 2012**

QualTech NP is providing this notification as a potential 10 CFR Part 21 issue. We have discovered a manufacturing defect in a timing relay which prevents the relay from operating at a specific setting. This relay was purchased as a commercial grade item and dedicated through our dedication process for safety related applications at our Cincinnati facility.

The subject equipment is TYCO Model CNT-35-96, a timing relay with adjustable trip ranges from seconds up to 9,990 hours. QualTech NP has recently identified a failure mode for this relay in that the device will not trip in the 10H setting. In communications with the manufacturer, they have confirmed that there is a flaw in the design that prevents this specific setting from tripping.

QualTech NP has only sold this unit to two plants, Exelon LaSalle and Quad Cities. We recognize, however that other utilities could have these installed. Based on the information in hand we are evaluating the need for a 10 CFR Part 21 notification. Since the item was qualified under the EPRI SQRSTS Program, QualTech NP recognizes that other SQRSTS members may have used the qualification basis as part of licensee dedication activities and, therefore will notify EPRI of the condition.

Additional details will be provided in the formal written report. Please contact Tim Franchuk at 513-528-7900, ext. 176 (office), or via email [tfranchuk@curtisswright.com](mailto:tfranchuk@curtisswright.com) for any additional information.

A handwritten signature in black ink, appearing to read 'T Franchuk', is written over the printed name.

Tim Franchuk  
Quality Assurance Director  
QualTech NP, a business unit of Curtiss-Wright Flow Control Company  
Office: 513-528-7900, ext. 176  
[tfranchuk@curtisswright.com](mailto:tfranchuk@curtisswright.com)

IE19  
NRR