Date: September 5, 2012

## PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-I-12-006A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility	Licensee Emergency Classification
Exelon Generation Company, LLC	Notification of Unusual Event
Three Mile Island Unit 1	Alert
Middletown, PA	Site Area Emergency
Docket: 50-289	General Emergency
License: DPR-50	X Not Applicable

## SUBJECT: UPDATE - THREE MILE ISLAND (TMI) SHUTDOWN DUE TO REACTOR COOLANT SYSTEM LEAK

This Preliminary Notification updates information discussed in PNO-I-12-006, which described a plant shutdown on August 22, 2012 due to reactor coolant system (RCS) leakage.

The plant reached cold shutdown on August 23, 2012, and the source of RCS leakage was confirmed to be from micro-cracks in the alloy 600 diaphragm for the upper pressurizer heater bundle. This heater bundle was subsequently replaced with a bundle that contained a stainless steel, non-alloy 600 heater diaphragm. An NRC specialist inspector, who was deployed to the site, confirmed the source of the RCS leakage and monitored pressurizer heater replacement activities. The licensee subsequently conducted extent-of-condition inspections on the other two pressurizer heater bundles and no indications of leakage were identified. The inspectors determined that the licensee's post-installation and extent-of-condition inspections were acceptable.

Once all repair activities were completed, operators proceeded with reactor heatup and plant startup. No additional RCS leakage was observed. Reactor startup was commenced on September 3, 2012, and full power was achieved on September 5. The resident inspectors monitored licensee activities throughout the initial shutdown and subsequent startup.

This information has been reviewed with TMI plant management. This preliminary notification is issued for information only and no further update by the staff is planned.

ADAMS Accession Number: ML12249A367

CONTACT: Gordon Hunegs (610) 337-5046

DISTRIBUTION: (by email: RI-DL-PN; PN Distribution) Chairman Macfarlane Comm. Svinicki Comm. Apostolakis Comm. Magwood Comm. Ostendorff OIP OCA OGC OPA EDO OE NRR SECY IRO NMSS ACRS OIG RES **NSIR** NRO PDR **RSLO Regional Offices** R1\_DL\_PN By Fax: DOT: Trans INPO NSAC **RI** Resident Office Licensee: Exelon Generation Company LLC Three Mile Island Unit 1 Generating Station

## DOCUMENT NAME: G:\DRP\PNs\PNO-I-12-006A - TMI RCS Leak and SD greater than 72 hours Update.docx ADAMS ACCESSION NUMBER: **ML12249A367**

SUNSI Review		✓ Non-Sensitive				$\mathbf{N}$	Publicly Available
		Sensitive					Non-Publicly Available
OFFICE	RI/DRP	RI/SLO	RI/PAO	RI/DRP	RI/DRP	RI/ORA	A
NAME	SBarber/ SB	NMcNamara/ NM	DScrenci/DS via email	GHunegs/GKH	DRoberts/ DJR	WDear	n/DCL for
DATE	09/ 05/12	09/05 /12	09/05/12	09/05 /12	09/05/12	09/05/1	2

OFFICIAL RECORD COPY