Date: November 28, 2012

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-I-12-008A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. Some of the information received may not yet be fully verified or evaluated by the Region Staff.

<u>Facility</u>		<u>Licensee Emergency Classification</u>					
Entergy Nuc	clear Operations, Inc	X Notification of Unusual Event					
James A. Fi	tzPatrick Nuclear Power Plant	Alert					
Lycoming, N	IY	Site Area Emergency					
Docket: 50-333		General Emergency					
		Not Applicable					
Subject:	UPDATE: JAMES A. FITZP	ATRICK NUCLEAR POWER PLANT					
,	NOTIFICATION OF UNUSUAL EVENT DUE TO FIRE IN MAIN						
	TRANSFORMER	= 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1					
	HAMINGI CHAMLIA						

This preliminary notification supplements information in PNO-1-12-008, which documented the declaration of an Unusual Event at the Fitzpatrick plant on November 11, 2012, following a fire in the T1-A main transformer. On-site fire brigade personnel, with assistance from a local fire department, extinguished the transformer fire. Operators declared an Unusual Event (UE) at 5:45 a.m. EST and exited the UE at 8:01 a.m. the same day. The plant includes two main transformers T1-A and T1-B. These transformers are located on-site, outside and adjacent to the turbine building.

On November 12, 2012, while the FitzPatrick plant was shut down, Entergy staff began maintenance activities that included inspection of the T1-A and T1-B main transformers. Entergy's investigation determined that the problem initiated in the "B" Phase winding of the T1-A main transformer that subsequently resulted in the fire. Entergy personnel replaced the T1-A main transformer and determined the T1-B was not damaged. FitzPatrick operators re-started the plant after completing replacement and testing of the replacement T1-A main transformer, and testing of other similar transformers. The plant reached full power on November 27, 2012.

The NRC staff continues to closely follow Entergy's causal evaluations of the transformer failure and corrective actions. NRC oversight is being conducted through the NRC's baseline inspection program.

Entergy issued two news releases on November 11, 2012, related to the Unusual Event declaration, transformer fire, and termination. The information presented herein has been discussed with Entergy and is current as of November 28, 2010, at 10:00 a.m. Region I Public Affairs has responded to media inquiries.

This preliminary notification is issued for information only and no further notification by the staff is anticipated.

ADAMS Accession Number: ML12333A307

Contacts: Mel Gray

(610) 337-5209 mel.gray@nrc.gov

	OWFN Chairman Mac Comm. Svinicl Comm. Aposto Comm. Magwo Comm. Osteno OIP OCA OGC OPA EDO OE NRR SECY IRO ACRS NSIR SRO PDR RSLO SECY IRO ACRS NSIR NRO PDR RSLO SECY IRO ACRS NSIR NRO PDR RSLO SECY IRO ACRS NSIR NRO PDR RSLO Regional Official	ki olakis ood dorff	TWFN NMSS OIG RES	INPO NSAC RI Reside	Entergy Nuclea	ar Operations Inc	
	ADAMS Acces	ssion Numbe	r:				
	IENT NAME: G:\DRP\I ACCESSION NUMBE		A307	E FITZ NOUE FOR FIRE	IN MAIN TRAN		
	SUNSI Review		✓ Non-Sensitive Sensitive			Publicly Availab	
OFFICI	E RI/DRP	F	RI/PAO	RI/SLO	RI/DRF	-	RI/ORA

DISTRIBUTIONS: BY E-MAIL:

NAME

DATE

MGray/ar for

11/28/2012

DTifft

11/28/2012

DRobert /prw for

11/28/2012

WDean

11/28/2012

DScrenci

11/28/2012