
NRC / NEI / UTILITY MTG 6/11/14 4" & 6" RD/CH Drain Piping Inspection at the Palo Verde Nuclear Generating Station **Utilizing Quest's HYDRA**[™] Intelligent Pigging Technology - Dan Wittas -

NRC / NEI / UTILITY MTG 6/11/14

1


- Consequence of a leak on these drain lines
- Location of the piping
 - Between 3 large tanks
 - Under other utilities
- Relatively accessible for deployment and retrieval inside the lines








NRC / NEI / UTILITY MTG 6/11/14




NRC / NEI / UTILITY MTG 6/11/14


PALO VERDE







7



RD LINES 4" THREADED CAP AND FLOOR DRAIN NRC / NEI / UTILITY MTG 6/11/14



- Build a team BP Engr / Ops / Proj Mgr / ISI / RP / Work Planner
- Select vendor and technology
 - Site visits to 2 potential vendors
 - Consideration of NDE technology, FME, equipment decontamination
 - Quest's HYDRA™ Intelligent Pigging Ultrasonic
 Technology was selected




- Full scale mockup for deployment, retrieval and blind flaw detection capability
 - The inspection tool could be deployed and retrieved, thru 90s and a tee.
 - The Quest Hydra[™] UT inspection tool detected 26 of 34 flaws. All 8 undetected flaws were below the published detection threshold. 10 flaws below the threshold were detected, including 2 - 1/8" diameter flaws.



- Contingencies / Lessons Learned
 - Design engineering T-min acceptance criteria
 - Sump pumps need to be removed for access
 - 2 Launchers
 - Backup water pump & inspection pig
 - Pre-req for hot water flush to dilute boric acid
 - Leak test ILI piping and use catch basins







FULL SCALE MOCK-UP W/ 32 FLAWS PRIOR TO BURIAL

NRC / NEI / UTILITY MTG 6/11/14

- Work and inspection instructions, with
 - Initial conditions, such as, remove sump pumps, remove 90° elbow in sump, disconnect tank overflow pipes, cap HUT pump skid and floor drains
 - Connection of ILI equip, pump, launcher, pipe and valves
 - Operate the ILI, evaluate the results and restore systems

