



Nuclear Innovation  
North America LLC  
122 West Way, Suite 405  
Lake Jackson, Texas 77566  
979-316-3000

September 15, 2014  
U7-C-NINA-NRC-140027  
10 CFR Part 21

U. S. Nuclear Regulatory Commission  
Document Control Desk  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852-2738

South Texas Project  
Units 3 and 4  
Docket Nos. 52-012 and 52-013  
Nuclear Innovation North America Response to General Electric-Hitachi  
Final 10CFR Part 21 Report

On August 29, 2014, General Electric-Hitachi (GEH) Nuclear Energy submitted a final 10CFR Part 21 report summarizing an investigation into a non-conservative assumption in the hydrodynamic load definition for the Advanced Boiling Water Reactor (ABWR). GEH had previously submitted interim reports on this subject on March 31, 2014, and June 26, 2014. The GEH final evaluation concluded that the predicted increase in the suppression pool water level above the value used for defining the ABWR loads and applied in structural analysis will not result in a Substantial Safety Hazard or lead to exceeding a Technical Specification Safety Limit for the US ABWR Certified Design.

Nuclear Innovation North America (NINA) and Toshiba Corporation have completed a separate evaluation of this issue. A change to the assumption of TS high suppression pool level to a higher level as an input to the load calculation has an insignificant (less than 1%) impact on the containment structure. The other structures that could be affected, most notably the access tunnel, have not been designed yet. However, analyses considering the Japanese ABWR access tunnels indicate that the increases in combined loads are relatively small, and sufficient margin exists to accommodate these increases.

NINA concludes that evaluation of this non-conservative assumption results in an insignificant change for the STP 3&4 design and, as such, does not require a change to the STP 3&4 application. Additionally NINA agrees with the GEH conclusion that this issue does not result in a Substantial Safety Hazard for the US ABWR design as defined under 10 CFR Part 21.

IE19  
MRO

The Toshiba report on this evaluation is available for review by the NRC Staff at their convenience in the Westinghouse Rockville office.

There are no commitments in this letter.

Should you have any questions regarding this matter, please contact Bill Mookhoek at 979-316-3014 or myself at 979-316-3011.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on 9/15/14



Scott Head  
Manager, Regulatory Affairs  
NINA STP Units 3 & 4

wem

cc: w/o attachment except\*  
(paper copy)

(electronic copy)

Director, Office of New Reactors  
U. S. Nuclear Regulatory Commission  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852-2738

\*Tom Tai  
Fred Brown  
U. S. Nuclear Regulatory Commission

Jamey Seely  
Nuclear Innovation North America

Regional Administrator, Region IV  
U. S. Nuclear Regulatory Commission  
1600 E. Lamar Blvd.  
Arlington, Texas 76011-4511

Peter G. Nemeth  
Crain, Caton & James, P.C.

Kathy C. Perkins, RN, MBA  
Assistant Commissioner  
Division for Regulatory Services  
Texas Department of State Health Services  
P. O. Box 149347  
Austin, Texas 78714-9347

Richard Peña  
Kevin Pollo  
L. D. Blaylock  
CPS Energy

Robert Free  
Radiation Inspections Branch Manager  
Texas Department of State Health Services  
P. O. Box 149347  
Austin, Texas 78714-9347

\*Steven P. Frantz, Esquire  
A. H. Gutterman, Esquire  
Morgan, Lewis & Bockius LLP  
1111 Pennsylvania Ave. NW  
Washington D.C. 20004

\*Tom Tai  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852