

PRELIMINARY NOTIFICATION

December 12, 2014

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE—PNO-III-14-012

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. Some of the information may not yet be fully verified or evaluated by the Region III staff.

Facility

Prairie Island Nuclear Plant
Northern States Power Co.
Welch, MN
Docket: 50–282
License: DPR–42

Licensee Emergency Classification

Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: SHUTDOWN OF PRAIRIE ISLAND UNIT 1 DUE TO INCREASING TREND IN REACTOR COOLANT SYSTEM LEAKAGE

Prairie Island Unit 1 was shut down on December 10, 2014, to repair a leak from one of two reactor coolant pumps. The leak was identified after plant operators observed an increasing trend in the reactor coolant system leakage rate. The plant shut down after the leakage reached the licensee's administrative limit, which was lower than the required limit of 1 gallon per minute per the Technical Specifications. The peak leakage measured was 0.851 gallons per minute. The reactor coolant pumps ensure adequate cooling of the reactor when the plant is operating at full power.

The NRC Resident Inspectors were promptly notified and were on site to monitor the shutdown. The Resident Inspectors and Region III staff will continue to monitor the activities to repair the leak and the subsequent restart.

This preliminary notification is issued for information only and no further action by the staff is anticipated. State and local officials have been informed.

Region III received initial notification of this occurrence by the NRC Resident inspectors on site who were observing the outage activities. The information presented herein has been discussed with the licensee, and is current as of 1:00 pm CDT, on December 12, 2014.

ADAMS Accession Number: ML14346A468

CONTACT: Nirodh Shah
630–829–9821
Nirodh.Shah@nrc.gov