

Date: January 29, 2015

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-I-15-001

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. Some of the information may not yet be fully verified or evaluated by the Region I staff.

<u>Facility</u>	<u>Licensee Emergency Classification</u>
Entergy Nuclear Operations, Inc.	<input type="checkbox"/> Notification of Unusual Event
Pilgrim Nuclear Power Station	<input type="checkbox"/> Alert
Plymouth, MA	<input type="checkbox"/> Site Area Emergency
Docket No. 50-293	<input type="checkbox"/> General Emergency
License No. DPR-35	<input checked="" type="checkbox"/> Not Applicable

SUBJECT: PILGRIM NUCLEAR POWER STATION: SHUTDOWN GREATER THAN 72 HOURS DUE TO REACTOR SCRAM FOLLOWING A PARTIAL LOSS OF OFFSITE POWER

On January 27, 2015, Pilgrim Nuclear Power Station experienced an automatic scram following a turbine trip due to a partial loss of offsite power. The station was experiencing high winds and heavy snowfall during a severe winter storm when the station began experiencing degrading switchyard conditions. The station had already transferred the emergency busses onto their respective emergency diesel generators and was downpowering to 20% power to take the turbine offline. At 4:02 a.m. with the reactor at 52% power, the second offsite line was lost and the station experienced a load reject.

The station experienced equipment issues while cooling down after the scram including: the station diesel air compressor failed to start, one of four safety relief valves could not be operated manually from the control room, and high pressure coolant injection had to be secured due to failure of the gland seal motor.

The station is currently in cold shutdown, the safety buses are being powered by their respective emergency diesel generators, and all safety-related equipment required for safe plant shutdown are available. The licensee is working on restoring their 345kV lines.

Resident inspectors and region-based inspectors are providing oversight and performing follow-up inspections.

This preliminary notification is issued for information only.

The information presented herein has been discussed with the licensee and is current as of 1:00 p.m. on January 29, 2015. Commonwealth of Massachusetts officials have been kept informed.

ADAMS Accession Number: ML15029A433

CONTACT: Raymond McKinley, Projects Branch 5  
(610) 337-5150  
[Raymond.McKinley@nrc.gov](mailto:Raymond.McKinley@nrc.gov)

DISTRIBUTION: (by email: RI-DL-PN; PN\_Distribution)

Chairman Burns  
 Comm. Svinicki  
 Comm. Ostendorff  
 Comm. Baran  
 OIP  
 OCA  
 OGC  
 OPA  
 EDO  
 OE  
 NRR  
 SECY  
 IRO  
 NMSS  
 ACRS  
 OIG  
 RES  
 NSIR  
 NRO  
 PDR  
 RSLO  
 Regional Offices  
 R1\_DL\_PN

By Fax:

DOT: Trans  
 INPO  
 NSAC  
 RI Resident Office  
 Licensee: Entergy Nuclear Operations, Inc  
 Pilgrim Nuclear Power Station

DOCUMENT NAME: G:\DRP\BRANCH5\DAIY NOTES\2015\PNO-I-15-001 - Pilgrim SCRAM during JUNO.docx  
 ADAMS ACCESSION NUMBER: **ML15029A433**

<input checked="" type="checkbox"/> SUNSI Review		<input checked="" type="checkbox"/> Non-Sensitive <input type="checkbox"/> Sensitive		<input checked="" type="checkbox"/> <b>Publicly Available</b> <input type="checkbox"/> Non-Publicly Available	
OFFICE	RI/DRP	RI/DRP	RI/PAO	RI/SLO	RI/ORA
NAME	RMcKinley/RRM	HNieh/HKN	DScrenci/DS	NMcNamara/NM	DLew/DCL
DATE	1/29/15	1/29/15	1/29/15	1/29/15	1/29/15

OFFICIAL RECORD COPY