

1717 Wakonade Drive
Welch, MN 55089

800.895.4999
xcelenergy.com



AUG 24 2016

L-PI-16-074
10 CFR 21

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Prairie Island Nuclear Generating Plant Units 1 and 2
Dockets 50-282 and 50-306
Renewed Facility Operating License Nos. DPR-42 and DPR-60

Followup to Interim Report Submitted under 10 CFR 21.21(a)(2)

Reference:

1. S. Northard, NSPM, letter to NRC Document Control Desk, "Interim Report of a Deviation or Failure to Comply," L-PI-16-036, 4/14/2016 (ADAMS Accession Number ML16106A207)

Northern States Power Company, a Minnesota corporation, doing business as Xcel Energy (hereafter "NSPM") submits this followup report to the interim report (Reference 1) submitted pursuant to 10 CFR 21.21(a)(2).

NSPM has completed its evaluation of a high contact resistance discovered during bench testing of a new undervoltage relay manufactured by ABB (Part number 27N411T0375). The relays were returned to the supplier for testing, and all testing of the relay was satisfactory. No nonconformance was identified, and the relay was not modified, nor altered, nor repaired. The condition is not reportable under Part 21.

If there is any question or if additional information is needed, please contact Dr. Glenn A. Carlson, P.E., at 651-267-1755.

Summary of Commitments

This letter contains no new commitment nor revision to an existing commitment.

A handwritten signature in black ink, appearing to read 'Scott Northard', written in a cursive style.

Scott Northard
Site Vice President – Prairie Island Nuclear Generating Plant
Northern States Power Company – Minnesota

cc: Regional Administrator, Region III, USNRC
Project Manager, Prairie Island Nuclear Generating Plant, USNRC
Resident Inspector, Prairie Island Nuclear Generating Plant, USNRC
State of Minnesota