

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 APR1400 Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, February 8, 2017

Work Order No.: NRC-2868

Pages 1-185

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

APR1400 SUBCOMMITTEE

+ + + + +

WEDNESDAY

FEBRUARY 8, 2017

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 8:31 a.m., Ronald G.
Ballinger, Chairman, presiding.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

COMMITTEE MEMBERS:

RONALD G. BALLINGER, Chairman

MARGARET CHU, Member

MICHAEL L. CORRADINI, Member

WALTER L. KIRCHNER, Member

JOSE A. MARCH-LEUBA, Member

DANA A. POWERS, Member

HAROLD B. RAY, Member

JOY REMPE, Member

PETER C. RICCARDELLA, Member

GORDON R. SKILLMAN, Member

JOHN W. STETKAR, Member

MATTHEW W. SUNSERI, Member

ACRS CONSULTANT:

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL:

CHRISTOPHER BROWN

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

ALSO PRESENT:

TONY AHN, KHNP

JOE ASHCRAFT, NRO

SUD BASU, Public Participant

ANDREW BIELEN, RES

ALEXANDRA BURJA, NRO

CHANG SOK CHO, KNF

WOOCHONG CHON, KEPCO NF

JEFF CIOCCO, NRO

MANSEOK DO, KEPCO NF

JAMES GILMER, NRO

SYED HAIDER, NRO

JOHN HONCHARIK, NRO

JANG, KEPCO E&C

REBECCA KARAS, NRO

HUNG JIN KIM, KEPCO NF

II KYU KIM, KEPCO NF

JONG SOO KIM, KEPCO E&C

KANGHOON KIM, KNF

TAE HAN KIM, KEPCO

YUNG HO KIM, KHNP

SHANLAI LU, NRO

DAE HEON LIM, KEPCO E&C

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

MICHAEL MCCOPPIN, NRO

MATTHEW A. MITCHELL, NRO

KEN MOTT, NRO

JIYONG OH, KHNP

MARK ORR, RES

SUNG KEW PARK, KEPCO NF

TAE SUN RO, KEPCO E&C

JAMES ROSS, AECOM

ROBERT SISK, Westinghouse

JEONG KWAN SUN, KHNP

YIXING SUNG, Westinghouse

CARL THURSTON, NRO

CHRISTOPHER VAN WERT, NRO

ANDREA D. VEIL, Executive Director, ACRS

DANIEL WIDREVITZ, NRO

GEORGE WUNDER, NRO

PETER YARSKY, RES

TAE YOUNG YOON, KEPCO NF

*Present via telephone

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

TABLE OF CONTENTS

Opening remarks, Ron Ballinger.....	6
NRC Staff Opening Remarks.....	8
KHNP Opening Remarks.....	8
Chapter 4, reactor, KHNP.....	9
Chapter 4, reactor, NRC staff.....	142
Public Comment.....	182
Adjourn.....	185

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

P R O C E E D I N G S

8:31 a.m.

CHAIRMAN BALLINGER: The meeting will now come to order.

This is the meeting of the APR1400 Subcommittee of the Advisory Committee on Reactor Safeguards.

I'm Ron Ballinger, Chairman of the APR1400 Subcommittee.

ACRS members present are Joy Rempe, Jose March-Leuba, Walt Kirchner, Pete Riccardella, Mat Sunseri, Dana Powers, Dick Skillman, Harold Ray, Margaret Chu and our consultant Stephen Schultz, former ACRS member.

I believe we're going to be joined by Mike Corradini and Charles Brown, I think.

The purpose of today's meeting is for the subcommittee to receive briefings from Korea Hydro and Nuclear Power Company, KHNP, regarding their designs verification application and the NRC staff regarding their review of the safety evaluation specific to Chapters 4, The Reactor.

This meeting is the sixth in a series of meetings of our subcommittee to review KHNP application and related NRC staff safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 evaluations.

2 The rules for participation in today's
3 meeting were announced in the Federal Register on
4 February 7th, 2017.

5 The meeting was announced as open, but,
6 portions can be closed as needed. I don't think
7 that's going to be the case, but to protect
8 proprietary information to KHNP or its vendors
9 pursuant to 5 USC 552(b)(c)(4).

10 No requests for making a statement to
11 the subcommittee has been received from the public.

12 A transcript of the meeting is being
13 kept and will be made available as stated in the
14 Federal Register Notice. Therefore, we request that
15 participants in this meeting use the microphones.
16 And, there's a little button on the lower part and
17 the little light has to turn green to make it work.

18 The bridge -- a bridge number and a
19 password were published in the Federal -- on the NRC
20 website, excuse me. To minimize disturbance, the
21 public line will be kept in a listen only mode.
22 And, those of you on the public line, if you would
23 be kind enough to mute your line when you're not
24 participating because there's feedback and things.

25 The public will have an opportunity to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 make a statement or provide comments as designated
2 towards the end of this meeting.

3 There is an additional line that the
4 staff has requested for NRO staff and contractors to
5 participate in certain portions of their
6 presentations.

7 Please let Chris know when this line
8 should be opened. And, Chris Brown is the
9 Designated Federal Official for this meeting.

10 I'll request that the attendees and
11 participants silence their cell phones and other
12 electronic devices please.

13 Now, I invite Jeff Ciocco, there he is,
14 NRO Project Manager to introduce others and start
15 the briefing.

16 MR. CIOCCO: Yes, good morning. My name
17 is Jeff Ciocco. I'm the Lead Project Manager for
18 the APR1400 design certification. Thank you for
19 having us today for the APR1400 Chapter 4 Safety
20 Evaluation with Open Items.

21 And, with that, let's get on with it.

22 MR. SISK: Rob Sisk, Westinghouse
23 representing the KHNP and the APR1400 design. We
24 look forward to continuing our discussion with this
25 ACRS to present the APR1400 DCA today in Chapter 4.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, I echo Jeff's comments, we're ready
2 to go. Are you ready?

3 CHAIRMAN BALLINGER: Yes.

4 MR. SISK: Then I'll turn it over to Il
5 Kyu Kim to lead us through Chapter 4.

6 MR. I. KIM: Good morning ladies and
7 gentlemen. My name is Il Kyu Kim from KEPCO-ENF.

8 We are going to present this Chapter 4
9 reactor today.

10 This presentation consists of overview
11 of Chapter 4, Section Summary, Summary and
12 Attachments.

13 In the Section Summary, summary or each
14 section will be presented from Section 4.1 to 4.6.

15 The Chapter 4 consists of six sections,
16 a summary description, fuel system design, nuclear
17 design, thermal-hydraulic design, reactor materials
18 and functional design of reactivity control system.

19 I will present Section 4.1 and 4.2.
20 Manseok Do will present Section 4.3; Kanghoon Kim
21 will present Section 4.4; Jong Soo Kim will present
22 Section 4.5 and 4.6.

23 This slide shows the summary to the
24 documents with related sections. DCD to topical
25 records and the six technical records are submitted

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for Chapter 4.

2 This table shows the summary of the
3 APR1400 core and the fuel design. Core power is
4 3,983 megawatt to thermal. The fuel rod lattice is
5 16x16.

6 The number of fuel lattice in our fuel
7 assembly are 236. The number of fuel assemblies in
8 core are 241. The number of control element
9 assemblies in core are 93.

10 The active fuel lengths is 150 inches.
11 Maximum peaking factor is 2.43 and maximum fuel rod
12 average burnup is 60,000 megawatt of metric ton
13 uranium.

14 This tables shows the primary core used
15 in this section -- used in each sections.

16 There is no open items for Section 4.1.

17 From this slide, let me give you a
18 presentation for the Section 4.2.

19 This slide shows the PLUS7 design
20 features. PLUS7 fuel assembly has been developed
21 here for combustion engine type nuclear power
22 plants. Therefore, PLUS7 has typical features of
23 combustion engine type fuel, such as core spring for
24 hold down spring and the big guided thimbles.

25 As I already explained it, a regular

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fuel rod in assembly is 16x16, the numbers of fuel
2 rods in assembly are 246 and the thermal core of
3 cladding is ZIRLO.

4 The number of the material we tied in
5 the back is Stainless Steel 304, except hold down
6 spring of which material is Inconel 718.

7 One top, one bottom and the one
8 protective grade are used at the top and bottom
9 portion of the fuel assembly. The material with
10 these grids are Inconel 718.

11 Nine mid grids and four guide thimbles
12 are used and in the metal of both is ZIRLO.

13 This slide explains the irradiation
14 experience of PLUS7 fuel. We had two surveillance
15 programs for PLUS7 fuel.

16 One is with lead test program, the other
17 one is commercial surveillance program.

18 Four lead test assemblies were loaded
19 and examined here for commercial supply. And, the
20 four assemblies were selected for per power
21 examination among the fuel assemblies commercially
22 supplied for Hanbit Unit 5, Cycle 5 which include
23 these four assemblies as commercial surveillance
24 assemblies.

25 Four site examinations were conducted

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for lead test assemblies and the commercial
2 surveillance assemblies.

3 Also, hot cell examination of related
4 test assembly has been completed after irradiation.

5 Per site examination and hot cell
6 examination results showed all design requirements
7 were met.

8 Now, I explain about the operating
9 experience. About 5,000 PLUS7 fuel assemblies have
10 been supplied as of 2016.

11 MEMBER MARCH-LEUBA: Can I ask a
12 question? I mean, each core loads 241 fuel
13 assemblies, correct?

14 MR. I. KIM: Yes.

15 MEMBER MARCH-LEUBA: So, 5,000 is 24
16 cores, roughly?

17 MR. I. KIM: Twenty-four core --

18 MEMBER MARCH-LEUBA: Five thousand
19 divided by 241.

20 MR. I. KIM: Five thousand -- yes,
21 approximately.

22 MEMBER MARCH-LEUBA: Approximately there
23 are 20. Yet, you're still talking about four LTAs,
24 so --

25 MR. I. KIM: Pardon me?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: You're talking
2 about four LTAs. So, it seems to me that only four
3 elements have been loaded in the core. And what's
4 this 5,000?

5 MR. I. KIM: Actually, the LTA loaded in
6 26 --

7 MEMBER MARCH-LEUBA: Okay.

8 MR. I. KIM: -- and the five short ones.
9 Anyway, after that, we supply the fuel assembly
10 commercially of about 20 years for operating power
11 plant.

12 MEMBER MARCH-LEUBA: For the last 20
13 years, you're been supplying or --

14 MR. I. KIM: Already we supplied about -
15 -

16 MR. SISK: Perhaps, I can just quickly.

17 The PLUS7 fuel was developed back around
18 -- in the 2000 as you could say. And, the LTA, this
19 is kind of a summary history were done in 2006.
20 It's the fuel PLUS7 is being used in Korea since
21 that time.

22 So, 2006 to now we're at 2017, PLUS7
23 fuel has quite a bit of experience.

24 MEMBER MARCH-LEUBA: But for the LTAs
25 can't be relevant because you have 5,000 of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 other ones?

2 MR. SISK: Except those were the ones
3 where you did the actual hot cell exams and so,
4 that's part of the history of the development of the
5 PLUS7.

6 CHAIRMAN BALLINGER: What's the peak
7 burnup?

8 MR. I. KIM: Peak burnup, I'm no -- I
9 don't remember quite what --

10 MR. DO: The peak burnup is 50 gigawatt
11 a day for material uranium.

12 CHAIRMAN BALLINGER: Well, okay, is that
13 the -- that's the design peak burnup. But, what's
14 the actual peak burnup been for these 5,000 PLUS7
15 fuel assemblies?

16 MR. I. KIM: I'm not sure.

17 CHAIRMAN BALLINGER: I couldn't find it.

18 MR. CHON: Yes, that's about 59,500
19 burnup.

20 CHAIRMAN BALLINGER: Oh, okay. Okay,
21 that'll do.

22 MR. CHON: This is Woochong Chon from
23 KEPCO Nuclear Fuel.

24 CHAIRMAN BALLINGER: Thank you.

25 I should ask one more question. What's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the failure rate been?

2 MR. I. KIM: Failure rate?

3 CHAIRMAN BALLINGER: Yes, how many fuel
4 rods --

5 MR. I. KIM: Ten fuel rods have been
6 failed.

7 CHAIRMAN BALLINGER: Okay.

8 MR. I. KIM: Okay.

9 CHAIRMAN BALLINGER: Thank you.

10 MR. SCHULTZ: I have a question related
11 to the fuel failure. You mention in the fuel
12 topical report that you had addressed fretting
13 failures for this fuel design very well. You
14 haven't had any experience with fretting failures
15 for many years now, many years.

16 When you say ten -- you've had ten fuel
17 failures, fuel pin failures, what have they been due
18 to? What have those failures been due to? Have you
19 investigated the cause of those failures?

20 MR. I. KIM: Seven failed rods, the
21 cause of the failure of seven fuel rods is debris
22 failure.

23 MR. SCHULTZ: That was debris?

24 MR. I. KIM: Yes. And --

25 MR. SCHULTZ: And, so, when did that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 happen? Was that many -- several years ago? You've
2 got some debris barriers now in your fuel design
3 system.

4 MR. I. KIM: I don't remember the date
5 when the failure happened. And, I have no
6 information now.

7 CHAIRMAN BALLINGER: So, to close the
8 loop, seven debris failures. What were the other
9 three?

10 MR. I. KIM: One is unknown, two is
11 manufacturing failure.

12 CHAIRMAN BALLINGER: Thank you.

13 MR. SCHULTZ: Thank you.

14 MR. I. KIM: You are welcome.

15 Okay, now, let me continue with the
16 presentation.

17 Single Unit 3 which is the referenced
18 plant of APR1400 state 30 commercials operating with
19 PLUS7 fuel assembly on December 20, last year.

20 PLUS7 fuel assemblies will be supplied
21 for 4 Barakah APR1400 nuclear power plants in UAE
22 and five APR1400 nuclear power plants in Korea.

23 The design requirements of Section 4.2
24 are 10 CFR Part 50 Appendix A and 10 CFR Part 50.46.
25 And the NRC guidance are Regulatory Guide 1.206,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Section 4.2 and the Standard Review Plans Section
2 4.2.

3 Design criteria related to fuel system
4 design are listed in this table. All the evaluation
5 for this design criteria were performed and
6 described in Section 4.2.

7 And, the results show that each
8 requirements are met.

9 This slide explains about the open
10 items. Open items in the Section 4.2 is related to
11 PLUS7 fuel assemblies structural analysis.

12 There are nine RAIs which is not
13 responded yet on the PLUS7 seismic technical report.
14 Fuel assembly tests and the seismic analysis have
15 been performed to answer the RAIs.

16 All of the tests have been performed
17 except the damping test.

18 RAIs will be responded by February 28th,
19 the end of this month and the technical report will
20 be revised.

21 MR. SCHULTZ: I have a question.

22 MR. I. KIM: Yes?

23 MR. SCHULTZ: In the topical report for
24 the fuel design, you have listed that this area
25 would be site specific or because of seismic.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. I. KIM: Yes.

2 MR. SCHULTZ: Yes.

3 MR. SCHULTZ: Because of seismic, is
4 that still a condition of the discussion with the
5 staff that there would be a site specific evaluation
6 of the seismic loading or have you come to an
7 approach where it is not site specific? You've
8 bounded it in some fashion?

9 MR. I. KIM: Yes, actually, the topical
10 report does not include that seismic LOCA
11 evaluation, but DCD includes the seismic LOCA
12 calculation. Yes, it's listed in the technical
13 report that's listed in this slide. This technical
14 report describes the analysis results for the
15 seismic LOCA analysis.

16 MR. SCHULTZ: And, what does that assume
17 for the seismic loading? Is there -- is that a
18 bounding evaluation or will there be a site specific
19 seismic evaluation in addition to what you're doing
20 here?

21 MR. SISK: Rob Sisk, Westinghouse.

22 In general, as you know, there is
23 Chapter 3 has yet to be reviewed. We'll talk about
24 these 37, 38, the seismic requirements. The APR1400
25 is a .3G plant. The fuel is being evaluated and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 demonstrated to be acceptable for the plant design
2 of .3G.

3 MR. SCHULTZ: Good, thank you. Go
4 ahead.

5 MEMBER CORRADINI: Just to follow up, so
6 then, that's the envelop and then if a particular
7 site exceeds the envelop, then it has to be site
8 specific?

9 MR. SISK: Of course.

10 MEMBER CORRADINI: Okay, that's fine.

11 MEMBER REMPE: So, I have a question to
12 follow on earlier about the maximum burnup of the
13 PLUS7 fuel.

14 In the report about the effect of
15 thermal conductivity degradation, it talks about the
16 FATE code, FATE 3, is it FATE 3S3B, I don't know how
17 you refer to it, that's another acronym said.

18 But, anyway, it said it's only been
19 calibrated up to maximum burnup greater than -- or
20 up to 23,000 megawatt days per metric ton uranium.

21 And, then, I know there's been some
22 discussion about what's going on about thermal
23 conductivity degradation and how you looked at the
24 results from your analysis versus what would happen
25 if you went to a higher burnup.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And, could you talk a little bit about
2 what your plan is to address some of the staff
3 questions about thermal conductivity degradation and
4 how that's progressing? Because that does impact
5 what we're reviewing here on the fuel today.

6 MR. CHON: This is Woonchong Chon from
7 KEPCO Nuclear Fuel.

8 We are still discussing about that issue
9 which is DCD with analysis test. And, we added more
10 housing data to justify our results. The added
11 housing data contains more higher burnup which is
12 almost the same as a range of PLUS7 fuel.

13 MEMBER REMPE: Okay.

14 MR. CHON: But, we will conclude DCD
15 issue maybe within this month.

16 MEMBER REMPE: Okay, thank you.

17 MR. DO: Good morning, everyone. I am
18 Manseok Do from KEPCO Nuclear Fuel. I am in charge
19 of the nuclear design for APR1400.

20 Today, I am going to make a brief
21 description about Chapter 4.3 of the APR1400 DCD.

22 And, I'll start with general
23 characteristics of load patterns and fuel assemblies
24 for APR1400 core.

25 The loading pattern on APR1400 core

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consists of three batch scheme. It reduces the
2 peaking factor.

3 The core that time is based on refueling
4 to of approximately 18 months with replacement of
5 one over three which is including each refueling
6 outage.

7 As you can see in this picture, the fuel
8 assembly is, again, a system by 16x16 containing 236
9 pure or one over equation rods with control rod
10 guide two and one instrumentation guide two.

11 The fuel rod contain uranium dioxide
12 pellets are various in each one. And, the rods
13 contain gadolinia-urania pellets.

14 The system improves the long term
15 control of the LOCA assembly power distribution.

16 If the ratio number of fuel assemblies
17 or fuel rods in each month, a number of gadolinia
18 rod assembly and gadolinia contents for each fuel
19 assembly type.

20 MEMBER SKILLMAN: Before you change that
21 image, let me ask this question. In the blue first
22 carry, you indicate three batch system, refueling
23 interval of 18 months.

24 But, the tech or the words that you
25 spoke were approximately 18 months and the DCD at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 4313 indicates approximately 18 months. Why have
2 you used that word approximately?

3 MR. DO: The 18 months cycle contain
4 over a period. So, you get operation time will be
5 varied between 400 to 500 EFPDs. So, I mean by
6 about, it will be expected 18 months for equilibrium
7 cycle.

8 MEMBER SKILLMAN: Okay, thank you. I
9 understand.

10 MR. SCHULTZ: With regard to the
11 gadolinia fuel rods -- containing fuel rods, I
12 didn't see it, have you demonstrated that in terms
13 of thermal performance that the gadolinia rods are
14 never limiting? The conductivity will be lower than
15 for the UO2 rods, so, therefore, have you done
16 analyses that demonstrate that gadolinia rods are
17 not thermally limiting because of the burnable
18 poison within them?

19 MR. DO: Do you mean if they --

20 MR. SCHULTZ: For the analysis that's
21 performed in safety analysis either for operating
22 performance -- we're not -- we're talking Chapter 4,
23 not Chapter 15, but as you do your thermal
24 performance analysis, I presume those rods, in terms
25 of their power are not limiting and so the thermal -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 - the melting -- the rod temperature, for example,
2 is not a limiting -- cannot be the limiting rod even
3 though the thermal conductivity in those rods will
4 be somewhat lower than for UO2 rods.

5 MR. CHON: This is Woochong Chon from
6 KEPCO Nuclear Fuel.

7 Generally, the gadolinia fuel has to do
8 much less enrichment. So, most cases, gadolinia
9 fuel is not limiting.

10 MR. SCHULTZ: Okay. Fine, thank you.

11 MR. CHON: No problem.

12 MEMBER MARCH-LEUBA: In the nuclear
13 enrichment, is the enrichment actually --

14 MR. DO: There's a pass of fuel per 2.0
15 with percent.

16 MEMBER MARCH-LEUBA: Say again?

17 MR. DO: 2.0 with percent for top and
18 bottoms.

19 So, these are basis for the nuclear
20 design of the APR1400 are, as part of first the core
21 power, the solutions are controlled through that the
22 power distribution.

23 Second, when the reactive is noted and
24 tends to compensate for rapid reactive decreases in
25 the power plant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Finally, control systems are capable of
2 providing an acceptable margin and of controlling
3 power decision.

4 But the force of the nuclear is to
5 provide the limits under power distribution so that
6 we don't damage the fuel during the power operation.

7 But, factor for full power condition is
8 2.43 which is based on the LOCA limit and the core
9 average.

10 The minimum DNBR is 1.29 as described in
11 Section 4.4. And, the maximum peak fuel rod is 50
12 given today on the uranium.

13 But, the limits on the power and the
14 initial conditions described in Chapter 6 and 15.

15 MEMBER SUNSERI: I have a question on
16 that slide. So, in a few places in the design
17 certification document, it describes this plant as
18 designed for base loaded operation but capable of
19 load following.

20 So, in your definition of normal
21 operation under the core power distribution, does
22 that include load following operations and do these
23 parameters bound the conditions that would be found
24 during load following?

25 MR. DO: No, we don't intend to load

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 following operation.

2 MEMBER SUNSERI: You don't intend to
3 load follow?

4 MR. DO: Just daily power or following
5 top end load.

6 MR. OH: This is Andy Oh, KHNP,
7 Washington Office.

8 That word is corrected by the RAI Number
9 293-8332. Initially, we used the word power, but we
10 corrected that word with power maneuvering. So,
11 that means that our -- the APR1400, there is no
12 intention to load follow operation anymore.

13 MEMBER SUNSERI: Okay, so, in various
14 places like in Chapter 8 where it says the turbine
15 generator is designed for -- or maybe it's 10, I
16 can't remember, 10 -- for load following operations,
17 that's been removed? Or changed to power
18 maneuvering?

19 MR. OH: I think that the next revision,
20 we probably we will change that inconsistent with
21 Chapter 4. So, I assume that the usually turbine as
22 it is, so that the initially, they had some function
23 for the load following. Whether it's in a --
24 incorporate to the nuclear or the fuel.

25 So, that's the reason there's a genetic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 function for the load following. But, in the fuel
2 side, we don't have some function for the load
3 following anymore.

4 So, even though it is some function for
5 the load following on the turbine side, there's no
6 function can be accomplished by the load following
7 anymore.

8 MEMBER SUNSERI: Okay. So, maybe I
9 understand this now a little better. So, the
10 overall plant may be able to load follow, but the
11 reactor's going to stay at full power because the
12 turbine generator side is going to be designed to
13 dump the steam or something so it can follow the
14 load, but the reactor stays constant? No? Yes?
15 No?

16 MR. OH: No, and for the fuel side, no
17 load following operation.

18 MEMBER SUNSERI: Okay.

19 MR. OH: So --

20 MEMBER CORRADINI: So, can I ask Matt's
21 question differently? Can you define the difference
22 between load follow and power maneuvering? Is it
23 just the rate of power change in the thermal power?
24 I'm still not clear of the difference in the words.

25 MR. OH: Yes, this is Andy Oh, KHNP,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Western Office again.

2 For load following is for, you know,
3 some constant operation for depending on a power
4 level. When we use the power maneuvering means that
5 we assume that both RPCS reactor power system or
6 something if some -- then the power can be compacted
7 to the some certain level of the power. Then we
8 assume that is a power maneuvering operation.
9 That's the reason we use the --

10 MEMBER CORRADINI: Yes, I understand.
11 All right, did that help? I'm still a little
12 unclear.

13 MEMBER SUNSERI: No, I think he's saying
14 -- I think they're describing power maneuvering as
15 just something that you would do to the plant to
16 maneuver it and varying transients and whatever.

17 But, load follow is a, at least in this
18 country, is defined as a capability to match the
19 output of the plant to the demand of the system as
20 it varies in significant ways, you know, like
21 overnight or during the day or something of that
22 nature.

23 And, typically, those load following
24 operations, if the reactor is allowed to follow the
25 load also causes power distribution concerns that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 need to managed. Right?

2 And, so, our questions are, we've seen
3 in the DCD where the term load following has been
4 used and we're wondering, you know, if it's been
5 thoroughly analyzed for that.

6 And, what I hear you saying is the
7 reactor is not intended to be operated in a load
8 following manner, is that correct?

9 CHAIRMAN BALLINGER: So, let's just get
10 the definitive statement because there's been a lot
11 of confusion and I think it might have been
12 confusion with respect to definitions and things
13 like that as well.

14 MEMBER REMPE: But, apparently this --

15 CHAIRMAN BALLINGER: This plant is not
16 designed to load follow, period.

17 MEMBER REMPE: But there has been an RAI
18 that where the staff asked them to clarify it and
19 you've committed to make that change.

20 MR. OH: Correct.

21 MEMBER REMPE: Can, maybe, again, there
22 were a lot of RAIs, but can we see that RAI? Can it
23 be sent to Chris, if we have it? Was it a recently
24 -- I mean, this was brought up when we talked about
25 Chapter 10 and it wasn't clear what was happening.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SUNSERI: Andy gave that number.
2 Could you repeat that number again so I can write it
3 down? That's okay, we'll get it. We can get it
4 later.

5 MR. OH: That is RAI Number 293-8332,
6 question number four.

7 MEMBER SUNSERI: Okay, thank you.

8 MEMBER REMPE: So, out of curiosity
9 then, in this Chapter, you still had load following.
10 So, I guess it was submitted earlier and the staff
11 was just silent about the load following. And, is
12 that because they knew that you were going to remove
13 it and that's why they didn't mention it? And,
14 maybe that's a question for the staff.

15 MR. LU: Shanlai Lu from the staff.

16 Yes, I think load following, after we
17 asked the question, we decided not to do the load
18 follow in there. So, therefore, it's not an issue
19 anymore from our perspective.

20 MEMBER REMPE: Okay, thank you.

21 MEMBER SUNSERI: Thank you.

22 MR. DO: This slide describes reactivity
23 coefficients. The figure shows the dependence on
24 the circulated temperature coefficient on the fuel
25 temperature.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Also, at the beginning and at the end of
2 the first cycles.

3 The fuel temperature coefficients are
4 noted for the range of fuel temperatures throughout
5 the cycle.

6 The mode of the temperature coefficient
7 is slightly positive at power for a short time of
8 the cycle.

9 But the net impact of the reactive
10 equation is noted for whole power operating ranges
11 throughout the cycle.

12 MEMBER MARCH-LEUBA: By burning up
13 absorbers, you mean gadolinia rods, control rods?

14 MR. DO: Gadolinia rods.

15 MEMBER MARCH-LEUBA: The gad rods. So,
16 that's built on the fuel not the coefficient? I
17 mean that's --

18 MR. DO: I'm sorry?

19 MEMBER MARCH-LEUBA: That's built on the
20 -- it's part of the coefficient?

21 MR. DO: Yes.

22 MEMBER MARCH-LEUBA: So, that is --

23 MR. DO: The gadolinia rods are the
24 critical boron concentration is reduced. MEMBER
25 MARCH-LEUBA: What -- say again?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DO: Because they are gadolinia
2 rods, we can reduce critical boron concentration at
3 EOC. You know, MTC is dependent on much of it on.
4 But it can be just above concentration, you can
5 maintain MTC.

6 MEMBER MARCH-LEUBA: Okay, so the MTC is
7 never positive. It would be using the gadolinia
8 rods? Is the MTC post the MTC the moderator
9 temperature coefficient positive with the gadolinia
10 rods inserted?

11 MR. DO: For power about 3,000 there are
12 -- uranium at the time MTC is slightly positive.
13 But over reactive to coefficient where the fuel
14 temperature was.

15 MEMBER MARCH-LEUBA: Okay, so the MTC is
16 positive?

17 MR. DO: I think just at the time.

18 MEMBER MARCH-LEUBA: For a short period
19 of time?

20 Yes, because the issue with positive
21 MTC, the moderator temperature coefficient responds
22 instantly to, at least, certainly to simultaneous to
23 moderator heating. Whereas, the fuel has a two,
24 three, five, ten second time response.

25 So, you may have -- I mean, whenever you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have positive reactivity coefficients, you have to
2 make sure that you don't have an accident that gets
3 you a serious problem.

4 And, as I'm sitting here, I don't have
5 any confidence that you have done an analysis. Have
6 you done that analysis?

7 MR. SCHULTZ: Could you describe again,
8 perhaps you mentioned it and I just missed the
9 range, you indicated when you might begin to have a
10 positive MTC, how long does it last? What's the
11 burnup range in which you might have a positive MTC?

12 MR. DO: One kilowatt a day permitted to
13 uranium.

14 MR. SCHULTZ: For that range? For a
15 short range? Why does that happen just over a
16 calculated short range? Is there a way to prevent
17 that?

18 MEMBER MARCH-LEUBA: Well, what happens
19 is you have too much reactivity and you had to put
20 too much dissolved boron.

21 MR. SCHULTZ: Yes, I understand. That's
22 a very short time frame.

23 MEMBER MARCH-LEUBA: Still, I mean, if
24 it happens, it happens. I mean, you should --

25 MR. SCHULTZ: Is that actually occurring

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in the cycle designs for other reactors with this
2 fuel? The positive MTC? And, it's part of the
3 control systems for those other reactors or is this
4 something special about this reactor design?

5 MR. DO: Not special.

6 MR. SCHULTZ: Okay.

7 MR. DO: For extremely low power, at low
8 power, MTC sometimes positive for other -- also
9 other type of reactor.

10 MR. SCHULTZ: Low power? If you --

11 MR. DO: Not low power.

12 MR. SCHULTZ: Okay, okay. But, not near
13 the very beginning of the cycle, that's controlled
14 by the burnable poison. The positive -- it is not a
15 positive MTC at beginning of cycle because of the
16 burnable poison?

17 MR. DO: Not beginning of cycle.

18 MR. SCHULTZ: But sometimes later at hot
19 zero power, it could be positive?

20 MR. DO: When the gadolinia depletions
21 are made. When gadolinias are depleted.

22 MR. SCHULTZ: Yes.

23 MR. DO: The concentration right here at
24 the time MTC is slightly positive at hot zero
25 condition.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCHULTZ: Okay, okay, thank you.

2 MS. BURJA: This is Alex Burja from the
3 staff.

4 I'd just like to add, again, so, there
5 is a slightly positive MTC at hot zero power at
6 beginning of cycle. But, during power operations,
7 it becomes negative.

8 MEMBER MARCH-LEUBA: So, when you go to
9 full temperature at a 100 percent power, everything
10 is negative?

11 MS. BURJA: Correct.

12 MEMBER MARCH-LEUBA: So, the issue would
13 be in startup? When your fuel is cold and you're
14 relying on that cold fuel to heat up to give you
15 that negative feedback?

16 I really would like to see some analysis
17 because that is textbook program with fast transits.

18 MS. BURJA: Okay, I understand.

19 MEMBER MARCH-LEUBA: I mean, when your
20 fuel is cold and your temperature coefficient on the
21 liquid is positive, you must have a very large over
22 shoot because you are at zero power, meaning you're
23 not heating up the fuel.

24 So, you have to have a tremendous over
25 shoot of power before you will heat up the fuel and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 get a negative feedback.

2 So, I will wait until you guys are here
3 and I'll ask you what analysis you've done to
4 confirm that you don't have startup problems.

5 MEMBER SUNSERI: But, I don't think it's
6 uncommon for --

7 MEMBER MARCH-LEUBA: It's not uncommon
8 but --

9 MEMBER SUNSERI: -- plants in the U.S.
10 to have a slightly positive at the beginning of life
11 right now.

12 MEMBER SKILLMAN: For every reload that
13 we did for years, we had a positive coefficient for
14 approximately the first week. And, as soon as we
15 build in the fission product poisons, that moderator
16 temperature coefficient became negative and remained
17 negative. We were on 24-month cycles, but it was
18 about the first 96 hours or so, the first four or
19 five days.

20 MEMBER MARCH-LEUBA: You were just
21 hoping you didn't have an accident those days?

22 MEMBER SKILLMAN: Well, no, no. We were
23 controlling the reactivity to make sure that we did
24 not have the accident that you are speaking about.
25 We were very deliberate and we knew it was in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 core operating limits report, just like the
2 gentleman said. So, this is not new.

3 MEMBER MARCH-LEUBA: I'd just like to
4 have the confidence that it has been analyzed.

5 MEMBER KIRCHNER: I think it has, if you
6 read the detailed reports.

7 (OFF MICROPHONE COMMENTS)

8 MR. SCHULTZ: That is true. It did
9 become an issue when the industry went to burnable
10 poisons at these levels. But, it was addressed and
11 so it has become, not a universal approach, but
12 certainly one that is used by many BWRs.

13 MR. DO: The reactive control system of
14 the APR1400 provides a shutdown margin considering
15 single malfunctions over the reactivity control
16 systems.

17 This figure shows the control element
18 assembly pictures for core.

19 The APR1400 core is equipped with the 81
20 full strength CEAs and 12 partial strength CEAs.
21 The internal materials in full strength CEA and
22 partial strength CEA.

23 Therefore, 12 of the internal elements
24 for full strength CEA and for elements for partial
25 strength CEA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The insertion limit is a function of the
2 core power and the components to shutdown margin.

3 The final issue in this section is the
4 stability. The APR1400 core is inherently stable to
5 the total power because of the negative overall
6 power correction.

7 Even though the general induce the power
8 the stability shows oscillations may occur. The
9 radial and azimuthal stability index is noted
10 throughout the entire cycle.

11 If oscillation occurs, based on the core
12 operating limits supervisory system, measurement of
13 the disposition, the operator may move the core
14 strength CEAs or partial strength CEAs to conserve
15 any axial power oscillations and that they can be
16 controlled effectively by partial strength CEAs in
17 the figure 4.3 page 43 of DCD.

18 MEMBER MARCH-LEUBA: So this xenon
19 oscillations will be mostly axial oscillations?

20 MR. DO: Yes, correct.

21 MEMBER MARCH-LEUBA: And, then, you have
22 to sufficient feedback that they are not supposed to
23 happen? That you have sufficient feedback,
24 sufficient reactivity coefficient that will dampen
25 them out under normal conditions? Is that not what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 your first bullet says? That oscillations will
2 happen?

3 MR. SCHULTZ: First of all, is they're
4 radial not axial.

5 MR. Y. KIM: This Yun Ho Kim.

6 Actually, the general oscillation temp
7 out, so you don't have to worry about general
8 oscillation.

9 MEMBER MARCH-LEUBA: You don't have
10 axial oscillations because of --

11 MR. Y. KIM: Yes, actually, in term of
12 radial oscillation, we have a monitoring part so
13 they can be monitored.

14 And, in terms of axial, usually, have
15 power. Usually, power creates a general oscillation
16 damper.

17 MEMBER MARCH-LEUBA: So, you have
18 performed some analysis that show that they damped
19 out?

20 MR. Y. KIM: Yes, right.

21 MEMBER MARCH-LEUBA: And, if you were
22 wrong and if it were to happen, the operator has
23 access to control rods and he will know how to
24 cancel them?

25 MR. Y. KIM: Yes, usually the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 inherently, they are general oscillation is at --
2 they're small, small, small.

3 CHAIRMAN BALLINGER: One last thing
4 about moderator temperature coefficient. Most of
5 the PLUS7 fuel has been used in OPR1000 reactor?

6 MR. DO: Yes.

7 CHAIRMAN BALLINGER: So, what's the
8 experience been in the OPR1000? Was that still --
9 it was a short period of time of burnup when you had
10 a positive moderator temperature coefficient and
11 that was handled easily? What's the experience been
12 in OPR1000?

13 MR. DO: It's a similar --

14 CHAIRMAN BALLINGER: But, there's been
15 no issue?

16 MR. DO: We set limiting conditions over
17 operation for MTC. MTC is efficient for limiting at
18 hot zero power.

19 CHAIRMAN BALLINGER: Okay.

20 MR. DO: And, that condition is used as
21 an input.

22 CHAIRMAN BALLINGER: Okay.

23 MR. DO: We don't have it.

24 MR. OH: This is Andy Oh, KHNP,
25 Washington Office.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 In addition to that, that is positive in
2 moderate temperature. It's only a fear in initial
3 core, not an equilibrium core.

4 CHAIRMAN BALLINGER: Okay, thank you.

5 MEMBER MARCH-LEUBA: Can you say that
6 again? You were blocked.

7 MR. OH: Yes, for that positive MTC is
8 only happen at initial core when it comes to
9 equilibrium core, there's no positive MTC fears
10 anymore.

11 MEMBER MARCH-LEUBA: Well, that's
12 relevant information that you should have provided.
13 So, that's very good. And, why is that? If
14 anything, the initial core will have more gadolinia.

15 MR. OH: Yes, the more gadolinia we used
16 in initial core, so as time goes, the gadolinia is
17 burnable poison it's burned up and then the soluble
18 poison is replaced the function of the burnable
19 poison.

20 That's the reason for the moderate
21 temperature coefficient has become slightly positive
22 in initial core. But after that, when it come to
23 the equilibrium core, we don't need to use much more
24 burnable poison or something. That only happens in
25 initial core.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: Let me just follow
2 up. In that initial core, do you have a problem
3 with shutdown margin? I mean, what you're telling
4 me is you have too much reactivity in the original
5 core that is compensated by soluble boron?

6 Are you having a shutdown problem? A
7 shutdown margin problem on the first core? Have you
8 calculated the shutdown margin for the initial core?

9 If you're telling me that the MTC is
10 probably positive on the initial core because the
11 core -- that core has too much reactivity. And, I'm
12 thinking, well, I need to shut it down, I need to
13 have sufficient shutdown margin.

14 I assume you've calculated the shutdown
15 margin for the initial core and it's okay.

16 MR. DO: It is okay. But, the MTC
17 appears relatively to shutdown margin because when
18 reactor temperature goes down because of MTC the
19 reactor can rise. So, the reactor MTC affects the
20 reactor for shutdown margin.

21 So, initial core shutdown margin is
22 okay.

23 MEMBER MARCH-LEUBA: It is okay?

24 MR. DO: There are no open items for
25 Section 4.3.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Thank you for your attention.

2 MR. SISK: I'm going to switch out
3 these. But, if there's any questions for 4.1, 4.2,
4 4.3, we're going to switch out for 4.4, 4.5 and 4.6.
5 It'll take just one minute.

6 MR. K. KIM: Okay, good morning. I am
7 Kanghoon Kim from KEPCO Nuclear Fuel and I will
8 present the DCD Section 4.4, Thermal Hydraulic
9 Design of the APR1400.

10 The design basis of the DCD Section 4.4
11 are based on TDC 10 and TDC 12. Those are during
12 the normal operations and AOOs, anticipated
13 operational occurrences, the hot fuel load in the
14 core will allow DNB.

15 It at least 95 probability at a 95
16 confidence level.

17 APR1400 special gadolinia limit is 1.29
18 with KCE-1 CHF correlation for PLUS7 closed design.

19 The temperature over uranium dioxide
20 pellets to assure that no melting occurs.

21 MEMBER POWERS: On the gadolinia
22 burnable poison rods, how does the melting
23 temperature on that change?

24 MR. K. KIM: It then maybe slighter
25 lower than uranium dioxide. I guess the melting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 temperature of the gadolinia pellets is
2 approximately 2500 degrees.

3 MR. SCHULTZ: And, what you've listed
4 here on the slide, just for clarity, is the -- it's
5 the whatever you want to call it, the maximum fuel
6 melting temperature for UO₂, it's going to degrade
7 with burnup over the course of the cycle.

8 So, and you've accounted for that in
9 your evaluation when you say the results are under
10 the melting temperature, you've accounted for the
11 degradation of melting temperature for burnup of the
12 UO₂ and for the addition of gadolinia, right?

13 MR. H. KIM: My name is Hung Jin Kim for
14 KEPCO NF.

15 Gadolinia melting temperature is
16 calculated from the UO₂ melting temperature minus
17 the gadolinia rate percent. The UO₂ melting
18 temperature is 5080 and then minus the 58 Fahrenheit
19 for 10 megawatt burnup and then minus the gadolinia
20 rate percent.

21 So, if we if -- so, gadolinia melting
22 temperature for gadolinia can be calculated from the
23 UO₂ melting temperature minus gadolinia rate
24 percent.

25 MR. K. KIM: Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And, to assure appropriate cooling for
2 APR1400, as its core is maintained greater than the
3 minimum and less than the maximum it is a 100
4 percent and 115 percent of the design.

5 And, instability in the core for in the
6 APR1400.

7 The typical for APR1400 from a hydraulic
8 and nominal conditions are given the table at the
9 lower part of this slide.

10 The main core of the APR1400 is the
11 coolant system depicted as the blue arrows on the
12 schematic diagram on the right side of the slide
13 enters into the -- with the pressure vessel through
14 the nozzles, pass through and 180 degree turns into
15 the lower core and assembly -- core fuel assembly
16 area and to the plates and the flow out to the
17 bottom nozzle.

18 Flow pushing on the flow which is not
19 effective for core cooling is up to 3 percent for
20 APR1400, depicted as a red small wave arrows in the
21 diagram.

22 MEMBER SKILLMAN: How is that 3 percent
23 confirmed?

24 MR. K. KIM: Just the calculation of a
25 flow network. It's up on the upper level pressure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 drop information to the core.

2 MEMBER CORRADINI: So, I was thinking
3 the same question. So, how is it confirmed? So,
4 that's what you calculate. Is there a way to back
5 calculate from measurements upon operation that
6 you're close to what you thought it was?

7 MR. JANG: My name is Ho Cheol Jang from
8 KEPCO E&C.

9 We calculate the core analytically any
10 without measurement. It cannot be measured in
11 tests, you only calculate it analytically.

12 MEMBER MARCH-LEUBA: So, do you have a
13 core exit thermal couples? Core exit temperature?

14 MR. JANG: Core exit temperature --

15 MEMBER MARCH-LEUBA: Inside the vessel.

16 MR. JANG: -- is 16150.

17 MEMBER MARCH-LEUBA: Right. No, what
18 I'm saying is you can do some calorimetric
19 calculation see what the flow is.

20 MR. JANG: Yes, yes.

21 MEMBER MARCH-LEUBA: And, it would be
22 wise to do it occasionally.

23 MEMBER CORRADINI: Well, but I guess my
24 question -- I'm assuming this fuel design is what's
25 at Shinkori. So, I'm curious, were any measurements

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 made at Shinkori to do a calorimetry measurement to
2 back estimate what the leakage was?

3 MEMBER MARCH-LEUBA: Yes, but it would
4 depend on what your temperature measurement is.

5 MEMBER CORRADINI: Sure, sure, but I'm
6 just curious.

7 CHAIRMAN BALLINGER: Yes, I'm going to
8 expose my ignorance, but, assuming that you could do
9 a calorimetric analysis, you could fix the flow,
10 measure the thermal output and there'll be an
11 imbalance and then adjust the flow to get the right
12 thermal balance. And, that is the sum relationship
13 to bypass flow. Right?

14 MEMBER CORRADINI: Right. That's what I
15 was thinking.

16 MEMBER MARCH-LEUBA: And, the active
17 core flow is about controls through DNBR and your
18 limits. So, if this 3 percent is never confirmed,
19 you have an uncertainty on your DNBR.

20 MR. JANG: Yes, the best estimate of
21 bypass flow rate is 2.4 percent. And, we add the
22 thermal to assure it's not go by this flow is below
23 the original barrier of 3 percent.

24 MEMBER MARCH-LEUBA: But, your
25 calculation says it's 2.4 percent?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. JANG: Yes.

2 MEMBER MARCH-LEUBA: I claim it's 6
3 percent and neither you nor I have any basis for it
4 because we haven't measured it.

5 MR. JANG: You say the 6 percent is your
6 calculation is that?

7 MEMBER MARCH-LEUBA: Yes, I'm just
8 making the number up. I'm saying, why is it not 6
9 percent? It begs for a measurement. I mean, that's
10 a very difficult calculation.

11 MR. KIRCHNER: If it were that large,
12 they wouldn't get the power out the --

13 MR. JANG: The core limit is different.

14 MEMBER MARCH-LEUBA: No, the flow is in
15 there. The flow -- the total flow, a 100 percent of
16 the flow goes out at hot layer. And the total power
17 goes out the hot layer. So, as far as the turbine
18 is concerned, you don't know how much it was.

19 MEMBER KIRCHNER: If it were very large,
20 they would have to increase the core thermal power
21 and you could detect that. But for a very large
22 bypass would require a significantly higher core
23 power output to get the rated power out of the
24 plant.

25 MEMBER MARCH-LEUBA: No, the same power

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 goes through the steam generator. All the power
2 goes through the steam generator.

3 CHAIRMAN BALLINGER: But, TH would go
4 up.

5 MEMBER MARCH-LEUBA: Your flow would be
6 you'll be burning your fuel.

7 MEMBER SKILLMAN: That's what I'm
8 saying, you'd have to raise the flow.

9 MEMBER MARCH-LEUBA: No.

10 MEMBER SKILLMAN: I asked that question
11 from a background of knowing the importance of the
12 vessel model flow test. The flow rate through that
13 gap at the hot leg is based on the manufacturing
14 tolerance of the idea of the reactor vessel outlet
15 vessel in the OD final machine diameter of the core
16 support structure. One grows into the other at the
17 plant heat.

18 And, if either of those dimensions is
19 off by more than a fraction of a millimeter, that
20 bypass flow will be different than what you assume.
21 That is a manufacturing issue.

22 But, I think that the answer is you
23 assume 2.4, you add .6 for 3, but you are really
24 depending on your manufacturing tolerances of the
25 reactor vessel final machining and the internals

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 final machining to assure that the growth closes
2 that gap. Is that accurate?

3 MR. SISK: This Rob Sisk, Westinghouse.

4 I appreciate the discussion, the
5 dialogue and would like to discuss it further, but I
6 think we need to have our team get together and get
7 the --

8 MEMBER SKILLMAN: I think so. And --

9 MR. SISK: I don't think we're prepared
10 to address this in detail --

11 MEMBER SKILLMAN: And, I would like --

12 MR. SISK: -- at this time.

13 MEMBER SKILLMAN: I would like to offer
14 one more comment on the bypass flow.

15 That bypass flow may be accurate for
16 four pump operation 100 percent power, four pump
17 operation, 100 percent power.

18 But, your tech specs allow you six
19 hours, six hours with an off normal condition where
20 you can have less than two pumps per loop.

21 And, under those circumstances, the
22 tabular data from your prior slide may need
23 adjustment. If you run for three pumps, you will
24 find that you will have flow direction different
25 than four pumps forward.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And, so, I don't believe that's
2 reflected in your analyses. So, I'm curious how you
3 will be communicating this information if you have
4 less than four pumps. You are permitted to run for
5 six hours with less than four pumps forward.

6 That's your tech spec 3.4.

7 MR. SISK: Again, appreciate the
8 description, good discussion in general. I think we
9 need to get the team, we have several groups of
10 experts that have to get together and prepare --
11 talk it through to see how it was addressed. I
12 don't think we're in a position to do that at this
13 time.

14 MEMBER SKILLMAN: Thank you, Rob.

15 MR. K. KIM: One thing for the APR1400,
16 initial flow rate less bypass flow.

17 The design basis limit on DNBR and fuel
18 temperatures are maintained by ACO in the technical
19 specification for the most limiting AOO.

20 Uncertainties for the DNBR calculations
21 are in input to a period the core and to the motor
22 which power distribution and positive relations and
23 so on. And, TORC model and CHF correlation.

24 KCE-1 CHF correlation was used with TORC
25 and CETOP codes to calculate the DNBR for normal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operation and AOOs. This correlation was developed
2 based on the PLUS7 CHF test data.

3 ACRS reviews the KCE-1 topical reports
4 on December 14th, 2015, last year.

5 MEMBER REMPE: So, this --

6 MEMBER MARCH-LEUBA: Okay, you go ahead.

7 MEMBER REMPE: A couple of things I
8 have.

9 First of all, this happens often with
10 the staff and there's usually one ACRS member who
11 points out that you attended a subcommittee meeting
12 on December 14th, not a full ACRS meeting. And,
13 it's very important to distinguish that you only had
14 the ACRS subcommittee review the topical report on
15 December 14th. We will be discussing it tomorrow.
16 And, so, it's good to clarify that.

17 But, during that discussion, we also,
18 when we reviewed the CHF correlation, we talked
19 about the CETOP-D code, not the CETOP code.

20 And, as I recall, there was a lot of
21 discussion in the write up on the CHF documentation
22 about that the staff had been concerned about TORC-C
23 and CETOP-D not providing the same results.

24 And, as I recall, KHNP said we were
25 going to come back and show that it was conservative

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and that they would give similar results. But, in
2 the documentation for Chapter 4, it just said, hey,
3 CETOP and TORC give the same results, just a simpler
4 model and there was no issue.

5 So, could you explain what the
6 differences between CETOP-D versus CETOP and why D-
7 TOP is fine?

8 MR. YOON: I am Taae Young Yoon from
9 KEPCO Nuclear Fuel. Actually, the core in this
10 picture, the CETOP-D core is used to record the
11 CETOP-1 and the CETOP-2. It's just two reduce the
12 calculated time or very toward simplified CETOP
13 code.

14 MEMBER MARCH-LEUBA: From the review of
15 this KCE correlation, the CHF correlation in the
16 subcommittee, it was our understanding that the
17 staff SER will impose a restriction that KCE cannot
18 be used with any CETOP version. It's not approved
19 for use.

20 And, therefore, if that restriction on
21 the SER is maintained, which I believe it is so far,
22 as far as I know, we cannot see any CETOP results
23 that use the KCE correlation for our review of
24 Chapter 4 because it's not allowed, it's not
25 approved.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Is that correct? I mean, is that my
2 understanding that the KCE correlation is not
3 approved for use with the CETOP code?

4 MEMBER CORRADINI: Are you asking the
5 staff or them?

6 MEMBER MARCH-LEUBA: I'm asking them,
7 they're looking for it.

8 MEMBER REMPE: Again, I just am puzzled
9 and maybe it is more appropriate for the staff, but
10 I was expecting KHNP to come back with -- again,
11 this is based on the transcript. But, basically,
12 there was a gentleman that had been part of the
13 testing program, and I would almost would have
14 guessed, if my memory's correct, he's from
15 Westinghouse, and he said we're going to be dealing
16 with that later in Chapter 4.

17 And, so, I, again, okay, so you are the
18 person and did I misunderstand you?

19 MR. SUNG: Yixing Sung from
20 Westinghouse.

21 Okay, let me just explain the difference
22 in the code.

23 MEMBER REMPE: Speak very close to the
24 microphone, because I must be hard of hearing.

25 MR. SUNG: Again, Yixing Sung from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Westinghouse.

2 So, let me just explain the code. The
3 code, the base code, the codes are TORC codes.

4 MEMBER REMPE: Right.

5 MR. SUNG: And, TORC codes, that's
6 reviewed by the staff was the KCE-1 DNB correlation.
7 And, that's the topical report addressed for.

8 And, when you look at the CETOP, CETOP
9 is really the simplified code based on the TORC
10 code. Okay, now there are different versions.
11 There's a CETOP-1, CETOP-2, that's actually a
12 program protective system.

13 And, CETOP-D is the one they use for
14 analysis. All the CETOP codes have the benchmark
15 with the TORC code which is the base code with the
16 correlation license.

17 But, what the benchmark process are, the
18 calibration processes show all these simplified
19 codes provides a conservative result as compared to
20 the approved version of TORC code.

21 MEMBER REMPE: So, the KHNP Westinghouse
22 position is that CETOP is just fine to use with the
23 correlation and whatever the staff imposed in the
24 restriction, we'll talk to the staff about.

25 But, out of curiosity, you mentioned

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CETOP-1 and 2, but you didn't mention CETOP-D.

2 MR. SUNG: I mentioned D as for the
3 analysis.

4 MEMBER REMPE: Okay.

5 MR. SUNG: When you do the analysis
6 calculation offline, you use the CETOP-D.

7 MEMBER REMPE: Okay.

8 MR. SUNG: But, online, you use CETOP-1
9 and CETOP-2.

10 MEMBER REMPE: Okay. That helps me at
11 least understand the differences because I was
12 puzzled. So, thank you.

13 MEMBER MARCH-LEUBA: But, from the
14 administrative point of view, if the staff's SER
15 restriction that thou shall not use KCE-1 with CETOP
16 will cause a serious problem to this review,
17 wouldn't it?

18 MR. SUNG: I'm not sure of the SER
19 condition. I would assume the condition would be --

20 MEMBER MARCH-LEUBA: It's in there.

21 MR. SUNG: -- the CETOP-1 or CETOP used
22 with KCE-1 has to be benchmarked with a TORC which
23 is the approved by the staff.

24 MEMBER MARCH-LEUBA: But, it hasn't been
25 approved. As far as December 14, was it, they told

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 us it has not -- it was going to be a limitation on
2 the SER.

3 So, I mean, administratively, I will
4 need to ask you which of these conclusions that
5 you're telling me are Chapter 4 are based on
6 unapproved code, on the use of a code that has not
7 been approved.

8 MEMBER KIRCHNER: So, in the thermal
9 design methodology report, and I'll just use the
10 abstract, it makes the statement that the
11 application of the KCE-1 CHF correlation with TORC
12 and CETOP codes is in full compliance with the
13 conditions of the SER on the codes and modeling.

14 MEMBER MARCH-LEUBA: That's not --

15 MEMBER KIRCHNER: So, I think we have to
16 ask the staff then to clarify.

17 MEMBER REMPE: Absolutely.

18 MEMBER MARCH-LEUBA: We have asked the
19 staff very clearly during the review of the CHF
20 correlation on December 14th, and they told us that
21 it was not provided for CETOP and, therefore, we
22 cannot approve it. But, we'll follow up this,
23 right?

24 MS. KARAS: This is Becky Karas.

25 So, I understand you'll ask the staff,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 but just because I need to bring them the person who
2 did the topical report review for CHF because they
3 are coming tomorrow with that topic report to the
4 subcommittee. But, we expect to ask that this
5 afternoon. I'll make sure they're available as
6 well.

7 MEMBER REMPE: Please do.

8 MR. K. KIM: For appropriate the core
9 summary response, cause and the protection system
10 provide reasonable assurance that the design based
11 are not violate for any normal operating condition
12 and AOOs.

13 As the analytical method applied to
14 APR1400, flow rate is based on the RPS flow
15 resistance and RCP performance of the APR1400.

16 The thermal margin analysis were
17 performed by TORC and CETOP codes and since the
18 combination of uncertainty methodology previously
19 opposed by NRC to apply to the thermal analysis.

20 MEMBER SKILLMAN: Would you describe how
21 you determined the system flow resistance?

22 MR. JANG: My name is Ho Cheol Jung from
23 KEPCO.

24 Your question is determining the system
25 flow?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: No, system flow
2 resistance.

3 MR. JANG: The flow resistance is the
4 estimate from the RSS flow model test for APR1400.
5 We have tested that from the AT flow test and we
6 measured the system from this test and we use the
7 measured data for the determination of APR1400.

8 MEMBER SKILLMAN: Thank you.

9 MEMBER CORRADINI: So, just to follow
10 on. So, what was the name of the facility you used
11 to measure? I didn't understand.

12 MR. K. KIM: You say the test was the
13 flow model test for APR1400?

14 MEMBER CORRADINI: Yes. I didn't
15 understand, what was the facility? What's the name?

16 MR. JANG: The test facility, we don't
17 have the test facility name, but at the design page
18 we made a flow test from the model of a system data.

19 MEMBER CORRADINI: Okay. So, then that
20 was going to lead me to another question which is,
21 since this is a design that's already running in
22 Korea, have you done any measurements either under
23 cold conditions or startup conditions where you
24 actually can verify some of these things?

25 You have a unique advantage of you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 actually have something that runs. So, I'm curious,
2 have you made any measurements so that you can
3 actually verify the flow resistance or at least
4 pieces of the flow resistance?

5 MEMBER MARCH-LEUBA: And, from the
6 philosophical point of view, you operate this plant
7 with so much margin into burnup that, if you were
8 wrong by a factor of two on the bypass flow, you
9 would never have a fuel damage because you have so much
10 margin and you never see the worst AOO.

11 Just the fact that the Shinkori plant
12 runs perfectly okay, doesn't mean that you --
13 everything is okay. I mean, it begs for a
14 confirmatory calculation with something because it's
15 an important parameter.

16 If your flow is off by --

17 MR. SISK: Again, Rob Sisk here.

18 I appreciate the discussion. It's an
19 interesting question and we'll need to pursue that
20 with the group as a whole.

21 MEMBER CORRADINI: I mean I look upon it
22 purely academically. You have a full scale
23 experiment. I'm very curious what it tells you.

24 MR. SISK: I'll have to go back and see
25 what all's available.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Okay.

2 MR. SISK: I appreciate the discussion,
3 but again, we're not prepared to do that.

4 MEMBER REMPE: So, could I beat a dead
5 horse to death and go back to the staff's draft SCE
6 on the topical report on the KCE-1 correlation?

7 It has that there's an RAI and it's
8 updated response to RAI 37443, question 16, the
9 applicant agreed to delete all references to CETOP-D
10 from the technical report and limit the application
11 of KCE-1 CHF correlation to TORC.

12 So, when I was reviewing Chapter 4, I
13 was puzzled why suddenly it seemed like it was okay
14 to use CETOP? And, that's where I'm coming from.

15 And, again, I'm quoting what the staff
16 wrote about the RAI response. But, that was our
17 understanding. And, the reason I'm beating the dead
18 horse to death is that we've got a letter we're
19 going to have to issue tomorrow or discuss tomorrow
20 about the CHF correlation.

21 MR. OH: This is Andy Oh, KHNP.

22 Member Rempe, do you expect to answer
23 this question to applicant or us the staff?

24 MEMBER REMPE: Well, I will be asking
25 the staff, but it would be good, again, to really

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 understand KHNP's position is, yes, it's fine to use
2 CETOP because, again, it could wait until tomorrow,
3 but it would really be good to understand that
4 because I'm seeing -- we're seeing a difference
5 between what is in the topical report versus what's
6 here in Chapter 4.

7 And, because we have to discuss that
8 this week and write a letter, it'd be good to know
9 what the story is. Okay?

10 MR. SUNG: This is Yixing Sung,
11 Westinghouse.

12 Okay, this is no different from the
13 traditional plant analysis. When you look at the
14 base code or baseline for licensing, and this is the
15 TORC code.

16 But, in the design calculation, from
17 time to time we use the simplified code to do the
18 calculation. But, it's up to the designer to verify
19 the simplified code used in true compliance with the
20 approved version of the code.

21 In this case, the TORC has to be
22 compared with the approved TORC -- I'm sorry, CETOP
23 has to be compared to the TORC approved version with
24 KCE-1 to demonstrate its use is conservative.

25 But, it does not change what the staff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 approved the position of the limits. It just had to
2 be confirmed in the application.

3 MEMBER REMPE: And, I guess I was hoping
4 to see that confirmation in Chapter 4 because the
5 staff expressed concerns about the numerical schemes
6 why that they had said use only TORC.

7 And, I guess, again, we'll talk to the
8 staff, too. But, I guess, that they had a reason
9 for saying don't use anything but TORC and I'm not
10 sure I understand why that reason has gone away.

11 MEMBER MARCH-LEUBA: Yes, and keep in
12 mind when you're doing that whatever you're doing
13 that often we use or you use CETOP, the fast running
14 code, to run all of the power distributions over the
15 core.

16 You have the whole depletion and you ran
17 all 1000 of them with CETOP and then confirmed the
18 bad ones with TORC. But, that, if CETOP was not
19 approved, how do you know that that was the bad one?

20 And, I'm not asking for an answer, but
21 keep that in mind when we're addressing the whole
22 thing because the separation is not a clean as you
23 made it look like.

24 CHAIRMAN BALLINGER: Continue.

25 MR. K. KIM: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 There are five total RAI questions in
2 Section 4.4. Among eight, two open items are
3 identified based on the corresponding response to
4 RAI questions.

5 The response to corresponding questions
6 were submitted in the middle of last year and then
7 most things.

8 This is the end of our presentation for
9 Section 4.4. Thank you.

10 MEMBER MARCH-LEUBA: I'm sorry, I guess
11 I wasn't paying attention. That second bullet that
12 the mixed cores DCD, can you talk a little bit about
13 that? How do you handle -- I mean, I know you want
14 150 percent expect to use only PLUS7 but have you
15 addressed the issue of having more than one fuel
16 element type in the core how that would be
17 calculated?

18 MR. K. KIM: We usually have -- it
19 depends on the functional approved design activities
20 which nuclear design that they have. And, some have
21 a design and something like that.

22 But start -- at the starting point of
23 the design, we simulate the difference in geometry
24 between the one type of fuel assembly into the high
25 load fuel assembly by TORC. Okay?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Then there is just some of possible some
2 whatever process solution by calculated by TORC then
3 it can be applied to predict with appropriate
4 correlation for each type of fuel geometry.

5 Inherently, reflect the effect as result
6 of loading pattern for missed core.

7 MEMBER MARCH-LEUBA: Okay, so --

8 MR. K. KIM: We just use only limiting
9 one, we apply to one of a more limiting one than
10 others.

11 MEMBER MARCH-LEUBA: Okay. So, you have
12 a methodology to handle mixed core calculations?

13 MR. K. KIM: Yes.

14 MEMBER MARCH-LEUBA: And, that has been
15 looked at by the staff and -- or you just think it's
16 good?

17 MR. Y. KIM: This is Yun Ho Kim from
18 KHNP.

19 Actually, we have a history of
20 developing different type of fuel. We use all, and
21 as we develop PLUS7 and all in the transient time,
22 we need that kind of formulation.

23 But, for APR1400 design, we only use
24 PLUS 7 fuel type. So, this mixed fuel do not apply
25 to our APR1400.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: So, it wouldn't
2 apply to the DCD review? The DCD is only approved
3 for PLUS7?

4 MR. Y. KIM: PLUS7 only.

5 MEMBER MARCH-LEUBA: Okay.

6 MEMBER SKILLMAN: Jose, that item is
7 open item OI 4.4-1 for mixed cores in the SER on
8 page 4.42 of the SER.

9 CHAIRMAN BALLINGER: Okay. I think this
10 is a convenient -- this next section is on
11 materials. But, I think this is a good time for a
12 break. So, let's break until -- well, we're
13 actually, by my reckoning, way ahead, so, let's take
14 a break until 15 minutes after 10:00.

15 (Whereupon, the above-entitled matter
16 went off the record at 9:57 a.m. and resumed at
17 10:15 a.m.)

18 CHAIRMAN BALLINGER: Okay. We're back
19 in session. Amongst the many side conversations
20 that happened during the break, we've had
21 discussions related to the CHF --

22 PARTICIPANT: Your mic?

23 CHAIRMAN BALLINGER: We have had
24 discussions related to the disposition of the use of
25 the CHF correlation. Maybe that is the best way to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 put it. And so I think before we get started here,
2 I am not sure who should lead the discussion -- the
3 staff? -- on that issue, and so can we have whoever
4 is ready to go on this discussion?

5 MR. HAIDER: Yes. This is Syed Haider.
6 I am the technical reviewer of the KCE-1 CHF
7 correlation topical report, and I would like to
8 bring some clarification. I was just called by my
9 branch chief, and even though I am supposed to make
10 the presentation tomorrow, but I think I would like
11 to address this issue today.

12 The staff had approved the application
13 of the KCE-1 CHF correlation with TORC code
14 contingent upon the DNBR limit of 1.124. So
15 essentially, this was the objective of establishing
16 the baseline number with the application of the TORC
17 code. So if the applicant wanted to modify the
18 1.124 limit, then they would have to stick to TORC
19 code. But however, for the plant safety analysis,
20 if they could demonstrate that the application of
21 CETOP had provided enough margin, and it was more
22 conservative compared to applying the KCE-1
23 correlation with TORC code, then this should be
24 acceptable to the staff.

25 MEMBER REMPE: You go first, since you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 went -- well, okay. So could you clarify a little
2 bit more, because perhaps it is in the documentation
3 either submitted by the applicant, or it's in the
4 draft SC, but where did they clearly state that they
5 have used this factor of was it 1.14 you mentioned?

6 MR. HAIDER: 1.124.

7 MEMBER REMPE: 124, okay.

8 MR. HAIDER: Yes.

9 MEMBER REMPE: Where is it stated?
10 Where can Jose and I find it so we comfortable from
11 --

12 MR. HAIDER: This is in the --

13 (Simultaneous speaking.)

14 MEMBER REMPE: -- I like to see with my
15 eyes.

16 MR. HAIDER: This is in the SER, in the
17 safety evaluation report --

18 MEMBER REMPE: Okay.

19 MR. HAIDER: -- for the topical report.

20 MEMBER REMPE: Okay. And it says hey,
21 they used this value of 1.124 --

22 MR. HAIDER: 124, yes.

23 MEMBER REMPE: -- and therefore it is
24 okay to use CETOP?

25 MR. HAIDER: No, no, that is not what we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are saying in the SER. In the SER, we are saying
2 that the -- that the use of the KCE-1 correlation is
3 approved with TORC code with the DNBR limit of
4 1.124. That is what we are documenting in the SER.
5 But if in the DCD part, if they do demonstrate that
6 the application of the correlation with CETOP had
7 additional margin, and it was more conservative,
8 then this should be acceptable to the staff.

9 MEMBER MARCH-LEUBA: Yes, but let me
10 before -- shall I start? Let me read you what the
11 SER says on page 12, Section 4.6. "The staff
12 include a limitation on Section 5.0 of the safety
13 evaluation to clarify that the use of the KCE-1
14 correlation with any other subchannel" -- by that it
15 means other than torque -- "would require additional
16 review by the NRC."

17 MR. HAIDER: Yes. That is the staff
18 understanding that -- that the additional review
19 will be conducted in the DCD part, and that --

20 MEMBER MARCH-LEUBA: Okay. So --

21 MR. HAIDER: -- it was conducted.

22 MEMBER MARCH-LEUBA: -- so the question
23 to the rest of the staff, which is reviewed in
24 Section 4, is -- has this review been performed for
25 CETOP and KCE-1?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. LU: The answer is yes. It has been
2 done, and as part of the audit and inspection for
3 Chapter 4, we did check that the multiplier --
4 addition of multiplier demonstrated the code, when
5 it -- really referencing this KCE-1 correlation,
6 they do have additional margin there. So in terms
7 of safety analysis, they can use other codes
8 referencing this one as long as they have additional
9 margin. That is the part that has been
10 demonstrated, that multiplier, and they did not
11 document any of the DCD because that is really just
12 too much detail, and in the audit, as part of the
13 audit, we checked that multiplier.

14 MEMBER REMPE: So --

15 MEMBER MARCH-LEUBA: Okay.

16 MEMBER REMPE: -- is there a document,
17 again, that the staff has that they can show us that
18 says hey, we did check this multiplier, and it would
19 have been nice to even go further and say so it's
20 okay to use CETOP.

21 MR. LU: Okay. Yes, we were -- we are
22 going to dig into that audit report. We will find
23 out --

24 MEMBER REMPE: Okay.

25 MR. LU: -- with the letter about a year

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ago.

2 MEMBER REMPE: Okay.

3 MR. LU: Okay.

4 MEMBER REMPE: Because it didn't come up
5 in the discussions on the CHF --

6 MR. LU: Yes, that is --

7 MEMBER REMPE: -- correlation.

8 MR. LU: -- a nice question because --

9 MEMBER REMPE: Yes.

10 MR. LU: -- logically, so you have -- we
11 imposed a limitation in the topical report. The
12 purpose and the intention there is you want to
13 change, 1.124, the number, that really came out from
14 their test data, and then it came from that
15 particular computer code to -- to process those test
16 data. That is where 1.124 came from.

17 However, if other codes in the safety
18 analysis, that is what the -- you know, Dr. Haider
19 had mentioned that if any other code was used in
20 other application or other part of safety analysis,
21 staff needs to review that. That is true, and that
22 is what we did.

23 MEMBER REMPE: Okay. Thank you.

24 PARTICIPANT: Can you state your name
25 one more time for the record?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. LU: Oh, Shanlai Lu from staff.

2 CHAIRMAN BALLINGER: Okay. Shall we
3 pick up where we left off?

4 MR. SISK: We're done with CHF? I
5 didn't know what we --

6 CHAIRMAN BALLINGER: I think we are.

7 MR. SISK: Okay.

8 MEMBER REMPE: But thank you.

9 CHAIRMAN BALLINGER: Far be it from me
10 to even think about this.

11 MR. SISK: Then we will move to 4.5.

12 MR. J. KIM: Good morning, ladies and
13 gentlemen. My name is Jong Soo Kim in KEPCO-E&C. I
14 will briefly introduce on reactor materials. This
15 section refers to materials used in control element
16 ride mechanism and both the internal and core
17 support.

18 And this picture shows CEDM assembly and
19 the vessel internals and core support. The main
20 function of the CEDM is to control the reactivity by
21 moving control element assembly. The pressure
22 boundary of the CEDM consists of the -- the motor
23 housing and upper pressure housing, and bent stem,
24 and a housing rod. The main -- main function of the
25 internal and core support is to support the fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assembly and maintain fuel -- fluid pass in that
2 vessel. The vessel internal and core supports are
3 in accordance with ASME Code NG.

4 The reactor coolant pressure boundary
5 materials in CEDM: the materials for C -- RCPB in
6 both housing assembly and upper pressure housing
7 assembly are Martensitic stainless steel, Austenitic
8 stainless steels, and nickel-base alloys. They
9 comply with ASME Sections III, II, IX and Reg Guide
10 1.84.

11 The reactor coolant contact materials in
12 CEDM are in the material of internal components of
13 the CEDM, that is motor assembly and extension shaft
14 assembly, and they are all corrosion resistance.
15 That means they are Austenitic stainless steels and
16 Martensitic stainless steels, nickel-base alloys, or
17 cobalt alloys.

18 And weld materials in CEDM, they are
19 also corrosion resistant. They are Austenitic
20 stainless steels and alloy 690 equivalent weld
21 metals.

22 The materials used in CEDMs are
23 essentially identical to those of the operating
24 plants in U.S. and Korea and show good performances
25 and have been tested for lifetime requirements.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BALLINGER: Now, does that --
2 does that include the use of cobalt-base alloys?
3 When you say essentially identical to Palo Verde and
4 12 operating plants, I will take your word for it
5 that they also use cobalt-base alloys?

6 MR. J. KIM: Yes, they do.

7 CHAIRMAN BALLINGER: It's like 6(b) or
8 something? I think I remember.

9 MR. J. KIM: Yes, yes, yes.

10 CHAIRMAN BALLINGER: And that experience
11 has been okay, and it hasn't resulted in issues
12 related to radioactivity in the coolant and things
13 like that?

14 MR. J. KIM: Yes. They included cobalt-
15 based alloys. So far, we don't have any material
16 problems in the CEDMs in Korea, no.

17 CHAIRMAN BALLINGER: Okay. Thank you.

18 MR. J. KIM: And various provisions of
19 materials and verification processes are applied on
20 Austenitic stainless steels of CEDMs, and basically,
21 requirements for RCPB materials of DCD Section
22 5.2.3.4 are also applied for CEDM Austenitic
23 stainless steels.

24 And venting of CEDM will be applied for degassing
25 before the plant starts.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And other materials of the nickel-base
2 alloys, cobalt alloys, and Martensitic stainless
3 steels are used for intended special purposes for
4 springs, grippers, latches and links, and inserts
5 and tabs and balls. And those materials have been
6 used with satisfactory performance in plant
7 operations.

8 Reactor internals and core support
9 materials: internals and core support materials
10 comply with ASME Code Section NG and Reg Guide 1.84.
11 They are primarily Type 304 Austenitic stainless
12 steels. Fasteners are typically Type 316 Austenitic
13 stainless steels, and hardfacing wear areas and
14 controls on cold-worked Austenitic stainless steels
15 are also applied. The material used in reactor
16 internals and core support are proven materials and
17 showed good performance in plant experience. And
18 material specifications, for core support barrels,
19 upper guide assembly, core shroud assembly are
20 mainly Austenitic stainless steels.

21 MEMBER RICCARDELLA: Excuse me. The
22 baffle-former assembly is welded, I believe? You
23 don't have baffle-former bolts?

24 MR. J. KIM: Yes, welded.

25 MEMBER RICCARDELLA: Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. J. KIM: Bolt -- bolt and pin
2 materials are Austenitic stainless steels. Chrome
3 plating and cobalt hardfacing materials are also
4 applied, and type 308L Austenitic stainless steel
5 reactor material is also used for welding. And the
6 welding and nondestructive examination comply with
7 ASME Section III, NG-4000, and NG-5000,
8 respectively.

9 The requirements for the RCPB materials
10 of DCD Section 5.2.3.4 and Reg Guide 1.44 are
11 applied on Austenitic stainless steels of reactor
12 internals and core supports in order to avoid
13 sensitization, and other materials of Austenitic
14 stainless steels and Martensitic stainless steels
15 are used for intended purpose of alignment keys,
16 pins, and HJTC tube and hold-down rings, and these
17 other materials showed good satisfactory performance
18 in plant experiences.

19 The challenging degradation for reactor
20 internals and core support materials are
21 irradiation-assisted stress corrosion cracking and
22 void swelling. The assessment -- assessment for APR
23 1400 reactor internals and core support materials
24 are performed -- was performed using EPRI
25 methodologies, and the result was acceptable.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Open items: there were 23 RAIs for this
2 section. Two RAIs are -- remain as open items.
3 They are about Versa Vent system of CEDM. KHNP was
4 questioned that the Versa Vent should be regarded as
5 a pressure boundary item. This is number 15. And
6 it was also requested to provide data or operational
7 experience that demonstrates the Versa Vent can work
8 in -- in practice -- in practice to eliminate the
9 air of the CEDM. This was 16. And the responses of
10 these open items were submitted.

11 This is --

12 CHAIRMAN BALLINGER: I have a question
13 about the Versa Vent. Am I to understand that these
14 Versa Vents are also used for example at Palo Verde
15 and other places?

16 MR. J. KIM: It was used, but for now,
17 the Palo Verde does not use any more when they
18 change it. They -- or the Versa had.

19 CHAIRMAN BALLINGER: Okay. Thank you.

20 MR. J. KIM: And this -- yes. This is
21 all for Section 4.5. Thank you for your attention.

22 MR. SCHULTZ: Thank you. Before we go
23 to the next section, leave reactor materials, could
24 you go back one slide? Just a general question I
25 have: as you have applied the EPRI-developed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 software for the assessment of the reactor vessel
2 internals, what does that mean? In the application,
3 or the application of that software, is it a best
4 estimate evaluation, or are there conservatisms in
5 the input data that one uses to provide assurance
6 that the performance is going to be satisfactory?
7 How is that evaluation done? Can you provide some
8 additional detail on that?

9 MR. J. KIM: Yes. The additional detail
10 was in the report.

11 MR. SCHULTZ: Yes.

12 MR. J. KIM: Yes yes --

13 MR. SCHULTZ: I haven't seen --

14 MR. J. KIM: -- yes yes --

15 MR. SCHULTZ: -- the report yet --

16 MR. J. KIM: -- yes --

17 MR. SCHULTZ: -- but --

18 MR. J. KIM: -- and we -- we referenced
19 the methodology and the EPRI-developed software used
20 in that, yes, used in that, that was developed by
21 the EPRI and -- EPRI.

22 MR. SCHULTZ: Yes. And do you
23 demonstrate that the assessment results are
24 acceptable by doing what you would call a bounding
25 analysis or conservative, or do you do a best

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 estimate evaluation of the performance over a
2 certain period of time and then say, oh, it came out
3 okay?

4 MR. J. KIM: Yes.

5 MR. SCHULTZ: Can you --

6 MR. J. KIM: Yes.

7 MR. SCHULTZ: -- elaborate there?

8 MR. J. KIM: -- actually, there was the
9 recommended acceptance criteria in the EPRI
10 guidelines there.

11 MR. SCHULTZ: The acceptance criteria on
12 the --

13 MR. J. KIM: Yes --

14 MR. SCHULTZ: -- result?

15 MR. J. KIM: -- yes, yes, that was --

16 MR. SCHULTZ: And does it specify how to
17 determine how one does the evaluation in terms of
18 input parameters?

19 MR. J. KIM: Yes. For example the --
20 the -- irradiation-assisted stress corrosion
21 cracking, there -- they provide the susceptible
22 stress.

23 MR. SCHULTZ: Okay.

24 MR. J. KIM: Yes, and they provide the
25 ratio, yes, provide some reference stress, and --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and if you are below those stress, and we -- we are
2 -- think it is acceptable. And -- and for the --
3 the void swelling, yes, they also provide some
4 acceptance criteria, volumetric 2.5 percent, 2.5 --

5 MR. SCHULTZ: Do you --

6 MR. J. KIM: -- yes.

7 MR. SCHULTZ: Yes. Do you compare your
8 results here with what has been done for other CE-
9 type plants that -- is there some sort of database
10 or results evaluation that has been done for other
11 similar plants --

12 MR. J. KIM: I --

13 MR. SCHULTZ: -- that is used for
14 comparisons, or is it just one evaluation for the
15 APR1400 that you have done --

16 MR. J. KIM: Yes, actually, we did just
17 follow one evaluation for the APR1400. This is
18 first time in Korea for --

19 MR. SCHULTZ: First time for you to --

20 MR. J. KIM: Yeah yeah yeah --

21 MR. SCHULTZ: -- use this?

22 MR. J. KIM: -- yeah, for this kind of
23 analysis.

24 MR. SCHULTZ: Yes. Did you have any
25 support from EPRI in reviewing the results to get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some assurance that the results that you have
2 developed is typical --

3 MR. J. KIM: We --

4 MR. SCHULTZ: -- of what they, the
5 developers of the tool, would have expected?

6 MR. J. KIM: Yes. We also contact with
7 EPRI because we need the -- the software.

8 MR. SCHULTZ: Yes.

9 MR. J. KIM: Yes, so that we contact
10 with EPRI people, yes, with -- with this work. But
11 they just provide the -- it is for free, yes, they
12 provide for anyone because we are EPRI members.

13 MR. SCHULTZ: Yes.

14 MR. J. KIM: Yes.

15 MR. SCHULTZ: But did you have any EPRI
16 staff or consultants review what you had done with
17 the tool?

18 MR. J. KIM: With -- with the -- with --
19 to -- we did not consult with the result, yeah. But
20 that they provide the detailed methodology and those
21 -- and their detailed procedures, yes.

22 MR. SCHULTZ: Okay. Okay.

23 CHAIRMAN BALLINGER: But --

24 MR. SCHULTZ: That is --

25 CHAIRMAN BALLINGER: -- you --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCHULTZ: -- helpful.

2 CHAIRMAN BALLINGER: -- also had access
3 to all of -- because you're EPRI members, you have
4 access to all of the -- the MRP, the Materials
5 Reliability Program data and all the reports and
6 everything to -- to augment what -- what they are --
7 what you are doing, is that correct?

8 MR. J. KIM: Yes. We can -- we did
9 contact with EPRI when we need some help or
10 documents or -- or we -- if we have some when we
11 feel some need for discussion, yes, yes we did.

12 MR. SCHULTZ: So in summary, you are
13 satisfied with the results that you achieved from
14 applying this methodology because, as you say in the
15 first bullet --

16 MR. J. KIM: Yes.

17 MR. SCHULTZ: -- this is a very
18 challenging area --

19 MR. J. KIM: Yes.

20 MR. SCHULTZ: -- and it is something
21 that you want to be able to demonstrate that you
22 have in terms of your material selection and the
23 parameters that are influencing factors in this --

24 MR. J. KIM: Yes.

25 MR. SCHULTZ: -- in this area --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. J. KIM: Yes.

2 MR. SCHULTZ: -- that you have got it
3 covered.

4 MR. J. KIM: Okay.

5 MR. SCHULTZ: You are not going to
6 experience failure due to the mechanism?

7 MR. J. KIM: Yes.

8 MR. SCHULTZ: Good. Oh, I will look
9 forward to reviewing the report. Thank you.

10 MR. J. KIM: Okay, thank you.

11 CHAIRMAN BALLINGER: In addition, are
12 these materials similar to materials that have been
13 used in the OPR1000?

14 MR. J. KIM: For the analysis?

15 CHAIRMAN BALLINGER: No, just in
16 practice.

17 MR. J. KIM: Materials, yes, yes, yeah,
18 yeah, identical, yes. Some -- I mean, there are
19 some weld materials, for example, alloy 600 to the
20 690 --

21 CHAIRMAN BALLINGER: Wise move.

22 MR. J. KIM: Yeah, yeah, yeah, yeah,
23 yeah.

24 CHAIRMAN BALLINGER: Very wise move.

25 MR. J. KIM: Yeah.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BALLINGER: Okay. Okay. So
2 but the experience has been good in OPR1000 for
3 materials that you are now using in APR1400?

4 MR. J. KIM: Yes, yes, that is correct.

5 CHAIRMAN BALLINGER: Because there is a
6 long history there.

7 MR. J. KIM: Yes.

8 CHAIRMAN BALLINGER: Okay. Thank --

9 MEMBER SKILLMAN: Jong --

10 CHAIRMAN BALLINGER: -- you.

11 MEMBER SKILLMAN: -- Jong Soo, let me
12 ask this --

13 MR. J. KIM: Yes.

14 MEMBER SKILLMAN: -- question: Dr.
15 Riccardella asked whether or not the baffles are
16 welded or bolted, and you responded that they are
17 welded.

18 MR. J. KIM: Yes.

19 MEMBER SKILLMAN: So there are no baffle
20 bolts.

21 MR. J. KIM: No.

22 MEMBER SKILLMAN: Okay. What experience
23 is there to show that the welded design is a durable
24 design?

25 MR. J. KIM: In the -- actually, the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the design of reactor internal is in another
2 different section, 3.9.5. That is a more -- there
3 is more detailed information about the reactor
4 vessel internals. And so -- so far, we -- the
5 reactor vessel internals, we just don't have any
6 material issues of APR1000, so we believe this is
7 proven materials for the reactor vessel internals.

8 MEMBER SKILLMAN: Are the APR1000
9 internals all welded?

10 PARTICIPANT: Yes.

11 MR. J. KIM: Yes, yes.

12 MEMBER SKILLMAN: No bolts?

13 MR. J. KIM: No bolt. It is -- it is CE
14 type, no bolt.

15 MEMBER RICCARDELLA: Dick, you know, the
16 welded design is similar to the CE plants in the
17 U.S., and there have been no incidences of issues
18 with the welded baffle form of design in CE plants,
19 with the exception of Palisades, which happens to
20 have bolts.

21 MEMBER SKILLMAN: Okay. Thank you.

22 MR. J. KIM: Chapter 4.6 is for
23 functional design of the reactivity control system
24 of APR1400. The section 4.6 describes the control
25 rod drive system, the CRDS. The CRDS consists of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 control element drive mechanism and digital rod
2 control systems. The CEDM is for inserting or
3 withdrawing the CEAs, and the DRCS is for actuating
4 the CEDMs.

5 The information and evaluation of
6 combined -- combined performance of the reactivity
7 control system are about design basis events which
8 are analyzed in Chapter 15. Chapter 15 requires
9 reactivity control system to operate for preventing
10 or mitigating each event. And there are no open
11 items for Section 4.6. Yes? Yes?

12 MEMBER SKILLMAN: Question, please. In
13 the material, in our reading material, the full-
14 strength rods have a tip, and that tip is a B4C
15 pellet wrapped in a sleeve of 347 material, and it
16 is called felt material.

17 MR. J. KIM: I am sorry. I don't
18 understand.

19 MEMBER SKILLMAN: See, the text that I
20 will read describes my question. "The applicant
21 stated that the control elements of a four-element
22 or twelve-element full strength CEA consists of an
23 Inconel 625 tube" --

24 MR. J. KIM: Yes.

25 MEMBER SKILLMAN: -- "loaded with a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stack of cylindrical boron carbide pellets, B4C,
2 with the exception of the lower portions of the
3 elements, which contain reduced diameter B4C pellets
4 wrapped in a sleeve of Type 347 stainless steel."

5 MR. J. KIM: Yes.

6 MEMBER SKILLMAN: What is your
7 experience with this design?

8 MR. J. KIM: Yes. For the reactor
9 internal and cesium -- yes, I am sorry, yes, there
10 is some -- another --

11 MR. YOON: Tae Young Yoon from KEPCO NF.
12 There is some material CEA, right? The CEA design
13 is same as the System 80+ design. It -- it has been
14 used a lot of years, and we also, CEA design you see
15 in OPR1000 in Korean plant also, yes. It has a lot
16 of experience for that.

17 MEMBER SKILLMAN: Thank you. Thank you.
18 Okay.

19 MEMBER MARCH-LEUBA: Off the top of your
20 head, or anybody in the room, do you remember what
21 the worth of the highest rod is, the highest worth
22 of a rod is? I am thinking rod injection: did you
23 know how much they are worth?

24 (Pause.)

25 MR. CHON: This is Woochong Chon from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 KEPCO Nuclear Fuel. It is around 4,000 PCM.

2 MEMBER MARCH-LEUBA: Okay. Very little,
3 yes, okay. Thank you.

4 CHAIRMAN BALLINGER: Okay. Continue,
5 okay.

6 MR. J. KIM: Summary: the APR1400
7 reactor design full demonstrates to comply with
8 requirements of federal regulations and NRC
9 regulatory documents. There are no open items for
10 Sections 4.1, 4.3, and 4.6. There are six open
11 items in total for Sections 4.2, 4.4, and 4.5.
12 Thank you. Thanks for your attention.

13 CHAIRMAN BALLINGER: We're mercifully
14 ahead of schedule, and consulting with my staff,
15 okay. We are ahead of schedule, and we've discussed
16 it with the staff, and they are ready to pick up and
17 start so that we can get -- stay ahead of the game,
18 if you will. So thank you very much. Thank you
19 very much.

20 MS. KARAS: This is Becky Karas. We are
21 missing I think --

22 CHAIRMAN BALLINGER: Oh, oh --

23 MS. KARAS: -- one staff member, so
24 we're trying to get a hold of them, but we can get
25 through I think the first -- we can get through 4.2.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 When we get to 4.3, we are missing one staff member
2 that we have been trying to get a hold of now to
3 come back early.

4 CHAIRMAN BALLINGER: Okay. Thank you,
5 distance made good.

6 MR. WUNDER: Thank you, Mr. Chairman,
7 and good morning, ladies and gentlemen. I'm George
8 Wunder, the project manager assigned to Chapter 4
9 for the APR1400 review. I'm joined today by Chris
10 Van Wert and Alexandra Burja of the Reactor Systems
11 Branch, and by Andrew Bielen of the Reactor Systems
12 Analysis Branch in the Office of Research.

13 When we switch out, we're a little bit
14 constrained by space today, but when we switch out,
15 I'll be joined by Jim Gilmer and Carl Thurston, also
16 of the Reactor Systems Branch, and finally by
17 Jonathan Honcharik and Dan Widrevitz both of the
18 Mechanical and Chemical Engineering Branch.

19 CHAIRMAN BALLINGER: Excuse me, I
20 violated the prime directive. I'm told that we need
21 to tell the contractor to mute his or her phone.

22 MR. WUNDER: The review was conducted by
23 a team of eight members of the technical staff.
24 They are the presenters who I have just introduced
25 to you, and also Peter Yarsky of the Reactor Systems

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Analysis Branch Office of Research.

2 We'll be presenting to you today in the
3 areas of fuel system design, nuclear design, thermal
4 and hydraulic design, materials, and reactivity
5 control. I'd now like to turn the presentation over
6 to Chris Van Wert. Chris?

7 MR. VAN WELT: Good morning, everyone.
8 My name is Chris Van Wert and I will be presenting
9 the staff's review of - sorry. All right, good
10 morning, again. My name is Chris Van Wert and I
11 will be presenting the staff's review of DCD Section
12 4.2 fuel system design.

13 I've listed on this slide the areas of
14 review, and this is similar to the other sections
15 that you'll hear about today, but we covered design
16 bases, descriptions and design drawings, design
17 evaluation, the testing, ITAACs, and COL action
18 items and certification restrictions.

19 And now I'd like to discuss a couple of
20 the more challenging review areas that we
21 encountered during the review. The first one is
22 burnup dependent thermal conductivity degradation,
23 and I believe that was discussed a little bit this
24 morning.

25 And as you are well aware, the APR1400's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fuel system design is based on the use primarily of
2 the FATES-3B fuel design code which does not contain
3 a burnup dependent TCD model. The staff identified
4 this as a concern regarding compliance with GDC 10
5 for various fuel system damage and fuel rod damage
6 mechanisms, as well as 10 CFR 50.46 for core
7 coolability requirements.

8 It should be noted that the burnup
9 dependent TCD model review is addressed more
10 completely within the associated topical report
11 reviews for the PLUS7 fuel design as well as the
12 large-break LOCA topical report. The resolution of
13 the DCD Section 4.2 open item is therefore dependent
14 upon the successful completion of those reviews.
15 Any questions on that? Yes?

16 MEMBER REMPE: Yes, could you just talk
17 a little bit about what the concerns are and, I
18 mean, typically when - are they going - my
19 understanding from the documentation is they're not
20 going to change their code and they went and used
21 FRAPCON and did something, but they concluded that
22 things are okay, and is the staff saying, "No, we
23 want a penalty," or what's going on and what are the
24 issues?

25 MR. VAN WELT: Yes, yes, so this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ongoing, so I don't want to give the impression that
2 it is complete and set in stone at this point, but
3 the path forward that we are looking at right now is
4 a penalty which would be applied to the results from
5 FATES-3B. The penalty is based on comparison of
6 FATES-3B results to the Halden test data, as well as
7 the staff performed confirmatory runs using FRAPCON.

8 So they are not relying on FRAPCON as a
9 design basis code. That is the staff's confirmatory
10 tool while reviewing their - I'll say the new
11 methodology that they're proposing is FATES-3B plus
12 penalty, and so we're using FRAPCON just to confirm
13 that.

14 MEMBER REMPE: Okay, thank you.

15 MEMBER MARCH-LEUBA: The penalty is on
16 the temperature or on decay? Can you explain a
17 little more?

18 MR. VAN WELT: I would like to hold off
19 on the specifics of it just because that part is
20 still ongoing.

21 MEMBER MARCH-LEUBA: Okay.

22 MR. VAN WELT: And that is associated
23 with the PLUS7 topical report.

24 MEMBER MARCH-LEUBA: We'll just call
25 this a general described penalty.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. VAN WELT: Yeah, but to give you a
2 little nugget, there is a temperature penalty, but
3 we won't go into that on the other topical reports
4 as they come up.

5 MR. SCHULTZ: Okay, I'd just like to
6 repeat back so I fully understand. The applicant is
7 going to derive and propose a penalty?

8 MR. VAN WELT: Correct.

9 MR. SCHULTZ: And the approach that
10 they've taken and present to you for that penalty
11 and its application will be for them to do. The
12 confirmatory analyses that are being done with
13 FRAPCON, have they been completed so you have a
14 sense as to what those results are in comparison to
15 the FATES code?

16 MR. VAN WELT: Yes, yes, we are actually
17 well along in this process. We've been having
18 probably every other week public phone calls with
19 KHNP on this topic, and there have been different
20 penalties proposed as we've gone along, and we've
21 performed confirmatory runs on those, and so I might
22 have made it sound like we were done.

23 MR. SCHULTZ: No, you didn't.

24 MR. VAN WELT: Okay.

25 MR. SCHULTZ: My next question is what's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the schedule here because it certainly involves a
2 submittal as well as a review?

3 MR. VAN WELT: Correct.

4 MR. SCHULTZ: I mean, you've got some of
5 the calculations done, but -

6 MR. VAN WELT: Yes.

7 MR. SCHULTZ: - the most important thing
8 is to get a thorough review of what's submitted.

9 MR. VAN WELT: So we have performed all
10 of the necessary FRAPCON confirmatory runs. Right
11 now - and I believe there's pretty good agreement
12 between KHNP and the staff on the temperature side
13 of the equation.

14 Right now, I believe KHNP is looking at
15 the impacts on the large-break LOCA PCT
16 calculations, and we have some internal trace
17 calculations that we will use for confirmatory
18 comparisons when that comes in.

19 I will casually glance over at KHNP at
20 this point to see if everything is on schedule for
21 the large-break LOCA PCT calculations, but I believe
22 we're looking in a few weeks, sorry, three months.
23 I was just signaled.

24 MR. SCHULTZ: Okay.

25 MR. VAN WELT: But that would be the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 final results.

2 MR. SCHULTZ: All right.

3 MR. VAN WELT: So we will probably in a
4 number of weeks, a month or two, we should have the
5 preliminary results that we can use to compare
6 against.

7 MR. SCHULTZ: Has the staff reviewed the
8 data set, the Halden data set? It's just going to
9 be Halden data that will be used?

10 MR. VAN WELT: For the temperature, yes.

11 MR. SCHULTZ: The applicant doesn't have
12 any separate data that could be used?

13 MR. VAN WELT: Correct, there's no
14 bilateral data that was supplied.

15 MR. SCHULTZ: Okay, and has the staff
16 reviewed the extent of the Halden data that's going
17 to be applied -

18 MR. VAN WELT: Yes.

19 MR. SCHULTZ: - and agreed that that
20 data set is sufficient?

21 MR. VAN WELT: Correct, yes.

22 MR. SCHULTZ: Thank you. And that
23 information has been submitted or is it going to be
24 submitted all in one package?

25 MR. VAN WELT: It will be submitted in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 one package.

2 MR. SCHULTZ: Okay, in about three
3 months?

4 MR. VAN WELT: I will look over, but I
5 believe that is -

6 MR. SCHULTZ: That's close enough.

7 MR. VAN WELT: Yes.

8 MR. SCHULTZ: Thank you.

9 MEMBER REMPE: So I'm a little slow
10 because I was going to pull up my schedule, but
11 isn't Chapter 15 coming to us? Will it come to us
12 before you have this completed?

13 MR. VAN WELT: I believe it will be very
14 similar to what you're seeing today where the DCD
15 Chapter 15 will be like just DCD Chapter 4 where we
16 have an open item associated with the TCD issue, and
17 so unfortunately, that means you will also have
18 maybe a -

19 MEMBER REMPE: Okay.

20 MR. VAN WELT: - bigger gap than you
21 would like at that stage, but during the topical
22 report, you know.

23 MEMBER MARCH-LEUBA: On the plan, I
24 believe, it's to adjust the acceptance criteria by
25 putting a penalty in temperature, so you don't have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to redo the calculations. Is that the way you're
2 thinking?

3 MR. VAN WELT: For? Now is this -

4 MEMBER MARCH-LEUBA: For the LOCA PCT
5 calculations.

6 MR. VAN WELT: It's actually redoing the
7 LOCA PCT calculations. That's the three months that
8 we're talking about.

9 MEMBER MARCH-LEUBA: Oh, for LOCA
10 they're not going to use a penalty. They're going
11 to do the calculations.

12 MR. VAN WELT: There's a penalty on the
13 calculations, but they are re-running because the -
14 I don't know if -

15 MR. CHON: This is Woochong Chon from
16 KEPCO Nuclear Fuel. We will add the fuel PCT
17 penalty on the fuel, and that data will be
18 transferred to the calculation of the RELAP for the
19 large-break LOCA calculation, so we have to re-
20 perform the whole large-break LOCA calculation with
21 the added penalty fuel data.

22 MEMBER MARCH-LEUBA: Yes, it's not just
23 an acceptance criteria. You have the thermal
24 hydraulics, so you have to follow-up with a penalty.

25 MR. CHON: We have to perform whole

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 calculation.

2 MEMBER MARCH-LEUBA: Yeah, so, well, to
3 perform the calculations, you need to know what the
4 penalty is.

5 MR. VAN WELT: Yes, and we've come to an
6 agreement on that. That's the part where we're
7 talking about the FATES-3B penalty, but that all
8 feeds into the input decks that they need, and
9 that's the part they're re-running at this point.

10 MEMBER MARCH-LEUBA: Talk about it
11 whenever Chapter 15 comes.

12 MEMBER REMPE: That is coming in March
13 subcommittee week, and will the RELAP analysis be
14 completed or we're going to be doing Chapter 15
15 without the RELAP analysis results?

16 MR. CHON: This is Woochong Chon of
17 KEPCO Nuclear Fuel again. To finish all of the
18 large-break LOCA calculations, we expect it will
19 take three months, but before that, we can check the
20 sensitivity study with the penalty added fuel
21 temperature, so we can calculate earlier than three
22 months, but the final DCD revision will be done
23 after three months later after the results of the
24 TCD.

25 MR. SCHULTZ: Why would it only effect

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 large-break LOCA calculations?

2 MR. VAN WELT: It doesn't. There are
3 other impacts.

4 MR. SCHULTZ: Okay, those will be
5 identified as well?

6 MR. VAN WELT: Yes, in general, some of
7 the other designs. The DCD Section 4.2 is really
8 more of the high-level results -

9 MR. SCHULTZ: Understood.

10 MR. VAN WELT: - calculation, so the
11 topical report will -

12 MR. SCHULTZ: I was thinking of Chapter
13 15.

14 MR. VAN WELT: Oh.

15 MR. SCHULTZ: And how many pieces are
16 involved there and affected there. Thank you.

17 MR. VAN WELT: Yes. If there are no
18 open questions on TCD, we can -

19 MEMBER KIRCHNER: It begs a question
20 that's a bit of a digression, but how has this been
21 handled with the CE plants? I would assume they're
22 using CE derivative methodologies and so on.

23 MR. VAN WELT: Correct.

24 MEMBER KIRCHNER: The FATES code. This
25 is a thermal degradation. The gap conductivity has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 been known for a long, long time, so what was done
2 previously with the US CE plants to address this?

3 MR. VAN WELT: Well, keeping in mind
4 that the staff only became aware of the magnitude of
5 some of the deltas more recently, especially when
6 you compare it to the licensing basis for most of
7 the CE fleet, so must they have command for an LAR
8 since the staff became aware of this, they would not
9 have necessarily had to address it in the same
10 magnitude that KHNP is addressing here.

11 That being said, you could see certain
12 plants have come in with LARs and they have
13 addressed it, but, and I don't want to speak for NRR
14 on this topic. You know, I would defer to them on
15 it, but my understanding was that there was -

16 Well, actually, Westinghouse might also
17 be able to speak up on what manner the generic
18 communication went out, but there was, I think it
19 was tied to 50.46, but it was the impacts of TCD on
20 that, and the operating fleet did have to come in
21 and address more or less a justification for
22 continued operation, a rough approximation of the
23 impact, and I believe most of them have committed to
24 switching over to the newer codes that are coming
25 out or have come out which address this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So for Westinghouse, there's PAD5. For
2 AREVA, there's COPERNIC. For GE, it's PRIME. As
3 those new codes have been coming out, the operating
4 fleet has been switching the licensing basis over to
5 the newer codes.

6 MEMBER MARCH-LEUBA: And I realize that
7 you're not the right person to ask this, but I would
8 expect that didn't they evaluate it through Part 21
9 and suddenly your calculation of record is put in
10 question? So I'm sure if they already planned the
11 Part 21 evaluation if, "Does this affect me?"

12 MR. VAN WELT: And there might be the
13 Part 21 evaluations for that, especially when you
14 get down to what different plants did or the plants
15 as a whole did. I would want to refer to NRR for
16 that one.

17 MEMBER MARCH-LEUBA: No, no, because we
18 are reviewing Part 5 soon.

19 MR. VAN WELT: Yes, yes, I think the
20 draft SDR is already completed, so.

21 MEMBER MARCH-LEUBA: Yes, we will see
22 them in May.

23 MR. VAN WELT: Okay, excellent. Any
24 more TCD questions? Okay, we can go to the - oh,
25 excellent, so the next challenging area - was there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 - okay, the next challenging review area that I
2 would like to discuss is the fuel assembly
3 structural response to externally applied loads.

4 And I believe you heard about this this
5 morning as well, but during the review of the
6 structural response analysis, the staff noted that
7 the reference methodology was not strictly followed
8 in its entirety, and that caused us to question the
9 determination or load limits for the PLUS7 fuel
10 assembly.

11 As a result of that concern and the back
12 and forth between the staff and the applicant, the
13 applicant is now in the process of completing its
14 open item resolution plan which includes a
15 comprehensive test program of the PLUS7 fuel
16 assembly and its modeling of both the beginning of
17 life and end of life, simulated end of life
18 conditions.

19 Again, this is another ongoing area, but
20 the staff has been auditing the tests as they've
21 occurred, and I believe the next test that we are
22 going to witness is coming up shortly at the end of
23 February here, which will be related to the flow
24 dampening credit.

25 And I believe the current schedule is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the end of spring, maybe early summer, we should
2 have the completed documentation for this and we
3 should be able to complete a review at that time.
4 Yes?

5 MEMBER SKILLMAN: What does test mean in
6 that context?

7 MR. VAN WELT: So they are doing
8 actually a full suite of tests including grid
9 assembly tests. They were doing through grid, BOL,
10 and EOL conditions, SEOL conditions, simulated EOL
11 conditions where they relaxed the springs to
12 simulate the grid relaxation that would occur.

13 Right now, the test that I mentioned
14 that's coming up is using the Westinghouse VIPER
15 loop which normally is used for flow induced
16 vibration test. They're modifying that, or did
17 modify it to perform flow dampening analysis or
18 testing so they can take credit for that in the
19 revised analysis when they present that.

20 MEMBER SKILLMAN: So these are physical
21 tests from which data is extracted for evaluation
22 for confirmation?

23 MR. VAN WELT: Correct.

24 MEMBER SKILLMAN: Copy that. Thank you.

25 MR. VAN WELT: Thank you. So when I was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 looking at this, I realized it sounds a little bit
2 odd here. So the title of this slide is, "Fuel
3 system design meets the following requirements," and
4 the next sentence says, "The staff is currently
5 unable to make regulatory findings on the fuel
6 system design."

7 The two open items that we talked about
8 are rather large, and since they impact pretty much
9 all of GDC 10, 35, GDC 2, we're unable at this time
10 to make regulatory findings. However, we do have a
11 plan. The applicant is well on the path to reaching
12 the completion there, and we expect to be able to
13 make our regulatory findings very soon.

14 Any further questions on fuel system
15 design? Thank you very much.

16 MS. BURJA: All right, my name is Alex
17 Burja and I will present to you the staff's review
18 of DCD Section 4.3 nuclear design. First, I will go
19 over the areas that the staff reviewed, then I'll go
20 into a little bit more detail on some of the more
21 challenging areas. Finally, I will provide the
22 staff's conclusions before turning it over to Dr.
23 Andrew Bielen from research who conducted the
24 staff's confirmatory analyses.

25 The first area that the staff reviewed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 under the nuclear design was the design bases to
2 ensure that they are consistent with the general
3 design criteria, which indeed they were.

4 Under the area of power distributions,
5 the staff looked at the representative power
6 distribution calculations presented in the DCD to
7 ensure that they were comprehensive and that they
8 included axial, radial, and pin power distributions,
9 and accounted for different times in the cycle, as
10 well as different operating conditions.

11 The staff confirms that these power
12 distributions that were presented were well within
13 the power distribution design limits, and based on
14 the confirmatory analyses, the power distributions
15 are about what we would expect.

16 The staff also ensured that there are
17 means to monitor the power distributions. These
18 included the non-safety related core operating
19 limits supervisory system or COLSS, which notifies
20 operators if tech specs are exceeded, and the safety
21 related core protection calculator system or CPCS
22 which will initiate a reactor trip if subpoints are
23 exceeded.

24 The staff also ensured that there are
25 means to control the power distributions, and these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consist of the core loading pattern, control element
2 assemblies or CEAs, and soluble boron.

3 The next major area of review for the
4 staff was that of reactivity coefficients.

5 MEMBER MARCH-LEUBA: Alex?

6 MS. BURJA: Yes?

7 MEMBER MARCH-LEUBA: On the power
8 distributions, my understanding for APR1400, what
9 they do is they run a full 18-month depletion of the
10 core and calculate every single power distribution
11 every day of those 18 months, and then they use
12 those power distributions to calculate the limits.
13 Is that correct?

14 MS. BURJA: That's my understanding,
15 yes.

16 MEMBER MARCH-LEUBA: Yes, so that's what
17 you mean when you reveal they were presenting power
18 distribution. You saw every power distribution in
19 an 18-month cycle, not that you looked at every
20 picture, but they were there.

21 MS. BURJA: Right, right, everything
22 that was presented in the DCD.

23 MEMBER MARCH-LEUBA: Okay, thank you.

24 MS. BURJA: Okay, so in the area of
25 reactivity coefficients, the staff ensured that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there is a negative power coefficient of reactivity
2 including a negative moderator temperature
3 coefficient at power, and the staff also ensured
4 that the transient and accident analyses used
5 conservative values relative to what was presented
6 in Section 4.3.

7 MR. SCHULTZ: So this statement doesn't
8 apply. We shouldn't presume that you've got - you
9 performed the conservative value evaluation that you
10 would have for Chapter 15 events, or is this
11 blanketing that conservative values have been used
12 or will be used in Chapter 15 analyses?

13 MS. BURJA: So based on the - so Chapter
14 15 tells us what MTC and FTC were used, and I
15 compared those values to what's used in 4.3 -

16 MR. SCHULTZ: Okay.

17 MS. BURJA: - and made sure that the
18 values used in the accident analyses are
19 conservative relative to the design values.

20 MR. SCHULTZ: I see, thank you.

21 MS. BURJA: Does that make sense?

22 MR. SCHULTZ: That's fine.

23 MEMBER MARCH-LEUBA: I know we are not
24 reviewing Chapter 15 now, but do they not use a 3D
25 automatic calculation of those coefficients for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 accident analysis or do they use the point kinetics
2 with the feedback with the conservative feedback?

3 MS. BURJA: It's my belief that they use
4 the point kinetics.

5 MEMBER MARCH-LEUBA: Point kinetics?

6 MS. BURJA: Yes.

7 MEMBER MARCH-LEUBA: So then it's
8 important that you review that they're using a
9 conservative number.

10 MS. BURJA: Right.

11 MEMBER MARCH-LEUBA: One of the being
12 positive for a week or two of every cycle.

13 MS. BURJA: Right, I did go back and
14 confirm that for accidents like rod ejection, they
15 do use a positive MTC value at the low power
16 conditions.

17 MEMBER MARCH-LEUBA: Yes, and while
18 we're talking about cross sections, most of the -
19 you are aware of the use in there before cross
20 sections for gadolinia which uses - but they use
21 gadolinia in special treatments, is that correct?
22 Because before, it had element gadolinia which does
23 not deplete properly.

24 MS. BURJA: So I actually did a little
25 bit of research on this, and based on the Brookhaven

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 National Lab data tapes, they do have some isotopic
2 data for gadolinia.

3 MEMBER MARCH-LEUBA: So it was for
4 amplified with the two main gadolinia isotopes, or
5 three, or however. Two are the important ones.

6 MS. BURJA: Right.

7 MEMBER MARCH-LEUBA: And you verified
8 that the limit is correct and they depleted the
9 gadolinia correctly because that affects that MTC
10 significantly.

11 MS. BURJA: Yes, yes, we did look into
12 the gadolinia treatment.

13 MEMBER MARCH-LEUBA: Okay.

14 MS. BURJA: Under the area of reactivity
15 control provisions and requirements, the staff
16 looked at things having to do with CEA patterns,
17 insertion limits, worths, and soluble boron and
18 burnable absorber worths and well.

19 And the staff confirms that the
20 available CEA worth is sufficient to safely shut
21 down the reactor during normal operation and
22 accident conditions, that conservative worth values
23 relative to what was calculated for the 4.3 nuclear
24 design are used in the Chapter 15 transient and
25 accident analyses.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The staff also ensured that the
2 requirements for reactivity controls such as the
3 necessary worths for different times in cycle are
4 clearly defined, and finally, the staff reviewed
5 that there are appropriate limits on reactivity
6 insertion rates to preclude power excursions.

7 MEMBER MARCH-LEUBA: Speaking of this
8 area, KHNP makes a claim that they are stable with
9 respect to xenon oscillations, that stable
10 oscillations will dampen. Did you find that?

11 MS. BURJA: Yes, the decay ratio was
12 negative, so they do dampen.

13 MR. SCHULTZ: Alex, how do you establish
14 that the conservative worth values that are used in
15 the transient and accident analyses are
16 satisfactory? Is there some criteria that the staff
17 has to say they will be called conservative if they
18 are so much larger than nominal, or is it just oh,
19 it's larger than nominal, so I guess that's
20 conservative, or lower than nominal depending on the
21 -

22 MS. BURJA: So there's no hard and fast
23 rule, but ultimately, you know, as long as they're
24 using something that, you know, if they assume that
25 they need a certain worth and - so if the nuclear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design says, "All right, we have this certain
2 worth," they must have at least that much for the
3 transient or - I'm sorry.

4 I'm not answering this very well, but it
5 is subjective, and based on the design information,
6 the assumptions in the transient and accident
7 analyses have to at least be the same or in a more
8 conservative direction.

9 MR. SCHULTZ: And then you're going to
10 do the evaluation also compared margin to limits for
11 the final evaluation and analysis, correct?

12 MS. BURJA: Mm-hmm.

13 MR. SCHULTZ: Okay, thank you.

14 MS. BURJA: Are there any more questions
15 on the reactivity control? Okay, the staff also
16 reviewed provisions to prevent reactor criticality
17 during refueling, and these are sufficient such as a
18 soluble boron concentration, enough to hold the core
19 K-effective under 0.95, as well as procedures that
20 require refueling to stop if neutron count rates
21 were to suddenly jump. Next slide, please.

22 The next area of review was stability
23 against xenon-induced power distribution
24 oscillations, and based on the staff's review, we
25 found that only axial xenon oscillations were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 possible, and they can be suppressed using the CEAs.

2 The staff also reviewed the applicant's
3 analytical methods for the nuclear design, and these
4 consist of the DIT and ROCS codes which were first
5 approved by the NRC in 1983, then again in 1988 to
6 include refinements for gadolinia fuel. Because
7 these were previously approved codes, the staff
8 really focused its review of this area on
9 applicability of the codes to APR1400.

10 The staff also ensured that the codes
11 used to process information from the ex-core
12 detectors for use in the CPCS are appropriate for
13 such an application.

14 MR. SCHULTZ: The review of the codes in
15 1988, I presume that included the range of gadolinia
16 that they -

17 MS. BURJA: Yes.

18 MR. SCHULTZ: - that they're using.

19 MS. BURJA: I don't recall offhand, but
20 I know the range meets -

21 MR. SCHULTZ: Encompassed the -

22 MS. BURJA: Yes.

23 MR. SCHULTZ: - eight percent? Thank
24 you.

25 MS. BURJA: Yes. In the area of reactor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 vessel fluence, the staff reviewed the methodology
2 that the applicant used which is DORT, a 2-D
3 discrete ordinates transport code, and also the
4 assumptions used within it to ensure that it's
5 conservative.

6 The staff also reviewed the vessel
7 fluence calculation and the calculation of bias and
8 uncertainty to ensure that everything was calculated
9 accurately and applied appropriately. And finally,
10 the staff requested a combined license information
11 item for plant specific surveillance data to
12 benchmark the methodology.

13 The staff also reviewed the nuclear
14 design tests in the initial test program and found
15 that they conformed to Reg Guide 1.68 and are
16 adequate to verify the nuclear design.

17 And I'd like to point out that there was
18 an open item in the SDR related to a Chapter 14
19 question, but it's not characterized as a
20 confirmatory item because of the satisfactory REI
21 response, and that ultimately is going to be handled
22 in Chapter 14. And finally, the staff reviewed the
23 nuclear design related tech specs and safety limits
24 to ensure that they are adequate.

25 MR. SCHULTZ: Alex, the COL information

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 item related to the testing program or surveillance
2 data program, is that - what does that mean? Does
3 that mean that you're just asking the applicant to
4 provide information to demonstrate that they have a
5 program or what does that entail? What's the
6 expectation associated with the program?

7 MS. BURJA: So we are looking for plant
8 specific data to verify that the methodology is
9 sufficient once, you know, there are - after, you
10 know, like, 20 effective full power years of
11 operation, because there's, you know, sufficient
12 conservatism for us to be able to conclude that the
13 methodology is good for -

14 OPERATOR: Please pardon the
15 interruption. Your conference contains less than
16 three participants at this time. If you would like
17 to continue, press star one now or the conference
18 will be terminated.

19 MR. SCHULTZ: Solved that problem
20 already. So, but is this a plant specific
21 surveillance program?

22 MS. BURJA: Yes.

23 MR. SCHULTZ: Okay.

24 MS. BURJA: It's plant specific.

25 MR. SCHULTZ: And so you're looking for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what they're going to - what -

2 OPERATOR: You have activated the help
3 menu. Press star zero -

4 MR. SCHULTZ: - what programs they're
5 going to use to make sure that they have that
6 covered?

7 MS. BURJA: Yes.

8 MR. SCHULTZ: Okay.

9 MS. BURJA: So we would expect to see
10 that surveillance data and, you know, provide
11 justification that the methodology is adequately
12 benchmarked.

13 MR. SCHULTZ: In time?

14 MS. BURJA: Yes.

15 MR. SCHULTZ: Okay.

16 MS. BURJA: Yes.

17 MR. SCHULTZ: Thank you.

18 MS. BURJA: You're welcome. Next slide,
19 please? So the first challenging review area that
20 the staff encountered was that of control rod worth
21 depletion. The staff became concerned that because
22 full-strength CEAs with boron carbide neutron
23 absorber can be inserted as regulating rods for
24 various lengths of time, that boron 10 depletion
25 could potentially affect CEA worth.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The staff discussed this issue with the
2 applicant during an April 2015 public meeting, and
3 issued RAIs concerning the loss of worth, potential
4 impacts on the transient and accident analyses, and
5 potential need for CEA service limits. In addition,
6 the staff audited the calculation notes related to
7 estimated boron 10 burnout.

8 Ultimately, the staff was able to come
9 to a resolution on this issue because the RAI
10 responses showed that the applicant's estimated
11 boron 10 burnout was not negligible, but it was
12 conservatively calculated. In addition, operating
13 experience for the OPR1000 shows that measurements
14 agree with predictions within the allowed
15 uncertainty bands.

16 The staff also confirms that the net rod
17 worth uncertainty listed in the DCD is much greater
18 than the estimated loss of worth provided in the RAI
19 response, so we have some assurance that the rod
20 worth uncertainty would bound the loss of worth. In
21 addition, the staff confirmed that the shutdown
22 reactivity curve presented in the DCD was
23 conservatively calculated.

24 The staff also noted that the 10-year
25 CEA lifetime, as well as the power dependent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 insertion limits in tech specs helped to limit the
2 loss of worth, and ultimately, startup physics tests
3 will confirm that rod worth is consistent with the
4 predictions, and if it's not, startup cannot
5 commence. Next slide, please?

6 MR. SCHULTZ: Alex, the startup physics
7 testing that you're describing here, is that for
8 just initial startup or for startups following
9 refueling?

10 MS. BURJA: It's for initial startup,
11 and then plant procedures typically require the rod
12 worth confirmation for every startup.

13 MR. SCHULTZ: Understood, thank you.

14 MS. BURJA: So the next challenging
15 review area was that of the benchmarking of the
16 nuclear design methodology. The staff became
17 concerned that the DCD didn't adequately describe
18 how the DIT and ROCS codes are benchmarked against
19 experimental data that would be specific to the
20 APR1400 nuclear design, including the use of
21 gadolinia fuel.

22 So again, this was an issue that the
23 staff discussed with the applicant during an April
24 2015 public meeting, and the staff issued an RAI on
25 the topic, and audited calculation notes showing how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 bias and uncertainty are determined for the DIT and
2 ROCS codes.

3 The staff resolved this issue because
4 the RAI response showed that the bias and
5 uncertainty manual is derived from measured versus
6 predicted data for eight U.S. combustion engineering
7 reactors that have core and nuclear designs that
8 bound the APR1400 design.

9 In addition, the staff's audit of
10 calculation notes confirmed that the methods used to
11 determine the bias and bias uncertainties are
12 adequate. The staff also confirmed through an audit
13 of the bias and uncertainty manual that the high-
14 level information about bias and uncertainty in the
15 DCD is supported.

16 The RAI response also noted that the
17 APR1400 bias and uncertainty manual is almost
18 identical to that for OPR1000, and the staff
19 confirmed that the OPR1000 DIT and ROCS predictions
20 provided in the RAI response compare well against
21 plant measurements which provides a level of
22 confidence that the same would be true for APR1400.

23 The final challenging review area for
24 the staff was that of the nuclear data that Jose
25 brought up a little bit earlier. As he mentioned,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the design methodology uses the ENDF/B-IV cross-
2 section library that was published in 1974, and
3 there have been many refinements and improvements to
4 the library since then.

5 To assess the impacts of using the
6 ENDF/B-IV cross-section library compared to a newer
7 version of the library, the staff performed
8 confirmatory criticality calculations using the
9 SCALE code and found that the differences were
10 substantial. If we could go to the next slide,
11 please?

12 So on this slide we have the results of
13 the staff confirmatory calculations. I ran
14 calculations for two cases, one with a well-known
15 criticality benchmark from the International
16 Handbook of Evaluated Criticality Safety Benchmark
17 Experiments, and one using a representative APR1400
18 3.14 weight percent on poison fuel assembly.

19 And in both cases, it is demonstrated
20 that the older cross-section libraries ENDF/B-IV and
21 even B-5, underestimated reactivity compared to the
22 current library. If we could go back to the
23 previous slide?

24 So therefore, the staff became concerned
25 that using ENDF/B-IV could lead to inaccurate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 nuclear design predictions and effect transient and
2 accident analyses as a result.

3 But through the staff's audit and
4 through reviewing the RAI response, the staff came
5 to determine that the bias and uncertainty values
6 applied to the DIT and ROCS codes are associated
7 with the use of ENDV/B-IV library itself, and
8 therefore the effects of using the library are
9 implicitly captured in the bias and uncertainty
10 that's applied to the nuclear design calculations.

11 MEMBER MARCH-LEUBA: So this is a bias
12 you applied to the k-effective?

13 MS. BURJA: That's correct.

14 MEMBER MARCH-LEUBA: So how does it
15 affect the reactivity coefficients?

16 MS. BURJA: Right, so the reactivity
17 coefficient bias and bias uncertainties are also
18 calculated in, you know, the same manner as all of
19 the rest nuclear design bias and bias uncertainties,
20 so because you're already accounting for the ENDV/B-
21 IV in those.

22 MEMBER MARCH-LEUBA: The biases I'm more
23 familiar with are done on a steady state, and what
24 was your predicted k-effective when you were on K1?
25 Well, I think they want to say something.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. BURJA: Okay.

2 MR. DO: I'm Manseok Do from KEPCO
3 Nuclear Fuel. You asked about a reactivity
4 question?

5 MEMBER MARCH-LEUBA: I was asking, I
6 mean, since the issue of biases because of the use
7 of the ENDV/B-IV on k-effective, there are some
8 biases. Is there an effect - the reliability of the
9 k-effective is to monitor coefficients.

10 MR. DO: The reactivity question to --
11 temperature coefficients are measured for each
12 cycle, and we compare the predictive values to
13 measure the values. The predictive values included
14 biases, and we are assured the biases is of proper
15 to use for APR1400.

16 MEMBER MARCH-LEUBA: Sorry, I didn't
17 follow that. So some plants do a moderated
18 temperature coefficient experimentally by setting up
19 two different temperatures? Is that what you did to
20 evaluate the bias?

21 So sometimes the moderator temperature
22 coefficient is evaluated by increasing the inner
23 temperature of the core, so you operate at one
24 temperature, and that temperature plus, say, 20
25 degrees, and calculate the difference in k-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 effective, so you experimentally measure the
2 temperature coefficient.

3 MR. DO: Yes, yes.

4 MEMBER MARCH-LEUBA: And then you
5 compare it to the one that you calculate, and is
6 that how you set up the biases?

7 MR. DO: Yes, we measure, but we can't
8 measure MTC. You measure ITC and we compare.

9 MEMBER MARCH-LEUBA: So you have a set
10 of biases based on experimental data that you apply
11 to your calculations?

12 MR. DO: Yes.

13 MEMBER MARCH-LEUBA: Okay, thank you.

14 MS. BURJA: Okay, are there any other
15 questions on this slide? If not, we can move to the
16 next, or the conclusion, please. Thank you.

17 So in conclusion, the staff was able to
18 find that the APR1400 nuclear design meets GDC 10
19 through 13, 20, and 25 through 28 respectively
20 because of the representative power distributions
21 and limits, the instrumentation to monitor the power
22 distributions, and the methods to control them
23 provide reasonable assurance that the specified
24 acceptable fuel design limits or SAFDLs will not be
25 exceeded during normal operation or anticipated

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operational occurrences or AOOs.

2 In addition, there's a negative power
3 coefficient of reactivity. Also, only axial xenon
4 oscillations are possible, and can be suppressed
5 using CEAs. In addition, there are instrumentation
6 and controls to maintain power distributions within
7 limits, also control systems and set points are
8 adequate to shut down the reactor at any time.

9 In addition, SAFDLs will not be exceeded
10 for any single reactivity control system malfunction
11 as shown by the Chapter 15 transient and accident
12 analyses and how the nuclear design was used in
13 those.

14 In addition, worth calculation
15 for Chapter 4.3 demonstrate that there is sufficient
16 shutdown margin assuming a stuck rod. Finally,
17 there are appropriate limits on reactivity insertion
18 rates, and appropriate reactivity values were used
19 in the transient and accident analyses.

20 In addition to these findings against
21 the GDC, the staff was also able to conclude that
22 the applicant's analytical methods and choice of
23 data are acceptable, and the methods are benchmarked
24 appropriately, that the initial test program is
25 adequate to verify the nuclear design, that the tech
specs are consistent with the requirements

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 identified in the Chapter 15 analyses to help ensure
2 the health and safety of the public, and in
3 addition, the staff confirmatory analyses support
4 the foregoing conclusions.

5 Are there any questions at this time?

6 MR. SCHULTZ: Just perhaps a fine point,
7 Alex. In that last statement for additional
8 considerations where you say analytical methods and
9 data are acceptable and benchmarked appropriately,
10 would one also include the bias and uncertainty -

11 MS. BURJA: Yes, that -

12 MR. SCHULTZ: - as part of that
13 statement that they are acceptable -

14 MS. BURJA: Yes, that's definitely -

15 MR. SCHULTZ: - because of appropriate
16 application of that?

17 MS. BURJA: That's definitely part of
18 the methodology. I would agree.

19 MR. SCHULTZ: Okay, that's what you
20 considered, that it's part of the overall
21 methodology?

22 MS. BURJA: Mm-mmm.

23 MR. SCHULTZ: Thank you.

24 MS. BURJA: You're welcome. If there
25 are no further questions, I will turn it over to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Andrew. Oh, yes?

2 MEMBER KIRCHNER: Just a quick question.
3 So you already looked at the reactivity insertion
4 accidents, the Chapter 15?

5 MS. BURJA: I didn't personally review
6 them, but I ensured that the initial conditions and
7 assumptions are consistent with or are conservative
8 relative to the nuclear design in 4.3.

9 MEMBER KIRCHNER: Okay, thank you.
10 We'll get change to see 15 at some point.

11 MS. BURJA: That's correct.

12 MEMBER KIRCHNER: Thank you.

13 MS. BURJA: You're welcome.

14 MEMBER REMPE: Out of curiosity, when I
15 was reading your draft SC or the staff's draft SC,
16 they had a statement in there about, "Well, we know
17 the values they assumed are typical," and then
18 there's a little caveat about, "If it significantly
19 differs, we'd have to evaluate," and I was just
20 curious what is significantly different? Is that
21 well understood in the community of folks who do
22 this? Is it 10 percent? Is it 50 percent? What's
23 significantly different?

24 MS. BURJA: I don't believe there is a
25 hard and fast rule, and I'm trying to remember what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the context of this was.

2 MEMBER REMPE: It was the nuclear design
3 parameters. It was on page 4-12, fuel assemblies
4 and core loading patterns.

5 MS. BURJA: Oh, right, so the DCD
6 presents representative core loading patterns, and
7 that's what their nuclear design calculations are
8 based on, and the problem is if they significantly
9 change loading patterns or, you know, any of that
10 sort of information, it would affect the power
11 distributions and whatnot.

12 MEMBER REMPE: But where is significant?
13 Does everybody kind of agree on that and it's well
14 understood when somebody comes in later that wants
15 to buy this plant, and it's a certified plant, will
16 everybody know what that means?

17 MS. BURJA: So I believe the information
18 about changing the core loading is contained in the
19 core operating limits report.

20 MEMBER REMPE: Okay.

21 MS. BURJA: So that would -

22 MEMBER REMPE: Give the guidance on it,
23 okay.

24 MEMBER MARCH-LEUBA: My understanding of
25 the process for the DCD is that there's a comment on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the applicant to provide the first cycle and another
2 cycle that will work, and exercise of other methods
3 against that code. Then the real cycles after you
4 build the plant, you analyze them one by one.

5 MEMBER REMPE: Yeah, okay, just
6 wondering if it's well understood.

7 MEMBER MARCH-LEUBA: And the real cycle
8 will not be the one they analyze for the DCD. It
9 would be hopefully closed, but they will analyze it
10 and make sure it works.

11 MEMBER REMPE: Okay.

12 MS. BURJA: Thank you. All right, if
13 there are no further questions, I'll turn it over to
14 Andrew Bielen from research to talk about the
15 confirmatory analyses.

16 MR. BIELEN: Hi, I'm Andy Bielen. I'm
17 from the Office of Research. I performed the
18 initial cycle core physics confirmatory analysis,
19 and this was to confirm the information that was
20 presented in Section 4.3, and also to provide our
21 basis for our cycle dependent transient and accident
22 confirmatory analysis which we'll present to you
23 next month.

24 So I want to keep today focused on the
25 core physics itself. You know, some of that will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 inevitably bleed over into Chapter 15. I'll do the
2 best I can to address that at this point in time,
3 but I make no promises about how thorough it will
4 be.

5 So what I'll talk about today is the
6 nuclear design methods that we use here at the NRC.
7 I'll talk about our power distribution comparisons
8 with the initial cycle presented in DCD Section 4.3,
9 both radial and axial.

10 I'll talk about the boron letdown curve
11 as the PWR operates with soluble boron in the
12 coolant, and that as the core depletes, that level
13 is diluted until you have basically zero boron at
14 the end, so we'll compare what our codes say with
15 what was presented in the DCD.

16 I'll talk about the control rod bank
17 worths and our comparisons there. I'll also just
18 present a few safety analysis related parameters
19 like the trip reactivity insertion curves,
20 reactivity feedback coefficients, and then we'll
21 just provide a summary and conclusions there.

22 So at NRC currently for PWRs, we're
23 using the POLARIS code which is a method of
24 characteristics codes relatively new to the SCALE
25 package that Oak Ridge develops.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 For this set of calculations, we used
2 seven history conditions which the lattices were
3 depleted, and then within those seven conditions, we
4 have a total of 81 different branch conditions to
5 capture different instantaneous conditions.

6 The reason we used so many was that we
7 wanted to have the ability, should it be necessary,
8 to calculate anything from an overpower condition
9 down to cold conditions. So I think that we have
10 confidence that our cross-section set is sufficient
11 to carry anything that could be reasonably expected
12 to occur within this plant.

13 To do the nodal core calculation, we
14 used our PARCS code. So in the axial direction, we
15 used 27 nodes, one reflector node in the bottom, one
16 reflector node at the top, and then 25 in the active
17 fuel region.

18 We used one radial node per fuel
19 assembly, and 250 MWd/MTU exposure increments, so
20 out to the full length of cycle one. Then to
21 provide our thermal-hydraulic conditions during the
22 core simulation, we used the PATHS code which is
23 sort of a TH solver subcode of PARCS, and again,
24 this is a one to one TH to neutron nodal mapping.

25 So first, I'll just present some of our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 power distribution results. These are sort of busy
2 figures, but this is the BOC no xenon case. We see
3 very good general agreement here. Next slide,
4 please?

5 EOC, so we're kind of tracking which
6 assemblies are hot and which assemblies are cold
7 versus what the applicant presented. I'd say the
8 biggest differences are usually in the periphery,
9 and that may be due to reflector modeling.

10 You know, everybody - reflector modeling
11 is more of an art than it is a science. Everybody
12 does things slightly differently with slightly
13 different assumptions, but in general, I think we
14 were pretty happy with how the radial power
15 distribution comparisons came out. Okay, next
16 slide, please? I'm sorry?

17 CHAIRMAN BALLINGER: What constitutes
18 not good? In other words, how much of a difference
19 -

20 MR. BIELEN: I'll talk about that in a
21 subsequent slide.

22 CHAIRMAN BALLINGER: Okay.

23 MR. BIELEN: Generally speaking though
24 just to give you a head's up, you know, when we look
25 at - you know, we do some benchmarking with PARCS as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 well. You know, we have our own internal
2 benchmarks. We have different plants that have gone
3 through Hatch, for example, TMI, and when you look
4 at the -

5 And we had an international effort a few
6 years ago where one of the, I think it was a
7 Norwegian country, one of the organizations there
8 compared against some operating data from plants
9 there, so I think that we feel good as within sort
10 of the differences with those benchmarking efforts.

11 I would say, you know, in our case, the
12 radial power distributions were all - worst-case,
13 the RMS difference in the initial cycle, or for the
14 initial point for the initial cycle was around five
15 percent. It got better as the GAD burned out. The
16 power distribution moved around, flattened out, so
17 by end of cycle, we were at, you know, two percent
18 RMS difference.

19 And in the peak power assembly, we were
20 at, generally speaking, less than one percent
21 different from the DCD calculation. So we feel like
22 that is a justifiably good, you know, number.

23 Now, if I ran a calculation and I saw,
24 you know, the hot assembly was somewhere completely
25 different, or you had an RMS different of 15

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 percent, you know, that would be something that
2 would cause for concern, but I think that where we
3 were at, given the information we had available and
4 the approaches that we used, we felt strongly that
5 it was sufficient.

6 MR. SCHULTZ: The radial distribution
7 looks at least that close.

8 MR. BIELEN: Yes.

9 MR. SCHULTZ: And, you know, I would say
10 that was pretty good, to quote you.

11 MR. BIELEN: This is the axial snapshots
12 at the beginning and end of cycle, and I think
13 again, worst case, we're about 10 percent in the
14 peak power node.

15 If you look at, you know, as Alex
16 pointed out, you look at what the operating limits
17 are and what the tech spec limits are versus what
18 some of the values that we have and the differences
19 that we have between their analysis and our
20 analysis, there's enough margin in the design I
21 think that any difference we have here or any
22 uncertainties we have are well within, you know, the
23 safety limits basically.

24 Okay, next slide, please? So as I said,
25 we're happy with the radial power. We're happy with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the axial power. The differences we saw are
2 consistent with some of the benchmarking activities
3 we've done with PARCS, so -

4 MEMBER MARCH-LEUBA: So yes, going back,
5 do you use seven for your -

6 MR. BIELEN: Yes, our - so POLARIS, the
7 default library is 7.1, so that is -

8 MEMBER MARCH-LEUBA: That could explain
9 the difference in the two calculations.

10 MR. BIELEN: Yes, and in fact, you know,
11 here when we talk about boron letdown, I think we
12 can have a little bit of - it should be more of an
13 interesting discussion, I think.

14 MEMBER MARCH-LEUBA: But on the
15 calculations, if you have the same cross-sections
16 and the same reflector, you should not be five
17 percent off.

18 MR. BIELEN: Right.

19 MEMBER MARCH-LEUBA: You should be
20 0.005.

21 MR. BIELEN: Exactly, right. So some of
22 these difference are either -

23 MEMBER MARCH-LEUBA: Well, four versus
24 seven, that will do it.

25 MR. BIELEN: Right, right, right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: And at the end of
2 the day, and maybe this is a question for KHNP more,
3 you compare your power distribution results versus
4 measured data in the plan would give you an
5 uncertainty that I assume gets rolled over to the
6 DNBR acceptability ratio. Is that correct?

7 I mean, when you calculate your power
8 distribution, there is an uncertainty to that, and
9 you developed the uncertainty by comparing versus
10 measured data. That becomes your uncertainty in the
11 power distribution, and I would put that on the
12 acceptable value of the DNBR which was 2.49?

13 MR. Y. KIM: Yes, this Yun Ho Kim from
14 KHNP. We used every - yeah every month, we measured
15 at the site, and we compared it to the power
16 distribution, and we got the predicted value, and if
17 there is a reading sum limit, they are reading some
18 limit, we just assume the current loading is okay,
19 the current design is the same as the -

20 MEMBER MARCH-LEUBA: I mean, they're not
21 within the limits? If they're outside the limits,
22 you did something wrong?

23 MR. Y. KIM: I cannot remember. We
24 would have to prepare you, but it is less than one
25 percent or two percent.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: Okay, thank you.

2 MR. BIELEN: Okay, so power distribution
3 looks good. As I said, the axial offset and, you
4 know, the other tech spec limits were well within
5 those things. From a safety standpoint, the initial
6 cycle is well within, you know, their operating box
7 basically. Next slide, please?

8 So boron letdown, I'm going to go old
9 school here with some arrows on some figures. On
10 the left side, we have the critical boron
11 concentration, and on the right side is the
12 difference between the staff and the applicant's
13 predictions, and I would say qualitatively, we have
14 agreement here.

15 We actually have a little hump here
16 around two or three gigawatts days per MTU where,
17 you know, you kind of see that as like the gadolinia
18 burnout, and then the core starts depleting across
19 the board.

20 Now, the big difference here is around
21 three to four out to around 12 gigawatt days per
22 MTU. Now, like when you do - when plants operate
23 and they measure what their critical boron
24 concentration is against what their predictions are,
25 generally speaking, the acceptance criteria is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 around 50 ppm, you know, so if you're within ppm,
2 you fell okay that your prediction looks good. Now,
3 here we do have an example where we're at worst case
4 about 125 ppm difference between our calculation and
5 what the simulation of the applicant is.

6 Now, you know, and I think that this is
7 a case, when you look at neutronics and you look at
8 things like what the cross-sections are doing, what
9 the core condition is from a thermal-hydraulic
10 standpoint and all of these things, I think the most
11 likely explanation here is differences in probably
12 gadolinia treatment as the core burns out.

13 MEMBER MARCH-LEUBA: So is this the
14 staff's depletion calculation?

15 MR. BIELEN: Yes, this is our - I'm
16 sorry if I didn't make that clear. Yes, this is our
17 depletion calculation.

18 MEMBER MARCH-LEUBA: But you're using
19 different cross-sections than they are?

20 MR. BIELEN: Right, like I said, our
21 cross-sections are NDF B7.1. Theirs are NDF 4.
22 However, you know, they do have their, you know,
23 benchmarking that they use from operating plants
24 where they establish the biases and uncertainties.
25 You know, we don't have that level of benchmarking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 available to us at this point because we're not
2 actually running a plant ourselves.

3 So it's possible that, you know,
4 whatever differences that they see, they've captured
5 within their biases and uncertainties. I'm not
6 really sure how, you know, the values that they
7 present here compare with whatever raw values come
8 out of their codes.

9 So next slide, please? So like I said,
10 qualitatively very good, and like I said, 50 ppm is
11 typically sort of the number I look at where I start
12 worrying that the differences are significant, and I
13 think that it's an isotopics issue. It may be an TH
14 issue as well. You know, I don't know anything
15 about what the TH solver is in ROCS. I doubt it,
16 but it's a possibility.

17 Now, you know, one thing that makes us
18 feel good about this is that the biggest differences
19 are in the middle of the cycle. However, from a
20 reactivity standpoint or a reactivity feedback
21 coefficient standpoint, your limiting values are
22 always at either beginning of cycle or end of cycle.
23 You know, you're either most positive or most
24 negative at those points.

25 So if we have bigger differences in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 middle of the cycle, a, from a safety standpoint,
2 those wouldn't be limiting times in the cycle for
3 almost all of the transient analysis in Chapter 15,
4 and b, they monitor boron concentration at the plant
5 every single day, of course. It's part of how the
6 plant operates.

7 If they're operating the plant and they
8 see, oh, geez, I've exceeded my predicted critical
9 boron concentration acceptance criteria, they would
10 have to go into their tech specs, you know,
11 reevaluate, and figure out what's going on. So
12 there are big differences here.

13 I don't feel like it's a safety concern.
14 It is something that, you know, we as the staff will
15 probably look at PARCS, you know, and sort of
16 assess, you know, where we think the issue is.

17 MEMBER MARCH-LEUBA: When I look at
18 slide 22, the previous slide, of course I just
19 looked at it, it feels to me that you're depleting
20 two isotopes at a different rate than they are.

21 MR. BIELEN: Okay.

22 MEMBER MARCH-LEUBA: You have the
23 beginning one that you depleted too fast, and
24 another one which is slower that you depleted too
25 slow.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BIELEN: Okay.

2 MEMBER MARCH-LEUBA: It feels like - I
3 mean, that's why you have that shape. One is going
4 down and the other one is going up, and then when
5 you sum them up, you get that.

6 MR. BIELEN: Okay.

7 MEMBER MARCH-LEUBA: So in my previous
8 life, depletion with PARCS, there isn't that much
9 benchmark.

10 MR. BIELEN: Right, that's, I mean -

11 MEMBER MARCH-LEUBA: It's a new - I
12 mean, we're not even able to do it. It's thanks to
13 PATHS we're able to do it now.

14 MR. BIELEN: Right.

15 MEMBER MARCH-LEUBA: So I would go with
16 the blue line as the more accurate.

17 MR. BIELEN: Right, and as I said, you
18 know, we do have benchmarking data with PARCS. I
19 would definitely say that the applicant, by virtue
20 of operating these plants, you know, has a much
21 bigger data set available to them to verify their
22 codes.

23 MEMBER MARCH-LEUBA: And the depletion
24 with PATHS, I know we've done it for one of the
25 foreign reactors and it worked very well, but there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 isn't as much experience.

2 MR. BIELEN: Right, absolutely.

3 MR. SCHULTZ: I agree with your
4 conclusion that with regard to safety analysis, the
5 conclusion is certainly valid and appropriate. At
6 the same time, operationally, this would present a
7 concern even though you can certainly modify the
8 concentrations and move through operations if you
9 had this consideration, but has the applicant -

10 It would prompt me to get more
11 information about the applicant's experience with
12 their codes for their plants for their operational
13 experience to ensure that their expectation is not
14 to see this difference -

15 MR. BIELEN: Right.

16 MR. SCHULTZ: - when they use their
17 tools, which they have proposed to use -

18 MR. BIELEN: Right.

19 MR. SCHULTZ: - in doing the analysis
20 cycle by cycle.

21 MR. BIELEN: Right.

22 MR. SCHULTZ: Have you done that to get
23 some more information about their experience base?

24 MR. BIELEN: I mean, I think I would,
25 you know - personally, no. The NRO staff that did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the review appeared to do a really good job of
2 looking at what the applicant's biases and
3 uncertainties were, you know, using DITS and ROCS.

4 I think that that review work or that
5 review effort there would have picked up and, you
6 know, you can speak to this better than I can, but,
7 you know, this seems like a large chunk of, you
8 know, what you would be concerned about, that I
9 think that those would be picked up within, you
10 know, the biases and uncertainties manual that the
11 applicant made available to us.

12 MR. SCHULTZ: Would you like to comment
13 on that?

14 MS. BURJA: Yeah, I would agree with
15 Andy on that.

16 MR. SCHULTZ: Okay, I appreciate that.
17 Thank you.

18 CHAIRMAN BALLINGER: The good news is
19 that we were ahead of schedule and so we were able
20 to accelerate things. The bad news is now we have
21 to decide on when to break. There are a number of
22 meetings that are happening at noon, and so I guess
23 we need to decide what is a good breaking point.
24 I'm looking at the slides and it doesn't look like
25 it's a great point here, but I'll leave that up to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you.

2 MR. BIELEN: I mean, I'm good to go.

3 You guys can -

4 CHAIRMAN BALLINGER: What does that
5 mean? You're here until nine?

6 MR. BIELEN: I am here at your pleasure,
7 sir.

8 CHAIRMAN BALLINGER: That doesn't answer
9 the question.

10 MEMBER MARCH-LEUBA: There are four
11 slides on 4.3. Do you think maybe you can go in
12 seven minutes?

13 MR. BIELEN: Yeah, I can certainly
14 present quickly, you know. It depends on how many
15 questions you want to ask me.

16 CHAIRMAN BALLINGER: All right, well,
17 let's push on and see what we can do, but we do
18 have, I think we have PNP at noon and another
19 meeting, so there's a fairly hard point that we have
20 to deal with.

21 MR. BIELEN: Okay, well, I can get
22 through these quickly if you let me.

23 MEMBER SUNSERI: Before you move on, I
24 just had one more question about the boron letdown
25 curve. You know, essentially, that's a measure of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the energy that's in the core, and you were talking
2 about conservative values were used. I presume you
3 looked at this and said, "Well, we're predicting
4 less energy than they are, so that's conservative."

5 Is that -

6 MR. BIELEN: Yeah, I mean, I think that
7 that's - I would put it that because they're
8 predicting a higher boron concentration, they see
9 the core as more reactive than we do, you know. I
10 have a hard time in general when you talk about
11 nuclear design saying conservative versus, you know,
12 non-conservative because, you know, it's a value
13 problem, you know, so high one place means low
14 another place, you know, but if you want to put it
15 that way, then, yes.

16 MEMBER SUNSERI: Yeah, I didn't frame my
17 question very well. I'm talking about the handoff
18 back to the safety analysis.

19 MR. BIELEN: Yeah, and I think that
20 again, because your extreme values of boron
21 concentration are still pinned at the beginning and
22 end regardless of what the path is in between the
23 two, that you're still covered in your safety
24 analysis by what you see in the core design.

25 MEMBER SUNSERI: Okay, thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BIELEN: Sure. Okay, so there are a
2 bunch of control rod banks. We looked at the worth
3 of every single one of them and compared them
4 against, and these are differences in worth versus
5 the applicant.

6 And when I say present, I mean if they
7 present a calculated 10 percent delta K over K for a
8 given rod bank worth and we calculated 11 percent
9 delta K over K, then the difference in worth is then
10 just 10 percent. Ten percent is again sort of the
11 figure of merit that I think of when I think of
12 control rod bank worths.

13 In general, we met that metric pretty
14 well, I think. And given the fact that in the
15 safety analysis, aside from your highest worth of
16 stuck rod, everything goes in, you know - I think
17 that we're doing pretty well as far as bank worth is
18 concerned. Next slide, please?

19 So this is our comparison of what the
20 trip reactivity insertion will look like at
21 different core conditions versus what they use in
22 the DCD safety analysis.

23 It's just present - this is a normalized
24 curve, so percent rod insertion from the top of the
25 core versus what the available worth is, or what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 worth is being put in at that given position, and so
2 I think that our calculations indicate that whatever
3 the DCD is using is pretty representative of what
4 you would expect in an actual cycle.

5 So talking about feedback coefficients
6 here, so when you have a fresh core that has no
7 burnable poison, so initial criticality basically,
8 or I'm sorry, no xenon/samarium, you have a limiting
9 point here where your moderator density coefficient
10 is very slightly positive, and that's actually not
11 right. That's 9.7 times 10 to the
12 minus four dollars per M cubed kilogram, and your
13 fuel temperature coefficient. So the MDC being
14 positive means the MTC is negative. Yeah, let me
15 think about this. I'm sorry.

16 MEMBER MARCH-LEUBA: Temperature goes
17 up, density goes down.

18 MR. BIELEN: Right, right, right.
19 Anyway, when you put these - so you have a point
20 here where you may have a positive MDC, or a
21 negative MDC and a positive MTC.

22 However, the fuel temperature
23 coefficient is strong enough of a contributor
24 between those two things that the overall power
25 coefficient is still negative as we indicated from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 our 4.3 review, and I think that we're, from a
2 safety standpoint, we're still where we want to be.

3 And then I think that we have run some
4 point kinetics calculations on the initial core
5 with, you know, coupled with TRACE, so we can talk a
6 little bit more about that at our Chapter 15 meeting
7 I think.

8 So next slide? All right, so power
9 distribution we feel looks really good, or at least,
10 you know, we feel good about them. The peak power
11 assemblies were within about a percent, which is
12 reasonable to excellent. We feel like the agreement
13 in the axial power distribution is also good, and
14 we're far enough away from any tech spec limits that
15 were covered by safety analysis.

16 Boron letdown, good qualitative
17 agreement, some disagreement probably due to
18 isotopic or treatment of gadolinia, and Jose, I'll
19 bring that back to the PARCS developers and see if
20 we can - if it is indeed a PARCS issue, it's
21 something that we should try to resolve.

22 MEMBER MARCH-LEUBA: I would suspect
23 it's not a PARCS issue, but it was an -- issue.

24 MR. BIELEN: Okay, all right, we'll see.
25 Our predicted bank worths were in good agreement,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and as was the reactor trip characteristics, and we
2 think that, you know, the initial cycle, based on
3 our confirmatory calcs, is very reasonably within
4 the safety box that is spelled out by the tech specs
5 and the accident analysis, so the initial cycle
6 should not challenge any of the safety analysis.
7 So, I think that's all I have.

8 CHAIRMAN BALLINGER: You're well within
9 the margin of error, including bias and uncertainty.
10 Thank you very much. Any questions from the members
11 before we break for lunch? In that case, we will
12 recess until 1:00 p.m.

13 (Whereupon, the above-entitled matter
14 went off the record at 11:56 a.m. and resumed at
15 1:01 p.m.)

16 CHAIRMAN BALLINGER: Okay, we're back in session. The floor is yours.

17 MR. WUNDER: Thank you, Mr. Chairman. I'm George Wunder and I
18 am joined now by Carl Thurston and Jim Gilmore, who
19 will be doing the Staff presentation on Section 4.4.
20 Carl, please?

21 MR. THURSTON: Okay.

22 CHAIRMAN BALLINGER: Same rules apply as
23 this morning.

24 MR. THURSTON: Didn't see it. My name is
25 Carl Thurston and I'm a recent transfer from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Office of Research and I will present the Staff's
2 evaluation of Section 4.4, Thermal and Hydraulic
3 Design.

4 Since the RCS design and configuration
5 is essentially that of the System 80+, the review is
6 primarily focused on confirming the applicability of
7 previously approved CE methods and the Applicant's
8 Technical Reports.

9 So, first of all, the key areas that we
10 reviewed included thermal and hydraulic design of
11 the RCS, the core in RCS, confirming that acceptable
12 analytical methods were used. Largely, the methods
13 were largely based on System 80 and System 80+ data,
14 confirming acceptable margins against conditions
15 leading to fuel damage during normal operation and
16 AOOs and confirming that the design is not
17 susceptible to thermal-hydraulic instability.

18 The key areas also included calculated
19 core parameters to establish minimum DNBR hydraulic
20 loads on the core and RCS during normal operation
21 and DBA conditions. The loads were extrapolated
22 from System 80 flow data, primarily Palo Verde. We
23 also confirmed negligible differences in APR1400
24 core geometry and operating parameters, as compared
25 to System 80+ and System 80 designs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BALLINGER: Back to the last
2 point, negligible differences between System 80+ and
3 System 80, have there been measured core bypass
4 numbers for those cores?

5 MR. THURSTON: The core bypass flow is
6 the same in the DCD. Jim, if you have any?

7 MR. GILMER: As far as I've seen, I don't
8 think even Palo Verde has measured the bypass.

9 CHAIRMAN BALLINGER: Okay. Just curious
10 as whether something was actually done on it.

11 MR. GILMER: We'll take that up with our
12 colleagues in NRO to --

13 MR. LU: Shanlai Lu, from Staff, so, even
14 for System 80, 80+, at Palo Verde was not
15 measurable.

16 CHAIRMAN BALLINGER: Okay.

17 MEMBER MARCH-LEUBA: So, let's follow-up
18 on that. The assumption then is that this source
19 that does not have really significant impact on the
20 worth measuring, I guess. For the bypass flow.

21 CHAIRMAN BALLINGER: Member Skillman
22 showed me some calculations where, if you're off by
23 a few thousandths of an inch, you can make a huge
24 difference in bypass flow.

25 MEMBER MARCH-LEUBA: Yes. If it was my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plant, I would like to measure it.

2 MR. LU: Okay. I think the way they
3 approach the bypass flow is really -- oh, sorry.
4 Here? Okay. The way they approach the bypass flow,
5 by itself, you look at how to calculate the
6 resistance itself.

7 It's really, the core condition,
8 calculating can be different. If you have thermal
9 expansion, you have different. So, all those bypass
10 flows in terms of percentage wise are so small at
11 this point, it's considered as part of the
12 uncertainty.

13 CHAIRMAN BALLINGER: Okay.

14 MR. LU: All right.

15 MEMBER MARCH-LEUBA: That is a good
16 answer.

17 MR. LU: That's part of uncertainty.

18 MEMBER MARCH-LEUBA: It's basically what
19 I was saying before --

20 MR. LU: Right.

21 MEMBER MARCH-LEUBA: -- but in a more
22 coherent way.

23 MR. LU: That's right.

24 MEMBER MARCH-LEUBA: That you can bury it
25 into the uncertainties.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. LU: That's right.

2 CHAIRMAN BALLINGER: Okay.

3 MR. LU: So, I don't want to take Alex --
4 any other questions about the bypass before we go
5 forward? I'm just trying to -- if no other
6 questions, then I'm off the table.

7 MR. WUNDER: Thank you for that. Okay.

8 MR. THURSTON: So, we're continuing with
9 the areas of review. So, the areas of review also
10 included uncertainty analysis methodologies, namely
11 Statistical Combination of Uncertainties, to ensure
12 that at least 95/95 confidence level that the hot
13 fuel rod does not experience DNBR during normal
14 operations, AOOs.

15 CPCS, core protection calculator system,
16 interfaces that support DNBR and local power density
17 safety limits. COLSS, core operating limits
18 supervisory system, interfaces with the CPCS that
19 support Chapter 7 reviews.

20 And computation of CPCS parameters
21 needed for core reload. Staff also noted that
22 reactor protection system design and operation,
23 namely the COLSS and CPCS, is essentially that of
24 the Palo Verde System 80.

25 So, the Technical Reports we reviewed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 included Thermal Design Methodology. This report
2 described overall CE methodology based on approved
3 TORC and CETOP codes, with the KCE1 CHF correlation
4 and CE methodology for statistical uncertainties
5 methods used to ensure 95/95 confidence level that
6 hot fuel rod does not experience DNBR during normal
7 operations or AOOs, consistent with SRP, including a
8 penalty for rod bow.

9 The Technical Reports also included
10 Functional Design Requirements for CPCS for the
11 AP1400 and Functional Design for the COLSS. These
12 described CE methods based on approved methodology
13 used at Palo Verde, but also implemented at San
14 Onofre, ANO-2, and Waterford.

15 The CPCS protection software design
16 assures 95/95 confidence that DNBR and LPD limits
17 are maintained. Procedures for development of CPC
18 constants will be developed by the COL holder,
19 consistent with existing procedures for operating
20 System 80 plants.

21 The next Technical Report was CPC
22 Setpoint Analysis. This report describes how CPCS
23 computes changes in linear power density and
24 describes measurements of core conditions for peak
25 power density and DNBR based on ex-core instrument

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 measurements.

2 And CPC uses monitored parameters to
3 calculate LPD and DNBR margin to trip limits.
4 Cycle-dependent uncertainties associated with CPC
5 trip point settings are combined such that the
6 adjusted LPD and DNBR setpoints are always
7 conservative.

8 The next Technical Report is Uncertainty
9 Methodology and Application for Instrumentation.
10 This report describes methodology used to combine
11 uncertainties to ensure that plant protective
12 functions activate at desired values under normal
13 and accident conditions, and is essentially the same
14 as the CE Topical Report CEN-356 approved by Staff
15 in 1988.

16 The next Technical Report is Setpoint
17 Methodology for Plant Protection System. It
18 describes methodologies used to establish setpoints
19 to be used for ex-core plant protection system trip
20 settings. PPS functions contain the other RPS trips
21 and the ESFAS trips.

22 Setpoints established such that during
23 DBEs, the analytical limit is not exceed and the
24 analytical limits are established such that safety
25 limits are not reached and the safety limits assure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that unacceptable consequences do not occur during
2 Design Basis Events.

3 So, I'll next review some of the
4 challenging areas of review that we encountered.
5 This one is concerning the CPCS and COLSS functions
6 and interfaces. The basis for the CPCS was not well
7 documented in the System 80+ DCD.

8 KHNP followed the System 80+ DCD, but
9 did not link references to post-1980 functional
10 changes and improvements to the current System 80
11 design. So, we had a concern that the documentation
12 was not adequate to assure -- for us to make a
13 safety finding that the design was correct and safe.

14 The Staff conducted an audit in January
15 2016 to address the issue. The issue was ultimately
16 resolved by finding the CE references and confirming
17 that the functionality are based on approved and
18 implemented changes at Palo Verde.

19 MR. SCHULTZ: Carl, just a moment there.
20 This goes back to a slide that was, I guess it's
21 Slide 31, which states that the procedures for the
22 CPCS constants were developed using existing
23 procedures for the System 80 plants, existing
24 procedures. This seems to suggest -- so, that's
25 what -- so, now, you're saying that you needed to go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 back and validate that?

2 MR. THURSTON: No, we're saying that the
3 COL holder will need to develop procedures similar
4 to the procedures that already exist for existing
5 System 80 plants.

6 MR. SCHULTZ: Similar to?

7 MR. THURSTON: Similar to.

8 MR. SCHULTZ: Okay.

9 MR. THURSTON: That's the intent.

10 MR. SCHULTZ: All right. But, I guess my
11 question is, is there sufficient guidance for the
12 COL to do that?

13 MR. THURSTON: Jim?

14 MR. GILMER: There's really -- there is
15 some guidance in, I believe, CEN-201 and --

16 MR. SCHULTZ: Okay.

17 MR. GILMER: -- I don't remember, but --

18 MR. SCHULTZ: That sounds like the right
19 number to me, but go ahead.

20 MR. GILMER: Yes. And we looked at the
21 existing procedures for Palo Verde, as well as the
22 recently commercial Shikori 3. KHNP routed --

23 MR. SCHULTZ: Okay.

24 MR. GILMER: -- that to us. So, we
25 compared that to Palo Verde's procedures and felt

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that it was adequate. But we just ask that they
2 include a COL holder item to develop the procedures.

3 MR. SCHULTZ: To make sure that that was
4 done by the holder?

5 MR. GILMER: Correct.

6 MR. SCHULTZ: Okay. Thank you. I
7 understand. But you reviewed that that had been
8 done previously --

9 MR. GILMER: Correct.

10 MR. SCHULTZ: -- so, it should be
11 appropriately applicable going forward?

12 MR. THURSTON: That's right.

13 MR. GILMER: Correct. For ANO-2, San
14 Onofre, and Palo Verde.

15 MR. SCHULTZ: So, what you did was
16 prescribe that in the future, it would be, what I
17 suggested needed to be done would be done?

18 MR. GILMER: That is correct.

19 MR. SCHULTZ: All right. Thank you.

20 MR. THURSTON: Okay. So, the next area
21 of challenging review involved single-sided versus
22 double-sided confidence. The Applicant used a
23 Statistical Combination of Uncertainties methodology
24 and we reviewed that methodology to confirm that the
25 DNBR safety limit of 1.124 being converted to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analytical limit of 1.29 was correct with the 95/95
2 confidence level.

3 And we found out that, basically, they
4 had used a previous Revision of 1.125, or, excuse
5 me, 1.105, which is the Reg Guide. And that Reg
6 Guide had been updated since the CE methodology was
7 approved and KHNP was following the previous
8 methodology that CE had used prior to this Reg Guide
9 being updated in 1999.

10 So, single-sided methodology was based
11 on the CEN-356 approved by the Staff in 1989, but,
12 again, that's prior to the change in the Reg Guide
13 in 1999. So, there -- and there's some other people
14 that can speak to this. Joe?

15 MR. ASHCRAFT: Joe Ashcraft.

16 MR. THURSTON: Yes, it's a Chapter 7,
17 really, item that affects our Section because of the
18 1.29 analytical limit.

19 MR. ASHCRAFT: This is Joe Ashcraft, I'm
20 NRO I&C. So, a colleague originally started this
21 review of this methodology, along with the setpoint
22 methodology, however, at some point, he went to a
23 different job, so I took over.

24 So, there is an RAI to Chapter 7 that
25 discusses this issue of the use of the -- they're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 using a conversion of 1.645 and, effectively, that
2 just decreases the margin. So, Rev. 3, which
3 requires the 95/95 confidence level, the Staff, NRO
4 Staff, we did not accept that use of 1.645 ratio.
5 So, that's the point at this time.

6 So, from our viewpoint, those two
7 setpoints are safety-related and are required to be
8 in conformance with Reg Guide 1.105 Rev. 3, as their
9 DCD stipulates at this time. So, we're not arguing
10 that this methodology that's been existing since
11 1980 is not valid, because it's an algorithm kind of
12 thing that we punt to reactor systems.

13 Our RAI basically says that use of that
14 ratio of 1.645 over a two sigma value does not meet
15 1.105 Rev. 3. There are some other minor issues,
16 but that's probably the major sticking point. We
17 have been in conversations with the Chapter 7 staff,
18 KHNP staff on this issue, and we presented some of
19 our questions via a setpoint audit that they're now
20 going to resolve or answer. So, that's where we
21 stand from a Chapter 7 perspective.

22 MR. THURSTON: Thank you, Joe. So, now -
23 -

24 MEMBER SUNSERI: So, if we go to the
25 double-sided confidence level versus the single,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what's the impact on this number then?

2 MR. THURSTON: It would probably go up.

3 MEMBER SUNSERI: Does it change it --

4 MR. THURSTON: It would.

5 MEMBER SUNSERI: -- substantially?

6 MR. THURSTON: I think so. We haven't
7 crunched the numbers, it's a very complicated
8 calculation.

9 MR. ASHCRAFT: This is Joe Ashcraft
10 again. Just from our experience, from setpoint
11 arena, not necessarily this methodology, but when
12 you use that single-sided ratio, it impacts the
13 margin between your safety limit or analytical limit
14 and your LSSS setpoint by approximately 18 percent.

15 MR. THURSTON: So, quite a bit.

16 MR. SCHULTZ: So, Joe, the -- I'm sorry
17 to pull you back, it should be a simple answer,
18 because it's just a repeat-back so I understand.
19 The expectation, then, is that there will be a
20 clarification from the Applicant to identify clearly
21 what Revision they are performing the analysis to,
22 the single-sided confidence levels approach, and if
23 they wanted to take advantage of Rev. 3, they would
24 have to come back? Come back for approval?

25 MR. ASHCRAFT: Right. So, from Chapter 7

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff of KHNP that we've talked to, we more or less
2 presented -- so they could continue to say they meet
3 1.105 Rev. 3, which they would have to come back
4 with more information.

5 However, a path forward that we
6 presented that could work as well, since this
7 methodology has been in use since the 1980s, would
8 be to take exception for these two setpoints and
9 denote in Chapter 1 that these two setpoints do not
10 meet 1.105 Rev. 3 and that they meet the regulations
11 per this methodology that Chapter 4 Staff has
12 reviewed. And there's a few minor changes in
13 Chapter 15 and Chapter 7 that would have to take
14 place, but then, we would have no issue.

15 MR. SCHULTZ: So, you're clarifying to me
16 that they have, they still have two paths to reach
17 resolution, but they've got to choose one and go
18 forward?

19 MR. ASHCRAFT: Exactly. And that's how
20 we presented it to the Chapter 7 staff. I don't
21 know if Chapter 4 staff was made aware of that
22 conversation, which happened last week.

23 MR. SCHULTZ: Understood, thank you.

24 MR. THURSTON: So, we can conclude for
25 Section 4.4, the Staff findings that, basically, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 GDC 10, the SAFDLs are not exceeded during normal
2 operation and AOs and, GDC 12, suppression of
3 reactor power oscillations can be reliably detected
4 and suppressed.

5 In summary, the Staff notes that the
6 thermal design methodology depends heavily upon
7 codes and methods previously approved by Staff for
8 domestic CE plants. The APR1400 thermal hydraulic
9 design is comparable to System 80+, with small
10 differences due to the slight increase in power,
11 less than two percent. And the Staff concludes that
12 the design provides adequate assurance that the
13 reactor will perform its related safety functions
14 under all modes of operation, pending completion of
15 open items.

16 MEMBER KIRCHNER: So, may I ask, the
17 existing fleet of CE designs that share a lot of the
18 same background, they're using the previous version
19 of Reg Guide 1.105?

20 MR. THURSTON: Correct.

21 MEMBER KIRCHNER: So, you're saying that
22 if they just make a change to reference Rev. 2,
23 that's acceptable?

24 MR. THURSTON: That's one path forward.

25 MEMBER KIRCHNER: Okay. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. THURSTON: Thank you. Jim, you --

2 MR. GILMER: Were there any more
3 questions before -- I wanted to address Dr. Rempe's
4 question from this morning on the KCE1 correlation.
5 One of the references in the Staff SE for 4.4 is the
6 vendor inspection of the software quality assurance.
7 So, I have a reference for that, I can give you an
8 ADAMS number and --

9 MEMBER REMPE: Please send it to Chris,
10 who's not in the room right now.

11 MR. GILMER: Okay. I'll --

12 MEMBER REMPE: Where is Chris?

13 MR. GILMER: I'll send it to him.

14 MEMBER REMPE: Yes, please send it to him
15 and -- yes.

16 MEMBER MARCH-LEUBA: He's likely in the
17 locker room.

18 MEMBER REMPE: Okay. So, yes, if you'll
19 send it to us, that would be great.

20 MR. GILMER: Okay. I was going to say
21 that this inspection was focused on three codes,
22 RELAP, CSAC-3 and CETOP-D, but in the process of the
23 inspection, we also examined all of the records for
24 both TORC and the older version of CETOP, as well as
25 the implementation of the KCE1 correlation and their

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 validation. And they basically did it identically
2 for the CETOP-D and the CETOP.

3 MEMBER REMPE: Okay.

4 MR. GILMER: And there's a statement in
5 the vendor inspection report that the inspection
6 team verified the thermal margin preserved by CETOP-
7 D is conservative with respect to analysis performed
8 with the TORC.

9 MEMBER REMPE: Thank you.

10 MR. GILMER: So, the dots may not be most
11 clearly connected, but --

12 MEMBER REMPE: But they are.

13 MR. GILMER: -- there is a reference.

14 MEMBER REMPE: Okay, thank you.

15 MR. GILMER: Okay. Further questions on
16 this Section?

17 MR. WUNDER: Okay. I guess that's it for
18 Section 4.4. If we could have our Section 4.5
19 people come up now? We've been joined by John
20 Honcharik and Dan Widrevitz, of our Materials and
21 Chemical Engineering Branch.

22 MR. HONCHARIK: Hello, my name is John
23 Honcharik. I'm a Senior Materials Engineer in NRO
24 Division Engineering and I reviewed the Section
25 4.5.1, CRDs, so today, I'll present to you the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 materials that were proposed in the design, based on
2 the application and also the responses to RAIs.

3 As you can see here, material selection
4 and fabrication techniques and heat treats and
5 cleanliness control were in accordance with the
6 NUREG-0800. The materials that were used for the
7 pressure boundary parts of the CRD were consistent
8 with other designs and have satisfactory operating
9 experience.

10 Some of the materials used were
11 stabilized stainless steels, martensitic stainless
12 steels, nickel alloys, basically alloy 690 that are
13 thermal treated, and austenitic stainless steels 304
14 and 316, and the associated filler metals.

15 For the materials for the non-pressure
16 boundary components, they were also consistent with
17 other designs and have very good operating
18 experience. And they also included austenitic
19 stainless steels 316, 321, and 204, and martensitic
20 with certain types of heat treating and also,
21 nickel-based alloy X-750 and alloy 625.

22 Now, I'll discuss the fabrication
23 techniques proposed with the cleanliness
24 requirements. Basically, with the austenitic
25 stainless steel base materials, they're going to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consistent with the recommendations that are in the
2 Reg Guide 1.44 and, basically, the procedures,
3 including welding procedures, will be demonstrated
4 and tested to make sure that they don't sensitize
5 the stainless steel components.

6 Also, the controls for abrasive work and
7 grinding and cleaning are going to, basically, be in
8 accordance with criteria in Reg Guide 1.28 and ASME
9 NQA-1. The heat treats for some of these alloys
10 were consistent with NUREG, including the operating
11 experience, such as alloy X-750, which is heated to
12 at least 1,149 degrees C, and Type 410 Condition T,
13 heat treated above 565 degrees C.

14 CHAIRMAN BALLINGER: I have a question
15 here.

16 MR. HONCHARIK: Yes?

17 CHAIRMAN BALLINGER: In Chapter 4, it
18 lists this alloy X-750 heat treatment, that's not a
19 heat treatment, that's a solution treatment. Most
20 of the times, X-750 and these others are followed by
21 an age.

22 MR. HONCHARIK: Right.

23 CHAIRMAN BALLINGER: In Chapter 4, it
24 says that the heat treatment is designed to be
25 resistant to stress corrosion cracking, but that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 heat treatment -- is that true, that you're just
2 going to use it in the solution and the
3 conditioning?

4 MR. HONCHARIK: Yes. Because that might
5 -- yes. It's basically a solution anneal.

6 CHAIRMAN BALLINGER: So, that's it?

7 MR. HONCHARIK: That's it. And not doing
8 any other -- you're using the solution anneal.

9 CHAIRMAN BALLINGER: Okay. And the same
10 thing goes for the A-276? No, the 410?

11 MR. HONCHARIK: Yes, from what I can
12 remember.

13 CHAIRMAN BALLINGER: That's more likely
14 the 410?

15 MR. HONCHARIK: Right.

16 CHAIRMAN BALLINGER: Okay. All right.
17 That's an unusual heat treatment.

18 MR. HONCHARIK: And then, the last thing
19 I want to talk about is the only remaining issue
20 that we had was dealing with the venting device,
21 that is called Versa Vent. The Versa Vent is used
22 to vent the CRD to minimize the levels of oxygen in
23 these dead-leg areas.

24 I guess, right now, the Applicant
25 considers the Versa Vent to be a non-pressure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 boundary component, even though it replaces a
2 pressure boundary component. So, the Staff
3 considers it pressure boundary and also, the Staff
4 requested that the material specifications and types
5 be provided so that Staff can review what the
6 material is for compatibility with the other
7 materials. A response has been received and is
8 currently in evaluation.

9 As part of this issue, there is another
10 open item and it deals with the Versa Vent and
11 whether or not there is operating experience with
12 data that shows that venting during these refueling
13 outages will reduce the oxygen levels, so that non-L
14 grade stainless can be used. And they've provided a
15 response and so far, that response has a lot of data
16 and operating experience for that, so that looks
17 pretty good. And that concludes my talk on CRD
18 materials.

19 MR. WIDREVITZ: All right. So, can we
20 actually start on Slide 41, please? My slides were
21 backwards. So, off to a good start. Section 4.5.2,
22 I am Dan Widrevitz. Section 4.5.2 is on Reactor
23 Internals and Core Support Materials.

24 The Staff review focuses on the topic
25 areas of material specifications, selection, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 heat treatments, controls on welding, nondestructive
2 examination, austenitic stainless steel issues,
3 other material issues, and other degradation
4 mechanisms, specifically IASCC and void swelling.

5 So, in terms of this review, this design
6 is very consistent with industry practice and
7 previous experience. So, the Applicant had a very
8 high level of adherence to what we consider
9 appropriate controls, such as Reg Guides on
10 sensitization and on cleanliness.

11 The Staff RAIs primarily focused on
12 clarification and completeness, getting to the same
13 page of what needs to be in a DCD and what the Staff
14 needed to adequately review on the topics.
15 Certainly, we were happy with where we ended up at
16 the end and I'm wondering, I heard some questions
17 earlier during the KHNP section, I was wondering if
18 you wanted to bring up anything here for me.

19 CHAIRMAN BALLINGER: A few of us are
20 mystified about the use of cobalt in some of these
21 CRDMs and stuff like that and we're just curious
22 about that whole issue. You're comfortable with --
23 I mean, it's a maintenance issue, when it comes
24 right down to it, but, yes, are you comfortable with
25 that?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WIDREVITZ: For my part, it's not any
2 different than what we've been seeing in a lot of
3 the existing reactors and they haven't had
4 particular trouble. There's -- obviously, we don't
5 spray it on every corner of the internals, but
6 there's a couple places where you want it for hard-
7 facing.

8 CHAIRMAN BALLINGER: Yes. I guess I
9 thought differently. That there was a big effort to
10 get cobalt out --

11 MR. WIDREVITZ: Yes, and there's --

12 CHAIRMAN BALLINGER: -- of the primary
13 systems --

14 MR. WIDREVITZ: It is mostly out.

15 CHAIRMAN BALLINGER: -- for sure.

16 MR. WIDREVITZ: It's mostly out, but
17 there's still a few places where its used.

18 MR. HONCHARIK: Yes, this is John
19 Honcharik. Most -- I think Dan's right. They've
20 tried to minimize it, but there are certain areas
21 where they can't. So, they have to use that still,
22 like for the hard-facing.

23 Sometimes, they tried to use some of the
24 chromium oxide to do it, but in certain areas, it
25 won't get the wear properties, so they need to use

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that. So, they tried to reduce it, but they can't
2 go away from it. And other designs are similar in
3 that respect.

4 CHAIRMAN BALLINGER: I recall some time
5 ago where they had a very large program at EPRI to
6 eliminate, to find a suitable replacement, and they
7 failed.

8 MR. HONCHARIK: Right.

9 CHAIRMAN BALLINGER: For some
10 applications. Thank you.

11 MR. SCHULTZ: Is this hard-facing on the
12 control rods systems or is it on the guide tubes or
13 neither?

14 MR. HONCHARIK: There are some small
15 little, like, pins and stuff that are in the CRD,
16 where they need hard-facing, and latch mechanisms.
17 So --

18 MR. SCHULTZ: Oh, okay.

19 MR. HONCHARIK: -- other than that, I'm
20 not sure how much --

21 MR. SCHULTZ: On the drive mechanisms?

22 MR. HONCHARIK: Yes. Most of it, I
23 think, is in the CRDs. There might be very minimal
24 in --

25 MR. WIDREVITZ: It's in similar --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HONCHARIK: -- reactor internals.

2 MR. WIDREVITZ: -- locations in the
3 reactor internals --

4 MR. HONCHARIK: Yes.

5 MR. WIDREVITZ: -- where there's latches.

6 MR. SCHULTZ: I understand. Thank you.

7 MS. BURJA: All right. Again, my name is
8 Alex Burja and I will present to you the Staff's
9 review of DCD Section 4.6, Functional Design of
10 Reactivity Control Systems.

11 I'll start out by saying that in the
12 Staff's review, there were no new or significant
13 issues that came up, as it's a pretty industry
14 standard design. So, I'll just go over the areas of
15 review and then, offer conclusions, as there were
16 really no challenging areas of review.

17 So, in terms of the functionality and
18 arrangement of the control rod drive system, or
19 CRDS, it's pretty standard. It consists of control
20 element drive mechanism, or CEDMs, and the digital
21 rod control system, or DRCS.

22 And during normal operation, the DRCS
23 actuates the CEDMs to insert or withdraw the CEAs.
24 Under conditions of reactor trip, the trip switch
25 gear removes power from the DRCS, which would de-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 energize the CEDM coils and drop the CEAs into the
2 core. So, fairly standard.

3 The Staff also reviewed the
4 environmental and seismic qualifications of the
5 CRDS, since the CRDS needs to remain functional
6 during and after design basis events and be able to
7 withstand harsh environments.

8 In addition, the Staff ensured that the
9 CRDS cooling system meets the design requirements so
10 that the CRDS can remain functional. In addition,
11 the Staff examined possible single failures of the
12 CRDS to ensure that no single failure will affect
13 the essential trip function or result in violating
14 SAFDLs.

15 The Staff also looked at the testing and
16 verification for the CRDS. So, testing for the
17 CEDMs is actually done under SRP Section 3.9.4, but
18 in terms of this review, the Staff looked at the
19 initial test program for the CRDS to ensure that
20 there was enough in there to verify the
21 functionality of the CRDS. In addition, the Staff
22 looked at the ITAAC and tech spec surveillance
23 requirements for scram time, which serve as
24 experimental verification that the trip function
25 will work.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The Staff also reviewed the combined
2 performance of reactivity control systems. So,
3 basically, how the CEAs work together with the
4 soluble boron from the CVCS, as well as safety
5 injection system to mitigate transience and
6 postulated accidents.

7 And ultimately, the Chapter 15 transient
8 and accident analyses will show that the reactivity
9 control systems are capable of working together to
10 control the reactivity changes during design basis
11 events.

12 The Staff also reviewed possible common
13 mode failures of the reactivity control systems.
14 And since these systems are completely independent,
15 the Staff identified no potential common mode
16 failures besides the possibility of postulated pipe
17 breaks and associated missiles. And that review is
18 conducted under SRP Section 3.6.

19 Finally, the Staff reviewed tech spec
20 requirements for the reactivity control systems,
21 such as rod insertion and alignment limits and
22 charging flow limits, to ensure that there are
23 appropriate limits on reactivity control.

24 So, in conclusion, the Staff finds that
25 the CRDS, in conjunction with the other reactivity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 control systems, meets GDC 4, 23, and 25 through 29,
2 for a number of reasons, including the design
3 qualification and physical protection of the CRDS
4 provide reasonable assurance that it will remain
5 functional and be able to safely shut down the
6 reactor under adverse environmental conditions and
7 after postulated accidents.

8 In addition, the CRDS is proven to fail
9 in a safe condition. Also, no single malfunction in
10 the CRDS will result in exceeding SAFDLs, as was
11 demonstrated in failure modes and effects analyses
12 and as will be shown in the Chapter 15 transient and
13 accidents analyses. Also, the CRDS and CVCS are
14 independent reactivity control systems based on
15 different design principles and are capable of
16 reliably controlling the rate of reactivity changes
17 during normal operation.

18 MR. SCHULTZ: Alex, they're --

19 MS. BURJA: Yes?

20 MR. SCHULTZ: They're independent, so
21 each are capable of reliably controlling the rate of
22 reactivity changes?

23 MS. BURJA: That --

24 MR. SCHULTZ: Each are capable of?

25 MS. BURJA: That's true. So, both are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 provided, because the CEAs do the short-term
2 reactivity control and then, the soluble boron is
3 there for the long-term control. But the
4 requirements for soluble boron, for instance, are,
5 like, being able to hold the core sub-critical under
6 cold conditions, that's also part of the GDC. But
7 each system is capable of performing the reactivity
8 control requirements.

9 MR. SCHULTZ: Without the other? That's
10 what I want to get to?

11 MS. BURJA: Not without -- so, we need, a
12 design needs both of them.

13 MR. SCHULTZ: I understand that, but in
14 terms of capability, are they independently capable
15 of controlling the reactivity changes under normal
16 operation?

17 MS. BURJA: I'm not really sure how to
18 answer that.

19 MR. SCHULTZ: Okay.

20 MR. LU: This is Shanlai Lu, from Staff.
21 Steve, yes, the answer is yes and they bank them
22 together depends on the different banking and for
23 the safety shutdown rod or whatever the control rod
24 there. But that's related to the independence of
25 the control system of the Chapter 7 review.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCHULTZ: Okay.

2 MR. LU: But the answer to your question
3 is, yes.

4 MR. SCHULTZ: Thank you.

5 MS. BURJA: Okay. Picking up where I
6 left off, the Chapter 15 transient and accident
7 analyses demonstrate that the reactivity control
8 systems can work together to control the reactivity
9 changes during design basis events. In addition,
10 the reactivity insertion limits in the tech specs
11 help to or will prevent a prompt power excursion.

12 Finally, the design and testing of the
13 reactivity control systems ensure an extremely high
14 probability that they will accomplish their safety
15 function during AOOs. In addition to the
16 conclusions about the GDC, the Staff was also able
17 to conclude that the CRDS cooling system meets the
18 design requirements.

19 In addition, the initial test program is
20 adequate to verify the reactivity control systems.
21 And the tech specs related to the reactivity control
22 systems are adequate and are consistent with the
23 requirements that are identified from the transient
24 and accident analyses. That concludes what I have
25 for Section 4.6. Are there any questions at this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 time?

2 MEMBER REMPE: Okay. So, I don't have
3 any on this Section, but I have something, just a
4 higher level question about the -- that came up
5 today about Section 4. And, actually, Matt started
6 the questioning and I've been trying to follow it
7 up. Is it okay to bring that up now or do people
8 have questions on this? Okay.

9 So, earlier today, Matt mentioned the
10 load-following question and KHNP came back with the
11 RAI 2938332, which was issued in November 2015, and
12 it clearly identifies the Staff's concern about the
13 use of the word load-following and, actually, it
14 shows up in many Sections, and in Section 4, the way
15 that, in my opinion, which doesn't count for
16 anything, since I'm a single member, but they
17 addressed it fine in Section 4, but in Section 3,
18 I'm not so happy with it, and it doesn't even
19 mention Section 10, or Chapter 10.

20 And I'm just wondering what the Staff's
21 position is. And the reason I'm asking it is, to
22 me, it would behoove the Staff in the draft SEs to
23 identify in each Section, even though they said they
24 can load-follow, we didn't do this.

25 And the reason why I think it might be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 important is, we've had two examples in design
2 certifications where, and I'm sure that won't happen
3 or it may not ever happen with this organization,
4 but other organizations have pulled out midway
5 through and if somebody comes back five years from
6 now and says, oh, we're going to try and certify it
7 again, where are we and why not document it? And
8 why isn't that occurring with the Staff's SEs?

9 MR. LU: Okay. I think I'll jump and
10 then, Alex, if you want to provide more answer, that
11 would be better. We did see, right at the beginning
12 we saw the DCD document and, oh, we want to have a
13 load-follow. I said, oh, when you have a load-
14 follow, your core design can be quite challenging.

15 So, the real question here, from 4.3,
16 nuclear design perspective, is, do you really want
17 to do load-follow? When you do load-follow, that
18 means you have very quick core responses, your
19 reactor system, the bank design, the control design,
20 the power shift has to be designed so well that you
21 can really do that a couple minutes load-follow,
22 within very quick transit.

23 So, we asked them, do you really want to
24 do that? If you want to do that, we are going to
25 impose different requirement on the core side of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design in terms of the reactor near the control, the
2 drive system, and also all the neutronic design
3 perspective. So, we ask the clarification question.
4 They said, oh, every intention was for base load.

5 MEMBER REMPE: Right.

6 MR. LU: So, from a 4.3 perspective,
7 because they designed it to go back to the just
8 normal power maneuver, because even you base load a
9 reactor, you start to have startup, your power goes
10 up, right, and then, when the power goes down, you
11 still can go down, it's not something you have
12 constant power all the time throughout the entire
13 cycle.

14 But they do not do load-follow. So,
15 from the core side, in terms of after they respond
16 to us, that's not their intention, we are fine with
17 the current submitted design, under the 4.3 for the
18 core. Then, let's go back to your question, relate
19 to other Sections, other Chapters --

20 MEMBER REMPE: And the process.

21 MR. LU: And the process.

22 MEMBER REMPE: Why not draw --

23 MR. LU: Okay.

24 MEMBER REMPE: Clearly, because I saw
25 this reference to that RAI --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. LU: Yes.

2 MEMBER REMPE: -- where you said, hey,
3 it's just a terminology thing --

4 MR. LU: Right.

5 MEMBER REMPE: -- but they have a whole
6 section --

7 MR. LU: It's not a simple word, from
8 load-follow to power maneuver is quite significant -
9 -

10 MEMBER REMPE: Right.

11 MR. LU: -- from the core perspective.
12 So, our side is for 4.3 presentation, our SER, is
13 focused on the core side. Now, let's go back to the
14 question related to the turbine. And in turbine, if
15 you have a very quick load drop, the turbine can be
16 fine.

17 It's not a safety issue from our
18 perspective, from a reactor system design
19 perspective. It's that really issue where you
20 impact the other transient or other in Chapter 15,
21 it should be bounded by the existing Chapter 15
22 safety analysis.

23 So, is there really a big problem for
24 other Sections? I think, right now, I think that's
25 a good question and then, I think we resolve the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 issue for 4.3, the question here is whether it needs
2 to be propagated to other Sections, and that's
3 something we can talk about.

4 MEMBER REMPE: Well --

5 MEMBER RAY: Let me make one comment
6 here. The -- you're talking about the core properly
7 and everything you've said, I take no exception to,
8 but the plant can load-follow by bypassing steam to
9 the condenser, just like Palo Verde has 100 percent
10 capability.

11 MR. LU: True.

12 MEMBER RAY: So, you've got to be a
13 little careful in talking about the plant, that
14 you're not confusing it with limitations on the
15 core.

16 MR. LU: That's right. I agree, yes.

17 MS. KARAS: This is Becky Karas, if I can
18 just add? And I think I understand where you're
19 going philosophically, that if there's in other
20 Sections statements that the plant has the
21 capability to load-follow, right, and if Chapter 4
22 says something different, I think you're asking, is
23 that a process problem or is that going to cause
24 confusion later when the DC comes for renewal or
25 something like that?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And I think our point is, within Chapter
2 4, it's clear that that's not the intent and that's
3 not assumed, but in other Sections, if the plant has
4 the capability for load-following, I don't think you
5 would necessarily go and change those Sections if
6 that capability is there.

7 You still have the restriction on the
8 analytical assumptions and what's okay in terms of
9 Chapter 4, that that would still limit you. And
10 then, you would know what you'd need to look at in
11 the future, if there would want to be a change to
12 that. But it's really a restriction within the
13 Chapter 4.

14 MEMBER REMPE: But, again, I guess, it's
15 very vague in Chapter 4, you say, hey, they had a
16 terminology issue, we didn't bring it up here, and
17 you refer to that RAI. You don't say, hey, they
18 said they could load-follow and we reviewed it and
19 said they need to change that.

20 And I just am wondering, is that just
21 the normal way that the Staff would do a design
22 certification and if everyone backed off and said
23 tomorrow, we're done, and that's happened in other
24 design certifications, is it really clearly
25 documented?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Why not say -- and there's been other
2 terminology issues, whether it's a multi-unit or a
3 single-unit plant, and I just am wondering is that
4 normal, and, again, even though I've been on ACRS
5 for quite a few years, the Staff wouldn't clearly
6 say, hey, we didn't agree with them on this and we
7 made them change it? It seems like a pretty
8 significant thing on the load-following.

9 MS. KARAS: Well, remember, within the
10 design certification, right, the certified design is
11 what's written in the DCD. So, I think I
12 understand, and Alex can correct me if I'm wrong,
13 that the language within Chapter 4 of the DCD, that
14 that language is going to be clarified, I think, as
15 a part of the response, right?

16 MS. BURJA: That's right.

17 MS. KARAS: So, that is in fact the
18 design, so with that language being corrected there,
19 then that's what the design is. You don't
20 necessarily have to have an extensive write-up in
21 the SER, because the design itself is what's in the
22 DC.

23 MS. BURJA: Right.

24 MS. KARAS: It's not like --

25 MEMBER REMPE: So, you're telling me,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it's okay that we were kind of vague here and we
2 didn't explicitly call it out, that's just what
3 we've got.

4 MS. KARAS: Right, you just don't want
5 the words within the DCD that says it's load-
6 following capable within Chapter 4.

7 MEMBER REMPE: But it does right now in
8 what was submitted.

9 MS. KARAS: But I think that's what's
10 being --

11 MEMBER REMPE: The RAI says they're --

12 MS. KARAS: -- clarified, corrected.

13 MEMBER REMPE: -- going to change it?

14 MS. KARAS: Yes.

15 MEMBER REMPE: Okay.

16 MS. BURJA: The RAI provided a lot of
17 mark-up, not only of Chapter 4, but of --

18 MS. KARAS: Right.

19 MS. BURJA: -- most of the rest of the
20 DCD. And I did a word search in the DCD as well to
21 make sure that it was being changed pretty
22 consistently.

23 MEMBER REMPE: And you think that you're
24 happy with every change they identified and you
25 think it addresses it?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. BURJA: I think so.

2 MEMBER MARCH-LEUBA: Yes. And from my
3 point of view, which Mike is not here, so I can say,
4 I'm easily confused, he always says that. It's not
5 a semantic issue, but people understand this as
6 semantics, load-follow versus power maneuvers,
7 you're just changing words.

8 Load-follow is rapid unplanned changes
9 of controlled rods that get through a demand signal.
10 And the key word is unplanned, unanalyzed, you don't
11 know where you're going to end up. Versus power
12 maneuvers are planned control rod movements that
13 they get analyzed before they get exercised.

14 So, I'm sure at the end of cycle,
15 they'll be running out of reactivity and they will
16 do a cycle stress where they're using the power.
17 That's perfectly okay, that's not load-follow.

18 So, it would be nice if we defined, let
19 them know, because people get caught up on the
20 terminology instead of what it really means. The
21 thing with the core, what Shanlai, I think, is
22 trying to say, if you're going to accept rapid
23 unplanned rod changes, you need to reanalyze them to
24 make sure that you're okay.

25 MS. BURJA: Understood. We'll definitely

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consider that.

2 MEMBER MARCH-LEUBA: So, if the SER or
3 the -- could define what they mean, it will go a
4 long time to --

5 MS. BURJA: Okay. Thank you.

6 MEMBER MARCH-LEUBA: -- avoiding
7 problems.

8 MEMBER SUNSERI: Yes. And, Alex, not to
9 belabor the point, but I'll belabor the point. So,
10 I know you said, you just stated you looked through
11 the DCD for changes that affected the reactor, did
12 that include things like, I mean, there's a
13 statement in that says the pressurizer is sized to
14 support load-following and the liquid waste handling
15 systems are sized to support load-following, that
16 all implies the reactor is going to be doing
17 something, right?

18 MS. BURJA: Right.

19 MEMBER SUNSERI: So, did your review
20 catch those kind of issues as well?

21 MS. BURJA: I searched for the term load-
22 follow and some more variations of that. So, it's
23 possible that I missed something, but I can
24 certainly do a more extensive review.

25 MEMBER SUNSERI: Yes. So, I guess our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 caution to the Staff is, this is not just a reactor
2 thing, this is a holistic look at how the DCD is
3 constructed and what's going to ultimately get
4 certified in the end.

5 MEMBER REMPE: Because the implication is
6 that when they say something like that and you don't
7 say, no, we didn't review this, that -- again, maybe
8 I'm taking it too literally, but someone could come
9 and say, well, we documented it there, the NRC
10 didn't have a problem with it, and that's where I'm
11 coming from. But, again, if that's the way things
12 are done --

13 MS. KARAS: Yes. This is --

14 MEMBER REMPE: -- I'm just bringing it
15 up.

16 MS. KARAS: This is Becky Karas, again.
17 I guess, I would just -- so, it can say in one other
18 Section, and I don't know what all Sections KHNP is
19 modifying, but if one Section said, such-and-such is
20 sized or designed or whatever to support load-
21 following, that doesn't mean that, throughout the
22 DCD, that that's necessarily allowed, right?

23 So, within Chapter 4, that in and of
24 itself could say, no, power maneuvers, and I think
25 it was characterized as semantics because I think we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 understood, talking to KHNP, that what they had
2 intended was power maneuvers and not actually to
3 take the plant off of base load. So, you could have
4 certain components that were designed to be able to
5 handled load-following, but that doesn't mean that
6 you're necessarily asking for the design of it to
7 include that capability.

8 So, as long as within those key
9 Sections, like within the Reactor Section, that it
10 says very clearly that this is base load with power
11 maneuvers, then that's what the design basis of that
12 would be, even if you had design bases of other
13 systems permitting other capabilities.

14 So, I mean, I think, and we can look at
15 it carefully again and make sure, but my
16 understanding was that we looked and we were relying
17 on KHNP to do that look that they had propagated
18 that throughout their DCD, that the design basis was
19 going to be clear.

20 MEMBER REMPE: Thanks.

21 CHAIRMAN BALLINGER: Five seconds. Okay.
22 This is the completion of today's, so far,
23 presentations. I think the next thing we need to do
24 is to solicit public comments, if there are any.
25 And that includes in the room. I don't -- I think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the public is not here in the room. But I think
2 we're opening the phone line.

3 I don't hear any crackling, there's just
4 -- no red light comes on or something. Is there
5 anybody out there on the phone line that would like
6 to make a comment? Is it open? It's open now.
7 There we go.

8 If there's anybody -- is there anybody
9 out there on the phone line? If you're there, can
10 you make a noise to let us know that you're there?
11 Is there anybody out there that would like to make a
12 comment? Hearing none, we can close the phone line.
13 And next thing is to go around the table and solicit
14 additional comments from members. Joy?

15 MEMBER REMPE: Thanks to everyone for
16 their work and their presentations today. No
17 additional comments.

18 MEMBER MARCH-LEUBA: Yes. I also have no
19 further comments. Thank you for your presentations,
20 I think it was excellent presentations, both you and
21 KHNP.

22 MEMBER KIRCHNER: I thank both parties
23 for their presentations. I just wanted to note, Mr.
24 Chairman, that I felt heartened by the presentations
25 from the Staff that included their own in-house

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 confirmatory analysis of the neutronic design of the
2 core.

3 And I don't mean this as a plug for
4 research, but I think it's extremely important that
5 the Agency retain that kind of in-house capability
6 to independently validate and verify the designs
7 that they are reviewing. So, I thought that very
8 good.

9 And just one minor point for Alex, for
10 completeness, I think you should say that the
11 control rod systems can control reactivity changes
12 during DBEs to maintain core cooling and allowable
13 pressure limits on the RCS. That's a factor when
14 you look at RIA, reactivity insertion accidents.
15 Thank you.

16 CHAIRMAN BALLINGER: Pete?

17 MEMBER RICCARDELLA: I have no comments.

18 CHAIRMAN BALLINGER: Matt?

19 MEMBER SUNSERI: Yes, I'd like to extend
20 my thanks to both the Staff and the Applicant for
21 the thorough discussions that we had today and the
22 patience with our questions. Thank you.

23 CHAIRMAN BALLINGER: Dana?

24 MEMBER POWERS: Well, I'm still perplexed
25 a --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BALLINGER: Cobalt?

2 MEMBER POWERS: -- little bit about
3 cobalt, but it seems to me that with all the
4 advances in making hard surfaces, there's a better
5 way to do it, but I don't have to do it, so I'm not
6 going to worry about that.

7 I am a little bit confused about this
8 compensation for the use of outdated cross-sections
9 by hiding it within biases and offsets and things
10 like that. It is bothersome to me, it seems to me
11 that up-to-date plants ought to use up-to-date
12 databases. That's the only comment I care to make.

13 CHAIRMAN BALLINGER: Dick?

14 MEMBER SKILLMAN: Ron, thank you. To
15 both teams, thank you very much. And no further
16 comment.

17 MEMBER RAY: No comments.

18 CHAIRMAN BALLINGER: Margaret?

19 MEMBER CHU: No comments. Thank you.

20 CHAIRMAN BALLINGER: Steve?

21 MR. SCHULTZ: I would only second the
22 comments of the Members who have made them here in
23 closing and certainly thank the Staff and the
24 Applicant for good presentations today and a
25 thorough discussion of what has been done so far in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this area. It was very well presented, thank you.

2 CHAIRMAN BALLINGER: And I'd like to
3 extend, second all the other comments, it's been
4 very good today, both on the KHNP side and on the
5 Staff side, and thorough enough so that we can
6 understand what's going on and ask good questions.

7 And also, I wish we could put the three
8 hours in the bank, but unfortunately we can't, but I
9 can thank you for getting us three hours that we
10 could put in the bank if we could put them in the
11 bank. And other than that, we are adjourned.

12 (Whereupon, the above-entitled matter
13 went off the record at 1:59 p.m.)

14

15

16


17

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

APR1400 DCA

Chapter 4: Reactor



KEPCO/KHNP

Feb. 8. 2017

ACRS Meeting (Feb. 8. 2017)

Contents

- **Overview of Chapter 4**
- **Section Summary**
 - **4.1 Summary Description**
 - **4.2 Fuel System Design**
 - **4.3 Nuclear Design**
 - **4.4 Thermal-Hydraulic Design**
 - **4.5 Reactor Materials**
 - **4.6 Functional Design of Reactivity Control System**
- **Summary**
- **Attachments**
 - **Acronyms**

Overview of Chapter 4

● Section Overview

Section	Title	Major Contents	Presenter
4.1	Summary Description	<ul style="list-style-type: none"> • Design features for initial core design and summary information 	Ilkyu Kim
4.2	Fuel System Design	<ul style="list-style-type: none"> • PLUS7 fuel rod and fuel assembly design 	Ilkyu Kim
4.3	Nuclear Design	<ul style="list-style-type: none"> • Nuclear design of APR1400 reactor system 	Manseok Do
4.4	Thermal-Hydraulic Design	<ul style="list-style-type: none"> • Steady-state thermal and hydraulic analysis of the reactor core 	Kanghoon Kim
4.5	Reactor Materials	<ul style="list-style-type: none"> • Materials for CEDM, reactor Internals and core supports 	Jongsoo Kim
4.6	Functional Design of Reactivity Control System	<ul style="list-style-type: none"> • Control Rod Drive System(CRDS) 	Jongsoo Kim

ACRS Meeting (Feb. 8. 2017)

Overview of Chapter 4

● References

Submitted Document				Related Section of DCD Chapter 4					
Type	Title	No.	Rev.	4.1	4.2	4.3	4.4	4.5	4.6
DCD	APR1400 Design Control Document Tier 2: Chapter 4 Reactor	APR1400-K-X-FS-14002-NP	0	○	○	○	○	○	○
TOR	PLUS7 Fuel Design for the APR1400	APR1400-F-M-TR-13001-P & NP	0		○		○		
TER	Structural Analysis of Fuel Assemblies for Seismic and Loss of Coolant Accident Loading	APR1400-Z-M-NR-14011-P & NP	0		○				
TER	Neutron Fluence Calculation Methodology for Reactor Vessel	APR1400-Z-A-NR-14015-P & NP	0			○			
TER	Evaluation of Irradiation Assisted Stress Corrosion Cracking and Void Swelling on Reactor Vessel Internals	APR1400-Z-M-NR-14017-P & NP	0					○	
TER	Thermal Design Methodology	APR1400-F-C-NR-12001-P & NP	1				○		
TOR	KCE-1 Critical Heat Flux Correlation for PLUS7 Thermal Design	APR1400-F-C-TR-12002-P & NP	0				○		
TER	CPC Setpoint Analysis Methodology for APR1400	APR1400-F-C-NR-14001-P & NP	0				○		
TER	Functional Design Requirements for a Core Operating Limit Supervisory System for APR1400	APR1400-F-C-NR-14002-P & NP	0			○	○		

* TOR: Topical Report / TER: Technical Report

ACRS Meeting (Feb. 8. 2017)

4.1 Summary Description

- **APR1400 Core and Fuel Design Summary**

Parameters	Values
Core power level (MWt)	3,983
Fuel rod lattice	16 x 16 (236 fuel rods)
Number of fuel assemblies	241
Number of Control Element Assemblies (CEAs)	93
Active fuel length (m)	3.81 (150 in.)
Max. peaking factor (Fq)	2.43
Max. fuel rod avg. burnup (MWD/MTU)	60,000

ACRS Meeting (Feb. 8, 2017)

4.1 Summary Description

- Analytical Techniques

Design Category	Primary Code (Doc. No.)	Analysis Techniques / Approach
Fuel System (Section 4.2)	FATES (CENPD-139-P-A, CEN-161(B)-P-A)	Fuel rod performance analysis
Nuclear (Section 4.3)	DIT (CENPD-266-P-A, CENPD-275-P)	Spectral calculations using discrete integral transport (DIT) theory and spatial calculations in assembly geometry
Nuclear (Section 4.3)	ROCS (CENPD-266-P-A, CENPD-275-P)	Two-group diffusion theory applied with a nodal expansion method (NEM)
Nuclear (Section 4.3)	DORT (Industrial Standard)	Discrete ordinates Sn transport methodology
Thermal-Hydraulic (Section 4.4)	TORC (CENPD-161-P-A)	Subchannel analysis of the local fluid condition in the core


ACRS Meeting (Feb. 8. 2017)

4.1 Summary Description

- **Open Items**
 - **There are no Open Items for Section 4.1.**

4.2 Fuel System Design

● PLUS7 Design Features



PLUS7™ FA Design

Fuel Rod	Array	Square, 16 x 16
	No. / FA	236
	Material	UO ₂ , ZIRLO
Top & Bottom Nozzle	No. / FA	Top: 1, Bottom: 1
	Material	SS304 , Inconel 718
Top & Bottom Grid	No. / FA	Top: 1, Bottom: 1
	Material	Inconel 718
Mid Grid	No. / FA	9
	Material	ZIRLO
Protective Grid	No. / FA	1
	Material	Inconel 718
Guide Thimble	No. / FA	4
	Material	ZIRLO

ACRS Meeting (Feb. 8. 2017)

4.2 Fuel System Design

● PLUS7 Irradiation Experience

➤ PLUS7 LTAs (Lead Test Assemblies) and CSAs (Commercial Surveillance Assemblies)

- ◆ Pool Side Examinations (PSEs) were conducted on four LTAs
- ◆ Hot cell examination of LTA has been completed after irradiation
- ◆ PSEs were conducted on four CSAs
 - ✓ Four CSAs were selected among the fuel assemblies commercially supplied for Hanbit unit 5 cycle 5
- ◆ PSE and hot cell examination results showed all design requirements were met

➤ Operating Experience

- ◆ About 5,000 PLUS7 fuel assemblies have been supplied as of 2016
 - ✓ Shinkori unit 3 started commercial operating with PLUS7 fuel assemblies on Dec. 20, 2016 (Shinkori unit 3 is the reference plant of APR1400)
- ◆ PLUS7 fuel assemblies will be supplied to 4 Barakah APR1400 NPPs in UAE and 5 APR1400 NPPs in KOREA

4.2 Fuel System Design

- **Design Requirements**

- **10CFR Part 50 Appendix A.**
 - ◆ GDC 10 : Reactor design
 - ◆ GDC 27 : Combined reactivity control systems capability
 - ◆ GDC 35 : Emergency core cooling

- **10CFR Part 50.46**

- **NRC Guidances**

- **Regulatory Guide 1.206 Section 4.2**
- **Standard Review Plan Section 4.2 (NUREG-0800)**
 - ◆ Fuel System Damage
 - ◆ Fuel Rod Failure
 - ◆ Fuel Coolability

4.2 Fuel System Design

- Design Criteria and Evaluation

Evaluation Items	Corresponding Sections
Cladding Stress	4.2.3.1.3, 4.2.3.5.3
Cladding Strain	4.2.3.1.6
Stress and Loading Limit for other than Cladding	4.2.3.4, 4.2.3.5
Cladding Fatigue	4.2.3.1.6
Fretting Wear	4.2.3.1.1, 4.2.3.1.5, 4.2.3.5.2
Cladding Oxidation and Hydriding	4.2.3.1.4
Dimensional Changes	4.2.3.4, 4.2.3.5.2
Rod Internal Pressure	4.2.3.1.2
Assembly Liftoff	4.2.3.5.2
Hydriding	4.2.3.1.4
Cladding Collapse	4.2.3.1.11
Overheating of Fuel Pellets (Melting)	4.2.3.2.3
Pellet-Cladding Interaction (PCI)	4.2.3.3.1

ACRS Meeting (Feb. 8. 2017)

4.2 Fuel System Design

● Open Items

➤ PLUS7 Seismic Technical Report Status

- ◆ APR1400-Z-M-NR-14011-P&NP, “Structural Analysis of Fuel Assemblies for Seismic and Loss of Coolant Accident Loading,” Rev.0
- ◆ Fuel assembly tests and seismic analysis have been performing to answer the RAIs
- ◆ RAIs will be responded by Feb. 28, 2017, and the technical report will be revised

RAI NO.	Question No. (Total/Completed/Not responded)
275-8294	8 / 5 / 3
425-8405	6 / 0 / 6

ACRS Meeting (Feb. 8. 2017)

4.3 Nuclear Design

● Nuclear Design Description


➤ Loading Pattern

- ◆ Three-batch loading scheme with a refueling interval of 18 months

➤ Fuel Assemblies

- ◆ UO₂ fuel rods with enrichment separation and gadolinia-urania (Gd₂O₃-UO₂) burnable absorber rods

Assembly Type	No. of Fuel Assemblies	Fuel Rod Enrichment (w/o)	No. of Gd ₂ O ₃ Rods per Assembly	Gd ₂ O ₃ Contents (w/o)
A	77	1.71	0	-
B	88	3.14/2.64	0, 12, or 16	8
C	76	3.64/3.14	0, 12, or 16	8



- Water Hole
- Normal Enriched Fuel Pin
- Low Enriched Fuel Pin
- Gadolinia-Urania Fuel Pin

Fuel Assembly Batch Information and Typical Configuration for Initial Core

ACRS Meeting (Feb. 8. 2017)

4.3 Nuclear Design

- **Design bases of the APR1400 complies with SRP 4.3**
 - **Power distributions are maintained within the design limits throughout normal operations**
 - **Reactivity coefficients are maintained negative during power operation**
 - **Control systems are capable of providing enough shutdown margin and of controlling power distribution oscillations**

- **Core Power Distributions**
 - **The power distributions during Normal Operation are maintained within the design limits throughout the cycle:**
 - ◆ Limiting three-dimensional heat flux peaking factor (F_q) of 2.43
 - ◆ Minimum DNBR of 1.29
 - ◆ Maximum peak fuel rod burnup of 60 GWD/MTU
 - **The design limits on the power distribution are used both as design input and as initial conditions for accident analyses**

4.3 Nuclear Design


● Reactivity Coefficients

➤ Fuel Doppler Temperature Coefficient

- ◆ Negative throughout the cycle

➤ Moderator Temperature Coefficient

- ◆ Negative for most of power operation ranges
- ◆ Burnable absorbers achieve a negative coefficient at BOC




ACRS Meeting (Feb. 8, 2017)

4.3 Nuclear Design

● Reactivity Control System

- Provides enough shutdown margin considering single malfunctions of the reactivity control systems
- B₄C for Full-strength CEA and Inconel for Part-strength CEA
- Power dependent insertion limits (PDILs) conform to shutdown margin



CEA Groups	No. of CEAs
Regulating CEA Group	45
Shutdown CEA Group	36
Part Strength CEA Group	12
Total	93

ACRS Meeting (Feb. 8. 2017)

4.3 Nuclear Design

- **Stability**

- **Total core power perturbation**

- ◆ Inherently stable because of the negative overall power coefficients

- **Power distribution perturbation**

- ◆ Stable for radial and azimuthal xenon-induced oscillations
- ◆ Monitoring and protection by COLSS and CPCS
- ◆ Effective control by PSCEAs or regulating CEAs

4.3 Nuclear Design

- **Open Items**
 - **There are no Open Items for Section 4.3.**

4.4 Thermal-Hydraulic Design

● Design Bases

Parameters	Bases	Values
DNBR Limit	95% Probability/95% Confidence	1.29
UO ₂ Max. Temperature	Under melting temperature	2,804 °C (5,080 °F) *
RCS Flow Rate	Greater than minimum / Less than maximum	Min.:100% Q _D Max.:115% Q _D
Hydraulic Instability	Not occur	←

● Thermal-Hydraulic Major Parameters

Parameters	Values
Total core heat output	3,983 MWt
Primary system pressure	158.2 kg/cm ² (2,250 psia)
Reactor inlet coolant temperature	290.6 °C (555 °F)
Design primary coolant flow rate(Q _D)	1,689,000 L/min (446,300 gpm)
Minimum DNBR at nominal condition	2.44
UO ₂ Max. Temperature at nominal condition	1,712 °C (3,114 °F)


* @ BOC

ACRS Meeting (Feb. 8. 2017)

4.4 Thermal-Hydraulic Design

● Reactor Vessel Flow Distribution

- **Main flow path**
Inlet Nozzle → Downcomer
→ Flow Skirt → Lower Plenum
→ Core → Fuel Alignment Plate
→ Upper Plenum → Outlet Nozzle
- **Core bypass flow**
3% of total vessel flow
- **Core flow rate is determined to ensure an adequate core cooling**



ACRS Meeting (Feb. 8. 2017)

4.4 Thermal-Hydraulic Design

- **Thermal Effects of Operational Transients**
 - Design basis limits on DNBR and fuel temperature are maintained by LCO in the Technical Specifications for the most limiting AOO
- **Uncertainties for DNBR Calculation**
 - Input to build the core analysis model
 - TORC analytical model
 - CHF (DNB) correlation
- **Critical Heat Flux**
 - KCE-1 CHF correlation was used with TORC and CETOP codes to calculate DNBR for normal operation and AOOs
 - This correlation was developed based on PLUS7 CHF test data
 - Topical Report of KCE-1 CHF correlation (APR1400-F-C-TR-12002)
→ ACRS reviewed on Dec. 14, 2016

4.4 Thermal-Hydraulic Design

- **Core Thermal Response**

- **COLSS and RPS provide reasonable assurance that the design bases are not violated for any normal operating condition and AOOs**

- **Analytical Methods**

- **Reactor coolant system flow was determined by the system flow resistance and the RCP performance**
- **Thermal Margin Analysis were performed by TORC/CETOP codes and SCU method, previously approved by NRC**

4.4 Thermal-Hydraulic Design

● Open Items


RAI No.	Question No.	RAI Topic / NRC Concern	RAI Response / DCD Impact
328-8422	04.04-7	<ul style="list-style-type: none"> Addition of APR1400-F-C-NR-14002-P to Reference in the DCD Tier 2 	<ul style="list-style-type: none"> (1) RAI response was submitted on 8/19, 2016. (ML16232A569) (2) Impact on DCD (Revision of DCD Tier 2, Table 1.6-2)
328-8422	04.04-8	<ul style="list-style-type: none"> Addition of the methodology for mixed cores to the DCD Tier 2 or corresponding TER 	<ul style="list-style-type: none"> (1) RAI response was submitted on 8/29, 2016. (ML16242A432) (2) Impact on DCD (Revision of DCD Tier 2, Table 1.6-2, TER : APR1400-F-C-NR-14001-P)

ACRS Meeting (Feb. 8, 2017)

4.5 Reactor Materials


➤ Control Element (Rod) Drive Mechanism

- ◆ Function : to control reactivity (DCD Section 3.9.4)



➤ Reactor Vessel Internals (RVI)

- ◆ Function : to support fuel and maintain flow in RV (DCD Section 3.9.5)



ACRS Meeting (Feb. 8. 2017)

4.5 Reactor Materials

● CEDM Materials –Material Specifications

➤ RCPB materials in CEDM

- ◆ Motor Housing Assembly
 - ✓ Martensitic stainless steel, Austenitic stainless steels, Nickel-base alloys
- ◆ Upper Pressure Housing Assembly
 - ✓ Austenitic stainless steels
- ◆ The materials used in RCPB comply with the requirements of ASME Sections III, II, IX and Reg. Guide 1.84.

➤ Reactor coolant contact materials in CEDM

- ◆ Internal components of CEDM (Motor Assembly, Extension Shaft Assembly)
- ◆ Corrosion resistant materials; Austenitic stainless steels, Martensitic stainless steels, Nickel base alloys, Cobalt alloys

4.5 Reactor Materials

● CEDM Materials – Material Specifications

➤ Weld materials in CEDM

- ◆ Austenitic stainless steel weld metals (SFA-5.9 ER 316L)
- ◆ Nickel-based weld metals (SFA-5.14 ERNiCrFe-7A)

➤ The materials used in CEDM Assembly of APR1400 are:

- ◆ Essentially identical to Palo Verde and 12 operating OPR1000 plants in Korea, which demonstrate that the CEDM operates without malfunction with these materials.
- ◆ Tested to exceed the life-time requirements (DCD Section 3.9.4)

4.5 Reactor Materials

- **CEDM Materials**

- **Austenitic Stainless Steel Components**

- ◆ Only proved procedures will be applied to CEDM fabrication
- ◆ Process controls for RCPB (DCD Sec. 5.2.3.4) are applied on CEDM
- ◆ Venting of CEDM will be applied on each refueling period before plant starts

- **Other Materials**

- ◆ Nickel base alloys, Cobalt alloys, and Martensitic stainless steels for Springs, Grippers, Latches and Links, Bearing Inserts, Alignment Tabs, and Steel Balls

4.5 Reactor Materials

● RVI Materials – Materials Specifications

➤ Reactor internals and core support (RVI) materials

- ◆ Comply with ASME Section III NG-2000 and Reg. Guide 1.84
- ◆ Primarily Type 304 austenitic stainless steels
- ◆ Welded connections are applied where feasible, structural fasteners are typically Type 316
- ◆ Cobalt hardfacing materials at wear points
- ◆ Cold worked austenitic stainless steel will not be used except for bolting or pins
- ◆ Proven materials which performed satisfactorily in operating reactors in US and Korea

➤ Reactor internals and core support materials specifications

- ◆ Core support barrel assembly, Upper Guide Assembly, Core Shroud Assembly
 - ✓ Mainly austenitic stainless steels

4.5 Reactor Materials

● RVI Materials –Materials Specifications

- **Reactor internals and core support materials specifications**
 - ◆ Bolt and pin material
 - ✓ Austenitic Stainless Steels
 - ◆ Chrome plating and Cobalt hardfacing
 - ◆ Weld materials for RVIs
 - ✓ Stainless steel weld metal of 308L (SFA-5.4, SFA-5.9), Stellite 25 for hardfacing weld
- **Controls on Welding and Nondestructive Examination**
 - ◆ Welding and Examination of Internals and Core support materials comply with ASME Section III (NG) Code
- **Fabrication and Processing of Austenitic Stainless Steel**
 - ◆ Reg. Guide 1.44 are applied to control the use of sensitized austenitic stainless steel
 - ◆ Process controls for RCPB (DCD Sec. 5.2.3.4) applied on RVI austenitic stainless steels

4.5 Reactor Materials

- **Reactor Internals and Core Support Materials**

- **Other Materials**

- ◆ Austenitic stainless steels (Grade 660, S21800) and Martensitic stainless steels (F6NM) for Alignment Keys, Insert pins, HJTC tube assembly and Hold down ring

- **Other Degradation Mechanisms (Irradiation Assisted Stress Corrosion Cracking (IASCC) and Void Swelling)**

- ◆ IASCC and Void Swelling become challenging degradations for RVI materials
- ◆ Neutron fluence, temperature and stresses are main influencing factors
- ◆ EPRI developed software applied for the assessment for APR1400 RVI
- ◆ The assessment results of APR1400 RVIs is acceptable
- ◆ Evaluation report was provided to NRC

4.5 Reactor Materials

- Open Items

RAI No.	Question No.	RAI Topic / NRC Concern	RAI Response
523-8684	04.05-01-15	DCD Section 4.5.1.1 be revised to include the material specifications and types for the Versa Vent™ since it is a pressure boundary component	RAI response was submitted on 10/25, 2016.
523-8684	04.05-01-16	Data/operational experience that demonstrates the venting with Versa Vent™ can work in practice to eliminate the air trapped in the top of the CEDM	RAI response was submitted on 11/15, 2016.

4.6 Functional Design of Reactivity Control System

- **The section 4.6 describes the Control Rod Drive System (CRDS) that consists of the CEDMs, which insert or withdraw the CEAs, and the Digital Rod Control System (DRCS), which actuates the CEDMs.**
- **Information and Evaluation of combined performance of the reactivity control systems are about the design bases events analyzed in chapter 15 that require reactivity control systems to operate for preventing or mitigating each event.**

4.6 Functional Design of Reactivity Control System

- **Open Items**
 - **There are no Open Items for Section 4.6.**

Summary

- **APR1400 reactor design of Chapter 4 demonstrates to comply with requirements of federal regulations and NRC regulatory documents.**
- **There are no Open Items for Sections 4.1, 4.3 and 4.6.**
- **There are 6 Open Items in total for Sections 4.2, 4.4 and 4.5.**

Attachment: Acronyms (1/3)

- ACRS : Advisory Committee on Reactor Safeguards
- AOO: Anticipated Operational Occurrence
- APR1400: Advanced Power Reactor 1400
- ARO: All Rods Out
- ASME: American Society of Mechanical Engineers
- BOC: Beginning of Cycle
- CEA: Control Element Assembly
- CEDM: Control Element Drive Mechanism
- CFR: Code of Federal Regulations
- CHF: Critical Heat Flux (or DNB : Departure from Nucleate Boiling)
- COLSS: Core Operating Limit Supervisory System
- CPCS: Core Protection Calculator System
- CRDM: Control Rod Drive Mechanism
- CSAs: Commercial Surveillance Assemblies

Attachment: Acronyms (2/3)

- DNBR: Departure from Nucleate Boiling Ratio
- EOC: End of Cycle
- FTC : Fuel Temperature Coefficient
- HJTC: Heated Junction Thermocouple
- IASCC: Irradiated Assisted Stress Corrosion Cracking
- GDC: General Design Criteria
- KHNP: Korea Hydro & Nuclear Power
- LCO: Limiting Conditions for Operation
- LTAs: Lead Test Assemblies
- MTC: Moderator Temperature Coefficient
- PCI: Pellet-Cladding Interaction
- PDIL: Power Dependent Insertion Limit
- PSCEA: Part Strength Control Element Assembly
- PSE: Pool Side Examination

Attachment: Acronyms (3/3)

- RAI: Request for Additional Information
- RCP: Reactor Coolant Pump
- RCPB: Reactor Coolant Pressure Boundary
- RCS: Reactor Coolant System
- RG: Regulatory Guide
- RPS : Reactor Protection System
- RVI: Reactor Vessel Internals and Core Support



Presentation to the ACRS Subcommittee

**Korea Hydro Nuclear Power Co., Ltd (KHNP)
APR1400 Design Certification Application Review**

Safety Evaluation with Open Items: Chapter 4

REACTOR

February 8, 2017

- **Technical Staff Presenters**

- ♦ Christopher Van Wert – SRSB
- ♦ Alexandra Burja – SRSB
- ♦ Andrew Bielen – RES/RSAB
- ♦ James Gilmer – SRSB
- ♦ Carl Thurston – SRSB
- ♦ John Honcharik - MCB
- ♦ Daniel Widrevitz - MCB

- **Project Managers**

- ♦ Jeff Ciocco – Lead Project Manager
- ♦ George Wunder – Chapter 4 Project Manager

Staff Review Team

- ♦ **Andrew Bielen**, Office of Nuclear Regulatory Research, Reactor Systems Analysis Branch (RES/RSAB)
- ♦ **Alexandra Burja**, Reactor Systems, Nuclear Performance & Code Review Branch (SRSB)
- ♦ **James Gilmer**, SRSB
- ♦ **Carl Thurston**, SRSB
- ♦ **Christopher Van Wert**, SRSB
- ♦ **Peter Yarsky**, RES/RSAB
- ♦ **John Honcharik**, Materials and Chemical Engineering Branch
- ♦ **Dan Widrevitz**, Materials and Chemical Engineering Branch

Technical Topics

Section 4.2 – Fuel System Design

Areas of Review

- Fuel System Design
- Nuclear Design
- Thermal and Hydraulic Design
- Materials
- Reactivity Control

Technical Topics

Section 4.2 – Fuel System Design

Areas of Review

- Design Bases
 - Fuel assembly damage
 - Fuel rod damage
 - Core coolability
- Descriptions and Design Drawings
- Design Evaluation
- Testing, Inspection, and Surveillance Plans
- ITAACs
- COL Action Items and Certification Restrictions

Technical Topics

Section 4.2 – Fuel System Design

Challenging Review Area: Burnup Dependent Thermal Conductivity Degradation

- APR1400 Fuel System Design safety analysis is based on the use of the FATES-3B fuel design code, which does not contain a burnup dependent thermal conductivity degradation (TCD) model
- The staff identified concerns regarding compliance with GDC 10 for various fuel system damage and fuel rod damage mechanisms as well as 10 CFR 50.46 for core coolability requirements when the burnup dependency of TCD is not modeled.
- The burnup dependent TCD model review area is addressed as part of the ongoing reviews of the referenced topical reports APR1400-F-M-TR-13001-P “PLUS7 Fuel Design for the APR1400” and APR1400-F-A-TR-12004-P, “Realistic Evaluation Methodology for Large-Break LOCA of the APR1400”. The resolution of the DCD Section 4.2 open item depends on the successful completion of these associated topical reports.

Technical Topics

Section 4.2 – Fuel System Design

Challenging Review Area: Fuel Assembly Structural Response to Externally Applied Loads

- During review of the fuel assembly structural response analysis, the staff noted that the referenced methodology was not strictly followed in its entirety calling into question the determination of load limits for the PLUS7 fuel assembly.
- The applicant is in the process of completing its open item resolution plan which includes a complete test program of the PLUS7 fuel assembly and grid for both beginning of life (BOL) and end of life (EOL) conditions.
- The staff has been auditing the tests as they occur and will be able to review the final analysis documentation when the open item resolution plan has been completed.

Technical Topics

Section 4.2 – Fuel System Design

Findings – Fuel System Design meets the following requirements:

- The staff is currently unable to make regulatory findings on the fuel system design criteria due to open items associated with the ongoing topical report reviews of APR1400-F-M-TR-13001-P “PLUS7 Fuel Design for the APR1400” and APR1400-F-A-TR-12004-P, “Realistic Evaluation Methodology for Large-Break LOCA of the APR1400”, as well as the open item resolution plan associated with technical report APR1400-Z-M-NR-14010-P, “Structural Analysis of Fuel Assemblies for Seismic and Loss of Coolant Accident Loading”.

Technical Topics

Section 4.3 – Nuclear Design

Areas of Review

- Design Bases
- Power Distributions
 - ◆ Representative power distributions
 - ◆ Monitoring: core operating limits supervisory system (COLSS) and core protection calculator system (CPCS)
 - ◆ Means of control: core loading pattern, control element assemblies (CEAs), soluble boron
- Reactivity Coefficients
 - ◆ Negative power coefficient of reactivity
 - ◆ Conservative values used in transient and accident analyses
- Reactivity Control Provisions and Requirements
 - ◆ Available CEA worth sufficient for safe shutdown during normal and accident conditions
 - ◆ Conservative worth values used in transient and accident analyses
 - ◆ Reactivity control requirements are clearly defined and reasonable
 - ◆ Limits on reactivity insertion rate
- Provisions to prevent reactor criticality during refueling

Technical Topics

Section 4.3 – Nuclear Design

Areas of Review, Continued

- Stability against xenon-induced power distribution oscillations
- Analytical Methods
 - ♦ Nuclear design methodology - DIT and ROCS
 - ♦ Codes used to process information from the ex-core detectors for use in the CPCS
- Reactor Vessel Fluence
 - ♦ Methodology and assumptions - DORT, a 2-D discrete ordinates transport code
 - ♦ Vessel fluence calculation, including associated bias and uncertainty
 - ♦ Combined license (COL) information item for plant-specific surveillance data for benchmarking (COL Information Item 5.3(5))
- Initial test program – nuclear design tests
 - ♦ Open Item 14.2.12.2-1 related to the absence of initial fuel load and initial criticality tests now a Confirmatory Item; response to RAI acceptable
- TS: safety limits and TS related to power distribution, reactivity control, and instrumentation

Technical Topics

Section 4.3 – Nuclear Design

Challenging Review Area: Control Rod Worth Depletion

- Staff concern: Full-strength CEAs with B₄C neutron absorber may be used as regulating rods, and B-10 depletion may affect CEA worth
- Resolution
 - ◆ Applicant's estimated B-10 burnout not negligible but conservative
 - ◆ Operating experience for a similar reactor design (Optimized Power Reactor 1000 (OPR1000)) shows measurements agree with predictions within allowed uncertainty
 - ◆ Net rod worth uncertainty listed in the DCD much greater than estimated loss of worth
 - ◆ Shutdown reactivity curve is already conservative
 - ◆ Ten-year CEA lifetime and power-dependent insertion limits limit loss of worth
 - ◆ Startup physics tests confirm rod worth is consistent with predictions

Technical Topics

Section 4.3 – Nuclear Design

Challenging Review Area: Nuclear Design Methodology – Benchmarking

- Staff concern: DCD did not adequately describe benchmarking of DIT and ROCS against experimental data for the APR1400-specific nuclear and fuel design
- Resolution
 - ♦ Bias and uncertainty manual derived from measured vs. predicted data for 8 US Combustion Engineering reactors with core and fuel designs that bound the APR1400 design
 - ♦ Audit of calculation notes confirmed methods to determine bias and bias uncertainties
 - ♦ Audit of bias and uncertainty manual confirmed the high-level information in the DCD
 - ♦ APR1400 bias and uncertainty manual almost identical to that for OPR1000
 - ♦ Staff confirmed that the OPR1000 DIT and ROCS predictions provided in RAI response compare well against plant measurements

Technical Topics

Section 4.3 – Nuclear Design

Challenging Review Area: Nuclear Design Methodology – Nuclear Data

- Staff concern:
 - ♦ Evaluated Nuclear Data File (ENDF)/B-IV cross-section library published in 1974; many important improvements since then
 - ♦ Staff performed confirmatory criticality calculations using the SCALE code to compare the results when using the ENDF/B-IV library instead of the current version; differences substantial (see next slide)
 - ♦ Use of ENDF/B-IV could lead to inaccurate nuclear design predictions and affect transient and accident analyses
- Resolution
 - ♦ Bias and uncertainty values applied to DIT and ROCS are associated with use of the ENDF/B-IV library; thus, effects of library implicitly captured in the bias and uncertainty applied to the nuclear design calculations

Technical Topics

Section 4.3 – Nuclear Design

Challenging Review Area: Nuclear Design Methodology – Nuclear Data

- Staff confirmatory calculation results

LEU-COMP-THERM-001, Case 1			
Cross-Section Library	k_{eff}	σ	Difference compared to ENDF/B-VII (pcm)
ENDF/B-VII (Continuous Energy)	0.99885	0.00099	0.00
ENDF/B-V (238-Group)	0.99584	0.00091	-301.35
ENDF/B-IV (218-Group)	0.99061	0.00088	-824.95

APR1400 3.14 wt% UO ₂ Unpoisoned Fuel Assembly			
Cross-Section Library	k_{∞}	σ	Difference compared to ENDF/B-VII (pcm)
ENDF/B-VII (Continuous Energy)	1.40879	0.00044	0.00
ENDF/B-V (238-Group)	1.40049	0.00043	-589.16
ENDF/B-IV (218-Group)	1.38736	0.00044	-1521.2

Technical Topics

Section 4.3 – Nuclear Design

Conclusions

- Meets GDC 10, 11, 12, 13, 20, 25, 26, 27, and 28 because:
 - ♦ Specified acceptable fuel design limits (SAFDLs) will not be exceeded during normal operation or anticipated operational occurrences (AOOs)
 - ♦ Negative power coefficient of reactivity
 - ♦ Only axial xenon oscillations are possible; can be suppressed using CEAs
 - ♦ Instrumentation and controls to maintain power distributions within limits
 - ♦ Control systems and setpoints for shutdown adequate
 - ♦ SAFDLs not exceeded for any single reactivity control system malfunction
 - ♦ CEAs and chemical and volume control system (CVCS) provided
 - ♦ Sufficient shutdown margin assuming a stuck rod
 - ♦ Reactivity insertion limited, appropriate reactivity values in transient and accident analyses
- Additional Considerations
 - ♦ Analytical methods and data acceptable, and methods benchmarked appropriately
 - ♦ Initial test program adequate to verify the nuclear design
 - ♦ Nuclear design TS ensure protection of public health and safety
 - ♦ Staff confirmatory analyses support the foregoing conclusions

Technical Topics

Section 4.3 – Nuclear Design

Staff Initial Cycle Confirmatory Analyses

Staff Initial Cycle Confirmatory Analyses: Outline

- Description of NRC nuclear design methods
- Comparison of power distributions
- Comparison of boron letdown
- Comparison of control bank worths
- Comparison of trip reactivity insertion curves
- Reactivity Feedback Coefficients
- Summary and Conclusions

Technical Topics

Section 4.3 – Nuclear Design

Staff Initial Cycle Confirmatory Analyses

NRC Methods

- Lattice Physics calculations are performed with SCALE/POLARIS
 - ♦ 7 history conditions
 - ♦ 81 branch conditions
 - ♦ Covers normal operation and anticipated operational occurrences
- Nodal core simulator neutronic calculations performed with PARCS
 - ♦ 27 total nodes, 25 active nodes axially
 - ♦ 1 radial node per fuel assembly
 - ♦ 250 MWd/MTU cycle exposure increments
- Nodal core simulator thermal-hydraulic calculations performed with PATHS
 - ♦ 1 thermal-hydraulic channel per fuel assembly

Technical Topics

Section 4.3 – Nuclear Design

Staff Initial Cycle Confirmatory Analyses

Radial Power Distribution – Beginning of Cycle (BOC)

					0.72	0.94	1.06	1.02
			0.78	1.09	1.00	1.08	1.05	1.12
		0.82	1.08	1.14	0.97	1.13	0.96	1.05
	0.78	1.08	1.03	0.95	1.05	0.96	1.16	0.97
	1.09	1.14	0.95	1.14	0.92	1.11	0.95	1.14
0.72	1.00	0.97	1.05	0.92	1.02	0.90	1.01	0.91
0.94	1.08	1.13	0.96	1.11	0.90	1.09	0.88	1.05
1.06	1.05	0.96	1.16	0.95	1.01	0.88	0.97	0.88
1.02	1.12	1.05	0.97	1.14	0.91	1.05	0.88	0.92

DCD Reference

					0.69	0.86	0.95	0.92
			0.75	1.04	0.96	1.02	0.99	1.06
		0.80	1.05	1.10	0.96	1.11	0.96	1.04
	0.75	1.05	1.02	0.96	1.06	0.98	1.17	1.00
	1.04	1.10	0.96	1.15	0.97	1.15	1.00	1.18
0.69	0.96	0.96	1.06	0.97	1.07	0.97	1.07	0.98
0.86	1.02	1.11	0.98	1.15	0.97	1.15	0.96	1.13
0.95	0.99	0.96	1.17	1.00	1.07	0.96	1.05	0.96
0.92	1.06	1.04	1.00	1.18	0.98	1.13	0.96	1.00

PARCS Result

Technical Topics

Section 4.3 – Nuclear Design

Staff Initial Cycle Confirmatory Analyses

Radial Power Distribution – End of Cycle (EOC)

					0.61	0.76	0.83	0.81
			0.65	0.88	0.98	1.09	1.12	1.19
		0.74	1.08	1.10	0.95	1.20	0.97	1.15
	0.65	1.08	1.15	0.97	1.14	0.96	1.12	0.94
	0.88	1.10	0.97	1.22	0.97	1.19	0.95	1.11
0.61	0.98	0.95	1.14	0.97	1.15	0.97	1.13	0.95
0.76	1.09	1.20	0.96	1.19	0.97	1.21	0.96	1.19
0.83	1.12	0.97	1.12	0.95	1.13	0.96	1.13	0.93
0.81	1.19	1.15	0.94	1.11	0.95	1.19	0.93	0.90

DCD Reference

					0.65	0.78	0.86	0.83
			0.68	0.91	1.00	1.10	1.14	1.21
		0.77	1.09	1.11	0.93	1.21	0.96	1.17
	0.68	1.09	1.15	0.95	1.15	0.94	1.13	0.93
	0.91	1.11	0.95	1.22	0.94	1.18	0.92	1.11
0.65	1.00	0.93	1.15	0.94	1.14	0.93	1.12	0.92
0.78	1.10	1.21	0.94	1.18	0.93	1.19	0.92	1.16
0.86	1.14	0.96	1.13	0.92	1.12	0.92	1.10	0.89
0.83	1.21	1.17	0.93	1.11	0.92	1.16	0.89	0.87



PARCS Result

Technical Topics

Section 4.3 – Nuclear Design

Staff Initial Cycle Confirmatory Analyses

Axial Power Distribution – Beginning and End of Cycle



Technical Topics

Section 4.3 – Nuclear Design

Staff Initial Cycle Confirmatory Analyses

Power Distribution Results


- The differences in radial power predictions were found to be reasonable and explainable, and there were minimal differences between the staff calculation and the applicant prediction of the highest-powered assemblies.
- The differences in axial peaking between the two cases are, at most, ~10% at certain points in cycle. This is consistent with PARCS assessment against plant data.
- At no time throughout the initial cycle are the results close to the axial offset limits set by APR1400 technical specifications.

Technical Topics

Section 4.3 – Nuclear Design

Staff Initial Cycle Confirmatory Analyses

Boron Letdown Comparison



Technical Topics

Section 4.3 – Nuclear Design

Staff Initial Cycle Confirmatory Analyses

Boron Letdown Conclusions

- The qualitative behavior of the NRC and applicant calculations is very similar.
- Starting from ~5 GWd/MTU of burnup through ~12 GWd/MTU, the deviation in critical boron concentration exceeds 50 ppm, with the applicant's calculations requiring a higher critical boron concentration. The differences in critical boron concentration are likely caused by differences in isotopics or fuel/moderator conditions.
- Mid-cycle conditions are not limiting in safety analysis, and at the limiting (i.e., BOC and EOC) points, the PARCS and applicant's analysis agreement is reasonable-to-excellent. Therefore, while the difference between DCD and PARCS predictions may be worthy of further study, they are not significant enough to warrant safety concern.

Technical Topics

Section 4.3 – Nuclear Design

Staff Initial Cycle Confirmatory Analyses

Control Rod Worth Comparison

Bank	Difference in Worth (%)			
	0 MWd/MTU	7018 MWd/MTU	13992 MWd/MTU	17571 MWd/MTU
1	13.60	1.17	2.03	1.25
2	-3.87	-4.24	-8.80	-10.42
3	-0.34	-6.59	-8.62	-10.20
4	-1.74	1.87	-2.18	-2.10
5	0.60	-6.41	0.00	0.25
SD	-2.22	-4.78	-4.76	-6.63
PS	-5.09	-9.23	-9.33	-8.24
Total	-0.58	-3.84	-4.07	-5.68


Generally excellent agreement between the DCD and the confirmatory analysis is evidenced. As a point of reference, a bank worth difference between expected and actual of approximately 10% is considered satisfactory for most core design applications.

Technical Topics

Section 4.3 – Nuclear Design

Staff Initial Cycle Confirmatory Analyses

Reactor Trip Reactivity Insertion



Technical Topics

Section 4.3 – Nuclear Design

Staff Initial Cycle Confirmatory Analyses

Reactivity Feedback Coefficients

- Moderator Density Coefficient (MDC) and Fuel Temperature Coefficient (FTC) were calculated at BOC and EOC conditions. Limiting point is BOC without Xenon/Samarium.
 - ♦ MDC is $\sim 9.7 \times 10^{-3} \text{ } \$/\text{-m}^3/\text{kg}$
 - ♦ FTC is $\sim -2.1 \times 10^{-3} \text{ } \$/\text{K}$
- Power feedback coefficient confirmed to be negative at power conditions.
 - ♦ Slightly negative MDC at very low power, fresh core. This is counter balanced by negative FTC at these conditions.
- Data can be used in conjunction with TRACE to perform transient calculations using point kinetics.

Technical Topics

Section 4.3 – Nuclear Design

Staff Initial Cycle Confirmatory Analyses

Summary and Conclusions

- Radial power distribution had a difference of ~2%-5% depending on time-in-cycle. Comparisons in the peak powered assemblies were on the order of 1%. This agreement is reasonable-to-excellent.
- There is excellent agreement in axial power distribution with differences less than ~10%.
- The boron letdown curve shows excellent qualitative agreement, but in the middle of the cycle differences are beyond expectations; however, the middle of cycle is non-limiting in terms of reactivity feedback. Agreement at the BOC and EOC is very good.
- Predicted worths for all banks throughout the cycle are in good agreement, as are the reactor trip characteristics used in safety analysis.
- PARCS calculated power feedback is negative.

Technical Topics

Section 4.4 – Thermal and Hydraulic Design

Areas of Review

- Thermal and Hydraulic Design of the Core and RCS
 - ♦ Acceptable Analytical Methods used (largely based on data extrapolation from System 80+ and System 80)
 - ♦ Provides Acceptable Margins against conditions leading to fuel damage during normal operation and AOOs
 - ♦ Not Susceptible to Thermal-Hydraulic Instability
- Calculated Core Parameters to establish minimum DNBR are based on previously approved CE Methods
- Hydraulic Loads on Core and RCS during normal operation and DBA Conditions are extrapolated from System 80 flow test data
- Confirmed negligible differences in APR1400 core geometry and operating parameters to System 80+ and System 80 Designs

Technical Topics

Section 4.4 – Thermal and Hydraulic Design

Areas of Review

- Uncertainty analysis Methodologies namely Statistical Combination of Uncertainties to assure that at least 95-percent probability at 95-percent confidence level that hot fuel rod does not experience DNB during normal operation or AOOs
- CPCS Interfaces that support the DNBR and local power density (LPD) safety limits
- COLSS interfaces with the CPCS to support Chapter 7 reviews
- Computation of CPCS parameters needed for Core Reload
- Reactor protection systems design and operation, COLSS and CPCS, is essentially that of Palo Verde System 80 Design

Technical Topics

Section 4.4 – Thermal and Hydraulic Design

Technical Report: APR1400-F-C-NR-12001-P “Thermal Design Methodology”

- CE Methodology based on approved TORC and CETOP codes with the KCE-1 CHF correlation
- CE Methodology approved statistical uncertainties methods used to assure a 95-percent Probability at 95-percent Confidence Level that the hot fuel rod does not experience DNB during normal operation or AOOs consistent with SRP including a penalty for rod bow

Technical Topics

Section 4.4 – Thermal and Hydraulic Design

Technical Reports: APR1400-F-C-NR-14003-P, “Functional Design Requirements for a Core Protection Calculator System for APR1400” and APR1400-F-C-NR-14002-P, “Functional Design Requirements for a Core Operating Limit Supervisory System for APR1400”

- CE Methodology based on approved methodology in use at Palo Verde, but also implemented at San Onofre, ANO-2, and Waterford since the early 1980’s
- CPC protection software design assures with 95% probability and 95% confidence that DNBR and LPD limits are maintained
- Procedures for development of CPCS constants will be developed by the COL holder consistent with existing procedures for the operating System 80 plants

Technical Topics

Section 4.4 – Thermal and Hydraulic Design

Technical Report: APR1400-F-C-NR-14001-P “CPC Setpoint Analysis Methodology APR1400”

- CPC computes changes in linear power density and provides measurements of core conditions for peak power density and DNBR based on ex-core instrument measurements
- CPC uses these monitored parameters to calculate the LPD and DNBR margin to trip limits, Cycle-dependent uncertainties associated with the CPC trip point settings are combined such that the adjusted LPD and DNBR setpoints are always conservative

Technical Topics

Section 4.4 – Thermal and Hydraulic Design

Technical Report: APR1400-Z-J-NR-14004-P “Uncertainty Methodology and Application for Instrumentation”

- Describes methodology used to combine uncertainties to ensure plant protective functions activate at desired values under normal and accident conditions
- Essentially identical to approved CE topical CEN-356(V)-P-A (1988)

Technical Report: APR1400-Z-J-NR-14005-P “Setpoint Methodology for Plant Protection System”

- Describes methodology used to establish setpoints to be used for the ex-core PPS trip settings
- PPS functions contain the other RPS trips and the ESFAS actuation trips
- Setpoints established such that during DBEs analytical limit (AL) not exceeded. ALs are established such that safety limits (SLs) not reached, and SLs assure that unacceptable consequences do not occur during DBEs

Technical Topics

Section 4.4 – Thermal and Hydraulic Design

Challenging Review Area: CPCS and COLSS Functions and Interfaces

- Basis for CPCS was not well documented in System 80+ DCD
- KHNP followed System 80+ DCD but did not link references to post-1980's functional changes and improvements to current system 80 design
- Staff concern: Basis documentation inadequate per 52.47(a) to assure safety
- Staff audit conducted January 2016
- The issue was ultimately resolved for the following reasons:
 - ♦ CE references located for CPCS and COLSS
 - ♦ Confirmed functionality are based on approved and implemented PVNGS changes

Technical Topics

Section 4.4 – Thermal and Hydraulic Design

Challenging Review Area: Single vs Double-sided Confidence Limit

- The statistical combination of uncertainties (SCU) methodology in the CPCS Setpoint technical report used to convert the DNBR safety limit of 1.124 to the analytical limit of 1.29 for 95/95 confidence level does not adhere to a recently updated RG 1.105 (requiring doubled sided, Rev 3 versus single sided confidence levels, Rev 2)
- Single sided Methodology based on CEN-356, approved by staff in 1989
- DCD Chapter 7 indicates methodology does not conform with RG 1.105 Rev. 3, so methodology used is not consistent with RG referenced
- Item remains open:
 - ♦ Based on CE operating plant experiences using CEN-356, staff will consider approval if the applicant takes exception to the setpoint methodology in RG 1.105 Rev. 3.

Technical Topics

Section 4.4 – Thermal and Hydraulic Design

Findings – Thermal-Hydraulic Design meets the following requirements:

- GDC 10: SAFDLs not exceeded during normal operation or AOOs
- GDC 12: suppression of reactor power oscillations can be reliably detected and suppressed
- Thermal design methodology depends heavily upon codes and methods previously approved by staff for domestic CE plants
- APR1400 thermal hydraulic design is comparable to System 80+ design with small differences due to the slight increase (i.e., < 2 %) in power of the APR1400
- Staff concludes that the design provides adequate assurance that the reactor will perform its related safety functions under all modes of operation pending completion of open items

Technical Topics

Section 4.5.1 – Control Rod Drive System Structural Materials

Technical Topics

Control Rod Drive (CRD) materials for reactor coolant system (RCS) pressure and non-pressure boundary components.

- KHNP provided:
 - ♦ Material selection, fabrication techniques, heat treatments and cleanliness control per NUREG-0800
 - ♦ Materials used for pressure boundary components are consistent with other designs and have satisfactory operating experience, such as stabilized stainless steel (Grades 347 and 348), martensitic stainless steel (ASME Code Case N-4-13 modified Type 403), nickel-based alloy (alloy 690, thermally treated) and austenitic stainless steel Type 304 and Type 316. Welding filler materials Alloy 52/52M, Alloy 152, and Alloy type 316L.
 - ♦ Materials used for non-pressure boundary components are consistent with other designs and have satisfactory operating experience, including austenitic stainless steels Type 316, Type 321, and Type 304. Martensitic stainless steels (Type 410 with conditions A and T, and Type 440C). Nickel-based alloys (Alloy X-750) and nickel-chromium-molybdenum-columbium alloy (Alloy 625).

Technical Topics

Section 4.5.1 – Control Rod Drive System Structural Materials

Technical Topics

- Use of austenitic stainless steel base materials is consistent with the recommendations of RG 1.44, and that only procedures that have been demonstrated to not sensitize CRD stainless steel components are used.
- Controls for abrasive work and cleaning on austenitic stainless steel surfaces are used to prevent cold work and contamination as specified in RG 1.28 and ASME NQA-1.
- Heat treatments consistent with NUREG-0800 and operating experience, including Alloy X-750 heat treated to 1149 degrees C (2100 degrees F), and Type 410 Condition T heated above 565°C (1050°F) for the ASME A276 Type 410T materials

Technical Topics

Section 4.5.1 – Control Rod Drive System Structural Materials

Open Items

- **RAI 8684, Questions 04.05.01-15** – The applicant needs to provide the material specifications and types for the Versa Vent™ component which is used for venting the CRD to minimize increased levels of oxygenated water in stagnant or dead end areas of the CRD components
 - ♦ Versa Vent™ is considered by the applicant as a non-pressure boundary component that replaces the CRD housing nut which is a pressure boundary component.
 - ♦ **Status:** The response was received and is in evaluation.
- **RAI 8684, Questions 04.05.01-16** – The applicant needs to provide data/operating experience that justifies venting during refueling outages keeps oxygen levels low (as stated in RG 1.44) so that non-L grade stainless steels can be used
 - ♦ **Status:** The response was received and is in evaluation.

Technical Topics

Section 4.5.2 – Reactor Internals and Core Support Materials

- Reactor Internals and Core Support Materials and Design in APR-1400 is consistent with industry practice. Applicant indicated a high level of adherence to appropriate controls, including adherence to relevant NRC Regulatory Guides. Staff RAIs focused on clarification and completeness. Staff found section acceptable pending incorporation of content from RAI responses.

Technical Topics

Section 4.5.2 – Reactor Internals and Core Support Materials

Staff review focused on the following topic areas:

- Materials specifications, selection, and heat treatments;
- Controls on welding;
- Nondestructive examination;
- Austenitic stainless steels;
- Other materials;
- Other degradation mechanisms (IASCC and void swelling in particular).

Technical Topics

Section 4.6 – Functional Design of Reactivity Control Systems

Areas of Review

- Control rod drive system (CRDS) functionality and arrangement
- Environmental and seismic qualifications of CRDS
- Design requirements for CRDS cooling system
- Possible single failures of CRDS
- Testing and verification of the CRDS
 - ♦ Initial test program
 - ♦ ITAAC and TS surveillance requirements for scram time
- Combined performance of reactivity control systems
 - ♦ Combination of systems used to mitigate specific AOOs and postulated accidents
 - ♦ Transient and accident analyses show reactivity control systems capable of controlling reactivity changes during design basis events (DBEs)
- Common mode failures of reactivity control systems
- TS requirements for reactivity control systems

Technical Topics

Section 4.6 – Functional Design of Reactivity Control Systems

Conclusions

- Meets GDC 4, 23, 25, 26, 27, 28, and 29 because:
 - ♦ Reasonable assurance that the CRDS will remain functional and provide safe shutdown capability under adverse environmental conditions and after postulated accidents
 - ♦ CRDS fails in a safe condition
 - ♦ No single malfunction in the CRDS will result in exceeding SAFDLs
 - ♦ CRDS and CVCS are independent, based on different design principles, and are capable of reliably controlling the rate of reactivity changes during normal operation
 - ♦ Transient and accident analyses show that the reactivity control systems can control reactivity changes during DBEs to maintain core cooling
 - ♦ Reactivity insertion limits prevent prompt power excursion
 - ♦ Extremely high probability of CRDS accomplishing safety function during AOOs
- Additional Considerations
 - ♦ CRDS cooling system meets design requirements
 - ♦ Initial test program adequate to verify reactivity control systems
 - ♦ Reactivity control systems TS ensure protection of public health and safety

ACRONYMS

AOO – anticipated operational occurrence

ASME – American Society of Mechanical Engineers

BOC – beginning of cycle

BOL – beginning of life

CE – Combustion Engineering

CEA – control element assembly

COL – combined license

COLSS – core operating limits supervisory system

CPC – core protection calculator

CPCS – core protection calculator system

CRD – control rod drive

CRDS – control rod drive system

CVCS – chemical and volume control system

DBE – design basis event

DCD – design control document

DNB – departure from nucleate boiling

DNBR – departure from nucleate boiling ratio

ENDF – Evaluated Nuclear Data File

ESFAS – emergency safeguards features actuation system

EOC – end of cycle

EOL – end of life

FTC – fuel temperature coefficient

GDC – general design criterion/criteria

ITAAC – inspections, tests, analyses, and acceptance criteria

LPD – local power density

MDC – moderator density coefficient

OPR1000 – Optimized Power Reactor 1000

PPS – plant protection system

RAI – request for additional information

RCS – reactor coolant system

RPS – reactor protection system

SAFDL – specified acceptable fuel design limit

SRP – Standard Review Plan

TCD – thermal conductivity degradation

TS – technical specifications