



WECTEC LLC  
3735 Glen Lake Drive  
Charlotte, NC 28208  
Tel: +1 980 859 8000

10 CFR 21.21

March 15, 2017

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555-0001

SUBJECT: INTERIM 10 CFR PART 21 REPORT REGARDING 5/8 INCH STAINLESS STEEL  
TUBING FOR V. C. SUMMER UNITS 2 AND 3 AP1000® PROJECT

This letter provides an interim report in accordance with 10 CFR 21.21 pertaining to 5/8 inch SA213 TP316, ASME III, Safety Class B stainless steel tubing that is being supplied for the V. C. Summer Units 2 and 3 AP1000® project. Based on information contained in an inspection report, portions of this tubing was identified with unsatisfactory conditions, including staining, spiral roller tracks on the tubing surface, and pitting of the tubing surface.

Evaluation for reportability in accordance with 10 CFR Part 21 is not able to be completed within the 60-day evaluation period. It is currently expected that the evaluation of this condition will be completed by May 18, 2017.

If you have any questions pertaining to this information, please contact Curtis Castell, Licensing Manager, at 980-859-6373.

Sincerely,

David Durham  
President  
WECTEC LLC

cc: Regional Administrator, USNRC, Region II

FE19  
NRD