

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 Power Uprate Subcommittee
 Open Session

Docket Number: N/A

Location: Rockville, Maryland

Date: May 3, 2017

Work Order No.: NRC-3055

Pages 1-154

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

POWER UPRATE SUBCOMMITTEE

+ + + + +

OPEN SESSION

+ + + + +

WEDNESDAY

MAY 3, 2017

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 8:31 a.m., Joy Rempe,
Chairman, presiding.

COMMITTEE MEMBERS:

JOY REMPE, Chairman

RONALD G. BALLINGER, Member

CHARLES H. BROWN, JR., Member

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

MICHAEL CORRADINI, Member

WALTER KIRCHNER, Member

DANA A. POWERS, Member

PETER C. RICCARDELLA, Member

GORDON R. SKILLMAN, Member

JOHN W. STETKAR, Member

MATTHEW W. SUNSERI, Member

DESIGNATED FEDERAL OFFICIAL:

WEIDONG WANG

ALSO PRESENT:

BILL BAKER, Browns Ferry

CHAKRAPANI BASAVARAJU, NRR

BENJAMIN BEASLEY, NRR

KATHRYN BROCK, NRR

DENNY CAMPBELL, TVA

MICHAEL DICK, TVA

PETER DONAHUE, Browns Ferry

GERRY DOYLE, Browns Ferry

DANIEL GREEN, Browns Ferry

STEPHEN HAMBRIC, Penn State University

LANG HUGHES, Browns Ferry

JEFF LEWIS, TVA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

MATTHEW PANICKER, NRR

MUHAMMAD RAZZAQUE, NRR

FARIDEH SABA, NRR

ED SCHRULL, TVA

VIK SHAH, Argonne National Laboratory

GREG STOREY, Browns Ferry

ANDREA D. VEIL, Executive Director, ACRS

SAMIR ZIADA, McMaster University

*Present via telephone

C-O-N-T-E-N-T-S

ACRS Opening Remarks	
Dr. Joy Rempe, ACRS	5
Staff Opening Remarks	
Kathryn Brock, NRR	8
Introduction	
Farideh Saba, NRR	9
EPU Overview	
Background	10
Parameter Changes Summary	30
Unit Differences	35
Modification Summary	43
Elimination of Containment Accident	
Pressure Credit	61
Transient and Accident Analyses Summary	70
Flow-Induced Vibration & Structural Analyses	77
Power Ascension	83
Public Comments	90

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 P R O C E E D I N G S

2 8:30 a.m.

3 CHAIRMAN REMPE: Good morning. This
4 meeting will now come to order. This is a meeting
5 of the Power Upgrades Subcommittee, a standing
6 subcommittee of the Advisory Committee on Reactor
7 Safeguards.

8 I am Joy Rempe, the Chairman of the
9 Subcommittee. ACRS members in attendance are Ron
10 Ballinger, Matt Sunseri, Dick Skillman, Dana Powers,
11 Mike Corradini, Pete Riccardella, John Stetkar, Walt
12 Kirchner, Charlie Brown -- and Charlie Brown. And
13 Weidong Wang of the ACRS staff is the Designated
14 Federal Official for this meeting.

15 In this meeting, the Subcommittee will
16 review a license amendment request for an extended
17 power uprate at Browns Ferry Nuclear Power Plant's
18 Units 1, 2, and 3. There are several aspects about
19 this LAR that I believe will be of special interest.
20 The three BWRs at Browns Ferry, have relatively high
21 power levels, and at the time of its initial
22 operation, Browns Ferry was the largest nuclear -- or
23 highest-powered nuclear power plant in the world.

24 Each unit is a GE BWR 4 housed within a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Mark I containment. Previously, Browns Ferry has
2 been approved to use AREVA ATRIUM 10 and 10XM fuels.
3 In this request, the licensee, Tennessee Valley
4 Authority, or TVA, has proposed to eliminate their
5 reliance on containment accident pressure credit, and
6 prior to implementation of BPU, TVA will install a
7 new replacement steam dryer in each unit.

8 And finally, I would like to note that
9 this is the first request for BWR that we have
10 reviewed in which the licensee has been approved for
11 transitioning to NFPA-805. Today, we are going to
12 hear presentations from the NRC staff and
13 representatives from the licensee. We have received
14 no written comments or requests for time to make oral
15 statements from members of the public regarding
16 today's meeting.

17 For agenda items on nuclear design and
18 safety analyses, containment analyses, and the steam
19 dryer, staff presentations will be closed in order to
20 discuss information that is proprietary to the
21 licensee and its contractors, pursuant to 5 U.S.C.
22 552 (b) (c) (4). Attendance during this portion of the
23 meeting will be limited to the staff and its
24 consultants, Tennessee Valley Authority, and those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 individuals and organizations who have entered into
2 an appropriate confidentiality agreement with them,
3 and consequently, we're going to have to confirm that
4 we only have eligible observers and participants in
5 the room for this portion of the meeting.

6 And I will rely on the staff and TVA to
7 help us ensure that that is true. In addition, if
8 we start asking questions during the open part of
9 this meeting, please -- that are proprietary, please
10 stop us, and we can hold such questions until the
11 closed portion of the meeting.

12 During today's meeting, the Subcommittee
13 will gather information, analyze relevant issues and
14 facts, and formulate proposed positions and actions
15 as appropriate for deliberation by the Full
16 Committee. The rules for participation in today's
17 meetings have been announced as part of the notice of
18 this meeting previously published in the Federal
19 Register. A transcript of the meeting is being kept
20 and will be made available as stated in the Federal
21 Register notice. Therefore, we request that
22 participants in this Subcommittee meeting use the
23 microphones located throughout the meeting room when
24 addressing us. The participants should first

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 identify themselves, and then speak with sufficient
2 clarity and volume so that they may be readily heard.

3 And we will now begin with this meeting,
4 and I would like to ask Kathryn Brock from NRR to
5 begin.

6 MS. BROCK: Thank you. Good morning,
7 everyone. My name is Kathryn Brock. I am the Deputy
8 Director in the Division of Operating Reactor
9 Licensing in the Office of Nuclear Reactor
10 Regulation.

11 So this is the first ACRS meeting
12 regarding the review of the power uprate application
13 from the Tennessee Valley Authority. The NRC staff
14 appreciates the opportunity to brief you on this
15 important licensing action.

16 The objective of today's discussion is to
17 present the ACRS a request by the licensee to perform
18 extended power uprates at each of the three Browns
19 Ferry nuclear plants. Attendees today include NRC
20 staff and contractors, TVA staff, and TVA staff
21 contractors and vendors. Thanks to everyone for
22 coming today.

23 As was mentioned, Browns Ferry Units 1,
24 2, and 3 are General Electric boiling water reactors

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the BWR/4 design with Mark I containments. Browns
2 Ferry is located in Athens, Alabama, approximately 30
3 miles west of Huntsville. The site contains
4 approximately 840 acres located on the north shore of
5 Wheeler Lake. Next slide.

6 As you can see from the dates, commercial
7 operation at Browns Ferry began in the 1970s, and
8 each unit has received a renewed license, with license
9 expirations in the 2030s. Next slide.

10 This technical review has involved over
11 25 staff from 14 different NRR branches. Technical
12 experts from Oak Ridge National Laboratory, Argonne
13 National Laboratory, the Applied Research Laboratory
14 at Penn State, and McMaster University have supported
15 NRC staff in the review of this license amendment
16 request.

17 Consistent with other BWR EP reviews,
18 much effort, and you will hear about this today, was
19 focused on the steam dryer analysis, containment
20 accident pressure, nuclear codes and methodologies,
21 and fuel analysis. I want to thank the staff and
22 contractors for their thorough and timely review of
23 this amendment request.

24 So after our extensive review, the NRC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff recommends approval of TVA's extended power
2 uprate request. And to give you details of the staff
3 review, I will turn the presentation to Farideh Saba,
4 who was our lead reviewer in this effort.

5 MS. SABA: Thank you. Thank you. Good
6 morning. My name is Farideh Saba. I am the
7 Regulatory Licensing Project Manager in the Office of
8 Nuclear Reactor Regulation Division of Operating
9 Reactor Licensing.

10 Today, you will hear presentations by the
11 Nuclear Regulatory Commission staff, NRC, and
12 Tennessee Valley Authority, TVA, staff, regarding the
13 proposed extended power uprate for Browns Ferry. I
14 will present some information regarding power uprate
15 background, EPU review standard, timeline, and the
16 NRC staff and TVA submittals. Then I present the
17 agenda for today's meeting.

18 Power uprates background: the three
19 categories of power uprates are measurement
20 uncertainty recapture power uprates, MUR; stretch
21 power uprates, SPU; extended power uprates, EPU. Of
22 the 157 power uprates, 31 are considered extended
23 power uprate, or EPU, requiring major modification to
24 the plant to achieve the increased power level. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 most recent EPU reviewed by this committee was Peach
2 Bottom Units 2 and 3. That was issued in August
3 2014.

4 Browns Ferry uprates: the proposed
5 changes would increase the maximum steady state
6 reactor power level for all three Browns Ferry units
7 from 3458 megawatts thermal to 3952 megawatts
8 thermal. This represents an increase of 14.3 percent
9 above the current licensed thermal power.
10 Previously, Browns Ferry Units 2 and 3 had implemented
11 5 percent SPU stretch power uprate in 1998, and Unit
12 1 had implemented a 5 percent stretch power uprate in
13 2007. As such, the proposed EPU represents an increase
14 of approximately 20 percent above the original
15 licensed thermal power level of 3293 megawatts
16 thermal.

17 MEMBER SKILLMAN: Farideh, may I ask this
18 question please?

19 MS. SABA: Sure.

20 MEMBER SKILLMAN: Why was there a time
21 difference between Unit 1 and Unit 2 and Unit 3?

22 MS. SABA: Unit 1 was shut down for a
23 long time. It started -- had the startup in 2007.

24 MEMBER SKILLMAN: Okay. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. SABA: BWR EPU comparison: to put the
2 14.3 percent EPU in perspective, here is a bar chart
3 showing the 20 BWR EPUs that have previously been
4 approved by the NRC. TVA's proposed uprate for
5 Browns Ferry would be represented in the second column
6 and is consistent with typical range of approved EPUs
7 for BWRs.

8 Now, I will review the standard. The NRR
9 document reviews Standard for Extended Power Uprate
10 RS-001, dated December 2003, for its guidance to the
11 staff when performing reviews of EPU applications.
12 TVA followed format and guidance delineated in RS-001
13 in the safety analysis report that is contained in
14 their application. The NRC staff review of the
15 proposed EPU for Browns Ferry also was completed using
16 RS-001 along with applicable regulatory --
17 regulations and regulatory guides and the Standard
18 Review Plan applicable sections.

19 The staff's safety evaluation also used
20 RS-001 SE template. A draft SE by the NRC staff was
21 transmitted to the ACRS in March of this year. An
22 updated version which only contains editorial changes
23 also was provided later in April for ACRS Full
24 Committee.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN REMPE: Okay. So just to
2 clarify here, folks, late last week, I received an
3 email saying you had an updated version. It only had
4 changes that were typo type of corrections, and
5 because it was so late and we are supposed to have 30
6 days, I said just announce it on the record that there
7 were just -- so if you saw a typo and they say we've
8 already fixed it, folks, that is what happened, right?

9 MS. SABA: That is correct, and so --

10 CHAIRMAN REMPE: Okay.

11 MS. SABA: -- the changes are all
12 editorial, no technical changes, evaluation changes,
13 or conclusion changes in the revised one. Basically,
14 the original one is okay right now. Thank you.

15 EPU timeline: now I would like to discuss
16 timeline for the review of Browns Ferry EPU. From
17 October 2014 until August 2015, the NRC staff held
18 seven pre-application meetings with TVA to discuss
19 the key aspects of the upcoming EPU project. On
20 September 21st, 2015, TVA submitted its request for
21 the proposed EPU for Browns Ferry Units 1, 2, and 3.
22 Immediately following the NRC receipt of TVA
23 application, the staff began its acceptance review of
24 the submittal. This was done in accordance with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Office of Nuclear Reactor Regulation, NRR, office
2 instruction LIC-109, Acceptance Review Procedures.

3 Three issues were identified that
4 impacted NRC's acceptance of the TVA EPU application.
5 First, in December -- in September 2015, -- TVA
6 informed the NRC of an error in AREVA's modeling code
7 referred to as MICROBURN-B2. This code was used as
8 part of the AREVA safety analysis. Following a
9 conference call with the staff regarding the impact
10 of this error on the safety analysis, the staff
11 concluded that a revised analysis reflecting the use
12 of MICROBURN-B2 is required prior to NRC staff
13 completing its acceptance review.

14 The second item also was during the
15 initial review of proposed EPU, the NRR staff from
16 the Electrical Branch identified that the final
17 interconnection system impact study associated with
18 electrical transmission was required prior to
19 performing its detailed technical review.

20 The third item was that during a public
21 meeting on November 10th, 2015, the NRC staff also
22 identified that TVA would need to submit additional
23 information associated with the spent fuel pool
24 criticality analysis for each unit.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Slide 12: the licensee provided the
2 supplemental information requested by the staff by
3 three letters in November and December 2015. After
4 reviewing TVA's supplemental information, the NRC
5 staff determined that the proposed EPU was acceptable
6 to comments with the full scoped detail review. The
7 NRC staff projected an EPU completion in July 2017.
8 This timeline supports the scheduled -- TVA's
9 scheduled EPU implementation dates for Unit 3 in
10 spring 2018, Unit 1 in fall 2018, and Unit 2 in spring
11 2019.

12 Now, I would like to talk about the key
13 elements and characteristics of TVA-requested EPU for
14 Browns Ferry. As actually Joy summarized, the --
15 Browns Ferry proposed constant dome pressure for
16 power uprate. Browns Ferry uses AREVA fuel for fuel
17 assemblies in all three units. TVA will replace the
18 -- its steam dryers for all three units for EPU. TVA
19 will not rely on any containment accident pressure
20 credit for specific events associated with the
21 proposed EPU.

22 TVA submitted two safety analysis reports
23 for Browns Ferry, PUSAR and FUSAR. PUSAR is the
24 Power Uprates Safety Analysis Report, which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 summarizes the results of the safety analysis
2 performed by General Electric for TVA to justify the
3 proposed review. PUSAR is based on an NRC-approved
4 approach referred as constant power pressure power
5 uprate by GE. In addition, TVA supplemented PUSAR
6 by the Fuel Uprate Safety Analysis Report, FUSAR.
7 Performed by AREVA, FUSAR technical evaluations are
8 based on a series of NRC-approved AREVA
9 methodologies.

10 Now I talk about the review of Browns
11 Ferry EPU. During the course of the NRC staff review
12 of Browns Ferry EPU, the staff held four public
13 meetings, also performed three audits regarding the
14 review of replacement steam dryers, containment
15 analysis, and spent fuel pool criticality analysis.
16 The NRC staff review resulted in 205 requests for
17 additional information, RAIs.

18 The chart in the following slide provides
19 a breakdown of the RAIs associated with review
20 categories. TVA submitted 37 supplements in response
21 to the staff RAIs in addition to the first three
22 supplements provided during acceptance. To date,
23 approximately 11,000 hours has been documented for
24 the review of this EPU.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Now, as I said before, this chart
2 presents a breakdown of the staff RAIs for review of
3 the proposed EPU. As you can see, 25 percent of RAIs
4 were related to replacement steam dryer. 21 percent
5 were related to the containment engineering
6 evaluation. 20 percent were in fuel and core design
7 areas. The staff presentation during today's
8 discussion will closely align with these areas that
9 are instrumental in the staff's overall assessment
10 and conclusion documented as part of the EPU safety
11 evaluation.

12 The last, the agenda: this slide presents
13 planned agenda for today's meeting. All the morning
14 presentations will be provided by TVA. Additional
15 details will be provided by the TVA staff during their
16 presentation. Following the power ascension
17 presentation, the members of public, stakeholders,
18 will have an opportunity to ask questions or provide
19 comments regarding the proposed EPU for Browns Ferry.
20 After a break for lunch, the NRC staff and TVA staff
21 will discuss four topics in closed sessions due to
22 proprietary nature of the information that will be
23 discussed.

24 CHAIRMAN REMPE: So you never know how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 these meetings will go, but if we go faster than
2 anticipated, will the staff be able to support
3 starting the afternoon session before lunch if that
4 is possible?

5 MS. SABA: I have already communicated
6 with them and let them know that they need to come
7 earlier. If I know how much earlier -- they're able
8 to start half an hour earlier, but if you want to
9 have even earlier than that, we can do that.

10 CHAIRMAN REMPE: We will just see how the
11 day goes, but I just wanted to --

12 MS. SABA: Exactly, yes --

13 CHAIRMAN REMPE: -- give you a heads up
14 on that.

15 MS. SABA: -- as you plan, I understand
16 that we communicated that with me yesterday, and I
17 communicated with the staff.

18 CHAIRMAN REMPE: Great. And then I just
19 wanted to say thank you. Some of these -- the draft
20 SEs we have received over the years for EPU's have
21 open items, and I appreciate that you have done a
22 thorough job and there are no open items in this one.

23 MS. SABA: Thank you. Yes, we don't have
24 any open items.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Now is -- if there are no other further
2 questions, I would like to turn it to -- over to Mr.
3 Edward Schrull, TVA Corporate Licensing Fleet
4 Manager, for an overview of EPU.

5 MR. SCHRULL: Thank you, Farideh. This
6 is the part we didn't rehearse yet, so --

7 (Laughter.)

8 MS. SABA: Yes, we have to move around.

9 CHAIRMAN REMPE: Yes, heads up: on all
10 those little microphones on the front desk, they have
11 green lights that indicate they are on, and as Farideh
12 just showed you, that is how you push it on and off.

13 MR. SCHRULL: Thank you.

14 CHAIRMAN REMPE: Usually members mess
15 that part up, but we will see.

16 (Laughter.)

17 MR. SCHRULL: Good morning.

18 CHAIRMAN REMPE: Do you want to talk?
19 You do need to state your name first, sir.

20 MR. SCHRULL: Yes. My name is Ed
21 Schrull. I am the -- higher? All right. Okay. How
22 is this? Better? Great, thank you.

23 My name is Ed Schrull. I am the TVA
24 Corporate Fleet Licensing Manager. My group authors

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 most of the license amendment requests for the TVA
2 fleet, including those for Browns Ferry, Sequoyah,
3 and Watts Bar. The exception to this are the major
4 projects, such as the Browns Ferry extended power
5 uprate, for which a dedicated site team is formed.
6 My group then provides the corporate oversight and
7 support functions.

8 The members of the Browns Ferry site
9 leadership team seated at the front table from right
10 to left, on the end there is Mr. Dan Green, the Senior
11 Licensing Manager for the EPU project; next to Dan is
12 Mr. Gerry Doyle, the Director of the EPU project; and
13 Mr. Pete Donahue, the Senior Engineering Manager for
14 the EPU project. All three of these gentlemen have
15 been with the project since its inception. Also
16 seated at the front table and presenting this morning,
17 next to Pete, is Mr. Lang Hughes, the Browns Ferry
18 General Manager of Site Operations, and Mr. Steve
19 Bono, the Browns Ferry Site Vice President.

20 At the kickoff pre-submittal meeting in
21 October of 2014, TVA committed to providing a high
22 quality EPU license amendment request by October
23 2015. While that submittal was being developed, TVA
24 held six technical pre-submittal meetings with NRC.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The subjects were fuel-related analyses, the startup
2 test program, replacement steam dryers, elimination
3 of the credit for containment accident pressure,
4 probabilistic risk assessment, and the flow-induced
5 vibration monitoring program. TVA met our commitment
6 with the submittal of the Browns Ferry EPU LAR on
7 September 21st, 2015, ahead of the committed October
8 2015 date.

9 At this time, I would like to turn it
10 over to Mr. Gerry Doyle, the Director of the EPU
11 project.

12 MR. DOYLE: Thank you, Ed, and thank you
13 to the ACRS and Deputy Director and NRC staff, and
14 thank you to all who participated in the project.

15 My name is Gerry Doyle, and I have been
16 with TVA for over seven years. I was hired in 2010
17 as the Browns Ferry Assistant Site VP and was involved
18 in the 95-003 recovery effort in 2011 and led that
19 recovery effort, starting in 2012. As Ed indicated,
20 I have been with EPU since 2014, when I was asked to
21 lead the EPU project in June of that year.

22 One of the first tasks we undertook was
23 to develop a functional organization from extensive
24 benchmarking of previous EPUs, including Grand Gulf,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Monticello, Peach Bottom, Nine Mile Point, and
2 others. I will say we are fortunate in that we are
3 the last in line and could take full advantage of a
4 wealth of industry operating experience, and
5 experienced, qualified, and talented experts. We
6 feel we have assembled the industry's best and expect
7 to demonstrate that today to the ACRS folks.

8 So our EPR -- our EPU project team is
9 staffed with personnel having extensive -- excuse me,
10 BWR plan and EPU experience. A lot of our folks, a
11 lot of our project team is from TVA, which is a
12 dedicated project, and plant resources and corporate
13 resources as well have interactively engaged in the
14 project. Our main vendors are GEH, GE-Hitachi, and
15 AREVA for our fuels. We have many industry-
16 experienced specialty contractors that we got as --
17 as a result of having previous EPU experience. Next
18 slide.

19 MEMBER SKILLMAN: Gerry, before you --

20 MR. DOYLE: Yes sir.

21 MEMBER SKILLMAN: -- change, let me ask
22 this question, and you put the question in describing
23 your background: how has the Authority's experience,
24 95-003, at this site influenced the quality, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 depth, and the breadth of this application?

2 MR. DOYLE: So one of the mantras for the
3 95-003 -- 95-003 recovery was to do exactly that, and
4 we -- we spent a lot of time, effort building both
5 organizationally and plant-wise. We replaced a lot
6 of equipment over the years to satisfy the 95-003
7 inspection criteria.

8 MR. BONO: If I could add -- this is
9 Steve Bono, Site Vice President -- I think there is
10 a wealth of knowledge we gained with respect to
11 nuclear safety and maintaining margins that assisted
12 us in the EPU project as well, so the experience of
13 recovering from 95-003 I think put a greater emphasis
14 on nuclear safety culture at the station.

15 MEMBER SKILLMAN: Thank you.

16 MEMBER SUNSERI: So that effort must have
17 overlapped with the planning and engineering for the
18 EPU. How did that affect your resources, and what -
19 -

20 MR. DOYLE: Actually, there was no
21 overlap.

22 MEMBER SUNSERI: Oh no? Okay.

23 MR. DOYLE: The inspection for 95-003 was
24 completed in January of 2013, and the EPU project

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 kicked off June of that -- of the following year.

2 MEMBER SUNSERI: All right. Good, thank
3 you.

4 MR. DOYLE: But quite frankly, to answer
5 you even further, there's a lot of the team that we
6 had for EPU was -- was asked to participate in EPU -
7 - I am sorry, for 95-003 was asked to participate in
8 95 -- I am getting these backwards -- participate in
9 95-003 was asked to participate in EPU, and we have
10 a lot of our TVA folks that have taken those
11 positions.

12 MEMBER SUNSERI: Yes, so where I was
13 going, just so you know where I was going with that
14 question, I was wondering, you know, what kind of
15 oversight did you have to provide? Because that is
16 kind of two separate paths there, and keep it straight
17 and make sure you have the right attention on the
18 right thing was important, but obviously, it wasn't
19 a conflict, so my question is overcome. Thanks.

20 MR. DOYLE: Thank you.

21 On slide 8, one of the first things we
22 did was align our project on high-level team goals.
23 We talked a little bit about -- other speakers have
24 talked about those already, but we recognized the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 need to work closely with our NRC counterparts and
2 demonstrating that we were committed to implementing
3 an industry-best EPU.

4 That said, we established team goals to
5 ensure source success, specifically, as Farideh noted
6 earlier, to present Nuclear Regulatory Commission
7 with a high quality license amendment request, LAR,
8 and consistent with the RS-001 standards. To that
9 end, we worked closely with Farideh and the technical
10 reviewers to ensure we were providing all the
11 necessary information in a timely manner. I think
12 some of the earlier slides had talked about the number
13 of pre-application meetings and audits that
14 demonstrate that commitment.

15 We also set out to resolve containment
16 accident pressurization credit issues, and Pete will
17 talk a little bit more about that in the next couple
18 segments. We also wanted -- we also committed to
19 replacing the steam dryers for all three units, as
20 Farideh noted earlier, and we have a separate
21 discussion on that topic later in the presentation.

22 Finally, and this goes to your -- one of
23 your questions, was we wanted to provide a smooth
24 transition to -- of EPU to plant operations such that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there were no surprises or issues in plant operations
2 or maintaining the plant at an acceptable level, and
3 Mr. Bill Baker, our -- my Senior Manager for EPU
4 Operations, will talk a little bit more about that a
5 little bit later on.

6 So with that, I would like to turn it
7 over to our Site Vice President, Mr. Steve Bono. Yes
8 sir?

9 MEMBER POWERS: Before you do, there
10 seems to me to be an 800-pound gorilla sitting here
11 in this room, and that is the fact that we have had
12 three rather severe accidents in Mark I containment
13 BWRs. And sooner or later, you're going to ask the
14 Commission to approve a power increase in a Mark I
15 containment BWR, and they are going to have to say
16 why is that prudent in light of the fact of those
17 accidents?

18 And in those accidents, the containment
19 boundary failed. At what point do we discuss how
20 that has influenced this power uprate request, and
21 how do we provide the Commission the defense to the
22 public that it is prudent to provide this power
23 uprate?

24 MR. DOYLE: I think -- I think the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 majority part, we have done extensive analysis and
2 gone through an extreme vetting process on all aspects
3 of the -- of the EPU project, from the hardware that
4 has either installed or we -- we replace over the
5 years, to further analysis, as you will hear
6 additionally on the containment accident
7 pressurization -- excuse me -- we have done extensive
8 analysis to make sure that we met and exceeded the
9 standards in most cases.

10 MEMBER CORRADINI: Right. I think what
11 -- I am not sure exactly where Dana is going, but I
12 thought where he was going was I am sure that you
13 meet the design basis, but are there things that are
14 being considered beyond the design basis that you
15 considered in how the 20 percent increase would
16 influence how you operate or your emergency
17 procedures, et cetera? Is that --

18 MEMBER POWERS: Well, I mean --

19 MEMBER CORRADINI: I don't know --

20 MEMBER POWERS: -- I think that is all -
21 - that could well be part of it, but understand what
22 the pressure -- I mean, our role is to provide
23 technical advice to the Commission on this, and this
24 is going to attract a substantial amount of public

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 attention, and the Commission is going to look at it
2 and say yes, verily, they have dotted every i and
3 crossed every t in the regulations. Is it prudent
4 to do in light of the fact that at the Fukushima
5 accidents, we failed the containment boundaries?
6 Because we failed the containment boundaries, there
7 was substantial release of radionuclides.

8 We don't know a lot about those -- failure
9 of the containment boundary, but it appears, and while
10 this is not founded on definitive evidence by any
11 means, that there is not a lot of margin between the
12 design pressure and the point at which it failed.
13 And so the question comes up to you, these
14 containments look an awful lot like those
15 containment, and is it prudent to do a power uprate
16 now? And when we don't have a lot of information,
17 is there some peculiarity about these reactors in
18 Japan that has been addressed here?

19 And that -- that is the kind of armament
20 that first, Dr. Rempe is going to have to have when
21 she sits in front of the Commission and tries to
22 defend this, and it is the kind of information the
23 Commission is going to have to have when they try to
24 defend any decision they make before the public.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DONAHUE: So this is Pete Donahue.
2 I am the Senior Engineering Manager for the EPU.

3 One thing to consider is that we are being
4 really aggressive with all the Fukushima
5 modifications that are necessary at Browns Ferry, for
6 example, the -- the hardened wetwell vent system, and
7 when we do these modifications to -- to the Browns
8 Ferry units, we -- we consider EPU conditions, so we
9 design them for EPU conditions. As an example of the
10 hardened wetwell vent, the requirement is -- is to be
11 able to pass approximately 32 pounds mass per second,
12 and we designed it for 58 pounds mass per second, so
13 that is --

14 MEMBER POWERS: That is the really kind
15 of terrific information that we need to have at hand
16 to do this. The other issue pertinent to those
17 hardened vents is there is substantial speculation,
18 I would call it now, that at Fukushima there was a
19 delay, a reluctance to use the hardened vents, and
20 providing evidence that in fact there won't be
21 reluctance to use those hardened vents seems to be
22 another piece of armament to have in hand when you
23 defend this power uprate.

24 So to the extent that you can -- but I am

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 asking you kind of extemporaneously to do this, but
2 I think you can, as Mr. Donahue just pointed out, you
3 know, it came -- you have this information at the
4 tips of your fingers. Understand the prudence
5 question that -- that is going to arise in this that
6 quite frankly is not written into the regulations,
7 but quite frankly does arise in highly public
8 decisions and has historically. It would not be
9 unique in that regard.

10 MR. DOYLE: Thank you. So with that, I
11 will turn it over to Mr. Steve Bono, our Site Vice
12 President.

13 CHAIRMAN REMPE: Actually, I had a
14 question, if you don't mind real quick on -- could
15 you tell me where you are on the transition to NFPA-
16 805? It has been approved by the staff, but has it
17 been fully implemented?

18 MR. HUGHES: We have transitioned over
19 to NFPA-805. All the modifications are not yet
20 complete. There are a couple of major modifications
21 that, you know, that are outstanding through 2019,
22 but many of the modifications, in accordance with our
23 timeline that we committed to, have already been
24 completed. The fire protection report, all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 procedures, the analysis that we do for transient
2 combustibles, fire areas, high-risk evolutions,
3 everything as such has already been completed and
4 proceduralized. We actually have implemented them
5 both for the online and the outage conditions, and
6 that will continue over the next two years to
7 implement the mods, the final one being the final
8 installation of the emergency high pressure makeup
9 pumps.

10 CHAIRMAN REMPE: Okay. So just as you
11 mentioned earlier with the wetwell vents, and you
12 considered EPU conditions, my understanding from what
13 I read in the documentation provided to me for this
14 meeting was that you considered EPU conditions in
15 your NFPA-805 application, true?

16 MR. DONAHUE: That is true, except for
17 crediting containment accident pressure. In that
18 case, we dealt with that in EPU --

19 CHAIRMAN REMPE: Okay.

20 MR. DONAHUE: -- and not in 805.

21 CHAIRMAN REMPE: Were there some things,
22 and maybe we can get to it later when you start
23 talking about like your containment accident pressure
24 analysis, but other things that the NFPA analyses

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 helped you with this EPU application --

2 MR. HUGHES: Absolutely.

3 CHAIRMAN REMPE: -- at all? And if you
4 could discuss that a little bit, I would be interested
5 in it.

6 MR. HUGHES: Okay.

7 CHAIRMAN REMPE: Thank you.

8 MR. BONO: All right. Thank you. Good
9 morning. Thank you for the opportunity. I am Steve
10 Bono. I am the Site Vice President at Browns Ferry.
11 I will give an overview of the Browns Ferry -- the
12 station, the changes in parameters, and then Lang
13 Hughes, the General Manager at the site, will go
14 through unit differences and modifications as we
15 implement the extended power uprate.

16 So as stated, Browns Ferry is a three-
17 unit GE BWR/4 Mark I containment. It is the only
18 three-unit BWR in the United States. The operating
19 license data as the dates and the extended license
20 renewals are shown on the screen there, and also the
21 power history, as was mentioned this morning, our
22 original thermal limit compared to what we're
23 proposing as part of the extended power uprate.

24 In the next slide, you will see there are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some parameters changes that we will talk briefly
2 about, some in more detail later. Some things that
3 I will point out: the core flow range is not changing
4 from the -- the current -- the upper band is not
5 changing for the current limit, the power limit, as
6 we go to extended power uprate, so we are a maximum
7 extended low-limit analysis plant, but we are not a
8 MELLLA+ plant, so that is one area that we are doing
9 the analysis now to give us more flexibility to our
10 operators as we go forward in EPU, but it is not part
11 of this presentation.

12 As mentioned, it is a constant pressure,
13 so our steam dome pressure will remain at 1050 as we
14 operate today, and we will in the extended power
15 uprate. And then Pete will talk in much greater
16 detail, but we do not credit the containment accident
17 pressure for the EPU condition, and Pete will go over
18 a lot of this in more detail later as we talk about
19 net positive suction head.

20 MEMBER SKILLMAN: Steve, let me ask this
21 relative to CAP and your heat sink temperature: how
22 many times in the course of an operating year are you
23 pressed on your ultimate heat sink temperature from
24 the Tennessee River there?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BONO: Lang can provide more detail,
2 but we generally don't challenge our ultimate heat
3 sink design temperature.

4 MR. HUGHES: No, we typically have not
5 ever challenged our ultimate heat sink design
6 temperature. The biggest, you know -- if you look,
7 you know, our ultimate heat sink, we have, you know,
8 quite a bit of margin with respect to our ultimate
9 heat sink temperature. We have alarms and
10 indications that we monitor on a frequent basis. You
11 know, river flow, you know, obviously helps in that
12 with the river flow past the plant, but typically,
13 even in the depths of summertime, we have quite a bit
14 of margin with respect to ultimate heat sink.

15 MEMBER SKILLMAN: Thank you.

16 MEMBER CORRADINI: So I don't remember,
17 I am sure I should: so with EPU, your window -- you
18 are now back to what I remember to be -- so are you
19 running with MELLLA or MELLLA+ in terms of your --

20 MR. BONO: We are running with MELLLA.
21 We --

22 MEMBER CORRADINI: Okay. That is what -
23 -

24 MR. BONO: -- are doing --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: -- I was guessing.

2 MR. BONO: -- the analysis for MELLLA+.

3 MEMBER CORRADINI: So are we going to see
4 you all again later for another --

5 CHAIRMAN REMPE: For an EFW --

6 MR. BONO: We have that analysis ongoing
7 now. When we complete that analysis, we are pursuing
8 MELLLA+.

9 MEMBER CORRADINI: Okay.

10 CHAIRMAN REMPE: MELLLA+, or EFW?

11 MR. BONO: MELLLA+.

12 CHAIRMAN REMPE: With AREVA fuel?

13 (No audible response.)

14 MEMBER CORRADINI: Oh, that is a new one.
15 I am sure our Chairman here will love to look at that.

16 MR. BONO: I think Brunswick is doing it
17 right now, right?

18 CHAIRMAN REMPE: Okay. The other
19 question I had was when we had another plant come in,
20 they actually gave us a time period for the CAP
21 credit. Do you know how many hours you rely on that
22 CAP credit?

23 MR. BONO: Yes. I mean, at a -- at a
24 maximum, it is 18 hours.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN REMPE: 18 hours? Okay.

2 MR. BONO: Yes. I am sorry. CAP credit,
3 I think it was -- it's not quite 18. Let me -- I've
4 got a number here somewhere.

5 CHAIRMAN REMPE: You can get it to me
6 later --

7 MR. BONO: I was going to wait for that
8 for mine, but --

9 CHAIRMAN REMPE: Yes --

10 (Simultaneous speaking.)

11 CHAIRMAN REMPE: -- it is something that --

12 MR. BONO: It is between -- it is about
13 80 minutes.

14 CHAIRMAN REMPE: Okay. Lang, do you want
15 to cover unit --

16 MR. HUGHES: Sure.

17 MR. BONO: -- differences?

18 MR. HUGHES: Yes. Next slide, please.

19 Good morning. My name is Lang Hughes.
20 I am the General Manager of Site Operations at Browns
21 Ferry. Been there for 25 years, and was a longtime
22 licensed operator at the plant.

23 On page 12, as I go through, I will be
24 talking about some of the unit differences as well as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some of the major modifications associated with the
2 extended power uprate, some of which have been in
3 place for some time. For several of these, there
4 will be extended discussion on these in later topics
5 in the presentation. I won't touch on all of them
6 as we go through, but, you know, for questions, I
7 will answer any questions that you may have.

8 If you look on slide -- slide 12 of the
9 unit differences, one is the main generator ratings,
10 with a difference between the Unit 1 generator and
11 the Unit 2 and 3, which are minor. This is simply a
12 function of the vendor that did the generator rewinds
13 on Unit 1 compared to Unit 2 and 3. And also, the
14 emergency diesel generators, which is all the
15 original design, Unit 1 and 2 share four diesel
16 generators. Unit 3 has its own four diesel
17 generators.

18 In addition to this, the operators are
19 trained and we have procedures such that we have the
20 ability to cross tie our diesel generators so that
21 specifically the Unit 3 can supplement Unit 1 and 2
22 if needed. We do have that cross tie function, that
23 cross tie capability, and it is proceduralized, and
24 our operators are trained as such.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Slide 13 --

2 CHAIRMAN REMPE: Do --

3 MR. HUGHES: Sure.

4 CHAIRMAN REMPE: -- as you go through
5 these, can you give me an idea -- I noticed in your
6 analysis for EPU, sometimes you have different
7 results for Units 1, 2, or 3, and which of these
8 differences in this slide and the next slide really
9 impacted those results that differ for Units 1 and 2?

10 MR. HUGHES: Actually, as far as the --
11 you know, the -- I will tell you, as far as the unit
12 differences and the impact on the operators, they are
13 transparent to the operators as far as what they see,
14 the way they operate. We have a simulator for Unit
15 3 and a simulator for Unit 1 and 2, so in reality,
16 the unit difference is really not an impact to the
17 operators at all.

18 CHAIRMAN REMPE: But the analysis results
19 differed for the units, and is there something of
20 these differences that really made a difference in -
21 -

22 MR. DONAHUE: Well, for instance, if you
23 take the -- the diesel generators and -- and if you
24 relate it to the analysis that was done on containment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 accident pressure, for the design basis accident, we
2 are -- the more diesels gives us the luxury of having
3 two RHR pumps aligned to two heat exchangers during
4 the design basis event, which kind of separates us
5 from other plants, other EPUs.

6 We are similar in configuration to the --
7 - the previous EPU that -- that was approved.
8 However, the difference between us and the previous
9 one is -- is exactly these diesels that help us --
10 give us more power to push the RHR pumps.

11 CHAIRMAN REMPE: Thank you.

12 MR. DONAHUE: You're welcome.

13 MR. HUGHES: Slide 13? So for the fuel
14 makeup, and we will have more discussion on this later
15 as well, for the EPU implementation, as you can see
16 on the slide, Unit 1 and Unit 3 will have a mixture
17 of the ATRIUM 10XM and the ATRIUM 10 twice burnt.
18 All the ATRIUM 10 will be the core periphery, but for
19 both of those, for Unit 2, just based on the timing
20 of the cycle, it will start up with all ATRIUM 10XM
21 fuel.

22 We did do the analysis for both
23 equilibrium and transition core designs. For the
24 RCIC system piping, we do have -- the original design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 had cross tie line, a 22-inch cross tie line between
2 both loops. This has been completely removed on
3 Units 1 and 3. Unit 2 has two cross tie valves. The
4 normal configuration of the plant is to maintain one
5 of these valves closed at all times. This is a
6 feature that was in the original design that actually
7 was not used after approximately 1977. All your
8 current operators are -- this has never been used,
9 and the only cross tie left is on Unit 2. The valve
10 is not only closed, it is also deactivated with no
11 electrical power on it, so it cannot be operated at
12 any time.

13 CHAIRMAN REMPE: So I have a couple of -
14 -

15 MEMBER KIRCHNER: Lang?

16 CHAIRMAN REMPE: Oh --

17 MEMBER KIRCHNER: Oh --

18 CHAIRMAN REMPE: -- go ahead.

19 MEMBER KIRCHNER: -- pardon. Could you
20 just highlight some of the major shared -- since
21 you're talking about cross tie lines, major shared
22 functions by the three units?

23 MR. HUGHES: Sure. The major shared
24 functions of the three units other than the diesel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 generators will revolve around --

2 MEMBER KIRCHNER: Yes.

3 MR. HUGHES: -- revolve around a lot of
4 your secondary containment systems, your standby gas
5 treatment system. We have three trains which are all
6 diesel-backed which the three units share, the
7 control room emergency ventilation pressurization
8 system. We have two trains also diesel-backed, which
9 are shared between the three control rooms. You
10 know, the original installation of the hard wetwell
11 vents, all of the units had a common discharge flow
12 path. As part of the modifications, that is all
13 being changed. Two of the units have already been
14 changed, to where they have their own flow paths and
15 filtration systems.

16 For the -- there are some things on the
17 secondary side, the turbine building side, which are
18 common, such as air systems, raw water cooling
19 systems, and so forth. Even though that they have
20 separate aspects for each unit, they do have cross
21 tie capability and so forth, and such are shared.
22 But for the most part, everything on the -- the
23 primary reactor side is specific to each unit, with
24 the exception of we do have cross tie capability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 amongst the diesel generators, and we can also cross
2 tie our residual heat removal systems. We have cross
3 tie lines for various functions, and also we have the
4 ability to use our reactor heat removal servicewater
5 system via our residual heat removal system from the
6 cross tie in certain emergency situations in the
7 emergency operating procedures to inject raw water
8 into the vessel, and we have cross tie capability for
9 that as well.

10 (Simultaneous speaking.)

11 MR. HUGHES: Those are the major ones.

12 MEMBER KIRCHNER: So post-Fukushima,
13 then, it sounds like, did you do major walkdown of
14 common mode, common cause kind of initiating events,
15 et cetera, and response?

16 MR. HUGHES: As part of the FLEX
17 modifications, the Fukushima modifications, we did do
18 a lot of that, a lot of the testing incorporated into
19 our procedures as well for that. But everything, and
20 the operators are trained as such, for the common
21 systems, the controls, you know, are -- are typically
22 done by the unit that -- that is using them at the
23 specific time. The only one that is a little bit
24 different than that is the control room emergency

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ventilation system, where all the controls for it are
2 specifically on the Unit 2, but they are not impacted
3 or anything as far as the auto-initiation or
4 everything like that. All the auto-initiation logic
5 and everything else, it stays the same and not
6 specific to any one unit.

7 MEMBER STETKAR: Could you --

8 MEMBER KIRCHNER: Thank you.

9 MEMBER STETKAR: -- elaborate a bit? You
10 kind of focused on 1, 2, and 3 as if they are sort of
11 the same. Could you focus on differences in the
12 amount of shared systems between just 1 and 2, and
13 put 3 over where it is?

14 MR. HUGHES: Sure. The biggest thing
15 between Unit 1 and 2 is obviously the sharing of the
16 diesel generators.

17 MEMBER STETKAR: What about the cooling
18 water systems?

19 MR. HUGHES: The cooling water systems,
20 the ultimate heat sink, they are. There's 12, or
21 actually, 12 pumps, four of which we use for emergency
22 equipment cooling water for like diesels --

23 MEMBER STETKAR: And they are normally
24 cross tied between the two units?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HUGHES: They are normally cross tied
2 --
3 MEMBER STETKAR: So it is --
4 MR. HUGHES: -- between the --
5 MEMBER STETKAR: -- one big --
6 MR. HUGHES: -- two.
7 MEMBER STETKAR: -- system that supplies
8 both units?
9 MR. HUGHES: That is correct.
10 MEMBER STETKAR: Nuclear service cooling
11 water, or whatever you -- I have forgotten what it is
12 --
13 MR. HUGHES: Correct.
14 MEMBER STETKAR: -- called. I -- I used
15 to know more about Browns Ferry than I have forgotten,
16 so --
17 MR. HUGHES: Yes. Those are shared
18 systems as well.
19 MEMBER STETKAR: Okay. So they are --
20 they are pretty -- my recollection is 1 and 2 are
21 pretty closely cross tied. 3, except for the
22 electrical supplies, is -- is a little bit more
23 separated.
24 MR. HUGHES: Unit 3 is more separated,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 correct.

2 MEMBER STETKAR: Thank you.

3 CHAIRMAN REMPE: So this is a nit, but I
4 read it not only in your FUSAR, but also in the
5 staff's draft SE, and I -- I don't think -- I think
6 I can say it in a non-proprietary manner, but
7 basically, in the combustible gas control section, it
8 talks about that you did a bounding analysis by
9 assuming that your AREVA fuel with the lowest cladding
10 mass because the lower cladding mass yields more
11 limiting results, and that seemed counterintuitive to
12 me. And can someone explain that --

13 MR. STOREY: Yes, Greg Storey --

14 CHAIRMAN REMPE: -- to me?

15 MR. STOREY: Yes. This is Greg Storey.
16 It is because the combustible gas control is actually
17 controlled by the oxygen, not the hydrogen, so it is
18 -- that is what makes it seem the reverse. So you're
19 controlling how much oxygen is present. I don't know
20 if that helped out or not, but --

21 CHAIRMAN REMPE: It doesn't, but maybe
22 you can explain to me --

23 MR. STOREY: The lower clad mass will
24 result in the more limiting of the oxygen, which is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what you're controlling it to.

2 CHAIRMAN REMPE: Okay.

3 MR. STOREY: Yes.

4 CHAIRMAN REMPE: I have to think about
5 that for a bit. Thank you.

6 MR. HUGHES: Go to slide 14? On slide
7 14, we have an overview of the major modifications.
8 You can look at several of the modifications which
9 have already been completed, such as the cooling fans,
10 the condensate pumps, the condensate booster pumps,
11 the reactor feed pumps. These are all the power
12 uprate pumps. Unit 1 and 2 have had all pumps
13 installed since 2007. Unit 3 completed final
14 installation of the reactor feed pumps in the spring
15 outage of 2016. These pumps and all the major are
16 something the operators are very familiar with,
17 trained on and have been in service for essentially
18 ten years on both Units 1 and 2, so all of that was
19 completed prior to the EPU, and really, a lot of these
20 modifications, the way it worked out such that we can
21 really focus on, you know, the EPU piece and the
22 start-up and the testing and so forth and not have to
23 go back with specific component-type training for the
24 operators for all the individual pumps and all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 changes that we made over time.

2 The other thing that we have been doing
3 for some time now is actually taking and running these
4 scenarios at EPU conditions. Going through, we have
5 a team of people. We have used some of our licensed
6 operators as well as some of our ex-operators, Mr.
7 Bill Baker and his team going through and running
8 these, and, you know, going through, and a lot of
9 this stuff we'll go through for the operator response
10 over the next -- course of the next year or so, and
11 operator training for the additional EPU aspect of
12 running these modifications.

13 MEMBER CORRADINI: I am sorry. I didn't
14 meant to interrupt you.

15 MR. HUGHES: That is fine. Go ahead.

16 MEMBER CORRADINI: Did you need to
17 finish? I am curious about, with EPU, did anything
18 change in terms of RCIC operation relative to things
19 beyond the design base or the emergency operating
20 procedures in how you operate RCIC?

21 MR. BONO: No.

22 MEMBER CORRADINI: So nothing is -- with
23 the BWR Owners' Group, things have remained the same
24 if I go up by, what is it, 14.3 percent? There's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 enough capacity and the operational window for RCIC
2 is the same?

3 MR. BONO: Yes.

4 MEMBER SKILLMAN: Lang, I would like to
5 ask this question please: as I began to review this
6 application, I was anticipating that there would be
7 a change in the slick flow rate, and I am assuming
8 the slick is a charging pump design, as --

9 MR. HUGHES: Correct.

10 MEMBER SKILLMAN: -- we have seen for --

11 MR. HUGHES: Positive displacement pump.

12 MEMBER SKILLMAN: -- 50 years. But the
13 hold down that is being added is the increase in the
14 B-10 concentration, and it is primarily to arrest
15 during an ATWS. That is the key to -- one of the two
16 keys to the CAP. I was looking for some calculation
17 that showed the consequence of the increase of the B-
18 10 concentration, the mass flow rate of slick
19 injection into the reactor coolant system, and some
20 calculation that identified mixing capability. I did
21 not find that in any of the documentation.

22 I was up about -- I reviewed all of the
23 attachments. I figured this has got to be here
24 somewhere. So I am curious: where is that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 information presented?

2 MR. HUGHES: Well, Michael, can you?

3 MEMBER SKILLMAN: The reason I ask is
4 this is one half of the argument for CAP. The other
5 is the fouling coefficients --

6 MR. HUGHES: Sure.

7 MEMBER SKILLMAN: -- for all your heat
8 exchangers, so I was -- I was really curious about
9 this piece of the CAP credit.

10 MEMBER CORRADINI: Just a clarification,
11 I want to ask, it was my impression -- again, I don't
12 remember this system compared to a previous EPU --
13 but I thought it was more LOCA and Appendix R that
14 were limiting for CAP, not ATWS. That was my memory,
15 but maybe it is different in this design.

16 MR. DONAHUE: Well, we looked at -- we
17 looked at both the design basis accidents and the
18 special events --

19 MEMBER CORRADINI: Okay.

20 MR. DONAHUE: -- and so there's some that
21 are more limiting, and the special --

22 MEMBER CORRADINI: Okay.

23 MR. DONAHUE: -- events --

24 MEMBER CORRADINI: Okay. So it may be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 different, okay.

2 MR. DONAHUE: From the design basis.

3 MR. DICK: This is Michael Dick with TVA.

4 MEMBER SKILLMAN: Yes sir.

5 MR. DICK: Just to clarify your question
6 on the mixing capability, are you talking about as
7 far as the vessel --

8 MEMBER SKILLMAN: Yes.

9 MR. DICK: -- model?

10 MEMBER SKILLMAN: Yes.

11 MR. DICK: Okay. Well, the vessel model
12 that was used by GE-Hitachi is the approved ODIN
13 model. That's in -- if you could -- we could -- we
14 can supply you the topical report where that was --
15 that was approved under a generic basis for use for
16 BWR ATWS analysis. So there wasn't any change in the
17 mixing model that was used for the EPU analysis.

18 MEMBER SKILLMAN: So simply changing the
19 B-10 and the charging rate -- and the charging rate
20 is the same, and that provides the incremental
21 negative reactivity essential to arrest this event?

22 MR. DICK: This is Michael Dick with TVA.
23 In actuality is the modification we performed was to
24 increase the boron-10 enrichment --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Yes.

2 MR. DICK: -- but what we're actually
3 crediting as far as with the boron equivalency
4 equation that's in the technical specification is
5 actually a higher flow rate, which is well within the
6 existing pump capability, i.e. the previous ATWS
7 analysis used a flow rate of 39 GPM. Okay. We used
8 in the analysis phase a flow rate of 50 GPM, and we
9 actually used as a concentration of 8.7 percent, but
10 how we have now -- we are now -- we are essentially
11 putting it into the technical specification to show
12 that we will be within the licensing bases, that we
13 have modified the boron equivalency equation in the
14 technical specifications.

15 MEMBER SKILLMAN: Okay. And that
16 changed tech spec is not in the documentation that we
17 received. That --

18 MR. DICK: Yes it is. It would be in --

19 MEMBER SKILLMAN: Then it would be a
20 later --

21 MR. DICK: It's in the safety evaluation.
22 It's also in LAR Attachment 2, I believe.

23 MEMBER SKILLMAN: Okay. I was looking
24 for the new 5.5.14 tech spec.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. GREEN: That tech spec is actually -
2 - this is Dan Green. That tech spec is --

3 MEMBER CORRADINI: Dan, you need to go
4 somewhere on a mic. I don't think --

5 MR. GREEN: Oh, sorry.

6 MEMBER CORRADINI: -- they can hear you.

7 MR. GREEN: That -- this is Dan Green.
8 That tech spec is actually 3.1.7.6 has the boron
9 equivalency equation, and you will see the change
10 there in our -- in Attachment 2 of the LAR. It is
11 also documented in the SE in the tech spec section.

12 MEMBER SKILLMAN: There must -- there are
13 multiple -- there are multiple attachments because
14 they are sequential, so I was up to about 48 or 47 or
15 46 last night --

16 MR. GREEN: In the SE, in the draft SE,
17 if you go to the back where the tech specs and --

18 CHAIRMAN REMPE: Page --

19 MR. GREEN: -- license conditions --

20 CHAIRMAN REMPE: -- 360.

21 MR. GREEN: -- are described, you will
22 see the tech spec in there.

23 CHAIRMAN REMPE: So it is page 360 out
24 of 402.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Thank you, Joy.

2 CHAIRMAN REMPE: Yes.

3 MEMBER SKILLMAN: Okay.

4 CHAIRMAN REMPE: Can't get there quickly.

5 MEMBER SKILLMAN: Enough. I have -- I
6 have received what I need. Thank you. Thanks.

7 MR. HUGHES: The only thing I will
8 mention on slide 14 as far as the major modifications,
9 in addition to the pumps, you know, really for us is
10 the addition of the tenth condensate demineralizer,
11 which has been completed on all units. The original
12 design had nine, so we now have ten condensate
13 demineralizers in all three units.

14 Slide 15, I will touch base on just a
15 couple of these. Some of this will be covered in the
16 later presentation. Slide 15, the one that I will
17 focus on for this discussion really is the change
18 with respect to the main generator hydrogen pressure.
19 There is an incremental change in the normal operating
20 pressure. The big change in this one really for the
21 operators is we are going to an automatically
22 regulated generator hydrogen pressure, which some
23 plants use, but right now, we use manual makeup to
24 maintain pressure between 60 and 65 psig, so this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will actually lessen the burden on the operators with
2 the installation of the auto-regulator and the main
3 generator hydrogen pressure control.

4 Slide 16, the hardened wetwell vent
5 system, as I mentioned earlier, this is something
6 that has been implemented on Units 1 and 2. As I
7 said, the original design had the common flow path,
8 but now, Units 1 and 2 have their own flow path, but
9 Unit 3 will get the final modifications during the
10 upcoming spring outage, the EPU implementation outage
11 in the spring of 2018.

12 And to kind of address your question,
13 sir, earlier with respect to protection of the
14 containment and the operators and so forth, you know,
15 one of the things -- you know, all of the use of our
16 hardened wetwell vents is covered by our emergency
17 operating procedures. Our operators are trained to
18 take action in accordance with our procedures. It
19 is something that we reinforce on a continual basis
20 to follow that, and the operation of our hardened
21 wetwell vents' procedures is dictated per our
22 emergency operating procedures, which drives you to
23 one of our appendices for this operation. It tells
24 you exactly what to do, what to monitor, and when you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 would use that.

2 MEMBER POWERS: It seems to me that what
3 needs to be stated and made very clear is that there
4 cannot be interference in the execution of those
5 emergency procedures by higher management. That is
6 -- that is one that -- that the Commission has got to
7 be on with that piece of information, because that is
8 the question that is going to be posed by an
9 interested member of the public when they contest
10 this decision and say yes, you've got these wonderful
11 hardened vents, but they have to cool downtown
12 Washington in order to get approval to use them.

13 You know, that is just not going to fly.
14 It has got to be absolutely crystalline that there is
15 not going to be interference in the execution of those
16 emergency procedures by the operators.

17 MR. BONO: Sir, we actually have some of
18 our licensed operators here with us today, and I will
19 -- I can assure you, they don't take direction from
20 anyone.

21 (Laughter.)

22 MR. BONO: I do not give direction during
23 the EOIs as a Site Vice President, that they are
24 trained to operate in accordance to --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: And I absolutely believe
2 you, but it has also got to be something that in your
3 defense of this proposal, you make absolutely
4 crystalline clear because that is -- I mean, that is
5 the legitimate question that is going to be raised of
6 you, and it -- just make it absolutely sure that
7 everybody understands that these hardened vents will
8 be used as prescribed in the emergency procedures,
9 without interference.

10 MR. BONO: Yes sir.

11 MR. BAKER: This is Bill Baker. I am the
12 Senior Manager of EP Operations. I was a longtime
13 SRO here at the plant, and I am in charge right now
14 of going through all the accident and transient
15 analysis at EPU conditions with all of the EOIs.

16 We are introducing the operators to those
17 now, and we see no difference in the way we would
18 execute those EOIs now as to what we did before. As
19 far as operating things like the hardened wetwell
20 vent, we take our operators to that level several
21 times during the year in transient and accident
22 conditions in the simulator, and -- and it is -- that
23 is the expectation of the SRO that they would execute
24 that step as necessary.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: And that is absolutely
2 believable. I have no doubt on that. What you have
3 to make crystalline is that outside the simulator, in
4 actual accident conditions, the -- the Site Vice
5 President says well, I don't know, we better not
6 release radioactivity out in the environment, so hold
7 off on that, that -- that the operator will say screw
8 you, the -- the procedure says do this, and my license
9 hangs on me doing this. That has to come across as
10 something that -- that you can take to the bank.

11 MR. BAKER: Yes sir.

12 MEMBER STETKAR: At Browns Ferry, when
13 you transition to whatever -- whatever you want to
14 call them, SAMGs or FSGs or whatever Gs you have that
15 aren't EOIs, who -- who gives the direction to open
16 the vents? Is it the -- the group in the technical
17 support center, or is it the shift manager or whatever
18 you call him down there?

19 MR. BAKER: This is Bill Baker.
20 Initially, it belongs to the shift manager, until --

21 MEMBER STETKAR: Okay.

22 MR. BAKER: -- until such time as we
23 staff the technical support center.

24 MEMBER STETKAR: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BAKER: And then once the transition
2 takes place where the shift manager turns over to the
3 TSC, that responsibility falls to the decision-makers
4 in the TSC.

5 MEMBER STETKAR: So in practice, if you
6 got into these venting scenarios, the timing would
7 probably be such that the command and control is over
8 in the TSC, right?

9 MR. BAKER: That is probably true, yes.

10 MEMBER STETKAR: Okay.

11 MR. CAMPBELL: My name is Denny Campbell.
12 I am a current SRO at Browns Ferry and a qualified
13 shift manager, and I would like to assure the
14 committee that the decisions made by the shift manager
15 in the control room are where the decisions are made.
16 We also address early containment venting to be able
17 to get ahead of the containment. That is a new
18 strategy for us. We have been using that for a couple
19 of years now.

20 We run scenarios where the shift manager
21 and the unit supervisor must utilize the -- the
22 hardened vent, and it is used, and that decision is
23 -- is predicated on the conditions of the -- of the
24 plant, and not on any upper management.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: I am not -- just help
2 me out just a little bit. I am not a BWR guy, so I
3 don't have an intuitive sense of timing. If you're
4 going to do an early vent, is the timing such that
5 you would expect that to be covered before the TSC is
6 manned, or is that -- I -- as I said, I don't have a
7 sense of the timing, so --

8 MR. CAMPBELL: We practice it that way.

9 MEMBER STETKAR: You do? Okay.

10 MR. CAMPBELL: Yes, we do practice it
11 that we make the decision in the --

12 MEMBER STETKAR: Okay.

13 MR. CAMPBELL: -- control room.

14 MEMBER STETKAR: Okay. Thank you.

15 CHAIRMAN REMPE: So since we have
16 digressed a bit into post-Fukushima, I am aware, and
17 we had someone come and talk -- right. Well, a group
18 came and talked to us about the new technical support
19 guidelines, and I know the BWR Owners' Group has been
20 developing them, and it is my understanding that they
21 are in the process of interacting with the plant staff
22 on some of these new procedures. Has Browns Ferry
23 been involved with some of those interactions?

24 MR. HUGHES: Our actual -- actually, one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of our senior reactor operators at Browns Ferry is on
2 the -- the committee for the BWR Owners' Group that
3 actually, he goes to all the meetings.

4 CHAIRMAN REMPE: Is this Bill Williamson,
5 or is this --

6 MR. HUGHES: Well, Bill Williamson is our
7 reactor engineer that's on it, and we also have
8 another SRO, Jeff Barker, that's on it. We actually
9 have two people that are -- attend all the meetings,
10 very familiar with the guidance, and are fully
11 ingrained in the implementation and changes going
12 forward.

13 CHAIRMAN REMPE: But okay, so I know they
14 participate in it, but have they started going to
15 your plant is what I am asking. Has some of it
16 started to reach out to the actual sites yet, and is
17 your site one of those that they're actually starting
18 to talk to the operators and say how it will work on
19 your plant-specific case?

20 MR. HUGHES: I don't know that we've got
21 that far with respect to talking to the operators.

22 MR. BONO: We can -- we can take that
23 action and --

24 CHAIRMAN REMPE: I am just curious.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BONO: -- after the break, we'll give
2 you an answer.

3 CHAIRMAN REMPE: This is a bit beyond the
4 EPU, but it is something that I have been curious
5 about.

6 MR. BONO: Okay.

7 CHAIRMAN REMPE: Go ahead. Thanks.

8 MR. BONO: We'll get you an answer.
9 You're welcome.

10 MR. HUGHES: But the other thing I will
11 mention on slide 16 is the changes to the alternate
12 leakage treatment pathway. You know, we did identify
13 that the alternate leakage pathway created in our
14 alternate source term amendments, it's a non-
15 conforming condition for us currently. You know, we
16 are making design modifications beginning on Unit 3
17 for EPU in the spring where we not only add a new
18 valve into the steam line, but we go and replace
19 several valves for this modification. All three
20 units will have this modification prior to operating
21 at EPU conditions.

22 Page 17, there's two items listed on page
23 17. The first one has to do with the instrumentation,
24 and really what we did was go back and look, and we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are going to be doing some specific instrumentation
2 changes really having to do with set points and a re-
3 spanning of the instrumentation. This is something
4 to where, you know, all of our control rooms are human
5 factors. Human factor, we do take into account the
6 human factors for this. As far as the operators and
7 what they will see, it will look the same to them.
8 There will be no differences as far as, you know, the
9 way they are trained or what they're used to with
10 respect to the instrumentation, and, you know,
11 something that, you know, for them will essentially
12 be transparent. Other than a few set point changes,
13 it will not look any different to them.

14 Additional instrument changes, probably
15 the most major for us is the upgraded condenser
16 instrumentation changes where we install nine new
17 condenser vacuum pressure transmitters. What this
18 really does is give the operators a better picture
19 with respect to operating margin on condenser vacuum.
20 Turbine operation, we will have vacuum
21 instrumentation for each individual water box for
22 which they will have indication of in the control
23 room.

24 Right now, you know, what they look at is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 really a combined overall instrument for condenser
2 vacuum, so they will have specific indication with
3 respect to turbine operating set points for the main
4 turbine reactor feed pumps, the turbine bypass valve
5 operation and everything associated with that, and
6 with that instrumentation logic, a better indication
7 for the operators.

8 And that concludes my portion, pending
9 questions.

10 CHAIRMAN REMPE: Actually, a bit early:
11 do we want to go ahead and take a break and then come
12 back early, or do you have a lot to -- you only have
13 like three slides for the CAP stuff. It's up to --
14 you want to -- let's go ahead and just -- do you --
15 is that okay? Let's just push on.

16 MR. DONAHUE: All right. My name is Pete
17 Donahue. I am the Senior Engineering Manager for
18 EPU, and I will be presenting CAP.

19 So I am on slide 19. 19 shows like a
20 simplified diagram of net positive suction head
21 available, and we compare that to the net positive
22 suction head required, and -- to ensure that we don't
23 take any credit for containment pressure as a result
24 of an event or an accident. So this just kind of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 shows a -- a general schematic, and the main term
2 that we're -- we will be working with is the -- is
3 the head due to vapor pressure on the pump. That
4 depends on temperature in the wetwell, and the
5 temperature in the wetwell is where mostly the
6 analysis resides.

7 So moving on to slide 20, as far as -- as
8 far as some background, we -- this is one of our major
9 goals that Gerry talked about, that we're not going
10 to be crediting containment accident pressure, and we
11 utilized the SECY document, 11-0014, to do our
12 analysis. And Joy, as you pointed out, what paved
13 the way is the 805 analysis that was done to
14 demonstrate that we didn't need to rely on containment
15 accident pressure, and also previous EPU's did the
16 same thing. I think the last one that was presented
17 to you guys was similar to the approach that we took.
18 So we utilized the -- the precedent as far as the --
19 the 805 and the previous EPU's, and also utilizing the
20 SECY document, 11-0014.

21 The next slide, slide 21, talks a little
22 bit about -- and we brought this up before, on what
23 do we credit currently in our current licensing basis
24 containment accident pressure? And we credit as much

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 as 3 psi. That is our design basis. It is 3 psi.
2 However, I think the maximum credit that we need is
3 2.1 psi, so there was some margin in that regard.
4 And we talked about how much time that we were
5 crediting, and we credit the first ten minutes, the
6 short-term part of the design basis accident, and
7 then there is another about 80 minutes that we credit
8 during the long-term part of the accident.

9 All right. I am on slide 22. 22 goes
10 over some of the -- some of the major parameters that
11 we utilize to -- or analyzed, and we performed several
12 SUPERHEX runs. If you're familiar with SUPERHEX
13 runs, they are the heat transfer analysis that is
14 done on the containment, and -- and the wetwell. It
15 will determine the temperature that we use for the -
16 - for the vapor pressure term, and how we do that, we
17 utilize what is called a K-value.

18 I am sure many of you are familiar with
19 this K-value, but the K-value is simply a factor that
20 is used that you can multiply it by the -- the result
21 of the -- of the containment temperature -- the
22 difference between the containment temperature and
23 your servicewater temperature. So if you have your
24 servicewater temperature and you analyze your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 containment temperature, this K-value is just a
2 simple term to use in the analysis.

3 And so when you set this K-value or
4 constant in the analysis, it will -- it will determine
5 what following factor you -- you have on your -- on
6 your heat exchangers, your performance of your heat
7 exchangers, so you can back out a following factor
8 based on this K-value, which determines the
9 temperature inside your containment.

10 So that -- that value was -- was utilized
11 in the containment analysis. So we performed, when
12 you look at all the events, the special events and
13 the -- the design basis events, we performed up to 21
14 different containment heat transfer analysis SUPERHEX
15 runs in order to demonstrate that -- that we didn't
16 require reliance on containment accident pressure.

17 The -- the -- as far as the -- the
18 following resistance, we are putting in a program
19 into technical specifications to do performance
20 testing on our heat exchangers periodically to ensure
21 that the following resistance that we used in the
22 design basis is less than the -- the following
23 resistance we used in the design basis.

24 MEMBER CORRADINI: So I guess that is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what I wanted to ask about. So let me make sure I
2 understand it: so you did an analysis that had this
3 empirical constant that essentially -- essentially
4 backs out the following factor, and so now you're
5 going to do periodic maintenance and testing to verify
6 that your following factor as measured, or as tested,
7 is below that limit?

8 MR. DONAHUE: That is correct.

9 MEMBER CORRADINI: Okay.

10 MR. DONAHUE: So the other thing, we --

11 MEMBER CORRADINI: What is it now?

12 MR. DONAHUE: What is the --

13 MEMBER CORRADINI: I mean, if -- just
14 pick numbers. I am not sure if K -- I don't remember
15 --

16 MR. DONAHUE: All right. So --

17 MEMBER CORRADINI: -- what K is versus -
18 -

19 MR. DONAHUE: -- so let -- so let me give
20 --

21 MEMBER CORRADINI: If K is 10, and you
22 needed 8 --

23 MR. DONAHUE: So let me give you an
24 example. I mean, let's say in units, K is -- it is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 really 0.0015 some odd, and -- and our testing, we
2 have performed testing on all the heat exchangers,
3 and a couple of them where the -- where the amount of
4 time between tests -- between cleaning and inspecting
5 was four years, it's really the greatest time. That
6 is the time that is going into our program, it is
7 four years, and we have a grace period of one year,
8 so it's as much as five years.

9 So these were in place for four years
10 without cleaning or inspecting, and their values were
11 -- their nominal values were -- 0.00074 was the
12 highest one for the ones that were in there for four
13 years. So it is -- it is half, about 50 percent
14 right now, the ones that are in there about four
15 years.

16 MEMBER CORRADINI: And so this is both
17 shell side and tube side just corrosion, or it's the
18 buildup?

19 MR. DONAHUE: Yes, both shell side and
20 tube side.

21 MEMBER CORRADINI: How do you clean them?

22 MR. HUGHES: We -- we remount the tube
23 side.

24 MEMBER CORRADINI: You just jam --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DONAHUE: Yes.

2 MEMBER CORRADINI: -- stuff through.

3 Okay.

4 MR. DONAHUE: We clean it out.

5 MEMBER CORRADINI: The old-fashioned
6 way?

7 MR. DONAHUE: Yes.

8 MR. HUGHES: Mechanical cleaning.

9 MR. DONAHUE: Mechanical cleaning.

10 MR. HUGHES: We do chemical cleaning on
11 a weekly basis as well.

12 MEMBER SKILLMAN: All right. Lang, how
13 do you do chemical on a weekly basis?

14 MR. HUGHES: We have for our servicewater
15 pumps, for the raw water side of the heat exchangers,
16 we actually inject chemicals into the pit for which
17 they take suction. It is chlorine-based, and it just
18 pumps from the pit through the tubes and back out.
19 It is a weekly preventative maintenance order that we
20 do on every pump, every heat exchanger.

21 MEMBER SKILLMAN: That's 12.

22 MR. HUGHES: Correct. Well, there's
23 actually -- there's eight of the pumps we use for the
24 -- the heat exchangers. The other four, we use for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the emergency equipment cooling for the diesel
2 generators and so forth. Now, we do treat that side
3 as well also with injection into the pits to go
4 through those components for chemical cleaning.

5 MEMBER SKILLMAN: Okay. Thank you.

6 MR. DONAHUE: So the other thing is that
7 we talked about the -- the boron-10 enrichment. We
8 went from 63 to 94 percent. We --

9 MEMBER SKILLMAN: Before you go on, I am
10 still looking for the change in the flow rate. I see
11 what Joy is pointing to, the 50, I see the number 86.
12 I got all that. I was looking for some write-up that
13 said we have changed the mass flow rate from this to
14 this. That is what I haven't found, so I am
15 wondering, is there such a document?

16 MR. DONAHUE: We can --

17 MEMBER SKILLMAN: Yes. I am just
18 curious. It seems that a key part of this application
19 for CAP and particularly for ATWS is the increase in
20 the injection rate of hold down. It's the increase
21 in the B-10 concentration, but it's also the flow
22 rate change. I was just looking for here's what it
23 was before, and here's what it is now, and here is
24 the basis for that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DICK: This is Michael Dick with TVA.
2 If you would look on the PUSAR, which is NEDC-33860P
3 Revision 1, if you would look in Table 2.8-1, both
4 the -- the CLTP analysis and the EPU analysis flow
5 rates and concentrations are shown there, as well as
6 all the other changes in parameters.

7 MEMBER SKILLMAN: Thank you. I will take
8 a look. Thanks. All right.

9 CHAIRMAN REMPE: So while we are there,
10 we're there some other things that aren't really
11 listed here? When I was trying to dig through the
12 PUSAR, and they are little things perhaps, but water
13 volume assumptions were perhaps changed a bit?

14 MR. DICK: The -- as far as the water
15 volume, we used the minimum for all events, special
16 and also the design basis events. We used the minimum
17 torus level as initial condition, as far as water
18 volume, and we also utilized the ring header, which
19 is different. The previous analyses that were done
20 didn't include the volume in the ring header which
21 surrounds the torus where the -- the suction -- where
22 the RHR water spray takes suction from.

23 CHAIRMAN REMPE: So can I say you made
24 more accurate assumptions, or you fine-tuned the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analysis to be less conservative?

2 MR. DICK: Right.

3 CHAIRMAN REMPE: And --

4 MR. DICK: We looked at conservative
5 shortcuts and -- and --

6 CHAIRMAN REMPE: Yes.

7 MR. DICK: -- in this case, that was one.

8 CHAIRMAN REMPE: And so with all these
9 other things, what is most important? Is it just the
10 K-value and the boron-10 in a bunch of other things,
11 or is there --

12 MR. DICK: Yes.

13 CHAIRMAN REMPE: Do you have a relative
14 feel for how important these things are versus the
15 things maybe that aren't on this slide?

16 MR. DICK: Yes. The K-value is -- is
17 probably the most significant piece -- piece of it.
18 The net positive suction head required from the
19 vendor, the 3 percent curves, are another significant
20 piece of the analysis.

21 CHAIRMAN REMPE: Okay.

22 MR. DICK: So -- so the -- the last bullet
23 talks about the -- the fire event. We utilized --
24 that was the only special event where we used nominal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 values for input values for the servicewater
2 temperature and the torus temperature.

3 MEMBER SKILLMAN: Let the record show
4 that the gentleman pointed out where that information
5 is located in the PUSAR, and I found it, so I am
6 satisfied with my questions. Thank you.

7 MR. DONAHUE: Okay. The next slide,
8 slide 23, shows a breakdown of the design basis events
9 and the special events that were evaluated and the
10 parameters that I showed on 22, basically where they
11 fit into each one of the analyses.

12 Then, and finally, the last slide, page
13 24 in our analysis, showed for all design basis events
14 and special events that the net positive suction head
15 available is higher than the net positive suction
16 head required. And we call it effective net positive
17 suction head because of uncertainties that are
18 applied in the analysis.

19 That is -- that is the --

20 CHAIRMAN REMPE: Okay. And actually, I
21 guess I was a little confused, and we are actually
22 now I guess ahead of schedule, but I obviously
23 couldn't count how many slides there were for CAP.
24 But anyway, do you want to take a break and come back

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about 5 after? And we will just keep plugging along.
2 Thank you.

3 (Whereupon, the meeting went off the
4 record at 9:52 a.m. and resumed at 10:04 a.m.)

5 CHAIRMAN REMPE: My mike is now on and
6 it's up to you, Mr. Story.

7 MR. STOREY: All right. I'm Greg B- oh,
8 there we go. Yes, this is Greg Story. I'm a project
9 engineer with the EPU team and I'm going to be going
10 through the next section, which is the Transient
11 Accident Analysis Summary. Next slide.

12 So for the fuel analyses, analyses were
13 performed and fuel-related reports were provided in
14 the EPU LAR consistent with our recent Browns Ferry
15 Fuel Transition License Amendment Request. And
16 pretty much the same reports that were docketed in
17 our XM transition, so that allows the staff to see
18 AREVA methods applied to XM fuel at EP Power that
19 they can compare back to similar analyses at the
20 current licensed power. Transition core was
21 evaluated, as well as an equilibrium core of XM fuel
22 in these reports.

23 In the transient analysis, the limiting
24 events are reevaluated on a cycle-to-cycle basis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Part of the evaluation included a disposition of
2 events where AREVA went back through the UFSAR events
3 for transients and accidents and evaluated whether
4 EPU would change the relative severity of these. So
5 we might have to analyze a different set of events.
6 The conclusion of it was that the limiting and near-
7 limiting events remained the same at EPU as they were
8 at current licensed power. The limiting event for
9 our delta C power remains our feedwater controller,
10 or failure transient. For ASME over pressure events,
11 the MSIV closure with a flux scram remains the
12 limiting event. For Atlas over pressure, the
13 pressure regulator failure open transient remains the
14 limiting event, same as Current Licensed Power.

15 And none of the non-limiting events
16 became limiting at EPU conditions. Evaluations
17 demonstrated minor changes to the Critical Power
18 Ratio in going from a CLTP to EPU. The delta CPRs
19 are pretty similar, or maybe within .01 on the near-
20 limiting events. The limiting feed water control or
21 failure does become somewhat milder just due to the
22 fact that you're operating at a higher initial feed
23 order flow, so the amount of run out gets naturally
24 limited by that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Safety limit B- minimum critical power
2 ratio B- EPU does have a small adverse impact on that
3 and that's because of the larger batch size that EPU
4 tends to flatten out the radio power shape within the
5 core. So what that means is there's more bundles
6 operating closer to the lead bundle. So when you do
7 the uncertainty analysis, it causes more rods to
8 contribute to transition boiling, and therefore you
9 have to raise your safety limit and CPR slightly.
10 What we saw was about a .01 effect on the B- the
11 safety limit.

12 The current safety limits we have in
13 place, 1.06 for a two loop operation, 108 for single
14 loop, were put in place as part of our XM fuel
15 transition. And we anticipated this effect in
16 advance, so there was enough margin to absorb the
17 effect without needing to change the safety limits
18 again. Moving on to accident response.

19 AREVA did the LOCA analysis for the EPU.
20 Browns Ferry is a small-break limited plant. The
21 peak clad temperature for the EPU increased by a
22 relatively modest amount, 23 degrees Fahrenheit, up
23 to a value of 2,008 degrees, which is well below the
24 2,200 degree F limit. I will note that the 2,008

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 number here comes from our B- the so called MAPLHGR
2 Report, which is what we as a licensee consider our
3 licensing basis number that we would report to the
4 NRC under 5046. You might see a slightly different
5 number from the staff today. That number would come
6 from the Break Spectrum Report. There's two slightly
7 different numbers that come out of the analysis.

8 In general B-

9 MEMBER CORRADINI: Which one with the
10 change of fuel are you limited by, though? That's
11 what I don't understand. You said the staff is
12 looking at a break spectrum analysis.

13 MR. STOREY: Oh, it's the break spectrum
14 of the XM fuel.

15 MEMBER CORRADINI: Right.

16 MR. STOREY: So there's a conservative
17 lattice that is used to do the break spectrum work.
18 And it gives a different B- slightly different PCT
19 number than analyzing it with the real fuel lattices
20 that are designed for Browns Ferry.

21 MEMBER CORRADINI: But we B- we probably
22 can't talk about it.

23 MR. STOREY: Right. That's B-

24 (Simultaneous speaking.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: But can you say
2 qualitatively? Is it just dimensional differences?

3 MR. STOREY: No, it's just B- it's the
4 characteristics of a fuel lattice that they use in
5 the break spectrum B-

6 MEMBER CORRADINI: Okay, fine.

7 MR. STOREY: Versus what B-

8 MEMBER CORRADINI: I think I know what
9 you're saying.

10 MR. STOREY: Yes. Okay.

11 MEMBER CORRADINI: Okay, thank you.

12 MR. STOREY: All right. I would say that
13 the LOCA analysis for the EPU's at very consistent
14 with what we had a Current Licensed Power. The
15 limiting break remains on the RCIC-discharge side, so
16 it's the same limiting break. The limiting failures
17 B- single failure did not change going to EPU. And
18 the limiting break size is very consistent going B-
19 this is non-proprietary, 0.2 square feet up to 0.23
20 square feet. So almost the same break size.

21 So extremely consistent results with the
22 original Current License Power Results. Control rod
23 drop accident really is relatively unaffected. It's
24 a zero-power event basically that it initiates from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 B- the only thing it really could affected is the EP
2 core design. But when you think about what you have
3 to do in the design to meet shut-down margin and limit
4 rod worths and start up, you're not going to get an
5 abnormally high accident rod worth for rod drop
6 accidents. So the analysis that was presented in the
7 FUSAR shows a relatively benign accident, only about
8 140 calories per gram which isn't even up to the
9 current fuel failure threshold of 170. So it shows
10 it wasn't even predicted to be any fuel failures in
11 the B- in the accident.

12 Moving on to the B-

13 MEMBER POWERS: What B- what sort of a
14 pulse with B- you said 140 calories per gram over
15 what sort of a pulse with?

16 MR. STOREY: We'd have to get back to you
17 on that.

18 MEMBER POWERS: Yes, because assuredly
19 we've had about fuel at relatively high burn ups fail
20 at 140.

21 MR. STOREY: Okay. All right, well we'll
22 have to get back to you then on the B- all right.
23 Containment analysis was performed by GE-Hitachi and
24 these last four bullets I'm just going to give you a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 B- kind of a summary of what it did, what the EPU
2 effect is. Suppression pole temperature increased,
3 and that was by seven degrees Fahrenheit. That was
4 limited by a Small Break LOCA, and it comes up about
5 187 degrees Fahrenheit compared to a 281 degree limit.
6 So significant margin remains there.

7 Suppression pool and drywell pressures
8 increased slightly but remained below the limit. The
9 drywell pressure increase three-tenths of a psi to
10 roughly 49 psig compared to a limit of 56. Wetwell
11 pressure increased by 0.4 up to roughly 30 psig, again
12 compared to a limit of 56. The drywell shell
13 temperature stayed within the 281-degree limit. And
14 the drywell air space temperature increased by 0.3
15 degrees Fahrenheit, so it's pretty negligible effect
16 on the equipment qualification. So that completes
17 my slide. Any other questions?

18 CHAIRMAN REMPE: Looks like no, so go
19 ahead.

20 MR. DOYLE: So if we could, just before
21 Pete gets into the Flow Induced Vibration, Michael
22 did B- you have an answer to the open item before the
23 break?

24 MR. DICK: Yes, this is Michael Dick with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 TVA. There was an earlier question concerning the
2 BWR Owners Group Task Group with the CMG interaction.
3 And we confirmed at the site that the B- there is
4 current interaction going on with the TVA Operations
5 and the Owners Group, and I think that was the crux
6 of the question. Does that answer it for you?

7 CHAIRMAN REMPE: Well, I B- I was
8 actually just wondering, are they starting to apply
9 the new technical support guidance at your plant?

10 MR. DICK: Not at this time.

11 CHAIRMAN REMPE: Right B-

12 MR. DICK: They're still doing the
13 interaction B-

14 CHAIRMAN REMPE: They're just
15 interacting, is it?

16 MR. DICK: Right.

17 CHAIRMAN REMPE: Okay, thank you.

18 MR. DONAHUE: This is Pete Donahue again.
19 I'll be presenting the Flow Induced Vibration and
20 Structural Analysis. So I'm on slide 28. As far as
21 the Flow Induced Vibration, pretty much the flow in
22 both the Main Steam and Feedwater are the B- are of
23 the same ratio as power B- as the power is being
24 upgraded. So we expect as much as a 16 percent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 increase in both the Main Steam and the Feedwater.
2 The B- the difference is related to the Feedwater
3 temperature increase. So there's B- there's a
4 slightly higher steam flow and feed flow based on the
5 mass and energy balances.

6 And also based on those mass and energy
7 balances we predict we're going to get increases in
8 the Extraction Steam flow and the Heater Drain flows.
9 As far as the core flow, there really isn't any
10 increase in core flow besides past the B- the upper
11 shroud where B- where the B- where the Main Steam
12 flow through the B- through the Separator and Dryer
13 to the B- to the Main Steam lines.

14 So as far as the Vibration Monitoring
15 Program, we have an advantage over most other plants
16 in that when we did restart Unit 1 during 2007 we had
17 instrumented the Main Steam and Feedwater lines. And
18 we collected vibration information from those Main
19 Steam and Feedwater lines. And B- and we were
20 extrapolate through -- to EPU conditions to give us
21 confidence that we'll remain within B- within
22 acceptable limits on the B- the Main Steam and
23 Feedwater lines.

24 The B- and we also B- and I'll get into

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that later B- we also instrumented the vessel
2 internals and were able to do similar thing with the
3 vessel internals. SO our B- our vibration monitoring
4 program B- and I'll go over to the next slide B-
5 consists B- consists of mainly doing this up-front
6 analysis. We B- we analyze all the B- all where we
7 expect to get any flow change, all the piping and
8 components in those systems to determine what are the
9 most limiting and B- and evaluate those against their
10 acceptance criteria to determine which one's the most
11 limiting.

12 And then we will do walk downs based on
13 that analysis to determine what's the best locations
14 to B- to put instruments that we will be monitoring
15 during plant start up. And we will also adjust our
16 analysis based on those walk downs. So they may B-
17 they may show that well, our analysis shows us the
18 pipe support here, but it's really here B- or anything
19 of that sort. We will change our analysis to B- to
20 compensate for that. And also to make sure that
21 we're evaluating all of the most limiting locations
22 in the systems where we expect to get the higher flow
23 rates.

24 MEMBER SKILLMAN: Pete, let me ask this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Based on your prior slide, you're B- you have
2 confidence based on extrapolation. And on the
3 following slide you are going to monitor?

4 MR. DONAHUE: Right.

5 MEMBER SKILLMAN: Where has
6 extrapolation been proven effective?

7 MR. DONAHUE: I believe that B- that B-
8 because we were B- we were the only ones that really
9 had instrument in both the B- the Main Steam and
10 Feedwater lines previously that we B- there are no
11 other examples that I can B- that I can give you.

12 MEMBER SKILLMAN: Okay, so you have your
13 data from Browns Ferry 1, but the conditions that you
14 are going to be subjecting all three plants to are
15 flow rates 16, 20 B-

16 MR. DONAHUE: Right.

17 MEMBER SKILLMAN: Eighteen percent
18 higher.

19 MR. DONAHUE: Right.

20 MEMBER SKILLMAN: So why is extrapolation
21 B- why does extrapolation give you basis for
22 confidence?

23 MR. DONAHUE: We B- it B- we utilized B-
24 it is the square of the velocity. So we B- we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 increased the B- the amplitudes of vibration by the
2 square of the velocity that we expect, and we feel
3 that that's B- that is conservative and we apply it
4 and we compare it to a conservative acceptance
5 criteria.

6 MEMBER SKILLMAN: Okay. Thank you.
7 Thanks.

8 MEMBER SUNSERI: Did that B- did that
9 analysis look into any frequency shifts of the
10 vibration? Because not only the amplitude, but if
11 the frequency changes you could excite components.

12 MR. DONAHUE: Yes, absolutely. We look
13 at any B- any residents that B- any criticals that we
14 may have also.

15 MEMBER RICCARDELLA: There's a whole
16 related topic on steam dryers that B-

17 MR. DONAHUE: Right.

18 MEMBER RICCARDELLA: That we're going to
19 talk about separately, right?

20 MR. DONAHUE: Yes, correct.

21 MEMBER RICCARDELLA: All right.

22 MR. DONAHUE: So that B- the next slide
23 is slide 30. So this B- this slide talks about the
24 RPV and internals. Again, we had a similar situation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 where we had B- we had instrumented during the 2007
2 startup of Unit 1 the B- the internals and we
3 extrapolated that those B- that vibration at 102
4 percent of EPU. So we added an additional
5 conservatism of 102 percent power. We also had
6 previously put clamps on the B- the jet pump sensing
7 lines to B- to push the B- the stiffness so that the
8 B- the resident frequency was B- was outside of the
9 vein passing frequency of the RCIC pumps.

10 So that had already previously been done.
11 And we were able to show that B- that based on that
12 extrapolation that that also B- all the stresses were
13 B- were less than the acceptance criteria, which
14 utilizes the fatigue curve and the SME code at ten to
15 the eleventh cycles. It actually uses a stress lower
16 than the B- the stress that you will find at ten to
17 the eleventh cycles it uses 10 ksi and ten to eleventh
18 cycles is approximately 13.5 ksi. It's all
19 austenitic stainless steel and internals.

20 So as far as the vessel, all of the B-
21 all of the stresses and B- and usage factors were B-
22 were all found to be less than the B- the code
23 allowables. And therefore the B- both the vessel and
24 internals are maintained in structural integrity.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RICCARDELLA: There's some new
2 fatigue curves out as part of the Environmental
3 Enhanced Fatigue Program that I think changed it B-
4 I'm not sure if it takes it out of B-

5 (Simultaneous speaking.)

6 MR. DONAHUE: Yes, absolutely. We B- we
7 utilized the B- the B- where appropriate we utilized
8 the Environmental Fatigue Curves. Feedwater nozzle
9 is an example.

10 MEMBER RICCARDELLA: Yes, the B- but B-
11 I know, but there's some new B- as part of that
12 effort, there's some new baseline air curves that
13 they published that are B- I think differ a little
14 from the ASME code curves.

15 MR. DONAHUE: We B- we can get back to
16 you on that. So B- so your question is B-

17 MEMBER RICCARDELLA: There's a new B- a
18 new reg B- rev one to the new reg that's about to be
19 issued in B- in the reg guide that B- you should look
20 at that and make sure it's consistent with B- I'm not
21 sure if the stainless steel curve changed way out at
22 those high B- at those high numbers or cycles, but
23 it's something worth checking.

24 MR. DONAHUE: Okay. You have questions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for flow induced vibration? All right.

2 MR. BAKER: Thanks, Pete. I am Bill
3 Baker. I am the senior manager of EPU Operations.
4 I'm previously licensed SRO at Browns Ferry. I've
5 been at Browns Ferry for 30 years. I've been involved
6 with the EPU project for the last three years and
7 I've been the lead for Operations on that project for
8 the last year. Turn the page.

9 Slide 32, our Power Ascension Test Plan.
10 It was developed using the methods and guidance of
11 NUREG-0800. It specifically evaluates the
12 applicability of testing them for the original plant
13 start up, as well as additional testing for EPU.
14 Modification testing that does not require the plant
15 to be at power will be done before we B- we go to EPU
16 condition B- before we start up to go to EPU
17 conditions. There is a single test plan that
18 consolidates the testing. It has to be done at power
19 with the operating conditions and operational
20 performance testing for EPU that Pete talked to you
21 about.

22 So we used the directive approach and we
23 developed the test plan. We used the procedures that
24 the operators are already familiar with. So we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 didn't put them in the test plan. We actually pointed
2 out to them B- so that they B- they used the ones
3 that they're familiar with and they use in training
4 all the time. That minimizes the amount of training
5 they will have to do for Operations to go to this
6 test plan. Next slide.

7 On the next two slides, 33 and 34, we're
8 going to conduct 32 individual tests in 16 areas shown
9 on these two pages. These are based on the original
10 start up test plan. In addition, we will do a
11 replacement steam dryer modification test making a
12 total of 33 tests. You can go to the next page, Dan.

13 The hold points and durations for the
14 steam dryer testing are identified in the license
15 conditions are shown on the bottom of this slide.
16 You can see down there B- NRC Holds. The test was
17 developed and validated and will be implemented by
18 our team. And Jerry has talked about, they are highly
19 experienced Browns Ferry personnel. We've got SROs
20 on the team, reactor, design and system engineering
21 members on the team B- chemistry and RAD protection.
22 When we perform the test we will have a group of test
23 directors in the Control Room with the Operating
24 staff. They will B- they are previous BFN Operations

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 personnel, and they will supplement the Operations
2 staff during the Power Ascension tests.

3 In addition to that on site there will be
4 an EPU Engineering Support Group during testing. And
5 they will lead the evaluations and Corrective Action
6 development for any test deficiencies that we might
7 have and then review and B- and approve the test
8 reports and assist the plant staff as needed during
9 the nest if we have any B- any conditions that we
10 don't expect. Dan, if you'll go over to the next
11 slide.

12 So we have two levels of acceptance
13 criteria, Level 1 and Level 2. Level 1 criteria
14 ensures the equipment and plant operational
15 performance meets all the required design criteria
16 that we talked about. Those are things such as
17 turbine first stage, bypassed scram pressure, maximum
18 feed pump run out, steam dryer moisture carry over B-
19 things that are in our design criteria for EPU.

20 If we get to a point where the Level 1
21 criteria is not met, we will place the testing on
22 hold. We will put the plant in a safe condition. We
23 will get an engineering evaluation and make any
24 adjustments as necessary and then we will re-perform

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that test following our Plant Operations Review
2 Committee core approval to move forward.

3 On the next slide is our Level 2
4 acceptance criteria. A little different. It's
5 associated with performance expectations that we
6 expect to see as we start up from EPU conditions, but
7 not the design criteria. Those are things such as
8 condenser vacuum and main steam line Delta P and main
9 transform oil temperatures B- among others.

10 If we don't meet a Level 2 criteria, we'll
11 take the same type of action. We'll put the testing
12 on hold. We'll resolve the condition and then if we
13 have to make any physical adjustments, we will then
14 re-perform that portion of the test again to get
15 acceptable results following our PORC approval.

16 That's B- that's in nutshell our B- our
17 test plan. Now it's got a lot of details that I
18 didn't talk about here today. Are there any question
19 you might have about that plan that we can answer for
20 you?

21 MEMBER SKILLMAN: Yes, I do. On your
22 Level 1 testing the outcome B- this is your slide 35
23 B- presumes that the adjustments that have been made
24 and approved by PORC have been successful. If they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are not successful, what do you do?

2 MR. BAKER: Stop, back up and reevaluate
3 where we are. I will let Pete follow with that.
4 Anything that you might have for your testing B-

5 MR. DONAHUE: Yes. As far as the B- the
6 steam dryer, we'll talk more about that this
7 afternoon. I mean on B- on what B- on what we're
8 doing with B- with the Level 1 and Level 2. However,
9 we won't proceed forward unless it meets the criteria.
10 So that's B- that will be a B- a stopping point until
11 we B- we either prove that B- that it won't or B- or
12 we B- we do not go any further.

13 MR. SKILLMAN: I can B- I can envision
14 that you could find an area where you haven't met the
15 Level 1 test criteria, and this is not pertaining to
16 the dryer. It's BOP.

17 MR. BAKER: Okay.

18 MR. SKILLMAN: And you'd say we are stuck
19 here. We cannot proceed. And you could be there for
20 a year. Is that baked into your admin and your
21 procedures and your Corrective Action Program?

22 MR. BAKER: We would enter it in our
23 Corrective Action Program. We would stop and it
24 would have to be evaluated as successful, or change

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the test plan appropriately to B- to make it B- to
2 make it so.

3 MR. SKILLMAN: Okay, thank you.

4 MEMBER SUNSERI: So it sounds to me like
5 the tests are going to be reviewed individually. Is
6 there going to be any kind of aggregate review of all
7 the test results to make sure that everything makes
8 sense? So as it fits together?

9 MR. BAKER: Yes, I'd like to ask Jeff
10 Lewis, the author of the test plan, to respond to
11 that, please.

12 MR. LEWIS: Yes, I'm Jeff Lewis, TVA EPU
13 project. When we go from plateau to plateau,
14 starting at B- starting at 3458, which is our current
15 100-percent power plateau, all of our test results
16 will go to our Plant Operations Review Committee for
17 B- for approval and recommendation to the plant
18 manager and continue up in power. So we will have
19 that at 3458, then we go up five percent, another
20 five percent and then we'll be at 3952 B- 100 percent
21 power.

22 MEMBER SUNSERI: So the B- I appreciate
23 that. Just one more clarification. I mean, so when
24 the Plant Operations Review Committee looks at all of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the results and aggregate at some point, though?

2 MR. LEWIS: Yes, that B- will B-

3 MEMBER SUNSERI: Not just that plateau
4 point by plateau, though?

5 MR. LEWIS: The final B- at B- when we're
6 complete with all testing, the final package will be
7 the complete test package for all testing.

8 MEMBER SUNSERI: Okay, thank you.

9 CHAIRMAN REMPE: Any more questions? So
10 this is the end of the open part of the meeting. And
11 before we ask if there's anyone out on the phone
12 lines, is there anyone in the room who would like to
13 make a comment. Seeing no one, I believe I just B-
14 the lines are open, so if anyone is out there, please
15 B- and wants to make a comment, please state your
16 name and provide that comment. Because it is quiet
17 I want to just get some verification that the line is
18 open.

19 And I do B- it's only 10:30, so we will
20 proceed with starting the closed session here right
21 after this. So I assume the staff is ready to go?

22 PARTICIPANT: Yes, the B- the line opener
23 is not there.

24 CHAIRMAN REMPE: Well B-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 PARTICIPANT: We have to wait.

2 CHAIRMAN REMPE: Oh, here we go. The
3 line is open. Are there B- is there any member of
4 the public who would like to provide a comment at
5 this time? Hearing no one B- okay, I B- we B- we're
6 going to close this line now and we are going to start
7 up with the closed session.

8 PARTICIPANT: You've got to verify B-

9 CHAIRMAN REMPE: What?

10 PARTICIPANT: You should verify the room
11 when all the Federal guys are out

12 CHAIRMAN REMPE: Will the folks from TVA
13 and their consultants and the staff verify that
14 there's no one in this room that's not authorized to
15 be in this room at this time? And by the way, I
16 guess I do need to bang this to end the open session
17 and we'll start up the closed one as soon as we have
18 such verification.

19 PARTICIPANT: I want to make a call to
20 close a line. That will take maybe five minutes.

21 CHAIRMAN REMPE: Just let me know when.
22 We've got five minutes now to close the room.

23 (Whereupon the above-entitled matter went
24 off the record at 10:30 a.m.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4



ACRS Subcommittee on Power Upgrades May 3, 2017

NRC Staff Review of Extended Power Upgrade for Browns Ferry Nuclear Plant Units 1, 2, & 3




OPENING REMARKS

Kathryn Brock

Deputy Director

Division of Operating Reactor Licensing

Office of Nuclear Reactor Regulation



U.S.NRC
UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

BROWNS FERRY





BROWNS FERRY GENERAL INFORMATION

➤ Commercial Operation:

- Unit 1 – 08/01/1974
- Unit 2 – 03/01/1975
- Unit 3 – 03/01/1977

➤ License Expiration:

- Unit 1 – 12/20/2033
- Unit 2 – 06/28/2034
- Unit 3 – 07/02/2036

LAR REVIEW

- 14 Technical Review Branches
- Over 25 lead and peer reviewers
- 4 NRC Contractors:
 - ORNL
 - ANL
 - Pennsylvania State University
 - McMaster University

Recommend approval of TVA's EPU request



INTRODUCTION

Farideh Saba

Senior Project Manager
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

POWER UPRATES BACKGROUND

- **Measurement Uncertainty Recapture
Power Uprates (MUR) (<2%)**
- **Stretch Power Uprates (SPU) ($\leq 7\%$)**
- **Extended Power Uprates (EPU) ($>7\%$)**
- **157 Power Uprates Approved (since 1977)
(Incl. MUR, SPU, EPU)**
- **31 EPUs (20 BWRs)**

BROWNS FERRY UPDATES

BFN Proposed EPU (each unit):

- **3458 (CLTP) to 3952 (EPU) Megawatts**


Thermal (MWt)

- **~14.3% increase from CLTP to EPU**
- **3293 MWt (OLTP)**
- **~20.0% increase from OLTP to EPU**

BFN approved SPU:

- **Unit 1 5% March 2007**
- **Units 2 and 3 5% September 1998**

BWR EPU COMPARISONS



REVIEW STANDARD

- **RS-001* used since 2005**
- **TVA followed format and guidance in RS-001**
- **NRC staff used RS-001 guidance to review BFN EPU**

*** RS-001, “Review Standard for Extended Power Uprates,” dated 2003**



EPU - Timeline

- **October 2014 to August 2015 – 7 pre-Application meetings with TVA**
- **September 21, 2015 – Application submitted to NRC.**
- **October - November 2015 – Staff informed TVA of need to supplement information associated with:**
 - **MIRCROBURN-B2 modeling error**
 - **Interconnection System Impact study**
 - **Spent Fuel Pool analysis.**

EPU – Timeline (cont.)

- **November - December, 2015 - TVA submitted 3 supplemental letters needed for the acceptance review of the LAR.**
- **January 11, 2016 – Application was accepted by NRC for review.**
- **July 2017 – NRC forecast for review completion based on 18 months from acceptance.**


BFN EPU KEY ELEMENTS

- **No Increase to Operating Pressure (Constant Pressure Power Uprate)**
- **AREVA Fuel**
- **Replacement of Steam Dryers**
- **Elimination of Containment Accident Pressure Credit**
- **Safety Analysis Reports:**
 - **PUSAR – General Electric Uprate Analysis**
 - **FUSAR –AREVA Fuel Analysis**

REVIEW OF BFN EPU

- **4 Meetings (3 open , and one closed)**
- **3 Audits**
 - **RSD Review**
 - **Containment**
 - **SFP**
- **205 RAIs**
- **40 Supplements**
- **~11,000 review hours (to date)**

Request for Additional Information (RAIs)



AGENDA

AM (open)

- **EPU Overview (TVA)**
- **Elimination of credit for Containment Accident Pressure (TVA)**
- **Transient and Accident Analyses Summary (TVA)**
- **Flow-Induced Vibration & Structural Analyses (TVA)**
- **Power Ascension (TVA)**
- **Public Comment**

PM (Closed)

- **Nuclear Design & Safety Analyses Review (NRC)**
- **Containment Analyses Review (NRC)**
- **Replacement Steam Dryer Overview (TVA)**
- **Replacement Steam Dryer Review (NRC)**
- **Committee Comments**



QUESTIONS



Browns Ferry Nuclear Plant
Extended Power Uprate License Amendment Request
Advisory Committee on Reactor Safeguards
Meeting of the Subcommittee on Power Uprates

May 3, 2017



Introductions

Browns Ferry Nuclear Plant Extended Power Uprate

Gerry Doyle

Director, Extended Power Uprate
and

Ed Schrull

TVA Corporate Fleet Licensing Manager

BFN EPU ACRS Subcommittee – Introductions

Agenda

- Introductions E. Schrull/
G. Doyle
- Overview
 - Background S. Bono
 - Parameter Change Summary S. Bono
 - Unit Differences L. Hughes
 - Modifications Summary L. Hughes
- Elimination of credit for Containment Accident Pressure (CAP) in Net Positive Suction Head (NPSH) evaluations for Emergency Core Cooling System (ECCS) pumps P. Donahue
- Transient and Accident Analyses Summary G. Storey
- Flow Induced Vibration and Structural Analyses P. Donahue
- Power Ascension B. Baker
- Replacement Steam Dryer (RSD) Overview (afternoon closed session) D. Pappone

BFN EPU ACRS Subcommittee – Introductions

Key Team Members Present

- Steve Bono – Browns Ferry Nuclear Plant (BFN) Site Vice President
- Lang Hughes – BFN General Manager, Site Operations
- Gerry Doyle – Director, Extended Power Uprate (EPU)
- Scott Hunnewell – BFN Director, Site Engineering
- Pete Donahue – EPU Senior Engineering Manager
- Denny Campbell – BFN Nuclear Plant Shift Operations Manager
- Bill Baker – EPU Senior Operations Manager
- Ed Schrull – Tennessee Valley Authority (TVA) Corporate Fleet Licensing Manager
- Gordon Williams – TVA Corporate Fleet Licensing Program Manager
- Dan Green – EPU Senior Licensing Manager
- Ashley Michael – EPU Project Manager
- Michael Dick – EPU Project Engineer
- Greg Storey – EPU Project Engineer
- Jeff Lewis – EPU Project
- Hugh Coleman – EPU Project

BFN EPU ACRS Subcommittee – Introductions

Key Team Members Present (continued)

- Bruce Hagemeyer – GE-Hitachi (GEH)
- Guangjun Li – GEH
- Dan Pappone – GEH
- Tao Wu – GEH
- David McBurney – AREVA
- Alan Meginnis – AREVA
- Brian Voll – Sargent and Lundy
- Nicholas Lovelace – Jensen Hughes

BFN EPU ACRS Subcommittee – Introductions

BFN EPU Team

- The EPU Project Team is staffed with personnel having extensive Boiling Water Reactor (BWR) plant and EPU experience
 - TVA
 - Combination of dedicated project and plant resources
 - GEH (Nuclear Steam Supply System)
 - AREVA (Fuels)
 - Industry EPU experienced specialty contractors

BFN EPU ACRS Subcommittee – Introductions

BFN EPU Project Team Goals

- Present Nuclear Regulatory Commission (NRC) with a high quality License Amendment Request (LAR) consistent with RS-001 Standards
- Resolve Containment Accident Pressurization (CAP) credit issues
- Install Replacement Steam Dryers (RSD) for all three units
- Provide smooth transition to EPU for Plant Operations

Overview

Browns Ferry Nuclear Plant Extended Power Uprate

Steve Bono

Browns Ferry Nuclear Plant Site Vice President
and

Lang Hughes

Browns Ferry Nuclear Plant General Manager, Site Operations

BFN EPU ACRS Subcommittee – Overview

Background

- BFN
 - GE BWR 4 Mark I Containment
- Operating Licenses issued
 - Unit 1 - 12/20/1973, Unit 2 - 8/20/1974, Unit 3 - 8/18/1976
- Commercial Operation commenced
 - Unit 1 - 8/1/1974, Unit 2 - 3/1/1975, Unit 3 - 3/1/1977
- Renewed Licenses issued 5/4/2006 (Units 1, 2, and 3)
- Licensed Thermal Power History
 - Original Licensed Thermal Power (OLTP) - 3293 MWt
 - Stretch Uprate (105% OLTP) - 3458 MWt
 - Units 2 and 3 - 9/8/1998, Unit 1 - 3/6/2007
 - Proposed EPU (120% OLTP, 14.3% CLTP) - 3952 MWt

BFN EPU ACRS Subcommittee – Overview

Parameter Change Summary

Parameter	CLTP	EPU
Core Thermal Power (MWt)	3458	3952
Licensed Full Power Core Flow Range (Mlbm/hr)	83.0 to 107.6	101.5 to 107.6
Licensed Full Power Core Flow Range (% core flow)	81 to 105	99 to 105
Steam Dome Pressure (psia)	1050	1050
Vessel Steam Flow (Mlbm/hr)	14.153	16.440
Feedwater Flow Rate (Mlbm/hr)	14.103	16.390
Feedwater Temperature (°F)	381.7	394.5
CAP Credit Required (psig) (DBA-LOCA)	3	CAP not credited

BFN EPU ACRS Subcommittee – Overview

Unit Differences

- Main Generator Ratings
 - Unit 1 - 1330 MWe at 0.95 power factor
 - Unit 2 - 1332 MWe at 0.93 power factor
 - Unit 3 - 1332 MWe at 0.93 power factor
 - Unit-specific main generator ratings were used in Transmission System Stability Study and in Interconnection System Impact Study
- Emergency Diesel Generators
 - Units 1 and 2 share four emergency diesel generators
 - Unit 3 has four emergency diesel generators
 - Emergency diesel generator design configurations, for each of the units, were accounted for in EPU analyses


BFN EPU ACRS Subcommittee – Overview

Unit Differences (continued)

- Nuclear Fuel
 - At startup from EPU implementation outage for each unit, nuclear fuel makeup will be as follows
 - Unit 1 - ATRIUM 10XM fuel and ATRIUM 10 fuel (twice burnt)
 - Unit 2 - ATRIUM 10XM fuel
 - Unit 3 - ATRIUM 10XM fuel and ATRIUM 10 fuel (twice burnt)
 - EPU analyses were performed for both equilibrium and transition core designs
- Recirculation System Piping
 - Recirculation System Loop cross-tie line has been removed on Units 1 and 3
 - One isolation valve on Unit 2 cross-tie line is maintained closed

BFN EPU ACRS Subcommittee – Overview

Modifications Summary



BFN EPU ACRS Subcommittee – Overview

Modifications Summary

- Remaining Modifications
 - Replacement Steam Dryer
 - New steam dryers to be installed to increase structural design margin to accommodate EPU operation
 - High Pressure Turbine Replacement
 - High pressure rotors to be replaced with rotors designed for increase flow associated with EPU
 - Feedwater Heaters
 - Tube bundle and channel head to be replaced in the number 4 Feedwater Heaters with design less susceptible to flow-induced vibration
 - Main Generator Hydrogen Pressure
 - Main generator hydrogen pressure to be increased to support EPU operation

BFN EPU ACRS Subcommittee – Overview

Modifications Summary

- Remaining Modifications (continued)
 - Standby Liquid Control (SLC) System
 - Increase Boron-10 enrichment from 63 to 94 atom percent in SLC Storage Tank solution to lower power faster during Anticipated Transient Without Scram (ATWS)
 - Hardened Wetwell Vent (HWWV)
 - Modify HWWV, as part of modifications for compliance with the Order on Reliable Hardened Containment Vents, to provide capacity of HWWV that is one percent of EPU thermal power
 - Self-Excited Generator Excitation System
 - Modify excitation system to a self-excited shaft driven alternator and modify the Automatic Voltage Regulator to address a transient stability issue resulting from increased electrical generation at EPU conditions (North American Electric Reliability Corporation issue)
 - Alternate Leakage Treatment Pathway
 - Modify the Alternate Leakage Treatment Pathway design to be consistent with the existing licensing basis dose calculations performed at EPU conditions

BFN EPU ACRS Subcommittee – Overview


Modifications Summary

- Remaining Instrumentation Changes to support EPU
 - Technical Specification Instrumentation Respan/Recalibration
 - Turbine first stage pressure scram bypass permissive setpoint to be recalibrated
 - Main steam line high flow isolation channel to be respanned
 - Average Power Range Monitor flow biased and setdown instrumentation to be respanned and setpoints recalibrated
 - Condenser Instrumentation Upgrade
 - Install nine new condenser vacuum pressure transmitters per unit (three on each condenser) and provide signals to electro-hydraulic control (EHC) system
 - Move condenser A/B/C low vacuum alarm, low vacuum turbine trip and low vacuum bypass trip functions to EHC logic
 - Perform hardware and software changes to EHC system to support alarm and trip functions

Elimination of Credit for Containment Accident Pressure in Net Positive Suction Head Evaluations for Emergency Core Cooling System Pumps

Pete Donahue
Extended Power Uprate Senior Engineering Manager

BFN EPU ACRS Subcommittee – Elimination of credit for CAP in NPSH Evaluations for ECCS pumps



BFN EPU ACRS Subcommittee – Elimination of credit for CAP in NPSH Evaluations for ECCS pumps

Background

- Opportunity to improve margins and address industry concerns associated with CAP credit
 - One of the EPU Project Team Goals
- Used guidance provided in SECY-11-0014, Use of Containment Accident Pressure in Analyzing Emergency Core Cooling System and Containment Heat Removal System Pump Performance in Postulated Accidents

BFN EPU ACRS Subcommittee – Elimination of credit for CAP in NPSH Evaluations for ECCS pumps

Current Licensing Basis

- CAP credit taken for Loss of Coolant Accident (LOCA) (both short term and long term)
- CAP credit not taken for Fire Event
- Maximum CAP credit approved: 3 psig
 - Unit 1 (3 psig - short and long term LOCA)
 - Units 2 and 3 LOCA analyses (3 psig - short term LOCA; 1 psig - long term LOCA)

BFN EPU ACRS Subcommittee – Elimination of credit for CAP in NPSH Evaluations for ECCS pumps

Actions to Eliminate CAP Credit

- Performed comprehensive analyses of accidents and special events
- Increased Residual Heat Removal (RHR) Heat Exchanger factor (K-value) for all events
- Validated acceptability of increased RHR Heat Exchanger K-value by performing RHR Heat Exchanger Performance Tests on all 12 RHR Heat Exchangers at BFN (4 per unit)
 - To ensure that this level of RHR Heat Exchanger performance is maintained, a Technical Specification for the RHR Heat Exchanger Performance Monitoring Program will be added
- Increased SLC System Boron-10 enrichment for ATWS event
- Used Vendor supplied NPSH curves (NPSHr 3% curves)
- Used Technical Specification values for initial conditions in DBA and Special Events analyses
 - Except for Fire Event
 - SECY-11-0014 allows use of nominal values for Special Events

BFN EPU ACRS Subcommittee – Elimination of credit for CAP in NPSH Evaluations for ECCS pumps

Actions to Eliminate CAP Credit (continued)

Accident/Event	Key Changes/Modifications
Short-term DBA-LOCA (0 – 10 minutes)	<ul style="list-style-type: none"> • Included ECCS pump suction ring header and RHR piping volumes • Used vendor supplied NPSH curves (NPSHr 3% curves)
Long-term DBA-LOCA (beyond 10 minutes)	<ul style="list-style-type: none"> • Increased RHR HX K-value • Used vendor supplied NPSH curves (NPSHr 3% curves)
Special Event – Fire Event	<ul style="list-style-type: none"> • Increased RHR HX K-value • Nominal initial suppression pool temperature, 92°F • Nominal Residual Heat Removal Service Water (river water) temperature, 88°F • Used vendor supplied NPSH curves (NPSHr 3% curves)
Special Event – Station Blackout (SBO) Event	<ul style="list-style-type: none"> • Increased RHR HX K-value • Used vendor supplied NPSH curves (NPSHr 3% curves)
Special Event – ATWS Event	<ul style="list-style-type: none"> • Increased Standby Liquid Control (SLC) System Boron-10 Enrichment • Increased RHR HX K-value • Used vendor supplied NPSH curves (NPSHr 3% curves)

BFN EPU ACRS Subcommittee – Elimination of credit for CAP in NPSH Evaluations for ECCS pumps

Results

- For all events
 - Net Positive Suction Head Available (NPSHa) is greater than Effective Net Positive Suction Head Required (NPSH_{eff})
- No CAP credit required
 - No additional operator actions required

Transient and Accident Analyses Summary

Greg Storey
Extended Power Uprate Project Engineer

BFN EPU ACRS Subcommittee – Transient and Accident Analyses Summary

For Fuels Analyses, analyses were performed and fuel related reports provided consistent with recent BFN fuel transition LARs

- Transient Response (AREVA analyses)
 - Limiting events are re-evaluated on a cycle-to-cycle basis
 - Evaluations demonstrated minor changes in Critical Power Ratio from Current Licensed Thermal Power (CLTP) to EPU conditions
 - Small increase in Safety Limit Minimum Critical Power Ratio from CLTP to EPU conditions
- Accident Response (AREVA analyses)
 - Peak clad temperature during limiting Small Break Loss of Coolant Accident increased 23°F to 2008°F, below the 2200°F limit
 - Control Rod Drop Accident unaffected by EPU conditions

For Containment Analyses (GEH analyses)

- Suppression Pool temperature is increased, but remains below the limit
- Suppression Pool and Drywell pressures increase slightly, but remain below the limit
- Drywell shell temperature meets limit
- Drywell air space temperature acceptable for equipment qualification

Flow Induced Vibration and Structural Analyses

Pete Donahue
Extended Power Uprate Senior Engineering Manager

BFN EPU ACRS Subcommittee – Flow Induced Vibration and Structural Analyses

Effect of EPU on the Plant

- Main Steam (MS) and Feedwater (FW) flow increase about 16%
- Vibration levels in MS and FW are expected to increase about 35%
- Extraction Steam flow increases up to 22% in some lines
- Heater Drain flow from 2nd stage to 3rd stage heater increases about 20%
- Maximum core flow and reactor pressure remain unchanged

Vibration Monitoring Program

- Review of previous vibration data collected during BFN Unit 1 restart power ascension testing (2007) indicates CLTP vibration levels are well within acceptable limits
- Extrapolation indicates that vibration of previously monitored piping and components will not be adversely affected by EPU operation
 - To provide further assurance, piping assessments are currently being performed to identify potentially susceptible configurations, and any modifications required to reduce vibration susceptibility will be made prior to EPU power ascension

BFN EPU ACRS Subcommittee – Flow Induced Vibration and Structural Analyses

Vibration Monitoring Program (continued)

- Vibration monitoring program will be performed during EPU power ascension
 - Detailed analyses were performed to establish monitoring locations and acceptance criteria
 - Multiple components and piping locations will be monitored inside and outside of containment
 - Data collected at each specified test plateau at or above CLTP will be processed and compared to established acceptance criteria to demonstrate acceptability of monitored piping and components

BFN EPU ACRS Subcommittee – Flow Induced Vibration and Structural Analyses

RPV and Internals

- Flow Induced Vibration (FIV) Effects
 - Maximum core flow is not increased by EPU, therefore, core flow dependent Reactor Pressure Vessel (RPV) internals not significantly affected by EPU
 - Analyses performed to evaluate FIV effects on reactor internals
 - Analyses extrapolated to 102% of EPU power level
 - Jet pump sensing line clamps were added based on Operating Experience
 - Jet pump sensing line clamps are included in analyses
 - Vibration levels were below acceptance criterion
- Structural Effects
 - All stresses and Cumulative Usage Factors within applicable design basis Code Allowables
 - RPV pressure retaining and internal components maintain structural integrity at EPU conditions
 - Site specific analyses, measurement, and inspection programs verify structural integrity of RSDs

Power Ascension

Bill Baker

Extended Power Uprate Senior Operations Manager

BFN EPU ACRS Subcommittee – Power Ascension

Power Ascension Test Preparation

- EPU test plan developed using guidance of NUREG-0800, Section 14.2.1, Generic Guidelines for EPU Testing Programs
- Equipment modification acceptance testing, that does not require plant operating conditions, will be verified to be satisfactorily completed prior to startup
- A single power ascension test procedure will consolidate modification acceptance/performance testing, that requires plant operating conditions, and EPU operational performance testing
- Test plan consists of 33 individual tests in 16 areas
 - 32 tests from original startup testing scope
 - RSD power ascension test plan

BFN EPU ACRS Subcommittee – Power Ascension

Power Ascension Major Testing

Test Description	Test Condition (%CLTP)					
	≤ 90	95	100	104.8	109.5	EPU
Chemical/ Radiochemical			X	X	X	X
Radiation Measurement			X	X	X	X
Control Rod Drives	X					X
IRM Calibration	X					
APRM Calibration	X	X	X	X	X	X
Core Power Distribution	X		X			X
Core Performance	X	X	X	X	X	X
Flux Response to Rods			X			X
Feedwater System	X	X	X	X	X	X

BFN EPU ACRS Subcommittee – Power Ascension

Power Ascension Major Testing (continued)

Test Description	Test Condition (%CLTP)					
	≤ 90	95	100	104.8	109.5	EPU
Pressure Regulator	X	X	X	X	X	X
Turbine Stop Valves and Bypass Valves	X	X	X	X		
MSIVs	X		X	X		
Reactor Recirculation System	X		X	X	X	X
Vibration Monitoring	X	X	X	X	X	X
Plant Monitoring	X	X	X	X	X	X
Steam Dryer	X	X	X (NRC Hold 10 days)	X (NRC Hold 4 days)	X (NRC Hold 4 days)	X (NRC Hold 4 days)

BFN EPU ACRS Subcommittee – Power Ascension

Power Ascension Testing, Non-Dryer Acceptance Criteria

- Level 1 Acceptance Criteria – associated with design performance
- If Level 1 Test Criterion is not met
 - Plant will be placed in a condition judged to be safe based on prior testing
 - Resolution will be pursued by equipment adjustments or engineering evaluation
 - Plant Operations Review Committee (PORC) must approve corrective actions
 - Applicable test portion must be repeated to verify Level 1 criterion is satisfied and results presented to PORC prior to increasing reactor power above the current test plateau

BFN EPU ACRS Subcommittee – Power Ascension

Power Ascension Testing, Non-Dryer Acceptance Criteria (continued)

- Level 2 Acceptance Criteria – associated with performance expectations
- If Level 2 Test Criterion is not met
 - Plant will be placed in a condition judged to be safe based on prior testing
 - An evaluation will be initiated to identify cause and corrective actions
 - PORC must approve corrective actions
 - If physical adjustments are required, applicable test portion must be repeated to verify Level 2 criterion is satisfied and results presented to PORC prior to increasing reactor power above current test plateau

CLOSED SESSION

Replacement Steam Dryer (RSD) Overview

Dan Pappone
GE – Hitachi Nuclear Energy

BFN EPU ACRS Subcommittee – Acronym List

- APRM – Average Power Range Monitor
- ATWS – Anticipated Transient Without Scram
- AVS – Acoustic Vibration Suppressors
- BFN – Browns Ferry Nuclear Plant
- BLEU – Blended Low Enriched Uranium
- BWR – Boiling Water Reactor
- CAP – Containment Accident Pressure
- CCW – Condenser Circulating Water
- CLTP – Current Licensed Thermal Power
- DBA – Design Basis Accident
- ECCS – Emergency Core Cooling System
- EHC – Electro-hydraulic Control
- EPU – Extended Power Uprate
- F – Fahrenheit
- FIV – Flow Induced Vibration
- FW – Feedwater
- GEH – General Electric – Hitachi
- HWWL – Hardened Wetwell Vent
- hr – hour
- IRM – Intermediate Range Monitor
- LAR – License Amendment Request
- LOCA – Loss of Coolant Accident
- Mlbm – Million pound mass
- MS – Main Steam
- MSIVs – Main Steam Isolation Valves
- MWe – Megawatt Electric
- MWt – Megawatt Thermal
- NPSH – Net Positive Suction Head
- NPSHa – Net Positive Suction Head Available
- NPSH_{eff} – Effective Net Positive Suction Head Required
- NRC – Nuclear Regulatory Commission
- OLTP – Original Licensed Thermal Power
- PORC – Plant Operations Review Committee
- psia – pounds per square inch absolute
- psig – pounds per square inch gage
- RHR – Residual Heat Removal
- RPV – Reactor Pressure Vessel
- RSD – Replacement Steam Dryer
- SBO – Station Blackout
- SLC – Standby Liquid Control
- TVA – Tennessee Valley Authority

BFN EPU ACRS Subcommittee – Questions/Comments