

Part 21 (PAR)

Event # 52741

Rep Org: EMERSON PROCESS MANAGEMENT	Notification Date / Time: 05/09/2017 14:36 (EDT)
Supplier: FISHER CONTROLS INTERNATIONAL	Event Date / Time: 03/10/2017 (CDT)
	Last Modification: 05/09/2017
Region: 3	Docket #:
City: MARSHALLTOWN	Agreement State: Yes
County:	License #:
State: IA	
NRC Notified by: KIM SAGAR	Notifications: DON JACKSON R1DO
HQ Ops Officer: BETHANY CECERE	RANDY MUSSER R2DO
Emergency Class: NON EMERGENCY	DAVID HILLS R3DO
10 CFR Section:	JOHN KRAMER R4DO
21.21(a)(2) INTERIM EVAL OF DEVIATION	PART 21/50.55 REACTORS EMAIL

PART 21 REPORT - POTENTIAL MINIMUM WALL THICKNESS ISSUE ON CERTAIN POSI-SEAL VALVES

The following report was received via email:

"Pursuant to 10 CFR 21.21 (a)(2), Fisher Controls International LLC ('Fisher') is providing required written interim notification of a potential failure to comply concerning minimum wall requirements in the packing box region of certain Posi-Seal valves [A11].

"On March 10, 2017, Fisher discovered a minimum wall issue while processing an order. While the order at issue was corrected prior to shipment, Fisher is currently engaged in an extent of condition investigation to determine whether the noncompliance extends beyond the specific order. Fisher anticipates completing this investigation and disseminating additional information on or before June 9, 2017. Appropriate corrective action will be initiated to prevent reoccurrence.

"Should there be any further questions concerning this matter, please contact Benjamin Ahrens, Manager, Quality by email at Benjamin.Ahrens@Emerson.com or via phone at 641-754-2249."

IE19
NR

Hoc, HOO X

From: Sagar, Kim E [AUTOSOL/FCV/MTWN] <Kim.Sagar@emerson.com>
Sent: Tuesday, May 09, 2017 2:36 PM
To: Hoc, HOO X
Subject: [External_Sender] Fisher Controls 10CFR21 Interim Report - A11 Packing Box Min Wall
Attachments: 17QP004 A11 Packing Box Min Wall Interim Report.pdf

Attached is a Fisher Controls 10CFR21 Interim Report – A11 Packing Box Min Wall

For technical questions, please contact Ben Ahrens at (641) 754-2249 or George Baitinger at (641) 754-2026

Kim Sagar
Project Coordinator
Nuclear Business Unit
Emerson Automation Solutions / Fisher Division
T 641-754-2070
Kim.Sagar@emerson.com



Fisher Controls International LLC
301 South First Ave
P.O. Box 190
Marshalltown, Iowa 50158-0190
USA
T (641) 754-3011
F (641) 754-2830

May 09, 2017

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk

Subject: Fisher Controls International LLC 10 CFR 21 Interim Report
Potential Minimum Wall Thickness Issue on Certain Posi-Seal A11 Packing Boxes

Dear Sir or Madam:

Pursuant to 10 CFR 21.21(a)(2), Fisher Controls International LLC ("Fisher") is providing required written interim notification of a potential failure to comply concerning minimum wall requirements in the packing box region of certain Posi-Seal valves.

On March 10, 2017, Fisher discovered a minimum wall issue while processing an order. While the order at issue was corrected prior to shipment, Fisher is currently engaged in an extent of condition investigation to determine whether the noncompliance extends beyond the specific order. Fisher anticipates completing this investigation and disseminating additional information on or before June 9, 2017. Appropriate corrective action will be initiated to prevent reoccurrence.

Should there be any further questions concerning this matter, please contact Benjamin Ahrens, Manager, Quality by email at Benjamin.Ahrens@Emerson.com or via phone at 641-754-2249.

Regards,

A handwritten signature in black ink, appearing to read 'Scott Lustyk', is written over a horizontal line.

Scott Lustyk
Manager, Nuclear Business Unit