

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: 643rd Meeting
Advisory Committee on Reactor Safeguards

Docket Number: N/A

Location: Rockville, Maryland

Date: May 4, 2017

Work Order No.: NRC-3060 Pages 1-188

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

643RD MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

THURSDAY

MAY 4, 2017

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 8:30 a.m., Dennis Bley,
Chairman, presiding.

COMMITTEE MEMBERS:

- DENNIS C. BLEY, Chairman
- MICHAEL L. CORRADINI, Vice Chairman
- PETER RICCARDELLA, Member-at-Large
- RONALD G. BALLINGER, Member
- CHARLES H. BROWN, JR. Member
- MARGARET CHU, Member
- WALTER L. KIRCHNER, Member

1 JOSE MARCH-LEUBA, Member
2 DANA A. POWERS, Member
3 JOY REMPE, Member
4 GORDON R. SKILLMAN, Member
5 JOHN W. STETKAR, Member
6 MATTHEW W. SUNSERI, Member

7
8 DESIGNATED FEDERAL OFFICIAL:

9 CHRISTOPHER BROWN
10 DEREK WIDMAYER

11
12 ALSO PRESENT:

13 ALI AZARM, IESS
14 STEVE BLOSSOM, STPNOC
15 KEVIN COYNE, RES
16 VICTOR CUSUMANO, NRR
17 CANDACE DE MESSIERES, NRR
18 ROB ENGEN, STPNOC
19 CJ FONG, NRR
20 MIRELA GAVRILAS, NRR
21 FELIX GONZALES, RES
22 WAYNE HARRISON, STPNOC
23 SHANA HELTON, NRR
24 RAJ IYENGAR, RES
25 JOSHUA KAIZER, NRR*

1 ERNIE KEE, STPNOC
2 PAUL KLEIN, NRR
3 MICHAEL MARSHALL, NRR
4 DOMINIC MUNOZ, Alion*
5 MICHAEL MURRAY, STPNOC
6 ROBERT PASCARELLI, NRR
7 OSVALDO PENSADO, SWRI
8 LISA REGNER, NRR
9 DREW RICHARDS, STPNOC
10 ANDREA RUSSELL, NRR
11 SELIM SANCAKTAR, RES
12 MICHAEL SALAY, RES
13 RAY SCHNEIDER, Westinghouse*
14 WES SCHULZ, STPNOC
15 ASHLEY SMITH, NRR
16 STEPHEN SMITH, NRR
17 MARK THAGGARD, RES
18 ANDREA D. VEIL, Executive Director, ACRS
19 DON WAKEFIELD, ABS*
20 MATTHEW YODER, NRR

21

22 *Present via telephone

23

24

25

C O N T E N T S

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Page

Opening Remarks by ACRS Chairman. 5

Risk-Informed South Texas Project License
Amendment Request

Remarks by Subcommittee Chairman. 7

NRC Staff Briefing. 10

Licensee Briefing.. . . . 29

Consequential Steam Generator Tube Rupture

Remarks by Subcommittee Chairman. 133

Briefings.. . . . 133

Preparation of ACRS Reports.. . . . 141

P R O C E E D I N G S

8:30 a.m.

CHAIRMAN BLEY: The meeting will now come to order. This is the first day of the 643rd meeting of the Advisory Committee of Reactor Safeguards.

During today's meeting, the Committee will consider the following: number one, Risk-Informed South Texas Project License Amendment Request. That's GSI-191. Two, Consequential Steam Generator Tube Rupture. Three, preparation of ACRS reports.

The ACRS was established by Statute. And is governed by the Federal Advisory Committee Act. As such, the meeting is conducted in accordance with the provisions of FACAs.

That means that the Committee can only speak through its published letter reports. We hold meetings to gather information to support our deliberations.

Interested parties who wish to provide comments can contact our offices requesting time after the Federal Register Notice describing the meeting is published. With that said, we also set aside ten minutes for spur of the moment comments for members of the public attending or listening to our meetings.

Written comments are also welcome. Mr.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Derek Widmayer is the designated Federal Official for
2 the initial portion of the meeting.

3 The ACRS section of the US NRC public
4 website provides our charter bylaws, letter reports,
5 and full transcripts of all our full and subcommittee
6 meetings, including slides presented at the meetings.

7 We have received no written comments or
8 requests to make oral statements from members of the
9 public regarding today's sessions. There will be a
10 telephone bridge-line. To preclude interruption of
11 the meeting, the phone will be placed in a listen-in
12 mode during presentations and the Committee
13 discussion.

14 A transcript of the portions of the
15 meeting is being kept. And it is requested that the
16 speakers use one of the microphones, identify
17 themselves, and speak with sufficient clarity and
18 volume to be readily heard.

19 I also want to make you aware that this
20 meeting is being webcast with the ability to view our
21 presentation slides on the web. If you're on the
22 bridge line and want to do that, you can dial -- you
23 can connect through the NRC's public meeting website,
24 and click on the link.

25 It seems to work well, and the sound when

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I tried it, is better than the sound on the bridge
2 line. If you have any problems, please call our
3 office.

4 At this point, I'm going to turn the
5 meeting over to Professor Corradini to lead us through
6 the discussion on the South Texas issue.

7 VICE CHAIRMAN CORRADINI: Okay. Thank you
8 Mr. Chair. So, for the members, this is, I guess, the
9 culmination of, I'm sure Lisa and Steve will tell us,
10 I can remember at least a few years. A hand full.
11 Maybe two handfulls of years in discussing GSI-191 with
12 a risk informed methodology.

13 To remind the members, we had meetings
14 back in 2012, '14, '15, and then two recently which
15 culminated in the staff's SE. Which essentially goes
16 through and analyzes and I think confirms, what STP
17 has suggested is their approach for risk informed.

18 So, I'll turn it over to Lisa. No. I'm
19 sorry. Excuse me.

20 MEMBER SUNSERI: Yes. And Dr. Corradini,
21 before you do that, may --

22 VICE CHAIRMAN CORRADINI: I'm sorry, I
23 forgot to turn to --

24 MEMBER SUNSERI: Yes. So, due to some
25 prior associations, I find that I need to recuse

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 myself from the deliberations on this topic. Thank
2 you.

3 VICE CHAIRMAN CORRADINI: Okay. Thank you
4 Matt. I forgot to turn it over to you. I forgot.
5 Shana?

6 MS. HELTON: Thank you. I'll just give
7 some brief opening remarks before handing off to Lisa
8 Regner.

9 To provide the Committee some additional
10 background. In 2010 the Commission directed the staff
11 to consider a risk informed method for closing GSI-
12 191. The Commission direction included specific
13 direction to be creative and innovative.

14 That led in 2012 to what is now known as
15 closure option 2B for generic letter 2004-02. Which
16 is the potential impact of debris blockage and
17 emergency recirculation during design basis accidents
18 at pressurized water reactors.

19 South Texas Project was the pilot plant
20 for exercising this option for closure of the generic
21 letter. The lessons learned from this pilot effort
22 have already benefitted and influenced the remaining
23 plants using the risk informed closure option.

24 We recently received a submittal from
25 Vogtle and expect preliminary closure documentation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for review from at least one additional plant in the
2 next few months.

3 I'd like to take a minute to thank some
4 key staff, two of whom are sitting in front of you at
5 the table here. Lisa Regner is the Doral Project
6 Manager. Steve Smith is our technical expert in
7 deterministic debris analysis. C.J. Fong, who is
8 sitting in the audience, and Candace Pfeffercorn-De
9 Messieres, have been instrumental on the PRA analysis.

10 There are a number of other people who
11 have been involved, some of whom are on the phone, who
12 have been instrumental to the effort as well.
13 Technical staff who are not presenting today in the
14 Division of Engineering, and the Division of Safety
15 Systems.

16 It's taken a lot of people for us to get
17 here today. And a lot of good efforts on behalf of
18 the staff. And additionally, I'd like to commend the
19 South Texas project staff and NRC contractors for
20 being creative and collaborative in addressing the
21 challenges that inevitably arose along the way.

22 The many meetings, audits and site visits
23 conducted over the last few years were critical in
24 ensuring mutual understanding. And led to the hybrid
25 method you will hear about today.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And finally, I'd like to express
2 appreciation to the ACRS members past and present who
3 have led us where we are with many thoughtful
4 insights. And we've presented to the committees and
5 subcommittees several times throughout the review
6 process over the past four years or so.

7 We've really taken the ACRS insights to
8 heart. And I think what you see in this staffs' SE is
9 a reflection of how we've addressed the ACRS concerns
10 to date.

11 With that, I'd like to turn things over to
12 Lisa Regner. Thank you for the opportunity to be here
13 today.

14 MS. REGNER: Thank you Shana. Good
15 morning. I moved it so I wouldn't forget. Sorry.

16 Thank you Shana. Good morning. I'm Lisa
17 Regner, the Project Manager for the South Texas
18 Project pilot -- licensing. I'm the Licensing Project
19 Manager for the South Texas Project.

20 As Shana stated, we're here today to
21 present the staffs' results of a pioneering action to
22 risk informed compliance with the regulatory
23 requirements for emergency core and containment
24 cooling considering debris.

25 Like most pilot projects, this review was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a series of stops and starts and course corrections.
2 But over the past year we've been able to make several
3 leaps forward. My goal for the first few minutes is
4 to share that voyage with you.

5 But before I start, I would also like to
6 acknowledge the NRC team, both present and absent,
7 that got us here. This is the best group of
8 professionals that I have ever had the pleasure to
9 work with.

10 And I would also like to acknowledge the
11 South Texas Project Nuclear Operating Station staff
12 and contractors. They are responsive, hardworking and
13 intelligent professionals. And big-hearted Texans as
14 well. For the agenda --

15 CHAIRMAN BLEY: And what?

16 (Laughter)

17 MS. REGNER: For the agenda today, we'll
18 cover the background of the risk informed option to
19 address GSI-191. And an overview of the STP review
20 project.

21 You'll hear from the STP team. And then
22 the staff will get into the fun technical aspects of
23 the review. For the first few minutes however, I want
24 to cover a bit of the history, the methods used by the
25 licensee and the staff, and the remaining actions for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 us to complete this action.

2 So, in terms of the background, Shana gave
3 you a real nice, high level quick look. I'm just
4 going to go just below the surface.

5 And the first -- the staff first
6 identified concerns with debris and containment as far
7 back as the 1970s. Over the last 40 years, important
8 efforts have been made by the industry in analysis,
9 testing, and redesign.

10 And installation of upgraded design
11 features for sumps and strainers to try to resolve the
12 issue. Progress has been made. But, not enough to
13 close the generic safety issue for our plans.

14 In fact, new concerns were identified
15 along the way. Such that closure of the generic
16 letter associated with GSI-191, involves licensee to
17 -- licensees to demonstrate compliance with 10 CFR
18 50.46, which, as I had said before, is the emergency
19 core cooling system performance criteria considering
20 debris and containment as well for both strainer
21 impacts and in-vessel effects.

22 And I'll talk a little bit more about
23 that. That those two separate issues to resolve GSI-
24 191. Because I want to make that clear for everybody
25 that hasn't been involved in the subcommittee

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discussions.

2 In 2010 the Commission directed the staff
3 to provide options to resolve GSI-191 and close the
4 generic letter, 2004-02. And consider risk informed
5 opportunities to do so.

6 And the staff developed three options, as
7 Shana mentioned. Option one provided the traditional
8 closure method based on existing models, using
9 deterministic methods and providing near term closure.
10 In fact, all 18 of those plants choosing option one,
11 have been closed.

12 Option two, was to provide -- uses a
13 graded approach based on the amount of insulation in
14 the plant. And provides licensees with two paths
15 allowing longer term closure.

16 The first aspect of option two is
17 mitigative measures as well as either 2A, term 2A, the
18 deterministic option, which allows for refined in-
19 vessel testing. And then 2B as you know, is a new
20 methodology employing risk information. Which STP
21 choose.

22 VICE CHAIRMAN CORRADINI: So just a
23 clarification. Under 2A, how many plants do you
24 expect?

25 MS. REGNER: Twenty-eight units.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN CORRADINI: Under 2A? Okay.

2 MS. REGNER: Yes, sir.

3 VICE CHAIRMAN CORRADINI: Okay.

4 MS. REGNER: Okay. Any other questions?

5 (No response)

6 MS. REGNER: Option three, plants may use
7 deterministic methods for strainer impacts. And a
8 risk informed resolution for in-vessel impacts. And
9 that's two units that are -- want to use that.

10 In addition to STP's use of option 2B,
11 mitigative measures and risk informed evaluation, this
12 slide also provides some of the other plants that have
13 submitted their intent to use option 2B.

14 VICE CHAIRMAN CORRADINI: So, just to
15 clarify. So under 2A, 28. Under 2B, the list is
16 here?

17 MS. REGNER: Correct.

18 VICE CHAIRMAN CORRADINI: Okay.

19 MS. REGNER: Yes. Okay. So, was far as
20 now --

21 VICE CHAIRMAN CORRADINI: How many under
22 three? Two?

23 MS. REGNER: Two plants.

24 VICE CHAIRMAN CORRADINI: I'm sorry. I
25 missed that. Excuse me. I'm sorry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. REGNER: Yes. Two plants under option
2 three. Okay?

3 MR. SMITH: I'll just say option three,
4 the one plant that's two units that came in under
5 option three is probably not going to actually use
6 option three. So they maybe 2B.

7 They just came in and they were doing it.
8 They proposed something that was different then was in
9 the SRM. So, we're probably not going to accept them
10 as option three.

11 So, they're probably going to have to
12 change. But that's what they've declared.

13 MS. REGNER: Thanks Steve. So now
14 focusing a little more on the South Texas review
15 specifically, they -- the STP pilot project began six
16 years ago in late 2010, early 2011 when STP formally
17 submitted its intent to use a risk informed option to
18 resolve GSI-191.

19 The staff hosted several public meetings
20 to discuss STP's risk informed approach. In fact the
21 STP method was developed enough that a description was
22 included in the staffs' proposal to the Commission on
23 GSI-191 closure options.

24 Shortly after the Commission's approval of
25 the closure options, of the three resolution options,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 STP submitted its licensing action request for review.
2 Now, originally the STP request was fully risk
3 informed, providing the estimated change in risk,
4 without removing debris generating material in
5 containment.

6 And the most detrimental debris of concern
7 is fibrous insulation on piping and components. The
8 STP approach attempted to characterize the physical
9 behavior of debris generation and transport over a
10 full range of conditions using a platform called
11 containment accident stochastic analysis or CASA
12 Grande.

13 And I'm sure the STP staff will go into a
14 little more detail than I intend to for this platform.
15 The CASA Grande platform developed by STP's contractor
16 Alion, is designed to model up to 50 different
17 parameters to compile a spectrum of time dependent
18 results for many thousands of postulated accident
19 sequences.

20 Ultimately, CASA Grande can provide the
21 change in risk for the actual 3-D modeled STP plant
22 compared to the postulated clean plant without debris
23 generating material.

24 Now, the full risk informed model proved
25 to have too many uncertainties for the staff. And an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 alternate method was developed. But I'll talk about
2 that in just a minute.

3 As expected, this project has become one
4 of the most resource intensive, risk informed reviews
5 undertaken by the staff. For example, experts from
6 five divisions, 14 branches in the Office of Nuclear
7 Reactor Regulation have contributed to this safety
8 evaluation or supporting document such as the
9 environmental assessment, which was issued yesterday
10 for publication in the FRN.

11 And that will show up in about two weeks
12 in the Federal Register Notice. And that is
13 associated with the exemptions that STP has requested.

14 We posted over 40 public meetings. And
15 asked more than 400 questions. Although many of those
16 questions answered by STP have been superseded when
17 they submitted their alternate methodology.

18 MEMBER POWERS: Lisa, you identify this as
19 a resource intensive for the agency. And -- but you
20 have about ten more plants that propose to do this.

21 Have you attempted to identify areas where
22 improved methods and technology, say generated by
23 research, could reduce the resource intensity of these
24 reviews?

25 MS. REGNER: Absolutely. I would probably

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 turn to either Vic or Steve if they'd like to provide,
2 you know, details of that.

3 MEMBER POWERS: Yes. I mean, I ask
4 because it might help us identify where research
5 resources could be focused and what not. And in lieu
6 of, I mean, if you have a quick response, that's fine.

7 But it would be useful perhaps to document
8 it in a memorandum or something like that. What --
9 the general areas where some additional research
10 intensity could reduce these resources.

11 Because you do have ten plants looking to
12 do this. And I don't think you want to have five
13 years and 43 meetings and six thousand pages of RAIs
14 going out if we can with just a little bit of research
15 effort give you -- put in your hands, better
16 technology for doing this.

17 MS. REGNER: Um-hum. Well, obviously the
18 overall project -- the overall project itself, there
19 were many, many lessons learned on uncertainties and
20 correlations that the staff just won't accept.

21 And so that information is out there.
22 There have been several plants that have followed in
23 the public meetings, so they already know that they
24 don't have to go down that road.

25 So just in simple terms, in those terms,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we have --

2 MEMBER POWERS: Well, yes. This new --
3 there's no question there's some learning goes through
4 -- anybody that goes through the first of a kind
5 operation will learn something that other people will
6 take advantage of.

7 But, my question is more pertinent to the
8 agency.

9 MS. REGNER: Right.

10 MEMBER POWERS: And how it goes about
11 doing its work to review these materials. The idea
12 being if there's improved technology that would just
13 make it easier and more efficient to do the mechanics
14 of the work that -- and at the cost of doing a little
15 research, we ought to do it.

16 MS. REGNER: Um-hum.

17 MEMBER POWERS: In preference to research
18 that's not so useful or something like that.

19 MR. CUSUMANO: Yes. If you don't mind.
20 This is Vic Cusumano. I'm over -- way over here.

21 The efficiencies that we expect to gain
22 are going to come from, in my opinion, the WCAP 17788
23 that we're looking at. The vast majority of the
24 follow up plans if you will, are going to rely on that
25 WCAP.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So we're going to have one methodology
2 that they all can use. South Texas Project was
3 basically a one off of that. Which is why it was so
4 resource intensive.

5 So, just having a topical report that all
6 the plants can use and in addition to that, as we
7 develop it, we fully expect to have a model submittal
8 worked out with industry. So it will be a
9 standardized submittal and as much as possible, a
10 standardized response.

11 So yes, efficiency has been forefront in
12 our mind with this many plants to go. Both on Two
13 Alpha and Two Bravo. We did leverage research to some
14 degree during this. Especially as it related to some
15 of the issues in the core that weren't being modeled
16 all that well.

17 And Trace was a big help to us there.
18 Thanks to Dr. Steve Pajoric (phonetic) in large part.

19 MEMBER KIRCHNER: May I ask a question
20 just to -- your choice of words in the first bullet
21 make me ask almost that fully risk informed would lead
22 one to believe what?

23 MS. REGNER: Yes. All it provided was a
24 change in risk. In considering the effects of degree.
25 Okay?

1 So those -- and now -- and that's where
2 the CASA Grande, you know, instead of developing a
3 threshold that they, you know, when I get into this
4 hybrid methodology as Shana called it, that develops
5 a threshold that showed that the majority of the
6 possible breaks meet the deterministic criteria.
7 Which is our traditional acceptance methodology.

8 Okay? However, when they first developed
9 this, they compared their existing plant with a clean
10 plant. Okay? And then analyzed the debris and
11 generation -- debris generation in transport, right,
12 for all of the possible breaks to determine the risk
13 change.

14 Maybe I'll let --

15 MR. FONG: Yes I was -- maybe I can weigh
16 in on that a little bit. CJ Fong from the Division of
17 Risk Assessment.

18 If you look at the original submittal, it
19 treated a lot more of the variables probabilistically.
20 But it also considered a lot more sequences.

21 And the newer version of the submittal
22 uses, in certain cases, more conservative screening
23 values, point estimates for some of the variables.
24 And screens a lot of the sequences deterministically
25 based on test data.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, they're both risk informed. It's just
2 that the scope of the original submittal in terms of
3 risk information was wider.

4 MEMBER KIRCHNER: Okay. Thank you. No,
5 it's just I think what we heard in previous meetings
6 makes a lot of sense. You use both techniques to
7 advantage.

8 I just -- the implication is it's not so
9 well risk informed when you go to option 2A or 2B or
10 whatever. I just -- I'm just reacting to the choice
11 of words. Thank you.

12 So is the new method called CASA Pequeno?
13 (Laughter)

14 MS. REGNER: We should use that. We'll
15 do. As expected, -- we talked about that.

16 The NRC conducted 13 audits at various
17 sites to support the review. Including several in
18 2008 and '09 to observe STP specific testing.

19 More recently the staff conducted audits
20 to observe piping layouts, quantity of insulation and
21 debris flow paths in STP containment. As well as
22 thermal-hydraulics and risk audits. These were
23 invaluable in understanding the details of the new
24 methodology and resolving concerns.

25 So the licensee's methodology, and again,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this is the post-methodology change, the -- well, and
2 let me go back to the original risk informed approach
3 did have merit.

4 It became apparent however that there was
5 just too much uncertainty even with plant specific
6 testing requested by the staff to support some of the
7 statistical distributions. The STP model was not able
8 to show accurate modeling in several areas such as
9 head loss, chemical effects, debris transport timing,
10 and others. There were issues as well with epoxy
11 coatings and the in-core analysis of debris impacts.

12 The licensee's methodology change was the
13 significant turning point. As you said, that was when
14 they did leverage the deterministic testing that they
15 had done, to simplify the process.

16 This new process was termed risk over
17 deterministic, or RoverD. And it provided the
18 benefits of simplifying the staff's review and
19 reducing a significant amount of uncertainty.

20 This graphic created by STP provides a
21 good overview of the key elements which the licensee
22 will discuss in more detail. The first element, the
23 deterministic test data incorporates the licensee's
24 plant specific testing.

25 As I said, they used staff approved

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 methods. And the staff observed some of the testing.
2 This testing established the debris threshold for the
3 emergency core cooling and containment spray systems.
4 Both of which rely on the containment sumps to remain
5 functional through long term core cooling.

6 CASA Grande used it a more limited scope
7 then before. Evaluated several thousand break
8 scenarios to determine the amount of debris generated
9 and transported for each break size, orientation, and
10 location in containment.

11 These calculations and -- so that's the
12 CASA Grande calculated degree for individual breaks.
13 These two were then tested.

14 So, if above the threshold it went into
15 the risk informed analysis. If below the threshold,
16 it met the traditional deterministic acceptability
17 bin.

18 It's important to distinguish between the
19 two separate evaluation segments. However, to be
20 addressed in GSI-191, first the impacts of debris
21 clogging at the sump strainer, and second, the debris
22 impacts to the in-core thermal-hydraulic environment.

23 The evaluations overlap and
24 deterministically dispositioning a majority of those
25 breaks. And both in-vessel and strainer segments use

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 risk to disposition all large hot leg breaks. Those
2 are breaks greater than 16 inches.

3 Where they diverge is in the deterministic
4 methods for each. For the strainer evaluation
5 calculated debris amounts from CASA Grande are
6 compared to deterministic testing thresholds, as is
7 represented here in the graphic.

8 For the cold leg in-vessel evaluation, the
9 debris amounts are compared to previously established
10 debris thresholds in NRC approved guidance. That's
11 WCAP 16793.

12 For the hot leg in-vessel evaluation for
13 small and medium sized breaks, the licensee choose to
14 use a calculational platform. And that's RELAP5 3-D.

15 Since RELAP5 3-D has not been approved for
16 this application, the staff's safety evaluation, as
17 you probably saw in enclosure two, provides our review
18 of the plant specific simulations using RELAP5 3-D.
19 And this will be discussed in a little more detail
20 following STP's presentation.

21 I do what to note however that the staff's
22 SE did not approve the evaluation methodology for
23 generic use. It only looked at simulations specific
24 to STP.

25 Slide seven is the staffs' methodology.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And what we were comparing against, our acceptance
2 criteria, obviously is 50.46, the ECCS performance
3 criteria. Everything else is guidance associated with
4 our evaluation in NEI 0407, the WCAP I mentioned
5 earlier, Reg Guide 1.182 and Reg Guide 1.174, which
6 provides the criteria. It's based on the Commission's
7 safety goal policy statement for risk.

8 The technical specification is relatively
9 simple. It recognizes the debris assessment
10 specifically for the emergency core cooling and
11 containment spray systems.

12 The new shut down action statement
13 provides for immediate compensatory actions if debris
14 is identified in containment in excess of the analyzed
15 amounts. And requires the system to return to
16 operable status within 90 days.

17 The structure of the staffs' SE uses the
18 five key principals of risk informed regulation.
19 Which is from Reg Guide 1.174.

20 This guidance provides an acceptable
21 method to assess the impact of licensing basis changes
22 using risk. And provides consistency in areas where
23 risk is used in regulatory decisions.

24 It specifies a method that compliments the
25 deterministic approach and supports the NRC's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 traditional defense in depth philosophy.

2 MEMBER SKILLMAN: Lisa, will we have an
3 opportunity to discuss how the operators will
4 interpret the new technical specification?

5 MS. REGNER: Sure.

6 MEMBER SKILLMAN: Will it be with the
7 staff or with the -- with STP?

8 MS. REGNER: I guess we'll let STP start.
9 And if they can't answer your questioning, we can talk
10 more.

11 MEMBER SKILLMAN: Thank you. Thank you.

12 MS. REGNER: The staff methodology again,
13 this is a graphic, a simple graphic that shows you the
14 five key principals of risk informed regulation.
15 Which is how we structured the SE.

16 The -- let's see, -- and again, this whole
17 review was specific to the effects of debris on 50.46
18 as specified in the generic letter.

19 The primary guidance documents to show
20 compliance with 50.46 ECCS -- oh, I'm sorry. I went
21 backwards. Excuse me.

22 This slide again, provides a graphic of
23 the five key principals. The first key principal in
24 white involves meeting existing regulations or
25 modifying the rules through rule making.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Key principals two and three, the blue
2 boxes, leverage deterministic criteria. And for this
3 review, involved the staff from Division of Safety
4 Systems and Division of Engineering.

5 Key principals four and five, the tan
6 boxes, -- oh, risk expectations. And appropriately
7 involve staff from the Division of Risk Assessment.

8 The NRC staffs' technical presentation
9 following South Texas Project reflects the structure
10 of the SE by presenting each key principal. These are
11 not our final conclusions, but a summary of the
12 staffs' preliminary results for your consideration.

13 Concerning remaining actions, the staff is
14 completing the legal review to finalize the
15 concurrence process for the licensing action requests.
16 The final environmental assessment was issued
17 yesterday as I said.

18 Once we address the ACRS items of concern,
19 the staff will be ready to issue the final decision
20 sometime this spring. And this concludes the
21 background and overview portion of the staffs'
22 presentation.

23 Unless there are questions, we will return
24 following the licensee's presentation.

25 VICE CHAIRMAN CORRADINI: Questions by the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 members?

2 (No response)

3 VICE CHAIRMAN CORRADINI: Okay. Why don't
4 we switch then -- who's up front? Who's going to kick
5 it off? Wayne or Mike? Fine. Sorry. Excuse me. Go
6 ahead.

7 MR. MURRAY: So, good morning. I
8 appreciate the opportunity to address the ACRS again.
9 I'd like to second Lisa's -- I'm Mike Murray,
10 Regulatory Affairs Manager at South Texas Project.

11 I'd like to second Lisa's comments of the
12 collaborative nature of the effort that we've all put
13 in. We've had a lot of industry expertise that's been
14 involved with it.

15 And interacting with the NRC staff is
16 always in a collaborative nature. The audits went
17 very well. Were very beneficial to all of us on that.

18 And also I'd like to appreciate the ACRS
19 for the interactions and challenging questions as
20 we've gone through it. So much appreciate it for that
21 opportunity.

22 So I'll let the rest of the team introduce
23 themselves, starting with Ernie.

24 MR. KEE: Ernie Kee, South Texas --

25 MR. HARRISON: Wayne Harrison, South Texas

1 Project.

2 MR. KEE: I'm sorry. Ernie Kee, South
3 Texas Project.

4 MR. HARRISON: Wayne Harrison, South Texas
5 project.

6 MR. SCHULZ: Wes Schultz, Mechanical
7 Engineer at South Texas.

8 MR. MURRAY: We have some other members
9 from South Texas Project that would like to introduce
10 themselves.

11 MR. RINKEREL: Good morning. My name is
12 Dave Rinkerel. I'm the Executive response for the
13 effort.

14 MR. INGAN: Rob Ingan, Manager of
15 Engineering Projects at South Texas Project.

16 MR. BLOSSOM: Steve Blossom, GSI-191
17 Project Manager, South Texas Project.

18 MR. RICHARDS: Drew Richards. I'm STP
19 Licensing Engineer.

20 MR. MURRAY: And on the phone we have Don
21 Wakefield with ABS if we should need his -- assistance
22 from him. And Dominic Munoz from Alion. They're
23 available as well. Next slide, please.

24 So meeting purpose, review and overview,
25 which was the request of the process we went through

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and the technical information. And we'll also
2 describe the risk informed treatment of debris and the
3 current risk over deterministic, RoverD methodology.
4 Next slide, please.

5 So in our agenda what we'll touch on so
6 you can see where we're planning to drive through
7 this, is we will look at the STP GSI-191, generic
8 letter 2004-02, option two bravo. We'll general
9 overview of the evolution of the application. Which
10 Lisa had covered a good bit of it as with -- on with
11 the opening.

12 And then general overview of the RoverD
13 methodology. Testing, deterministic element of it.
14 Determining and the determination of the governing
15 brake size. How we went about that.

16 And in-vessel effects. Quantitative
17 results and regulatory implementation. And that's --
18 I think that's where we'll be able to answer your
19 question on -- in that area, so.

20 And then I'll do the closure comments on
21 it. So with that, I'll turn it over to Wayne Harrison
22 to start carrying us through the first part of the
23 presentation.

24 MR. HARRISON: Thank you Mike. As Lisa
25 mentioned, South Texas Project, Unit Two, we have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 large amount of fibrous insulation in the reactor
2 coolant system. And in order to meet a deterministic
3 threshold value for containment debris loading, the
4 amount of debris generating contributors in the plant
5 design would need to be significantly reduced.

6 This would result in a real burden with
7 respect to occupational dose. Primarily with respect,
8 it would be almost 88 rim per cycle, per unit or for
9 that cycle for removing and banding insulation.
10 Compared to a -- like a 20 rim normal cycle dose.

11 So we're talking about real dose to real
12 people to do this modification. The cost was not
13 insignificant at about 55 million dollars.

14 And I'd also point out that as Lisa had
15 mentioned also in hers, her presentation, that we had
16 already taken a number of mitigative actions,
17 significant mitigative actions. Primarily the
18 replacement of our three original 155 square foot
19 strainers with three new 18 hundred and 18 square foot
20 strainers.

21 And in addition to the generic letter of
22 2002-02 -- 2004-02 response, South Texas Project has
23 been very proactive with respect to the initiating
24 event, the pipe break frequency. We replaced the
25 steam generator safe in wells with alloy 690 material

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 when we replaced our steam generators.

2 We overlaid the pressurizer wells with
3 alloy 690 material. And in Unit One we just finished
4 doing the mechanical stress improvement process on the
5 reactor pressure vessel butt wells, or the nozzle
6 wells.

7 And we will be doing that in our coming
8 outage on Unit Two. So we've been very proactive in
9 our activities.

10 Lisa covered most of -- going onto seven.

11 VICE CHAIRMAN CORRADINI: Wait, before you
12 go -- can you just go back? I know you've said it.
13 But I can't remember when. When did you replace the
14 strainers from 155 to 1818?

15 MR. HARRISON: Wes, do you --

16 MR. SCHULZ: I believe it was in 2006.

17 VICE CHAIRMAN CORRADINI: Yes. I was
18 guessing it was a while ago.

19 MR. SCHULZ: Yes. It was.

20 VICE CHAIRMAN CORRADINI: This was part of
21 the industry's --

22 MR. SCHULZ: In 2006 and 2007, we replaced
23 them.

24 VICE CHAIRMAN CORRADINI: But this was
25 part of an industry, this is not just you all?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCHULZ: That's correct.

2 VICE CHAIRMAN CORRADINI: Okay. Fine.

3 MR. HARRISON: That's correct.

4 VICE CHAIRMAN CORRADINI: And then the
5 third bullet, I remember that this one I had not
6 caught. And one of our consultants caught it.

7 When was that replacement made? Do you
8 know?

9 MR. SCHULZ: You know, I --

10 MR. HARRISON: The Marinite replacement,
11 Wes.

12 MR. SCHULZ: That was about two years
13 after the strainers. So, it was about 2009 time
14 frame.

15 VICE CHAIRMAN CORRADINI: Okay. All
16 right. Thank you.

17 MR. HARRISON: Thanks Wes. Lisa covered
18 most of this. So, I'm not going to go through the
19 detail of the original.

20 As she said, the original application was
21 a full risk informed where CASA Grande basically
22 provided conditional failure probabilities to the PRA.
23 And with respect -- in that there were issues with the
24 modeling as Lisa described.

25 And so we reduced the complexity. So we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 determined that we could take advantage of our good
2 deterministic testing that we had performed, and apply
3 the tools that we had with CASA Grande, which does
4 other than -- which does a good bit of analytical work
5 for us.

6 And to show that there was a small risk of
7 having a break that generates more debris than what
8 our deterministic test showed. And that's what we
9 ended up with.

10 And that's a bounded analysis that we
11 used, RoverD. And Ernie Kee is going to describe
12 that. Just give a brief overview of the RoverD
13 analysis.

14 MR. KEE: So this is Ernie Kee. And we'll
15 move to slide nine.

16 And Lisa's already described this in some
17 detail. I might mention here that the basic
18 deterministic test data were WCAP 16793 for in-core
19 hot leg breaks -- oh, cold leg breaks. And we have
20 the strainer tests of 2008 that Wes Schulz will go
21 into in detail later.

22 I might mention also that CASA Grande, it
23 basically is a flexible analytic framework that can be
24 used in a -- to support a full risk informed mode. To
25 your question, Dr. Kirchner.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So earlier, in fact at the end of 2011, I
2 would say that full risk informed also implies maybe
3 best estimate inputs into the -- into a PRA. And we
4 used that CASA Grande framework in that mode to supply
5 those inputs.

6 And so it's more of a best estimate. For
7 instance we, based on previous testing, didn't take
8 into account chemical effects that both NRC tests.
9 And then later we confirmed that we could reasonably
10 ignore that kind of effect on a best estimate basis.

11 So we use CASA Grande now in what we call
12 a deterministic mode. Where we obey all the guidance
13 that was mentioned in the IO-407. These kinds of
14 guidance in that application.

15 And then we basically generate many, many
16 scenarios. And as Lisa also mentioned, some of these
17 meet deterministic criteria, others don't. And the
18 ones that don't, we put into the category of risk
19 informed.

20 So we've kind of devolved this problem
21 into two kinds of categories. Either risk informed or
22 deterministic. And that was the main simplification
23 that came about with this RoverD. Slide ten then.

24 So I think this has been said. That the
25 RoverD framework simplifies this very complex risk

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assessment of many thousands of scenarios by using
2 deterministic test data and bounding analysis.

3 So we've talked about in-core analysis.
4 And for example a hot leg breaks, we assume a full and
5 complete blockage of the core and core bypass. Which
6 is a theoretically bounding approach to that in-core
7 behavior.

8 We bound them -- we create bounds on
9 uncertainties to make the assessment tractable,
10 reviewable, and easily understood. I think that's the
11 kind of a core idea here that we have an
12 understandable way to view this, this risk.

13 And the PRA from the South Texas Project
14 along with CASA Grande was actually used quite
15 extensively in this project. Primarily now we have
16 the ability to look at the success frequencies.

17 For example, different thousands and
18 thousands of configurations of equipment for example.
19 And so that's how we use the PRA for that. And to
20 understand the largely release frequency, given a core
21 damage frequency. And now we're on slide 11.

22 So at a high level we ensure the tested
23 fine fiber which we've ensured bounding all other
24 types of debris species, is either met or if it's not,
25 we assign it -- we assign those scenarios that don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 meet that criteria to risk inform.

2 And those that are in the risk informed --
3 the scenarios that land in the risk informed category,
4 we do some additional analysis. But we basically
5 assign those to core damage.

6 So it's again, kind of a bounding concept.
7 And finally, we confirm the containment integrity is
8 maintained for defense in depth. Even though we don't
9 expect to get there, but should we get there, we check
10 to make sure that the concerns raised in GSI-191 don't
11 lead to a containment failure.

12 And with that, I'll turn it over to Wes
13 Schulz.

14 VICE CHAIRMAN CORRADINI: So, I didn't
15 know where to bring this up. But since you brought up
16 containment.

17 So, other members in particular who know
18 the system better than I sometimes, reminded me that
19 South Texas, I'll use the word unique, but has
20 essentially the containment fan coolers. Which if
21 containment spray failed, containment fan coolers
22 could provide the appropriate heat decay removal
23 function that allows bullet three to be maintained.

24 MR. KEE: Yes, sir.

25 VICE CHAIRMAN CORRADINI: Is that a fair

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 --

2 MR. KEE: Yes, sir. They're independent
3 if you will, from those kind of concerns that are --

4 VICE CHAIRMAN CORRADINI: Okay. So this
5 doesn't apply to you, but eventually we're going to
6 get around too somewhere if we have time, how what you
7 do can be applied to others.

8 But this containment fan cooler attribute
9 is unique to South Texas. It doesn't apply across the
10 board in many of the PWR containments.

11 MR. KEE: I can't make a claim for other
12 plants. But I think the --

13 VICE CHAIRMAN CORRADINI: I don't remember
14 it's --

15 MR. KEE: Many have a similar.

16 MEMBER STETKAR: In my experience --

17 VICE CHAIRMAN CORRADINI: The only one I
18 remember is Zion.

19 MEMBER STETKAR: It's neither unique to
20 South Texas nor is it ubiquitous throughout the fleet.
21 Some plants --

22 VICE CHAIRMAN CORRADINI: In between.

23 MEMBER STETKAR: Have them, some plants
24 don't. So, the plants that don't, have containment
25 fan coolers that would be available during these types

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of scenarios.

2 The conditional large release probability
3 would be, I don't want to say guaranteed, but it would
4 be very close to one given core damage and sump plug
5 in.

6 VICE CHAIRMAN CORRADINI: Right. Okay.

7 MEMBER STETKAR: So that it's -- you need
8 to look -- they're fortunate because they do have it.
9 So therefore there's a distinct numerical separation
10 between the amount of -- if all of the sumps plug,
11 they still have a lot of margin before they can reach
12 containment failure.

13 VICE CHAIRMAN CORRADINI: And that was
14 one. The second things, because you can guess the
15 member who reminded me of all this, you have three
16 sumps. That also, I won't say use -- he was very good
17 at not unique versus ubiquitous.

18 But three is not necessarily what I'd see
19 in others. I don't remember any plants with four.
20 But I remember, and I've been reminded that most
21 plants have probably two sumps.

22 Is that fair?

23 MR. KEE: Yes, sir.

24 VICE CHAIRMAN CORRADINI: Okay. Okay.

25 Fine. The only reason I'm bringing that up is, how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this, which I'm -- somebody used the word hybrid,
2 which I liked, this hybrid risk informed approach is,
3 to me, quite interesting.

4 But then it's applicability very much
5 determined, is a function of what equipment and
6 geometry it's applied to.

7 MEMBER STETKAR: Now just, I'd say that
8 the approach is applicable to any plant with any
9 configuration with any number of trains. The
10 complexity of applying it becomes more difficult as I
11 have larger numbers of trains and let's just say
12 interesting configurations of the sumps. Interesting
13 hydraulic configurations now of the sumps.

14 VICE CHAIRMAN CORRADINI: Well, I think
15 John said it better than I. But thanks. Let's keep
16 on going. I just wanted to make sure your third
17 bullet that I had it in my mind.

18 MR. SCHULZ: Good morning. This is Wes
19 Schulz. I'm going to talk about a deterministic
20 element of our RoverD approach. And also a head loss
21 -- the strainer head loss testing.

22 Let's go to slide 13. And that's a photo
23 inside containment. South Texas is called the high
24 fiber plant because we have fiberglass insulation over
25 virtually all of our insulated piping and equipment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 inside containment.

2 You can see from the photo here we have --
3 fiberglass blankets on the piping. The trade name is
4 NUCON.

5 On the right-hand side there is -- in the
6 back, is the reactor coolant pumps. So the equipment
7 has fiberglass insulation on it also. The steam
8 generators have fiberglass insulation on them.

9 In the foreground there is, I think that
10 might be my head. I was showing this slide to my
11 wife. I told her that's definitely me. But to make
12 her happy, but okay. Let's go to slide 14.

13 This is a picture of our original design
14 strainer, we mentioned that. Put some scale on this,
15 the top of the strainer is about four and a half feet
16 off the floor.

17 Underneath that strainer is a sump pit.
18 The pits are below floor level. And we have three
19 individual sump pits, one for each train.

20 The strainer consists of perforated plate
21 on four sides. The hole size is a quarter inch.
22 Let's go to the next slide.

23 Fifteen shows our new strainers, which we
24 installed like the rest of the industry, in response
25 to the generic letter. These -- we have 20 strainer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 modules per sump. You can see them here.

2 Again, the scale of this, the top of the
3 strainer is about two and a half feet of the floor.
4 And again the sump pit is underneath, is below this.

5 The bottom right picture shows some
6 protective grading in front of the sump. That's not
7 for hydraulic reasons. That's more just to protect it
8 during outages when we're moving equipment and
9 material in that area. So we want to protect our
10 sumps there.

11 And the whole size for these is .095
12 inches. A much smaller hole size for the new designed
13 strainers. Let's go to slide 16.

14 This is a figure from our CAD model. We
15 developed this CAD model through the years. It's
16 become very sophisticated.

17 We modeled the configuration of all the
18 piping inside containment with the associated
19 insulation type and the insulation thickness. We
20 modeled in the equipment, equipment supports,
21 equipment insulation.

22 And we show where the coatings are, the
23 type of coatings. We've got the structural steel in
24 there. We also modeled in the concrete walls, the
25 floors, the grating of the floors.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 A very sophisticated picture of our
2 physical configuration at South Texas. And this
3 picture shows the zone of influence for a 31-inch pipe
4 break. That you can see that. Get some perspective
5 on what the ZOI for this 31-inch pipe break is.

6 Let's go to slide 17.

7 MEMBER MARCH-LEUBA: So wait. Can you go
8 back in there? So some of us are not familiar with
9 the whole methodology.

10 You will assume that all of the insulation
11 in that sphere goes down the drain?

12 MR. SCHULZ: Yes. All that insulation in
13 that sphere is affected by the pipe break. And we
14 would apply the transport rules for moving that debris
15 to the sump.

16 I mean, --

17 MEMBER MARCH-LEUBA: And that transfer
18 rule is two percent of it? Or five percent?

19 MR. SCHULZ: Well, it depends on, for a
20 given size there's some -- we get large pieces, we get
21 small pieces, and we get fine. So, depending on how
22 far away it is from the break, there's a certain
23 amount of insulation.

24 And each insulation has its own transport
25 type. But for our purposes, for our RoverD approach,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we're looking at fiber fines, which readily transport.
2 They're the small fibers that will clog stuff.

3 So, that's what we'll do.

4 VICE CHAIRMAN CORRADINI: But to answer
5 Jose's question, the testing in 2008 determined, was
6 meant to determine what gets there versus what settles
7 out on the way there.

8 Is that a fair point?

9 MR. SCHULZ: Well, the 2008 test showed
10 that for this amount of fiber fines, we had an
11 acceptable strainer head loss. So, transport didn't
12 really enter into it.

13 Did I answer your questions?

14 MEMBER MARCH-LEUBA: Yes. But that's not
15 the transport. That is how much fiber gets into the
16 mesh.

17 MR. SCHULZ: The actual mesh. Yes.

18 MEMBER MARCH-LEUBA: But in other monitor,
19 you run these calculations? Did you transport five
20 percent of the mesh? Or the fibers? Or none --

21 MR. SCHULZ: Oh, no. Like over 95 percent
22 of the -- all goes yes. About everything goes.

23 MEMBER MARCH-LEUBA: Okay. So you use 95
24 percent then.

25 MR. SCHULZ: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RICCARDELLA: And was that
2 established by testing? What -- you said there was
3 different amounts depending on how far you are from
4 the break.

5 How was that established?

6 MR. SCHULZ: That was established by a
7 test, right. Alion did some testing for that. Which
8 the staff reviewed and --

9 VICE CHAIRMAN CORRADINI: But not the
10 2008? Not the 2008 testing? Separate testing.

11 MR. SCHULZ: How we -- for a given -- for
12 the zone of influence, how much large pieces, small
13 pieces, fine fibers are generated. That's the
14 standard that there is.

15 MR. RICCARDELLA: And for different types
16 of insulation too, you said?

17 MR. SCHULZ: Yes. It would apply too
18 different. Particularly ZOI for the particular debris
19 type. This is for NUCON insulation. There's another
20 one for coatings.

21 There's another one for our Marinite and
22 another one for Insulite. And those are established
23 in the guidance that we've evolved.

24 VICE CHAIRMAN CORRADINI: And part of the
25 reason I went back to one of the bullets that Wayne

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 had mentioned, in the calculations done, Marinite is
2 still considered.

3 MR. SCHULZ: Yes. I'll address that.
4 Yes. I'll get there.

5 VICE CHAIRMAN CORRADINI: Okay. Fine. I
6 just wanted to make sure to connect it back to the
7 bullet that what had been removed but is still
8 considered in the analysis.

9 MR. SCHULZ: Right.

10 MR. KEE: This is Ernie Key. I just
11 wanted to make sure that we understand. That zone of
12 influence that is indeed spherical, but we do -- CASA
13 takes care of this.

14 If there's a big concrete wall in the way,
15 it doesn't go through that. But the pipes themselves
16 are transparent to that. So, but --

17 MR. SCHULZ: Yes. So there's wall
18 shadowing but not equipment shadowing.

19 MR. KEE: Correct.

20 MR. SCHULZ: Okay. Right. Okay. Let's
21 go to slide 17, Wayne.

22 So this is the -- a deterministic
23 evaluation followed the NEI guidance approved by the
24 staff. And we submitted that in the format to -- as
25 the staff put out this content guide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So these are the elements of our response,
2 of our deterministic evaluation. And these -- our
3 break selection initially for the test we had back in
4 2007, we had three or four, we actually had four
5 different large breaks.

6 And we took the maximum, looked at the
7 debris for each break. And we took the maximum amount
8 for a particular debris type for our test. We tried
9 to use a bounding amount in our test that would
10 overlap that.

11 But again, that's sort of immaterial going
12 forward. Because the test is just the test for that
13 amount of debris. And we used that as a benchmark
14 going forward.

15 Now, as Ernie mentioned, break selection,
16 we have breaks at thousands of places and thousands of
17 different size breaks at those locations.

18 VICE CHAIRMAN CORRADINI: But just to
19 repeat so that -- for the members that weren't at the
20 April 5 subcommittee. These tests determine a
21 threshold limit that above which strainers have -- are
22 challenged, below which strainers are not challenged.

23 MR. SCHULZ: Yes. It was the limit that
24 was successful. We didn't test to a --

25 VICE CHAIRMAN CORRADINI: I understand.

1 MR. SCHULZ: That's official. That
2 threshold mark --

3 VICE CHAIRMAN CORRADINI: That's a
4 threshold limit.

5 MR. SCHULZ: That's a measure for success.

6 VICE CHAIRMAN CORRADINI: Okay. Thank
7 you.

8 MR. SCHULZ: We assume it fails after.
9 Everything about that fails.

10 So, the same thing with debris generation.
11 Well, we talked about the different COIs. We have all
12 that in our current analysis for that.

13 Debris characteristics per the NEI
14 guidance, latent debris, we did a walk down to confirm
15 that the number we used from the NEI guidance was in
16 fact bounding.

17 Debris transport, again, in our current
18 analysis we assume all the fiber -- most of the fiber
19 finds are readily transported. The particulates
20 readily transport.

21 Head loss, vortexing, that positive
22 suction head, we evaluated the debris head loss on the
23 strainer to show that the strainer would perform
24 adequately. And that it was acceptable.

25 Coatings evaluation and all of these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 elements are in the NEI guidance. We assume that
2 coating fail particulates in a couple of locations, we
3 assumed there were chips.

4 And we went -- used the REI process to
5 evaluate this with the staff. So they were acceptable
6 with the -- once we had that dialog.

7 Screen modification, knowing
8 modifications, hardware modification, we did when we
9 installed the new strainers. And then we removed the
10 Marinite insulation on the reactor vessel nozzles.

11 Marinite is a trade name for calcium
12 silicate. Which is a very problematic insulation.
13 So, we took that and removed that.

14 And put the NUCON fiberglass insulation on
15 the reactor vessel nozzles. So those are the only
16 hardware modifications that we did for this paper.

17 Upstream effects, we looked at choke
18 points. Count all the break flow, and it came
19 straight flow, get to the strainers. And that was
20 acceptable. And we have a very favorable lay out for
21 that.

22 Downstream effects, we looked at our
23 components and our safety injection system and our
24 containment spray system to make sure that the
25 insulation fibers and the particulate debris is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 acceptable. These components again, perform
2 acceptably with this debris being recirculated.

3 MEMBER SKILLMAN: Did you make any changes
4 to your equipment?

5 MR. SCHULZ: No. We did not.

6 MEMBER SKILLMAN: Okay. Thank you.

7 MR. SCHULZ: We didn't have to. We showed
8 everything was acceptable.

9 MEMBER RICCARDELLA: Excuse me, but on the
10 break selection, does your model include different
11 frequencies for different break sizes? Or how's that
12 --

13 MR. SCHULZ: Yes. Ernie you want -- about
14 here?

15 MR. KEE: Yes, sir. We basically
16 interpret the NUREG-1829 frequency tables for -- based
17 on the size of the break that we estimate what that
18 frequency is.

19 MEMBER RICCARDELLA: Yes. I was part of
20 the 1829 effort. Thank you.

21 MR. SCHULZ: Last thing is debris source
22 stream. We based our evaluation on information in the
23 plant. And we want to make sure that that's valid,
24 still valid going forward.

25 So we have programs, instituted programs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to help maintain that. We have a containment closeout
2 inspection. Which is really a surveillance at the end
3 of an outage.

4 We'll go through and make sure we remove
5 all the items that don't belong there. And we'll look
6 for loose debris and remove that from containment.

7 And then our design change process, we've
8 added steps in there to make sure that when we
9 evaluate changes we need to address -- we want to
10 maintain the insulation types. And the cooling types,
11 the same as the analysis. If not, we have to justify
12 them with respect to the analysis.

13 And we also looked at an addition of
14 metals, including aluminum. Which is a contributor to
15 a source for our chemical particulates.

16 So it's in our design change process to
17 evaluate future changes to make sure that our
18 evaluation here is still valid.

19 MEMBER SKILLMAN: So Wes, what do you do
20 when you close out your outage? Do you go in there
21 with mops and brooms and take out every tiny little
22 piece of stuff that the carpenters left behind when
23 they were making scaffolding?

24 MR. MURRAY: Let me answer that. This is
25 Mike Murray. I'm on the -- I actually have to sign

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 off the surveillance for an area. So I can tell you
2 exactly what we do.

3 So during the outage, and when we get into
4 closeout, we have a phase that's call the containment
5 cleanup. And at that point we have coordinators that
6 are basically working with teams that do, in some
7 cases, mop, clean up.

8 And then I go through three times during
9 the later part of an outage. For example, from my
10 area, and I'll look for every nit to pick. Tie wraps,
11 anything. I'll look in cabinets, I'll look in
12 stanchions. I look everywhere, behind things.

13 We then identify any punch list items.
14 They get cleaned up. And then prior to mode four
15 entry, we go through, there's a team that has
16 different areas, area managers we're called.

17 And we go back through containment the
18 last time before we actually enter mode four and sign
19 off the surveillance. And if there's any outstanding
20 items, there's a punch list that has to be taken care
21 of before entry into mode four.

22 And that is -- and then our resident
23 inspector goes behind us and takes a look. And gives
24 us feedback in anything that he may have found that we
25 may have missed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And we take that into our lessons learned
2 for future outages.

3 MEMBER SKILLMAN: Thank you, Mike. Thank
4 you.

5 MR. SCHULZ: Thanks Mike. Yes. Let's
6 move onto slide 18. And talk about our strainer head
7 loss testing.

8 This was conducted in July 2008 at Alden
9 Labs up in Massachusetts. We used a -- one of our
10 spare strainer models. So we had a full size strainer
11 module there with the design flow for the module.

12 Debris loading was based on two trains in
13 operation. So we're going to just scale the debris
14 for this one module based on the total debris load.
15 And then we scaled it -- for the two trains, we scaled
16 it down.

17 And Alden constructed the flume channel to
18 emulate the approach velocity and turbulence that we
19 would expect in -- inside containment. Let's go to --

20 VICE CHAIRMAN CORRADINI: I don't
21 remember. I remember the meeting. I don't remember.
22 So did Alden do it so that -- because the way you
23 describe these things, here's the sump, here's all the
24 strainers.

25 So did Alden do them like this? Or like

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this?

2 MR. SCHULZ: They did both ways.

3 VICE CHAIRMAN CORRADINI: They did?

4 MR. SCHULZ: Yes. I mean, they picked a
5 velocity field near the strainer so some's coming this
6 way, some comes that way. So they --

7 VICE CHAIRMAN CORRADINI: And they took
8 the lowest value that's --

9 MR. SCHULZ: They did a bounding thing.
10 Yes. To make sure.

11 VICE CHAIRMAN CORRADINI: Okay. Right.
12 I didn't remember. So this threshold limit which
13 you're eventually going to talk about, is from all
14 these kind of here versus here as the lower limit of
15 those.

16 MR. SCHULZ: Right.

17 VICE CHAIRMAN CORRADINI: Okay.

18 MR. SCHULZ: And they tried to simulate
19 that in our test. To make sure we got a close
20 velocity.

21 VICE CHAIRMAN CORRADINI: Okay. That's
22 fine. I just couldn't remember.

23 MR. SCHULTZ: Let's go to slide 19. This
24 is the debris we used during the test. We had our
25 fiberglass debris. We had the fiberglass fine and had

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the smalls.

2 We had particulates from our Microtherm
3 insulation. Microtherm is another trade name, brand
4 name, of a high density microporous insulation. We
5 have very little of it.

6 But it's another problematic insulation.
7 We use that in pipe penetrations through concrete
8 walls. So we do have some of that.

9 And we had the Marinite particulates, the
10 Marinite calcium silicate. We used that in our test.
11 And we had latent dust and dirt particulates also.

12 The chemical debris, we used -- I didn't
13 talk about that earlier. We need -- was based on very
14 conservative calculation from -- through Westinghouse
15 methodology.

16 We used 30 days of containment spray to
17 maximize the amount of chemical precipitants. And
18 there's some precipitants, there's another way of --
19 two ways of doing it is a minimum pool volume and a
20 maximum pool volume.

21 And depending on that, the particular
22 precipitants would -- they'd be maximized. And again,
23 we picked the worst of each from the two different
24 ones. So we get a maximum chemical debris loading.

25 And our coatings, we represented the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 different various types of coatings that we have
2 inside the plant. So that's for the strainer debris.

3 Let's go onto slide 20.

4 MEMBER MARCH-LEUBA: So when you talk
5 about coatings and you talk about flaking of paint and
6 that flake blocking the strainer? Or is there a --

7 MR. SCHULZ: Right. Within the zone of
8 influence, the particulates fail -- the coatings fail
9 as particulates. You know, 10 micron particulates.

10 And our unqualified coatings, we assume
11 they all fail not matter where they are. Whether
12 they're inside the ZOI or outside the ZOI. They're
13 still --

14 MEMBER MARCH-LEUBA: More then flakes.
15 You're talking about grains of sand that fall out.

16 MR. SCHULZ: Right. Small particulates.
17 Yes.

18 MEMBER MARCH-LEUBA: Yes.

19 MR. SCHULZ: and in one case we had chips.
20 And we -- in one location we treated -- that was again
21 with the staff, we agreed on the methodology for
22 treating those particulates.

23 MEMBER MARCH-LEUBA: And those typically
24 go into the vessel? Or they stay on the strainer?

25 MR. SCHULZ: Well they can -- they go to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the strainer. They can be captured on the debris bed.
2 They form a debris bed on the strainer.

3 But some fibers and some particulates pass
4 through. And that's what our downstream effects look
5 at, both in-vessel and for other confluence too.

6 So some of it does get through the
7 strainer, yes.

8 MEMBER MARCH-LEUBA: All right.

9 MR. SCHULZ: So back -- on slide 20, we do
10 a reconciliation of the debris using the tests. And
11 these test amounts were calculated back in 2007.

12 And since then, we did use Marinite
13 insulation in the test. However, we removed it so we
14 had the test had more -- extra Marinite in it.

15 We also -- subsequent analysis showed that
16 the Microtherm insulation that we used in the test was
17 much more than what actually transport. On the other
18 hand we showed that some of our coding particulate
19 debris, more is calculated to transport compared.

20 It was under the predicted amount compared
21 to what we had in our test. So we that credit here
22 with -- from the Microtherm and the Marinite. And we
23 had a debit from our particulates.

24 And we did a reconciliation of that to the
25 -- again, reviewed by the staff in the REI process, to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 show that they compensated. And so that's how we
2 reconciled our test amounts of debris.

3 Let's go to slide 21. So the results of
4 our strainer head loss testing, the debris preparation
5 and the conduct of the test were acceptable to the
6 staff.

7 The staff witnessed the test back in July
8 2008. We had a debris bed formed of a large quantity
9 of particulate with the chemical loading and it did
10 not show the need for additional thin bed testing.

11 So the test showed about half the head
12 loss was due to the chemical debris. The other half
13 was due to the fibers and particulates.

14 We added them in sequence. We had
15 particulates and the fibers first. The test took
16 about two and a half days.

17 We had them in batches. We added the
18 fibers and particulates in batches. And then we added
19 the chemicals. And about half of the head loss was
20 due to the chemical precipitous.

21 Although the test shows that it was
22 acceptable. And it shows we have satisfactory
23 performance of our equipment up to the level of the
24 amount of debris that we tested.

25 So that's our benchmark going forward.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And also this eliminated the need for head loss
2 correlation. Our very first fully risk informed
3 approach we used a head loss correlation to calculate
4 debris loss.

5 But we -- that was getting too many
6 questions from the staff. And there was too much
7 uncertainty there. So we're actually using actual
8 test results was about that uncertainty if you were us
9 a correlation.

10 MEMBER MARCH-LEUBA: And sorry to ask
11 these questions this late in the review, because I
12 wasn't here. But, on the testing will you use two
13 foot flow into the channel?

14 Because in real life, you will have two
15 inches. And those two inches will clog. And then the
16 level will rise. And you'll have clean strain then
17 that will clog. And then --

18 MR. SCHULZ: Oh. Yes. We had full level.
19 Yes. To do what we had.

20 MEMBER MARCH-LEUBA: Yes. So that's
21 fairly conservative. I would expect most of the
22 fibers to deposit on the first two inches. Right?

23 MR. SCHULZ: No. We don't turn the pumps
24 on until we get the level above the strainers. So --

25 MEMBER MARCH-LEUBA: Oh. You have to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cover it completely?

2 MR. SCHULZ: We have a containment spray
3 and safety injection takes selection from a fueling
4 wash storage tank. And that tank gets depleted and
5 gets -- ends up on the containment floor and fills
6 that up.

7 When that tank's nearly depleted, then we
8 switch over to recirculation mode. And then we --
9 then the flow goes through the strainer then.

10 MEMBER MARCH-LEUBA: Oh, they explained it
11 --

12 MR. SCHULZ: So those will, yes. There's
13 about -- the minimum amount is about ten inches above
14 the strainers when we turn the pumps on.

15 MEMBER MARCH-LEUBA: And is there --

16 MR. SCHULZ: At least one of the pumps.

17 MEMBER MARCH-LEUBA: Then is there enough
18 time for it to settle into the floor?

19 MR. SCHULZ: Yes. There is some set --
20 maybe some settling to it. Yes. We didn't query that
21 too much in our transport. But we have to --

22 MEMBER MARCH-LEUBA: Okay.

23 MR. SCHULZ: So, the strainer head loss
24 testing established a benchmark of this quantity of
25 debris, the various debris types resulted in a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 successful strainer operation head loss testing.

2 And now Ernie is going to continue with
3 how we use those. Our benchmark.

4 MR. KEE: And so this is Ernie Kee. We
5 can move to slide 23.

6 So we've already said this that RoverD
7 scenarios begin with a break at a particular location.
8 At each location there's many thousands of scenarios
9 examined.

10 And this was for the purpose of finding a
11 certain value. Which I'll address here in a minute.
12 But, so we look at break sizes and orientation of the
13 break to find a particular one we're interested in.
14 Or to exclude as deterministic that whole location.

15 I mentioned already that we'll use CASA
16 Grande in the deterministic mode to calculate the
17 generation transport and erosion to the floor pool.
18 And this is where we get the limit of -- we look to
19 see if all that material that gets into the floor pool
20 is greater than or less than what Wes has described in
21 his test.

22 And if it's greater than that amount in
23 terms of fine fiber, which is the most readily
24 transported debris, then if it's more than what Wes
25 has tested, then we relegate those scenarios to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 risk-informed category.

2 I might mention -- now I can't recall who
3 asked this question. But, about the particulate being
4 cat -- was that you Dr. March-Leuba?

5 MEMBER MARCH-LEUBA: Call me Jose.

6 MR. KEE: Yes. I'm sorry. That debris is
7 actually counted twice by virtue of the way the tests
8 are done. So, we put all the particulate in Wes'
9 test. And collect it as it will be collected on the
10 screen.

11 But then also the WCAP at 16793 test,
12 which we used for the cold leg break criteria for
13 adequate core cooling, it uses all the particulate in
14 its test as well. And all the chemicals.

15 So it kind of -- those things get counted
16 twice. And that's an area of conservatism or
17 uncertainty quantification.

18 And then scenarios that have to meet the
19 deterministic criteria upstream, as Wes talked about
20 that downstream. Wes talked about that in-vessel and
21 reactor containment building integrity criteria. Or
22 else they're categorized as risk informed.

23 So we're moving onto slide 24. Of these
24 scenarios that we put in the risk-informed category,
25 and this goes to Dr. Riccardella's question about how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 do we determine these frequencies.

2 So this is one of the great
3 simplifications we make in the RoverD analysis. We
4 only have to look at -- well, you could look at many.
5 But what we've done is we only look at one of those --
6 at each location, we only look at one of the scenarios
7 that's in the risk informed category.

8 What one is that? That's the one that by
9 carefully looking in a very fine mesh for the break
10 that just exceeds the break size. It just exceeds the
11 amount of debris that was tested.

12 So, we only have to look at one. Because
13 any other break will create more. You could think of
14 it that way. In fact, it's another conservative
15 assumption in terms of risk estimation that we make
16 because of how we do that.

17 I don't think we need to get into that.
18 But the point is, we've degenerated this into one
19 scenario that just exceeds the break, the tested
20 deterministic amount, and we find the highest
21 frequency by virtue of the smallest break size on that
22 scenario.

23 MEMBER RICCARDELLA: Wouldn't a larger
24 break create more debris? And be more of a concern?

25 MR. KEE: Absolutely.

1 MEMBER RICCARDELLA: But it's a lower
2 frequency? Is that what you're saying?

3 MR. KEE: It's a -- well, those larger
4 breaks are also in the risk informed category. And so
5 --

6 MEMBER RICCARDELLA: Oh, I see. That's
7 fine.

8 MR. KEE: Exactly right that it would have
9 a much lower frequency as they become larger and
10 larger. So we're looking for the --

11 MEMBER RICCARDELLA: And this is the
12 determinant.

13 MR. KEE: A risk estimate. Yes.

14 MEMBER RICCARDELLA: All right. All
15 right. I've got it. Just a comment.

16 You know, there's another big program
17 going on now called, oh, what is it? XLRP? You know
18 XLPR, or extra low probability of rupture which is a
19 big quantitative -- quantified study that try to
20 replace leak before break and come up with, you know,
21 more accurate pipe break frequencies than what's in
22 this.

23 There's NUREG-1829 which was kind of an
24 expert solicitation effort. But, I don't know.
25 That's -- we're not there yet. But just so you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 aware, there is more research going on in that area.

2 MR. KEE: Yes, sir. We've kind of looked
3 into that in a very early time of this -- addressing
4 this problem. And tried to look at probabilistic
5 fracture mechanics. And what kind of causal models
6 are out there for these breaks.

7 And there's not much information. I think
8 it's still the best source today is this NUREG-1829.

9 MEMBER RICCARDELLA: I'm sure.

10 MEMBER SKILLMAN: Ernie, before you go on,
11 that second bullet. Kind of building on Pete's
12 question, relative to the break size.

13 Fetch smallest break size. Why isn't that
14 fetch the most probable break size? Or the most
15 likely break size? Regardless of its orientation?

16 MR. KEE: Actually, that is the most
17 probable, based on the way these curves are developed.
18 The smaller the break size the greater the frequency
19 estimate is for currents.

20 So, there actually can be larger breaks --
21 I don't know if we want to get mired down. But there
22 actually can be larger break sizes that don't fail
23 this tested amount of material. We know that.

24 MEMBER SKILLMAN: Yes. I can understand
25 that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KEE: Yes. So -- but we still --
2 still we look for the smallest one. So that's a --

3 MEMBER SKILLMAN: Because it's most
4 likely.

5 MR. KEE: Yes. And it produces a
6 conservative estimate.

7 MEMBER SKILLMAN: The greatest amount of
8 fiber.

9 MR. KEE: Yes. For the risk. So we want
10 to know are -- we want to have a good sense that we've
11 bounded the risk shall we say.

12 MR. HARRISON: The smallest break that
13 exceeds the tested amount.

14 VICE CHAIRMAN CORRADINI: And anything
15 above that is assumed to also fail.

16 MR. KEE: All those -- yes. We assume
17 they all fail.

18 VICE CHAIRMAN CORRADINI: Could go larger
19 ones and a different orientation would be --

20 MR. KEE: Might not.

21 VICE CHAIRMAN CORRADINI: Master tool
22 might not.

23 MR. KEE: They may not.

24 VICE CHAIRMAN CORRADINI: Okay. Very
25 good. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KEE: Yes, sir. So why don't we --
2 we're on slide 24 now.

3 VICE CHAIRMAN CORRADINI: Next bullet.

4 MR. KEE: Oh. Wayne changed the slide on
5 me.

6 MR. HARRISON: No, I didn't.

7 (Laughter)

8 VICE CHAIRMAN CORRADINI: Very crafty
9 Wayne.

10 MR. KEE: So we look at all these smallest
11 breaks at each location. And we interpret -- we say
12 we interpret the NUREG-1829 tables to arrive at the
13 total frequency across all the risk informed
14 scenarios.

15 And we assign that frequency to core
16 damage. So, that's another kind of area that is a
17 conservative estimate if you think in terms of PRA.
18 There would be other failures along the way that could
19 occur.

20 And then we use the probabilistic risk
21 assessment from the South Texas Project. The same one
22 we developed early and like we were talking about in
23 2011, to get the change in large early release
24 frequency.

25 Now I already said that this -- the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 containment integrity is maintained independent of
2 this -- the concerns raised in GSI-191. The concerns
3 raised in GSI-191 do not lead to containment failure.

4 But of course since the core damage
5 frequency increases, these other kinds of scenarios
6 that exist, you know, for isolation and so forth,
7 those are still out there that are in the PRA. And so
8 we -- there's an increase in learn from that effect.

9 So, we need to this -- we're moving to
10 slide 25. And we need to look at in-core reactor
11 vessel scenarios. We've talked about all the others
12 so far.

13 And in this case, in this vessel
14 situation, we look at two kinds of breaks, hot leg
15 breaks and cold leg breaks. Because they're different
16 in terms of how the debris flows into the core and the
17 driving head.

18 So looking first at the hot leg break
19 scenarios, and I've already mentioned this, we're
20 using peak clad temperature. Which is a common
21 acceptance criteria for success.

22 And in this case, the theoretically
23 bounding assumption that we make here is that for all
24 the fuel assemblies and the core barrel bypass channel
25 are blocked fully at the time of sump recirculation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 switch over. We do take credit for the build up to 15
2 grams of per fuel assembly that's in the WCAP 1693
3 testing.

4 MEMBER MARCH-LEUBA: So Ernie, is there
5 any flow path for water to get into the reactor core
6 after you block those?

7 MR. KEE: Yes. There is. And there's
8 flow paths that have large enough holes in them. For
9 instance, the upper head spray flow and then of course
10 the flow through the other intact loops of steam
11 generator can come around eventually and come into the
12 top of the core.

13 MEMBER MARCH-LEUBA: They'll go from up in
14 the hot leg?

15 MR. KEE: Correct. Correct. And so we
16 show that we meet the thermal hydraulic requirements
17 with this kind of a limiting of function. And so we
18 move to slide 26.

19 MR. HARRISON: And those were the RELAP5
20 3-D analysis that Lisa was talking to. And we don't
21 use the 3-D function as I recall.

22 MR. KEE: That's correct. Although we
23 have looked at that.

24 VICE CHAIRMAN CORRADINI: But just to
25 clarify for the members, you -- I don't think you said

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it for the out of -- for the strainers. But this
2 large of a break is already covered from a failure
3 standpoint because by that time the pipe diameter that
4 would have caused suction and strainer blockage is
5 smaller than the 16 inches.

6 MR. KEE: Yes, sir.

7 VICE CHAIRMAN CORRADINI: So you don't --
8 in some sense this is included in the failures that
9 already would have occurred by just blocking the
10 strainers?

11 MR. KEE: Yes. So we're looking at the
12 ones that we said passed deterministically through the
13 strainers. And now do they pass in-vessel? Yes, sir.

14 VICE CHAIRMAN CORRADINI: Okay.

15 MEMBER MARCH-LEUBA: So every single break
16 that passes deterministic -- that is accepted
17 deterministic from the strainers will also be
18 acceptable for in-core.

19 MR. KEE: That's what we have to make
20 sure. Yes, sir.

21 MEMBER RICCARDELLA: And then those get
22 eliminated from your eventual probabilistic
23 assessment, PRA assessment? Is that the -- is that
24 the way it works?

25 They're acceptable deterministically, then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you don't consider them?

2 MR. KEE: That's correct. All those
3 scenarios that meet the -- to Wes' test level. Tested
4 them out of the fiber level. And also are acceptable
5 in-core in-vessel.

6 MEMBER RICCARDELLA: Okay.

7 MR. KEE: They have to meet all these
8 deterministic criteria. Yes, sir.

9 MEMBER RICCARDELLA: And that's 16 inches
10 for a hot leg break?

11 MR. KEE: Yes. When we look at 16 inches
12 and below.

13 MEMBER RICCARDELLA: Sixteen inches and
14 below.

15 MR. KEE: They all pass. Yes, sir.

16 MEMBER RICCARDELLA: Okay. And then for
17 things greater than 16 inches, you're going to include
18 that in the probabilistic, in the PRA model?

19 MR. KEE: Yes. We did that. Yes, sir.

20 MEMBER RICCARDELLA: Got it. Got it.

21 MR. KEE: So moving to slide 26 now. So
22 the cold leg break only has a driving head of the down
23 comer of course, the excess water from the ECCS just
24 flows out the break in this case.

25 And because of that characteristic, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 accumulate much less fiber on the core. And we
2 analyzed that with a mass conservation three linear
3 different -- well actually they're nonlinear.

4 But anyway, three differential equations
5 for the strainers, the core and the pool with how much
6 is allocated all throughout. And then we check to
7 make sure that the -- we look at many scenarios and
8 check to make sure that we don't exceed the WCAP 16793
9 criteria, 15 grams per fuel assembly.

10 And in fact we couldn't conjure up a
11 scenario that came even close to that level.

12 MEMBER MARCH-LEUBA: Okay. So what you're
13 saying is that for all the cold break -- cold leg
14 breaks, none of them are produce enough fiber in the
15 core to block it.

16 MR. KEE: That are below the deterministic
17 criteria. Yes, sir. So both hot leg and cold leg are
18 acceptable from that point of view in-vessel.

19 MEMBER RICCARDELLA: And what is it that
20 makes the cold leg less critical? Cold leg breaks
21 less critical?

22 MR. KEE: They're not less critical. But
23 --

24 MEMBER RICCARDELLA: Create less debris.

25 MR. KEE: It's the same amount of debris

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in the pool. But what happens is, the -- all that
2 flow that's being bypassed right out through the cold
3 leg, the broken cold leg, goes right through and gets
4 restrained through the strainers.

5 It gets strained again --

6 MEMBER MARCH-LEUBA: It then runs right
7 through the filter.

8 MR. KEE: Yes. And we've done --

9 MEMBER MARCH-LEUBA: So you've -- the
10 water pump get into the cold leg leaks out, goes back
11 to the filter again. And that's all. The filter has
12 a chance for catching it again.

13 MEMBER RICCARDELLA: I see.

14 VICE CHAIRMAN CORRADINI: The flow -- can
15 I try it a different way? Also the flow from through
16 the core is reduced since it's not a hot leg break,
17 it's a cold leg break.

18 So whatever is there, a lot of it doesn't
19 get transported to the core. It gets transported back
20 out the cold leg break. Back to the strainer.

21 MR. KEE: That's even a better -- yes.
22 And it's governed by the decay heat level. Which
23 doesn't demand near the -- we have a huge amount of
24 flow from our emergency core cooling system.

25 MEMBER RICCARDELLA: So it's less critical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from the standpoint of in-vessel effects. It's not --
2 no different for the strainers. It's still a concern
3 to the strainer.

4 MR. KEE: Yes, sir. Yes. It has to pass.
5 Yes. So, we're moving onto slide 27 now.

6 This question came up with regard to
7 single train assumption in our last -- in the
8 subcommittee. So some people weren't here.

9 And the question is regarding taking into
10 account the extra amount of flow that you realize in
11 the containment spray system in single train
12 operation. And whether or not that extra flow under
13 the assumption of half the debris load criteria, which
14 we adopted for single train, if that would be
15 acceptable.

16 And the answer is no, using the -- using
17 that half amount. So we turned back to the PRA. And
18 we asked again, remember we've done all these
19 different equipment configurations already.

20 So we know the answer to this as to what
21 the level of risk is. Which was when you add up all
22 the scenarios that represent the single train
23 configuration, they're like on the order of 18 to the
24 minus 9.

25 So, these kind of -- in terms of success.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And these kind of scenarios contribute very little to
2 the total problem where we're looking at 18 to the
3 minus 7 numbers.

4 So moving onto slide 28.

5 MEMBER MARCH-LEUBA: So then go back to
6 the last bullet. You said the single terms then it
7 could be added to risk informed integrity.

8 But how do you do it?

9 MR. KEE: No. Well, just add 18 to the
10 minus 9 to 15 to the minus 7.

11 MEMBER MARCH-LEUBA: You did add it, and
12 it was inconsequential.

13 MR. KEE: Yes. It's so small. Yes. So
14 now we're on slide 28.

15 And this just summarizes all the
16 information that we've talked about so far. Basically
17 the measures we took at South Texas when we replaced
18 the strainers and insulation and so forth, did achieve
19 the desired result that we have a very low expectation
20 for any kind of problems related to the concerns
21 raised in GSI-191.

22 And these risk estimates include a
23 significant safety margin. We talked about that and
24 Wes has talked about that.

25 Also, we maintained defense in depth. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 even in the unlikely event that we see something like
2 this happening, we're relatively sure that the
3 containment is not going to be conditionally failed
4 due to the same cause.

5 We've done, as Lisa mentioned, many, many
6 different approaches of many different -- incorporated
7 many different analyses using this best estimate and
8 modified best estimate. And now with this RoverD
9 approach, hybrid approach is, I think Ms. Shelton
10 mentioned, Helton mentioned, we consistently see the
11 same kind of low risk estimates in all these
12 approaches.

13 So moving to slide 29. Just to summarize
14 RoverD as a framework. It makes GSI-191 risk
15 assessment understandable, easy to review.

16 We use conservative testing and bounding
17 analysis to accomplish that kind of simplification.
18 Scenarios fall into just two categories. And that --
19 by applying accepted test methods and bounding
20 analysis.

21 We've done many supporting additional
22 tests and analysis throughout the six-year life of
23 this project. I think it's about six years. That
24 confirm for example, the morphology and the quantity
25 of chemicals and so forth that we made publically

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 available.

2 It's on Adams. A lot of this information
3 is on Adams. Or we've also published in the academic
4 literature.

5 With that I'll turn it back to -- the
6 discussion back to Wayne Harrison.

7 MEMBER MARCH-LEUBA: Not so fast Eric.

8 MR. KEE: Okay.

9 MEMBER MARCH-LEUBA: All these conclusions
10 that you have here in the summary, how much do they
11 depend on the fact that you increase the size of those
12 filters from 155 to 1800?

13 MR. KEE: Oh, it's -- no, and that is --
14 that observation that was made in the generic letter
15 asking us to review whether or not we expected that we
16 would be successful with that current strainer design,
17 I mean, that was instrumental in everything we've done
18 since then.

19 We've changed our design change package
20 approach to make sure we control this aluminum and
21 nefarious kind of debris types. And then Wes replaced
22 these strainers with these enormous things to
23 accommodate large amounts of debris.

24 MEMBER MARCH-LEUBA: I don't think you
25 take enough credit for the positive steps you took to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 make your plant safer.

2 VICE CHAIRMAN CORRADINI: I think I know
3 where Jose is going. But I think just to put it in
4 context, I think the PWR community, the population as
5 a whole, not just South Texas, made these equipment
6 changes early up front.

7 And then I'll get confused about the right
8 name, the generic letter -- I'm sorry, I've got it
9 wrong. But, a second communication concern about
10 downstream in-vessel effects, et cetera, then led to.

11 So I think South Texas took the initiative
12 to look at a combined holistic look at the problem.
13 That's my kind of way of thinking about it.

14 But the population of all the plants had
15 to do the first thing in terms of strainer change out.

16 MR. KEE: Yes, sir. And that led to these
17 lowered risk estimates for the -- for problems.

18 MEMBER RICCARDELLA: It would be
19 interesting to see what these Delta CDF and Delta LERF
20 values would be if you went through the full analysis
21 with the old trains. Did you do that?

22 MR. KEE: We've done that actually. I
23 believe that was -- that maybe in one of our
24 applications. I think it is.

25 And it maybe the supplement two.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RICCARDELLA: I don't recall that.

2 MR. KEE: We've done that.

3 MEMBER MARCH-LEUBA: Your critical break
4 size will go down to one or two inches instead of 16.

5 MR. KEE: Yes. And downstream effects are
6 -- in other words, these in-core effects with these
7 larger holes would bypass much more debris into the --

8 MEMBER MARCH-LEUBA: You might still make
9 a risk informed argument that you're okay. But you
10 wouldn't feel comfortable with a one inch break
11 critical effects.

12 MR. KEE: Yes. I'm not sure. Yes. It
13 was pretty high I recall, for the number.

14 MEMBER MARCH-LEUBA: But where there is a
15 13, 14-inch break, critical break size with
16 conservative assumptions, it makes you feel very
17 comfortable. It does to me.

18 MR. KEE: Yes, sir. Yes, sir.

19 MEMBER BALLINGER: To pick up on what
20 Pete's mentioned, I was pouring through 1829 to try to
21 find out what probabilities of failure are for the
22 larger pipes. I mean, the XLPR program is going to
23 basically eliminate those as failure modes, I think.

24 So, I don't know which ones dominate the
25 CDF here. I don't remember.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HARRISON: All break lower, it's about
2 13 inches basically.

3 MR. KEE: Twelve point eight.

4 MR. HARRISON: Twelve point eight.

5 MR. KEE: And above.

6 MR. HARRISON: Yes.

7 MR. KEE: See that's not surprising.

8 MEMBER RICCARDELLA: I wouldn't try to
9 predict what -- it's not surprising either. But I
10 wouldn't try to predict what's going to come out of
11 it.

12 MEMBER STETKAR: It's probably safe to say
13 the numbers will be different.

14 (Laughter)

15 MEMBER BALLINGER: However, you can assume
16 leak before break.

17 VICE CHAIRMAN CORRADINI: Okay, Wayne?
18 Wayne?

19 MR. HARRISON: I will talk about -- this
20 is Wayne Harrison. I will take about the regulatory
21 implementation starting on slide 31.

22 And basically our regulatory information
23 -- implementation included three elements. We had a
24 debris specific action, promote three and above, and
25 our emergency core cooling system and containment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 spray system technical specifications.

2 Those are the only two systems that we
3 have that have any dependencies on the emergency
4 sumps. We have a set of updated final safety analysis
5 report changes that help us as a licensee in our
6 implementation process.

7 We will change -- for instance, I'm going
8 to talk just briefly about the exemptions field to
9 change the description of how we comply with the
10 regulations using the risk informed process.

11 We will explain the program. What we just
12 went through here, we will have an appendix in Chapter
13 6 of our USFAR that explains the analysis that we went
14 through and the rules of engagement for that analysis
15 with our plant.

16 And it also has elements of change control
17 that you've seen in the draft rule, 50.46(c), and the
18 things that are analogous to 50.59 that we can't
19 change without prior staff approval.

20 Because there's some of these things that
21 are fundamental to our methodology that we -- that
22 would require prior staff approval to change it. And
23 that's outlined in our USFAR changes as well.

24 We have requested exemption to four of the
25 regulations, 50.46(a)(1), the other properties portion

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of that. Basically the basis for all these exemptions
2 is that we're using a risk informed methodology
3 instead of the deterministic methodology that's
4 implicitly if not explicitly required by the
5 regulations.

6 So, we can -- the basis is that we can
7 achieve the underlying purpose of the rule without
8 using the deterministic method that the risk informed
9 still achieves the basic purpose of the rule.

10 And I mentioned the burden associated with
11 it, but the basic reason is that we can achieve the
12 rule's purpose using the risk informed approach.

13 General design criteria in 35 for
14 emergency core cooling system, general design criteria
15 in 38 for containment heat removal, and general design
16 criteria in 41 for containment cleanup. And they all
17 have the same basis.

18 I'll go on and talk about the regulatory
19 information -- implementation of the technical
20 specification change. Because I think you had a
21 question on that. And I can -- we can talk about
22 that.

23 This is what the emergency core cooling
24 system tech spec looks like. The containment spray
25 system is very similar to this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And this is in addition to the already --
2 the existing action statements that we already have.
3 But we have a statement for -- with less than the
4 required flow paths operable solely do the potential
5 effects of LOCA generated and transported debris that
6 exceeds analyzed amounts perform the following, and
7 that's to implement action to -- action for a --
8 compensatory actions.

9 And then has a 90-day action statement on
10 that. You'll notice that there are a couple of things
11 that are important here. One is this only applies --
12 it can only be applied for effects of debris.

13 If it's something else that's broke with
14 that strainer or that emergency core cooling system or
15 containment spray system, you have to apply the other
16 tech spec actions.

17 MEMBER MARCH-LEUBA: But does the tech
18 spec tell you how to evaluate this?

19 MR. HARRISON: The basis will. And we --
20 no. This tells you what the requirements are. And we
21 don't -- but we get additional guidance to the
22 operators in the basis for the technical
23 specifications, where we will explain what we mean by
24 debris effects.

25 So they will, for instance, say well I've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 got a tarp over the strainer. Is that a debris
2 effect? Well no. a tarp over the strainer is
3 something worse than the debris effect. Okay?

4 But if it's something out there in the
5 containment that's covered by Wes' analysis, well
6 that's debris. And you can go assess that in
7 accordance with the analysis.

8 Now, we do this in accordance with our
9 corrective action program in how we address degraded,
10 non-conforming conditions. Nothing's really changed
11 in that program.

12 There's a guidance in that that we are
13 currently applying for debris. And this will actually
14 -- so the operators you see -- and it's in that
15 procedure and it's also in another procedure that says
16 the kind of debris and the quantities of debris that
17 they're -- that they have when they do those walk
18 downs Mike's talking about.

19 Well, they're doing this in accordance
20 with a walk down procedure. And there's guidance in
21 that procedure on the amounts of debris that you can
22 have.

23 As part of our implementation of this, Wes
24 is going to go in and polish those. Or update those
25 debris instructions. I think he's probably going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 make it simpler.

2 So the process that we've always been
3 using is essentially the same process we're going to
4 use. If they find something, they're going to make an
5 immediate operability determination and a prompt
6 operability determination necessary in accordance with
7 that procedure.

8 Engineering will get involved in the
9 evaluation, is that in conformance with our -- what we
10 did in this evaluation. And make a determination is
11 there too much debris or is it okay?

12 And there's margin in the calculations
13 that Wes has. And there can be some room for
14 evaluations. No -- really no different from any other
15 engineering assisted operability determination.

16 MEMBER KIRCHNER: Pragmatically though,
17 you wouldn't have this kind of occurrence except after
18 you've gone to shut down and refueling and
19 maintenance, right?

20 MR. HARRISON: That would be --

21 MEMBER KIRCHNER: Or are there other -- I
22 mean, where I'm going with this question is, during
23 the normal operation of the plant, when the
24 containment's buttoned up, what's going to change the
25 status?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HARRISON: Probably the only way you
2 would have that occurring, and Wes can chime in, is
3 that if something comes out and you say, oh, my gosh,
4 I found a calculation that we didn't account for this
5 debris. Or we found this piece of thing that came in
6 here that has this insulation on it or this other
7 debris source that we didn't -- it was a calculational
8 error that we --

9 MEMBER KIRCHNER: That would be in the
10 engineering department, not in the operation of the
11 plant.

12 MR. HARRISON: Yes. That's right.

13 MEMBER SKILLMAN: Yes. That's where I was
14 going when I introduced this topic an hour or two
15 hours ago.

16 Mike described the close out, the cleanup,
17 and I presume, you secure the door. You lock the
18 containment.

19 MR. MURRAY: So this is Mike Murray.
20 There's one thing I thought about that I didn't add.
21 Is once we get the containment closed out, there's
22 also a procedure for every entry into containment
23 after it's closed.

24 I think that may close the gap there. And
25 in that procedure, you have to account for what you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 take in. You have to account for what you bring out.

2 And you also have to keep your -- one of
3 the requirements is you look for other things that
4 someone else may have missed.

5 And that is a briefing that happens with
6 every entry team after we've established containment
7 integrity. Which was the surveillance when we signed
8 it off. And operations accepts that surveillance.

9 Containment integrity is then set. The
10 door interlocks are in. And then you go into the
11 process of every entry team has to be accountable for
12 what's taken in and brought out.

13 MEMBER SKILLMAN: Here's what prompted my
14 question. Presuming that we're on watch. All of us
15 have gone one. Let's go to nuclear one.

16 It's three o'clock in the morning on a 24-
17 month fuel cycle. We're out four hundred days. We're
18 doing great.

19 And at three o'clock in the morning one of
20 us says, you know, I forgot. I think we're inoperable
21 because there's something down there that just struck
22 me would render that one strainer inoperable.

23 What do you do? And the way this
24 surveillance is written or the way this tech spec is
25 written, potential effects of debris generated and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 transported.

2 And it just seems to me that that is --
3 first of all, I understand the words. But it's
4 certainly vague for a practical operator.

5 You're sitting there on -- at power. And
6 you're saying, I think something's wrong down on that
7 strainer.

8 But if you're like most PWRs, you do not
9 do in power containment entries.

10 MR. HARRISON: We do.

11 MEMBER SKILLMAN: Do you do it often?

12 MR. HARRISON: Absolutely.

13 MEMBER SKILLMAN: Yes? You don't go into
14 the primary shield.

15 MR. HARRISON: No.

16 MEMBER SKILLMAN: Okay. So you're on the
17 operating flat or you're in a shielded area. But this
18 probably not something that's done a lot.

19 MR. HARRISON: No. And remember, you
20 know, we're -- this is something that is -- that's not
21 debris -- that's not unique to debris.

22 You know, that could be anything that is
23 -- becomes an operability question. And that's where
24 you go back to your procedures.

25 You go back to this degraded non-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conforming condition procedure. You go back to your
2 basics of the presumption of operability.

3 That it's the shift manager's call. And
4 it's based on his presumption of operability. And
5 there's a process you go by that operations will
6 drive.

7 And we have confidence in that process.
8 It's worked for us for a long time. You know, a very
9 -- depending upon the level of assurance that shift
10 manager has with what he believes is in that
11 containment, he may say well, I'm going to enter this
12 action statement.

13 And then they can go do a confirmation.
14 They determine that it's okay. They can exit the
15 action statement.

16 MEMBER SKILLMAN: That's fair enough. I
17 understand what you're saying. And I understand the
18 authority risks with the shift manager to make the
19 call.

20 And I understand you can also go too
21 operably degraded and continue to operate. So, I
22 really do understand that.

23 I was just intrigued at what could be the
24 interpretational vagueness of this wording.

25 MR. HARRISON: And we -- and I'm glad you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 brought that up. Because we will get -- we hadn't got
2 -- we will train operations on this.

3 And we will sit with them in their
4 classroom, here's this new tech spec change. And they
5 reviewed this by the way, also. So this shouldn't be
6 news to them. They were part of the review.

7 But there will be questions from the
8 various shift managers and license operators. And we
9 will respond to those questions. It might result in
10 some additional clarification in the basis.

11 MEMBER SKILLMAN: Yes. Okay. Okay.
12 Thank you. That's fine.

13 MR. MURRAY: We've answered those questions
14 I think that they're -- are you all ready -- are you
15 ready to move on?

16 MR. HARRISON: The only thing that I was
17 going to add to this was with -- I think there was
18 some question with compensatory actions.

19 And those are the -- our typical risk
20 management compensatory actions that might mean we'll
21 -- if we know what the debris is, we can remove the
22 debris or take action that would prevent transport of
23 the debris.

24 We can defer maintenance that would affect
25 availability of effective mitigation systems. We can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 increase the frequency of leak detection monitoring
2 and brief operators.

3 There are a number of risk management
4 actions that we can take as compensatory actions. And
5 the 90 days is based on the very low likelihood of a
6 break that would challenge our -- or exceed our tested
7 amount.

8 And that also gives additional time if we
9 do find that to have -- if, you know, we need
10 additional regulatory relief from the Nuclear
11 Regulatory Commission, we would have additional time
12 to do that.

13 But it's analogous to what was done
14 previously with the containment -- I mean, the control
15 room cleanup system.

16 So, with that, I'm done and ready to turn
17 it over to Mike.

18 MR. MURRAY: All right. Change the slide,
19 please. Next. Mike Murray. I'd like to do the
20 conclusion statement on it.

21 From -- the RoverD process incorporates
22 all aspects of the debris. It allows closure of the
23 generic letter of 2004-02. It has deterministic
24 testing, debris generation and transport, core effects
25 and risk informed evaluation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 All being said, we have confidence that
2 we've established through our extensive analysis,
3 debris transport modeling, testing and risk analysis,
4 that the change in risk is a result of the LOCA
5 generated debris meets the risk acceptance guidelines
6 established in REG Guide 1.174.

7 VICE CHAIRMAN CORRADINI: Okay. Questions
8 by the members? Otherwise, we're scheduled for a
9 break. So they can change out, staff will come up.
10 Questions?

11 (No response)

12 VICE CHAIRMAN CORRADINI: Okay. We'll
13 take a break. Come back here at 10:30.

14 (Whereupon, the above-entitled matter went
15 off the record at 10:18 a.m. and resumed at 10:30
16 a.m.)

17 VICE-CHAIRMAN CORRADINI: Okay, let's get
18 back in session, and staff will begin. Lisa, I guess
19 you're up.

20 MS. REGNER: Yes, sir.

21 VICE-CHAIRMAN CORRADINI: Green light.
22 Yeah, you're fine.

23 MS. REGNER: At this point, the staff will
24 go into more details. The safety evaluation, starting
25 with Key Principle One of the five Key Principles of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Risk-Informed Regulation. The proposed change meets
2 current regulations, unless it is explicitly related
3 to a requested exemption or rule change.

4 The proposed change does not meet current
5 regulations, since the NRC has interpreted the
6 regulations in 50.46 as requiring a deterministic
7 approach to show compliance. In 2012, the staff
8 proposed a change to 50.46 to allow licensees to use
9 risk without meeting an exemption from the use of the
10 deterministic approach.

11 The rule change would allow licensees, on
12 a case-by-case basis, to use risk information, risk-
13 informed-alternatives to assess the impact of debris.
14 In March 2016, the staff submitted the final rule and
15 is awaiting commission vote.

16 In the meantime, since the rule-making has
17 not been promulgated, STP requested four exemptions,
18 which Wayne talked about. So I don't intend to go
19 into those again, unless you have questions.

20 MEMBER MARCH-LEUBA: I do. It may be a
21 novice question, and you may be the wrong person to
22 ask. But why is this a change? The reactor hasn't
23 changed. You haven't done anything but re-analyze an
24 erroneous analysis that you did before.

25 MS. REGNER: That is true. However,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 again, ECC -- your question is, Nothing is changed,
2 why do we need --

3 MEMBER MARCH-LEUBA: The reactor yesterday
4 was just as good as the reactor tomorrow.

5 MS. REGNER: Correct.

6 MEMBER MARCH-LEUBA: Exactly the same
7 reactor.

8 MS. REGNER: Correct.

9 MEMBER MARCH-LEUBA: Nothing has changed.

10 MS. REGNER: Correct.

11 MEMBER MARCH-LEUBA: Only we found out
12 there was a bad calculation on the record, and they're
13 redoing it.

14 MS. REGNER: Correct.

15 MEMBER MARCH-LEUBA: So maybe, as I said,
16 maybe it is a logic question. I would consider a
17 change if I want to replace my insulation, I want to
18 put in new insulation. Then it's a change. But they
19 didn't change anything.

20 MS. REGNER: Right. It was a series of
21 accidents, both here and abroad, that brought the --

22 MEMBER MARCH-LEUBA: Could this have been
23 handled through a Part 21, for example? I mean, I
24 have an analysis on the record.

25 MS. REGNER: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: Which I now know to
2 be incorrect. And I'm fixing it.

3 MS. REGNER: Right, right. There are
4 alternative ways. However, this, and I don't know as
5 much history as Steve does. But from a regulatory
6 standpoint, there usually are alternative ways to
7 handle things. In this case, since ECCS is such a
8 safety significant part of our design bases --

9 MEMBER MARCH-LEUBA: I'm not in any way
10 insinuating that we're wasting our time.

11 MS. REGNER: Right, right. No, no, no,
12 understood.

13 MEMBER MARCH-LEUBA: Absolutely, we need
14 to do it.

15 MS. REGNER: You are right, and
16 ultimately, people keep asking me what's changed,
17 what's changed. Nothing has changed but the
18 paperwork.

19 MEMBER MARCH-LEUBA: The analysis of
20 record has found something incorrect, and we are
21 fixing it.

22 MS. REGNER: Right, right. Now, there has
23 been a lot of work in terms of replacing the strainers
24 and in terms of replacing insulation. The licensees
25 have taken, as I said, a lot of effort. However, this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 exercise right here that we're talking about today is
2 ultimately a paperwork exercise. A really, really
3 expensive paperwork exercise.

4 Yeah. And when I was doing the
5 environmental assessment, there are no design -- it
6 was a hard concept to get across. Why are you doing
7 an environmental assessment for no changes to the
8 plant?

9 So it didn't need to be done. The
10 environmental assessment did not need to be done. But
11 we did it because this is a significant departure from
12 the way we've done business before for compliance with
13 50.46. Does that help?

14 MEMBER MARCH-LEUBA: Yeah, as I say, this
15 is probably a question for the lawyers more than for
16 you.

17 MS. REGNER: Oh. Do we have any lawyers
18 here?

19 MEMBER MARCH-LEUBA: No, no, we don't want
20 them.

21 MS. REGNER: No, we don't, but. So I
22 won't go into the exemptions any more, unless there
23 are questions. And again, but I will say that if the
24 staff grants these exemptions, the only departure is
25 for STP to use the risk-informed methodology to show

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 compliance considering the impacts of debris.

2 At this point, I'd like to introduce Mr.
3 Steve Smith to talk about Key Principles Two and
4 Three.

5 MR. SMITH: All right, next slide. All
6 right, for the deterministic part of the review, we
7 concentrated on the colored slides on the right. Two
8 and three is defense in-depth and safety margins. And
9 we also have to input to the risk evaluation, so
10 that's block four.

11 I'm not going to take too much time, I
12 don't want to repeat things that have already been
13 said. I'm just going to kind of go over the major
14 differences between how STP did things and how things
15 were done in the past, because that might be of
16 interest. And if you have any questions, please ask.
17 Next one.

18 This slide we've seen, and this just shows
19 where the deterministic review went into the test. It
20 went into how the debris amounts are calculated, and
21 then we determine if the scenario is acceptable or
22 not.

23 The next slide, safety margins and
24 defense-in-depth is the staff's evaluation of that is
25 detailed in the SE. And we had input from a lot of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 branches on the safety margin and defense-in-depth,
2 and we appreciated that help.

3 I'm not going to talk about this in
4 detail, but if there's any questions about safety
5 margins or defense-in-depth, I can try to answer
6 those. All right, next slide.

7 This talks about the debris source term.
8 And the way that STP calculated the debris source term
9 was in accordance with staff guidance, and it's
10 conservative guidance. First, they performed a test
11 with a known amount of debris under which the strainer
12 performance was acceptable. And they talked about
13 that.

14 Then they performed evaluations for
15 thousands of break scenarios and compared the amount
16 of debris from those scenarios with that which was
17 tested. And if any scenarios ended up with more
18 debris, then that was tested. Then that scenario was
19 assumed to go to core damage and had an impact on
20 risk.

21 The way typical evaluations for this are
22 done, for example, like the option 1 plans or the
23 options 2A plans, they would go and they would
24 identify two or three breaks that were the most likely
25 ones to create the largest amount of debris, or the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 most problematic combination of debris, and they would
2 put all that debris in a test and show that the test
3 was acceptable.

4 So in STP's case, they couldn't show that.
5 So then they had to, anything that was more than what
6 was acceptable was considered to be core damage.

7 The way we've talked about this, and they
8 did calculate those amounts of debris using the CASA
9 Grande code, which automated it, made it so that it
10 could be done in a reasonable amount of time.
11 Otherwise, we'd probably still be cranking out
12 calculations.

13 VICE-CHAIRMAN CORRADINI: So just to stop
14 you. You said something that I've been trying to
15 understand. So the difference between and 2A and 2B
16 for strainers is strictly the comprehensive nature of
17 the analysis that STP used, versus picking what are
18 obviously bounding break sizes at particular locations
19 in containment.

20 MR. SMITH: Right.

21 VICE-CHAIRMAN CORRADINI: That's really
22 the difference between 2A and 2B.

23 MR. SMITH: 2A plants, every break would
24 be deterministically okay.

25 VICE-CHAIRMAN CORRADINI: Fine.

1 MR. SMITH: 2B plants, some breaks might
2 not be deterministically okay.

3 VICE-CHAIRMAN CORRADINI: All right, thank
4 you.

5 MEMBER RICCARDELLA: But isn't what South
6 Texas is doing is some combination of 2A and 2B, in
7 effect?

8 MR. SMITH: Yeah, we lump them in the 2B
9 category. If the plant had one scenario that was not
10 deterministically acceptable, we would lump them in
11 the 2B category, yeah.

12 The other thing we talked about a little
13 bit was for partial breaks, they chose the break
14 orientation that created the largest amount of debris,
15 sort of. Anyway, they chose the orientation that
16 produced the smallest break, which is the most likely
17 break to occur.

18 So that cranked their risk values up, you
19 know, higher than they normally would be. So we
20 thought that was a good margin that they had there.

21 And then the last thing I'll say about
22 this slide is that we had some good help from
23 Southwest Research. They independently verified the
24 calculations, they exercised the CASA Grande software
25 to make sure it was working properly, and gave us a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 lot of confidence in our evaluation.

2 This slide 19 is about debris transport.
3 I'm not going to talk about the strainer debris
4 transport. That was all done with CASA Grande. The
5 debris transport for in-vessel effects was done
6 separately from CASA Grande. So what they did was
7 they tested how much debris could get through the
8 strainer under various conditions.

9 They chose a conservative value from those
10 tests. And then what they did was they took the
11 amount that could get through the strainer, and then
12 they calculated where that might go. How much is
13 going to go to the vessel, how much is going to go out
14 the break, how much is going to go to the containment
15 spray.

16 And what they found was that in general,
17 the fewer pumps that were running would have more
18 fiber reach the core for a cold leg break. Because
19 the lower the flow, the more of that flow has to go
20 into the core, so the more debris is going to go into
21 the core. If you have a lot of pumps running, there's
22 a lot more flow going out the break.

23 And what they found was that as far as
24 debris amounts, is that under design basis cases, the
25 debris amount is very low. And then if you start

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 getting into some other cases, they did one case where
2 they had only HHSI, high head safety injection, pump
3 running.

4 And that increased it a little bit, but it
5 still was much lower than the values that we found
6 acceptable when we did some evaluation for WCAP-16793.
7 And again, Southwest did independent calculations to
8 verify that they had calculated these transport
9 amounts correctly.

10 Okay, then we talked about the impact of
11 debris in the strainer. One thing I did want to say,
12 I thought maybe during the discussion with South Texas
13 there was a little bit of, I don't know if it was well
14 understood how much of the debris that's generated
15 actually gets to the strainer.

16 So it's actually about, of all the debris
17 that's generated or even knocked off in whole pieces,
18 about 20-30% of that debris is going to be fine debris
19 that's going to get to the strainer. And that
20 accounts for the amount of debris that's generated as
21 fine. And then when it gets in the pool, some of that
22 is considered to be eroded.

23 Now, in the very first phase, the amount
24 of debris that got to the strainer was way higher.
25 Because we said 40% would be generated as what we call

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 small fines. And that had to be treated as fine.

2 And then 90% of whatever was left would
3 erode. So almost all of it got to the strainer. But
4 there's been testing done since then that gives us
5 more realistic values.

6 So as far as impact of debris on the
7 strainer, what they did was, when they did their test,
8 they came up with a head loss for the amount of
9 debris.

10 They put all the debris and all the
11 chemicals on, and then they evaluated various aspects
12 of the strainer or the pumps, net positive suction
13 head, structural vortexing, and also flashing. And
14 they found that at load, the strainer would pass when
15 you considered staff guidance and you did things in
16 accordance with staff guidance.

17 ACRS had previously questioned that South
18 Texas had done a test before this with a lot more
19 debris in it. And ACRS had questioned why the head
20 loss was so much higher than the second test. And it
21 was basically just the amount of fiber that was in the
22 test.

23 And if we look at the next slide, we can
24 see in the circle, I tried to fix this up since the
25 last meeting, in the circle are all the breaks that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fail, all the weld locations that produce debris
2 amounts great enough to cause the strainer to have too
3 much debris on it, okay.

4 And the one, most of them are, the ones
5 that are about 400 pounds of fiber fines, are all loop
6 piping breaks. So big breaks. And these are all
7 double-ended breaks, these are not the single end
8 breaks, because the whole chart would be filled up and
9 we wouldn't be able to see anything.

10 The one small, the one break that's just
11 above the 200 line, that's the pressurizer surge line
12 break. And that's the only non-loop piping break that
13 can cause an excessive amount of debris on the
14 strainer. And all the other breaks below the 200
15 pound line are, those all would result in a
16 deterministic success.

17 Now, the arrow up on the upper left side
18 --

19 VICE-CHAIRMAN CORRADINI: Just for some of
20 the members, so that's literally near the, that is the
21 threshold limit that was --

22 MR. SMITH: About 200, it's just below
23 200 is the threshold limit. And then, and that's what
24 the test, that's what the 2008 test was done with,
25 just below 200 -- 191, 192 pounds. If you see the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 arrow up on the left, that's what the original test --
2 so it had about almost four times as much fiber in it.
3 And that's why that first test was unsuccessful.
4 Yeah.

5 Okay, and then we want to talk about the
6 impact of debris on the in-vessel. And this is only
7 talking about the cold leg break. We'll get into the
8 hot leg break in a minute.

9 But for the cold leg break, the amount of
10 debris reaching the core at STP is much lower than the
11 amounts that we found to be acceptable when we did a
12 review on WACP-16793.

13 That WCAP did not evaluate the potential
14 need for changes in boric acid precipitation
15 calculations due to debris effect.

16 And the problem that could occur when you
17 have debris in the core, at the inlet of the core,
18 most plants credit both the core water volume and the
19 volume below the core inlet, like it's called the
20 lower plenum in the PWR, as a mixing volume for,
21 basically to reduce the concentration of the boric
22 acid.

23 So if you have debris at the core inlet,
24 it could split those two volumes up. You might get a
25 very high concentration in the core and a low

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 concentration in the lower plenum. So that's a
2 concern.

3 The staff doesn't have any kind of
4 information on what kind of debris amount would
5 actually cause that segregation between the lower
6 plenum and the core. We think the amounts of debris
7 that South Texas has would not cause that issue.

8 We're still searching for a good answer
9 for boric acid. And the Option One plants are going
10 to have to address this in the future as well.

11 So basically, what we're saying is that
12 we're not going to say that it's bad, but we're not
13 going to say that it's good. And we're going to
14 expect STP to come back and evaluate boric acid
15 precipitation with the effects of debris at some later
16 time.

17 The Option One plants are also going to
18 have to come back and do that. And we think the
19 answer to that will be in WCAP-17788. We're not sure,
20 but we're still looking at that.

21 VICE-CHAIRMAN CORRADINI: So I guess I
22 didn't catch that in the, what you just said, I didn't
23 catch in the subcommittee meeting.

24 MR. SMITH: Okay.

25 VICE-CHAIRMAN CORRADINI: Maybe I missed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it. So how is this going to be resolved, or is the
2 resolution to be determined?

3 MR. SMITH: The resolution is to be
4 determined. We think that WCAP-17788, which is the
5 new in-vessel for the two alpha plants, which is under
6 staff review at this time, addresses it.

7 We haven't said it, we haven't come to the
8 point where we're agreeing with what the PWR Owners
9 Group is saying yet. You know, we have some RAIs on
10 it. So we have to see how those RAIs are responded to
11 before we can write an SE on it.

12 MEMBER POWERS: The boric acid
13 precipitation issue is supersaturation in boric acid,
14 or is it chemical reaction with all the junk?

15 MR. SMITH: Supersaturation.

16 MEMBER POWERS: And you don't worry about
17 precipitation by precipitating Loctite and things like
18 that.

19 MR. SMITH: The other chemical effects are
20 evaluated separately. We haven't attempted to try to
21 combine the two phenomena and, you know, evaluate them
22 together.

23 MEMBER POWERS: And the reason for not
24 combining the two effects?

25 MR. SMITH: The reason to have to do it?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 UNIDENTIFIED SPEAKER: The reason you're
2 not doing it, I think he's asking.

3 MR. SMITH: Well, I have Paul Klein here
4 from the audience to hopefully jump it.

5 MR. KLEIN: Paul Klein from NRR. The
6 reason we're not concerned boric acid precipitation is
7 designed not to happen. So the hot log switchover
8 time is designed to flush the core out before we get
9 to the point where the boric acid reaches the point
10 where it will precipitate.

11 MEMBER POWERS: Yeah, but I think what I'm
12 asking is you're now going to sweep in to your sump
13 liquid a lot of goethite and a variety of other stuff,
14 a little calcium, magnesium. Other things that just
15 love to glomp onto a borate ion and drop out of
16 solution in a nice flocculate precipitate that's nice
17 and soft and pushes through any hole that it can. Why
18 wouldn't you recognize that?

19 MR. KLEIN: I think I maybe I
20 misunderstood your question, Dr. Powers. I was
21 talking about global boric acid precipitation in a
22 cold leg break scenario, where you concentrate it over
23 a period of time until you reach a point where it
24 begins to precipitate.

25 I think, if I understand you correctly,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you're more considering local effects, perhaps
2 deposits on fuel rods of borates and other species
3 that are dissolved in solution?

4 MEMBER POWERS: I mean, you can expect
5 this stuff in, you're going to have certain, I mean,
6 you put a lot of junk down into the sump. Now you're
7 into recirc mode, you're putting a lot of junk into
8 your core along with boric acid.

9 Zinc just loves to precipitate out of zinc
10 borate. Iron loves to precipitate out of ferric
11 borate. Calcium likes to drop out of calcium borate.
12 Why wouldn't you recognize that?

13 MR. KLEIN: That is considered as part of
14 the analysis of the LOCA DM part of WCAP-16793.

15 VICE-CHAIRMAN CORRADINI: So that is being
16 considered now.

17 MR. KLEIN: It is considered as part of
18 the --

19 VICE-CHAIRMAN CORRADINI: That's part of
20 the LOCA DM calculation?

21 MR. KLEIN: LOCA DM, yes.

22 VICE-CHAIRMAN CORRADINI: Okay.

23 MEMBER POWERS: Thanks, Paul.

24 MR. SMITH: Let's see, did I finish this
25 one? Yep, I think I did get to the bottom. So I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 think we're now going to move on to the thermal
2 hydraulic part of the presentation.

3 MS. REGNER: Dr. Kaizer, are you able to
4 hear us? Josh Kaizer? Dr. Josh Kaizer's supposed to
5 be on the phone --

6 VICE-CHAIRMAN CORRADINI: Let's make sure,
7 yeah, I hear it start crackling. Something's going to
8 happen. Josh, are you out there?

9 MR. KAIZER: I am. Can you hear me?

10 VICE-CHAIRMAN CORRADINI: We can now.

11 MS. REGNER: Thanks, Josh.

12 MR. KAIZER: Excellent.

13 MR. SMITH: Okay, so Josh isn't here.
14 He's at ASME's main V&V conference, making a
15 presentation. And one of the V stands for Vegas,
16 because it's in Vegas. I don't know what the other V
17 stands for.

18 VICE-CHAIRMAN CORRADINI: Verification.
19 Are you really in Vegas?

20 MR. KAIZER: I am.

21 MR. SMITH: And the other reviewer, Reed
22 Anzalone, he isn't here today because he's home taking
23 care of a newborn baby. So therefore, I get to
24 present these slides.

25 VICE-CHAIRMAN CORRADINI: But we can call

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 upon them as needed.

2 MR. SMITH: Yes, we can call on Josh.
3 Let's go to the next one. Okay, the goal of the
4 thermal hydraulic evaluation was to determine whether
5 the LTCC, long-term core cooling, model used by South
6 Texas was acceptable.

7 When they started doing the evaluation,
8 they determined that large breaks, greater than 16
9 inches, were too complex to evaluate, and they were
10 not evaluate with the evaluation model, the RELAP5.

11 So the evaluation only focused on the
12 long-term portion of the event, which requires the
13 evaluation of fewer phenomena. And then the phenomena
14 that are evaluated are a lot less complex than the
15 typical LOCA evaluations. So this reduced the
16 complexity of the evaluation and made the review much
17 more reasonable.

18 And then the next slide shows what portion
19 of the in-vessel evaluation was done by the long-term
20 core cooling evaluation model. And that small and
21 medium, medium is less than 16-inch, I know that's not
22 a typical medium, but that's what we called for the
23 long-term core cooling evaluation model, that's what
24 where that evaluation model came in.

25 The big, greater than 16-inch, hot leg

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 breaks were risk-informed, that means they were
2 assumed to go to core damage, just so that they didn't
3 have to do a RELAP5 evaluation of those. And the cold
4 leg evaluations were all done by RoverD by comparing
5 with WCAP-16793.

6 One thing I think I heard perhaps during
7 the STP discussion was it was asked if all the greater
8 than 16-inch breaks already went to failures due to
9 debris effects. And they do not.

10 There are some hot leg 16-inch breaks that
11 do not result in a debris failure. So they added a
12 few breaks, I think maybe five for the two train case,
13 to the core damage bin. I don't know if that was
14 clear during the earlier discussion.

15 VICE-CHAIRMAN CORRADINI: Well, actually,
16 I said it, and I probably said it wrong. So what I
17 thought was occurring was that when I'm larger than 16
18 inches, I would have already covered that failure from
19 the strainer failures. That's what I thought I was
20 trying to say, but that didn't --

21 MR. SMITH: But you don't. That's
22 incorrect. There's a few greater than 16 inch hot leg
23 breaks that don't generate enough debris to cause the
24 strainer to be considered to go to core damage. So it
25 added a few large breaks to the risk.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 VICE-CHAIRMAN CORRADINI: Okay, then,
2 actually, I'm going to, don't move your slides, but I
3 want to take a step back. Because you guys did a
4 bounding analysis, which I think properly, in notes to
5 myself and how I'm trying to inform the members. But
6 in the staff's bounding analysis, you took some
7 number, I think 12 point whatever.

8 MR. SMITH: Twelve point eight.

9 VICE-CHAIRMAN CORRADINI: For the two
10 train and operations. And anything above that, you
11 said, Let there be a failure.

12 MR. SMITH: That's right.

13 VICE-CHAIRMAN CORRADINI: And that's your
14 bounding analysis.

15 MR. SMITH: Correct.

16 VICE-CHAIRMAN CORRADINI: Okay, and that
17 delta CDF and delta LERF was all, of course, higher
18 but still -- so do I have that correct?

19 MR. SMITH: Yes, you do.

20 VICE-CHAIRMAN CORRADINI: Okay.

21 MR. SMITH: So that analysis would have
22 accounted for all those breaks, all the breaks that
23 we're talking about. And then the other part of this
24 slide is that the review concentrated on the criteria
25 which came from WCAP-16793, for a maximum PCT and a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 deposit thickness.

2 VICE-CHAIRMAN CORRADINI: All right, look
3 what I wrote.

4 MR. SMITH: And the next slide, this is
5 just a summary of the conservatisms and
6 simplifications that were used in the evaluation
7 model. For the first one, the full core blockage,
8 it's unlikely that it would occur, especially at the
9 early time of five minutes. Very unlikely that it
10 would occur at that time, or that it would be full
11 core blockage.

12 The other thing is that the flow through
13 the barrel baffle region was ignored. That would have
14 allowed more coolant into the core. Other than, what
15 was assumed was it just spilled over the steam
16 generator tubes. There's other paths that the coolant
17 could take that were just assumed not to be available.

18 VICE-CHAIRMAN CORRADINI: And just to ask
19 there, because I think you guys made a point of this.
20 It's just too hard to evaluate what the flow was. So
21 because it didn't affect the end result, it
22 conservatively was ignored. But for sure, there'll be
23 some flow through the first two, the second and third
24 bullet. Correct?

25 MR. SMITH: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 VICE-CHAIRMAN CORRADINI: It's just too
2 hard to know what it is?

3 MR. SMITH: And actually, looking into the
4 future, 17788 is trying to quantify some of those
5 flows through the barrel baffle region to credit them.

6 VICE-CHAIRMAN CORRADINI: Okay, fine.
7 Thank you.

8 MR. SMITH: So that's a later topic I'm
9 we'll be back talking about.

10 MEMBER MARCH-LEUBA: What I think you have
11 told us is not hard to get an estimate of what those
12 numbers are, it's how to validate that estimate. And
13 that would have been a very large effort to validate.

14 MR. SMITH: Yes. And the flow, the
15 trouble is that the flow -- those are relatively, I'm
16 not going to say high resistance, but higher
17 resistance flow passed through the barrel baffle.

18 So the flow actually doesn't, it's complex
19 because the flow doesn't actually start going through
20 those until you start getting debris built up at the
21 core inlet. So it's a, you know, it's a dynamic
22 problem.

23 VICE-CHAIRMAN CORRADINI: Okay, thank you.

24 MR. SMITH: They biased the key input
25 parameter conservatively, and they also used a counter

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 current flow model. It was a conservative model, it
2 was implemented conservatively to reduce the flow
3 through the core. So the implementation maximized the
4 effects of the counter current flow, which would tend
5 to reduce the flow through the core.

6 And the bottom line is this ended up in a
7 simplified hot leg break simulation, which the staff
8 was able to review and find to be acceptable. Is
9 there any questions on the thermal hydraulics? Josh,
10 I think you're off the hook.

11 Now I'm going to turn it over to CJ for
12 the risk portion of the presentation.

13 MR. FONG: Thanks, Steve. My name's CJ
14 Fong, I'm a team leader for risk-informed licensing at
15 NRR.

16 Candace De Messieres, who you heard it
17 from at the subcommittee meeting, couldn't be here
18 today, but I did want to take a moment and thank her
19 on the record. She was instrumental in producing not
20 just these slides, but also the safety evaluation.
21 So, certainly appreciate her help. Next slide,
22 please.

23 As you heard mentioned earlier today,
24 this was a very integrated review. So I'm going to
25 talk about Principles Four and Five, which talk about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 risk and long-term performance monitoring. But of
2 course, a lot of topics Steve just mentioned really
3 fed into how we calculated that risk.

4 And then on topic five, or Principle Five
5 rather, what we wanted to monitor and what portions of
6 the licensee's analysis, that was really a team
7 decision. So, again, these are presented as kind of
8 five individual or independent principles, but in this
9 review, the concept was that we did a very integrated,
10 team-focused approach. Next slide, please.

11 So a little background. This is sometimes
12 affectionately referred to as the most famous figure
13 in risk, figure 4 from Reg. Guide 1.174. What we did
14 here was we wanted to rely on the existing framework
15 for risk-informed changes to a plant's licensing
16 basis. So you see this stair step figure here, this
17 defines how much of an increase in risk is acceptable
18 to the staff.

19 And so for a GSI 191 evaluation, we look
20 at the delta CDF, which is the CDF from the as-built
21 as-operated plant, as realistically as possible with
22 all the debris that's there, minus the CDF from a
23 plant, a hypothetical clean plant, where debris would
24 not present a challenge.

25 And of course, there's a corresponding

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 figure for LERF. I didn't show it here, but the risk
2 thresholds are a factor of ten lower. Next slide,
3 please.

4 So the major areas reviewed by the staff,
5 again, kind of a recap. We looked both at the
6 increase in risk with a delta CDF, and also the
7 plant's baseline risk, in order to do a comparison
8 with our acceptance guidelines. And so very
9 comprehensive review.

10 We looked at the initiating event
11 frequencies; what plant configurations were in place,
12 in other words, the pump combinations; how the
13 licensee identified the breaks to be evaluated;
14 scenarios; what hazard groups were in play. A whole
15 litany of things here.

16 I have highlighted two in red that we're
17 going to talk about in a little more detail on future
18 slides. And we also looked at the licensee's base
19 PRA, and of course we leveraged Reg. Guide 1.200, and
20 the results of previous looks at South Texas's PRA.

21 And so for the most part, the base PRA
22 evaluation the staff did was to verify the CDF results
23 and LERF results presented by the licensee, i.e., the
24 X-axis.

25 Although I'll point out that some portions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the base model were used, both in identifying which
2 sequences to look at it and also the percentage of
3 time that the licensees was in, for example, a two
4 train operation versus one train. So that base model
5 did feed into the delta CDF calc a little bit. So
6 maybe I should have had a dash there or going up
7 there, but kept it clean.

8 And then, of course, we took a long, hard
9 look at the delta CDF and delta LERF. And to do that,
10 all the bulleted items that you see here were
11 evaluated by the staff.

12 MEMBER STETKAR: In fairness, CJ, it did
13 affect the conditional probability of being in a
14 single train configuration versus not a single train
15 configuration. But it also affected something that
16 Dr. Corradini brought up before the fact, the
17 likelihood that those containment fan coolers are
18 running.

19 MR. FONG: Sure.

20 MEMBER STETKAR: Which substantially
21 affects their delta LERF calculation.

22 MR. FONG: Yeah.

23 MEMBER STETKAR: And that came directly
24 out of your base PRA model also.

25 MR. FONG: Absolutely. So yeah, it's,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 like I said, you could argue there should be another
2 arrow there, but just trying to illustrate the
3 concept. Yup. Next slide, please.

4 So the really, the key assumptions that we
5 noticed South Texas made in order to calculate the
6 increase in risk, as was mentioned earlier, they
7 relied on NUREG 1829, LOCA frequencies. And if you
8 read NUREG 1829, there's a bunch of those. There's 25
9 year, 40 year, PWR, BWR, there's different aggregation
10 schemes. It's not kind of a one-stop shop, it's more
11 like a large menu.

12 So the staff took a long, hard look at
13 which frequencies were actually used, and we noted
14 that there's been a lot of discussion about
15 aggregating the opinions of experts in different
16 schemes, mainly geometric arithmetic.

17 And of course, we're aware of the ACRS
18 feedback on that topic, both in this case, and also
19 with 50.46(a) proposed rulemaking. So I think it was
20 important to note that the licensee presented their
21 results using both schemes, which is an approach
22 recommended by the ACRS on several occasions, and the
23 staff agreed with that.

24 Number two, you heard earlier a little bit
25 about how the licensee took plant-wide LOCA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 frequencies that are provided by NUREG 1829 and
2 allocated them onto individual locations.

3 So you'll get, for example, a value out of
4 NUREG 1829 that says, Large break low frequency at a
5 PWR is 5E minus 6. But it doesn't tell you how to
6 allocate that onto individual breaks.

7 So South Texas did that using what we call
8 the top-down approach, which assumes that the
9 likelihood of a break is a function only of its size
10 and doesn't look at location-specific factors, for
11 example, what kind of weld it is, what shape it is,
12 that sort of thing.

13 And there is some information in the
14 literature that suggests that that can make a
15 difference. And we'll talk about how that was
16 addressed in a future slide.

17 The third topic is what South Texas called
18 their continuum break assumption. And what they did
19 was, they did consider partial breaks under this
20 model. And they assumed that a break, for example, a
21 partial break of six inches, has the same likelihood
22 as a complete break of six inches.

23 Again, if you read NUREG 1829, there's
24 some kind of qualitative thoughts on that. It's
25 difficult to assign a numeric value to that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And so what South Texas also did was
2 consider an alternate assumption, which was that only
3 double-ended guillotine breaks occur, or only complete
4 breaks. And again, the staff felt that, lacking a
5 clear-cut consensus approach, exploring these two sort
6 of ends of the spectrum was a reasonable solution.
7 Next slide, please.

8 MEMBER RICCARDELLA: So they did that as
9 sort of a sensitivity study, and determined that it
10 didn't affect the result?

11 MR. FONG: Right. They did both cases.
12 It's kind of interesting, because you really can't say
13 that one's more conservative than the other. It kind
14 of depends on what scheme you are in and, you know --

15 MEMBER KIRCHNER: CJ, given what they were
16 using it for, wasn't location more important that?

17 MR. FONG: Yeah, they always look at all
18 the locations, right. For each location --

19 MEMBER KIRCHNER: Debris source term is
20 the real issue here.

21 MR. FONG: It is, yup.

22 MEMBER RICCARDELLA: But they didn't
23 consider, well, if something's a dissimilar metal weld
24 that has known susceptibility to a mechanism.

25 MR. FONG: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RICCARDELLA: They didn't treat
2 that differently than another on that doesn't have
3 that concern, right?

4 MR. FONG: Exactly. And there are other
5 approaches out there, albeit not endorsed by the NRC
6 staff, but in academic literature, for example. It'd
7 say, Hey, if it's a dissimilar metal, well, you should
8 bump it up by a factor of ten.

9 Or if it's been recently, you recently had
10 a weld overlay, you can reduce it by a factor of ten.
11 So there's some thoughts out there on how to do that,
12 but there's not a clear-cut consensus approach.

13 VICE-CHAIRMAN CORRADINI: But geometry
14 dominated, and then if I understand this -- I still
15 want to get to how they tried to do it compared to
16 your bounding calculation. Geometry dominated, they
17 came in said, If I had a double-ended at some scale,
18 12 point whatever, anything like that bigger would
19 have failed, even though geometrically, it may not
20 have produced as much debris.

21 You came in and then did a bounding on top
22 of that and said, Okay, I'm not really sure about
23 whether it's how you weight these, so anything above
24 the 12 point whatever failed. And now did that the
25 delta CDF or delta LERF enough to be concerned. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the conclusion was not.

2 MR. FONG: Right, and we'll show you
3 numerically what that looks like in a second, Dr.
4 Corradini.

5 VICE-CHAIRMAN CORRADINI: There are two
6 kind of check calculations, one by them, one by you.

7 MR. FONG: Right, and then another way to
8 look at it is we both felt that the 12.8 double-ended
9 guillotine of the pressurizer surge line would be a
10 core damage scenario under the conservative
11 assumptions analysis, etc.

12 If you start going up and looking at
13 bigger breaks, they have a number of them where they
14 said, There's no core damage here because of where
15 it's located. As a conservative assumption, we said,
16 No, anything bigger than that goes to core damage. So
17 we're kind of bounding all that with our approach.

18 VICE-CHAIRMAN CORRADINI: Okay, thank you.

19 MR. FONG: Next slide, please. So here's
20 what we did, and this has been shared with the ACRS on
21 a couple different occasions. We just assumed,
22 conservatively, that the portion of risk attributable
23 to debris, or delta CDF, is equal to the frequency of
24 the smallest what we're calling critical break size.

25 Critical break means it can produce and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 transport debris in excess of the tested amount. And
2 it's not shown here, but we looked at this under the
3 two train and single train configurations and used the
4 appropriate waiting factors.

5 The graph I'm going to show you uses the
6 arithmetic mean, but in our safety evaluation, we
7 present several other cases as well. Next slide,
8 please.

9 So what you saw at the subcommittee, we'll
10 kind of work from the bottom up, there's a range of
11 licensee-reported values. As I mentioned, they looked
12 at arithmetic mean, geometric mean, continuum break,
13 double-ended guillotine. And depending on what
14 combination of assumptions you want to look at, those
15 kind of light blue diamonds, thanks Lisa, indicate the
16 increase in CDF.

17 The bounding calculation in our safety
18 evaluation, using the method I just described, Dr.
19 Corradini, is the blue diamond here. So it does make
20 a difference, but still, substantial margin to the
21 acceptance guidelines.

22 And then, in response to some of the
23 discussion at the follow-up subcommittee, which is I
24 think on April 18 or around then, I wanted to include
25 -- we'd already performed this calculation, our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consultant had already performed it.

2 But I want to include what happens if you
3 assume that for the single train case, any break two
4 inches and up goes straight to core damage. And
5 that's the orange diamond you see there. So again,
6 there is certainly an increase, which makes sense.
7 But it's not something that challenges the acceptance
8 guidelines. Next slide, please.

9 So to summarize, we looked at the
10 licensee's base PRA and determined that it was of the
11 appropriate scope level of detail and technical
12 adequacy for this application. We looked at the
13 approach they used to quantify that portion of risk
14 attributable to debris, that was not initially in
15 their base PRA, of course.

16 And we compared the calculated risk to the
17 acceptance guidelines in Reg. Guide 1.174 under a
18 variety of different assumptions, and we performed our
19 own bounding calculation and sensitivity, and
20 confirmed that the acceptance guidelines are met.
21 Next slide, please.

22 Moving on to Principle Five, which is
23 long-term performance monitoring, so we took a look at
24 the risk assessment provided by the licensee. Of
25 course, that's kind of a snapshot.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And so the concept behind the Fifth
2 Principle in Risk-Informed Decisionmaking is you want
3 to make sure that there aren't changes to the plant
4 down the road that could erode the safety gains that
5 were made or could undermine the assumptions that went
6 into the risk calculation.

7 MEMBER STETKAR: CJ, I'm, sorry, can you
8 back? You said something that caught my attention,
9 and I want to make sure that I understand it. Can you
10 go back to that picture that you showed on, that
11 picture there. What is that orange diamond, that
12 sensitivity thing? Can you explain that again?

13 MR. FONG: Yes, that's a sensitivity
14 calculation provided by Southwest which assumes that,
15 for the two train case, 12.8 is still the threshold.
16 But for the one train case, instead of the nine inches
17 and change, it goes down to two.

18 MEMBER STETKAR: Thank you for clarifying
19 that, because when you first said it, I got the
20 impression that you assumed that any two-train break,
21 two-inch break went to core damage regardless of --

22 (Simultaneous speaking.)

23 MR. FONG: That'd be off scale high, I
24 believe.

25 MEMBER RICCARDELLA: But when you say --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: It wouldn't be off scale
2 high, it would be on the order of a couple times ten
3 to the minus five. Off this scale.

4 MR. FONG: Yeah, yeah.

5 MEMBER RICCARDELLA: But when you say goes
6 to core damage, that doesn't go to core damage with a
7 probability of one, does it?

8 MEMBER STETKAR: Yeah. That would, the
9 assumption is, that break generates enough debris that
10 you would plug the strainers, that you would not have
11 -- if you only had one train available, one set of
12 pumps running. That's all you have, the other pumps
13 all failed because they didn't have electric power or
14 they, you know.

15 MR. FONG: Out for maintenance, whatever.

16 MEMBER STETKAR: Out for maintenance or,
17 you know, whatever. If you only had one train running
18 and you had a two-inch break, that would be the core
19 damage frequency.

20 MR. FONG: Correct.

21 MEMBER STETKAR: Because you would plug
22 the strainer for that one train.

23 MEMBER MARCH-LEUBA: No, it's a
24 conditional probability of core damage where you need
25 to multiply times the frequency.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: That's right.

2 UNIDENTIFIED SPEAKER: The frequency of
3 the two-inch break.

4 MEMBER KIRCHNER: But that's the frequency
5 of the two-inch break.

6 MR. FONG: Don't forget it's kind of a
7 weighted value, right. Because the likelihood of
8 being in a configuration where only one train's
9 available is small.

10 Can we go back to the future here? Okay,
11 so performance monitoring, as I said, it's a process
12 to ensure that long-term, the assumptions made in the
13 risk analysis remain valid. So the information
14 provided by South Texas is that they're going to
15 update their analysis every 48 months.

16 The staff looked at the procedures and
17 controls they have in place to ensure that debris is
18 prevented or mitigated if it's discovered. You heard
19 about the tech spec this morning, and also the design
20 control process.

21 There's also a provision that the NRC
22 would be notified if the acceptance guidelines are
23 exceeded. And that's all spelled out in the SR,
24 again, as you heard this morning. Next slide, please.

25 So to summarize these last two principles,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we feel that, you know, just kind of in plain English,
2 the licensee provided a credible calculation for risk
3 that met the acceptance guidelines. We acknowledged
4 there were some portions of their analysis that didn't
5 use a consensus method.

6 We felt they addressed that adequately,
7 either through credible, reasonable, alternative
8 calculations, or the staff's bounding calculations and
9 sensitivity calculations.

10 And we took a look at their performance
11 monitoring approach and determined that it was
12 consistent with our guidance in Reg. Guide 1.174.
13 Next slide. That's it.

14 MS. REGNER: So this is a summary.

15 VICE-CHAIRMAN CORRADINI: Green light.
16 That's right, you're no worse than some of us.

17 MEMBER POWERS: Actually, you just provide
18 an exercise for him.

19 MS. REGNER: Just trying to make you feel
20 good, doctor.

21 VICE-CHAIRMAN CORRADINI: Thank you. I
22 need everything I can get.

23 MS. REGNER: This is a summary of some of
24 the major topics that were discussed during the
25 subcommittee and where questions were answered by the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 South Texas project. I didn't necessarily want to go
2 into them unless there are questions.

3 MEMBER STETKAR: Lisa, are those
4 supplements now on the docket with this application?

5 MS. REGNER: Both the email response is
6 publicly available on the docket.

7 MEMBER STETKAR: Okay, but the second?

8 MS. REGNER: The second was submitted
9 under oath and affirmation as a formal document, and
10 that is recognized in our SE, correct. And there --
11 right. Okay, any other questions about these topics?

12 So in summary, STP acceptably evaluated
13 the impact of debris, appropriately considered both
14 risk and deterministic aspects. Most of the break
15 scenarios are addressed using the traditional
16 deterministic methods.

17 Their long-term core cooling evaluation,
18 in this case that's the in-vessel thermal hydraulic
19 analysis, those simulations are conservative. They
20 meet the acceptance criteria. Their debris analysis
21 meets the key principles of risk-informed regulation.
22 And their probabilistic risk assessment results show
23 that the change in risk is very small.

24 What questions do you have on what the
25 staff has presented?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 VICE-CHAIRMAN CORRADINI: Thank you, Lisa.
2 Any questions from the members? They haven't been
3 shy. Okay, so no more questions from the members.
4 I'll thank the staff. And I think now we want to turn
5 and see if there's members of the public, either
6 inside the room or the phone line, and --

7 UNIDENTIFIED SPEAKER: Bridge open.

8 VICE-CHAIRMAN CORRADINI: Thank you. So
9 are the members of the public, if you could please
10 give us your comment. First identify yourself,
11 please. Going once, going twice. Okay, why don't you
12 close the line. Okay. I'll turn it back to our
13 chairman.

14 CHAIRMAN BLEY: Thank you, Mr. Corradini.
15 We will go off the record at this time until 12:45,
16 when we'll reconvene. Members, wait. Off the record.

17 (Whereupon, the above-entitled matter went
18 off the record at 11:19 a.m. and resumed at 12:44
19 a.m.)

20 CHAIRMAN BLEY: We are back in session.
21 At this point, I'll turn it over to Dr. Rempe to take
22 us through the work on our Consequential Steam
23 Generator Tube Rupture. Joy.

24 MEMBER REMPE: Colleagues, today we are
25 going to receive what I believe will be our final

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 briefing on the report Consequential Steam Generator
2 Tube Rupture Analysis for Westinghouse and Combustion
3 Engineering Plants with Thermally Treated Alloy 600
4 and 690 Steam Generator Tubes, or NUREG 2195.

5 This report documents results from a
6 multi-year and multi-disciplinary effort that the
7 staff completed to address the user need concerning
8 CSGTR phenomena. The last time we met about this
9 topic as a full committee was way back in May 2013.
10 But since that -- really.

11 Since that time, we've had several
12 meetings with the subcommittee on materials,
13 metallurgy, and reactor fuels. And during our last
14 meeting, which was December 2106, the members of the
15 subcommittee that were present agreed that this effort
16 was ready to be presented to the full committee for
17 comment.

18 And I believe today that we're going to be
19 starting by hearing from Kevin Coyne from the Office
20 of Research.

21 MR. COYNE: Okay, thank you, Dr. Rempe.
22 My name is Kevin Coyne, I'm with the Office of Nuclear
23 Regulatory Research, and am their branch chief
24 responsible for this effort since it kicked off in
25 late 2009.

1 Thank you again for the opportunity to
2 brief the full committee this afternoon. We're
3 looking forward to the briefing and any additional
4 comments we get from the committee.

5 Just to go through some very brief
6 history, I believe Raj Iyengar will go through some of
7 it in his presentation. But just to put this in
8 context, this work was initially kicked off after the
9 agency closed the Steam Generator Action Plan in
10 December of 2009.

11 The focus of this effort was to take all
12 that we learned from the Steam Generator Action Plan
13 and focus on developing a better and more integrated
14 and traceable approach for assessing the risk from
15 consequential steam generator tube rupture events.

16 Needless to say, we had several challenges
17 along the way. Most notably, we had diversion of
18 staff to address higher priority work, such as the
19 Fukushima follow-up, and we had some budget
20 challenges. So the schedule for this work became much
21 longer than we had initially assumed, and the scope of
22 the work had changed.

23 So when you look through some of the user
24 need documents, maybe some questions of how the work
25 today looks as how it was initially envisioned. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it's because we kind of dynamically re-scoped things
2 as the regulatory picture evolved over time.

3 Despite those efforts, there are several
4 advancements that we came out with through this
5 effort. We have a much better and improved
6 understanding of how to characterize steam generator
7 flaws in the steam generators based on operating
8 experience, and the ability to align that flaw
9 characterization to an actual operating plan, which is
10 a significant advancement over what we had with the
11 previous approach.

12 We have a full analysis of the combustion
13 engineering steam generator geometries to complement
14 the previous work we did on Westinghouse steam
15 generators. We have a much better integration of the
16 thermal hydraulic work, the CFD and MELCOR work that
17 underpins the PRA analysis.

18 And improved validation of the structural
19 modeling we use in our steam generator tube rupture
20 calculator that helps us calculate the probabilities.

21 So we've talked about some of this in
22 previous subcommittee meetings, and I won't go through
23 that anymore. And we'll discuss portions of that as
24 we go through the briefing today. But with that, and
25 my remarks, and turn it over to the staff. And again,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 appreciate the opportunity to brief the committee
2 today.

3 VICE-CHAIRMAN CORRADINI: Kevin, can I ask
4 a question?

5 MR. COYNE: Sure.

6 VICE-CHAIRMAN CORRADINI: Maybe I'm, I
7 want to understand. So assuming all of this is good,
8 and it seems quite good to me, where is this going to
9 be used? How is this going to be used? I'm vague on
10 that.

11 MR. COYNE: So this is one of the things
12 that was one of the big evolutions in our thinking
13 when this work started. So if we go back to 2009, we
14 had initially presumed there may be issues with the
15 combustion engineering designs, with the geometry of
16 the steam generator and how they would respond these
17 severe accident conditions.

18 However, the staff hadn't fully documented
19 the technical basis for that concern. So the thinking
20 at that time was that this work would lead to a much
21 better technical basis to support a potential
22 backfitting analysis, for CE plants or at least a
23 generic communication of stressing the need to keep
24 water on the secondary side of the steam generators to
25 prevent creep failure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So that was before the Fukushima accident.
2 As we progressed with the work in the Fukushima
3 follow-up, the Flex Initiative came through. And in
4 large part the Flex Initiative did for the steam
5 generators what we were hoping this effort would do.

6 So the regulatory purpose of this work
7 evolved from that, and so we have NRR here today to
8 speak to their regulatory view and how this would be
9 used. But right now, our focus is on developing
10 improved tools to underpin the significance
11 determination process. So some of the things we use
12 for assessing steam generator issues --

13 VICE-CHAIRMAN CORRADINI: Can you stop
14 there? Just help me, significant determination for
15 current operating plan?

16 MR. COYNE: Yes, yes, the ROP.

17 VICE-CHAIRMAN CORRADINI: Okay, okay. All
18 right, and that currently is the main point of
19 application.

20 MR. COYNE: Right. In addition to making
21 sure we fully document the staff work completed today,
22 that would be one of the potential outcomes of this
23 effort.

24 VICE-CHAIRMAN CORRADINI: Okay. The
25 reason I'm asking the question is, for example, would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it be used as part of an audit tool when the staff is
2 looking at PRAs from other plants? Like APR 1400?

3 MR. COYNE: It's a good question. It
4 could certainly inform that. And one of the initial
5 purposes, and it's still useful to support this, is
6 when we first had the user need from NRR, one of the
7 questions, in addition to reactor oversight, was the
8 evaluation of the SAMDA analysis for license renewal.

9 And so these types of scenarios come up in
10 the SAMDA analysis. And the staff lacked an
11 independent assessment tool to really look at some of
12 the consequential steam generator scenarios that were
13 coming up in the license renewal review. So part of
14 the purpose of this was to provide an updated and
15 independent evaluation of those methods.

16 MEMBER STETKAR: Okay, let me just say,
17 from my perspective, Mike, I would hope that the staff
18 would use it in that context. Because in particular,
19 for anybody under Part 52, they are supposed to do a
20 level two assessment of large release frequency.

21 VICE-CHAIRMAN CORRADINI: Right.

22 MEMBER STETKAR: As part of their PRA
23 that's audited by the staff. And if this issue was
24 not addressed at all, that could conceivably be an
25 omission from the scope of their level two analyses.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Because this isn't, you know, it's not
2 going to affect core damage frequency, but it could
3 conceivably have a measurable effect on conditional
4 large release frequency. So in terms of auditing, at
5 least, you know, a question I would ask is, Have you
6 considered it, and if not, that's not so good.

7 VICE-CHAIRMAN CORRADINI: But you wouldn't
8 go so far as to change?

9 MEMBER STETKAR: I've got it for now. So
10 for right now, significant determination, possibly
11 PRAs for those that have geometric similarities to
12 what you're considering.

13 VICE-CHAIRMAN CORRADINI: Any PRA should
14 address it.

15 MEMBER STETKAR: Right, but it might not
16 be important, for some plants, depending on their
17 design, how many, you know, all of the other factors
18 that feed into this. But it ought to be addressed.
19 In terms of staff auditing, in terms of big picture
20 things.

21 MEMBER REMPE: But this topic did come up
22 in our review of the APR. And yeah, so I think it is
23 important to have the staff make sure that all of the
24 staff is aware of it. During our last subcommittee
25 meeting, we did mention that this work is being used

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 as part of the level three PRA?

2 MR. COYNE: That's correct. And notably,
3 the tools that we developed as part of this work were
4 applied for the global project.

5 VICE-CHAIRMAN CORRADINI: Thank you.

6 MR. IYENGAR: Okay, thank you, Kevin. I
7 think Kevin already walked through some of these
8 steps. When you start in 2009 and went through some
9 tough times because of re-prioritization of our work.
10 But we pulled through, and we engaged with you in a
11 full committee meeting in 2013.

12 Since then, we prepared a NUREG, and we
13 came and talked to you in 2015. But I want to tell
14 you interim, we always had some informal meetings with
15 Dr. Rempe and some of her colleagues present here.
16 And then since then, we have prepared the NUREG. We
17 came to you, we briefed you on the public comments.
18 Yes?

19 MEMBER STETKAR: Just for the record,
20 informal meetings with members of the ACRS have no
21 bearing on the committee's deliberations. I just want
22 to make that clear on the public record.

23 MR. IYENGAR: Right. Well, I'll come back
24 to it, why I mentioned that. So now, I think after
25 the meeting late last year, we had kind of a path

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 forward with you.

2 And then we have certain things that we
3 wanted to address in front of the committee, full
4 committee, particularly focused on some thermal
5 hydraulic issues that Mike Salay would be giving an
6 overview on. Because other things that I guess have
7 been satisfactorily addressed in the NUREG.

8 Before I turn over to Mike, I just wanted
9 to mention that throughout that six-year period since
10 2009, or a seven-year period, we have been very
11 fortunate to have the guidance and support from you,
12 and the feedback has been very important. And we've
13 had differing priorities. Some of us have actually
14 taken on other assignments or other responsibilities
15 in the agency.

16 But I wanted to highlight this, a single
17 commitment of a staff is because we are still here.
18 All of us are in a very different, some, like Kevin is
19 in a different office and a different branch. But we
20 are still here because we want to make sure this
21 happens and this is closed satisfactorily.

22 It's very important, and just shows, this
23 is probably only one of the many hundreds of examples
24 you have seen of staff commitment. And throughout the
25 process I also, I'm thankful to the ACRS committee

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 members, in particular Dr. Rempe and Dr. Dana Powers.

2 I want to highlight they've been guiding
3 us and prodding, if I may say, throughout the process,
4 and ensuring that we are here at this stage. Thank
5 you all very much. Mike.

6 MR. SALAY: Good afternoon, I'm Mike
7 Salay, and I'll talk about thermal hydraulic overview
8 and some response to the questions about the thermal
9 hydraulic analysis.

10 Hadn't seen this before, so I will talk
11 about CSGTR scenario description, the TH analyses that
12 were done, briefly go over the method, and just a
13 bullet on the experimental basis, and then discuss
14 some of the differences between CE and Westinghouse
15 plants.

16 The scenario that we're looking at is the
17 station blackout. It's a low probability event, and
18 combined with a loss of feed water to steam
19 generators. The reactor inventory boils off, the
20 system is at high pressure, and it starts heating up.
21 And something in the RCS is going to fail.

22 It's either going to be the tubes or
23 something else in the RCS. If the tubes fail, it can
24 provide half-efficient products to the environment,
25 bypassing the containment. If something else fails,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the containment can contain what is released.

2 And so here you see Westinghouse, a fast
3 Westinghouse scenario for -- oh, it's the PDF. Okay,
4 for a fast Westinghouse scenario. This actually was
5 an animation, but, oh well. Yeah, so you start with
6 a full system, then you lose offsite power, the
7 secondary starts draining down.

8 Your primary is lost only through a pump
9 leakage, if any. When your secondary side inventory
10 depletes, then your primary inventory starts boiling
11 off. Then when your primary sedimentary hits the top
12 of the U tube, your recirculation, the primary, of
13 water, stops.

14 And the whole thing boils off, and you
15 release, you develop a steam recirculation with, if
16 your loop seals are closed, then the recirculation
17 pattern goes up through the hot leg, through the steam
18 generator tubes, back through the steam generator
19 tubes, and back.

20 This occurs within four hours, and this is
21 for a situation where AFW fails immediately. And this
22 is from NUREG 6995, this work. And more likely
23 scenarios involve operator actions to delay or prevent
24 this from happening. So it will delay failure time.

25 And here the temperature traces for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 hot leg, hottest tube and average tube for the
2 scenario. It shows steam generator dry-out, where we
3 start delaying super-heated steam, and it shows the
4 temperature difference between the hot leg hottest
5 tube and your average tube. And then, your oxidation
6 accelerates and temperatures rise rapidly before
7 failure.

8 And there are a few points on the RCS that
9 are of special interest. You have, it should be noted
10 that you have different materials with different
11 oxidation and melting temperatures. Another important
12 aspect is your wall thicknesses.

13 Your thermal response time is quicker for
14 lower thickness materials. Your steam generator tubes
15 would provide a path for fission products containment
16 if they fail to bypass containment, are very thin,
17 five hundredths of an inch. Whereas your hot leg's
18 about two and a half inches.

19 There's a bunch of other points of
20 interest. I've listed them before and just put them
21 on a slide here. And the situation that we're looking
22 at is the so-called high dry low scenario, where your
23 primary side of your steam generator is at high
24 pressure. Your secondary side is dry and at low
25 pressure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KIRCHNER: Do you have any sense
2 for how strong any validation of this recirculation of
3 the superheated steam in the steam generator?

4 MR. SALAY: Yeah, the --

5 MEMBER KIRCHNER: Have there been any
6 experiments?

7 MR. SALAY: There've been the Westinghouse
8 one-seventh scale experiments.

9 MEMBER KIRCHNER: I'm just curious how
10 much the flow might stagnate rather than recirculate.

11 MR. SALAY: In? Well, if you have
12 buoyant.

13 MEMBER KIRCHNER: No, I understand the
14 thermal hydraulics. I'm just curious how strong this
15 effect might be in the actual condition that you're
16 describing.

17 MEMBER POWERS: Pretty effective.

18 MEMBER KIRCHNER: It is pretty effective?

19 MEMBER POWERS: Yeah, all the questions
20 you have running through your mind like crazy right
21 now arose when it was first proposed. And
22 Westinghouse did their one-seventh scale with sulphur
23 hexafluoride, and they tried, to the limits that you
24 can, to scale things properly. They got pretty
25 healthy flows, and stable flows.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Now, you ask what are the potentials.
2 Well, clearly they didn't have the kind of radiant
3 heat transfer that you would have in these accidents
4 here, which is going to affect things.

5 MEMBER KIRCHNER: Well, I'm thinking of
6 the pressurizer sitting there too, as to how that
7 heats up.

8 MEMBER POWERS: Yeah, there's limits to
9 how they do things, and I think they did have some
10 simulation of the pressurizer. It's one of those
11 tests that's kind of receded into the folklore of
12 reactor safety. So it's a bit of a struggle to find
13 things, but I think I do actually have the topic
14 report if you want to see it.

15 VICE-CHAIRMAN CORRADINI: The assumption,
16 though, in the cartoon is the loop seal is closed.

17 MR. SALAY: Here you're looking at two
18 flow paths. There's one where the loop seal's closed,
19 and one where your loop seal's open.

20 VICE-CHAIRMAN CORRADINI: But in terms of
21 the analyses, the cartoon calculation you showed
22 before, that's assuming it was closed.

23 MR. SALAY: The loop seal's closed, yeah.

24 VICE-CHAIRMAN CORRADINI: So --

25 MR. SALAY: If the loop seal opens, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 know, there's a --

2 VICE-CHAIRMAN CORRADINI: And the analysis
3 you guys are doing considers either path?

4 MR. SALAY: No, we only look at closed.
5 If the loop seal's open, you get, I mean, you're going
6 to get a release. And was the assumption with
7 Westinghouse, because your tubes get to much higher
8 temperatures.

9 VICE-CHAIRMAN CORRADINI: No, I understand
10 that. What I guess I'm kind of asking is, is there
11 any deterministic, or how do you know if it's open or
12 closed? That's what I guess I'm getting at.

13 MR. SALAY: Well, they looked at it in
14 NUREG CR6995, they looked at it in quite a lot of
15 detail. And I do go over it a little bit, but it's
16 basically say they look at it as detail. Lots of
17 parameters, they came up with little parameter maps
18 to, when it, they calculated it to clear or not.

19 And so they came up with maps. And when
20 it would and wouldn't clear, they point out that there
21 were lots of things that would affect behavior that
22 wasn't even in there, such as bypass leakage area
23 between the downcomer and the upper core internals.
24 Because you need to have a sealed lower head and a
25 sealed loop seal to, it has to come up.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And the flow, if you have enough leakage,
2 you don't have a pressure differential to, but --

3 VICE-CHAIRMAN CORRADINI: You don't have
4 a pressure differential to blow it out.

5 MR. SALAY: Yeah.

6 VICE-CHAIRMAN CORRADINI: Well, the reason
7 I'm asking the question, one is when we did small
8 break LOCA spectrum analysis for Westinghouse, and I
9 guess I can't say anything more than that in this
10 meeting, the loop seal was forced to clear because
11 that made it worse, right.

12 MR. SALAY: Yeah.

13 VICE-CHAIRMAN CORRADINI: In this case,
14 I'm just trying to understand it. So the other
15 question is, so Westinghouse is in the topical, they
16 actually had, not criteria, but regions where it was
17 clear and not clear. And so is it a race with the
18 loop seal clearing also with, in terms of the hot leg
19 heating up and opening, versus the tube?

20 That is, the prediction is both the mostly
21 likely scenario is, in a Westinghouse design, is that
22 I start this natural circulation, the loop is not
23 cleared, I overheat somewhere near the pressurizer
24 surge line, and I pop a hole. That's the likely
25 scenario.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SALAY: Yeah.

2 VICE-CHAIRMAN CORRADINI: And then how can
3 I, in a Westinghouse geometry, get the loop seal to
4 clear early because of the bypass? That's what I
5 can't remember.

6 MR. SALAY: Well, if they had no bypass at
7 all, I think Chris mentioned. I wasn't involved in
8 that.

9 VICE-CHAIRMAN CORRADINI: Oh, okay.

10 MR. SALAY: This was in the steam
11 generator action plan.

12 VICE-CHAIRMAN CORRADINI: Okay, how would
13 you stabilized it.

14 MR. SALAY: But, no, it would have caused
15 clearing almost every time. So if you have area, you
16 don't get the DP, because --

17 MEMBER MARCH-LEUBA: Yeah, but first
18 principle, without revealing any proprietary
19 information, same as the bypass, it's clearing one
20 seal. Once you clear one seal, you release the
21 pressure in the upper plenum.

22 So if I were going to bet on something,
23 it's at most one we clear. Because once one clears,
24 the pressure in the upper plenum releases, and there
25 is no pressure to push that wire on the other two

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 loops or one loop. So there will be always one or two
2 loops that will be closed. If there is sufficient
3 bypass where you were pointing on core value then none
4 will clear.

5 VICE-CHAIRMAN CORRADINI: Well, that's
6 what I was thinking.

7 MEMBER MARCH-LEUBA: Yeah, that's a
8 possible situation too.

9 MR. SALAY: This is one of the things that
10 was deferred. We started looking at how we'd look at
11 it and how we'd adjust the model to make, check the
12 model deck to verify how it'd be. But then we never
13 ended up doing that work.

14 MEMBER MARCH-LEUBA: Yeah, but my first
15 principle modeling is that that drawing that you have
16 in there, you don't need to put the dotted line in the
17 middle. That's what you really have in the reactor.
18 Half of it is clear, the other half is not.

19 (Laughter.)

20 MEMBER POWERS: Except that if you've got
21 one loop that's clear, you're going to have such a
22 ferocious flow through there, it's going to pop on the
23 open line.

24 MEMBER MARCH-LEUBA: I mean, if you are
25 going to pop, I'm not planning, but I would assume

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it's possible.

2 MEMBER POWERS: It don't take much.

3 MEMBER MARCH-LEUBA: If it's possible and
4 likely to clear it, you should assume it cleared,
5 unless you know better.

6 MR. SALAY: They also notice some effects
7 with the pump suction elevation and nodalization would
8 affect it. So they included that there was
9 considerable uncertainty in whether it clears or not.

10 MEMBER MARCH-LEUBA: And your models, how
11 long does it take to boil that? I mean, you have
12 really, really hot steam out there. How come is that
13 water staying liquid there? How long does it take to
14 boil?

15 MR. SALAY: Yeah, this, well, had the
16 previous, this actually was a little step through each
17 step. So, you got dry-outs, steam generator dries out
18 in 100 minutes.

19 MEMBER MARCH-LEUBA: That's the steam --
20 not the steam. I'm talking on the loop seal. The
21 loop seal is leaking water in there and you have steam
22 --

23 MR. SALAY: Leaking water, you have hot
24 steam here, and then you have heat losses to the
25 environment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: In your models, they
2 never boil?

3 MR. SALAY: In ours, they didn't, and I'm
4 not sure about the previous analysis. And I think the
5 loops, in some analyses, the loop seals, in the ones
6 we were using, the loop seals, were net condensing.
7 But, okay.

8 Anyway, the full loop seal, full loop
9 natural circulation occurs if your loop seal has been
10 cleared. It's a severe challenge to your tubes. And
11 I mentioned some of these things.

12 And the other scenario is the counter
13 current, natural circulation. And if you're looking
14 at, see whether you'd have a bypass, you'd expect the
15 bypass in the full loop seal.

16 So you look at the counter current natural
17 circulation to see if you get a bypass in those
18 scenarios. And these are the analyses. So we ended
19 up analyzing these rather than the others, unless
20 you're actually looking at releases.

21 MEMBER KIRCHNER: What's your sense of how
22 the pressurized and surge line play in this scenario?

23 MR. SALAY: Well, there is actually water
24 level. It actually goes up and down. It actually
25 went down, and then starts bubbling up and then gets

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 full and then I can't remember. I have actually an
2 animation that I wasn't planning to show, but I could
3 show.

4 MEMBER KIRCHNER: Is that a heat sink
5 effect that the pressurizer level goes up and down?

6 MR. SALAY: Well, you're having steam come
7 up through here, and so it keeps it up. And so if
8 you're, I mean, it depends how much your loss is.
9 Could be heat losses, could be. I mean it was one of
10 things, again, that we would have liked to look at,
11 but.

12 MEMBER KIRCHNER: Okay.

13 MEMBER MARCH-LEUBA: I don't know, it's
14 hard to believe that you have steam hard enough to
15 melt the steel and keep water liquid.

16 VICE-CHAIRMAN CORRADINI: I think the
17 point that Mike is getting at is, is that you've got
18 your saturated water down here at the given pressure,
19 but you're cooking it and it never sees that way down
20 in the loop seal. You see it --

21 MEMBER MARCH-LEUBA: No, no --

22 MR. SALAY: He's talking about how do you
23 still have water in the pressurizer.

24 MEMBER MARCH-LEUBA: You're bubbling
25 superheated steam through that liquid in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pressurizer, and the liquid remains? I mean, you're
2 not going to evaporate all of it soon.

3 VICE-CHAIRMAN CORRADINI: But the
4 pressurized empties. I don't remember this station
5 blackout scenario, but I think the pressurizer empties
6 --

7 MR. SALAY: We had it. It would go up
8 down. Yeah, and I think in Three Mile Island, it was
9 water --

10 MEMBER POWERS: There was water all the
11 time in TMI. In the pressurizer.

12 VICE-CHAIRMAN CORRADINI: It wasn't this
13 long cooking it at these temperatures, was it?

14 MEMBER POWERS: No.

15 VICE-CHAIRMAN CORRADINI: Okay.

16 MEMBER POWERS: TMI was a wet plant.
17 There was water going in nearly all the time.

18 MR. SALAY: So TH, there are two analyses.
19 There is the Westinghouse analysis that was performed
20 for the steam generator action plan. And this is
21 documented in NUREG 699 -- CR 6995.

22 They did perform some CE analyses, but it
23 didn't receive the same level of attention. And so
24 they didn't update some of the models the way they
25 updated their Westinghouse models.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Babcock and Wilcox plants were not
2 analyzed because vigorous natural circulation flows
3 were not expected. So both Westinghouse and
4 Combustion Engineering TH analyses were used for the
5 current work, and we did the CE TH analysis under this
6 project.

7 We used a system code, MELCOR, and CFD
8 code. CFD predicts the spatial flow and temperature
9 distributions.

10 Your system code predicts the whole
11 overall transient behavior. It uses the CFD results
12 from both modeling and the results on the transient
13 results can also be combined with those of the CFD to
14 develop a transient spatial temperature distribution
15 for your steam generator tubes.

16 So the CFD analyses were validated against
17 Westinghouse one-seventh scale experiments, and they
18 built up from those models to prototypic steam
19 generator geometries. Multiple sensitivity studies
20 were performed at the CFD.

21 And so here you see both CFD and system
22 analyses. That's from NUREG 1922. So you have a CFD
23 analysis, and then you have a much coarser
24 nodalization in your system code, and you sort of have
25 to transfer information from one to the other. They

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 used parameters that were based on previous hand
2 calculations.

3 And the CFD provides the hot leg flow rate
4 by the use of the discharge coefficient based on the
5 approved number of correlations. Inlet plenum mixing
6 amount, hot tube fraction, recirc ratio. And it also
7 provides the distribution of temperatures entering
8 your tubes.

9 And this is shown by, given by a
10 distribution, and it's normalized temperature. And
11 there are differences between C and Westinghouse
12 plants. In CE, there's considerably less mixing of
13 the hot gasses before it reaches the steam generator
14 tube inlets. This is because there's a lower hot leg
15 length to diameter ratio.

16 And some CE plants have shallow inlet
17 plena. There are few other effects in the CE plant
18 analyzed. The hot leg comes in normal to the plates
19 separating the steam generator plena. And whereas it
20 comes in at an angle from Westinghouse, which adds
21 additional mixing.

22 MEMBER REMPE: Mike?

23 MR. SALAY: Yeah.

24 MEMBER REMPE: For some reason, in our
25 subcommittee meeting, I thought when we discussed how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 representative the example plans were of the whole
2 fleet, that we heard back about ten percent responded
3 back. But the geometries are about the same.

4 And now I see the words some CE plants
5 have shallower inlet plena. Have you identified some
6 CE plants that differ?

7 MR. SALAY: I know Chris asked around, and
8 he's the one who answered that question. I can't,
9 Chris Boyd is not here.

10 MEMBER REMPE: He did answer at the
11 meeting. I just am puzzled because I thought you guys
12 said, Well, as far as we know, but we only have ten
13 percent. And now do you have knowledge that says --

14 MR. SALAY: No, no, I don't have any
15 additional knowledge.

16 MEMBER REMPE: Okay, thank you.

17 MR. SALAY: Yeah, so under certain
18 conditions, I mean because your temperatures are
19 nearly as hot as your steam, the gas temperatures that
20 your steam generator tubes are seeing are nearly as
21 hot as the gas temperatures of the hot legs you're
22 seeing. There is a potential for unflawed tubes being
23 ruptured before the hot leg.

24 And since you have a lot of unflawed
25 tubes, multiple unflawed tubes could potentially reach

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the failure condition at the same time.

2 And so here you see the Westinghouse model
3 51 and CE inlet plenum showing about the plume
4 diameter. And you have about a one and a half plume
5 diameters before you hit the tube sheet for CE, where
6 you have four and a half plume diameters, hot plume
7 diameters, before you hit the tube sheet. So there's
8 more opportunity for mixing there.

9 And here you see CFD results for both CE
10 and Westinghouse. And if you look, you can see at the
11 hottest temperatures reaching the Westinghouse steam
12 generator at about 0.6.

13 Whereas, the hottest for the CE are about
14 one. And this is normalized temperature relative to
15 the temperature difference between what the hot leg
16 sees to the cold side of the steam generator.

17 So one means that the steam generator
18 tubes are seeing hot leg temperatures. And so for the
19 MELCOR CE calculations, the objectives were to provide
20 thermal hydraulic results for CE plants to calculate
21 failure using the CSGTR calculator and finite element
22 calculations.

23 It's also to provide some scoping
24 component failure calculations and to calculate some
25 fission product releases, although that was de-scoped.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 On the analyses, so for each case, you had
2 to run for each event, you had to run two analyses.
3 One for scoping, to see what MELCOR would predict to
4 fail, and one in which component failure was
5 suppressed to allow the other codes to, to provide
6 input for the other codes to calculate.

7 And that short-term station blackout,
8 long-term station blackout where the auxiliary feeding
9 water were assumed to operate for four hours. And
10 there were variations assumed, operator action and
11 relief valve behavior and variation on reactor coolant
12 pump seal leakage. Yeah.

13 MEMBER KIRCHNER: During the transit, what
14 do you assume happens at the reactor coolant pumps
15 seals when you're in the steaming configuration? Is
16 there any loss of pressure there that's measurable?
17 Or do you make a very conservative assumption that the
18 seals block any steam release?

19 MR. SALAY: Essentially, it modeled the
20 flow path. So, and with a flow area that would match
21 the expected seal leakage rate and allowed the code to
22 calculate. So it didn't --

23 MEMBER KIRCHNER: No, I understand seal
24 leakage when you have water. I'm thinking now you're
25 in a steaming condition. So what are the seals doing?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SALAY: Yeah, so we just take the same
2 hole and assume gas leakage from there. So --

3 MEMBER KIRCHNER: That doesn't help
4 depressurize the system at all?

5 MR. SALAY: So, yeah, you would lose some
6 gas. That's calculated by the flow solver.

7 VICE-CHAIRMAN CORRADINI: But to answer
8 your question directly, everything is leaking. PRVs
9 are opening, this thing is leaking. And so it's kind
10 of sitting there.

11 UNIDENTIFIED SPEAKER: It's just
12 chattering away.

13 VICE-CHAIRMAN CORRADINI: There is a
14 surface station blackout analysis with MELCOR actually
15 shows the seal leakage starting off at its prescribed
16 ring then getting saturated. Pops up, water exits,
17 steams comes in, and it kind of goes back down again,
18 as Michael suggested.

19 MR. SALAY: And there was also an
20 uncertainty analysis to determine the impact of
21 thermal hydraulic uncertainty on failure timing. And
22 here is some example of the MELCOR CE results, which
23 this is RTP leak, reactor coolant pump seal leakage
24 sensitivity on both pressure and temperature. And so
25 that's what they look like.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER REMPE: So let's go back to that
2 one just for a minute. As I recall in our
3 subcommittee meeting, the reason that you are, what
4 motivated that analysis was the comment from the PWR
5 Owners Group, where they said, Hey, you've made the
6 wrong assumption about the seal leakage.

7 And, again, my recollection was that you
8 said, Well, okay, let's assume we don't have any
9 leakage, and what happens.

10 MR. SALAY: Yeah, that's exactly.

11 MEMBER REMPE: And that was the reason you
12 did this analysis and why you went forward with the
13 same conclusion.

14 MR. SALAY: Yes.

15 MEMBER REMPE: Okay, thanks.

16 MEMBER BALLINGER: Do you assume that the
17 seal leaks but remains intact?

18 MR. SALAY: Yeah.

19 MEMBER BALLINGER: Because the seals at
20 least contain some stuff that'll handle pretty high
21 temperatures, but some stuff which will erode very
22 quickly. And so you end up with parts of the seal
23 which are basically gone, and parts of the seal
24 surfaces that are still there.

25 And so I'm guessing that you would get a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 lot of flow after a while. A lot of those seals are
2 -- but they assume that they remain intact. They leak
3 but remain intact.

4 VICE-CHAIRMAN CORRADINI: I'm not familiar
5 with their analysis, but the MELCOR analysis for
6 SOARCA has three levels based on time and temperature,
7 if my --

8 MEMBER BALLINGER: Okay, because the
9 graphite's going to be gone.

10 CHAIRMAN BLEY: If they get up to 500 GPM,
11 that's going to add another seal there.

12 UNIDENTIFIED SPEAKER: That's about right.

13 CHAIRMAN BLEY: I don't know what they
14 get.

15 UNIDENTIFIED SPEAKER: 500 GPM is an O
16 seal.

17 MR. SALAY: Yeah, I think we just use a
18 single seal leakage, and then yeah, the PWR Owners
19 Group, they said you really wouldn't get any, or much,
20 and I don't know. Do any of you have anything to do
21 add or no? About seal leakage.

22 MR. AZARM: Yeah, I do. First if I might
23 confirm what Mike said, we basically assumed an
24 initial clearance of the seal, the spacing tack
25 doesn't grow as the accident goes on. That's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 question or assumption when you are in the regime of
2 severe accidents and you are dealing with high
3 temperature. As mentioned, lot of seals are going to
4 fail.

5 I think we also, we haven't done the
6 analysis but we talked about the a lot. The timing of
7 failure becomes really important. So you know, like
8 as Dr. Corradini was saying, you can have three
9 phases, but it is important when is the threshold of
10 those phases.

11 Because when your seal fails
12 catastrophically, we are worried about the loop seal
13 to get cleared. And if that happens, basically it's
14 end of the run for us.

15 So, no, the analysis has been done, we
16 have done quite a bit of thinking about it. We
17 haven't done what SOARCA has done, and I'm not even
18 aware of it, but we do understand the timing of seal
19 failure plays an important role. And might be
20 expecting high temperatures, but it was not within the
21 scope of this analysis.

22 MR. COYNE: Mike, if I, Kevin Coyne from
23 the Office of Research. If I could add when we re-
24 scoped this work several years ago to try to finish it
25 more efficiently, and I know this always dangerous to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 say in the severe accident space, but we tried to bias
2 some of the assumptions towards minimizing the
3 likelihood of CSGTR issues for the CE plant.

4 In other words, if we changed the
5 assumption, the presumption would be it would get
6 worse if we move the assumption.

7 And I know it's hard to necessarily hit
8 that sweet spot in the severe accident modeling, but
9 this is one case where loop seal clearing for the CE
10 plant is just going to make the consequential steam
11 generator tube rupture probability higher than what we
12 calculate if we assume the loop seals are intact.

13 Now in the end, the temperatures the tube
14 sees wouldn't change dramatically between the loop
15 seal intact and the loop seal cleared. Is that
16 correct?

17 MR. SALAY: Yeah, and so some engines in
18 possible works --

19 MEMBER MARCH-LEUBA: Can you rephrase
20 that? I mean are we talking about the loop seal or
21 the pump seal?

22 MR. SALAY: The loop seal. He was
23 mentioning the loop seal.

24 MEMBER MARCH-LEUBA: He was mentioning the
25 loop seal. You weren't mentioning the pump seal.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SALAY: Initially, yeah, we switched
2 seals.

3 MEMBER MARCH-LEUBA: So if the pump seals
4 or doesn't fail has not consequence that you can see
5 with any certainty?

6 UNIDENTIFIED SPEAKER: We haven't done
7 that.

8 MEMBER MARCH-LEUBA: But if the loop seal
9 is open, then you have a lot more consequences. It's
10 bad. Loop seal clearing is bad, pumps it clean,
11 inconsequential. Is that correct?

12 MR. AZARM: I don't think I said that.

13 MEMBER STETKAR: In general, if the pump
14 seals fail, the loop seal is going to clear it.

15 MEMBER MARCH-LEUBA: So that's really bad.

16 MEMBER STETKAR: That's not a good day.

17 MEMBER MARCH-LEUBA: Why would it clear?

18 MEMBER STETKAR: Because the pump's at the
19 bottom of the loop seal.

20 MEMBER MARCH-LEUBA: No, no, no.

21 MEMBER STETKAR: It's a low pressure spot,
22 and it'll flash it out through the seals.

23 MEMBER MARCH-LEUBA: If you say so.

24 MR. SALAY: Another factor is that your
25 temperatures in CE are already that hot, so the loop

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 seal clearing isn't going to make that big of a
2 difference because you can't really increase the
3 temperatures relative to the Westinghouse --

4 VICE-CHAIRMAN CORRADINI: I think the
5 reason we're asking, or some are asking all these
6 questions, is that these can change your timing. So
7 I want to go back to what Kevin said to make sure I
8 understood it.

9 So at least with the CE plant, or maybe
10 for both Westinghouse and CE, you chose a set of
11 conditions which would delay steam generator tube
12 rupture, or enhance its timing compared to the hot leg
13 creep rupture. That's what I didn't understand.

14 MR. SALAY: To paraphrase, I think Kevin
15 is, we looked at Westinghouse and CE, tried to make
16 what's the worst Westinghouse can get and what's the
17 best CE can get, sort of take that.

18 VICE-CHAIRMAN CORRADINI: Okay, all right,
19 so I did hear it right. What the best CE did.

20 MR. COYNE: With the presumption that if
21 the reality was different from the assumption, it
22 would only make the probability of the CSGTR get
23 worse.

24 We were trying to get kind of a lower,
25 these are dangerous terms for me to use, but a lower

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 estimate of what the probability would be or a best
2 estimate assuming optimistic --

3 VICE-CHAIRMAN CORRADINI: What if you say
4 that, I was just asking it again because I didn't
5 think I heard that, so I.

6 MR. SALAY: Would it be bad, even with the
7 optimistic assumptions?

8 VICE-CHAIRMAN CORRADINI: Okay, you said
9 it right. I'm with you, thank you.

10 MEMBER REMPE: To go back, just to make
11 sure I understand in my mind, a long time ago when
12 they did the Westinghouse plant, they did have a
13 situation where you had a seal leakage rate and you
14 increased it for the pump.

15 But I believe for your MELCOR
16 calculations, you just left it at 21 gallons per
17 minute until you did this thing for the PWR Owners
18 Group. Is that a true statement?

19 MR. SALAY: We left it at the hole size
20 that would give 21 gallons per minute.

21 MEMBER REMPE: Okay, so you did not
22 increase the hole size.

23 MR. SALAY: We did not.

24 MEMBER REMPE: And so that's why your
25 answer might have seemed a little fuzzy to some folks.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I was trying to clarify that. Thank you.

2 MR. SALAY: So it was interesting, but a
3 lot of it was determined to potentially not be worth
4 the effort. But some of the things that could be done
5 in more detailed spatial temperature distribution,
6 assessment of TH factors that impact relative failure
7 timing, analysis of loop seal clearing.

8 Look at water hold-up in the steam
9 generator and flooding counter current flows is known,
10 so water was also held up in the previous steam
11 generator action plan calculations. And a detailed
12 evaluation of fission product release.

13 I mean, this analysis focused on thermal
14 hydraulic input, not fission product release. So we
15 didn't re-run cases when they failed solely for
16 purposes of extracting of the fission product release
17 behavior.

18 Now I'll go over some of the questions
19 that were asked since the last meeting. So the recent
20 questions were, temperature distributions, the impact
21 of loop seal clearing. I'll sort of reiterate what I
22 already said. And expected impact of models that have
23 been subsequently added to MELCOR after this analysis,
24 and a little bit on the TH uncertainty analysis that
25 was done.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And so here you see the Combustion
2 Engineering tube sheet inlet temperature distribution.
3 This was calculated using fluent, anti-fluent, and
4 what it shows is the normalized temperature
5 distribution in terms of percentage of tubes of the
6 whole bundle.

7 There are five data sets captured at the
8 transient CFD calculations. And there are five data
9 sets, so this gives you an indication of how the size
10 of the plume changes and moves around.

11 One thing I should mention is for the
12 Westinghouse, your distribution looks like this, where
13 the maximum is about 0.5, 0.6. So here the hottest
14 tubes for Westinghouse around up here, at 0.5, 0.6.

15 Whereas for CE, your hottest tube
16 temperatures are essentially the hot leg temperature.
17 It's about 1.5-2% of eight thousand-some tubes. So
18 it's about 160 tubes up here are about as hot as the
19 hot leg, the basic temperature is about as hot as the
20 hot leg.

21 When your loop seal clears, in
22 Westinghouse, you go from this distribution to
23 something more that looks like what's on the screen
24 now. And so your hottest tubes become as hot as hot
25 leg.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: Sorry, Mike, I'm
2 confused. That represents five different
3 calculations?

4 MR. SALAY: The same calculation, but it's
5 a transient calculation.

6 MEMBER MARCH-LEUBA: This is a histogram.

7 MR. SALAY: It's a histogram, so the first
8 one is some period within the calculations. It's as
9 it's increasing in temperature.

10 MEMBER MARCH-LEUBA: So it's the same
11 calculation.

12 MR. SALAY: It's the same calculation, but
13 it's a transient calculation. But it's different
14 snapshots of the same calculation. So --

15 UNIDENTIFIED SPEAKER: Of each?

16 MR. AZARM: I'm sorry, I shouldn't say,
17 but think about this a time-dependent calculation. Do
18 you remember that plume he was showing you --

19 MR. SALAY: The plumes moving around.

20 MR. AZARM: That thing is moving, and the
21 number of tubes within that tube is moving. So he has
22 taken five snapshots.

23 MEMBER MARCH-LEUBA: Five snapshots.

24 MR. AZARM: You know, between 0.2 to 0.25,
25 you see five lines. In each of those snapshots,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that's what I saw.

2 MEMBER MARCH-LEUBA: If I take the left
3 line of every one of those histograms, that will be
4 one of the --

5 MR. AZARM: One, yes.

6 MR. SALAY: Next one is ten seconds later,
7 the next one is ten seconds later, the next one's ten
8 seconds later, and the next one's ten seconds later.
9 And so it gives an indication of how much it changes
10 over time.

11 MEMBER MARCH-LEUBA: You have significant
12 number on the high end, which is --

13 MR. SALAY: Yeah, I mean, that's
14 important. And also concerned, at least in CFD
15 analysis, was whether, for the Westinghouse CFD
16 analysis, to what extent are your same tubes hot, and
17 are the same tubes hot at different times.

18 So another thing about loop seal clearing,
19 it was pointed out that many studies out there
20 conclude that loop seals would clear before core
21 damage. Do any scenarios indicate that, and discussed
22 it earlier.

23 I mean, it was looked at in steam
24 generator action plan and documented in NUREG 6995.
25 They generated parameter maps that were based on pump

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 seal leak rate, feed water operation time, number of
2 PORV openings, and number of PORV opens, and when
3 operator action started.

4 It was also found that it was sensitive to
5 nodalization and core bypass area. And they concluded
6 that uncertainty still remains on loop seal clearing.

7 The loop seals did not clear in any of the
8 calculations we did for CE. However, it is a
9 shallower. The initial scoping work, we did initial
10 scoping work, but analysis of loop seal clearing was
11 one of the things that was cut during the work scope
12 reduction. So we never actually looked in detail.

13 It's also more important for Westinghouse
14 plants because, again, it takes that normalized
15 temperature and brings it nearly as hot as hot legs.
16 Whereas for CE, you've got some tubes always at that
17 high temperature.

18 And another question was that their models
19 were added and were used in SOARCA. And these models
20 were added after the version of the code used in this
21 analysis. And the question was, Do these changes
22 affect the conclusions of the study? And those
23 analyses were done for CSGTR were done in 2011, 2012,
24 there was some recalculation in early 2013.

25 MELCOR-186 was used for the CE CSGTR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analysis. There were different MELCOR-2 versions used
2 in different SOARCA analyses. So the Surry SOARCA
3 analysis, they did a comparison, they formed a
4 comparison, well, they compared 186 and 2.1 timings.

5 And we can see here station blackout,
6 station dry-out. It's a few minutes off, but the
7 fission product gap releases were at the same time hot
8 leg creep failure within a minute, even though the
9 calculation was nearly four hours.

10 And I mean, all the way to accumulator
11 injection, you're pretty close. So major event timing
12 for that version, you wouldn't expect any changes for
13 CE, since it's the same version. There have been some
14 further model changes subsequent to that analysis.
15 And the ones that could potentially affect behavior
16 are the upgrade, update to the dry-out model and
17 update of the declension models.

18 Both of these models, they affect behavior
19 when you're reflooding or when the accumulators kicked
20 in. And for interest for this analysis, we're looking
21 at the situation before accumulator injection. And so
22 we don't expect that these updated models would
23 significantly affect or alter the report conclusions.

24 And there was a request for more
25 information on certainty analysis. So the impact on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 certainties on thermal hydraulic-caused uncertainties
2 was looked at upon initial decreation (phonetic),
3 essentially how much do uncertainties in TH affect
4 failure timing releases.

5 This is, people put a calculator, Ali was
6 asking. And so Sandia performed uncertainty analysis
7 on an early station blackout models prior to addition
8 of hot tube final flows and prior to addition of heat
9 structures for the tube sheet.

10 So they used an average hot tube for steam
11 generators, it's a stress multiplier of two. Expect
12 results to be reasonably representative of failure
13 timing variation resulting from TH variations, but we
14 don't necessarily expect the actual values to be
15 representative.

16 So the analysis performed by sampling from
17 the hydraulic parameters, and observed the effect on
18 absolute and relative failure timing using a Monte
19 Carlo sampling, 100 realizations. It was analyzed
20 with the STEPWISE (phonetic) code.

21 MEMBER STETKAR: Mike?

22 MR. SALAY: Yeah.

23 MEMBER STETKAR: A hundred samples from
24 any kind of reasonable analysis won't give you any
25 sense of what the uncertainty is. So I'm curious what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 anyone learned from that exercise.

2 MR. SALAY: Well, just giving the results.

3 And so --

4 MEMBER STETKAR: It is 100, that's not a
5 typo somehow, that it was really 1,000 or 10,000?

6 MR. SALAY: I think it was 100.

7 MEMBER STETKAR: 100.

8 MR. SALAY: And these were the parameters.
9 They were sampled, the discharge coefficients for PORV
10 and SRV, the oxidation rate constant. The mixing
11 parameters that were applied from the CFD. So, what
12 if the CFDs off a little bit? Heat transferred
13 multipliers for the outer tube wall and RCS
14 containment heat transfer.

15 And these were distributions that they got
16 out that with a 95% confidence interval for hot leg,
17 and for the tube and hot leg. And this is the
18 distribution for the relative failure timing in both.

19 MEMBER REMPE: But can you confirm that it
20 is 100 is all you did for sampling or what was done?

21 MR. SALAY: I'm pretty it was 100.

22 MEMBER POWERS: I think you can be
23 positive it was 100, not 1,000.

24 MEMBER MARCH-LEUBA: One hundred MELCOR
25 calculations?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 UNIDENTIFIED SPEAKER: MELCOR
2 calculations, yes.

3 MEMBER MARCH-LEUBA: Of a thousand, two
4 thousand seconds each? They were not a thousand.

5 MR. SALAY: The short-term station
6 blackouts take about a week to run each.

7 MEMBER MARCH-LEUBA: I would have run only
8 59 myself. Which is the minimum number you're
9 supposed to do.

10 VICE-CHAIRMAN CORRADINI: He's, 59.

11 MR. SALAY: And these are what they found
12 to affect the failure timing. It was the RCS to
13 containment, heat transfer multiple, see our oxidation
14 rate, recirculation ratio in order of importance.
15 Didn't look at, although it would have been better to
16 look at also was the relative, what impacted the
17 relative failure timing.

18 So these are the standard deviations for
19 absolute failure timing. About six minutes, nearly
20 seven minutes for steam generator absolute failure
21 timing. Eight and a half minutes for hot leg absolute
22 failure timing. And if you take the difference of the
23 two distributions, well not the difference of the
24 distributions, the difference in timing actually. The
25 distribution of the difference in timing, and it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about seven minutes.

2 MR. COYNE: Mike, can I interrupt for a
3 second? On the uncertainty analysis you just covered,
4 was that, is SOARCA uncertainty analysis?

5 MR. SALAY: No, no, this was done at the
6 beginning of the CSGTR project.

7 MR. COYNE: Okay, just wanted to clarify.
8 Thanks.

9 MR. SALAY: Yeah, so we did perform MELCOR
10 calculations for CE plant with replacement steam
11 generators and provide that input to the CSGTR
12 calculator and find out element component failure
13 analyses.

14 Relative temperature increase rates and
15 relative component failure time between steam
16 generator tubes and other components is more important
17 for releases than absolute failure time.

18 Some work was deferred because of limited
19 resources, and many of these, the benefit was
20 determined not to be worth the expense. And we
21 received and incorporated useful feedback from both
22 the ACRS and the public.

23 MEMBER MARCH-LEUBA: Can you go back to
24 slide 38? All right, so am I reading this correctly
25 that the tubes break before the hot leg?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SALAY: Again, this was done before
2 the models were completed, and I think that one of the
3 major things that hadn't been added is the heat
4 structures of the tube sheet. So it seems there is
5 some heat loss there.

6 MEMBER MARCH-LEUBA: So with improved
7 models, this would not be --

8 MR. SALAY: No, no, there were some cases
9 where you did get, but most of the cases it was the
10 hot leg that failed first.

11 MEMBER MARCH-LEUBA: I mean, if I look at
12 that, some tubes fail at time 20, some hot legs fail
13 at time 19. But those are different parameters here.
14 Use the same parameters, the tube always fails before?

15 MR. SALAY: In this one, yeah. This is
16 the difference of failure times. For this set of
17 analyses, yes, the tube always failed first. But for
18 the final analyses, it wasn't.

19 MEMBER MARCH-LEUBA: Maybe not 100%
20 probability, but 25.

21 MR. SALAY: The point was to get how much
22 variation in TH would affect them. So how much
23 uncertainty in timing would this give them, for the
24 failure calculator.

25 MEMBER MARCH-LEUBA: But no matter how you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 change parameters of conductants to containment or
2 this and that or all the parameters you change, the
3 tube always failures earlier.

4 MR. SALAY: For this one. But for the
5 later analyses, it was the other way.

6 MR. COYNE: Mike, is it a true statement
7 that you're using the MELCOR calculation to determine
8 hot leg and tube failure for this calculation?

9 MR. SALAY: For this one, yeah. And this
10 was also earlier too. Even for MELCOR with subsequent
11 analyses, it went the other way when you added heat
12 structures.

13 MR. COYNE: So these are simplified
14 correlations that predict tube failure in hot leg and
15 MELCOR. The actual -- for the project and the results
16 presented in NUREG 2195, we used the steam generator
17 calculator, which takes a thermal hydraulic output
18 from MELCOR and represents the actual flaw
19 distribution in the tube.

20 So it's a more realistic manner of doing
21 that. What is the relative timing between hot leg and
22 tube failure?

23 MR. SALAY: And this, yeah, just gives how
24 much variations in TH would affect the relative and
25 absolute time --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KIRCHNER: Since he brought it up,
2 may I ask, the flaw distribution, did that change the
3 time to failure significantly?

4 MR. SALAY: For?

5 MEMBER KIRCHNER: Within the band of these
6 kind of results you're showing, did the factoring that
7 added level of fidelity, so to speak, into the
8 calculations, did that have a significant effect?

9 MR. COYNE: So I'll start, and then I'll
10 immediately turn to Ali Azarm, but one of the, I
11 think, giveaways on this graph for me was this $MP=2$.
12 So previous work used a pressure multiplier to
13 represent degradation in the tubes.

14 And to be honest, it's very hard to
15 correlate a pressure multiplier to an actual observed
16 flaw characterization you get from a steam generator
17 tube. So it was practically hard to work with,
18 particularly if we were going to use this for, say, a
19 STP-type determination for a particular plant. So
20 it's hard to speak for the relative timing.

21 But the more recent work that Ali Azarm
22 had led was to use operating experience to come up
23 with distributions to characterize the flaw
24 distribution. And then we can use that within the
25 steam generator calculator to get a more, what I think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it is a realistic prediction of the failure.

2 MEMBER KIRCHNER: Yeah, but Ali, when you
3 did that, did you see a marked impact on the time to
4 failure within the scope of the overall?

5 MR. AZARM: Let me first clarify, if I
6 may, if you look at your NUREG document, I believe
7 there's a bunch of graphs, like 7-25, 7-26, that has
8 the distribution or the probability of public failure
9 graph.

10 And then it has the graph for leak area.
11 Because when we do the PRA for us, the two failures
12 wasn't good enough. We needed to accumulate leak area
13 of three centimeters squared, six centimeters squared,
14 etc.

15 So yes, those graphs have been generated
16 showing more or less similar behavior that with high
17 likelihood that you're going to fail first. And you
18 will get those leak areas. Now, the only problem with
19 those graphs in NUREG is that it accounted for no
20 uncertainty from thermal hydraulic.

21 I don't want to get -- for us, most of the
22 system uncertainly, model uncertainty, it's epistemic.
23 So basically, the graph stays the same, the confidence
24 bound will be added. But right now, your NUREG gives
25 you the blue curve, but not the confidence bound that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is coming from the thermal hydraulic.

2 So the picture, you know, the glass is
3 half-full. You have the uncertainty from material,
4 from all other stuff, but you do not have the
5 uncertainty from thermal hydraulic.

6 MR. SALAY: This is a scoping calc that
7 doesn't include the flaw distribution. It just
8 assumes a single large flaw.

9 MEMBER BALLINGER: In answer to your
10 question, the answer is no. If you look at figure 5-6
11 in 2195, it shows predicted versus observed time to
12 fail for flawed and unflawed tubes. And they lay on
13 top of one another, the scatter is --

14 MEMBER KIRCHNER: It's almost like putting
15 too much information into the estimate, given all the
16 other variables and uncertainty.

17 MEMBER BALLINGER: At those temperatures,
18 the creep rate is so high.

19 MEMBER KIRCHNER: Yeah, exactly. So I'm
20 not a metallurgist, but I'm just saying.

21 MEMBER BALLINGER: The creep rate is so
22 high that --

23 MEMBER KIRCHNER: That defect history is
24 probably matched right away at these high
25 temperatures.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BALLINGER: Because you don't get
2 cracks.

3 MEMBER POWERS: Not your problem there.

4 MEMBER BALLINGER: Not.

5 (Simultaneous speaking.)

6 MR. IYENGER: I did skip Selim's slide, I
7 am sorry. I apologize for that.

8 MR. SANCAKTAR: That's okay. So after the
9 fact, let me quickly say couple of closing things.
10 The first bullet is already I guess obvious that we
11 had multiple branches and fields involved in this,
12 with its benefits and challenges.

13 And as we said in the past, most of the
14 work was done in-house. PRA work was contracted out
15 to IESS eventually, although it started without our
16 vendor, it basically transferred to IESS.

17 Okay, and this we talked about, Fukushima,
18 seven years. There was one more thing I wanted to
19 mention. Not this, oh, here. The two bullets at the
20 bottom.

21 So the next actions we have are have the
22 draft NUREG go through NRC technical editing process,
23 which turns out to be rather hefty. And then we will
24 send it, the edited version, to NRC publishing, and
25 then cross our fingers that it will go through the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 competing other publications and finish, hopefully we
2 will finish it in the calendar year, not the school
3 year but the calendar year this year.

4 And I keep mentioning this, because it's
5 very dear to me, we are trying to get this
6 grandfathered format-wise, because there is a new
7 NUREG format.

8 MEMBER POWERS: God help us.

9 MR. SANCAKTAR: I don't know what else
10 will happen. So we will ask for mercy and we
11 grandfather this and use the existing format.
12 Otherwise, we'll introduce all kinds of new challenges
13 into the process.

14 So that's our expectation, and that's
15 pretty much the scope that relates to this.

16 MEMBER REMPE: The one thing I didn't hear
17 you discuss but you did discuss at the last
18 subcommittee meeting is the guidance document that
19 will be generated after this NUREG is done. And so
20 could I have your --

21 MR. SANCAKTAR: Yes, I asked, and as I
22 mentioned at the time, what form they are interested
23 in seeing it. And they at that -- sorry. They
24 indicated interest in a RAS section --

25 MEMBER STETKAR: Just for RASP? What is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 RASP?

2 MR. SANCAKTAR: That's a very good
3 question. Risk Assessment Standard --

4 UNIDENTIFIED SPEAKER: Risk Assessment
5 Standard --

6 MR. COYNE: Standardization Process. It's
7 a name that had meaning. He's said LOCA. No, I know
8 what it is, but it's not like LOCA for the public.
9 This is a public meeting.

10 MR. SANCAKTAR: Oh, yeah, you're right,
11 sorry.

12 MR. COYNE: Risk Assessment
13 Standardization Project.

14 MR. SANCAKTAR: Section, a technical
15 description of RASP handbook, so that they can take it
16 and put it in their format of more guidance for the
17 actual practitioners. And I already put together, I
18 distilled the PRA portion of this to about 50 pages.
19 So I prepared something which I thought was pretty,
20 which I hoped to be useful in a practical way.

21 And so we are going to see how the
22 response will be, if that's a satisfactory format and
23 detail, then we'll have that document that will be
24 consistent with this NUREG.

25 MEMBER REMPE: Thank you. So are there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 any other questions from members?

2 At this point, I believe we should ask if
3 there's any comments that the members in the audience
4 or the public would like to provide. And if so,
5 either come up to the microphone and state your name,
6 or, assuming that the line is open --

7 UNIDENTIFIED SPEAKER: It's open.

8 MEMBER REMPE: Thank you, please state
9 your name and provide your comment. And not hearing
10 any comments --

11 MR. SCHNEIDER: Well, hang on. Hang on.
12 I just wasn't sure who's actually there. This is Ray
13 Schneider from Westinghouse. I do have one question
14 to ask. When you did the, I noticed the plot for the
15 heat trays where you basically, it looks like you
16 started to -- there's feedback on the line.

17 But when you started the calculation, it
18 looks like the finite element or the finite difference
19 calculation, whatever, was done assuming some kind of
20 boundary condition on the detailed model --

21 MEMBER REMPE: Ray, I need to stop you
22 right now because, one, you're breaking up a little
23 bit. But two, you do need to realize that this is not
24 a question and answer period. This is an opportunity
25 to provide comments, okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCHNEIDER: Well, right, so I guess
2 the, okay. I guess the comment is it doesn't look
3 like the model considers the detailed upper head and
4 upper plenum models for the combustion design, which
5 may have resulted in mixing. Which would then change
6 possibly the distribution that you're getting in the
7 hot leg, which may make the feeding of the steam
8 generator plenum a little different.

9 MEMBER REMPE: Thank you for that comment.
10 Are there any other members of the public that would
11 like to provide a comment? And hearing none, I'd like
12 to turn it back to the chairman.

13 CHAIRMAN BLEY: Thank you very much.
14 Thank you, John. Thanks, sorry for the -- at this
15 point, we're almost on schedule. We're a little bit
16 early. We are going to go off the record for the day.

17 (Whereupon, the above-entitled matter went
18 off the record at 1:57 p.m.)
19
20
21
22
23
24
25



South Texas Project Generic Safety Issue 191 Risk-Informed Resolution

Background and Overview

Lisa Regner, Senior Project Manager

Office of Nuclear Reactor Regulation
Division of Operating Reactor Licensing



Agenda

- Background
- Overview
- Licensee Methodology
- Staff Methodology
- Remaining Actions

Background

Generic Safety Issue 191

- Identification of safety issue
 - Sump Strainer Impacts
 - In-Vessel Impacts
- Staff developed three options, approved by the Commission
 - Option 1 *Compliance based on approved models*
 - Option 2 *Mitigative measures and alternative methods*
 - A. Deterministic – refined in-vessel testing
 - B. Risk-informed - STPNOC pilot
 - Option 3 *Different treatment for suction strainer and in-vessel effects*
- Other plants that plan to use Option 2B:
 - Calvert Cliffs, Vogtle, St. Lucie, Diablo Canyon, Point Beach, Turkey Point, Palisades, Callaway, Wolf Creek, Seabrook

Overview

South Texas Project Review


- Original request fully risk-informed
- CASA Grande
- Requests for additional information
- Public meetings
- Audits

Licensee Methodology

Risk over Deterministic (RoverD)

- Problems with original submittal
 - Uncertainties with head loss, chemical effects, debris transport timing, others
 - Epoxy coatings contributions
 - In-core thermal-hydraulic analysis
- RoverD was the significant turning point
- RoverD uses deterministic testing and analysis combined with probabilistic risk analysis (PRA)
- Reduced uncertainty in original submittal

Risk over Deterministic Methodology




Staff Methodology

- Bases of review
 - **10 CFR 50.46** ECCS Performance Criteria
 - **NEI 04-07** “Pressurized Water Reactor Containment Sump Evaluation Methodology,”
 - **WCAP-16793** “Evaluation of Long Term Cooling Considering Particulate, Fibrous and Chemical Debris in the Recirculating Fluid,”
 - **Regulatory Guide (RG) 1.182** “Water Sources for Long-Term Recirculation Cooling Following a Loss-of-Coolant Accident;”
 - **RG 1.174** “An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decision on Plant-Specific Changes to the Licensing Basis”
- Technical Specifications change
- Structure of the staff’s safety evaluation
- 5 Key Principles of Risk-Informed Regulation

Staff Methodology

Five Key Principles of Risk-Informed Regulation



Remaining Actions

- Complete concurrence process
- Resolve ACRS comments
- Coordinate issuance of final decision with internal and external stakeholders
- Issue final decision



STP Nuclear Operating Co.
Risk-Informed Approach to
Generic Safety Issue-191 and
Closure of GL2004-02:
Assessment of Debris Accumulation on
PWR Sump Performance

ACRS Full Committee Meeting
May 4, 2017

Introductions

- **Introductions, Speakers**
 - Mike Murray, Manager Regulatory Affairs, STPNOC
 - Ernie Kee, Risk-Informed GSI-191 Technical Team Lead, STPNOC
 - Wes Schulz, Design Engineering, STPNOC
 - Wayne Harrison, Risk-Informed GSI-191 Licensing, STPNOC
- **Additional STPNOC Attendees**
 - David Rencurrel, Senior Vice President, Operations, STPNOC
 - Rob Engen, Engineering Projects Manager, STPNOC
 - Steve Blossom, Risk-Informed GSI-191 Project Manager, STPNOC
 - Drew Richards, Licensing, STPNOC

Meeting Purpose

- Brief overview of history of STPNOC's risk-informed GSI-191 application
- Describe the risk-informed treatment of debris in the current “Risk over Deterministic” (RoverD) methodology and present results of the RoverD analysis

Agenda

- STP GSI-191/GL2004 Related Actions – Wayne Harrison
- General overview of the evolution of the STPNOC licensing application - Wayne Harrison
- General overview of the RoverD methodology – Ernie Kee
- Testing and deterministic element of RoverD – Wes Schulz
- Determination of governing break size and description of process for risk quantification – Ernie Kee
- In-vessel effects and thermal hydraulic analyses – Ernie Kee
- Quantitative Results – Ernie Kee
- Regulatory implementation – Wayne Harrison
- Closure – Mike Murray

STP GSI-191/GL2004 Related Actions

General overview of the evolution of the
STPNOC licensing application

Wayne Harrison

STP GSI-191/GL2004-02 Related Actions

- STP Units 1 & 2 have fibrous insulation on RCS
 - Large burden associated with insulation removal
 - Real occupational dose
 - Cost
- Actions taken
 - Replaced original three 155 ft² strainers with three new 1818 ft² strainers
 - Weld mitigation (overlay, replacement SG welds with low PWSCC susceptibility material, MSIP)
 - Replaced Marinite[®] insulation with NUKON


STPNOC Licensing Application

- January 2013: STPNOC requests exemptions from regulations that would enable the use of risk-informed methods where deterministic methods were previously required.
- Comprehensive model of debris generation and transport phenomena
- Coupled thermal hydraulic analyses
- Conditional failure probabilities input to STP PRA
- In order to reduce the complexity and scope of scenarios to review, in December 2014, STPNOC began a RoverD approach to bound uncertainties

General overview of the RoverD methodology

Ernie Kee

RoverD Process Overview



General Overview of RoverD Methodology

- RoverD simplifies complex risk assessment by using deterministic test data and bounding analyses
- Bounds on uncertainties make the assessment tractable, reviewable, and easily understood
- The STP PRA used to supplement the RoverD assessment with a few, easily understood evaluations

High Level Overview

- Ensure tested fine fiber amounts bound all tested debris species on filter screens and fuel assemblies
- Assume scenarios that exceed tested fine fiber amounts lead to core damage and assess risk
- Confirm containment integrity is maintained for defense-in-depth


Testing and Deterministic Element of RoverD

Wes Schulz

Insulation



Original Strainer (155 Sq. Ft.)



New Strainer (1818 Sq.Ft.)



Zone of Influence for 31" Pipe Break




Figure 5.4.1 – Illustration of 17D Nukon ZOI for a 31" DEGB

Elements of Nov 2007 GL2004-02 Response Content Guidance

- Break Selection
- Debris Generation (ZOI)
- Debris Characteristics
- Latent Debris
- Debris Transport
- Head Loss and Vortexing
- Net Positive Suction Head
- Coatings Evaluation
- Screen Modification Package
- Sump Structural Analysis
- Upstream Effects
- Downstream Effects
- Chemical Effects
- Debris Source Term

Flume Test Description

- July 2008 flume testing at Alden Research Laboratory to satisfy GL 2004-02
- One full-size STP strainer module at design flow (20 modules per sump)
- Fiber, particle, and chemical loads scaled for 2 trains (out of 3) operating
- Flume channel designed to emulate approach velocity and turbulence

Strainer Head Loss Test Debris

Debris forms included in test:

- Low Density Fiber Glass fine and small fibers
- Particulates, Microtherm[®], and Marinite[®] board particulates, latent dust and dirt
- Chemical precipitates representing 30 days of containment spray operation
- Coatings, zinc, epoxy, polyamide primer, alkyds, baked enamel

Reconciliation of Debris Used in Test

- Calcium Silicate (Marinite[®]) insulation was used in test. However this insulation type has since been removed from the containment building
- Subsequent analysis showed that the Microtherm[®] test amount exceeded that calculated to transport
- Subsequent analysis showed that the amounts of coatings particulate debris calculated to transport were under-predicted compared to the test
- The tested amounts of Marinite[®] and Microtherm[®] were shown to compensate for the under-prediction for the coatings particulates

Results

- Debris preparation and introduction procedures acceptable to NRC Staff
- Debris bed that formed with large quantity of particulate in combination with chemical load did not show need for additional thin bed testing
- Approximately half of head loss was due to chemical precipitates
- Successful test satisfies failure concerns up to the level of the tested debris loading
- Direct comparison of break spectrum to test results eliminates need for head-loss correlation

RoverD Risk Element and Results

Ernie Kee

Risk Element of RoverD

- RoverD scenarios begin with a break at a particular location (many thousands of scenarios are created)
- Use CASA Grande to deterministically calculate debris generation, transport, and erosion to the RCB floor pool
- Scenarios must meet deterministic criteria (upstream, downstream, in-vessel, RCB integrity criteria are met) or be categorized as risk-informed

Risk Element of RoverD

- Scenarios that introduce more fine fiber than tested are assigned to the risk-informed category
- Fetch the smallest break size among any at the location to be used for risk estimates
- Interpret NUREG 1829 for total frequency of risk-informed scenarios and assign to core damage to determine Δ CDF
- Calculate Δ LERF from PRA assessment

HLB PCT Simulations

- Assumes core fuel assemblies and core barrel bypass channels are fully blocked
- Thermal-hydraulic simulations show core cooling requirements are met for largest HLB break that is deterministically acceptable (16")

CLB - Core Fiber Analyses

- Uncertainty in core fiber buildup in CLB is assessed using bounding limiting analyses for strainer flow and RCB floor pool fiber concentrations
- The worst case fiber buildup cases show that the industry bounding fuel fiber cooling test (WCAP 16793) criteria are met

Single Train Assumption (ACRS Subcommittee Question)

- With CS and ECCS pumps running, the total strainer flow in the strainer is 7220 gpm, or about 200 gpm more than for the tested, 2 train flow
- Using the deterministic test, full flow on a single strainer is not bounded.
- Single train scenarios can be added to the risk-informed category or screened based on risk evaluation

Risk Assessment Results

- Measures taken by STPNOC minimize the risk of concerns raised in GSI-191 (Δ CDF - $1.50E-07$, Δ LERF - $3.75E-10$)
- Significant safety margin is included
- Defense in depth is maintained
- Results from different approaches consistently show minimal risk from the concerns raised in GSI-191

Summary

- RoverD is a framework that makes GSI-191 risk assessment understandable and easy to review through use of conservative testing and bounding analyses.
- Scenarios fall into two categories by application of accepted testing methods and bounding analyses
- Many additional supporting tests and analyses help support the conclusions and are publically available on the docket and other academic literature

Regulatory implementation

Wayne Harrison

Regulatory Implementation

- Debris-specific action for Mode 3 and above ECCS and CSS Technical Specifications
- UFSAR changes
- Exemptions to permit use of risk-informed approach instead of prescribed deterministic methodology

Regulatory Implementation

ECCS Technical Specification change (CSS similar)

With less than the required flow paths OPERABLE solely due to potential effects of LOCA generated and transported debris that exceeds analyzed amounts, perform the following:

1. Immediately initiate action to implement compensatory actions,
- AND
2. Within 90 days restore the affected flowpath(s) to OPERABLE status,

OR

Be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.

Closure

Mike Murray

Conclusions

- The RoverD process incorporates all aspects of the debris issue
 - GL2004-02 closure
 - Deterministic (testing for fiber and chemical effects)
 - Debris generation and transport
 - In-core effects
 - Risk-informed evaluation
- RoverD meets RG 1.174 acceptance guidelines with defense in depth and safety margin

Staff Review of STP GSI-191 LAR


Principle 1: Meets Current Regulations

Lisa Regner, Senior Project Manager

Office of Nuclear Reactor Regulation



Staff Methodology



* Principles of Risk-informed Integrated Decisionmaking from Regulatory Guide 1.174, Rev. 2, "An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant Specific Changes to the Licensing Basis" (ADAMS ML100910006).

Principle 1

Risk-Informed Regulation

“The proposed change meets current regulations unless it is explicitly related to a requested exemption or rule change.”

- 10 CFR 50.46c rulemaking status
- Exemptions requested from use of deterministic analysis method
 - Acceptance Criteria for emergency core cooling systems (ECCS)
 - General Design Criteria associated with ECCS, containment heat removal, and containment atmosphere cleanup

Staff Review of STP GSI-191 LAR


Principle 2: Defense-In-Depth
Principle 3: Safety Margins

Steve Smith, Senior Reactor Systems Engineer

Office of Nuclear Reactor Regulation




Integrated Decisionmaking



* Principles of Risk-informed Integrated Decisionmaking from Regulatory Guide 1.174, Rev. 2, "An Approach for Using Probabilistic Risk Assessment in Risk-informed Decisions on Plant specific Change to the Licensing Basis" (ADAMS ML100910006).

Risk over Deterministic Methodology



Principles 2 and 3

Safety Margins

Defense-In-Depth

- Licensee met guidance of RG 1.174 and listed significant Safety Margins and Defense-In-Depth (DiD)
- Safety Margins include construction and inspection per industry codes and the use of licensing basis values when assigning strainer failure criteria.
- DiD includes actions identified that are taken in response to the loss of the normal ECCS function. DiD also includes verification that balance is maintained among prevention and mitigation, redundancy is maintained, barrier independence is maintained, etc.

Principle 4

Deterministic Inputs to Risk Analysis

- Debris Source Term
 - Used NRC approved guidance for all areas
 - Calculations performed in CASA Grande
 - Differences from typical deterministic evaluations
 - For partial breaks, all weld locations evaluated for multiple orientations instead of focusing on the limiting large break
 - Double-ended guillotine break (DEGB) source term uses the same method as typical deterministic calculations
 - Source term calculated for each break and compared against tested amount
 - The most conservative orientation was selected for partial breaks at each weld location
 - Assumptions and calculations independently verified by SwRI

Principle 4

Deterministic Inputs to Risk Analysis

- Debris Transport – Strainer Evaluation
 - Used NRC approved guidance implemented via CASA Grande
- Debris Transport – In-Vessel Effects
 - Fiber penetration determined via testing
 - Used conservative bypass values from testing
 - Calculated fiber amounts arriving at the core for cold-leg breaks considering varying plant states (pump combinations)
 - Determined fiber amount reaching the core is small in all cases (2 g/FA design basis, 4 g/FA 1 LHSI, 7 g/FA 1 HHSI)
 - Calculations independently validated by SwRI


Principle 4

Deterministic Inputs to Risk Analysis

- Impact of Debris – Strainer
 - Strainer evaluated at tested debris load/dP for net positive suction head, structural, deaeration, vortexing, and flashing
 - Testing and evaluations were performed using staff approved guidance
 - Testing shows that increasing fiber amounts results in greater head losses
 - Majority of breaks were bounded by 2008 test results
 - Some breaks generate much larger debris amounts

Principle 4

Debris Generation Amount



Principle 4

Deterministic Inputs to Risk Analysis

- Impact of Debris – In-vessel – Cold-Leg Break
 - Debris amounts low enough to permit adequate cooling flow to the core based on WCAP-16793 findings
 - Boric Acid Precipitation not resolved by the LAR because staff has no basis to conclude that any amount of debris will not reduce mixing with the lower plenum
 - Previous staff conclusions indicate that the STP debris amounts do not result in a significant impact to boric acid precipitation (BAP) timing conclusions currently assumed by STP
 - Licensee to address BAP for the CL break at a later time

Staff Review of STP GSI-191 LAR

Deterministic In-vessel

Steve Smith

Joshua Kaizer, PhD

Division of Safety Systems

Office of Nuclear Reactor Regulation



In-Vessel Deterministic: Review Goal

Goal

- To determine if the LTCC Evaluation Model (EM) provided credible results which could be trusted for reactor safety analysis.

Solution

- All large breaks were treated with risk (removes the need to model complex phenomena)
- Focus only on “long term” portion of the event (removes the need to validate complex phenomena associated with blowdown, refill, reflood)

In-Vessel Deterministic: Review Scope

| Break Size | Hot-Leg | Cold-Leg |
|-----------------------|---------------|----------|
| Small | LTCC EM | RoverD |
| Medium (< 16") | LTCC EM | RoverD |
| Large ($\geq 16''$) | Risk Informed | RoverD |

Criteria (WCAP-16793)

1. Max PCT < 800 °F* - LTCC EM (SRP 15.0.2)
2. Deposit thickness < 0.050 inches

* Preferably, not above saturation (reduces complexity)

In-Vessel Deterministic: Summary

Conservatism / Simplifications

- full core blockage
- ignoring flow through the barrel-baffle region
- ignoring flow through the holes between the barrel-baffle region and the core
- biasing key input parameters conservatively
- using a conservative counter current flow limitation model and core modeling

Simplified hot leg break simulation

Staff Review of STP GSI-191 LAR


Principle 4: Risk Principle 5: Performance Monitoring

CJ Fong, PE, Team Leader
Candace Pfefferkorn de Messieres, PhD, Reliability and Risk Analyst

Office of Nuclear Reactor Regulation
Division of Risk Assessment
Risk Informed Licensing




Integrated Decisionmaking



* Principles of Risk-informed Integrated Decisionmaking from Regulatory Guide 1.174, Rev. 2, "An Approach for Using Probabilistic Risk Assessment in Risk-informed Decisions on Plant-specific Change to the Licensing Basis" (ADAMS ML100910006).


Staff relied on existing framework in RG 1.174



$$\Delta CDF = CDF \text{ with debris} - CDF \text{ no debris}$$

Major areas reviewed by the staff

- Was risk attributable to debris (Δ CDF, Δ LERF) calculated in an acceptable manner?
 - **Initiating Event Frequencies**
 - Plant configurations (pump combinations)
 - **Break selection**
 - Scenario development
 - ...
 - Sensitivity and Uncertainty Analyses
- Is the base PRA model acceptable?
 - Scope
 - Level of detail
 - Technical adequacy



The STPNOC Systematic Risk Assessment Key Assumptions

1. Considered both the geometric and arithmetic mean aggregation schemes
2. LOCA frequency allocated to various break locations according only to break size (e.g. "Top down")
3. Considered complete vs. partial breaks.
 - In the "continuum break" assumption a complete break of a given size in one pipe is equally as likely as a partial break of the same size in a larger pipe.
 - In the "DEGB only" assumption, only complete, DEGBs were evaluated.

Staff Performed a Bounding Calculation to Evaluate all Key Assumptions


- Staff applied the conservative, upper bound approach presented to the ACRS during discussions on draft RG 1.229*

$$\Delta CDF_{debris} = f(x_{min})$$

x_{min} = smallest critical break size

$f(x_{min})$ = exceedance frequency using arithmetic mean

Staff Explored Various Models and Assumptions when Evaluating Risk



*assumes core damage for all breaks ≥ 2 inches for one train case

Principle 4

Summary of Key Criteria

- The licensee PRA is of the appropriate scope, level of detail, and technical adequacy.
- The risk-informed approach used by the licensee to address the effects of debris on long-term core cooling is consistent with approved practices.
- The increase in risk meets the risk acceptance guidelines as defined RG 1.174.

Principle 5

Performance Monitoring

- Risk analysis reviewed/updated every 48 months
- Procedures/controls have been developed to prevent/mitigate debris in containment (e.g. new TS and programs)
- NRC is notified if acceptance guidelines exceeded
- STP licensing basis (UFSAR) will specify key methods and assumptions that impact results

Principles 4 and 5 Summary

- STPNOC appropriately identified the scenarios that contribute to the increase in risk due to debris (ΔCDF_{debris} , $\Delta LERF_{debris}$)
- There is a lack of consensus for some assumptions in STPNOC's risk calculations
- Bounding calculation addresses lack of consensus and provides confidence that risk is within acceptance guidelines
- Performance monitoring approach is consistent with NRC guidance

ACRS Subcommittee Topics

- Containment Spray System flow rate for single train operation and resulting net positive suction head for sump pump
- Reason for delta CDF decrease for continuum break model when critical break size decreased
- Expected primary pressure transitioning from Mode 3 to Mode 4 and required number of ECCS trains

Overall Summary

- STP acceptably evaluated the impact of debris
- STP appropriately considered both risk and deterministic aspects in the submittal
- Most break scenarios are addressed using conservative deterministic methods
- STP's LTCC evaluation method and simulations are conservative and meet acceptance criteria
- STP's debris analyses meet the key principles of risk-informed regulation
- STP's PRA results show that the change in risk is very small

Questions?

A Probabilistic Risk Assessment of Consequential SGTR (C-SGTR) for a Westinghouse and a Combustion Engineering Plants

**With Thermally-Treated Alloy 600 and 690 Steam
Generator Tubes**

**U.S. NRC/RES, IESS presentation to
ACRS**

May 4, 2017

Purpose and Background

- NRR User Need Request “Developing Analytical Bases and Guidance for Future Risk Assessments of Consequential Steam Generator Tube Rupture (C-SGTR) Events” issued December 2009
 - Requested development of improved analytical bases and guidance for probabilistic risk assessments of C-SGTR events
- Subsequent to an April 2011 ACRS sub-committee briefing, NRR Management requested RES to restructure project to focus on near-term deliverables and to allow for an incremental approach
- Informal meetings with lead ACRS member for C-SGTR issues (Dr. Rempe) held January 2012, January 2013, and April 2013

Purpose and Background - 2

- ACRS full-committee meeting in May 2013
- Staff prepared a draft NUREG-2195
- ACRS Sub-committee briefing in April 2015
- Since the last meeting:
 - ACRS member comments reviewed and addressed (ML16315A250)
 - Draft NUREG-2195 processed and issued for public comment (ML16134A029) – May 2016
 - Public comments reviewed and addressed (ML16315A251)
 - NUREG-2195 revised (ML16315A253)

Recent Work and Path Forward

- ACRS Subcommittee meeting held on December 2016
- ACRS member comments were addressed and NUREG was further revised (ML17082A324)
- Next actions in the project are
 - Have the draft NUREG 2195 go through NRC technical editing process
 - Send the edited version to NRC publishing
- Expect to publish NUREG 2195 in the calendar year 2017

Outline of today's presentation

- Today's presentation focuses on current status and Thermal Hydraulic aspects of the C-SGTR project
- Presentation contains 3 sections:
 - Current status of C-SGTR Project
 - Thermal Hydraulic Overview of C-SGTR
 - Overview and proposed resolution of comments on thermal hydraulic work

C-SGTR Project

Pilot Risk Assessment of Consequential SG tube rupture (Pressure Induced/Creep Rupture) for a Westinghouse and a CE plant consisting of three elements

- Deterministic based Element
 - TH evaluation (MELCOR/RELAP) – informed by CFD
 - Finite element Analysis (Abaqus)
- Performance based Element
 - Failure probabilities (Calculator)
 - Flaw Characteristics/Statistics
- Risk-Informed Element
 - Simplified CDF
 - Conservative LERF

C-SGTR Project (2)

- Involved work scope by 3 RES divisions including 4 branches
- T&H and structure/materials related studies were mostly done in-house; PRA work was contracted out
- During its current work period of 7 years, the project competed for resources with other projects, including Fukushima-related ones.

Severe Accident-Induced Steam Generator Tube Rupture (SGTR)

Thermal Hydraulic Overview of CSGTR

Michael Salay

NRC – Office of Nuclear Regulatory Research

Consequential Steam Generator Tube Rupture (C-SGTR) ACRS Briefing

May 4, 2017

Topics


- CSGTR Scenario Description
- TH analyses
- Method (CFD & System Code)
- Experimental Basis
- Differences Between CE and Westinghouse Plants

The Station Blackout


- A low probability station blackout event with immediate or subsequent loss of feed water to the steam generators.
- Reactor inventory boils off resulting in fuel damage and high temperature and high pressure conditions within RCS.
- Failure of the RCS boundary is induced by these conditions.
 - If SG tubes fail first, then a flow path is created that bypasses the containment
 - Failures of other RCS components (hot leg or surge line), RCS blow down into the containment
 - Determining SG tubes failure is important in consequence analysis

A Fast Westinghouse Scenario RCS failure within 4 hours

- loss of offsite power, failure of diesels, and failure of auxiliary feedwater systems
- primary inventory lost through reactor coolant pump seals. Secondary side boils off
- secondary side dry, primary inventory lost through safety valve cycling and pump seals
- loop natural circulation stops as primary inventory falls in SG tubes.
- natural circulation of superheated steam begins as inventory falls below hot leg. Core and system heat up.
- Core uncovers, core oxidizes and produces significant power, system heat up accelerates and induced failure is predicted for RCS components.
- More likely scenarios involve some auxiliary feedwater or operator actions that significantly delay the failure time.



RCS Structure Temperatures – Fast Westinghouse Scenario



RCS Points of interest and modeling considerations


Different oxidation and melting temperatures

Wall thickness indicative of thermal response times

SL – 1.5 inch wall - moderate T

HL – 2.5 inch wall - high T

SG tube – thin Wall (0.050") lower T



SG tube ruptures provide a path for fission products to bypass containment.

Rapid temperature rise and pressure difference leads to induced failure.

- failure location affects consequences

RCS Points of interest and modeling considerations

- Pressurizer draining and surge line orientation
- Primary relief valve behavior

- Shell heat loss
- SG depressurization

Different oxidation and melting temperatures

Wall thickness indicative of thermal response times

SL – 1.5 inch wall - moderate T

HL – 2.5 inch wall - high T


SG tube – thin Wall (0.050") lower T

- Tube heat transfer
- Secondary flows
- Tube mass flow fraction
- Leakage
- Tube plugging

Natural recirc core bypass flow

SG tube ruptures provide a path for fission products to bypass containment.

- Core oxidation rate
- Core blockage
- Nodalization
- Natural circulation
- Instrument tube failure



- Downcomer clearing
- Nodalization

- Loop seal clearing
- RCP suction height

- Inlet plenum mixing
- Recirculation ratio
- Plume T distribution

- HL Flow rate
- Entrainment
- Radiation modeling
- Entrance effects

Rapid temperature rise and pressure difference leads to induced failure.

- failure location affects consequences

High-Dry-Low

Primary Side

High Pressure

* no significant leakage to reduce pressure



Secondary Side

Dry


* Loss of water allows tubes to heat up

Low Pressure


* Secondary side leakage increases pressure difference (i.e. mechanical load on tube wall)

SG tube wall

Two Flow Patterns - PWRs with U-Tube SGs




full-loop natural circulation




Counter-current natural circulation

Full-Loop Natural Circulation

- Water cleared from the reactor coolant pump loop seal (and lower downcomer).
- Loop seal clearing is affected by:
 - depth of the pump loop seal and water temperature
 - reactor coolant pump seal leakage rate and elevation
 - primary side depressurization rates
 - downcomer bypass flows
- Westinghouse PWR studies have indicated that loop seals are more likely to remain blocked with water.
- Careful modeling and benchmarking is important to build confidence in predictions of loop seal clearing.
- Full loop circulation reduces mixing of the hot gasses that enter the SG tube bundle. A severe thermal challenge.
- System analysis tools such as MELCOR or SCDAP/RELAP5 are used to predict the system flows and heat transfer.



Counter-Current Natural Circulation



- With the pump loop seal filled with water, a counter-current flow field is established.
 - This flow pattern mixes the hot gases with cooler flows returning from the SG. The thermal challenge to the tubes is reduced but not eliminated.
- System code models require external information to ensure consistency:
 - hot leg flows, mixing, and heat transfer
 - inlet plenum mixing and entrainment
 - pressurizer surge line mixing
 - SG tube bundle flows, temperatures, and distribution
- System codes account for the overall response but are not designed to explicitly predict the three dimensional mixing and entrainment.
 - MELCOR and SCDAP/R5 models are adjusted to ensure consistency with experiments and/or CFD predictions


TH Analyses

- Westinghouse TH analyses performed for the Steam Generator Action Plan (SGAP)
 - Documented in NUREG/CR-6995
 - TH analyses for Combustion Engineering (CE) plants did not receive the same level of attention
- B&W plants not analyzed - vigorous natural circulation flows not expected
- Westinghouse and Combustion Engineering TH analyses used for current work
 - TH analyses conducted with CE under CSGTR project

TH Analyses (2)

- Use system code and CFD code
 - CFD predicts spatial flow and temperature distributions
 - System code predicts transient behavior
 - Uses CFD results for modeling
 - Results can be combined with those of CFD to obtain a transient spatial temperature distribution
- CFD Validated against Westinghouse 1/7th scale experiments
 - Built up to prototypical SG geometries
- Multiple sensitivity studies on parameters



CFD Support Modeling



- Hot Leg Flow Rate - C_d
- Inlet Plenum Mixing - f
- SG Tube Bundle Flow and T
 - Hot tube fraction
 - recirc ratio - $r = m_t / m$
- Distribution of Temperatures
 - T_m - Normalized T
- Surge Line Split/Mixing

System Code


Hot leg and Inlet Plenum Nodalization




SGTR Behavior Differences between CE and Westinghouse Plants

- CE has Less mixing of hot gases before reaching SG tube inlets
 - Lower hot leg Length/Diameter ratio
 - Some CE plants have shallower inlet plena
- In CE SG tubes are exposed to similar gas temperatures as hot legs
- Under certain conditions unflawed tubes could rupture before hot legs
- Unlike for the rupture of a flawed tube, multiple unflawed tubes could potentially reach the failure condition nearly simultaneously resulting in a rupture large enough to depressurize the RCS sufficiently fast to prevent failure of other RCS components.

The CE inlet plenum (compared to W model 51)



CFD Predictions - Westinghouse and CE (hottest tube region circled)




(temperature contours on vertical centerline plane of hot leg)

MELCOR CE Calculations


- Objectives:
 - Provide TH results for CE plants to be used to calculate component failure using:
 - CSGTR Calculator
 - Finite Element calculations
 - Provide scoping component failure calculations
 - Provide FP releases
- Analyses (scoping and component-failure-suppressed calculations)
 - Accidents
 - Short terms station blackout (stsbo) (AFW fails to start)
 - Long term station blackout (ltsbo)
 - Variations
 - Operator actions/relief valve behavior
 - RCP seal leakage
- Comparison against RELAP5 CE calculation
- Uncertainty analysis to determine impact of TH uncertainty on failure timing

Example MELCOR CE results

Impact of RCP seal leakage sensitivity



Effect on system pressures



Effect on Loop B structure temperatures

Possible future CE TH work

- Interesting but deferred work because of resource limitations
 - More detailed spatial temperature distribution
 - Assessment of TH factors that impact relative component failure timing
 - Analysis of loop seal clearing
 - Water hold up in SG, flooding / counter-current flow
 - Water also held up in previous SGAP calculations
 - Detailed evaluation of FP release
 - Current focus on TH input, not FP release
 - Didn't rerun cases to solely extract FP release behavior

Severe Accident-Induced Steam Generator Tube Rupture (SGTR)

Overview and Proposed Resolution of Comments on TH Work

Michael Salay

NRC – Office of Nuclear Regulatory Research


Consequential Steam Generator Tube Rupture (C-SGTR) ACRS Briefing

May 24, 2017

Recent ACRS questions

- CE tubesheet inlet T distributions
- Impact on Loop seal clearing
- Expected impact of models in later versions of MELCOR
- Uncertainties in TH analyses

CE tubesheet inlet T distribution



Loop seal clearing (1/2)

- Q: Many studies out there conclude that loops seals would clear before core damage. Do any of scenarios indicate that?
- Loop seal clearing was studied extensively for Westinghouse for SGAP and several mechanisms studied and documented in NUREG/CR-6995
 - Generated parameter maps for conditions under which loop seals would clear or stay intact
 - $f(\text{RCP pump seal leak rate, TDAFW operation time, number of PORV opened, time of operator action})$
 - Found to also be affected by core bypass area and nodalization
 - Concluded that uncertainty remains regarding whether loop seals would clear.

Loop seal clearing (2/2)

- Loop seals did not clear in any of the MELCOR CE calculations
- Initial scoping work for loop seal clearing CE built upon the SGAP analyses
- Analysis of loop seal clearing eliminated upon work scope reduction - Issue not explored fully for CE
 - Loop seal clearing is more important for Westinghouse plants because this clearing exposes SG tubes to gases nearly as hot as those in the hot leg
 - For the CE geometry studied, the hottest gases entering SG tube bundle are nearly as hot as those in the hot leg
 - Loop seal clearing not as important

Impact of Updated MELCOR Models (1/3)

- Q: MELCOR models used in the SOARCA analysis resulted in significant changes in timing of events. Do these changes affect the conclusions of this study?
- Most TH analysis work done primarily in 2011 and 2012. Some cases recalculated in 2013.
- MELCOR 1.8.6 used for CE CSGTR analysis
- Different MELCOR 2 versions used in different SOARCA analyses

Impact of Updated MELCOR Models (2/3)

- SOARCA Uncertainty Analysis for Surry short term station blackout compared event timing of MELCOR 1.8.6 to MELCOR 2.1
- Major event timing very close up to and beyond component creep failure
- No significant change expected to CE MELCOR calculations models

Event times for Surry STSBO (hh:mm)

| Event | 1.86 | 2.1 |
|--------------------------|-------|-------|
| SBO | 00:00 | 00:00 |
| SG dryout | 01:16 | 01:14 |
| Start of fuel heatup | 02:19 | 02:20 |
| RCP seal failure | 02:45 | 02:47 |
| First FP gap releases | 02:57 | 02:57 |
| HL creep rupture failure | 03:45 | 03:45 |
| Accumulators start | 03:45 | 03:46 |

Impact of Updated MELCOR Models (3/3)

- There have been phenomenon model updates in MELCOR subsequent to Surry analysis:
 - Update to Lipinski debris bed dryout model
 - Update to quenching models
- Both of these models affect behavior during reflood
- The CE analysis concerns system behavior at high pressure before accumulator injection
- The use of the updated models are not expected to alter report conclusions

CE TH Uncertainty Analysis (1/6)

- Additional detail on MELCOR uncertainty analysis requested
- The impact of uncertainties in TH considered upon initial deck creation: “How much do uncertainties in TH affect failure timing and releases?”
- SNL performed TH uncertainty analysis on early stsbo model with deck prior to addition of hot tube and other modifications
 - Used Average Hot tube for SG with stress multiplier of 2
 - Expect results to be representative of failure timing variation resulting from TH variations
 - NOT necessarily expected to be representative of component or relative failure time
- Sampled TH parameters and observed effect on predicted absolute component failure timing and relative SG-tube-to-RCS-component failure timing
 - “simple” Monte Carlo sampling
 - 100 realizations
 - Analyzed with STEPWISE regression software
- TH uncertainty analysis parameters chosen based on those in NUREG/CR-6285 and NUREG/CR-6995:

CE TH Uncertainty Analysis (2/6)


Sampled Parameters

| Parameter | Range |
|---|-----------------|
| PORV and SRV Valve discharge coefficients | 0.7 - 1.1 |
| Zr oxidation rate constant | 14.8 -44.4 |
| Mixing parameters | |
| Cd | 0.064 - 0.0863 |
| Recirculation ratio | 1.1 - 1.4 |
| SG tube outer wall heat transfer multiplier | 0.5 - 1.5 |
| Hot leg wall emissivity | 0.3 – 0.9 |
| RCS to containment heat transfer multiplier | 2.8075 – 8.4225 |

CE TH Uncertainty Analysis (3/6)

Component failure time distributions


Probabilities at 95% Confidence Interval



CE TH Uncertainty Analysis (4/6)

Relative component failure time distribution

Probabilities at 95% Confidence Interval



CE TH Uncertainty Analysis (5/6)

What affected absolute failure timing?

R²

| Parameter (SG) | SG tube | | Parameter (HL) | Hot Leg |
|----------------------|---------|--|----------------------|---------|
| RCS to Cont HTC mult | 0.585 | | RCS to Cont HTC mult | 0.784 |
| SG wall HTC mult | 0.279 | | Mixing Cd | 0.113 |
| Zr oxidation rate | 0.06 | | Zr oxidation rate | 0.049 |
| Recirc. ratio | 0.023 | | SG wall HTC mult | 0.014 |
| Mixing Cd | 0.012 | | Recirc. ratio | 0.01 |
| PORV/SRV discharge | 0.002 | | | |

(Higher numbers indicate greater importance)

What affected relative failure timing?

CE TH uncertainty Analysis (6/6)

- Distribution of failure timings resulting from TH variation uncertainty analysis had standard deviations of:
 - ± 400 s (6 min 40 s) – SG absolute failure timing
 - ± 511 s (8.5 min) – HL absolute failure timing
 - Approximately ± 420 s (7 min) – relative SG-to-RCS component failure timing

CE TH Conclusions

- MELCOR calculations for a CE plant with replacement SGs provide input to CSGTR calculator and finite-element component failure analysis
- Relative temperature increase rates and relative component failure timing between SG tubes and other components more important for releases than absolute failure time
- Some work was deferred because of limited resources
 - Benefit determined to not be worth the expense for the project
- Received and incorporated useful feedback from ACRS and public

A Probabilistic Risk Assessment of Consequential SGTR (C-SGTR) for a Westinghouse and a Combustion Engineering Plants

**With Thermally-Treated Alloy 600 and 690 Steam
Generator Tubes**

**U.S. NRC/RES, IESS presentation to
ACRS**

May 4, 2017

Purpose and Background

- NRR User Need Request “Developing Analytical Bases and Guidance for Future Risk Assessments of Consequential Steam Generator Tube Rupture (C-SGTR) Events” issued December 2009
 - Requested development of improved analytical bases and guidance for probabilistic risk assessments of C-SGTR events
- Subsequent to an April 2011 ACRS sub-committee briefing, NRR Management requested RES to restructure project to focus on near-term deliverables and to allow for an incremental approach
- Informal meetings with lead ACRS member for C-SGTR issues (Dr. Rempe) held January 2012, January 2013, and April 2013

Purpose and Background - 2

- ACRS full-committee meeting in May 2013
- Staff prepared a draft NUREG-2195
- ACRS Sub-committee briefing in April 2015
- Since the last meeting:
 - ACRS member comments reviewed and addressed (ML16315A250)
 - Draft NUREG-2195 processed and issued for public comment (ML16134A029) – May 2016
 - Public comments reviewed and addressed (ML16315A251)
 - NUREG-2195 revised (ML16315A253)

Recent Work and Path Forward

- ACRS Subcommittee meeting held on December 2016
- ACRS member comments were addressed and NUREG was further revised (ML17082A324)
- Next actions in the project are
 - Have the draft NUREG 2195 go through NRC technical editing process
 - Send the edited version to NRC publishing
- Expect to publish NUREG 2195 in the calendar year 2017

Outline of today's presentation

- Today's presentation focuses on current status and Thermal Hydraulic aspects of the C-SGTR project
- Presentation contains 3 sections:
 - Current status of C-SGTR Project
 - Thermal Hydraulic Overview of C-SGTR
 - Overview and proposed resolution of comments on thermal hydraulic work

C-SGTR Project

Pilot Risk Assessment of Consequential SG tube rupture (Pressure Induced/Creep Rupture) for a Westinghouse and a CE plant consisting of three elements

- Deterministic based Element
 - TH evaluation (MELCOR/RELAP) – informed by CFD
 - Finite element Analysis (Abaqus)
- Performance based Element
 - Failure probabilities (Calculator)
 - Flaw Characteristics/Statistics
- Risk-Informed Element
 - Simplified CDF
 - Conservative LERF

C-SGTR Project (2)

- Involved work scope by 3 RES divisions including 4 branches
- T&H and structure/materials related studies were mostly done in-house; PRA work was contracted out
- During its current work period of 7 years, the project competed for resources with other projects, including Fukushima-related ones.

Severe Accident-Induced Steam Generator Tube Rupture (SGTR)

Thermal Hydraulic Overview of CSGTR

Michael Salay

NRC – Office of Nuclear Regulatory Research

Consequential Steam Generator Tube Rupture (C-SGTR) ACRS Briefing

May 4, 2017

Topics


- CSGTR Scenario Description
- TH analyses
- Method (CFD & System Code)
- Experimental Basis
- Differences Between CE and Westinghouse Plants

The Station Blackout


- A low probability station blackout event with immediate or subsequent loss of feed water to the steam generators.
- Reactor inventory boils off resulting in fuel damage and high temperature and high pressure conditions within RCS.
- Failure of the RCS boundary is induced by these conditions.
 - If SG tubes fail first, then a flow path is created that bypasses the containment
 - Failures of other RCS components (hot leg or surge line), RCS blow down into the containment
 - Determining SG tubes failure is important in consequence analysis

A Fast Westinghouse Scenario RCS failure within 4 hours

- loss of offsite power, failure of diesels, and failure of auxiliary feedwater systems
- primary inventory lost through reactor coolant pump seals. Secondary side boils off
- secondary side dry, primary inventory lost through safety valve cycling and pump seals
- loop natural circulation stops as primary inventory falls in SG tubes.
- natural circulation of superheated steam begins as inventory falls below hot leg. Core and system heat up.
- Core uncovers, core oxidizes and produces significant power, system heat up accelerates and induced failure is predicted for RCS components.
- More likely scenarios involve some auxiliary feedwater or operator actions that significantly delay the failure time.



RCS Structure Temperatures – Fast Westinghouse Scenario



RCS Points of interest and modeling considerations


Different oxidation and melting temperatures

Wall thickness indicative of thermal response times

SL – 1.5 inch wall - moderate T

HL – 2.5 inch wall - high T

SG tube – thin Wall (0.050") lower T



SG tube ruptures provide a path for fission products to bypass containment.

Rapid temperature rise and pressure difference leads to induced failure.

- failure location affects consequences

RCS Points of interest and modeling considerations

- Pressurizer draining and surge line orientation
- Primary relief valve behavior

- Shell heat loss
- SG depressurization

Different oxidation and melting temperatures

Wall thickness indicative of thermal response times

SL – 1.5 inch wall - moderate T

HL – 2.5 inch wall - high T


SG tube – thin Wall (0.050") lower T

- Tube heat transfer
- Secondary flows
- Tube mass flow fraction
- Leakage
- Tube plugging

Natural recirc core bypass flow

SG tube ruptures provide a path for fission products to bypass containment.

- Core oxidation rate
- Core blockage
- Nodalization
- Natural circulation
- Instrument tube failure



- Downcomer clearing
- Nodalization

- Loop seal clearing
- RCP suction height

- Inlet plenum mixing
- Recirculation ratio
- Plume T distribution

- HL Flow rate
- Entrainment
- Radiation modeling
- Entrance effects

Rapid temperature rise and pressure difference leads to induced failure.

- failure location affects consequences

High-Dry-Low

Primary Side

High Pressure

* no significant leakage to reduce pressure



Secondary Side

Dry


* Loss of water allows tubes to heat up

Low Pressure


* Secondary side leakage increases pressure difference (i.e. mechanical load on tube wall)

SG tube wall

Two Flow Patterns - PWRs with U-Tube SGs




full-loop natural circulation




Counter-current natural circulation

Full-Loop Natural Circulation

- Water cleared from the reactor coolant pump loop seal (and lower downcomer).
- Loop seal clearing is affected by:
 - depth of the pump loop seal and water temperature
 - reactor coolant pump seal leakage rate and elevation
 - primary side depressurization rates
 - downcomer bypass flows
- Westinghouse PWR studies have indicated that loop seals are more likely to remain blocked with water.
- Careful modeling and benchmarking is important to build confidence in predictions of loop seal clearing.
- Full loop circulation reduces mixing of the hot gasses that enter the SG tube bundle. A severe thermal challenge.
- System analysis tools such as MELCOR or SCDAP/RELAP5 are used to predict the system flows and heat transfer.



Counter-Current Natural Circulation



- With the pump loop seal filled with water, a counter-current flow field is established.
 - This flow pattern mixes the hot gases with cooler flows returning from the SG. The thermal challenge to the tubes is reduced but not eliminated.
- System code models require external information to ensure consistency:
 - hot leg flows, mixing, and heat transfer
 - inlet plenum mixing and entrainment
 - pressurizer surge line mixing
 - SG tube bundle flows, temperatures, and distribution
- System codes account for the overall response but are not designed to explicitly predict the three dimensional mixing and entrainment.
 - MELCOR and SCDAP/R5 models are adjusted to ensure consistency with experiments and/or CFD predictions


TH Analyses

- Westinghouse TH analyses performed for the Steam Generator Action Plan (SGAP)
 - Documented in NUREG/CR-6995
 - TH analyses for Combustion Engineering (CE) plants did not receive the same level of attention
- B&W plants not analyzed - vigorous natural circulation flows not expected
- Westinghouse and Combustion Engineering TH analyses used for current work
 - TH analyses conducted with CE under CSGTR project

TH Analyses (2)

- Use system code and CFD code
 - CFD predicts spatial flow and temperature distributions
 - System code predicts transient behavior
 - Uses CFD results for modeling
 - Results can be combined with those of CFD to obtain a transient spatial temperature distribution
- CFD Validated against Westinghouse 1/7th scale experiments
 - Built up to prototypical SG geometries
- Multiple sensitivity studies on parameters



CFD Support Modeling



- Hot Leg Flow Rate - C_d
- Inlet Plenum Mixing - f
- SG Tube Bundle Flow and T
 - Hot tube fraction
 - recirc ratio - $r = m_t / m$
- Distribution of Temperatures
 - T_m - Normalized T
- Surge Line Split/Mixing

System Code


Hot leg and Inlet Plenum Nodalization




SGTR Behavior Differences between CE and Westinghouse Plants

- CE has Less mixing of hot gases before reaching SG tube inlets
 - Lower hot leg Length/Diameter ratio
 - Some CE plants have shallower inlet plena
- In CE SG tubes are exposed to similar gas temperatures as hot legs
- Under certain conditions unflawed tubes could rupture before hot legs
- Unlike for the rupture of a flawed tube, multiple unflawed tubes could potentially reach the failure condition nearly simultaneously resulting in a rupture large enough to depressurize the RCS sufficiently fast to prevent failure of other RCS components.

The CE inlet plenum (compared to W model 51)



CFD Predictions - Westinghouse and CE (hottest tube region circled)




(temperature contours on vertical centerline plane of hot leg)

MELCOR CE Calculations


- Objectives:
 - Provide TH results for CE plants to be used to calculate component failure using:
 - CSGTR Calculator
 - Finite Element calculations
 - Provide scoping component failure calculations
 - Provide FP releases
- Analyses (scoping and component-failure-suppressed calculations)
 - Accidents
 - Short terms station blackout (stsbo) (AFW fails to start)
 - Long term station blackout (ltsbo)
 - Variations
 - Operator actions/relief valve behavior
 - RCP seal leakage
- Comparison against RELAP5 CE calculation
- Uncertainty analysis to determine impact of TH uncertainty on failure timing

Example MELCOR CE results

Impact of RCP seal leakage sensitivity



Effect on system pressures



Effect on Loop B structure temperatures

Possible future CE TH work

- Interesting but deferred work because of resource limitations
 - More detailed spatial temperature distribution
 - Assessment of TH factors that impact relative component failure timing
 - Analysis of loop seal clearing
 - Water hold up in SG, flooding / counter-current flow
 - Water also held up in previous SGAP calculations
 - Detailed evaluation of FP release
 - Current focus on TH input, not FP release
 - Didn't rerun cases to solely extract FP release behavior