



CB&I Laurens
PO Box 1199
366 Old Airport Rd.
Laurens, SC 29360
www.CBI.com

May 26, 2017

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

**SUBJECT: INTERIM 10 CFR PART 21 REPORT REGARDING INDETERMINATE
NONDESTRUCTIVE EXAMINATION (NDE) TEST REPORTS FOR V.C.
SUMMER UNITS 2 AND 3 AND VOGTLE UNITS 3 AND 4 AP1000@ PROJECTS**

On April 10, 2017 by way of interim letter CB&I Laurens notified the commission of identified indeterminate NDE inspections related to CR 584 and identified in inspection report 99901432/2017-201 in accordance with 10 CFR 21.21.

The UT thickness verification of the identified spools within the extent of condition were completed and no nonconformities were identified. This condition has been determined to not be reportable in accordance with 10CFR Part 21.

If you have any questions pertaining to this information, please contact Matt Rossignol, CB&I Laurens Quality Assurance Manager, at 864-683-3986.

Sincerely,

A handwritten signature in black ink that reads 'Matt Rossignol'.

Matt Rossignol
Quality Assurance Manager
CB&I Laurens


IE19
NRD



CB&I
366 Old Airport Road
PO Box 1199
Laurens, SC 29360
USA

GREENVILLE SC 296

25 MAY 2017 PM 1 1



060

U.S. Nuclear Regulatory Commission
Chief, Quality Assurance Vendor Inspection
Branch-2 Vendor Branch,
Division of Construction Inspection and
Operational Programs,
Office of New Reactors
Washington, DC 20555-0001

20555-0001

