

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 APR1400 Subcommittee

Docket Number: N/A

Location: Rockville, Maryland

Date: June 5, 2017

Work Order No.: NRC-3111

Pages 1-333

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

UNITED STATES OF AMERICA
 NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)

+ + + + +

APR1400 SUBCOMMITTEE

+ + + + +

MONDAY,

JUNE 5, 2017

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
 Regulatory Commission, Two White Flint North, Room
 T2B1, 11545 Rockville Pike, at 8:30 a.m., Ronald G.
 Ballinger, Chairman, presiding.

COMMITTEE MEMBERS:

RONALD G. BALLINGER, Chairman

JOSE MARCH-LEUBA, Member

DANA A. POWERS, Member

JOY REMPE, Member

PETER RICCARDELLA, Member

GORDON R. SKILLMAN, Member

JOHN W. STETKAR, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
 1323 RHODE ISLAND AVE., N.W.
 WASHINGTON, D.C. 20005-3701

DESIGNATED FEDERAL OFFICIAL:

CHRISTOPHER BROWN

ALSO PRESENT:

TONY AHN, KHNP

BUMSIK CHANG, KEPCO E&C

HOONIN CHO, KEPCO E&C

BOSUNG CHOI, KEPCO E&C

JORGE CINTRON-RIVERA, NRO

CARL CONSTANTINO, BNL

NICHOLAS HANSING, NRO

DAVID HEESZEL, NRO

JOHN HONCHARIK, NRO

TOM HOUSTON, BNL

JASON HUANA, NRO

SEOKHWAN HUR, KEPCO E&C

ATA ISTAR, NRO

HYEOK JEONG, KHNP

JIN JUNG, KHNP

DAEJEONG KIM, KEPCO E&C

JUNGHO KIM, KHNP

TAE HAN KIM, KEPCO E&C

YOUNGHOON KIM, KEPCO E&C

YUNHO KIM, KHNP

SUNGUOK KWON, KHNP

NEAL R. GROSSCOURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

YOUNGMAW KWAN, KEPCO E&C
YIU LAW, NRO
TUAN LE, NRO
JONG BO LEE, KHNP
KYUMIN LEE, KEPCO E&C
SANGGYU LEE, KHNP
YONGSUN LEE, KHNP and KEPCO E&C
CHANG-YANG LI, NRO
RENEE LI, NRO
DAEHEON LIM, KEPCO E&C
KWANGIL LIM, KEPCO E&C
SHANLAI LU, NRO
TIM LUPOLD, NRO
JOHN MA, NRO
STEVE MANNON, AECOM
TANIA MARTINEZ-NAVEDO, NRR
MIKE MCCOPPIN, NRO
JINSUO NIE, NRO
RYAN NOLAN, NRO
JIYONG OH, KHNP
CHONGHO PARK, KEPCO E&C
HONGSUN PARK, KHNP and KEPCO E&C
JAEWAN PARK, KHNP
SUNWOO PARK, NRO
SHEILA RAY, NRR

ERIC REICHELT, NRO
ROBERT ROCHE-RIVERA, NRO
TOM SCARBROUGH, NRO
ROBERT SISK, Westinghouse
EDWARD STUTZCAGE, NRO
KIKWANG SUNG, KEPCO E&C
TOMEKA TERRY, NRO
VAUGHN THOMAS, NRO
ALEXANDER TSIRIGOTIS, NRO
MARIELIZ VERA, NRO
DAVE WAGNER, AECOM
JAY WALLACE, RES
BILL WARD, NRO
DAN WIDREVITZ, NRO
YUKEN WONG, NRO
JOHN WU, NRO
JIM XU, NRO
JINKYOO YOON, KHNP and KEPCO E&C
KISEOK YOON, KEPCO E&C
SUNGHO YOU, KEPCO E&C
KWANHEE YUN, KEPCO E&C

* Present via telephone

T-A-B-L-E O-F C-O-N-T-E-N-T-S

	<u>Page</u>
Opening Remarks and Objectives.....	6
Staff Opening Remarks.....	9
KHNP Opening Remarks.....	9
Chapter 3, Design of Structures, Systems, Components, and Equipment.....	11
Break.....	69
Chapter 3, Design of Structures, Systems, Components, and Equipment (continued).....	71
Chapter 3, Design of Structures, Systems, Components, and Equipment Overview Section 3.5.2, 3.6.3, & 3.13.....	97
Chapter 3, Design of Structures, Systems, Components, and Equipment Sections 3.6.2 & 3.7-3.12.....	98
Public Comment Period.....	160
Committee Discussion.....	160

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

P R O C E E D I N G S

8:30 a.m.

CHAIRMAN BALLINGER: The meeting will now come to order. This is a meeting of the APR1400 Subcommittee of the Advisory Committee on Reactor Safeguards.

I'm Ron Ballinger, Chairman of the APR1400 Subcommittee. The ACRS members in attendance are Dick Skillman, Dana Powers will be here shortly, John Stetkar, Jose March-Leuba and Joy Rempe.

The purpose of today's meeting is for the Subcommittee to receive briefings from Korea Electric Power Corporation, KEPCO, and Korea Hydro and Nuclear Power Company, Limited, KHNP, regarding their design certification application and the NRC staff regarding their safety evaluation with open items, specific of Chapter 3, Design of Structure Systems and Components and Equipment.

The ACRS was established by statute and is governed by the Federal Advisory Committee Act, FACA.

That means that the Committee can only speak through its published letter reports.

We hold meetings to gather information to support our deliberations.

Interested parties who wish to provide

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 comments can contact our offices requesting time after
2 the meeting.

3 An announcement is published in the
4 Federal Register.

5 That said, we also set aside ten minutes
6 for comments from members of the public attending or
7 listening to our meetings.

8 Written comments are also welcome.

9 I might add, also, that Chris Brown, who's
10 here now, is the Designated Federal Official for this
11 meeting.

12 The ACRS section of the U.S. NRC public
13 website provides our charter, bylaws, letter reports
14 and full transcripts of all Full and Subcommittee
15 meetings including slides presented at the meetings.

16 The rules for participation in today's
17 meeting were announced in the Federal Register on
18 Tuesday, May 30th, 2017. The meeting was announced as
19 an open/closed public meeting. This meant that the
20 Chairman can close the meeting as needed to protect
21 information proprietary to KHNP or its vendors.

22 I believe that this is all open today.

23 No requests for making a statement to the
24 Subcommittee has been received from the public.

25 A transcript of the meeting is being kept

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and will be made available as stated in the Federal
2 Register Notice. Therefore, I would request that
3 participants of this meeting use the microphones
4 located throughout the meeting room when addressing
5 the Subcommittee.

6 Participants should first identify
7 themselves and speak with sufficient clarity and
8 volume so that they can be readily heard. And, we
9 keep going through this for every meeting, it seems.
10 It's like a social experiment but the microphones that
11 are in front up here, there's a little light on the
12 top, that's not what you press to speak. There's a
13 little button on the bottom.

14 We have a bridge line established for
15 interested members of the public to listen in. The
16 bridge number and password were published in the
17 agenda posted on the NRC public website.

18 To minimize disturbance, this public line
19 will be kept in a listen only mode. The public will
20 have an opportunity to make a statement or provide
21 comments at a designated time towards the end of this
22 meeting.

23 We request now that meeting attendees and
24 participants silence cell phones and other electronic
25 devices.

1 And, we have been joined by the
2 inestimable Peter Riccardella.

3 And by Bill Ward, NRO Project Manager to
4 introduce the presenters and start the briefing.

5 Bill?

6 MR. WARD: Thank you.

7 The staff and KHNP are pleased to present
8 one more chapter. This is the second to the last
9 meeting. We'll be done with the presentations to the
10 Subcommittee for Phase II versions from the SCE.

11 I know that it's a long chapter and it's
12 only one day. So, I wanted to point out that the
13 staff presentation will only cover certain sections
14 where there was significant issues and they'll point
15 that out later in their presentation.

16 So, we will take questions on any section
17 that's not specifically mentioned in the discussion,
18 but we look forward to being able to present that.

19 And, that's all I have today.

20 Thank you.

21 CHAIRMAN BALLINGER: The floor is yours.

22 MR. SISK: Thank you.

23 This is Bob Sisk, let me introduce Mr.
24 Yunho Kim from KHNP.

25 MR. Y. KIM: Yes, I am Yunho Kim from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 KHNP. I'm the APR1400 Project Manager. So, I have a
2 -- at this time, we have the meeting until now. So, I
3 look forward to having a good discussion today.

4 I am turn the presentation to Bob and to
5 Mr. Yoon.

6 Thank you.

7 MR. SISK: Mr. Yoon?

8 MR. YOON: Good morning, ladies and
9 gentlemen. My name is Jinkyoo Yoon, working for
10 Nuclear Engineering Department at KEPCO Engineering
11 and Construction.

12 This morning, I will -- I'm going to talk
13 about design of structures, system, component and
14 equipment of the APR1400.

15 And so, I'm very pleased to have this
16 opportunity to present the overview, outlines of
17 Chapter 3 of APR1400.

18 First of all, I think my presentation will
19 proceed that these contents.

20 The section overview is briefly introduced
21 and then each section is summarized as follows.

22 Chapter 3 consists of certain subsections
23 from 3.1, Conformance with NRC General Design
24 Criteria, through 3.13, Threaded Fasteners.

25 First of all, I'll address the key factor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 outlines of the DCD, Section 3.1 through 3.6 as a
2 representative presenter.

3 If there is a question or comments, the
4 answers will be provided by our responsible and expert
5 staff sitting on my left and in this room.

6 The rest of this DCD Section 3 will be
7 mentioned by the following presenters. Section 3.7 is
8 Yongsun Lee, 3.8 is Hoonin Cho, 3.9 is Hongsun Park.

9 And, 3.10 through 3.12 is Bosung Choi.
10 Lastly, 3.13 is presented by Hongsun Park.

11 For the NRC staff review, we only
12 submitted to this DCD document and 11 TRs, Technical
13 Evaluation Reports.

14 Now, I'm going to talk about the APR1400
15 conformance with NRC general design criteria in
16 Appendix A to 10 CFR 50.

17 This section discussed the extent to which
18 the design criteria for the plant structures, systems
19 and components important to safety meet the NRC
20 General Design Criteria specified in Appendix A to 10
21 CFR 50.

22 For each criterion, a summary was provided
23 to show how the principle design features meet the
24 criterion in the relevant DCD sections.

25 The Section 3.2 describes classification

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of SSCs according to seismic category, quality groups,
2 nuclear safety classifications.

3 The Subsection 3.2.1 describes the
4 classification of the SSCs in terms of seismic
5 activity. It used the guideline provided in the Reg
6 Guide 1.29 to meeting general design criteria, two,
7 for identifying and classifying those SSCs.

8 These SSCs are classified as Seismic
9 Category 1, 2 and 3.

10 Subsection 3.2.2 describes the various
11 equipment classifications based on -- identified to
12 meet GDC 1.

13 Quality Group A, B, C and D are classified
14 by Reg Guide 1.26.

15 3.2.3 describes the safety classes. Fluid
16 system components important to safety are classified
17 in accordance with ANSI/ANS-51.1-1983 as Safety Class
18 1, 2, 3 and non-safety class.

19 MEMBER SKILLMAN: Before you proceed, back
20 to 3.2.2, you explained quality classifications A, B,
21 C and D. Would you care to make a comment about
22 quality groups E and G?

23 You actually had six quality
24 classification groups.

25 MR. YOON: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: You put A, B, C, D and
2 then you also have E and G.

3 MR. YOON: Yes, we considered quality
4 groups as poor, A, B, C, D, as I mentioned, but --
5 excuse me, I'm not the right person to answer or to
6 provide expert steps.

7 MR. CHOI: My name is Bosung Choi. I am
8 KEPCO, Inc.'s Licensing Engineer. I'll reply to your
9 question.

10 Two other quality groups, E and G, is
11 classified to indicate the governing design course for
12 confidence. So, it is not covered by Reg Guide 1.26.

13 MEMBER SKILLMAN: Do you have the six
14 quality classifications for your Korean plant?

15 MR. CHOI: Yes.

16 MEMBER SKILLMAN: Yes, so, you follow A,
17 B, C, D, E and G for them as well?

18 MR. CHOI: Yes, right.

19 MEMBER SKILLMAN: And E and G are
20 exception categories so that you can apply seismic
21 qualification to components that aren't directly
22 associated with A, B, C, and D? It appears that
23 that's what you've attempted to do.

24 MR. CHOI: Yes.

25 MEMBER SKILLMAN: Will we have a chance to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 hear you speak about your emergency diesels and how
2 they are addressed from a seismic perspective? I
3 believe that is the category G.

4 MR. JEONG: This is Hyeok Jeong from KEPCO
5 EDG.

6 The seismic category of EDG is seismic
7 category 1. And we apply the quality group G because
8 the quality standard applied to EDG is different from
9 the quality standards defined in Reg Guide 1.26.

10 G, the quality group G is applied to the
11 safety-related systems and components that the quality
12 standards applied to different from the Reg Guide
13 1.26.

14 MEMBER SKILLMAN: Different from 1.26? I
15 understand.

16 MR. JEONG: Thank you.

17 MEMBER SKILLMAN: We'll stop here. Okay,
18 thank you.

19 MR. YOON: The Subsection 3.2.4 is the
20 risk component classifications. This detail of 2.3.2-
21 1 describes the seismic categories quality groups
22 nuclear safety classifications, quality assurance
23 classifications and quality standards.

24 In this slide, it talks about wind and
25 tornado loading which is considered in the design of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 seismic category 1 and 2 structure.

2 The design wind loading on the surface of
3 seismic category 1 and 2 SSCs subject to wind are
4 determined in accordance with ASCE/SEI 7-05.

5 Fifty-year 30 second wind gust speed is
6 determined to 145 miles per hour which corresponded to
7 the wind speed at the 33 feet above the ground for
8 exposure category C.

9 The APR1400 standard and site specific
10 plant is designed to protect SSCs listed in the
11 Appendix to Reg Guide 1.117 from tornados and
12 hurricanes.

13 The applicable design parameters for
14 tornados and hurricanes is as follows for design base
15 tornados, maximum horizontal wind speed for 10 million
16 years is 213 miles per hour as those are list one and
17 categorized in Reg Guide 1.76.

18 For design basis hurricanes, maximum wind
19 speed for 10 million years is 260 miles per hour.
20 That is the demand from the wind speed control maps
21 for hurricane prone regions of the parameters in 19
22 states presented in Reg Guide 1.221.

23 In this slide, I'll talk about the
24 standard design basis flood level which is considered
25 at the SSCs design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The design basis flood level at reactor
2 site will be determined in accordance with Reg Guide
3 1.59 and ANSI/ANS 2.8.

4 The design basis flood level of the
5 APR1400 is, at the least, 1 foot below the plant
6 grade.

7 Accordingly, all safety related SSCs
8 located on the reactor site are protected from the
9 external flood event.

10 The maximum ground water levels is 2 feet
11 below the plant grade, all seismic category 1
12 structures are designed to withstand the static and
13 dynamic forces due to the maximum ground water level.

14 The flood protection measures for seismic
15 category 1 SSCs from external sources design in
16 accordance with Reg Guide 1.1 or 2.

17 From this slide, I will speak about the
18 flood protection from internal sources.

19 The safety related SSCs are designed to
20 withstand the effect of flooding due to the natural
21 phenomena or onsite equipment failures without the
22 loss of the capability to perform their safety related
23 functions.

24 The flood protection mechanisms from
25 internal sources are designed in APR1400 in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consideration of structure enclosure or barrier walls,
2 a drainage system including Emergency Overflow Line,
3 this is called the EOL, emergency sump, internal curbs
4 or ramps and watertight doors.

5 Potential flooding sources include flood
6 water due to the postulated pipe failures, inadvertent
7 operation of fire protection systems and failure of
8 non-seismic piping.

9 This slide is about the variation of
10 internal flooding analysis for reactor containment
11 building and auxiliary building.

12 For reactor containment buildings at the
13 flooding sources flow to the elevation 100 feet of the
14 reactor containment building and flow to the hold-up
15 volume tank. And the containment building, water
16 storage tanks through 24 inch spillways.

17 The limiting flood sources is water source
18 from LOCA scenarios.

19 The flood height is determined to be two
20 feet from the elevation 100 feet, considering the
21 floodable area and LOCA volumes.

22 For auxiliary buildings, the flood sources
23 flows to the bottom level at elevation 55 feet by
24 drainage system and emergency overflow line.

25 The limiting flood source is the water

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 source of the IRWST.

2 The flood height is determined to be nine
3 feet from the elevation 55 feet considering total
4 water volumes of IRWST and floodable areas.

5 Each quadrant of the auxiliary building at
6 elevation 55 is separated by division walls. This
7 elevation is the lowest elevation in the auxiliary
8 building.

9 And, the watertight doors are designed to
10 prevent flooding source from spreading to adjacent
11 quadrants.

12 MEMBER STETKAR: I'm surprised that you
13 identified the IRWST as the limiting flooding source
14 for the auxiliary building when your PRA identifies
15 the fire protections systems as the most important
16 flooding source in the auxiliary building.

17 MR. YOON: Yes, right. We have
18 investigated the various internal flood sources in the
19 containment building. There are many sources such as
20 --

21 MEMBER STETKAR: I didn't say containment,
22 I said auxiliary building.

23 MR. YOON: Yes.

24 MEMBER STETKAR: Okay.

25 MR. YOON: It's the same, sir.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 There is failures flood source, as you
2 mentioned, fire protection systems and feed waters and
3 something like that.

4 But, the IRWST source is used for barriers
5 function to feed water primary system and this is the
6 limiting sources in auxiliary building.

7 MEMBER STETKAR: Okay, go on.

8 MR. YOON: Maybe I'm not articulating it
9 but, the volume is --

10 MEMBER STETKAR: As I recall, I'm trying
11 to read my notes here quickly, I didn't recall the
12 IRWST being identified in the PRA as a flooding source
13 for the auxiliary building.

14 And, I recalled, and in fact, my notes
15 confirm that, that the fire protection system was the
16 most important flooding source in the auxiliary
17 building.

18 So, I'm curious why the presentation today
19 now says that the IRWST is the most important source
20 or the limiting source.

21 MR. YOON: As this case is most elevation
22 auxiliary building --

23 MEMBER STETKAR: Sure, 55 meters --

24 MR. YOON: Yes, yes.

25 MEMBER STETKAR: Or 55 feet.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. YOON: Yes.

2 MEMBER STETKAR: Yes, well, I don't do
3 well in plumbing and I -- the only think I know about
4 plumbing is water flows downhill as does all of the
5 fire protection system water flow downhill.

6 So, I'm just curious why we're hearing
7 about the IRWST today when the PRA does not mention it
8 and why we're not hearing about the fire protection
9 system today when the PRA identifies the fire
10 protection system as the most important flooding
11 source in the auxiliary building.

12 MR. YOON: In my --

13 MEMBER STETKAR: So, I'm just curious
14 about that. I don't think we'll have an answer today.

15 MR. SISK: This is Rob Sisk, Westinghouse.

16 Appreciate the question and let us take
17 that back and look into that.

18 MEMBER STETKAR: Sure, thank you.

19 MR. YOON: Let me go to the next slide,
20 please?

21 From this slide, I'll speak about missile
22 protection regarding to this Section 3.5.

23 The analysis has been performed to meet
24 the regulatory requirement 10 CFR 50 Appendix A GDC 2
25 and 4.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Missile protection is provided for SSCs
2 important to safety so that the potential missile
3 cannot cause the release of significant radioactivity
4 or do not prevent the safe shutdown of the reactor.

5 Missile protections are accomplished as
6 follows. First, to minimize the missile generation
7 source by equipment design.

8 And, second, to orient of physically
9 separate the potential missile source from safety
10 related equipment and components.

11 Third, to contain the potential missiles
12 through protective shields or barriers.

13 Fourth, hardening the safety-related
14 equipment and components to withstand the missile
15 impact.

16 Internally generated missiles could be
17 categorized as two types of components which are
18 rotating and pressurized components.

19 The probability of missile generation is
20 used for validating the internally generated missiles.

21 If the probability of missile generation
22 P_1 is maintained less than 10^{-7} per years, missile is
23 not considered statistically significant.

24 Potential internal missile sources inside
25 containment are listed in Table 3.5-1.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 To protect the SSCs from internal
2 missiles, structure inside containment, secondary
3 shield wall, refueling pool wall, beams and slabs are
4 served as missile shields.

5 It's identified in Subsection 3.5.1.2.

6 Concerning the turbine missile, the
7 analysis has been performed based on Reg Guide 1.110
8 and the related SRPs.

9 The turbine generator is placed with
10 favorable orientation so that all essential SSCs are
11 excluded from the low-trajectory turbine missile
12 strike zone as shown in this figure 3.5-1.

13 Essential SSCs to be protected from
14 external generated missiles and turbine missiles are
15 listed in Table 3.5-4.

16 For missiles generated by the tornados and
17 extreme winds, safety-related SSCs of the APR1400 are
18 protected against the impact generated by tornado or
19 hurricane missiles.

20 The protection provides reasonable
21 assurance of performance with related 10 CFR
22 requirements.

23 The five automobiles and solid steel
24 spears are considered as a typical external missiles.

25 MEMBER SKILLMAN: Let me ask you a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 question about that. As I read the safety evaluation
2 report that is associated with your Chapter 3 Revision
3 1, there is a statement that there's a COL item that
4 will address that automobile missiles cannot be
5 generated within a half-mile radius of safety-related
6 SSCs that would lead to an impact higher than 10
7 meters.

8 What is the basis of that?

9 MR. YOON: Yes, I think that answer is we
10 provide specialist in the head.

11 MEMBER SKILLMAN: That would be a very
12 interesting answer. We've got tornados in this
13 country and high winds in this country that can
14 certainly move a pickup truck or an automobile 2600
15 feet, can deposit it on a roof of the building.

16 So, I'm wondering about the accuracy of
17 that assumption.

18 That would also presume that there's an
19 exclusion radius around safety-related equipment that
20 precludes vehicles being closer than a half-mile.

21 MR. YOON: Yes.

22 MEMBER SKILLMAN: And, most of the plants
23 that I've seen have automobiles, pickup trucks,
24 delivery trucks closer than a half-mile.

25 MR. NOLAN: This is Ryan Nolan from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff.

2 That's actually an item that's in the
3 guidance, Reg Guide 1.76 and Reg Guide 1.221. So,
4 that's where the --

5 MEMBER SKILLMAN: Half-mile came?

6 MR. NOLAN: -- the 10 meters came from.
7 And then, the COL item is maybe I'll call it operating
8 experience for lack of a better term. We had some COL
9 sites where they had elevated parking lots.

10 And so, we wanted to ensure that an
11 automobile missile would not invalidate that 10 meter
12 assumption. So, that's sort of the history of where
13 that comes from.

14 MEMBER SKILLMAN: Good, thank you. Thank
15 you.

16 MEMBER STETKAR: I need to, before we
17 continue, correct something that I said on the record.

18 I don't know what the most important
19 flooding contribution is in the updated version of the
20 PRA. But, as I scan through Chapter 19 of Rev 1 of
21 the DCD, I noticed that you do not -- that you now do
22 take account for breaks that drain the IRWST into the
23 auxiliary building.

24 So, that's -- it's included in the scope
25 of the model to now, it's just I haven't seen them.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, forget the last question, it's at
2 least in there, it's somewhere.

3 Thank you.

4 MEMBER REMPE: So, I had a question, too,
5 on this section. I found the wording in the design
6 certification document as well as in the staff's SC
7 about bit vague about the multi-unit issue.

8 And, is it planned somewhere that -- I
9 mean, it would have helped if the staff had clearly --
10 and I was going to bring it up to them, instead, this
11 is for a single unit application. But, instead, it's
12 bouncing that off again about the considerations of
13 the -- in the -- about multi-unit sites.

14 And, I was just kind of curious if KHNP
15 plans to clarify any of the discussion in updated
16 versions of this chapter?

17 MR. OH: This is Andy Oh, KHNP Washington
18 Office.

19 For this application is only one unit that
20 persist. But, in terms of multi-unit sites for the
21 missile protection or turbine generators missile
22 protection assessment is performed. We've set it as a
23 COL action item for COL action item 3.5-2.

24 So, COL applicant is perform assessment of
25 the -- those assessment when, as a multi-unit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 established in the same site construction.

2 MEMBER REMPE: Yes, I guess I'd like to
3 see the wording clarified because it -- I think it can
4 be misinterpreted and I would like, especially with
5 the staff, to just clearly say, hey, again, this is a
6 single unit application and if there are other
7 existing units prior or after for other types of
8 units, that's -- you need to consider this.

9 But, I think I've made the point
10 hopefully.

11 MR. OH: Correct.

12 MR. SISK: This is Rob Sisk, Westinghouse.

13 I will point out that it does say in the
14 DCD, I'm looking at language here, specifically that
15 SSCs that perform safety functions are not shared
16 between two units because the APR1400 is a single unit
17 plant.

18 MEMBER REMPE: In what chapter?

19 MR. SISK: Chapter 3.1.5, just as an
20 example.

21 MEMBER REMPE: Okay. But, later in like
22 Section 3.5.1, it gets a little more vague. But, I
23 didn't see that it said that earlier. So, that's
24 good, at least in your section it clearly says it.

25 MR. SISK: Well, I just wanted -- it is in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 various sections --

2 MEMBER REMPE: Yes?

3 MR. SISK: -- various chapters. And,
4 where there are potentials for multi-unit, whether new
5 construction or existing construction --

6 MEMBER REMPE: Right.

7 MR. SISK: -- there is a COL item for
8 looking at the site and evaluating --

9 MEMBER REMPE: Okay.

10 MR. SISK: -- proximity to other sites.
11 So, it is in there, I'm not sure if it's everywhere
12 that you would like in terms of the chapter, but we do
13 try to be clear that it's a single unit application.

14 MEMBER REMPE: Okay.

15 MEMBER STETKAR: We've actually seen COL
16 applicants that had to address that when they've
17 installed either a single unit where turbine -- I'm
18 talking about main turbine missiles now, could affect
19 one or more of the existing buildings and --

20 MEMBER REMPE: I do think --

21 MEMBER STETKAR: -- even a dual unit
22 installation where missiles from one of the units can
23 affect part of, you know, they're within the -- words
24 fail me.

25 MEMBER REMPE: I get what you --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Within the area.

2 MEMBER REMPE: I get that you need to
3 think about it for existing or new construction, but
4 it just sometimes it --

5 MEMBER STETKAR: And people have -- my
6 point is, people have. I mean, we've seen COL
7 applicants who have actually had to deal with that.

8 MEMBER REMPE: Yes, I --

9 MR. YOON: And, let's get started, okay?

10 On this page, also we considered the site
11 proximity missiles, the COL applicant is to evaluate
12 the potential for site proximity explosion and
13 missiles.

14 Due to the train explosion, shipboard
15 explosion, in the steel facilities, pipeline exclusion
16 or military facilities.

17 The COL applicant is to provide
18 justification for the site specific aircraft hazard
19 and an aircraft hazard analysis in accordance with the
20 requirement in Reg Guide 1.206.

21 The aircraft impact analysis is address in
22 Section 19.5.

23 For the structures, systems, components to
24 be protected from externally generated missiles such
25 as used to protect safety-related SSCs met the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 requirement Reg Guide 1.13, 1.27, 1.115 and 1.117.

2 The essential SSCs protected against a
3 missile impact are listed in this Table 3.5-4.

4 This slide is for as assist to be
5 protected from externally generated missiles and
6 barriers design procedures.

7 Missile barriers are designed with
8 sufficient strengths and thickness to prevent local
9 damage, including perforation, spalling and spreading
10 and overall damages.

11 Local damages prediction for concrete
12 structures includes the estimation on the depths of a
13 missile penetration and on assessment of whether a
14 secondary missile could be generated by spalling.

15 The steel barriers are not used in the
16 APR1400 design to protect safety-related equipment or
17 systems from missile impact.

18 For the variation of overall expanse,
19 reinforced concrete barriers and impact and impulse
20 load, nonlinear and elastoplastic response of
21 structures is used.

22 This slide shows the dynamic effect
23 associated with the postulated rupture of piping.

24 Plant design break analysis has been
25 performed in accordance with the following regulatory

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 requirements such as 10 CFR, SRP and ANSI/ANS.

2 The high and moderate energy fluid systems
3 are identified and summarized in this Table 3.6-1.

4 The protection design such as separation,
5 physical barriers or pipe heat restraints are designed
6 to protect essential SSCs from the effect of
7 postulated pipe break.

8 The pipe break locations are determined in
9 accordance with BPT 3-4, Part B.

10 Break locations are considered at terminal
11 ends and at the intermediate location based on stress
12 analysis results.

13 The criteria used to define location and
14 configurations of pipe ruptures are provided in
15 Subsections 3.6.2.1.

16 The analytical method to define forcing
17 functions are described in this Subsection 3.6.2.3.

18 The Main Steve Valve House is the only
19 area that met the break exclusion criteria described
20 in BTP 3-4, B.A(ii) for ASME Class 2 piping.

21 The design of break exclusion is applied
22 for fluid system piping and containment penetration
23 areas, between containment and auxiliary building
24 anchor walls beyond the isolation valves.

25 The forcing function for pipe thrust and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 jet loads are based on ANSI/ANS 58.2, Appendix B
2 procedure addressing the methodologies.

3 The dynamic and environmental impact due
4 to the HELB and MELB are summarized in the pipe
5 rupture analysis report.

6 The dynamic impact is analyzed with
7 respect of pipe whip, jet impingement and sub-
8 compartment pressurizations.

9 The environmental impact considered with
10 regard to flooding and environmental qualifications.

11 The potential non-conservative of jet
12 impingement models in ANSI/ANS 58.2 will be addressed
13 in some open items.

14 With respect to blast waves, jet plume
15 expansion and zone of influence and distribution of
16 pressure within the jet plume and jet dynamic loading
17 including potential feedback amplifications and
18 resonance effects.

19 The current technical report and related
20 RAI responses will be revised to address the above
21 issues.

22 In this slide, I'm going to talk about
23 structural design of pipe whip restraints.

24 PWRs provide to protect the safety-related
25 components against impact of pipe whipping during the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 postulated pipe break. PWR is pipe whip restraint.

2 The design of pipe whip restraint is
3 governed not only by the pipe break blowdown thrust,
4 functional requirement, deformation limitations but
5 also by the property of the whipping pipe and the
6 capacity of support structures.

7 The strain of energy-absorbing members is
8 limited to 50 percent of ASTM specified minimum
9 elongations.

10 To allow stress for non-energy-absorbing
11 members, structural attachment and support steel
12 structures are specified in AISC N690.

13 The consider of leak before break is
14 applied to APR1400, the LBB analysis is used to
15 eliminate the dynamic impact of pipe break.

16 This section describes how the piping
17 system with the LBB criteria and demonstrate that the
18 probability of pipe ruptures is extremely low.

19 The design of the LBB is incorporated into
20 the reactor coolant loop piping, a surge line, direct
21 vessel injection line and shutdown cooling line.

22 The method of piping evaluation diagrams
23 allows for the evaluation of the piping systems.

24 The LBB evaluation is consistent with the
25 requirement of SRP and NUREG report.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RICCARDELLA: Yes, approximately,
2 what percentage of the Class 1 piping was addressed
3 via leak before break versus dynamic analysis?

4 MR. YOON: We -- the concept of LBB is
5 applied to various systems and specifically into the
6 primary system. And then --

7 MEMBER RICCARDELLA: But, I mean, is it
8 half of the systems usually leak before break? Ninety
9 percent of them? You know, that's what I'm trying to
10 get a feel for.

11 MR. YOON: Excuse me, let me talk about
12 coolant and guides.

13 MR. SISK: This is Rob Sisk, Westinghouse.
14 We'll take that offline and get a discussion. We
15 don't have a precise or a good estimate at this point.

16 MEMBER RICCARDELLA: Yes, I don't need it
17 precise, I just wanted a feel.

18 MR. SISK: Yes, I think we need to get the
19 right individuals.

20 MEMBER RICCARDELLA: Thank you.

21 MR. Y. KIM: Yes, Yunho Kim.

22 Actually, we cannot say the percent of
23 piping for LBB application, just to be saying -- that
24 we can say that main reactor coolant system and the
25 surge line that is reapplied to LBB. But, I cannot

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 say how percent of pipe, I don't have the data.

2 MR. YOON: This is the end of Section 3.6.

3 If there is no more questions or comments, let me
4 transfer the speaker to Yongsun Lee. He will take up
5 Section 3.7.

6 MR. Y. LEE: Good morning, ladies and
7 gentlemen, I am Yongsun Lee, Senior Engineer of KEPCO
8 EDC Seismic Team.

9 I am going to present Chapter 3.7, Seismic
10 Design including Seismic Design Parameters, Seismic
11 System Analysis, Seismic Subsystem Analysis and
12 Seismic Instrumentation.

13 For Section 3.7.1, Seismic Design
14 Parameters, this slide presents certified seismic
15 design response spectra.

16 The peak ground acceleration of the CSDRS
17 is set to 0.3g for the APR1400 design for the boost
18 parameter and vertical directions.

19 The horizontal and vertical CSDRS for the
20 APR1400 are based on the Regulatory Guide 1.60
21 response spectra.

22 In each of the high frequency range from 9
23 hertz to 50 hertz.

24 Below figures show the horizontal and
25 vertical CSDRS with 2, 3, 4, 5, 7 and 10 calculations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This slide presents time histories
2 compatible with CSDRS. You notice with Option 1,
3 which 1 standard plan 3.7.1.

4 The three design histories and time
5 histories which envelope the CSDRS are generated to be
6 applied in both surge injection lines and system based
7 analysis of the APR1400 Seismic Category 1 structures.

8 The initial motions that were used to
9 create the design time analysis was actual recorded
10 0.3g plus K time histories.

11 The cross-section coefficients among the
12 three design CSDRS time histories are less than 0.16
13 as specified in standard plan 3.7.1.

14 The figures show the east, west, north,
15 south and vertical components of the design affiliated
16 time histories from the top.

17 This slide presents the high frequency
18 response spectra.

19 The groundwater and response spectra for
20 some Central and Eastern United States rock sites show
21 higher amplitude at the high frequency standard CSDRS.

22 The ground response -- the ground motion
23 response spectra for such a site, called HRHF seismic
24 motion, the peak ground affiliation HRH -- the peak
25 ground acceleration of the HRHF response spectra

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 prescribed as 0.46g for the evaluation of the APR1400
2 standard plant design for both the horizontal and
3 vertical directions.

4 The HRHF horizontal and vertical response
5 spectra are shown in the figures. This HRHF response
6 spectra, you see the CSDRS for the frequencies higher
7 than approximately 10 hertz.

8 This slide presents the HRHF time
9 histories. The three HRHF time histories which
10 envelope the HRHF response spectra also generated in
11 accordance with Option 1, approach 1 in standard
12 review plan 3.7.1.

13 The initial motion the vertical pipe
14 creates the time histories compatible with HRHF
15 response spectra are actually seed recorded Nahani
16 plus K time histories.

17 The cross-correlation coefficients are
18 among these HRHF associated time histories are also
19 less than 0.16.

20 The figures show the east, west, north,
21 south and vertical components of the HRHF time
22 histories from the top.

23 This slide presents the critical damping
24 measures. Basically, damping measures is used for
25 various nuclear safety-related structures, systems,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 components, based on the Regulatory Guide 1.61.

2 The damping barriers of soil using the
3 soil-structure interaction analysis obtained from the
4 generally models reduction and damping covers
5 recommended by EPRI report.

6 The table shows the various structures
7 damping related using the seismic soil structure
8 interaction analysis and peak space analysis.

9 This slide presents the supporting media
10 for the Seismic Category 1 structures.

11 Seismic Category 1 structures are founded
12 directly on rock or component soil.

13 For the design of Seismic Category 1
14 structures, eight soil profiles and one fixed-based
15 condition are established with various velocities
16 compared with soil depth to cover a wide range of
17 seismic conditions.

18 Figures show seismic velocities of several
19 soil profiles using the seismic analysis, for example.

20 The soil velocities, blue lines in the
21 figure and compression velocities, red dot lines in
22 the figure, varies from approximately 1000 feet per
23 sec to 9200 feet per sec and from 4800 feet per sec to
24 18,000 feet per sec respectively in the soil profiles.

25 For Section 3.7.2, Seismic System

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Analysis, this slide presents the APR1400 seismic
2 analysis methods and models.

3 Complex frequencies response analysis
4 method is used for the three dimensional soil
5 structure interaction analysis and fixed-based
6 analysis to obtain seismic response of the Seismic
7 Category 1 structures.

8 A fixed-based analysis also performed with
9 this complex frequency response analysis method by
10 assigning a very high seismic wave analysis to the
11 foundation medium.

12 The APR1400 safety-related structures such
13 as reactor containment building and auxiliary building
14 are modeled as three dimensional finite element
15 models.

16 This slide shows the seismic analysis
17 models for the auxiliary building and emergency diesel
18 generator building and the diesel fuel storage tank
19 room.

20 For the reactor containment building
21 seismic model, please refer to DCD R2, figure 3.7-24
22 and 25.

23 This slide presents the in-structure
24 response spectra generation.

25 The complex frequency response method with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ACS SASSI software is used to generate ISRS at wall
2 and floor locations in the finite element models.

3 For the impact of potential concrete
4 cracking, both uncracked and cracked concrete
5 stiffness cases are considered separately in the
6 seismic analysis models.

7 So, the finite design basis ISRS envelopes
8 the ISRS generated from 9 soil cases included fixed-
9 base analysis condition for both uncracked and cracked
10 concrete stiffness cases.

11 This slide presents the interaction non-
12 seismic Category 1 structures with the Seismic
13 Category 1 structures.

14 The turbine generator building and
15 compound building are located on the west side and the
16 south side of the auxiliary building with a 3-foot gap
17 on each side.

18 The Seismic Category 2 turbine generator
19 building and the compound building are to be analyzed
20 and designed to prevent the failure under the SSE
21 condition in the COL stage.

22 To evaluate the structure soil structure
23 interaction impact on the nuclear island due to the
24 presence of adjacent non-seismic Category 1 structures
25 such as turbine and compound buildings, the structure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 soil structure interaction analysis using the coupled
2 model for the entire power block is performed.

3 The interaction impacts of this non-
4 seismic Category 1 structures on the nuclear island
5 are negligible. However, the nuclear island impact or
6 seismic response of the emergency diesel generator
7 building source, the ISRS of the emergency diesel
8 generator building are increased to accommodate those
9 interaction impacts.

10 This slides shows the structure soil
11 structure interaction analysis model for the entire
12 power block with surface-supported foundation
13 condition.

14 And, this slide shows the structure soil
15 structure interaction analysis model for the nuclear
16 island and emergency diesel generator building with
17 excavated soil volumes.

18 This model is to consider embedded
19 foundation conditions.

20 MEMBER SKILLMAN: I would like to ask this
21 question, you just mentioned that the compound
22 building and the other buildings will be the
23 responsibility of the COL applicant.

24 MR. Y. LEE: Yes, sure. The design of the
25 turbine generator building and the compound building

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is not included in the APR1400 standard design. So,
2 those buildings should be analyzed and designed in the
3 -- by the COL applicant.

4 MEMBER SKILLMAN: The reason I asked the
5 question is, it seems that there are systems and
6 components in the compound building and the essential
7 service water building and the alternating current
8 building that are critical components to the function
9 of the nuclear island.

10 And, I'm excluding the turbine building
11 because the turbine building could be a kilometer away
12 if you wanted to transport the steam.

13 But, the compound building and several of
14 these other buildings are the structures that protect
15 components that are used in the nuclear island.

16 So, my question is a broad question, why
17 aren't those particular buildings part of your design
18 application? Right now, they are left to the COL
19 applicant.

20 MR. Y. LEE: My understanding is that
21 major important systems are designed in this APR1400
22 standard plant design. Those are included in the
23 center design.

24 But --

25 MEMBER STETKAR: That's not quite true

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 when you look at the -- I always forget the name of
2 it, you guys call it essential cooling water -- the
3 service water.

4 The structures for the service water, the
5 component cooling water heat exchanger building and
6 the piping tunnels between the nuclear island and
7 those other buildings are left to the design of the
8 COL applicant.

9 MR. Y. LEE: Yes, those are also
10 classified as Seismic Category 1 structures. But,
11 those structures are also -- do not included in the
12 standard design scope.

13 MEMBER SKILLMAN: I understand that they
14 are excluded. I'm asking why. And, my point is, as
15 John Stetkar points out, the UHS building, the
16 component cooling water tunnels, the component cooling
17 water heat exchangers are all somewhere else and not
18 in the nuclear island.

19 But, those devices, those systems and
20 structures, are critical to the successful functioning
21 of the nuclear island and the structures in which they
22 reside are, therefore, highly important.

23 So, my question is a curiosity question
24 more than a challenge. But, I'm wondering why those
25 key systems and their buildings are not part of your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 standard design?

2 MR. OH: Yes, this is Andy Oh, KHNP
3 Washington Office.

4 For example, for the ESW building, for a
5 COL applicant can locate the ESW building, depending
6 on a site specific condition. So, the -- as per the
7 standard design applicant, we cannot locate the
8 specific condition. That's the reason and for the
9 counter for the CCW.

10 If the COL applicant is positioned for the
11 north way or south way, and depending on the tunnel
12 where it can be determined.

13 So, that's the one reason for the standard
14 design applicant not decided for the tunnel, the
15 building or something.

16 And also, for ESW for essential service
17 water is very specifically depending on the site
18 specific condition.

19 MEMBER SKILLMAN: I understand that, Andy.
20 But, it seems to me that those buildings that I
21 mentioned are as critical to the successful operation
22 of the nuclear island as your emergency diesel
23 generator building.

24 MR. OH: Yes, I --

25 MEMBER SKILLMAN: I put them in the same

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 category. And so, it seems to me, that because of the
2 design specific requirements for those systems,
3 structures and components, KHNP would have insisted
4 that those key buildings and their components would
5 have been governed by your standard design.

6 MR. OH: Right, right, sir.

7 So, for system design is in scope for the
8 APR1400. Essential service water and component
9 cooling water and also even in a compound building for
10 waste assistance.

11 System design is in scope for this
12 standard design. However, for the structural design
13 for the seismic Category 1 or something, it's just for
14 the COL applicant. You have to construct the building
15 seismic will be classified for the Category 1. That's
16 per our request to standard design and requested for
17 COL applicant.

18 So, that's the current status for the
19 APR1400 designs.

20 MEMBER SKILLMAN: Thank you. I understand
21 your answer, thank you.

22 MR. Y. LEE: Thanks, Dr. Oh.

23 This slide presents the incoherent SSI
24 analysis to evaluate the impact of the HRHF seismic
25 input motion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Based on the 2011 EPRI report, the APR1400
2 HRHF response spectra determined that the 0.8-
3 fractile, five percent depth for the entire
4 containment site and below ground motion response
5 spectra for the Central and Eastern United States
6 hazard size.

7 The soil structure interaction analysis is
8 performed with incoherent input motion and coherency
9 functions developed by Norm Abrahamson using input
10 code and the incoherent ground motion vector input to
11 ACS SASSI software.

12 So, the seismic capacity of the structures
13 and systems and components of the nuclear island,
14 including reactor containment building and OCR
15 building and the emergency diesel generator building
16 are examined.

17 For the Section 3.7.3, Seismic Subsystem
18 Analysis, this slide presents the seismic subsystem
19 analysis method.

20 The seismic analysis of Seismic Category 1
21 subsystem is performed using either the response
22 spectra analysis or time history analysis or
23 equivalent static analysis method.

24 Since a lot of the content is Section
25 3.7.3 are similar to those in Section 3.7.2, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 content in Section 3.7.3 are not described in this
2 presentation model.

3 For Section 3.7.4, Seismic
4 Instrumentation, this slide presents seismic
5 monitoring system of the APR1400 standard plant.

6 The seismic monitoring system is designed
7 in accordance with Regulatory Guide 1.12.

8 The time history accelerographs installed
9 at appropriate locations which are described in
10 Regulatory Guide 1.12.

11 Provide time history data on the seismic
12 risk parts of the pre-fueled contained structure and
13 other Seismic Category 1 structures.

14 MEMBER SKILLMAN: What are you going to
15 use this system for?

16 MR. Y. LEE: For the seismic monitoring
17 system?

18 MEMBER SKILLMAN: Yes. What are you going
19 to use it for?

20 MR. Y. LEE: That --

21 MEMBER SKILLMAN: Okay, let me say a
22 little more. You are using an OBE that is one-third
23 your SSE.

24 MR. Y. LEE: Yes.

25 MEMBER SKILLMAN: Is it your intention

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that if your seismic monitoring equipment shows that
2 the ground motion is one-third of SSE or less,
3 therefore, OBE, that you simply do an inspection and
4 keep on operating? Is that your -- is that the design
5 intent of your seismic monitoring system?

6 MR. Y. LEE: Yes, basically, the OBE data
7 is set to the seismic monitoring system to investigate
8 -- I'm sorry -- basically, the core nuclear part plant
9 has the seismic monitoring system based on the OBE,
10 that slide.

11 And, the OBE is now set to the one-third
12 SSE.

13 MEMBER SKILLMAN: Okay. So, let's imagine
14 that we are in the control room and there is ground
15 motion and the ground motion is just a little bit less
16 than the OBE. What do we do?

17 MR. Y. LEE: The ground motion is not
18 exceed the OBE, am I right?

19 MEMBER SKILLMAN: You're right.

20 MR. Y. LEE: In that case --

21 MEMBER SKILLMAN: You're right, okay.
22 Just keep on going?

23 MR. Y. LEE: I will pose that it's like
24 that, but the details should be prepare -- should be
25 described in the operation manual.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Yes, okay. I was just
2 trying to understand what you intend to do with your
3 one-third SSE which is your OBE, which is appropriate
4 under Appendix S of 10 CFR 50.

5 So, I understand what you're
6 communicating. I was just wondering, what is the
7 design intent? Is your seismic monitoring system
8 intended to demonstrate overall plant experience with
9 the ground motion? Or, is it intended to be an
10 operator's aid to enable continued operation after
11 minor ground motion?

12 MR. Y. KIM: Yes, this is Yunho Kim from
13 KHNP.

14 Actually, we had also in Korea listen to
15 the variety of the model. Little --

16 MEMBER STETKAR: Andy, speak up a little
17 bit so -- or, I'm sorry --

18 MR. Y. KIM: Yes, so actually, we had
19 experience that we also can listen to it in the Kenji
20 site as compared to our Shinkori site.

21 And so, the main purpose of the seismic
22 monitor is just to input seismic is exceed one-third
23 of SSE which is OBE, then we have a procedure to --
24 for the operator to trip the reactor.

25 And then, after trip, there is a procedure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to look around to see the condition.

2 MEMBER SKILLMAN: To inspect?

3 MR. Y. KIM: Yes, yes. So, what is the
4 impact on also to major safety components, we want to
5 know. So, that is the, I think, main purpose of the
6 seismic monitoring system to aid for the operator to
7 trip the system.

8 MR. OH: Yes, this is Andy Oh, Washington
9 Office.

10 One more thing is for the monitor is a
11 recorder function. So, from that, the motions, then
12 after that, we can just evaluate how much impact is to
13 the plant.

14 And so, it's like the Member Skillman
15 said, that case port. It's very close to the OBE, but
16 it's not exceeding it. But, in that case, we also
17 consider, is there some of the, you know, additional
18 action we have to take for inspection for the plant or
19 not.

20 That is also can be the function for this
21 seismic monitoring system.

22 MEMBER SKILLMAN: Thank you, thank you.

23 MR. Y. LEE: There is one open item
24 related -- important to the analysis of the HRHF
25 seismic motions in Chapter 3.7.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We are working on this and try to resolve
2 it.

3 This is the end of my presentation for
4 Chapter 3.7. Thank you for your attention.

5 Do you have any further questions or
6 comments?

7 Then, the next chapter, 3.8, will be
8 presented by Mr. Hoonin Cho.

9 Thank you.

10 MR. SISK: Maybe just switch out.

11 MR. CHO: Sorry, good morning. I'm Hoonin
12 Cho and I'm in charge of ICS Structural Design in
13 KEPCO E&C.

14 Now, I'm going to talk about 3.8 design of
15 Category 1 structures.

16 First of all, let me tell you about
17 concrete containment structure description.

18 The containment is a pre-stressed concrete
19 structure composed of a right center cylinder with a
20 hemispherical dome and is bounded on safety-related
21 common basement.

22 The structures are lined on the inside of
23 a quarter-inch thickness steel plate that acts as a
24 retard membrane.

25 The internal structures are basically

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 independent of the containment except at the
2 supporting foundation basement.

3 The containment shares a common basement
4 with the auxiliary building. The auxiliary building
5 wraps around the containment with a seismic isolation
6 gap of six inches.

7 There are a equipment hatch, two personnel
8 airlocks, IRWST, tendon gallery and polar crane.

9 This slide shows containment dimensions.
10 Inside diameter of containment, inside height of
11 containment from the top of base slab to the ceiling
12 of dome apex, the thickness of containment wall and
13 the dome thickness.

14 The 3D Finite Element Model with ANSYS was
15 developed to perform the structural analysis of the
16 containment structure.

17 MEMBER SKILLMAN: May I ask this question
18 before you proceed?

19 The tendons --

20 MR. CHO: Yes?

21 MEMBER SKILLMAN: -- that will be used are
22 approximately 100 meters long, as I calculate.

23 MR. CHO: Yes.

24 MEMBER SKILLMAN: They are continuous?

25 MR. CHO: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: How are the temperature
2 changes associated with those tendons accounted for in
3 the analysis of the containment? That member is so
4 long --

5 MR. CHO: Yes.

6 MEMBER SKILLMAN: -- and there are so many
7 of them, the changes from summer to winter, and
8 particular summer heating on the concrete will cause
9 the tendons to expand and contract ever so slightly
10 unless the spring constant is such that the tension is
11 relatively constant than the compression of the
12 building is changing according to those temperature
13 changes.

14 And, I have the same question relative to
15 accident maximum temperature when those tendons would,
16 therefore, be relaxed.

17 So, my question is, these tendons are so
18 long, how is the temperature change with the tendons
19 accounted for?

20 MR. CHO: Yes, actually, in the analysis
21 of the structure, the temperature change is considered
22 in the concrete members.

23 As you know, the temperature is various
24 through the thickness. But, actually, the temperature
25 change in tendon is not considered because we think it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is in the middle of the wall of the containment and it
2 may be negligible inside the containment concrete
3 wall.

4 MEMBER SKILLMAN: How certain are you that
5 that temperature change is negligible?

6 MR. CHO: In tendon?

7 MEMBER SKILLMAN: Yes. Let's say a 3
8 degrees C, 2 degrees C temperature change in a 100
9 meter long tendon --

10 MR. CHO: Yes.

11 MEMBER SKILLMAN: -- could result in a
12 more than inconsequential change in tensile force.

13 MR. CHO: I'm sorry.

14 MR. SISK: This is Rob Sisk, Westinghouse.

15 I think we understand the question being
16 asked relative to the small temperature change and the
17 confidence level relative to the length of the tendon.

18 MEMBER SKILLMAN: Yes.

19 MR. SISK: We're going to take that aside
20 and look into that in a little bit more detail.

21 MEMBER SKILLMAN: Fair enough. And, maybe
22 in a topical report or technical report --

23 MR. SISK: We got you.

24 MEMBER SKILLMAN: -- that I think that the
25 assumption that the change will be -- the temperature

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 change will be negligible is one that may have some
2 significant uncertainty associated with it.

3 If we were talking tendons that were 30
4 meters long, 40 meters long, I wouldn't ask the
5 question. But, these tendons are very long tendons.
6 Perhaps there's experience, it's just experience I've
7 never had, but I'm curious.

8 MR. SISK: And we need to check into that
9 and make sure we have it correctly understood. So,
10 let --

11 MEMBER SKILLMAN: Okay.

12 MR. SISK: -- we'll take that as a --

13 MEMBER SKILLMAN: Let's make an open -- an
14 action item, please?

15 MR. CHO: Okay.

16 MEMBER SKILLMAN: Thank you.

17 MR. CHO: Let me go on?

18 MEMBER SKILLMAN: Please.

19 MR. CHO: For combustible gas control
20 inside containment, structural integrity of the
21 containment structure was evaluated in accordance with
22 Reg Guide 1.216.

23 Acceptance criteria is provides in ASME
24 Code CC-3720.

25 Maximum temperature of 350 degrees

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Fahrenheit was used to evaluate according to NUREG.

2 The 3D Finite Element Model were developed
3 with ABAQUS software to confirm the structural
4 integrity of the containment structure and the
5 combustible gas load condition.

6 3D Finite Element Model consists of the
7 three types element for four materials.

8 The maximum pressure is 109 psig.

9 Analysis research shows the maximum liner
10 plate strain for tension and it does not reach the
11 allowable limit strain values based on ASME CC-3720.

12 The assessment of the pressure capacity of
13 the containment were performed based on the Reg Guide
14 1.216. At this pressure condition, the structural
15 integrity is retained and a failure leading to a
16 significant release of fission product does not occur.

17 Analysis research shows that the UPC
18 pressure is 158 psig.

19 The research of the design of the pressure
20 reinforcement are summarized in DCD.

21 For pressure reinforcement, it is
22 confirmed that the maximum stresses provided
23 reinforcement do not exceed the allowable stresses for
24 both the service and factor load conditions.

25 Let me talk about the steel part of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 containment.

2 The COL applicant is to provide the
3 detailed design results and the variation of the
4 ultimate pressure capacity of penetrations including
5 the equipment hatch, personnel airlocks, electrical
6 and piping penetration.

7 Let me talk about structural descriptions
8 of the internal structures.

9 The internal structure is a group of
10 reinforced concrete structures that enclose the
11 reactor vessel and primary system.

12 The internal structure is located in the
13 reactor containment building, consists of the follow
14 major components, PSW, SSW, IRWST, operating and
15 intermediate floors and refueling pool.

16 The three dimensional finite element model
17 with ANSYS software was developed to perform the
18 structural analysis of the internal structure.

19 The results of the design are summarized
20 in DCD.

21 The concrete section strengths determined
22 from the criteria in ACI 349 are sufficient to resist
23 the design basis load.

24 This slide shows the structural
25 description of an auxiliary building. AB is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reinforced concrete structures which is composed of a
2 rectangular walls, floors, slabs, columns and beams.

3 AB surrounds RCB with a seismic gap of six
4 inches and share a common basement with RCB.

5 AB structure provides a protection against
6 both external and internal hazards.

7 AB is separated from other buildings by
8 the isolation gap of three feet.

9 The auxiliary building is rectangular with
10 the maximum dimensions of 348 feet by 353 feet.

11 AB structural analysis method is for
12 static analysis. The analysis was performed to find
13 all the member forces of shear and section shear
14 forces of slabs in AB.

15 The result on the design for AB are
16 summarized in DCD.

17 The concrete section strengths determined
18 from the criteria in ACI 349 are sufficient to resist
19 the design basis load.

20 This slide shows the structural
21 description of EDG building and diesel fuel oil tank
22 building.

23 EDG building block consists of two
24 independent buildings. EDG is separated from other
25 buildings by the isolation gap of three feet.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 EDGB houses two additional generators and
2 DFOT building houses the DFOTs thereof.

3 The results under design for EDG building
4 are summarized in DCD.

5 The concrete section strengths determined
6 from the criteria in ACI 349 are sufficient to resist
7 the design basis load.

8 This slide shows structural description of
9 NI common basement. NI common basement consists of
10 two areas, one central circular shaped area which
11 supports RCB and the other rectangular shaped area
12 which supports AB.

13 Disk shaped reinforced concrete structure
14 in RCB area has various thickness.

15 For the applied load on the NI basement
16 analysis, the equivalent static acceleration method is
17 used to consider the seismic load.

18 Stability check for overturning, sliding
19 and floatation of NI common basement was performed in
20 accordance with Section II of SRP 3.8.5 and the
21 results are as follows.

22 All the results meet the SRP requirement
23 as shown in this table.

24 The results on the design for RCB basement
25 and AB basement are summarized in DCD.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The concrete section strengths determined
2 from the criteria in ASME Section III Division 2
3 Subsection 3C for ASME basement and ACI 349 for AB
4 basement are sufficient to resist the design basis
5 load.

6 This slide is the end of Section 3.8.

7 There are seven open items in Section 3.8
8 and it is summarized in the open items summary slides.

9 For next slide, Section 3.9, will be
10 presented.

11 I appreciate your attention.

12 MR. P. HONGSUN: Good morning, Chairman
13 and ACRS Subcommittee. It is an honor to be here
14 today.

15 I am Park Hongsun from KEPCO E&C.

16 Let's start with Section 3.9. This
17 section provides the method of design dynamic testing
18 and analysis for Class 1, 2 and 3 components and
19 supports, including core support structures.

20 This slide shows the special topics for
21 mechanical components. This subsection provides the
22 transient using the design and quality analysis of
23 ASME Code Class 1 components and reactor internals.

24 The design transients gives the
25 information such as fluid system pressure,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 temperature, flow rate and frequency.

2 However, it does not cover the seismic
3 loading and other mechanical loading.

4 In this section, service level and test
5 conditions are addressed.

6 For APR1400, the 60-year design life and
7 the effect of environmentally assisted fatigue is
8 considered.

9 The frequencies of events traditionally
10 categorized as a Service Level C condition are
11 conservatively classified as a Service Level B
12 condition.

13 A number of computer programs are used in
14 the stress and structural analysis. The programs are
15 verified and validated in accordance with the design
16 control methods.

17 Those are consist with the quality
18 assurance program described in Chapter 17.

19 And, for APR1400, experimental stress
20 analysis is not used.

21 In order to consider the evaluation of the
22 faulted conditions, the major components of the RCS
23 are designed to withstand the pipe break loads.

24 The system or subsystem analysis is
25 performed on the elastic basis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Section 3.9.2 is for the dynamic testing
2 and analysis of systems, components and equipment.

3 Reactor coolant system structure analysis
4 --

5 MEMBER SKILLMAN: Before you proceed, may
6 I please ask some questions on 3.9.1?

7 MR. P. HONGSUN: Okay.

8 MEMBER SKILLMAN: I would like to direct
9 your attention or KHNP's attention to your DCD. It is
10 your page 3.9-4, it is Section 3.9.1.1.1 and this is
11 Revision 1 of your design control document.

12 And, you're explaining the Service Level A
13 conditions. And, you introduce the topic that the
14 Service Level A condition consists of 14 events
15 identified in Table 3.9-1.

16 Now, 3.9-1 is your main table for your
17 stress analysis for the reactor coolant system. And,
18 in that table on 3.9.1, your Service Level A
19 conditions show nine events, not 14 events.

20 And so, either the table has an error or
21 the text in Chapter 3.9.1.1.1 is in error. And, I'm
22 referring to Revision 1 of the DCD in both instances.

23 MR. P. HONGSUN: Okay, I don't have DCD
24 now, so I will check the table and the subsentences.

25 MEMBER SKILLMAN: And, I have a number of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 questions that I believe are at a level of detail that
2 is too fine for this meeting, but I'm -- my background
3 is in SSS design and I went through this table very
4 carefully. And, I do have some questions about the
5 KHNP assignment of transients for Service Levels A, B,
6 C and D.

7 And so, we might be wise to have an
8 offline discussion, or if you'd like me to, I can --

9 MEMBER STETKAR: We can't do that.

10 MEMBER SKILLMAN: Okay. Let me ask just
11 several questions. Okay?

12 MR. P. HONGSUN: Okay.

13 MEMBER SKILLMAN: You have in your Service
14 Level A condition, normal events 1A and 1B, steady
15 state operation with normal parameters and you
16 identify a million five cycles for increases and
17 decreases and those are changes between 5 and a 100
18 percent.

19 A portion of these are repeated under
20 Service Level B and I don't understand how the
21 transient can be in both categories, Service Level A
22 and Service Level B.

23 Because, if I go to Service Level B, I get
24 a very similar set of conditions. These are decreases
25 in main feedwater temperature and increases in flow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 rate which are identical in terms of what drive these
2 million five cycles for power changes.

3 So, it appears as though there might be
4 double counting for the transients. So, would it be
5 to your benefit to not double count, because, as you
6 count double, you're increasing your eating into your
7 U, your cumulative utilization factor.

8 MR. SISK: This is Rob Sisk.

9 Thank you for that. We will look into
10 both the Service Level A, B, C, D and check to see if
11 there are any corrections or clarifications that need
12 to be addressed.

13 MEMBER SKILLMAN: I had questions on
14 starting and stopping of the reactor coolant pumps at
15 hot shutdown.

16 And, where I was really pointing my
17 question is relative to which loop is started and when
18 you can drive flow backwards into the downcomer back
19 into the steam generator.

20 And, it isn't clear to me how the reverse
21 flow temperature changes are accounted for.

22 If you're in Mode 3, if you have some heat
23 in the system, perhaps you are identical in T hot and
24 T cold. But, once you begin to move T hot above T
25 cold and go to a pump start, you generate a rather

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 rapid transient.

2 And, it would seem to me that those need
3 to be accounted for somehow. And, those transients
4 are quite rapid, the reactor coolant pumps are about
5 110,000, 120,000 gallons a minute each.

6 And, depending on how you move those
7 pumps, you're going to move that water very rapidly.

8 MR. P. HONGSUN: Thank you for your
9 comments, we will check your comments.

10 MEMBER SKILLMAN: Let me -- I have one or
11 two more.

12 MR. P. HONGSUN: Okay.

13 MEMBER SKILLMAN: You've included one
14 steam generator tube rupture in 60 years. One steam
15 generator tube rupture in 60 years.

16 It would be fine if that is your actual
17 experience and there is not a whole lot of experience
18 with steam generator tube ruptures.

19 But, it would seem to me to be prudent to
20 consider more than one, even though the transient
21 itself is not particularly severe. It turns out that
22 the radiological conditions are the greater issue.

23 But, for as many tubes as you have, for 60
24 operating years, that is a long, long time.

25 CHAIRMAN BALLINGER: I might comment that,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 if they were using Alloy-600, that would be wrong.
2 But, since they're using Alloy-690, they haven't had,
3 to my knowledge, a tube rupture with Alloy-690.

4 MEMBER STETKAR: Also, my comment that the
5 operating experience worldwide is less than one tube
6 rupture every 60 years, much less.

7 CHAIRMAN BALLINGER: That does not mean
8 that they won't have one in 60 years.

9 MEMBER STETKAR: No, it doesn't.

10 CHAIRMAN BALLINGER: It means --

11 MEMBER STETKAR: It's just that the
12 average frequency is much lower than that.

13 CHAIRMAN BALLINGER: It's a much better
14 situation.

15 MEMBER SKILLMAN: My final question is on
16 your Table 3.9.2, I can pick it up in the next section
17 when you get into 3.9.2, so I'll wait for you to move
18 into 3.9.2.

19 MR. SISK: Well, we do thank you for the
20 comments. And, we have captured those for
21 consideration as we move forward.

22 So, please, go ahead.

23 MR. P. HONGSUN: Okay. Let's move on to
24 Section 3.9.2, the reactor coolant system structural
25 analysis is performed to generate the design data such

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 as processes and movement, motions and response
2 spectra.

3 Finite Element Model is used for the RCS
4 structure analysis.

5 Structural analysis for the normal
6 operation conditions are performed in linear static
7 analysis.

8 The dead weight, pressures and temperature
9 is three additions for each operation condition are
10 considered.

11 The seismic analysis performed using
12 nuclear island component RCS model details the
13 information described in Section 3.7.

14 The structural analysis for the postulated
15 pipe breaks is also performed.

16 The effects on the postulated pipe break
17 are the jet impingement and thrust subcompartment
18 pressure, internal pressure into the blowdown and
19 branch nozzle loads.

20 MEMBER SKILLMAN: Are those four bullets
21 that you just presented breaks where LBB is not
22 applied, jet impingement subcompartment, pressure
23 blowdown and branch nozzle loads, the DFL loads that
24 you show in your Table 3.9.2, the DFL loads are
25 described as the dynamic fluid loads and occasional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 loads. Is that is what you are communicating here?

2 MR. P. HONGSUN: Yes.

3 MEMBER SKILLMAN: It appears that is what
4 that is.

5 MR. P. HONGSUN: Yes.

6 MEMBER SKILLMAN: That's what that is?

7 MR. P. HONGSUN: Yes.

8 MEMBER SKILLMAN: Yes? Okay, thank you.
9 It's in your table? The table is not specific. Here,
10 you have been more specific and I presume there are
11 still more that are not identified. But, that is a
12 classification of your dynamic fluid loads.

13 Okay, thank you.

14 MR. P. HONGSUN: Next slide?

15 Flow-induced vibration assessment for the
16 reactor internals is described in Subsection 3.9.2.3,
17 4 and 6 and technical records, especially vibration
18 assessment programs are implemented for mechanical
19 systems and components subjective to vibratory force.

20 The reactor internals important to safety
21 are designed to accommodate steady state and transient
22 vibratory loads throughout the service life.

23 The APR1400 reactor internals are
24 classified as non-prototype Category 1 with Palo Verde
25 Unit 1 of ES.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Because the APR1400 reactor internals are
2 a substantially the same as Palo Verde Unit 1 with
3 regard to arrangement, design, size and operating
4 conditions.

5 Analysis program includes the calculation
6 of hydraulic loads and dynamic response and a
7 comparison between predicted and measures of
8 responses.

9 Full inspections procedure will be
10 conducting pre- and post- the hot functional tests.

11 For the dynamic system, unless it's for
12 the reactor internals under faulted condition, the
13 dynamic analysis for the reactor internals or core are
14 performed to determine the maximum structural
15 responses under pipe breaks and seismic loadings.

16 For excitation loads, pipe break blowdown
17 loads and reactor vessel motion are applied to the
18 structural analysis using Finite Element Method.

19 The analysis results for the core are
20 provided to evaluate the structural integrity of the
21 fuel assembly that is shown in DCD Section 4.2.

22 The analysis results for the faulted
23 conditions show that the reactor internals meet the
24 stress limits of the ASME Section 3 Subsection NG.

25 The dynamic analysis of the CEDM calculate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the maximum structural responses in order to confirm
2 the structural integrity of the pressure housings and
3 scramability.

4 CHAIRMAN BALLINGER: Excuse me, I've been
5 looking through the slides going forward and I'm
6 trying to find a convenient place for a break and it
7 doesn't seem like there actually is a convenient place
8 for a break within the next 20 minutes or more.

9 So, what I would propose is that we do
10 take a break now because this is at least a
11 subdividing point and come back at 25 minutes until.

12 So, we'll adjourn until 25 minutes until.

13 MEMBER STETKAR: Recess.

14 CHAIRMAN BALLINGER: Recess, excuse me.

15 (Whereupon, the above-entitled matter went
16 off the record at 10:20 a.m. and resumed at 10:35
17 a.m.)

18 CHAIRMAN BALLINGER: Okay, we're back in
19 session.

20 MR. SISK: This is Rob Sisk, Westinghouse.

21 We wanted to make a clarification on the
22 record to a question that was raised by Mr. Skillman
23 relative to Table 3.9-1 and the text in 3.9-1.

24 MEMBER SKILLMAN: Yes?

25 MR. SISK: So, please, go ahead and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 clarify.

2 MR. P. HONGSUN: DCD Section 3.9-1, Table
3 1, Service Level A condition is described that Service
4 Level A condition consists of 14 event conditions.
5 Okay?

6 And, Table 3.9-1, Level A Service
7 Condition consists of 14 conditions. But, the number
8 of events, nine, but we divided two or three events of
9 Service Level 1, 2, 3. So, we have 14 events of
10 Service Level A condition.

11 MEMBER SKILLMAN: Thank you for your
12 explanation. I would like my question to remain on
13 the record, because I have the table in front of me,
14 and I see the nine events, and I see many more than 14
15 conditions.

16 MR. SISK: I think when you count the nine
17 events, there are a couple of the events that had A,
18 B, C, D.

19 MEMBER SKILLMAN: That's correct.

20 MR. SISK: And, when you count the events
21 with the A, B, and C, D categorization, there's a
22 total of 14.

23 MEMBER SKILLMAN: I'm pleased to stand
24 corrected. Let me go back and take a look. I can see
25 that what you have under the events are not only the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 subevents, but the total of the subevents. And, that
2 would be a double count in each of the events and I
3 had not appreciated that until now.

4 Thank you, that's good, thank you.

5 MR. P. HONGSUN: Thank you.

6 MEMBER SKILLMAN: Actually, I would like
7 to comment that the reason I asked the question was in
8 your behalf because it appears as though you might
9 have been creating a great amount of analytical
10 utilization for your cumulative utilization factor
11 than you needed to. That's what I was thinking.

12 It seemed to me that you might have been
13 double counting and I was curious why you might want
14 to do that. That would certainly lead to
15 conservatism, but that probably isn't something that
16 you would want to do. That's why I asked the
17 question.

18 Thank you.

19 MR. P. HONGSUN: Okay, thank you for your
20 comments.

21 And, let's move -- let's start to read
22 Section 3.9.3.

23 The Subsection describes the structural
24 integrity of pressure retaining components, component
25 supports and core support structures.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The loading conditions are categorized as
2 design, Level A, B, C and D conditions.

3 Design pressure, temperature and other
4 loading conditions are presented in this subsection.

5 By stress analysis and fatigue variations,
6 it is confirmed that pressure components meet the
7 stress level stress limits and the structure adequacy
8 under the operation condition.

9 Pressure relieving devices are designed in
10 accordance with the requirements of ASME Code Section
11 III Appendix O.

12 The POSRVs are designed to provide
13 overpressure protection for the RCS.

14 Pressure relieving devices for ASME
15 Section III Class 2 systems are on the streamline and
16 the containment isolation portion of the normal
17 shutdown cooling system.

18 Pressure relieving devices for Class 3
19 systems are on heat exchanges, tanks and piping lines
20 to prevent overpressurization of the components and
21 systems.

22 The functional design and qualification of
23 safety-related active components are performed in
24 accordance with ASME QME-1.

25 The functional capability is confirmed by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design analysis, inspection, testing and start up
2 periodic in service testing.

3 Supports are designed and constructed in
4 accordance with ASME Section III and ASME Code Cases.

5 Snubbers are minimized to the extent
6 practical through the use of design optimization.

7 Reasonable assurance of snubber
8 operability is provided incorporating analytical,
9 design, installation, in service and verification
10 criteria.

11 This subsection provides the information
12 on design, functional requirements and operability
13 assurance program for the control element drive
14 mechanism.

15 The CDM for the APR1400 is basically the
16 same as the system 80 CEDM. It has a lot of operation
17 experiences in U.S. as well as Korea.

18 Since the CEDM pressure housing is a
19 pressure boundary component, it is designed in
20 accordance with ASME Section III Subsection NB.

21 Reactor pressure vessel internals refer to
22 the core support structures and internal structures in
23 accordance with ASME Section III Subsection NG.

24 The components of the reactor internals
25 are divided into two major parts. These are core

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 support barrel assembly on the left figure and the
2 upper guide structure assembly on the right figure.

3 The core support barrel assembly consists
4 of the core support barrel, the low support structure
5 and ICI nozzle assembly and the core shrouds.

6 The upper guide structural assembly
7 consists of the UGS barrel assembly and the inner
8 barrel assembly.

9 The UGS barrel assembly consists of UGS
10 support barrel, fuel alignment plate, UGS support
11 plates and control element guide tube.

12 The reactor pressure vessel internals are
13 classified in Safety Class 3 and Seismic Category 1.

14 This slide shows the hold down ring of
15 reactor pressure vessel internals. As you can see,
16 the detail drawing on the right figure, the hold down
17 ring sits on the core support barrel of the flange.

18 The hold down ring provides extra force on
19 the flange of the upper guide structure assembly and
20 core support barrel assembly in order to minimize
21 movement of the structures on the hydraulic forces.

22 And, that is designed to accommodate the
23 differential thermal expansion between the reactor
24 vessel and reactor internals in the vessel ledge
25 region.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Before you change this
2 image, and Andy, thank you for including this in the
3 presentation, KHNP, thank you for including this.

4 Please explain the physical status of the
5 hold down ring before the reactor vessel head is
6 placed on the reactor vessel lower flange.

7 Is the hold down ring in a configuration
8 to be compressed or to be pre-loaded so that when the
9 reactor vessel head is placed on the lower flange, the
10 core support assembly is driven downward?

11 MR. P. HONGSUN: That's right.

12 MEMBER SKILLMAN: So, that's a spring that
13 actually goes into bending and pushes it down?

14 MR. P. HONGSUN: That's right.

15 MR. SISK: I think it's above the washer.

16 MEMBER SKILLMAN: That's what I'm --
17 that's the question. That's the question.

18 MR. P. HONGSUN: That's right.

19 MEMBER SKILLMAN: Okay, now, is there a
20 competing load path where the upper guide structure
21 floats on the fuel springs and is, therefore, also
22 driven down by the reactor vessel head to ensure that
23 the fuel assemblies are clamped so they cannot react
24 against reactor coolant pump flow?

25 MR. P. HONGSUN: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: They are? So, when you
2 remove your reactor vessel head, does the core support
3 assembly rise?

4 MR. P. HONGSUN: Yes.

5 MEMBER SKILLMAN: It does? By about how
6 much?

7 MR. P. HONGSUN: I don't know.

8 MEMBER SKILLMAN: One centimeter? Half a
9 centimeter?

10 MR. P. HONGSUN: I don't know exactly.

11 MEMBER SKILLMAN: But, you know that it
12 rises?

13 MR. P. HONGSUN: Where it permits -- and
14 Korean members --

15 MR. SUNG: This is Kikwang Sung from KEPCO
16 E&C.

17 And, you asked -- do you ask the amount of
18 the displacement of the core support barrel? Right?

19 MEMBER SKILLMAN: Not the core support
20 barrel, it's of the upper guide assembly --

21 MR. SUNG: Upper guide --

22 MEMBER SKILLMAN: -- where it's up by the
23 refuel springs?

24 MR. SUNG: And then, as far as I know,
25 there is no relative displacement because the upper

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ledge and upper heads are clamped by using close head
2 studs around the head. So, there is no vertical
3 movement.

4 MEMBER SKILLMAN: Yes, I understand that.

5 Let's presume that you and I take a stud
6 tensioner and we untension the head, take off the nuts
7 --

8 MR. SUNG: Yes?

9 MEMBER SKILLMAN: -- reactor vessel head
10 rises?

11 MR. SUNG: Rise.

12 MEMBER SKILLMAN: What pushes it up?

13 MR. SUNG: I am sorry that I don't think I
14 can answer because --

15 MEMBER SKILLMAN: The answer is the
16 springs on the fuel assemblies --

17 MR. SUNG: Yes.

18 MEMBER SKILLMAN: -- actually rise --

19 MR. SUNG: Yes, right.

20 MEMBER SKILLMAN: -- raise the upper
21 structure.

22 MR. SUNG: Yes, right.

23 MEMBER SKILLMAN: Is that correct?

24 MR. SUNG: There are two kinds of hold
25 down springs in the reactor internals. One is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 hold down ring.

2 MEMBER SKILLMAN: The ring.

3 MR. SUNG: And, one spring is the --

4 MEMBER SKILLMAN: Fuel --

5 MR. SUNG: -- fuel assembly hold down
6 ring. You are right.

7 MEMBER SKILLMAN: Okay. That answers my
8 question. Where I was really going with this is to
9 understand how the internals are, on the one hand,
10 free to float until you place the reactor vessel head
11 in place.

12 And, when you do place the reactor vessel
13 head in place, how the internals are clamped and the
14 fuel assemblies are set in their lower fittings.

15 And, you've explained it at least from a
16 practical perspective. I do understand it.

17 Thank you, I'm done. Thanks.

18 MEMBER MARCH-LEUBA: I'm not -- can I ask
19 a question?

20 This question he was drawing out for you,
21 we've talked during LOCA analysis and somewhere it's
22 up to 15 about this bypass flow from the upper plenum
23 to the downcomer that relieves loop seals and other
24 things that happen with LOCA.

25 Is that complicated path I see in this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 figure where this bypass happen? Anybody know? You
2 do?

3 MEMBER SKILLMAN: I'll leave it to KHNP
4 first. Yes, if you look on the left image, if you
5 look at the T hot outlet, if you look at that 41-inch
6 diameter T hot exit, what happens is, as the reactor
7 vessel internals come to temperature, the reactor
8 vessel internals grow such that the outlet boss on the
9 internals interface and clamp on to the machine outlet
10 of the hotleg.

11 And, it's the closure of that 41-inch
12 diameter circumference that seals against the leakage
13 of which you --

14 MEMBER MARCH-LEUBA: So, it's not a
15 complicated path on the right?

16 MEMBER SKILLMAN: Oh no, it's really the
17 hotleg closure.

18 MEMBER MARCH-LEUBA: It's the hotleg
19 closure, but it's being clamped very strongly by the
20 upper head.

21 MEMBER SKILLMAN: Well, what happens is
22 the upper head clamps the internals, but the internals
23 grow and that fit up machining is a critical item for
24 the design of the internals and the design of the
25 reactor.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The final machining of the internals and
2 the reactor vessel, yes, it's radial machining.

3 MEMBER MARCH-LEUBA: Okay, thank you.

4 CHAIRMAN BALLINGER: Before we keep -- are
5 we through with that?

6 MEMBER SKILLMAN: Yes, I'm -- thank you.
7 Thank you, I'm good.

8 CHAIRMAN BALLINGER: Pete and I have been
9 going back and forth, if you look at your Table 3.9-1
10 which gives the transients, there's Event 2A and 2B
11 which are daily load follow operation.

12 If you actually literally consider that to
13 be daily and you look at 22,000 and 60 years, you
14 don't come up with any kind of number that makes any
15 sense.

16 MEMBER RICCARDELLA: No, 22,000 is like
17 six years.

18 CHAIRMAN BALLINGER: Yes. But, if you
19 look --

20 MEMBER SKILLMAN: Let me weigh in. That's
21 why I asked the question earlier about normal Level 1A
22 and 1B and Service Level A at 1.5 million.

23 CHAIRMAN BALLINGER: Yes.

24 MEMBER SKILLMAN: It appears as though the
25 1.5 million might include those first two Service

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Level B events. That's why I asked that question.

2 CHAIRMAN BALLINGER: But, if you note in,
3 fortunately or unfortunately, we've gotten both DCD
4 Revision 0 and Revision 1.

5 If you look at Revision 1, there's a Note
6 2 which is at the end of that table which says,
7 although the APR1400 will be operated as a base load
8 plant, the effects of daily load follow operation are
9 accounted for in the structural design and analysis of
10 ASME Code Class 1 components, reactor internals, dah,
11 dah, dah.

12 Somebody ought to fix the number because
13 daily to me means daily. And, the numbers don't -- if
14 you divide it up, it doesn't work.

15 MEMBER SKILLMAN: Well, I did that
16 arithmetic and I got, for the 15 -- for the 1.5
17 million times during 60 years, I got 68 per day.

18 And so, that's getting pretty close to a
19 couple times an hour. But they're small changes, yes.

20 But that is very consistent with how a load follow
21 plant would behave. You would hear the drives going
22 click, click up, click, click down.

23 MEMBER RICCARDELLA: Yes, but wouldn't the
24 load follow it one more than just like a 5 percent
25 change? You know, you'd want to come down to maybe 50

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 percent at night, you know, like those other -- like
2 those 22,000 cycles.

3 CHAIRMAN BALLINGER: But, I would note
4 that in Rev 0 that note is not there.

5 MEMBER RICCARDELLA: What is it? Read the
6 note again.

7 CHAIRMAN BALLINGER: The note says,
8 although the APR1400 will be operated as a base load
9 plant, which we always assumed, the effects of daily
10 load follow operation are accounted for in the
11 structural design and analysis of ASME Code Class 1
12 components, reactor internals and component supports.

13 But, that note is not in Rev 0.

14 MEMBER RICCARDELLA: Yes, right.

15 MEMBER SKILLMAN: Well, I can't fault KHNP
16 for advertising a base load plant but also
17 incorporating the cycles that could be required for a
18 plant that might be sited in South Africa or in Japan
19 or in Europe or Greenland or some place.

20 So, I certainly don't fault them for
21 building that capability into the plant through their
22 mechanical analysis.

23 MEMBER RICCARDELLA: Yes, but if it's only
24 22,000 cycles, it's not really daily for 60 years.

25 MEMBER STETKAR: It actually is if you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 read in Rev 0 of the DCD how they define load cycle.
2 It's one reduction per day which is 21,960 years.
3 Sixty times 365 --

4 MEMBER SKILLMAN: Is that many cycles.

5 MEMBER STETKAR: -- is 21,900 -- wait a
6 minute -- I can -- I have it here somewhere. Do you
7 have a calculator? I did the math and they defined
8 the load cycle as one cycle per day.

9 CHAIRMAN BALLINGER: This conversation is
10 completely --

11 MEMBER STETKAR: This is what happens and
12 this is on the public record, this is what happens
13 when you get a bunch of doctorates together in a room.
14 Eventually, you asymptotically approach something
15 that might be similar to the correct answer.

16 CHAIRMAN BALLINGER: Or you can if you're
17 stupid.

18 MEMBER RICCARDELLA: Understood, I
19 apologize.

20 MEMBER SKILLMAN: But, thank you for your
21 discussion --

22 MEMBER SKILLMAN: -- on the hold down
23 ring. Thank you, I appreciate that. Okay, thank you.

24 MR. P. HONGSUN: Let's move on to Section
25 3.9.6.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This section is to discuss functional
2 design qualification and in service testing program
3 for pumps, valves and dynamic restraints.

4 IST program for ASME Code Section III,
5 Class 1, 2 and 3 safety-related pumps, valves and
6 dynamic restraint is developed.

7 The COL applicant will provide a full
8 description of the IST program.

9 Functional qualifications are performed in
10 accordance with ASME QME-1.

11 This is the end of Section 3.9. Mr. Choi
12 will continue to present from Section 3.10.

13 MR CHOI: Hello, my name is Bosung Choi.
14 I am an Equipment Qualification Engineer from KEPCO
15 E&C to give presentation from Section 3.10 to Section
16 3.12.

17 Seismic qualification requirements for
18 Seismic Category 1 instrumentation, electrical
19 equipment and mechanical equipment are established to
20 provide reasonable assurance of structure integrity
21 and perform the designed safety-related functions or
22 intended function under the postulated SSE in
23 combination with other concurrent loading conditions
24 identified in the equipment design specification.

25 Qualification standards used in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 seismic qualification include IEEE standards 344S
2 modified by Reg Guide 1.100 for safety-related
3 mechanical and electrical equipment and support.

4 And, IEEE Standard 323 is included for the
5 equipment qualification in conjunction with the
6 environmental qualification.

7 ASME Code Section III for structural
8 integrity of safety related pressure boundary
9 components are used for the seismic qualification.

10 And, ASME QME-1 2007 for qualification of
11 active mechanical equipment is used for the criteria
12 for the seismic qualification.

13 So the methods for qualifying mechanical
14 and electrical equipment and instrumentation, testing
15 is conducted for equipment that cannot be qualified
16 with the analysis alone or equipment having components
17 that potentially cause any malfunctions related to
18 their intended functions.

19 Analysis without testing is acceptable
20 only if structural integrity alone can assure the
21 design intended function.

22 Combination of testing and analysis is
23 utilized when the equipment cannot be practically
24 qualified by analysis or testing alone.

25 Test or analysis is performed for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 supports of mechanical equipment, electrical equipment
2 and instrumentation to assure structural integrity of
3 the equipment being qualified.

4 When electrical equipment and
5 instrumentation supports are qualified by testing, the
6 components of the equipment are installed or dummies
7 are installed.

8 The supports can be qualified by analysis
9 when only the structural integrity of supports are
10 interested.

11 For mechanical equipment support,
12 qualification will be performed in accordance with
13 ASME Code Section III.

14 When instrumentation line supports are
15 qualified, the criteria from ASME Code Section III are
16 applied. Subsection NF for equipment Class 1 and 2
17 are applicable.

18 And the seismic qualification file will
19 include qualification methods used for equipment, test
20 and analysis results, list of systems, equipment and
21 equipment support structures, seismic qualifications,
22 summary data sheets which summarizes the components
23 qualification and seismic input requirements.

24 This will end the Section 3.10.

25 Section 3.11 is about the environmental

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 qualification of mechanical and electrical equipment.

2 Location of each equipment is specified as
3 room numbers in DCD Table 3.11-2 and classified into
4 mild or harsh condition based on the environmental
5 conditions.

6 The environmental conditions to be
7 considered in the equipment qualification are normal
8 condition, AOOs, DBAs and post-DBA.

9 The conditions are as conditions as a
10 result of analysis of certain events, environmental
11 parameter values for each room are specified in
12 Technical Report for equipment qualification program,
13 as Table 3 in the EQP.

14 Environmental qualification of Class 1
15 equipment is consistent with the requirements of 10
16 CFR 50.49, 10 CFR 50 Appendix B, Reg Guide 1.89 and
17 IEEE Standard 323.

18 For specific equipment, there are specific
19 EQ Regulatory Guides and they endorse some IEEE
20 standards. APR1400 uses these specific standards for
21 certain equipment.

22 For example, IEEE 382 for valve actuator,
23 IEEE 383 for cables and IEEE 649 for motor control
24 center.

25 Test results of the qualification are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 documented in auditable files in accordance with 10
2 CFR 50.49(j).

3 The vital instruments and equipment are
4 served with 100 percent redundancy of HVAC unit.

5 Design basis that prevent the loss of
6 safety-related ventilation are described in Section
7 6.4 and Section 9.4 of DCD.

8 The radiation qualification for individual
9 safety-related components are developed based on the
10 fact that the equipment will be qualified up to the
11 time the equipment is required to remain functional
12 following an accident and the limiting DBAs are LOCA
13 in containment building, MSLB in main steam well house
14 and FHA in fuel handling area.

15 The assumptions for determining normal and
16 accident condition TIDs are as follows.

17 For estimation of the normal EQ TID
18 values, the Microshield code was used. And, for the
19 accident EQ TID values, RUNT-G code is used.

20 Assumptions and methodology for evaluating
21 radiation doses for equipment qualification are based
22 on Reg Guide 1.89 and 1.183 guidance.

23 According to the Reg Guide 1.89 and 1.183,
24 the source term for the normal TIDs is from 1 percent
25 failed fuel and the source term for the accident TIDs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is from accident source term used for radiological
2 consequence analysis in DCD Chapter 15.

3 Exposure time in radiation environment is
4 60 years of continuous operation with full power plus
5 one year post-accident period.

6 Per Reg Guide 1.89 guidance, 10 percent
7 margin is considered for uncertainty of tests.

8 Mechanical equipment can be divided into
9 active and passive equipment. Active mechanical
10 equipment has mechanical moving parts to achieve its
11 safety function. For active mechanical equipment,
12 environmental qualification focuses on non-metallic
13 parts of the equipment in conformance with ASME QME-1
14 Appendix QR-B.

15 The main safety function of passive
16 mechanical equipment is maintaining its structural
17 integrity. As the structural integrity is achieved
18 really by the analysis of the passive equipment.

19 Now, I'm going to move to Section 3.12,
20 the piping design review.

21 This section provides the adequacy of the
22 structural integrity as well as the functional
23 capability of the safety-related piping system, piping
24 components and their associated supports.

25 A graded approach is taken to the scope of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 piping systems and components design.

2 The scope of design for ASME Code Class 1
3 piping includes RCS main loops, pressurized surge
4 line, DVI line and SC line.

5 And the scope of design for ASME Codes
6 Class 2 and 3 piping includes main steam and main fuel
7 piping.

8 Piping systems and supports are designed
9 in accordance with 2007 Edition with 2008 Addenda of
10 ASME Code Section III.

11 And, the piping analysis methods, the
12 procedure used for analytical modeling selection of
13 frequencies that being criteria combination of model
14 responses is described.

15 For seismic analysis, response spectrum,
16 time history and equivalent static load method is
17 used.

18 The computer codes used for modeling is
19 pipe stress ANSYS, RELAP5 and GTSTRUDL.

20 And the piping benchmark problems
21 prescribed in NUREG/CR-1677 are used to validate the
22 pipe stress computer program used in piping system
23 analysis.

24 Based on methodology and the equations
25 from the ASME Code, pipe stresses are calculated for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 various load combinations. The ASME Code includes
2 design limits for design conditions such as Service
3 Level A, B, C, D and testing.

4 The evaluation of the environmental
5 fatigue for Class 1 piping is performed in accordance
6 with Reg Guide 1.207.

7 Seismic Category 1 pipe supports are
8 designed in accordance with ASME Section III
9 Subsection NF for Service Levels A, B, C and D.

10 And, the acceptance limits of Appendix F
11 of ASME Section III are used for Service Level D.

12 For non-seismic category pipe supports
13 where supporting piping system is analyzed to ASME
14 B31.1, the requirements of ASME B31.1 will be met
15 where applicable.

16 Design of base plate and anchor bolt for
17 piping support is in accordance with ACI 349-1
18 Appendix B and Reg Guide 1.199, Bulletin Letter 79-2.

19 This will end the presentation of Section
20 3.12.

21 Mr. Park will continue from Section 3.13.

22 MR. P. HONGSUN: Okay, let's move on to
23 the Section 3.13.

24 This subsection provides the design
25 features of the threaded fasteners.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 In this slide, several design
2 considerations on threaded fasteners are discussed.

3 At first, fastener materials are selected
4 in accordance with ASME Section III NCA and NB/CD.

5 The fasteners are fabricated using the
6 materials prescribed in ASME Section III or ASME Code
7 Classes.

8 Boric acid corrosion and galvanic
9 corrosion are also considered. Special processes and
10 considers related --

11 MEMBER SKILLMAN: Excuse me. Please
12 explain what you mean by that statement, prevention of
13 boric acid corrosion, galvanic corrosion unless
14 considered to be acceptable.

15 Are you suggesting that you are choosing
16 materials that are immune to boric acid and to
17 galvanic corrosion?

18 MR. P. HONGSUN: Yes, we considered
19 prevention of boric acid, PAC and galvanic corrosion.
20 So, we selected materials to consider this corrosion.

21 MEMBER SKILLMAN: What materials are
22 immune to boric acid corrosion and to galvanic
23 corrosion? I mean, some of these bolts, some of these
24 studs are static at a very high stress intensity and
25 small amounts of boric acid plus some amount of fluid

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that acts as an aqueous conduit has the capability to
2 degrade the material.

3 So, I understand what I think you're
4 trying to communicate. But, I'm curious from a
5 practical perspective what it is you're going to do.

6 Any amount of electrolyte has the
7 potential to shear off a bolt head, to shear off a
8 nut. I've seen it happen.

9 CHAIRMAN BALLINGER: I think that there's
10 a wording problem here. I think if you were -- the
11 words unless considered to be acceptable, I'm not
12 exactly sure what that means. I'm not sure if Dick
13 knows what it means either.

14 MEMBER SKILLMAN: No, that's why I'm
15 asking. What I do know is that, for the pressurized
16 water reactors, at least that I'm aware of, following
17 the Davis-Besse incident, there was a massive attack
18 on boric acid leakage.

19 And, every licensee had to prove that the
20 licensee was ensuring that boric acid leakage was
21 prevented or, if it was discovered, that whatever
22 equipment the boric acid attached itself to was not
23 degraded.

24 But, the thrust of this is under material
25 selection, so I'm wondering if you have some very

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 superior material that is immune to galvanic corrosion
2 or to boric acid corrosion?

3 CHAIRMAN BALLINGER: The wording is just
4 very murky.

5 MR. SISK: Yes, this is Rob Sisk,
6 Westinghouse.

7 I certainly agree with you. And, I
8 believe what you're seeing there is a wording issue.
9 But, I think the message here is that the material
10 selection takes into consideration the boric acid,
11 galvanic corrosions.

12 And, I think, Dick, as you pointed out,
13 there's nothing that's totally immune, but you have to
14 be aware of it and factor that into an incremented
15 maintenance program, any sort of program for that
16 equipment as you go forward.

17 So, I think the issue here is to make sure
18 that we fully account for these factors in the
19 selection of the material and their application.

20 MEMBER SKILLMAN: That's fine. I
21 understand. Thank you.

22 MR. P. HONGSUN: Let's us go -- let me go.

23 And, the special processes and controls
24 related to material properties are in accordance with
25 Section II and III and threaded fasteners are cleaned

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in accordance with Regulatory Guide 1.28.

2 During fabrication, fasteners are
3 inspected in accordance with ASME Section III and B, C
4 or D.

5 Lubricants are selected in accordance with
6 the guidance provided in NUREG report. Acceptable
7 lubricants are Loctite N-5000, Neolube and Never Seez
8 Pure Nickel Special Nuclear Grade.

9 However, molybdenum disulfide is not
10 allowed for use in any circumstances.

11 Ferritic fasteners are tested in
12 accordance with Section III and B, C or D and 10 CFR
13 50 Appendix G.

14 In addition, all CMTRs are controlled,
15 maintained and stored in accordance with the quality
16 assurance program.

17 Pre-service and in-service inspection
18 follows the relevant requirements of ASME Section XI.

19 COL applicant is to submit the inspection programs.

20 This is the end of Section 3.13 and
21 Chapter 3 and the last of presentation materials, RAI
22 Summaries and Status, Open Items and COL Items are
23 summarized for your information.

24 Thank you for your listening.

25 CHAIRMAN BALLINGER: Is it your intention

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to stop here?

2 MR. SISK: This is Rob Sisk, Westinghouse.

3 Yes, as mentioned, the open items and the
4 COL items in the back are provided for your
5 information. Given the brevity of the time, we had to
6 cover the chapter. We weren't going to try to cover
7 all the open items. So, we're finished with Chapter 3
8 at this time unless there are additional questions
9 from the Committee.

10 CHAIRMAN BALLINGER: Now, I guess I'm in a
11 quandary. I sort of thought we would go longer, so I
12 didn't ask the staff if they were ready to start. So,
13 I'm assuming they're not ready to start. Okay?

14 So, that solves that problem.

15 Which means that we don't have much of a
16 choice except to --

17 MEMBER REMPE: Before we bang the gavel,
18 could we start earlier than the plan?

19 CHAIRMAN BALLINGER: They just nodded no.

20 MR. WARD: We could start earlier, we
21 can't start now, but we could probably --

22 CHAIRMAN BALLINGER: Start at 12:30?

23 MR. WARD: Yes, we'll round up the staff
24 and we can start earlier.

25 MEMBER STETKAR: Just as long as -- just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 announce it.

2 CHAIRMAN BALLINGER: Okay, all right,
3 option A.

4 MEMBER STETKAR: Because we're on the
5 public record, so if anyone is listening in they know
6 when to tune in again.

7 CHAIRMAN BALLINGER: Okay. After some
8 discussion, we will recess until 12:30 at which time
9 we'll pick up the staff's presentation.

10 (Whereupon, the above-entitled matter went
11 off the record at 11:16 a.m. and resumed at 12:30
12 p.m.)

13 CHAIRMAN BALLINGER: Okay, we're back in
14 session with the staff's presentation, and I'm not
15 sure who's going to go first, but whoever it is, go
16 first.

17 MS. TERRY: Good. Hi, good afternoon. My
18 name is Tomeka Terry, and I am the Chapter Project
19 Manager for APR1400 Design Certification Application
20 Review for Chapter 3.

21 This slide provides a list of the
22 technical staff who will be presenting today -- this
23 afternoon, ACRS.

24 In Section 3.1 through Section 3.6.1,
25 3.6.4 and 3.13 were no specific issues in these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sections. However, if ACRS Members have any
2 questions, the staff will be happy to answer your
3 questions.

4 Next slide?

5 Okay, during the design certification
6 review, the staff conducted pre-application QA audits
7 and performed audits at the applicant facility.

8 The staff also held biweekly public
9 meetings with the applicant to resolve technical
10 issues and to improve RAIs which the staff issued
11 several RAIs to the applicant.

12 Also, the staff incorporate lessons
13 learned from previous design certification
14 applications to ensure consistency with other designs
15 certifications, too.

16 Now, I will turn it over to Robert Rivera
17 who will be presenting seismic parameters and analysis
18 SER Section 3.7.

19 MR. ROCHE RIVERA: Thank you, Tomeka.

20 Good afternoon, my name is Robert Roche-
21 Rivera. I'm a Structural Engineer in the Structural
22 Engineering Branch in the Office of New Reactors.

23 My colleague, Jinsuo Nie and I were the
24 reviewers of DCD Section 3.7 related to the
25 applicant's seismic parameters and analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Specifically, DCD Section 3.7.1 over
2 seismic parameters, Section 3.7.2 covers seismic
3 system analysis. Section 3.7.3 covers seismic
4 subsystem analysis.

5 In a moment, Jinsuo will present review
6 topics related to 3.7.1 and 3.7.3 and I'll present
7 review topics related to Section 3.7.2.

8 I would also like to recognize the support
9 from BNL, Brookhaven National Laboratory who supported
10 our review of the APR1400 application.

11 On the phone, we have -- we should have
12 Joe Bragerman. Joe, are you there?

13 (No response.)

14 MR. ROCHE RIVERA: Okay, he should join
15 momentarily and then here in the audience, we have Dr.
16 Carl Constantino and Dr. Thomas Houston.

17 So, next slide, please?

18 So, this slide provides an overview of our
19 review of the applicant's seismic parameters and
20 analysis.

21 As part of our review process, we reviewed
22 DCD Section 3.7, and this is 3.7(a) which is related
23 to the applicant's full structural interaction
24 analysis.

25 Appendix 3.7(b) which describes the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applicant's evaluation for high frequency seismic
2 input as well as six referenced technical reports
3 supporting all these evaluations.

4 We held biweekly public meetings with the
5 applicant to discuss technical issues. We performed
6 independent confirmatory analysis of the acceleration
7 tank histories used for input to the seismic analysis.

8 We conducted a seismic audit, seismic
9 design audit. We confirmed consistency with the staff
10 guidance and, with the exception of one open item
11 which is related to the applicant's evaluation for
12 high frequency seismic input, we concluded that the
13 seismic design parameters and seismic analysis
14 procedures and criteria delineated by the applicant
15 provides an acceptable basis for the seismic design.

16 I will now turn over the presentation to
17 my colleague Jinsuo Nie.

18 MR. NIE: Thanks, Robert.

19 Good afternoon. My name is Jinsuo Nie. I
20 am a Structural Engineer.

21 I was responsible for reviewing two areas,
22 first the seismic design parameters and the other one
23 is seismic subsystem analysis.

24 All identified technical issues in these
25 two areas have been resolved and all RAIs are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 confirmatory.

2 For my presentation, I selected three
3 examples that I hope are of interest to the Committee.

4 These examples are in the area of seismic
5 design parameters.

6 For seismic subsystem analysis, the DCD
7 covers generic methodologies and the only physical
8 component in this area, part of the piping, conduit
9 and tunnels, concrete dams and above ground tanks are
10 treated as COL information items.

11 I'll now present the information there.
12 If there are any questions, I can answer.

13 Next, please?

14 My first example is about the evaluation
15 of CSDRS consistent foundation level response spectra
16 in the free field or CSDRS_{ff}.

17 Appendix S to 10 CFR Part 50 requires
18 CSDRS_{ff} to bound the minimum required response spectra
19 for MRRS. MRRS for APR1400 is defined as the CSDRS
20 anchored to 0.1g in the horizontal directions.

21 The applicant initially used the envelope
22 of the CSDRS_{ff} for all soil profiles to compare with
23 MRRS.

24 Since each soil profile can be evaluated
25 at the plant site, and the staff's request, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applicant compared CSDRS_{ff} for each soil profile and
2 determined that they bound MRRS.

3 CSDRS_{ff} was found to have large dips for
4 two soil profiles, S6 and S7. The applicant explained
5 that these dips were caused by a soil layer interface
6 right about the foundation level for these two soil
7 profiles.

8 However, the transfer functions providing
9 RAI response did not appear to explain these dips.
10 During the audit Robert just mentioned, the staff
11 reviewed the applicant input file for said response
12 analysis and found the transfer functions were not
13 from the ground surface to the foundation level.

14 But, instead, they found the bedrock to
15 the foundation level.

16 And, the applicant later provided the
17 transfer functions from the ground surface to the
18 foundation level which showed dips consistent with the
19 dips in CSDRS_{ff}. So this can resolve this particular
20 technical issue.

21 Next, please?

22 My second example is about the development
23 of targeted power spectra density function or PSD.

24 SRP 3.7.1 Option 1, Approach 1 makes
25 provisions to check the PSDs of the design time

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 histories against targeted PSDs as a secondary check.

2 The applicant has specified the targeted
3 PSD for the horizontal CSDRS below 9 hertz as the one
4 for the Reg Guide 1.60 horizontal spectra.

5 The vertical target PSD was based on one
6 time scaling of the horizontal targeted PSD. This
7 measure may not produce a targets PSD compatible with
8 the CSDRS.

9 In the RAI response, the applicant showed
10 that these targeted PSDs were in general agreement
11 with those developed based on 30 simulated time
12 histories.

13 The staff's confirmatory analysis showed
14 that its targeted PSDs were higher in some frequency
15 ranges than the applicant's targeted PSD.

16 However, the applicant's minimum targeted
17 PSDs which were actually used in assessing power
18 sufficiency of the design time histories were very
19 close to or higher than the staff's minimum targeted
20 PSDs.

21 The reason was that the applicant used a
22 factor of 0.8 which is slightly higher than the 0.7
23 specified in SRP 3.7.1 Appendix B.

24 Just for background, a higher minimum
25 targeted PSD means a more conservative PSD check.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Next slide, please?

2 My last example is about the seed records
3 and design time histories.

4 The staff conducted a confirmatory
5 analysis of the seed records because the staff --
6 because those records do not show high frequency
7 contents and the staff had a concern how they could
8 affect the design time histories that have an accuracy
9 frequency of 100 hertz.

10 It was found out that Fourier phase
11 spectra of the seed records were cyclic constant or
12 with a gap in some frequency ranges.

13 However, the design time histories were
14 not found to have this unrealistic features and they
15 have high frequency contents.

16 The staff confirmatory analysis also
17 identified the low pass filters were applied to the
18 design time histories with corner frequencies lower
19 than 50 hertz.

20 The applicant explained that the low pass
21 filters were used to remove artificial high frequency
22 contents due to baseline correction and clipping in
23 the spectra matching process.

24 The effect of the low pass filters were
25 determined to be insignificant because the low corner

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 frequencies of only 48 hertz well within the 10 hertz
2 frequency window for PSD modeling and affected hertz.

3 The last point on this slide is that to
4 estimate the PSD of the design time histories, the
5 applicant initially used a method that was not
6 consistent with the SRP guidance.

7 In some cases, that method may
8 overestimate the PSD for frequencies with small
9 amplitudes.

10 The applicant's comparison of the two
11 methods show that the generally produced comparable
12 PSD estimates, in some cases, they differ by a factor
13 of about three at some frequencies.

14 Both the applicant's revised calculation
15 and the staff confirmatory analysis confirmed that the
16 PSD of the design time histories are higher than the
17 minimum targeted PSD which we just talked about in the
18 previous slide, shown in other design time history has
19 sufficient power.

20 This completes my presentation and I will
21 be glad to answer any questions you may have.

22 So, we're good? Okay, I now will turn
23 over my seat to David Heeszal and the turn to my
24 colleague, Robert who will talk about the seismic
25 system analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Thank you.

2 MR. ROCHE-RIVERA: Okay, thank you Jinsuo.

3 Good afternoon, again.

4 I was the reviewer for DCD Section 3.7.2
5 which documented the applicant's seismic system
6 analysis.

7 Specifically, this section of the DCD
8 addressed the seismic analysis methods and models
9 which are used to establish the seismic demands for
10 the design of Seismic Category 1 structures of the
11 APR1400 standard plan.

12 In the next few slides, I'll present two
13 topics that are related to the review areas within DCD
14 Section 3.7.2.

15 Next slide, please?

16 The first topic is on soil structure
17 interaction sensitivity studies.

18 I think maybe the previous slide, there we
19 go, yes, there we go. Thank you.

20 So, in accordance with the acceptance
21 criteria in SRP 3.7.2, Roman Numeral II, IV,
22 sensitivity studies are performed to assist in
23 evaluating the adequacy of the seismic response
24 obtained from linear SSI analysis methods.

25 For example, studies are performed to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 verify whether nonlinear effects associated with the
2 separation between soil and sidewalls that imbedded or
3 foundation uplift would adversely affect the results
4 that are obtained from SSI linear analysis.

5 So, the staff review found that the
6 original submittal lacked the performance of
7 sensitivity studies.

8 Also, while the original submittal
9 included a study of the basement uplift, such study
10 did not appear to be consistent with the guidance in
11 the SRP.

12 Now, to address these issues, the
13 applicant revised its basement uplift study and
14 performed additional studies as follows and are
15 delineated in the slide.

16 So, the applicant performed a study of the
17 separation of soil from the sidewalls that are
18 embedded.

19 As part of its study, the applicant
20 performed SSI analysis of the nuclear island with soft
21 soil and hard rock soil profiles with modifications to
22 allow or permit separation between the soil and the
23 walls.

24 The applicant compared the in structure
25 response spectra obtained from this study with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 corresponding in structure response spectra obtained
2 from the fixed space analysis case for which the
3 separation of the soil and the wall is not a concern.

4 In other words, it's not applicable.

5 Also, this fixed-base case is part of the
6 design envelope that forms the envelope in structure
7 response spectra for the APR1400 structures.

8 So, what this comparison showed was that
9 the in structure response spectra from the fixed-base
10 analysis bound the in structure response spectra from
11 the analysis that allowed separation between the soil
12 and the sidewalls that are embedded.

13 And, on this basis, the staff found that
14 the assumption of no soil separation in the design
15 basis linear analysis to be acceptable.

16 The applicant also performed analysis
17 cases for several values of concentration and
18 demonstrated that none of the variables exist in the
19 design basis SSI analysis to the Poisson's Ratio
20 values that were used in the design basis analysis.

21 And, lastly, the applicant revised its
22 study of basement uplift for consistency with the SRP
23 guidance and demonstrated that the contact ratios
24 between the basement and the subgrade media below it
25 are greater than 80 percent which meets the SRP

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 criteria in Section 3.7.2 Roman Numeral II, IV for
2 acceptability of the linear analysis response.

3 Next slide, please?

4 The second topic that I would like to
5 present, it's on structural soil structural
6 interaction analysis.

7 So, in accordance with the acceptance
8 criteria in the SRP, again, Section 3.7.2, the
9 significance of SSSI analysis has to be evaluated and
10 addressed if significant in the design -- in the
11 seismic design.

12 So, while the original submittal included
13 a SSSI evaluation, such evaluation assumed the surface
14 founded the structure and did not consider the
15 pressures on the exterior below grade walls due to the
16 SSSI effects.

17 To address this issue, the applicant
18 performed a SSSI analysis based on an embedded
19 foundation configuration. Or, in other words,
20 considering embedment.

21 So, the results of this evaluation showed
22 that the lateral soil pressures computed from the SSSI
23 as well as the SSI analysis were higher than the
24 dynamic soil pressure that was originally used in the
25 design of the exterior below grade walls in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 auxiliary building and the diesel fuel oil tank room.

2 To address the exceedance of the original
3 dynamic soil pressure, the applicant reevaluated the
4 structural design of exterior below grade walls to
5 consider the calculated maximum lateral soil pressures
6 from the SSSI and SSI analysis.

7 The structural and soil aspect of the
8 structural design of the below grade walls will be
9 discussed in more details in a few moment by my
10 colleague Vaughn Thomas.

11 So, this right now, completes my portion
12 of the presentation. If there's no questions, then I
13 will turn over the presentation to Vaughn Thomas.

14 MR. THOMAS: Okay, good afternoon and
15 thanks, Robert.

16 Good afternoon, my name is Vaughn Thomas.
17 I'm Structural Engineer in the Office of New
18 Reactors.

19 In the next few slides, I'm going to
20 present some of the key technical issues identified
21 during the review of Section 8.1 through 3.8.4. 3.8.1
22 has to do with containment, the concrete containment
23 at 3.8.2.

24 They do have a steel containment, but they
25 are components that are -- that are not backed by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 concrete, for example.

2 They have a fuel line, but I'll talk about
3 that in my next few slides.

4 Some of the issues that are associated
5 with the view that were identified were, we talked
6 about the hydrogen duration pressure load in the
7 design of the concrete containment, the ultimate
8 pressure capacity of the concrete containment, the
9 leak chase channels in the containment internal
10 structures and the dynamic lateral of pressure of the
11 below grade walls as Robert alluded to.

12 Next slide?

13 The staff focused its structural review on
14 the design approach and methodology to ensure that the
15 applicant's design of the Cat 1 structures are
16 reasonable and acceptable in terms of the scope level
17 of details and technical adequacy of the information
18 provided.

19 The staff performed the review in
20 accordance with the Agency regulatory requirements and
21 staff guidance.

22 The staff held numerous biweekly meetings
23 with the applicant to discuss technical issues and
24 resolution of RAIs.

25 The staff also examined and compared

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applicant's results to the applicable code allowable.

2 The staff confirmed the applicant's method
3 for demonstrating the design adequacy of the
4 structures are consistent with Agency regulatory
5 requirements.

6 Next slide, please?

7 The first topic of interest is the
8 hydrogen duration pressure load using the design of
9 the concrete containment.

10 In reviewing the load and load
11 combinations associated with the design of the
12 concrete containment, the staff noticed that the DCD
13 did not describe the design and analysis procedures
14 and the acceptable acceptance criteria for the
15 hydrogen generation pressure load due to fuel clad and
16 water reaction.

17 As a result, the staff requested
18 additional information to ensure that the containment
19 structural integrity is maintained when subjected to
20 hydrogen generation pressure loads resulting from fuel
21 cladding and water interaction.

22 To resolve this issue, the applicant
23 performed additional calculation and sensitivity
24 analysis of the 3D Finite Element Model of the
25 containment structure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The applicant's result demonstrated that
2 the liner strains are below the ASME Code allowable
3 limits and that the rebar and tendons remain in
4 elastic range.

5 The applicant also demonstrated that the
6 structural integrity of the containment subject or
7 hydrogen pressure load meets the NRC regulatory
8 requirements.

9 The applicant provided model copies that
10 describe the design analysis approach and the
11 acceptance criteria for the hydrogen pressure load.

12 The staff concludes that the information
13 provided by the applicant demonstrated the containment
14 structural integrity is adequately maintained when
15 subject to hydrogen generated pressure loads resulting
16 from fuel cladding and water interaction. Therefore,
17 this issue is resolved and is being tracked as a
18 confirmatory item.

19 Next slide, please?

20 MEMBER SKILLMAN: Vaughn, let me ask this
21 question, please?

22 MR. THOMAS: Yes?

23 MEMBER SKILLMAN: As I read the safety
24 evaluation, it's page 3-205, the staff communicates
25 with specific regard to the containment pressure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Ultimate pressure level -- at the ultimate
2 pressure level the maximum strains of the rebar and
3 tendons do not reach the allowable limit strain
4 values. In addition, with regard to the punching
5 shear, local failure of concrete near discontinuities
6 such as the equipment hatch, the shear capacity of
7 shear rebar exceeds the shear force corresponding to
8 the ultimate pressure level.

9 However, the concrete shear strength is
10 conservatively neglected.

11 And, as I interpret that, that tells me
12 that you've placed all of the load on a combination of
13 the rebar and the tendons. And, although the concrete
14 may be able to take a huge amount of the load, it is
15 conservatively ignored.

16 Hence, there is conservatism in this
17 design that is really not being taken credit for. Is
18 that accurate?

19 MR. THOMAS: Yes. Yes, sir.

20 MEMBER SKILLMAN: Thank you.

21 MR. THOMAS: The second topic of interest
22 is the ultimate capacity of the concrete containment.

23 In reviewing the design and analysis
24 procedures for the concrete containment, the staff
25 noticed that the applicant's approach and acceptance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 criteria used to calculate the UPC of the containment
2 does not accurately to be in accordance with the
3 approach described in our regulatory position of Reg
4 Guide 1.216 which is the containment structural
5 integrity evaluation for internal pressure loadings
6 above design basis pressure.

7 As a result, the staff requested
8 additional information in order to better understand
9 the applicant's design and analysis approach for
10 determining the ultimate capacity of the concrete
11 containment.

12 To resolve this issue, the applicant is
13 committed to using Reg Guide 1.216 design and
14 acceptance criteria for determining the UPC of the
15 concrete containment.

16 The applicant also performed additional
17 calculations and sensitivity analysis of the 3D Finite
18 Element Model of the containment structure.

19 The applicant demonstrated through its
20 results that the rebar, tendon and liner streams at
21 the ultimate pressure level are below the stream
22 limits.

23 The applicant also included a COL item
24 which requires the COL applicant to provide the detail
25 design results and evaluation of the penetrations and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it shows equipment like equipment hatch, personnel
2 airlocks and so on.

3 The staff concludes that the information
4 provided by the applicant demonstrates the design and
5 analysis procedures for determining the ultimate
6 capacity of the concrete containment is acceptable.
7 Therefore, this issue is resolved and is being tracked
8 as a confirmatory item.

9 Next slide, please?

10 For the third topic of interest which is
11 the leak chase tunnels as part of the design of the
12 IRWST, the staff reviewed the components associated
13 with the APR1400 containment internal structures,
14 particularly the IRWST and noticed that the applicant
15 did not provide a description or associated design
16 details of the leak chase channels in the IRWST.

17 The leak chase channel collection system
18 intends to prevent leakage of the braided water from
19 the IRWST to its running concrete and containment
20 liner below.

21 As a result, the staff requested
22 additional information in order to adequately review
23 the design and analysis procedures of the IRWST,
24 including the leak chase channels and the stainless
25 steel liner plate.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 To resolve this issue, the applicant is
2 committed to using a leak chase channel to the extent
3 to monitor potential leakage of water from the IRWST.

4 The applicant provided backup copies of
5 applicable sections of the DCD that includes the
6 description of the leak chase channels collection
7 system that will be used in the design of the IRWST.

8 The applicant included a COL item for
9 monitoring and inspecting of the leak chase channels
10 collection system.

11 The staff concludes that the information
12 provided by the applicant demonstrates that the IRWST
13 design and analysis procedure is adequate. Therefore,
14 this issue is resolved and is being tracked as a
15 confirmatory item.

16 Next slide, please?

17 For the final topic of interest, the
18 evaluation of dynamic lateral earth pressures acting
19 on the embedded walls like Robert talked about a
20 little bit earlier.

21 The staff reviewed the design and analysis
22 procedures in Section 3.4 and noticed that the
23 applicant did not adequately describe the approach for
24 developing the dynamic earth pressure loads that are
25 considered in the analysis and design of the embedded

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 walls.

2 As a result, the staff requested
3 additional information related to the design and
4 analysis procedures for the below grade walls for the
5 Cat 1 structures considering the governing dynamic
6 lateral earth pressures.

7 To resolve this issue, the applicant
8 performed a sensitivity analysis which showed that,
9 for the aux building and the diesel fuel oil tank
10 structures, dynamic earth pressure determined from the
11 SSI and the SSSI and analysis results were higher than
12 those calculated in accordance with ASCE-498 method
13 which was previously used for the design of the
14 imbedded walls.

15 As a result, the applicant revised its
16 structural analysis of the aux building and the DFOT
17 and used the dynamic earth pressure obtained from the
18 SSI and SSSI analysis as the governing dynamic earth
19 pressure.

20 The increase in the dynamic earth pressure
21 led to revising the member forces of the exterior
22 walls.

23 The applicant provided markup copies of
24 applicable sections of the DCD that reflect those
25 changes.

1 The staff concludes that the information
2 provided by the applicant adequately addressed the
3 design and analysis of the below grade walls for the
4 Cat 1 structures. Therefore, this issue is resolved
5 and is being tracked as a confirmatory item.

6 And, this concludes my presentation. And,
7 if you have any questions, I'll be happy to address
8 them.

9 And, if not, I'll just turn to my
10 colleague, Ata Istar to present the reapplied
11 foundation.

12 MR. ISTAR: Good afternoon. My name is
13 Ata Istar, Structural Engineer at Office of New
14 Reactors.

15 And, I reviewed Section 3.8.5 foundations
16 and I'll present the following selected examples
17 during the review.

18 Could you turn to --

19 First, tendon gallery. The tendon gallery
20 is the integral part of the nuclear island foundation
21 of the APR1400 design.

22 However, the applicant did not describe
23 the tendon gallery and the analysis and the design
24 approaches for the tendon gallery in the DCD.

25 According to the SRP and areas of review,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 any unique design features that appear in the load pad
2 needs to be describe which includes any safety-related
3 function that the tendon gallery may have as part of
4 the foundation and the pre-stress containment.

5 The applicant responded and provided a
6 description of the tendon gallery and the tendon
7 gallery was included in the analysis and design as
8 part of the nuclear island common basement.

9 Therefore, this item is resolved and is
10 considered as a confirmatory item.

11 Next slide, please?

12 A waterproofing membrane, the applicant
13 did not provide any description whether waterproofing
14 membrane used in the DCD.

15 Accordingly, the SRP in the areas
16 overview, if waterproofing membranes are used, their
17 effects on the shear resistance on the foundations
18 needs to be addressed and the appropriate coefficient
19 of friction for the waterproofing membrane needs to be
20 considered when performing the stability evaluation.

21 The applicant responded that the
22 waterproofing membrane will be used for the exterior
23 below grade horizontal and vertical surfaces of the
24 structure and nuclear island pad's basement in the
25 APR1400 design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The applicant also included the COL item
2 3.8.13 to verify the coefficient of friction between
3 the lean concrete and the waterproofing membrane is
4 greater than 0.55 used in the design.

5 Therefore, this item is resolved and
6 considered as a confirmatory item as well.

7 Next slide, please?

8 Construction sequence and differential
9 settlements. The applicant did not include this super
10 structure or the reactor containment building and
11 auxiliary building into the construction sequence
12 evaluation and did not clearly determine the
13 settlement types of maximum vertical settlement, tilt
14 settlement, differential settlement between the
15 buildings and angle of distortion throughout the
16 nuclear island foundation.

17 According to the SRP in areas of review,
18 loads that are induced by the construction sequence
19 and differential settlements needs to be addressed.

20 However, currently, this issue is being
21 addressed by the applicant and it's considered to be
22 an open item.

23 This concludes my presentation. If you
24 have any questions, I will be glad to answer.

25 MR. HEESZEL: Good afternoon, I'm David

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Heeszal, a geophysicist in NRR. I'll be presenting
2 the seismic instrumentation portion of the
3 presentation.

4 The staff found that the applicant has
5 adequately described the location of seismic
6 instrumentation and the plans the COL applicants will
7 have to develop for locating the instruments.

8 In addition, the applicant has cited
9 appropriate regulatory guides that the COL applicants
10 will have to follow for determining the exceedance of
11 an OBE and plant inspection or restart following a
12 seismic event.

13 And that concludes my presentation.

14 MS. TERRY: So, should we take a break or
15 --

16 CHAIRMAN BALLINGER: No, we can keep
17 going.

18 MS. TERRY: We should go? Okay.

19 So, let me change panels.

20 CHAIRMAN BALLINGER: We're off the record
21 for a minute.

22 (Whereupon, the above-entitled matter went
23 off the record at 1:04 p.m. and resumed at 1:11 p.m.)

24 CHAIRMAN BALLINGER: We're back in
25 session.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WONG: My name is Yuken Wong. I'm the
2 Mechanical Engineer Branch. I'm the reviewer for
3 Section 3.10, seismic and dynamic testing of
4 qualification of equipment. I will also present
5 Sections 3.9.2, 3.9.5 and 3.12.

6 The reviewer for these sections can answer
7 any questions if needed.

8 Section 3.9.2, dynamic testing and
9 analysis of systems structures and components.

10 Next slide, please?

11 The staff reviewed the methodology testing
12 procedures, inspection program and dynamic analysis to
13 ensure the structural integrity and functionality of
14 piping systems, mechanical equipment and their
15 supports under regulatory ruling.

16 Especially the staff reviewed the
17 following six areas, piping vibration, thermal
18 expansion, dynamic effects testing during initial
19 start testing for ASME order and pressure vessel code
20 Section III Class 1, 2 and 3 piping.

21 Seismic analysis and qualification of
22 Seismic Category 1 components, dynamic analysis of
23 reactor internals under steady state and transient
24 conditions, pre-operation of flow induced vibration
25 testing of reactor internals, dynamic analysis of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactor internals under faulted conditions.

2 Lastly, correlation of reactor internals
3 and vibration test results with analytical results.

4 Next slide, please?

5 The staff also reviewed the comprehensive
6 vibration assessment program, or CVAP report, for
7 APR1400 steam generator and reactor internal design in
8 comparison with System 80 design.

9 The Palo Verde Unit 1 reactor internal
10 design is designated as the prototype and APR1400 as
11 the non-prototype Category 1.

12 The staff issued an RAI to request the
13 basis for using 33 hertz instead of the 0 period
14 acceleration of 50 hertz for APR1400 to determine if
15 the equipment is rigid or flexible for selecting the
16 static or dynamic analysis method.

17 The applicant revised the DCD to use 50
18 hertz. The staff finds the response acceptable.

19 The staff issued an RAI to determine
20 whether the fluid structure interaction and sloshing
21 effects are included in the tank analysis.

22 The applicant responded that hydrodynamic
23 forces exerted by the fluid on the tank walls are
24 included in the analysis.

25 The staff finds the response acceptable.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The staff requested the benchmarking
2 information for the DPVIB computer code used for the
3 pump pulsation pressure analysis.

4 The applicant provided the verification
5 and validation information in Revision 1 of the code.

6 The staff finds the response acceptable.

7 Next slide, please?

8 Section 3.5, reactor pressure vessel
9 internals. The staff reviewed the arrangement of
10 reactor internals, their functions, flow paths through
11 the reactor vessel and design criteria.

12 Compared the APR1400 reactor internal
13 design and CE System 80 reactor internal design, i.e.,
14 Palo Verde Units 1, 2 and 3 as their designs are
15 similar.

16 The staff held public meetings with the
17 applicant early in the design review process. Many of
18 these issues were addressed by the applicant early.
19 The remaining and additional issues were raised
20 through RAIs.

21 The staff verified the core support
22 structures and internal structures are designed and
23 constructed in accordance with ASME order and pressure
24 vessel code Subsection NG.

25 Next slide, please?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 One open item is about the control element
2 guide tube structure integrity. KHNP has since
3 provided calculations to show the guide tube structure
4 integrity can be maintained during a safe shutdown
5 earthquake.

6 The staff finds the analysis acceptable.

7 The staff also request that KHNP to look
8 into the operational history from operating plants
9 with the System 80+ design.

10 KHNP investigated, Young Gwang Unit 2
11 since July 1995 and found no failure data on any
12 reactor internals or guide tubes.

13 The staff asked KHNP to check Kori and
14 Palo Verde as well. The status is ongoing.

15 The other open item is regarding the
16 static O-ring at the seal table for the in-core
17 instrumentation support system.

18 KHNP provided test data to validate the O-
19 ring design.

20 The staff finds the response acceptable.

21 The last open item is about the seismic
22 category for reactor internals.

23 KHNP provided clarification that all
24 reactor internals including internal structures are
25 classified as Seismic Category 1.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The staff finds the response acceptable.

2 Next slide, please?

3 Section 3.10, seismic and dynamic
4 qualification of equipment.

5 Next slide?

6 The staff reviewed DCD Section 3.10, 3.7,
7 B.7.4 and technical reports related to the equipment
8 qualification, verified that equipment seismic
9 qualifications standards and methods are in accordance
10 with Reg Guide 1.100, IEEE 344 and ASME QME-1.

11 Verified procedures to evaluate the
12 effects of hot rock high frequency, or HRHF, response
13 spectra on high frequency sensitive equipment.

14 For new equipment, qualification will
15 envelop certified as seismic design response spectra,
16 or CSDRS and HRHF response spectra.

17 For equipment that has undergone prior
18 qualification, the applicant will verify that test
19 results envelop CSDRS and HRHF response spectra.

20 The prior test results do not envelop the
21 HRHF response spectra. The applicant will perform
22 screening tests using required response spectra
23 enveloping HRHF response spectra.

24 The staff finds the response acceptable.

25 The staff conducted an audit of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 procurement and design specifications to verify
2 seismic qualification methodologies are in accordance
3 with the DCD.

4 Next slide, please?

5 There is an open item related to the audit
6 findings. The staff conducted a follow up audit and
7 verified that the applicant's resolutions of the staff
8 audit findings are acceptable.

9 The applicant will update a procurement
10 specifications to address the staff audit findings.

11 Next slide, please?

12 MEMBER SKILLMAN: May I ask a question,
13 please? And, it's on Section 3.10, if you go back a
14 slide.

15 You have a COL item, it's COL 3.10(1),
16 it's on your safety evaluation page 3-411.

17 And, the way this COL item is worded is as
18 follows, the COL applicant is to provide documentation
19 that the designs of Seismic Category 1 SSCs are
20 analyzed for OBE if OBE is higher than one-third SSE.

21 I understand the concept that if the OBE
22 is higher than one-third of the SSE that you need an
23 analysis. But, I thought that this application
24 established that, by definition, the OBE is one-third
25 the SSE.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, I'm curious where there would be an
2 instance where a potential COL applicant would have a
3 higher OBE than one-third of the SSE?

4 MR. WONG: You're correct. The DCD does
5 establish the OBE equals one-third the SSE.

6 This COL item, it gives the COL applicant
7 the option to set their OBE level. If they do not
8 taking departure from the DCD, then there's no need to
9 take action on this COL item.

10 MEMBER SKILLMAN: Does the staff
11 anticipate that a COL applicant would take a
12 departure?

13 MR. WONG: I do not expect the COL
14 applicant would take a departure.

15 MEMBER SKILLMAN: Yes, I would not think
16 so. But, that's why I'm asking the question. I can
17 understand the notion that if somebody wanted to have
18 a higher OBE then they would have to justify it which
19 is what this question is pointing to.

20 But, I'm -- I guess I'm asking why the
21 staff would anticipate that if the application for the
22 design certification establishes that the OBE is one-
23 third the SSE?

24 MR. WONG: Yes, I do not expect the
25 applicant, COL applicant, would set a different OBE

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 level.

2 MEMBER SKILLMAN: Thank you.

3 MR. WONG: Section 3.12 ASME Code Class 1,
4 2 and 3 piping systems and associated supports.

5 The staff confirmed that APR1400 piping
6 and support analysis is in accordance with NRC
7 guidance, conducted an audit of piping stress analysis
8 and support designs to confirm consistency with the
9 DCD, held public meetings with the applicant to
10 discuss technical issues, issue RAIs that led to
11 proposed DCD markup changes, revisions to the
12 technical supports and added piping analysis.

13 Identified the environmental to assess the
14 fatigue for the reactor coolant loop piping had not
15 been performed.

16 The applicant has since completed the
17 analysis and is currently under staff review.

18 The staff questioned the seismic analysis
19 approach used. The applicant revised the calculation
20 and the staff finds the revised calculation
21 acceptable.

22 Next slide, please?

23 The applicant revised the nonlinear
24 analysis using the time history methods and the staff
25 finds it acceptable.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The HRHF response spectrum analysis,
2 seismic analysis of piping within the scope of greater
3 approach has been omitted.

4 The applicant has since completed the
5 analysis and it will be included in a revision to
6 technical report.

7 The evaluation of effects of HRHF response
8 spectra on SSCs. This report is currently under
9 review by the staff.

10 The staff requested the information
11 regarding the structural integrity or piping and pipe
12 supports that could be impacted by vibration and water
13 hammer which could potentially originate from the
14 operation and safety injection tank, operation of the
15 safety injection tank and its fluidic device.

16 The applicant's response is pending.

17 This concludes --

18 MEMBER SKILLMAN: Is there a date for that
19 product from the applicant? Because, I would like to
20 see it and perhaps some of my colleagues would like to
21 see that.

22 MR. WONG: Okay. It's the review of
23 Section 3.10.

24 MR. TSIRIGOTIS: My name is Alexander
25 Tsirigotis, I'm a Mechanical Engineer in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Mechanical Engineering Branch.

2 We engaged the applicant with questions
3 about the operation of the safety injection tank and
4 its related device.

5 This was like two or three months ago.
6 Since then, the applicant provided the write-up which
7 I received today and I haven't had enough time to
8 complete my review.

9 In addition, two weeks ago, one or two
10 weeks ago, we prepared the official Request for
11 Additional Information on this issue and ended up
12 sending it out to them.

13 MEMBER SKILLMAN: Thank you, thank you.

14 MS. LI: I'm Renee Li from Mechanical
15 Engineering Branch.

16 The topics I'm going to talk about is
17 determination of rupture location and dynamic effects
18 associated with postulate rupture piping.

19 The review goal is to ensure that SSCs
20 important to safety will accommodate or protect
21 against the effects of postulate pipe failure.

22 The review approach -- next slide.

23 The staff reviewed the applicant's
24 criteria used to define the pipe break and leakage
25 crack location and consideration which includes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 circumferential break, longitudinal break and through
2 leakage crack for both high energy line and also
3 considered the model image piping.

4 The staff also reviewed the outline of the
5 information which will be included in the pipe break
6 hazard analysis summary report. From now on, I'll
7 refer as PRHA report.

8 And, the staff has requested the applicant
9 to submit a PRHA summary report upon their completion.

10 The staff also reviewed the applicant's
11 methodology for addressing the non-potential non-
12 conservatism of ANS 58.2 standard related to the
13 dynamic jet modeling.

14 As you may know, the ANS 58.2 standard jet
15 modeling has been commonly used by nuclear industry.
16 However, following the interaction with ACRS Members
17 during the general issue 191 review, the staff
18 determined that there are four potential non-
19 conservatism in the standard jet modeling.

20 First, the standard does not consider the
21 brass whip effect.

22 Second, the standard assumes at universal
23 jet expansion configuration. However, the
24 characteristic of the jet expansion are not universal
25 and are highly depends on the ratio of the fluid

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 condition in the pipe that postulate failure to the
2 ambient condition.

3 And, also, some testing results has shown
4 that for the steam jet, the jet can travel much longer
5 than the distance that would be determined by the
6 standard model.

7 And, the third issue is that related to
8 the jet -- the pressure distribution within the jet
9 plume. For certain cases, the standard assumes that
10 the peak pressure that can occur along the jet center
11 line, that's valid for the area that close to the
12 break exit.

13 However, four feet from the jet often the
14 jet pressure will peak along the outer edge of the
15 jet.

16 And, lastly, the standard does not
17 consider the potential feedback amplification and the
18 resonance due to the line break structure in case that
19 synchronize the jet time scale.

20 So, in light of those potential non-
21 conservatisms, the staff request applicant, because,
22 in the DCD, it refers to the ANS 58.2 standard, so
23 request applicant address those potential non-
24 conservatisms.

25 And, in response, the applicant submit a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design specific technical report that address those
2 four issues.

3 And, based on the staff review of both the
4 DCD and the technical report, first, the staff found
5 out the applicant's criteria for defining the break
6 and the leakage crack location and the configuration
7 are consistent with the staff guideline.

8 However, the application of the break
9 exclusion area, the applicant's area of break
10 exclusion is beyond what the break potential position
11 described for the containment penetration.

12 Assuming now, the staff guideline for
13 containment penetration as the containment wall and
14 that include the both input and output containment
15 isolation valve.

16 For this region, the staff guidance
17 describes certain design provisions, also the inspect
18 requirement.

19 The provision of those additional design
20 requirements is to ensure that the possibility of pipe
21 break within this area is extremely, extremely low
22 such that breaks and cracks can be excluded from the
23 design basis of those portion of piping.

24 For the APR1400, the applicant's will
25 extend this break exclusion zone for the main steam

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and feedwater lines to the beyond the upper isolation
2 valve to the auxiliary building wall that they call it
3 a main steam loft house. There's anchoring there.

4 So, the staff request applicant to justify
5 the variation.

6 I want to make a note that for the design
7 provision that I earlier mentioned, the DCD's design
8 provision are consistent with the staff guidelines.

9 However, because the area they expanded,
10 so specifically, in the Request for Additional
11 Information, the staff like to know how those design
12 provision are considered and applied to the results of
13 their PRHA analysis.

14 And, that particular area, the staff will
15 review that with the PRHA report that when they
16 finally submit because which will provide more detail
17 information of the piping analysis results and that
18 still is an open item.

19 And, next slide, please?

20 And, about the technical report
21 methodology for addressing the four potential non-
22 conservatisms, the staff found out the applicant's
23 methodology in addressing the jet plume expansion and
24 distribution of the pressure within the jet plume, the
25 staff found acceptable.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 However, the evaluation of blast wave and
2 potential feedback amplification and resonance effects
3 are still open.

4 And, the status of those open issues, as I
5 mentioned earlier, the break exclusion area as well as
6 the PRHA report, the staff will review them together
7 because they are inter-related and the applicant
8 indicates that it will be submitted probably in the
9 July time frame of this year.

10 And, as far as the blast wave and
11 potential feedback amplification and resonance
12 effects, this -- for this, the applicant has indicated
13 the resulting dynamic effects using the current
14 technical report methodology would result in a dynamic
15 allowed that's too conservative.

16 So, they indicate that they will revise
17 the approach and submit a technical report revision,
18 again, probably in the same time frame as the PRHA
19 report.

20 And this concludes my presentation.

21 Thank you.

22 MR. REICHEL: Good afternoon, my name is
23 Eric Reichelt. I'm a Senior Materials Engineer in the
24 Materials and Chemical Engineer Branch of the EIA and
25 NRO.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I am the reviewer for SER Section 3.6.3,
2 leak before break for the APR1400 DCD review.

3 I would also like to introduce Jay Wallace
4 who's out in the audience from the Office of Research
5 who has provided us with technical assistance with the
6 confirmatory analysis of the applicant's piping
7 evaluation diagrams.

8 Next slide, please?

9 The staff reviewed the applicable APR1400
10 DCD sections and Subsection 3.6.3 to the acceptance
11 criteria and SRP 3.6.3.

12 The staff reviewed the DCD references for
13 applicability and use.

14 The staff held public meetings with KHNP
15 and KEPCO about technical issues early on in the
16 review and potential RAIs leading to proposed DCD
17 markups.

18 The staff found these DCD sections mostly
19 acceptable, most of the technical issues and response
20 to the RAIs and confirmatory items by KHNP were
21 acceptable and were, therefore, closed.

22 One RAI remains as an open item.

23 Next slide, please?

24 The staff questioned the PICEP input file
25 for the surge line fluid temperature against what was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 provided in the DCD. In addition, the PICEP source
2 code was requested, if available.

3 This one RAI remains to us as an open
4 item. KHNP will be providing us with their response
5 in the very near future.

6 The confirmatory analysis will continue
7 upon receiving this response to the open item.

8 This concludes my presentation. Thank you
9 and I will turn it over to -- my seat over to Tom
10 Scarbrough.

11 CHAIRMAN BALLINGER: This PICEP code is an
12 EPRI code?

13 MR. REICHELT: I know the PICEP code --

14 CHAIRMAN BALLINGER: So, are you likely to
15 get the source code is what I'm asking?

16 MR. REICHELT: The PICEP code has been
17 utilized in previous designs.

18 CHAIRMAN BALLINGER: For the past 25
19 years, but --

20 MR. REICHELT: Yes.

21 CHAIRMAN BALLINGER: But --

22 MR. REICHELT: Yes, Jay, do you happen to
23 --

24 MR. WALLACE: This is Jay Wallace, Office
25 of Research.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Yes, the PICEP code is an EPRI product.
2 One of the issues that we're having is that the code
3 that we're presently using for doing leak rate
4 analysis, leak bore disagrees slightly with the PICEP
5 code.

6 The other problem is the PICEP code is
7 quite old and doesn't run on Windows 7 machines.

8 CHAIRMAN BALLINGER: DOS.

9 So, what's the resolution?

10 MR. WALLACE: The resolution there was to
11 fire up the virtual machine under Windows 7 and run
12 the PICEP code for comparison.

13 CHAIRMAN BALLINGER: Thank you.

14 MEMBER RICCARDELLA: Excuse me, before you
15 leave --

16 MR. REICHEL: Oh, sorry.

17 MEMBER RICCARDELLA: I asked a question
18 earlier about roughly what percentage of lines inside
19 containment are addressed by leak before break versus
20 by normal --

21 MR. REICHEL: And, it's funny, I had a
22 feeling that I wasn't going to get away from this
23 table without you asking me a question here.

24 So, the percentage --

25 MEMBER RICCARDELLA: Just roughly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. REICHELT: We know that, you know,
2 obviously, they're using -- they're looking to apply
3 LBB on the reactor coolant loop, the surge line, the
4 direct vessel injection lines and the shutdown cooling
5 lines.

6 Their approach is no different than the
7 previous new reactor designs and what's currently been
8 utilized for leak before break out in the operating
9 fleet.

10 However, as a percentage, I'm sorry, I
11 don't have that answer.

12 MEMBER RICCARDELLA: As I recall, I think
13 the tendency is to apply it to the larger diameter
14 lines.

15 MR. REICHELT: Yes.

16 MEMBER RICCARDELLA: And, not the smaller
17 ones.

18 MR. REICHELT: Correct.

19 MEMBER RICCARDELLA: Because it's more
20 difficult to demonstrate --

21 MR. REICHELT: Right.

22 MEMBER RICCARDELLA: -- on the smaller
23 diameter ones.

24 MR. REICHELT: Correct.

25 MEMBER RICCARDELLA: Okay, thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. REICHELT: Okay.

2 MR. HUR: Excuse me, this is Seokhwan Hur
3 from KEPCO E&C.

4 I looked at it just a little more
5 explanation for the presentation of the LBB piping
6 within the question scope.

7 Actually, there are two, I'm not sure of
8 the exact number of the correct piping, there are two
9 uncertain question piping -- current piping from the
10 breaks or from the final rule. So, it becomes a total
11 number to the portion of the piping that cold break
12 and hotleg and the prime rule and associated piping,
13 and there are four piping that is collected to the
14 reactor vessel from the SIT and from the containment
15 break region.

16 And, there are two shutdown cooling piping
17 and so those are the -- all the LBB piping and there
18 are some more piping like the four piping and
19 pressurize spray piping. But, those are not LBB scope
20 because very small compared to the LBB piping.

21 So, it's hard to say the percentage of the
22 piping but those are the --

23 MEMBER RICCARDELLA: Essentially all
24 larger diameter pipes that are LBB?

25 MR. HUR: Yes, that's correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RICCARDELLA: Okay, that's what I
2 thought. Thank you.

3 MR. SCARBROUGH: Good afternoon. I'm Tom
4 Scarbrough. I'm going to go over three topics,
5 specific subsections of Chapter 3.

6 The first one is the special topics for
7 mechanical components. The staff reviewed the design
8 transients and found that the APR1400 transient
9 occurrences are conservatively designed and, based on
10 the certified System 80+ design transients.

11 Regarding the computer programs, the staff
12 audited the verification and validation documents for
13 those programs. The staff reviewed sample
14 calculations that are used to benchmark those
15 calculations and prepare audit reports.

16 There was one specific computer program
17 identified as DPVIB that was used to calculate
18 fluctuating pressure distribution in the downcomer
19 region caused by reactor coolant pump pressure
20 pulsation.

21 There was initially no benchmarks that
22 were identified for that program during the initial
23 audit and during the follow up audit, there were two
24 separate benchmarks provided for that.

25 The staff found that that output was in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 agreement with the test data and the description of
2 this program has been added to DCD Tier 2 Revision 1,
3 I checked that and it is in there.

4 Regarding faulted conditions, the staff
5 evaluated the faulted conditions and found that they
6 were in conformance with the boiler and pressure
7 vessel code Section III Appendix F which is the
8 guidance for service loadings for Level B
9 calculations.

10 MEMBER SKILLMAN: Tom, before you change,
11 on that slide, the first bullet, design transients and
12 the, if you will, the staff's comfort with what is
13 presented for the design certification document, Dr.
14 Ballinger pointed out a couple hours ago that there is
15 this new note at the dead end of Table 3.9-1, page 7
16 of 7. It's on the Design Cert 3.9-119, is the page
17 location.

18 And, this is Rev 1, the most recent.

19 And, that note is, although APR1400 will
20 be operated as a base load plant, the effects of daily
21 load follow operation are accounted for in the
22 structural design and the analysis of the ASME Code
23 Class 1 components, reactor internals and component
24 supports.

25 My question is this, the overarching

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design of this plant is a base load plant. This is a
2 new note and there is no comment in the safety
3 evaluation that opines on, digests, suggests any
4 knowledge of this new note.

5 So, my question is, what's going on here?

6 Is this -- you might have heard me say an hour or two
7 ago, I find nothing inappropriate with designing this,
8 that could be margin for a plant that would be
9 licenses outside of the United States. But, it just
10 strikes me as that's new and there was no flag in the
11 safety evaluation.

12 MR. SCARBROUGH: Right.

13 MEMBER SKILLMAN: Hence, I'm asking the
14 question, how come?

15 MR. SCARBROUGH: Yes, Tuan Le was the
16 reviewer for this particular section. He's right
17 there at the microphone and, Tuan, have you seen this
18 note before?

19 MR. LE: That's not a new note. I haven't
20 seen it before. So, is that in the recent revision of
21 the --

22 MEMBER SKILLMAN: Yes, yes it's Revision
23 1.

24 MR. LE: The staff has to review a new
25 addition to confirm those items but have not come

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 across that note yet.

2 Now, you mention it to look at that now.

3 MEMBER SKILLMAN: Okay. Well, here's --

4 MR. LE: And into the validation process.

5 MEMBER SKILLMAN: Thank you.

6 Here's why I'm raising the question. You
7 said, Tom, that you found that these transients are
8 conservative and you've based your assessment based on
9 the APR1400 looking at Palo Verde.

10 MR. SCARBROUGH: Right.

11 MEMBER SKILLMAN: So, what's different
12 with the plant that would be base loaded versus a
13 plant that say has a 1.5 million cycles over the
14 course of 60 years for small load changes?

15 MR. SCARBROUGH: Yes, we would have to
16 take a look and see if that would change a number of
17 transients that we've evaluated. Right? If it has a
18 different -- if it has a base load or if it's a
19 following load, you know, is there going to be a
20 difference in the number of transients, we should take
21 a look at that.

22 So, we'll go back and take a look at that
23 note and talk to the applicant about it and see if
24 that changes any of the determination of the number of
25 occurrences and make sure it's still consistent with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the System 80+ which is what was sort of the baseline
2 for this review.

3 MEMBER SKILLMAN: Oh, it has to do with
4 consistency with Palo Verde but also is the cumulative
5 usage factor calculated as it should be given the idea
6 that this could be a load following plant.

7 MR. SCARBROUGH: Right.

8 MEMBER SKILLMAN: So --

9 MR. SCARBROUGH: Exactly.

10 MEMBER SKILLMAN: I would like to get that
11 question on the record, please.

12 MR. SCARBROUGH: Yes, we'll go back and
13 look at that and when we come back again, we'll have
14 an answer for you. We may have to have another RAI or
15 something on this to look at this question and resolve
16 it for you.

17 MEMBER SKILLMAN: Thank you.

18 MR. SCARBROUGH: Thank you for identifying
19 that.

20 MR. SISK: Excuse me, this is Rob Sisk,
21 Westinghouse.

22 I do want to just kind of clarify on this
23 particular note that the note was added in recognition
24 of previous concerns during the ACRS about clarifying
25 as load follow or base.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, there are places that you've talked
2 before where we have done some work that follows load
3 following. But, we did not want to have any confusion
4 that because we did that in this case, that we were
5 assuming load follow in the U.S.

6 We wanted to be clear that there is -- we
7 had done this analysis and put a note in there to
8 distinguish between base load from the U.S. and
9 additional calculations that were being performed.

10 MEMBER RICCARDELLA: Am I correct in
11 saying, I don't think I saw any difference between the
12 number -- the transients or the numbers of transients
13 in the two Revs. It's just that we had discussions at
14 a prior meeting about base load versus load follow and
15 you put the note in but you didn't really change the
16 transients. So, therefore, the fatigue usage factors
17 wouldn't change, right?

18 MR. SISK: Yes, correct, not changed.

19 MEMBER RICCARDELLA: But, you know, I
20 think there's other aspects of load following like
21 concerns with fuel and things that aren't covered in
22 Section 3 design that would need to be addressed
23 before you could load follow?

24 MR. SISK: Yes, sir.

25 MEMBER SKILLMAN: Thank you, Pete. Thank

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you, Tom.

2 MR. SCARBROUGH: Okay, thank you.

3 MEMBER SKILLMAN: Thank you.

4 MR. SCARBROUGH: We'll follow up on that.

5 MEMBER SKILLMAN: Okay.

6 MR. SCARBROUGH: Regarding the next topic
7 is Section 3.9.3 having to do with components, Class
8 1, 2 and 3 components with the code.

9 The staff found that the load combinations
10 of the ASME Code Class 1, 2, and 3 components and
11 their supports conformed to the ASME Boiler Code
12 Section III.

13 We specifically looked at the dynamic
14 system loadings and the dynamic fluid loading. The
15 dynamic system loadings are used in Level D. They are
16 associated with pipe breaks and relief valve
17 actuations.

18 And, dynamic fluid loadings are associated
19 with more normal valve actuations.

20 And they are specified and conformed to
21 the boiler code in Section III.

22 The component supports were found to be
23 designed in accordance with Subsection NF for the
24 boiler code which is the supports subsection.

25 Now, we did conduct an audit, actually a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 couple of audits, an initial audit and then a follow
2 up audit recently of the component design
3 specifications in accordance with 10 CFR 52.47 to
4 establish that the design criteria, analytical methods
5 and functional capability satisfied the ASME code
6 requirements and to confirm that the design
7 information from DCD is probably translated into the
8 design specifications.

9 The initial audit was conducted in 2015
10 and the follow up audit was conducted relatively
11 recently in 2016 and we're working on the close out
12 audit report for that now.

13 There are going to be some design
14 specification changes and some DCD updates based on
15 that audit. And, we've prepared an RAI to track those
16 changes so that KHNP will notify us when those design
17 specs are updated and the DCD changes are ready so
18 that we can verify that those changes are incorporated
19 into those specs and DCD.

20 And so, that will be an open item until we
21 resolve that RAI.

22 So, that was 3.9.3, now 3.9.6 is the
23 functional design and qualification and IC program.

24 We evaluated the Section 3.9.6 using the
25 SRP section. The staff found that the DCD provisions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for functional qualification of pumps, valves and
2 snubbers specifying the ASME standard QME-1 2007 as
3 endorsed in Reg Guide 1.100 Revision 3 is acceptable.

4 As I mentioned, we conducted an audit that
5 included the requirements for components to ensure
6 that QME standard is referenced. A number of other
7 areas that we made sure that actuator sizing and
8 things of that nature for valves is properly included.
9 And that report is in preparation.

10 The DCD description is being updated to --
11 for the IST program based on the OM code, the 2004
12 Edition and 2006 Addenda as incorporated in 50.55(a)
13 and it's acceptable for reference in a COL
14 application.

15 Revision 1 of the DCD includes those
16 updates to describe the program consistent with OM
17 code. There is MOV sizing discussion. There is power
18 operator valve lessons learned discussion in there and
19 also the IST table is being updated.

20 So, those are -- I've seen those already
21 in the DCD Revision 1 and will confirm those and then
22 close that out.

23 We had three open items in this section
24 that we sent to you. One was the design spec follow
25 up audit. All those functional design and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 qualification issues have been addressed and the
2 follow up audit is being prepared and the DCD changes
3 and also the design spec changes will be incorporated.

4 We wanted to make sure there was
5 references to the QME-1 flow testing and actuators
6 sites and all those sorts of things.

7 Another open item had to do with the IST
8 table itself. Our original review found that it was
9 not consistent with the OM code and we've -- the
10 latest version they sent in a proposed change back in
11 August of last year. That's consistent with the OM
12 code and we'll be looking over that IST table in
13 Revision 1 to make sure all those changes were made.
14 But, that should be closed out as well.

15 Our last open item had to do with the
16 ITAAC for pumps and valves. Originally KHNP indicated
17 that they were going to follow the standardized ITAAC
18 the staff was preparing.

19 Recently, they decided that they would
20 keep the ITAAC they have. So, as a result, we have a
21 few RAIs related to those ITAAC to make sure that, for
22 example, the prototype testing was conducted
23 appropriately and that sort of thing for those ITAAC.

24 And so, we've sent those RAIs out and KHNP
25 is preparing those responses. So, we imagine that'll

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be resolved sometime as soon as they get their
2 responses back in to us.

3 Basically, that's my presentation and I'll
4 turn it over to Tomeka.

5 MR. CINTRON-RIVERA: Good afternoon. My
6 name is Jorge Cintron. I'm an electrical engineer
7 from the Office of Nuclear Reactor Regulations. And I
8 will be discussing the staff review on Section 3.11.

9 Section 3.11 provides the APR1400 approach
10 for environmental qualification of mechanical and
11 electrical equipment.

12 10 CFR 50.49 requires to establish the
13 environmental qualification program to verify the
14 electrical and mechanical equipment important to
15 safety is capable of performing design safety
16 functions on their own environmental conditions.

17 Regulatory Guide 1.89 provides the
18 guidance for environmental qualification of electrical
19 and mechanical equipment.

20 In addition, the staff also reviewed
21 nonmetallic parts of safety related mechanical
22 equipment to verify that nonmetallic parts are
23 qualified by testing per ASME standard QME-1 2007.

24 The staff performed the review following
25 the guidance of SRP 3.11 and the staff officer review

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and the methodology proposed by the applicant to
2 perform the environmental qualification of mechanical
3 and electrical equipment.

4 The equipment includes safety-related
5 equipment, non-safety-related equipment as failure on
6 their postulated environmental conditions to prevent
7 satisfactory accomplishments of specified safety
8 functions and certain post-accident monitoring
9 equipment.

10 Next slide?

11 The staff is currently reviewing an open
12 item with regard to Section 3.11. Regulatory Guide
13 1.89 provides the acceptable methods for environmental
14 qualifications. The guidance endorsed IEEE 323 1974
15 as an acceptable method for environmental
16 qualification of electrical equipment.

17 The applicant deviates from the Regulatory
18 Guide and proposed the use of IEEE 323 2003.

19 The staff performed an assessment of both
20 the standards to identify technical differences and
21 are confident that IEEE 323 2003 and the 1974 and
22 issued a follow up RAI requesting the applicant to
23 provide justification of the technical differences
24 between the 1974 and 2003 version.

25 Next slide?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The staff is --

2 MEMBER STETKAR: Jorge, just out of
3 curiosity, why hasn't the staff updated the Reg Guide
4 since it's based on information that's now 43 years
5 old?

6 MR. CINTRON-RIVERA: Good question.

7 MEMBER STETKAR: Probably older than you,
8 not older than me.

9 MR. CINTRON-RIVERA: The 2003 version was
10 never endorsed by the staff. However, there is a 2016
11 that is being issued, and the staff will consider
12 endorsing the new guidance.

13 MEMBER STETKAR: Okay.

14 MR. CINTRON-RIVERA: I guess for the
15 purpose of 2003 version versus the one that version
16 now the staff were more involved in the development of
17 the 2016 version. So, we believe that it will be
18 considered for endorsement.

19 MEMBER STETKAR: Thank you.

20 MR. CINTRON-RIVERA: So, right now, the
21 staff is currently evaluating the applicant's revised
22 response to develop RAI which is an open for Section
23 3.11.

24 With that, it concludes my presentation.

25 MR. STUTZCAGE: Hi, I'm Ed Stutzcage and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I'm the Radiological reviewer for Section 3.11.

2 Next slide, please?

3 Staff reviewed the applicant's methodology
4 and results for calculating the total integrated dose
5 to equipment within the EQ program.

6 For the normal operation dose, the
7 applicant calculated the normal operation doses at
8 rooms based on radiation sources in the plant,
9 considering gamma and neutron radiation.

10 Normal operation doses for equipment was
11 calculated assuming the highest dose within the room
12 using a similar methodology to that use to determine
13 Chapter 12 radiation zone maps, except that, for the
14 EQ analysis, 1 percent failed fuel is assumed
15 consistent with Reg Guide 1.89.

16 Staff reviewed the normal operation
17 sources and dose values and found them to be
18 acceptable with the exception of the open items.

19 For the accident doses, they're based on
20 the most limiting design basis accident for each
21 radiated plant, for most areas, that the LOCA.

22 Auxiliary building sources include post-
23 accident fluid recirculating the shutdown cooling
24 system, safety injection system and containment spray
25 system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The staff verified these sources were
2 consistent with the guidance in Reg Guide 1.183.

3 The total integrated dose is the sum of
4 the 60-year normal operation dose plus the limiting
5 accident doses.

6 Next slide, please?

7 For most areas of the plant, staff finds
8 the applicant's normal operation dose values for
9 equipment qualification to be acceptable.

10 Outstanding issues include inconsistencies
11 with Chapter 12 information regarding normal operation
12 neutron doses under the refueling floor.

13 As part of our Chapter 12 review, we did
14 review the calculation package that indicated there'd
15 be neutron streaming past the shield blocks into the -
16 - on to the operating floor and the EQ analysis didn't
17 seem to include that neutron dose. So, the
18 applicant's looking into that.

19 Another issue is doses within the
20 auxiliary building. Their accidents didn't appear to
21 consider radiation streaming through containment
22 penetrations.

23 But, we found that doing some Microshield
24 calculations and some other just reviewing their TID
25 values.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, we asked the applicant to resolve that
2 issue.

3 We requested the applicant provide
4 additional information regarding how some of the post-
5 accident gamma dose rate information was determined.

6 And, there was unjustified assumptions for
7 post-accident fluid leakage rate outside of
8 containment. Their post-accident fluid leakage
9 assumption was different in Section 3.11 than it was
10 in the Chapter 15 analysis. So, we asked the
11 applicant to explain the difference and justify it.

12 That concludes my presentation.

13 MEMBER MARCH-LEUBA: If calculating the
14 neutron streaming through holes and deep shielding is
15 not in the calculation, have you considered asking the
16 applicant for experimental data on their existing
17 reactors?

18 MR. STUTZCAGE: Didn't ask them for
19 experimental data.

20 MEMBER MARCH-LEUBA: I mean, it's a very
21 easy thing to how a reactor is working or measured
22 because those calculations aren't difficult.

23 MR. STUTZCAGE: Right, right, I agree.

24 We can look into that. I can look into
25 that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: And, probably be
2 better for them the calculation actually because
3 things tend to smear.

4 MR. STUTZCAGE: Yes, right, right, agree.
5 Thanks.

6 MS. TERRY: That concludes our
7 presentation. Unless you have anything else you would
8 like to discuss with us.

9 CHAIRMAN BALLINGER: Yes, we've finished
10 very, very early and myself as well as other members
11 have looked at the SER pretty carefully.

12 But, and I'm sure we would have raised
13 questions if we had seen something in there that we
14 thought was important enough for you to discuss but
15 you hadn't discussed.

16 But, for the record, I'd like to ask you
17 whether or not, based on your presentations and the
18 ones that haven't been given, are there any other
19 potential -- well, not any other -- any potential
20 important issues that were not discussed today?

21 MR. SCARBROUGH: This is Tom Scarbrough.

22 I don't know of any issues that we have
23 concerns with. If we did, we would definitely raise
24 them with you.

25 MS. TERRY: Yes, most of the other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sections didn't have any -- no specific issues.

2 CHAIRMAN BALLINGER: Yes, I didn't see
3 any, but then again, who knows.

4 So, I guess we should get the bridge line
5 open.

6 MR. BROWN: Bridge open.

7 CHAIRMAN BALLINGER: Good. While we're
8 doing that, is there anybody in the room that would
9 like to make a comment? I have to face the mic.

10 (No response.)

11 CHAIRMAN BALLINGER: Hearing none, the
12 bridge line is open. Is there anybody out on the
13 bridge line that would like to make a comment?

14 (No response.)

15 CHAIRMAN BALLINGER: You're sure it's
16 open, no crackling or anything?

17 MR. BROWN: Open.

18 CHAIRMAN BALLINGER: Okay, good. Well, I
19 heard a crackle, good.

20 Hearing none, I'd like to go around the
21 table for any other member comments.

22 Joy?

23 MEMBER REMPE: No comments.

24 MEMBER MARCH-LEUBA: I have no further
25 comments.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Nothing at all, and
2 especially congratulations to the applicant for a
3 heroic effort to go through all of that material in
4 the morning.

5 MEMBER RICCARDELLA: No comments.

6 CHAIRMAN BALLINGER: Dana?

7 MEMBER POWERS: No.

8 CHAIRMAN BALLINGER: Dick?

9 MEMBER SKILLMAN: Thank you, no further
10 comment.

11 CHAIRMAN BALLINGER: And, I'd like to
12 congratulate the staff and the applicant as we've gone
13 through this process chapter by chapter by chapter,
14 you can see an obvious significant improvement in the
15 process itself.

16 So, I think that's reflected in today's
17 presentations. So congratulations, and I can't turn
18 around and congratulate the applicant.

19 But, that being the case, we are
20 adjourned.

21 (Whereupon, the above-entitled matter went
22 off the record at 2:06 p.m.)

23


24

25

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

APR1400 DCA

Chapter 3: Design of Structures, Systems, Components, and Equipment



KEPCO/KHNP
June 5, 2017

ACRS SC Meeting (June 5, 2017)

Contents

- **Overview of Chapter 3**
 - **Section Overview**
 - **List of Submitted Documents**
- **Section Summary**
 - **3.1 Conformance with Nuclear Regulatory Commission General Design Criteria**
 - **3.2 Classification of Structures, Systems, and Components**
 - **3.3 Wind and Tornado Loadings**
 - **3.4 Water Level (Flood) Design**
 - **3.5 Missile Protection**
 - **3.6 Protection against Dynamic Effects Associated with the Postulated Rupture of Piping**
 - **3.7 Seismic Design**
 - **3.8 Design of Category I Structures**
 - **3.9 Mechanical Systems and Components**
 - **3.10 Seismic and Dynamic Qualification of Mechanical and Electrical Equipment**
 - **3.11 Environmental Qualification of Mechanical and Electrical Equipment**
 - **3.12 Piping Design Review**
 - **3.13 Threaded Fasteners (ASME Section III Class 1, 2, and 3)**

Overview of Chapter 3

● Section Overview

Section	Title	Major Contents	Presenter
3.1	Conformance with Nuclear Regulatory Commission General Design Criteria	<ul style="list-style-type: none"> Conformance with Nuclear Regulatory Commission General Design Criteria 1 through 64 	Jinkyoo Yoon
3.2	Classification of Structures, Systems, and Components	<ul style="list-style-type: none"> Classification of Structures, Systems, and Components according to nuclear safety classification, quality groups and seismic category 	Jinkyoo Yoon
3.3	Wind and Tornado Loadings	<ul style="list-style-type: none"> Design features of wind and tornado/hurricane loading considered in the design of seismic Category I and II structures 	Jinkyoo Yoon
3.4	Water Level (Flood) Design	<ul style="list-style-type: none"> Design features of flood protection from internal and external sources considered in the design of seismic Category I and II structures 	Jinkyoo Yoon
3.5	Missile Protection	<ul style="list-style-type: none"> Design features of internally generated missiles Design features of external missiles considered in the design of seismic Category I and II structures 	Jinkyoo Yoon

ACRS SC Meeting (June 5, 2017)

Overview of Chapter 3

● Section Overview

Section	Title	Major Contents	Presenter
3.6	Protection against Dynamic Effects Associated with the Postulated Rupture of Piping	<ul style="list-style-type: none"> • Design Protection against postulated piping failures in fluid system • Determination of break locations and dynamic effects associated with postulate rupture of piping • Design features of pipe whip restraints • Leak before-break evaluation procedure 	Jinkyoo Yoon
3.7	Seismic Design	<ul style="list-style-type: none"> • Seismic input motions • Seismic analysis methodology and results of seismic Category I Structures with generic soil sites • Seismic analysis methodology of seismic Category I subsystems • Seismic monitoring system 	Yongsun Lee
3.8	Design of Category I Structures	<ul style="list-style-type: none"> • Design features of Category I Structures including concrete containment, steel containment, internal structures of containment, other seismic Category I structures, and foundations 	Hoonin Cho
3.9	Mechanical Systems and Components	<ul style="list-style-type: none"> • Design, dynamic testing and analysis for ASME Code Section III, Division 1, Class 1, 2, and 3 components and supports including core support structures. 	Hongsun Park

Overview of Chapter 3

● Section Overview

Section	Title	Major Contents	Presenter
3.10	Seismic and Dynamic Qualification of Mechanical and Electrical Equipment	<ul style="list-style-type: none"> Acceptance criteria, code and standards, procedures, and methods applied to the seismic and dynamic qualification of mechanical and electrical equipment including instrumentation 	Bosung Choi
3.11	Environmental Qualification of Mechanical and Electrical Equipment	<ul style="list-style-type: none"> Equipment Location and Environmental Conditions, Qualification Tests and Analysis, Environmental Qualification Method. Equipment Qualification List, Environmental Parameters Data. 	Bosung Choi
3.12	Piping Design Review	<ul style="list-style-type: none"> Design of the piping system and piping support including the structural integrity, as well as the functional capability. The design transients and resulting loads and load combinations with appropriate specified design and service limits. 	Bosung Choi
3.13	Threaded Fasteners (ASME Section III Class 1, 2, and 3)	<ul style="list-style-type: none"> Design feature of ASME Section III Class 1, 2 and 3 component fastener 	Hongsun Park

ACRS SC Meeting (June 5, 2017)

Overview of Chapter 3

● List of Submitted Documents

Document No.	Title	Rev.	Type	ADAMS Accession No.
APR1400-K-X-FS-14002-P&NP	APR1400 Design Control Document Tier 2: Chapter 3	1	DCD	-
APR1400-K-X-IT-14001-P&NP	APR1400 Design Control Document Tier 1, Section 2.2	1	DCD	-
APR1400-E-S-NR-14001-P&NP	Seismic Design Bases	1	TER	ML17094A154
APR1400-E-S-NR-14002-P&NP	Finite Element Seismic Models for SSI Analyses of the NI Buildings	1	TER	ML17094A157
APR1400-E-S-NR-14003-P&NP	SSI Analysis Methodology and Results of NI Buildings	1	TER	ML17094A115
APR1400-E-S-NR-14004-P&NP	Evaluation of Effects of HRHF Response Spectra on SSCs	2	TER	ML17094A116
APR1400-E-S-NR-14005-P&NP	Evaluation of Structure-Soil-Structure Interaction (SSSI) Effects	1	TER	ML17094A117
APR1400-E-S-NR-14006-P&NP	Stability Check for NI Common Basemat	2	TER	ML17094A118
APR1400-Z-M-NR-14009-P&NP	Comprehensive Vibration Assessment Program for the Reactor Vessel Internals	1	TER	ML17094A142
APR1400-E-X-NR-14001-P&NP	Equipment Qualification Program	0	TER	ML13304A908
APR1400-E-N-NR-14003-P&NP	Evaluation Methodology of Jet Impingement Loads on SSCs	0	TER	ML15279A003
APR1400-E-N-NR-14004-P&NP	Summary Report of High-Energy Piping Rupture Analysis	0	TER	ML15243A015
APR1400-Z-M-NR-14016-P&NP	Leak-Before-Break Evaluation for Surge Line	0	TER	ML15009A122

ACRS SC Meeting (June 5, 2017)

3.1 Conformance with Nuclear Regulatory Commission General Design Criteria

NON-PROPRIETARY

❖ General Description

- This section discussed the extent to which the design criteria for the plant structures, systems, and components important to safety meet the NRC “General Design Criteria for Nuclear Power Plants” specified in Appendix A to 10 CFR Part 50
- For each criterion, a summary was provided to show how the principal design features meet the criterion in the relevant DCD sections

3.2 Classification of Structures, Systems, and Components

The APR1400 structures, systems, and components (SSCs) are classified according to seismic category, quality groups, and nuclear safety classification.

3.2.1 Seismic Classification

Seismic classification is identified to meet GDC 2 in accordance with RG 1.29

3.2.2 System Quality Group Classification

System quality group classification is identified to meet GDC 1 in accordance with RG 1.26

3.2.3 Safety Class

Fluid system components important to safety are classified in accordance with ANSI/ANS-51.1-1983

3.2.4 Classification Listings

Component classifications including quality assurance and codes and standards are provided in DCD Table 3.2-1.

3.3 Wind and Tornado Loadings

3.3.1 Wind Loadings

The design wind loadings on the surfaces of the SSCs subject to wind are determined in accordance with ASCE/SEI 7-05

- **Design Wind Velocity**

- 50-year 3-second wind gust speed : 64.8 m/sec (145 mph)
- Wind speed at 10 m (33 ft) above ground

3.3.2 Tornado Loadings

The APR 1400 standard and site-specific plant is designed to protect SSCs from tornadoes and hurricanes

- **Applicable Design Parameters**

- Design Basis Tornado (NRC RG 1.76)
 - ◆ Max. horizontal wind speed for 10 million years : 102.8 m/s (230 mph)
- Design Basis Hurricane (NRC RG 1.221)
 - ◆ Max. wind speed for 10 million years: 116 m/s (260 mph)

3.4 Water Level (Flood) Design

3.4.1 Flood Protection and Evaluation

- **Design Bases**

- The design basis flood level at the reactor site is determined in accordance with NRC RG 1.59 and ANSI/ANS 2.8.
- Design Basis Flood Level
 - ◆ 0.3 m (1 ft) below the plant grade
- Maximum groundwater level
 - ◆ 0.61 m (2 ft) below the plant grade

- **Flood Protection from External Sources**

- The flood protection measures are designed in accordance with NRC RG 1.102.

3.4 Water Level (Flood) Design

3.4.1 Flood Protection and Evaluation (Cont'd)

- **Flood Protection from Internal Sources**

- The safety-related SSCs are designed to withstand the effects of flooding due to natural phenomena or onsite equipment failures without loss of the capability to perform their safety-related functions.
- The flood protection mechanisms from internal sources are designed in APR1400 ;
 - ◆ Structural enclosure or barrier walls, drainage system including Emergency Overflow Line(EOL), emergency sump, internal curbs or ramp and watertight doors.
- Potential flooding sources include flood water due to postulated pipe failure, inadvertent operations of fire protection systems, failure of non-seismic piping.

3.4 Water Level (Flood) Design

3.4.1 Flood Protection and Evaluation (Cont'd)


● Evaluation of Internal Flooding

➤ Reactor Containment Building(RCB)

- ◆ Flooding source flows to the EL.100 ft of RCB, and to the HVT and IRWST through two 24-inch spillways.
- ◆ Limiting flood source is considered as LOCA.
- ◆ Flood height is determined to be 0.61 m (2 ft) from the EL.100 ft considering the floodable area and LOCA volume.

➤ Auxiliary Building(AB)

- ◆ Flooding source flows to the bottom level (EL.55 ft) by drainage system and EOL.
- ◆ Limiting flood source is the water source of the IRWST.
- ◆ Flood height is determined to be 2.74 m (9 ft) from the EL.55 ft considering total water volume of IRWST and floodable area.
- ◆ Each quadrant of AB at EL.55 ft is separated by division walls and watertight doors are designed to prevent flooding source from spreading to adjacent quadrants.



3.5 Missile Protection

3.5.1 Missile Selection and Description

- **Missile Protection**

- Applicable code : 10 CFR 50 Appendix A, GDC 2 and 4.
- Missile protection is provided for SSCs important to safety
 - ◆ Potential missiles do not cause the release of significant radioactivity or,
 - ◆ Do not prevent the safe shutdown of reactor
- Missile protections are accomplished as following:
 - ◆ Minimizing the missile generation source by equipment design
 - ◆ Orienting or physically separating potential missile sources from safety related equipment and components
 - ◆ Containing the potential missiles through protective shields or barriers
 - ◆ Hardening of safety-related equipment and components to withstand missiles impact

3.5 Missile Protection

3.5.1 Missile Selection and Description(Cont'd)

- **Missile Protection(Cont'd)**

- Internally Generated Missile

- ◆ Internally generated missiles are categorized as two types missiles, rotating and pressurized components.
- ◆ If the probability of missile generation P_1 is maintained less than 10^{-7} per year, missile is not considered statistically significant.
- ◆ Potential missiles inside containment are summarized in Table 3.5-1.
- ◆ Structures inside the containment, secondary shield wall, refueling pool wall, structural beams, and floor slabs are served as missile shields.

3.5 Missile Protection

3.5.1 Missile Selection and Description(Cont'd)

- **Missile Protection(Cont'd)**

- **Turbine Missiles**

- ◆ The turbine generator is placed with favorable orientation so that all essential SSCs are excluded from the low-trajectory turbine missile strike zone as defined by R.G 1.115.
- ◆ Essential SSCs outside the RCB to be protected from externally generated missiles are listed in Table 3.5-4.

- **Missiles Generated by Tornadoes and Extreme Winds**

- ◆ Safety-related SSCs are protected against the impact generated by tornado or hurricane missiles.
- ◆ Provides reasonable assurance for the protection according to 10 CFR Part 50, Appendix A GDC 2, 4 and 10 CFR 52.47(b)(1)
- ◆ Selected missile types - Pipe, Automobile, Solid Steel Sphere

3.5 Missile Protection

3.5.1 Missile Selection and Description(Cont'd)

- **Missile Protection(Cont'd)**

- Site Proximity Missile (Except Aircraft)
 - ◆ Evaluation of the potential for site proximity explosions and missiles by the COL Applicant
- Aircraft Hazards
 - ◆ Justification for the site-specific aircraft hazard and an aircraft hazard analysis in accordance with the requirements of NRC RG 1.206 by the COL Applicant

3.5.2 Structure, Systems, and Components to be Protected from Externally Generated Missiles

- **Structures used to protect safety-related SSCs meet the requirements of NRC RGs 1.13, 1.27, 1.115 and 1.117**
- **Essential SSCs protected against missile impact are listed in DCD Table 3.5-4**

3.5 Missile Protection

3.5.3 Barrier Design Procedures

- **Missile barriers are designed with sufficient strength and thickness to prevent local damage including perforation, spalling and scabbing, and overall damage**
- **Evaluation of Local Structural Effects**
 - Concrete Barriers
 - ◆ Estimation of the depth of missile penetration
 - ◆ Assessment of secondary missile by spalling
 - Steel Barriers
 - ◆ Not use in the APR1400 design
- **Overall Damage Prediction**
 - For the evaluation of overall response of reinforced concrete barriers under impact and impulse load, nonlinear and elasto-plastic response of structures is used.

3.6 Protection against Dynamic Effects

NON-PROPRIETARY

Associated with the Postulated Rupture of Piping

3.6.1 Plant Design for Protection against Postulated Piping Failures in Fluid Systems Inside and Outside the Containment

- **Design Bases**

- Codes & Standards:

- ◆ 10 CFR 50, Appendix A, GDC 2, 4
- ◆ SRP 3.6.1, 3.6.2, 3.6.3, BTP 3-3 and 3-4
- ◆ ANSI/ANS 58.2 -1988

- High and moderate energy fluid systems are summarized in Table 3.6-1.

- **Protection of Essential SSCs**

- The design to protect essential SSCs from the effect of postulated break is basically achieved by separation, physical barriers, or pipe whip restraints(PWR).

3.6 Protection against Dynamic Effects

NON-PROPRIETARY

Associated with the Postulated Rupture of Piping

3.6.2 Determination of Break Locations and Dynamic Effects Associated with the Postulated Rupture of Piping

- **Postulated pipe break locations are determined in accordance with BTP 3-4, Part B**
 - Terminal ends
 - Intermediate location based on stress analysis results
- **The criteria used to define locations and configurations of pipe rupture are provided in Subsection 3.6.2.1**
- **The analytical methods to define forcing functions are described in Subsection 3.6.2.3**

3.6 Protection against Dynamic Effects

NON-PROPRIETARY

Associated with the Postulated Rupture of Piping

3.6.2 Determination of Break Locations and Dynamic Effects Associated with the Postulated Rupture of Piping (Cont'd)

- **The MSVH is the only area that meets the break exclusion criteria described in BTP 3-4 B.A.(ii) for ASME Class 2 piping**
 - The design of break exclusion is applied for fluid system piping in containment penetration areas, between containment wall and auxiliary building anchor wall beyond the isolation valve.
- **Forcing functions for pipe thrust and jet loads are based on ANSI 58.2 Appendix B**
- **Dynamic and environmental effects due to HELB and MELB are summarized in the pipe rupture analysis report**
 - Dynamic effects analysis; pipe whip, jet impingement and sub-compartment pressurization
 - Environmental effects analysis; flooding, environmental qualification

* MSVH: Main Steam Valve House

3.6 Protection against Dynamic Effects

NON-PROPRIETARY

Associated with the Postulated Rupture of Piping

3.6.2 Determination of Break Locations and Dynamic Effects

Associated with the Postulated Rupture of Piping (Cont'd)

- **Non-conservatism of jet impingement model in ANSI 58.2 will be addressed as an open item**
 - Blast Waves
 - Jet Plume Expansion and Zone of Influence
 - Distribution of Pressure within the Jet Plume
 - Jet Dynamic Loading including Potential Feedback Amplification and Resonance Effects.
- **The current technical report and related RAI responses will be revised to address the above issues**

3.6 Protection against Dynamic Effects

NON-PROPRIETARY

Associated with the Postulated Rupture of Piping

3.6.2 Determination of Break Locations and Dynamic Effects

Associated with the Postulated Rupture of Piping (Cont'd)

- **Pipe Whip Restraints**

- Provide to protect the safety-related component against the effects of pipe whipping during postulated pipe break
- Consideration of pipe whip restraints design
 - ◆ Pipe break blowdown thrust, functional requirement, deformation limitations
 - ◆ Properties of whipping pipe, capacity of the support structure
- Allowable stresses
 - ◆ Limitation of strain of energy-absorbing members
 - ◆ Application of AISC N690 for non-energy-absorbing members

3.6 Protection against Dynamic Effects

NON-PROPRIETARY

Associated with the Postulated Rupture of Piping



3.6.3 Leak-Before-Break Evaluation Procedure

- LBB analysis is used to eliminate the dynamic effects of pipe breaks
- This subsection describes how the piping system meets the LBB criteria in accordance with SRP 3.6.3 and demonstrates that the probability of pipe rupture is extremely low
- LBB is applied to the following piping systems:
 - Reactor coolant loop piping
 - Surge line
 - Direct vessel injection line inside containment
 - Shutdown cooling line inside containment
- The method of PEDs (Piping Evaluation Diagrams) allows for the evaluation of the piping system incorporating LBB considerations into the piping design
- The LBB evaluation is consistent with the requirements of SRP 3.6.3 and NUREG-1061, Volume 3

3.7 Seismic Design

3.7.1 Seismic Design Parameters

- **Certified Seismic Design Response Spectra (CSDRS)**
 - Peak ground acceleration (PGA) : 0.3g
 - Zero period acceleration frequency : 50 Hz
 - CSDRS based on the NRC RG 1.60 with enrichment in the high frequency range.






ACRS SC Meeting (June 5, 2017)

3.7 Seismic Design

3.7.1 Seismic Design Parameters

- **CSDRS Time Histories**

- Generation criterion : Single set of time histories (Option 1, Approach 1) in NRC SRP 3.7.1
- Initial seed motions : Northridge earthquake time histories
- Cross-correlation coefficients :
 - EW-NS : $0.032 < 0.16$
 - NS-VT : $0.029 < 0.16$
 - EW-VT : $0.079 < 0.16$





ACRS SC Meeting (June 5, 2017)

3.7 Seismic Design

3.7.1 Seismic Design Parameters

- **Hard Rock High Frequency (HRHF) Response Spectra**
 - GMRS for some Central and Eastern United States rock sites show higher amplitude at high frequency than the CSDRS.
 - Peak ground acceleration : 0.46g






ACRS SC Meeting (June 5, 2017)

3.7 Seismic Design

3.7.1 Seismic Design Parameters

- **HRHF Time Histories**
 - Generation criterion : Single set of time histories (Option 1, Approach 1) in NRC SRP 3.7.1
 - Initial seed motions : Nahanni earthquake time histories
 - Cross-correlation coefficients :
 - EW-NS : $0.028 < 0.16$
 - NS-VT : $0.031 < 0.16$
 - EW-VT : $0.036 < 0.16$



ACRS SC Meeting (June 5, 2017)

3.7 Seismic Design

3.7.1 Seismic Design Parameters

- **Critical Damping Values**

- Damping values for structural material based on NRC RG 1.61.
- Soil damping values which are used in soil-structure interaction analysis recommended by EPRI TR-102293.


Structural material	SSE	OBE
Welded steel or bolted steel with friction connections	4 %	3 %
Bolted steel with bearing connections	7 %	5 %
Prestressed concrete	5 %	3 %
Reinforced concrete	7 %	4 %

ACRS SC Meeting (June 5, 2017)


3.7 Seismic Design

3.7.1 Seismic Design Parameters


- **Supporting Media for Seismic Category I Structures**
 - Founded directly on rock or competent soil
 - Eight soil profiles and one fixed-base condition



S01 Soil Profile



S04 Soil Profile



S09 Soil Profile

ACRS SC Meeting (June 5, 2017)

3.7 Seismic Design


3.7.2 Seismic System Analysis

- **Seismic Analysis Methods**
 - Complex frequency response analysis method : used for three-dimensional soil-structure interaction analyses including a fixed-base analysis to obtain seismic responses of the standard plant seismic Category I structures
- **Analysis Models of Seismic Category I Structures**
 - Safety-related structures model : three-dimensional finite element models (FEMs).


3.7 Seismic Design

3.7.2 Seismic System Analysis

- Analysis Models of Seismic Category I Structures



Auxiliary Building



Emergency Diesel Generator Building and Diesel Fuel Oil Storage Tank Room

3.7 Seismic Design

3.7.2 Seismic System Analysis

- **In-structure Response Spectra**

- Generation method and software : Complex frequency response method and ACS SASSI software at wall and floor locations in the FEMs
- Effect of potential concrete cracking : uncracked and cracked concrete stiffness cases
- Design-basis ISRS : Enveloped ISRS of 9 soil cases for both uncracked and cracked concrete stiffness cases

3.7 Seismic Design


3.7.2 Seismic System Analysis

- **Interaction of Non-Seismic Category I Structures with Seismic Category I Structures**
 - Seismic Category II structures : Turbine generator building and compound building with a 900 mm (3 ft) gap on nuclear island
 - Analysis and design of seismic Category II structure : Prevention their failure under SSE conditions
 - Structure-soil-structure interaction (SSSI) analysis : Evaluation on the nuclear island structures due to presence of adjacent non-seismic Category I structures, the SSSI analysis using the coupled model
 - SSSI effect
 - Increased seismic response of emergency diesel generator building by nuclear island
 - Negligible effect to nuclear island by non-seismic Category I structures

3.7 Seismic Design

3.7.2 Seismic System Analysis

- SSSI Analysis Model




SSSI Analysis Model for Power Block with Surface-supported Foundation Condition

ACRS SC Meeting (June 5, 2017)

3.7 Seismic Design

3.7.2 Seismic System Analysis

- SSSI Analysis Model



SSSI Analysis Model for Nuclear Island and EDGB with Excavated Soil Volume

ACRS SC Meeting (June 5, 2017)

3.7 Seismic Design

3.7.2 Seismic System Analysis

- **Incoherent SSI Analysis with HRHF Seismic Input Motion**
 - APR1400 HRHF response spectra : 0.8-fractile GMRS based on the 2011 EPRI Report “Evaluation of seismic hazard at Central and Eastern US nuclear power sites”
 - Incoherent input motion and coherency functions : Developed by Abrahamson (2007) using INCOH code, and incoherent ground motion vector input to ACS SASSI software
 - Evaluated structures, systems and components : Nuclear island (RCB, AB, RCS) and EDGB

3.7 Seismic Design

3.7.3 Seismic Subsystem Analysis

- **Seismic Analysis Methods of Seismic Category I Subsystem**
 - Response spectrum analysis
 - Time-history analysis
 - Equivalent static analysis method

3.7 Seismic Design

3.7.4 Seismic Instrumentation


- **Seismic Monitoring System**

- Seismic monitoring system design in accordance with NRC RG 1.12.
- Time-history accelerographs installed at appropriate locations
 - Free-field
 - Containment structure
 - Other seismic Category I structures

3.8 Design of Category I Structures

3.8.1 Concrete Containment

- Structure Description



ACRS SC Meeting (June 5, 2017)

3.8 Design of Category I Structures

3.8.1 Concrete Containment

- **Containment Dimensions**

- Inside diameter of containment: 45.72 m (150 ft)
- Inside height of containment: 76.66 m (251.5 ft) from the top of base slab to the ceiling of dome apex
- Thickness of containment wall: 1.37 m (4 ft 6 in)
- Dome thickness: 1.22 m (4 ft)

- **Structural Analysis**

- The 3D Finite Element models (ANSYS) are developed to perform the structural analysis of the containment structure.

3.8 Design of Category I Structures

3.8.1 Concrete Containment


- **Combustible Gas Control Inside Containment**

- Structural Integrity of the containment structure (10CFR50.44, RG 1.216)
 - ◆ Factored Load Category requirements of ASME Code Section III, Division 2 Subarticle CC-3720 (for concrete containment)
- Acceptance Criteria (Leak-tightness criteria)
 - ◆ Allowable strain of liner plate: Subarticle CC-3720 of ASME Code
- Temperature-Dependent Material Property Degradation (NUREC/CR-6906)
 - ◆ Maximum temperature = 350 °F


3.8 Design of Category I Structures

3.8.1 Concrete Containment


- Combustible Gas Control Inside Containment (ABAQUS)



Concrete



Liner



Rebar



Tendon

ACRS SC Meeting (June 5, 2017)

3.8 Design of Category I Structures

3.8.1 Concrete Containment





- **Combustible Gas Control Inside Containment**

- Max Pressure = 109 psig
- Analysis Results
 - ◆ The maximum Liner plate strain does not reach the allowable limit strain values based on ASME CC 3720.

3.8 Design of Category I Structures

3.8.1 Concrete Containment

- **Ultimate Pressure Capacity (UPC)**
 - Ultimate pressure capacity assessment
 - ◆ Strain limit for pressure capacity in accordance with RG 1.216
 - ◆ Design-basis accident temperature = 290 ° F
 - ◆ **UPC of containment = 158 psig**



Strain contour of tendon, rebar, and liner plate

ACRS SC Meeting (June 5, 2017)

3.8 Design of Category I Structures

3.8.1 Concrete Containment

- **Structural Design**

- The results on the design of the flexural reinforcement are summarized in DCD Tables 3.8A-3 and 3.8A-4.
- For the flexural reinforcement, it is confirmed that the maximum stresses of the provided reinforcement do not exceed the allowable stresses for both the service and factored load conditions.

3.8 Design of Category I Structures

3.8.2 Steel Containment


- **Design of the Steel Part of the Containment**
 - The COL applicant is to provide the detailed design results and evaluation of the ultimate pressure capacity of penetrations, including the Equipment Hatch, Personnel Airlocks, Electrical and Piping Penetration.

3.8 Design of Category I Structures

3.8.3 Concrete and Steel Internal Structures of Steel or Concrete Containment

• Structural Descriptions

- The internal structure is a group of reinforced concrete structures that enclose the reactor vessel and primary system
- The internal structures located in the reactor containment building consist of the following major components:
 - ◆ Primary shield wall (PSW)
 - ◆ Secondary shield wall (SSW)
 - ◆ In-containment refueling water storage tank (IRWST)
 - ◆ Operating and intermediate floors
 - ◆ Refueling Pool




ACRS SC Meeting (June 5, 2017)

3.8 Design of Category I Structures

3.8.3 Concrete and Steel Internal Structures of Steel or Concrete Containment

- **Structural Analysis**

- The 3-dimensional Finite Element models (ANSYS) are developed to perform the structural analysis of the internal structure.



3.8 Design of Category I Structures

3.8.3 Concrete and Steel Internal Structures of Steel or Concrete Containment

- **Structural Design**

- The results on the design are summarized in DCD Tables 3.8A-21 through 3.8A-25.
- The concrete section strengths determined from the criteria in ACI 349 are sufficient to resist the design basis loads.

3.8 Design of Category I Structures

3.8.4 Other Seismic Category I Structures



- **Structural Descriptions of AB Superstructure**

- AB is reinforced concrete structures, which is composed of rectangular walls, floor slabs, columns, and beams.
- AB surrounds RCB with a seismic gap of 150 mm (6 in.) and shares a common basemat with RCB. AB structure provides a protection against both external and internal hazards.
- AB is separated from other buildings by the isolation gap of 900 mm (3 ft.)
- The auxiliary building is rectangular with maximum dimensions of 106.0 m × 107.6 m (348 ft × 353 ft).

3.8 Design of Category I Structures

3.8.4 Other Seismic Category I Structures

- **Structural Analysis for AB Superstructures**
 - Global Structural Analysis
 - ◆ The analysis is to compute all member forces of shear walls and sectional shear forces of slabs in AB.



3.8 Design of Category I Structures

3.8.4 Other Seismic Category I Structures

- **Structural Design of AB Superstructures**

- The results on the design for **AB** are summarized in DCD Tables 3.8A-29 and 3.8A-33.
- The concrete section strengths determined from the criteria in ACI 349 are sufficient to resist the design basis loads.

3.8 Design of Category I Structures

3.8.4 Other Seismic Category I Structures

- **Structural Descriptions of EDG Building Block**

- Emergency diesel generator (EDG) building block consists of two independent buildings:
 - ◆ EDG building (EDGB)
 - ◆ Diesel Fuel Oil Tank (DFOT) building
- EDGB is separated from other buildings by the isolation gap of 900 mm (3 ft.)
- EDGB houses two additional generators, and DFOT building houses the DFOTs thereof.

3.8 Design of Category I Structures

3.8.4 Other Seismic Category I Structures

- **Structural Design of EDG Building Block**

- The results on the design for EDG Building are summarized in DCD Tables 3.8A-36.
- The concrete section strengths determined from the criteria in ACI 349 are sufficient to resist the design basis loads.

3.8 Design of Category I Structures

3.8.5 Foundations


- **Structural Descriptions of NI Common Basemat**
 - NI common basemat consists of two areas, one central circular shaped area which supports RCB, and the other rectangular shaped area which supports AB.
 - Disk-shaped reinforced concrete structure in RCB area has variable thickness.

3.8 Design of Category I Structures

3.8.5 Foundations

- **Structural Analysis**

- For the applied loads on the NI basemat analysis, the equivalent static acceleration method is used to consider the seismic load.



3.8 Design of Category I Structures

3.8.5 Foundations

- **Stability Check Result**

- Stability check for overturning, sliding, and floatation of NI common basemat was performed in accordance with Section II of SRP 3.8.5 and the results are as follows.

NI Common Basemat		Allowable Criteria (A)	Factor of Safety (B)	Result (A < B)
Overturning	by Wind	1.5	16.46	OK
	by Earthquake	1.1	1.24	OK
Sliding	by Wind	1.5	8.30	OK
	by Earthquake	1.1	1.25	OK
Floatation		1.1	3.39	OK

ACRS SC Meeting (June 5, 2017)

3.8 Design of Category I Structures

3.8.5 Foundations

- **Structural Design of NI common basemat**
 - The results on the design for RCB Basemat and AB Basemat are summarized in DCD Tables 3.8A-10 through Tables 3.8A-13.
 - The concrete section strengths determined from the criteria in ASME Section III Division 2 Subsection CC for RCB Basemat and ACI 349 for AB Basemat are sufficient to resist the design basis loads.

3.9 Mechanical Systems and Components

3.9.1 Special Topics for Mechanical Components (1/2)

- This subsection provides the transients used in the design and fatigue analysis of ASME Code Class 1 components and reactor internals.
- The design transients give fluid system pressure, temperature, flow rate, and frequency.
 - ◆ Not cover the seismic loading and other mechanical loading on each component.
- The design transient items of each Service Level (A, B, C and D) and test conditions are addressed.
- The 60-year design life is considered when determining the number of occurrences of each transient.
- Fatigue evaluation includes the effects of reactor coolant environment of the APR1400 components
- The frequencies of events traditionally categorized as a Service Level C condition are conservatively modified to be classified as a Service Level B condition for design purpose.

3.9 Mechanical Systems and Components

3.9.1 Special Topics for Mechanical Components (2/2)

- A number of computer programs, which are commercial codes and in-house codes, are used in the stress and structural analyses for ASME Code Class systems, components and supports.
- All computer programs are verified and validated in accordance with design control methods, consistent with the quality assurance program described in Chapter 17.
- Experimental stress analysis is not used for the APR1400.
- In order to consider the evaluation of the faulted conditions, the major components of the Reactor Coolant System (RCS) are designed to withstand the loads associated with the pipe breaks described in Section 3.6.
- The system or subsystem analysis used to establish or confirm loads that are specified for the design of components and supports is performed on an elastic basis.

3.9 Mechanical Systems and Components

3.9.2 Dynamic Testing and Analysis of Systems, Components, and Equipment (1/3)

- **Reactor Coolant System (RCS) Structural Analysis (App. 3.9B)**
 - Finite element model is used for RCS Analysis
 - Static Analysis for normal operating conditions
 - ◆ Dead weight, Pressure and Temperature
 - Seismic Analysis
 - ◆ Described in Section 3.7
 - Postulated pipe break analysis
 - ◆ Breaks effects of pipe lines to which LBB concept is not applied
 - ◆ Jet impingements and thrust
 - ◆ Subcompartment pressure and blowdown loads
 - ◆ Branch nozzle loads

3.9 Mechanical Systems and Components

3.9.2 Dynamic Testing and Analysis of Systems, Components, and Equipment (2/3)

- **Flow-Induced Vibration Assessment for Reactor Internals (3.9.2.3, 3.9.2.4, 3.9.2.6 and APR1400-Z-M-NR-14009)**
 - APR1400 is classified as non-prototype Category I with Palo Verde Unit 1 as the valid prototype in accordance with RG 1.20.
 - ◆ APR1400 reactor internals are substantially the same arrangement, design, size and operating conditions as the valid prototype (Palo Verde 1).
 - Analysis Program for Comprehensive Vibration Assessment Program
 - ◆ Calculation of hydraulic loads
 - ◆ Calculation of dynamic response of reactor internals
 - ◆ Measured responses are smaller than the predicted values
 - Inspection Program for Comprehensive Vibration Assessment Program
 - ◆ Pre and post hot functional test inspection

3.9 Mechanical Systems and Components

3.9.2 Dynamic Testing and Analysis of Systems, Components, and Equipment (3/3)

- **Dynamic System Analysis for the Reactor Internals under Faulted Conditions**
 - Dynamic analyses for the reactor internals and core are performed to determine the maximum structural responses under the pipe breaks and seismic loadings.
 - ◆ Excitation : Pipe break blowdown loads and reactor vessel motions
 - ◆ Structural analysis using finite element method
 - ◆ The analysis results for the core are provided to evaluate the structural integrity of fuel assembly as shown in DCD Subsection 4.2.
 - The analysis results for the faulted conditions shows that the reactor internals meet the stress limits of ASME Section III, Subsection NG.
- **Dynamic System Analysis for the CEDM**
 - Calculation of the maximum structural responses to confirm structural integrity of the pressure housings and scramability.

3.9 Mechanical Systems and Components

3.9.3 ASME Code Class 1, 2 and 3 Components, Component Supports, and Class CS Core Support Structures (1/2)

- **Loading Combinations, Design Transients, and Stress Limits**
 - Loading combinations: Categorized as Design, Level A, Level B, Level C, and Level D conditions
 - Design Transients: Design pressure, temperature, and other loading
 - Stress limits: Stress analysis and fatigue evaluations
- **Design and Installation of Pressure Relief Devices**
 - Designed in accordance with ASME Section III, Appendix O.
 - The pressurizer pilot-operated safety relief valves (POSRV) are designed to provide overpressure protection for the RCS.
 - Pressure-relieving devices
 - ◆ Class 2 systems: on the steam line and the containment isolation portion of the normal shutdown cooling system (SCS)
 - ◆ Class 3 systems: on heat exchangers, tanks, and piping lines to prevent overpressurization of the components and systems.

3.9 Mechanical Systems and Components

3.9.3 ASME Code Class 1, 2 and 3 Components, Component Supports, and Class CS Core Support Structures (2/2)

- **Pump and Valve Functionality Assurance**

- The functional design and qualification of safety-related active components are performed in accordance with ASME QME-1-2007.
- The functional capability of active components during and after exposure to design basis events is confirmed by design, analysis, inspection, testing and startup/periodic in-service testing.


- **Component Support Design**

- Designed and constructed in accordance with ASME Section III and ASME Code Case(s) approved in NRC RG 1.84.
- Snubbers, used as shock arrestors for safety-related systems and components, are minimized to the extent practical through the use of design optimization.
- Reasonable assurance of snubber operability is provided by incorporating analytical, design, installation, in-service, and verification criteria.

3.9 Mechanical Systems and Components

3.9.4 Control Element Drive Mechanisms

- This subsection provides information on design, functional requirements, and operability assurance program for the Control Element Drive Mechanism (CEDM) portion of the Control Rod Drive System (CRDS).
- The CEDM for the APR1400 is based on the System 80 CEDM which has been used in many nuclear power plants in the United States and Korea.
- The CEDM pressure housing is designed in accordance with the ASME Code Section III, Subsection NB.





ACRS SC Meeting (June 5, 2017)

3.9 Mechanical Systems and Components

3.9.5 Reactor Pressure Vessel Internals (1/2)

- Safety Class : Safety Class 3 (ANSI/ANS 51.1)
- Seismic Category : Seismic Category I (RG 1.29)
- Designed and constructed according to Section III, NG




ACRS SC Meeting (June 5, 2017)

3.9 Mechanical Systems and Components

3.9.5 Reactor Pressure Vessel Internals (2/2)

- To provide axial force on the flange of the upper guide structure barrel and core support barrel.
- To be designed to accommodate the differential thermal expansion.



ACRS SC Meeting (June 5, 2017)

3.9 Mechanical Systems and Components

3.9.6 Functional Design, Qualification, and Inservice Testing Program for Pumps, Valves, and Dynamic Restraints

- **Inservice Testing (IST) Program**

- IST program for ASME Code, Section III, Class 1, 2 and 3 safety-related pumps, valves, and dynamic restraints is developed in accordance with the requirements of ASME OM Code, as required by 10 CFR 50.55a(f) and the acceptable ASME Code Cases listed in RG 1.192 that are incorporated by 10 CFR 50.55a(b).
- The COL applicant will provide a full description of the IST program.

- **Functional Qualification**

- Functional qualification of safety-related pumps, valves, and dynamic restraints (snubbers) are performed in accordance with ASME QME-1-2007, as endorsed in RG 1.100, Rev.3.

3.10 Seismic and Dynamic Qualification of Mechanical and Electrical Equipment

NON-PROPRIETARY

3.10.1 Seismic Qualification Criteria

- Seismic Qualification Requirements for Seismic Category I instrumentation, electrical equipment, and mechanical equipment::
 - ◆ To provide reasonable assurance of structural integrity and performance of their designated safety-related function(s) or intended function(s) under the postulated SSE in combination with other concurrent loading conditions identified in the equipment's design specification.
- IEEE Std 344-2004, as modified by RG 1.100, for safety-related mechanical and electrical equipment and their supports
- IEEE Std. 323-2003 in conjunction with the environmental qualification
- ASME Code, Section III for structural integrity of safety-related pressure boundary components
- ASME QME-1-2007, as modified by RG 1.100, for qualification of active mechanical equipment

3.10 Seismic and Dynamic Qualification of Mechanical and Electrical Equipment

NON-PROPRIETARY

3.10.2 Methods and Procedures for Qualifying Mechanical and Electrical Equipment and Instrumentation

- **Testing**

- Conducted for equipment that cannot be qualified with analysis alone or equipment having components that potentially cause any malfunctions related to their intended functions.

- **Analysis**

- Analysis without testing is acceptable only if structural integrity alone can assure the design-intended design function.

- **Combination of Testing and Analysis**

- Utilized when the equipment cannot be practically qualified by analysis or testing alone

3.10 Seismic and Dynamic Qualification of Mechanical and Electrical Equipment

NON-PROPRIETARY

3.10.3 Methods and Procedures of Analysis or Testing of Supports of Mechanical and Electrical Equipment and Instrumentation

- **Tests or analyses to assure structural capability**

- Electrical equipment and instrumentation supports (including instrument racks, control consoles, cabinets, and panels) are tested with the equipment installed or equivalent dummy.
- For mechanical equipment supports (including pumps, valves, valve operators and fans), in accordance with ASME Code, Section III
- For instrumentation line supports, using the criteria from ASME Code, Section III, Subsection NF for Equipment Class 1 and 2 supports

3.10 Seismic and Dynamic Qualification of Mechanical and Electrical Equipment

NON-PROPRIETARY

3.10.4 Test and Analyses Results and Experience Database

- **Seismic qualification file includes:**

- Qualification method used for equipment
- Tests and analyses results
- List of systems, equipment
- Equipment support structures
- Seismic Qualification Summary Data Sheets (SQSDSs), which summarize the component's qualification
- Seismic Input Requirements

3.11 Environmental Qualification of Mechanical and Electrical Equipment

NON-PROPRIETARY

3.11.1 Equipment Location and Environmental Conditions

- **Equipment Location**

- Location of each equipment is specified in DCD Table 3.11-2.
- Classified Mild or Harsh based on the environmental conditions.

- **Environmental Conditions**

- Normal, AOOs, DBA, Post DBA
- Environmental parameter values for each room are specified in APR1400 Equipment Qualification Program (APR1400-E-X-NR-14001-P) Table 3.

3.11 Environmental Qualification of Mechanical and Electrical Equipment

NON-PROPRIETARY

3.11.2 Qualification Tests and Analyses

- **Environmental Qualification of Class 1E equipment**
 - Conforms to the requirements of 10 CFR 50.49, 10 CFR 50 Appendix B, NRC RG 1.89, and IEEE Std. 323.
 - Valve actuator(IEEE Std. 382), Cable(IEEE Std. 383), etc.

3.11.3 Qualification Test Results

- **Results and status of qualification are documented in auditable files in accordance with 10 CFR 50.49(j)**

3.11.4 Loss of Ventilation

- **The vital instrument and equipment are served with 100% redundancy of the HVAC unit**
- **Related section: 6.4, 9.4**

3.11 Environmental Qualification of Mechanical and Electrical Equipment

NON-PROPRIETARY

3.11.5 Radiation Environment

- **Radiation Qualification are developed based on:**
 - Up to the time the equipment is required to remain functional
 - Limiting DBAs: LOCA, MSLB, and FHA
- **Assumptions for determining normal/accident condition TIDs**
 - Used codes: Microshield code / RUNT-G code
 - Based on NRC RGs 1.89 and 1.183
 - 1.0% failed fuel for normal TIDs and accident source term used for radiological consequence analysis for accident TIDs
 - 60 years of continuous normal operation with full power plus 1 year post-accident
 - Additional margin of 10% for uncertainty of test

3.11 Environmental Qualification of Mechanical and Electrical Equipment

NON-PROPRIETARY


3.11.6 Qualification of Mechanical Equipment

- **Active mechanical equipment**
 - Focus on nonmetallic parts
 - Conforms to ASME QME-1, Appendix QR-B
- **Passive mechanical equipment**
 - Safety function: maintain structural integrity

3.12 Piping Design Review

3.12.1 Introduction

- **This section provides**
 - Structural integrity
 - Functional capability
- **Graded Approach**
 - RCS main loops, Surge line, DVI, and SC
 - MS and FW from nozzle to MSVH



3.12.2 Codes and Standards

- **The safety-related piping system design and analysis**
 - 2007 Edition with 2008 addenda of the ASME Section III
- **Pipe supports**
 - NF of the 2007 Edition with 2008 addenda of the ASME Section III

3.12 Piping Design Review

3.12.3 Piping Analysis Methods

- Procedure for analytical modeling, selection of frequencies, damping criteria, combination of modal responses
- Seismic analysis methods
 - ◆ Response spectrum, Time-history, or Equivalent static load method

3.12.4 Piping Modeling Technique

- Computer Codes : PIPESTRESS, ANSYS, RELAP5, GTSTRUDL
- The piping benchmark problems prescribed in NUREG/CR-1677 are used to validate the PIPESTRESS computer program used in piping system analysis.

3.12.5 Piping Stress Analysis Criteria

- Based on the methodology and equations from the ASME Code, pipe stresses are calculated for various load combinations. The ASME Code includes design limits for design conditions; Service Levels A, B, C, D; and testing.
- The environmental fatigue for class 1 piping is performed in accordance with NRC RG 1.207

3.12 Piping Design Review

3.12.6 Piping Support Design Criteria

- Seismic Category I pipe supports are designed in accordance with ASME Section III, NF for Service Levels A, B, C, and D.
- For non-seismic category pipe supports supporting piping analyzed to ASME B31.1, the requirements of ASME B31.1 are met, where applicable
- Baseplate and Anchor Bolt Design for Piping Support
 - ◆ ACI 349-01 Appendix B, NRC RG 1.199, NRC Bulletin 79-02

3.13 Threaded Fasteners (ASME Section III Class 1, 2, and 3)

NON-PROPRIETARY

3.13.1 Design Consideration (1/2)

- **Materials Selection**

- Selected in accordance with ASME Section III NCA-1220 and NB/NC/ND-2128
- Fabricated using the materials prescribed in ASME Section III or Code cases allowed by RG 1.84
- Prevention of boric acid corrosion (BAC), galvanic corrosion unless considered to be acceptable

- **Special Materials Fabrication Processes and Special Controls**

- in accordance with Section II, Section III NB/NC/ND-2200
- Cleaned in accordance with RG 1.28

- **Fabrication Inspection**

- Inspected in accordance with ASME Section III, NB/NC/ND-2580

3.13 Threaded Fasteners (ASME Section III Class 1, 2, and 3)

3.13.1 Design Consideration (2/2)

- **Lubricants**

- Selected in accordance with NUREG-1339
- Acceptable lubricants : Loctite N-5000, Neolube, and Never Seez Pure Nickel Special Nuclear Grade
- MoS₂ is not allowed

- **Fracture Toughness for Ferritic Threaded Fasteners:**

- Tested in accordance with Section III NB/NC/ND-2300 and 10CFR50 Appendix G

- **Certified Material Test Reports**

- Quality records are controlled, maintained, and stored in accordance with 10CFR Part 50, Appendix B; ASME NQA-1; and ASME NCA-3860

3.13 Threaded Fasteners (ASME Section III Class 1, 2, and 3)

3.13.2 Inservice Inspection Requirements

- **Preservice Inspection (PSI) and Inservice Inspection (ISI)**
 - The relevant requirements of ASME Section XI are followed
 - Inspection programs are to be submitted to the NRC by the COL applicant

Attachments

❖ RAI Summary

	No. of Questions	No. of Responses	Not Responded	No. of Open Items
3.1	0	0	0	0
3.2	12	12	0	0
3.3	0	0	0	0
3.4	10	10	0	1
3.5	21	21	0	0
3.6	19	14	5	5
3.7	30	30	0	1
3.8	56	56	0	7
3.9	58	58	0	5
3.10	9	9	0	1
3.11	24	24	0	1
3.12	18	18	0	2
3.13	0	0	0	0
Total	257	252	5	23

ACRS SC Meeting (June 5, 2017)

Chapter 3 Open Items Summary

❖ RAI 8197, Question 03.07.02-1

- Date of issue: Aug. 31, 2015
- Description of issue: Adequacy of the number of modes used in HRHF incoherency analysis to capture the incoherent-motion
- Point of argument:
 - Justification for implementing ISRS reduction levels in excess of those provided in SRP 3.7.2
 - Justification for selection of appropriate number of modes to be used in HRHF incoherency analysis
 - Structural evaluation for the HRHF input motions
 - Justification of non-converged 16 mode response and evaluation of seismic demand on the plant structures for 16 mode response

Chapter 3 Open Items Summary

❖ RAI 8245, Question 03.08.03-5

- Date of issue: Sept. 14, 2015
- Description of issue: Design of concrete and steel internal structures of concrete containment
- Point of argument: Design of concrete slab, Effect on design of internal concrete structure due to separated slab analysis model.

Chapter 3 Open Items Summary

❖ RAI 8285, Question 03.08.05-7

- Date of issue: Oct. 19, 2015
- Description of issue: Construction sequence analysis & settlement of basemat
- Point of argument: Effect on the design of super structure due to construction sequence analysis and allowable settlement criteria

❖ RAI 8285, Question 03.08.05-8

- Date of issue: Oct. 19, 2015
- Description of issue: Liner & non-liner analysis considering 100-40-40 method
- Point of argument: Design of NI common basemat under linear & non-linear analysis considering 100-40-40 method

Chapter 3 Open Items Summary

❖ RAI 8285, Question 03.08.05-12

- Date of issue: Oct. 19, 2015
- Description of issue: Soil bearing pressure
- Point of argument: Comparison of soil bearing pressure between SASSI and structural analysis considering equivalent static acceleration.

❖ RAI 8285, Question 03.08.05-13

- Date of issue: Oct. 19, 2015
- Description of issue: Consideration of crane load for seismic category I structures.
- Point of argument: Technical basis for consideration of crane load

Chapter 3 Open Items Summary

❖ RAI 8285, Question 03.08.05-16

- Date of issue: Oct. 19, 2015
- Description of issue: Soil bearing pressure evaluation
- Point of argument: Explanation of soil bearing pressure evaluation in related documents.

❖ RAI 8285, Question 03.08.05-17

- Date of issue: Oct. 19, 2015
- Description of issue: Differential settlement
- Point of argument: The differential settlement criteria and approaching method to calculate differential settlement, all issues are closed and defer to RAI 8285, Question 03.08.05-7.

Chapter 3 Open Items Summary

❖ RAI 7955, Question 03.12-2

- Date of issue: Jun. 17, 2015
- Description of issue: Evaluations of piping systems selected for the graded approach
- Point of argument: - The evaluations will be finished at the end of June, since the new version of PIPESTRESS was released at the end of 2016.

❖ RAI 8278, Question 03.12-9

- Date of issue: Nov. 16, 2015
- Description of issue: HRHF evaluation of the piping systems within the graded approach
- Point of argument: - Justification for not having evaluated the piping that was selected in the graded approach for HRHF seismic effects
- The results of evaluations is submitted in May.

Chapter 3 Open Items Summary

❖ RAI 8373, Question 03.12-10

- Date of issue: Nov. 16, 2015
- Description of issue: Time history analysis
- Point of argument: - ASCE standard is not completely consistent with current NRC guidance and staff positions
 - The number of modes is sufficient to ensure that inclusion of all remaining modes does not result in more than a 10 percent increase in the total response of interest.

Attachment: List of COL Items for Ch. 3 (1/14)

COL Identifier	Description
COL 3.3(1)	The COL applicant is to demonstrate that the site-specific design wind speed is bounded by the design wind speed of 64.8 m/s (145 mph).
COL 3.3(2)	The COL applicant is to demonstrate that the site-specific seismic Category II structures adjacent to the seismic Category I structures are designed to meet the provisions described in Subsection 3.3.1.2.
COL 3.3(3)	The COL applicant is to perform an analysis if the site-specific wind and tornado/hurricane characteristics are not bounded by the site parameter postulated for the certified design.
COL 3.3(4)	The COL applicant is to provide reasonable assurance that site-specific structures and components not designed for the extreme wind loads do not impact either the function or integrity of adjacent seismic Category I SSCs.

ACRS SC Meeting (June 5, 2017)

Attachment: List of COL Items for Ch. 3 (2/14)

COL Identifier	Description
COL 3.4(1)	The COL applicant is to provide the site-specific design of plant grading and drainage.
COL 3.4(2)	The COL applicant is to provide site-specific information on protection measures for the design basis flood, such levees, seawalls, flood walls, revetments or breakwaters or site bulkheads pursuant to RG 1.102 as required in Subsection 2.4.10.
COL 3.4(3)	The COL applicant is to establish procedures and programmatic controls to ensure the availability of the floor drainage.
COL 3.4(4)	The COL applicant is to periodically inspect watertight doors and the penetration seals to ensure their functionality.
COL 3.4(5)	The COL applicant is to provide flooding analysis with flood protection and mitigation features from internal flooding for the CCW Heat Exchanger Building and ESW Building.
COL 3.4(6)	The COL applicant is to provide the site-specific flooding hazards from engineered features, such as water tank collapsing, water piping breaking, etc.
COL 3.4(7)	The COL applicant is to confirm that the potential site-specific external flooding events are bounded by design basis flood values or otherwise demonstrate that the design is acceptable.
COL 3.4(8)	The COL applicant is to provide the site-specific dewatering system if the plant is built below the design basis flood level.
COL 3.4(9)	The COL applicant is to describe the basis for the Probable Maximum Flood (PMF) to determine the maximum site-specific ground water elevation above the grade that may occur from tsunami or hurricane sources.
COL 3.4(10)	The COL applicant is to identify any site-specific physical models that could be used to predict prototype performance of hydraulic structures and systems.

Attachment: List of COL Items for Ch. 3 (3/14)

COL Identifier	Description
COL 3.5(1)	The COL applicant is to provide the procedure for heavy load transfer to strictly limit the transfer route inside and outside containment during plant maintenance and repair periods.
COL 3.5(2)	The COL applicant is to provide the procedures which ensure that equipment required during maintenance, should be removed from containment prior to operation, moved to a location where it is not a potential hazard to SSC important to safety, or seismically restrained.
COL 3.5(3)	The COL applicant is to perform an assessment of the orientation of the turbine generator of this and other unit(s) at multi-unit sites for the probability of missile generation using the evaluation of Subsection 3.5.1.3.2 to verify that essential SSCs are outside the low-trajectory turbine missile strike zone.
COL 3.5(4)	The COL applicant is to evaluate site-specific hazards induced by external events that may produce more energetic missiles than tornado or hurricane missiles, and provide reasonable assurance that seismic Category I and II structures are designed to withstand these loads.
COL 3.5(5)	The COL applicant is to confirm that automobile missiles cannot be generated within a 0.5 mile radius of safety-related SSCs that would lead to impact higher than 10.06 m (33 ft) above plant grade.
COL 3.5(6)	The COL applicant is to identify applicable tornado missile spectra and associate velocities for the compound building, and to evaluate the missile protection provided by the building.
COL 3.5(7)	The COL applicant is to evaluate the potential for site proximity explosions and missiles due to train explosions (including rocket effects), truck explosions, ship or barge explosions, industrial facilities, pipeline explosions, or military facilities.
COL 3.5(8)	The COL applicant is to provide justification for the site-specific aircraft hazard and an aircraft hazard analysis in accordance with the requirements of NRC RG 1.206.
COL 3.5(9)	The COL applicant is to provide reasonable assurance that site-specific structures and components not designed for missile loads will not prevent safety-related SSCs from performing their safety function.

Attachment: List of COL Items for Ch. 3 (4/14)

COL Identifier	Description
COL 3.6(1)	The COL applicant is to identify the site-specific SSCs that are safety related or required for safe shutdown that are located near high- and moderate-energy piping systems and that are susceptible to the consequences of piping failures.
COL 3.6(2)	The COL applicant is to provide a list of site-specific high- and moderate-energy piping systems including layout drawings and protection features and the failure modes and effects analysis for safe shutdown due to the postulated HELBs.
COL 3.6(3)	The COL applicant is to confirm that the bases for the LBB acceptance criteria are satisfied by the final as-built design and materials of the piping systems as site-specific evaluations, and is to provide the information including LBB evaluation report for the verification of LBB analyses.
COL 3.6(4)	The COL applicant is to provide the procedure for initial filling and venting to avoid the known causes for water hammer in each piping system designed for LBB.
COL 3.6(5)	The COL applicant is to provide the information on welding of Alloy 52/52M/152 concerning the residual stress and dilution effects of welds.

ACRS SC Meeting (June 5, 2017)

Attachment: List of COL Items for Ch. 3 (5/14)

COL Identifier	Description
COL 3.7(1)	The COL applicant is to demonstrate the applicability of soil degradation models used in site-specific site response analysis for the site conditions.
COL 3.7(2)	The COL applicant is to compare the site-specific strain-compatible soil properties with generic soil properties in order to confirm that the site meets the generic soil profile used in the standard design.
COL 3.7(3)	<p>The COL applicant is to provide the seismic design of the seismic Category I SSCs and seismic Category II structures that are not part of the APR1400 standard plant design. The seismic Category I and II structures are as follows:</p> <ul style="list-style-type: none"> a. Seismic Category I essential service water building b. Seismic Category I component cooling water heat exchanger building c. Seismic Category II turbine generator building d. Seismic Category II compound building e. Seismic Category II alternate alternating current gas turbine generator building
COL 3.7(4)	The COL applicant is to confirm that any site-specific non-seismic Category I structures are designed not to degrade the function of a seismic Category I SSC to an unacceptable safety level due to their structural failure or interaction. The COL applicant is to confirm that the calculated relative displacements do not exceed the gaps between seismic Category I and non-seismic Category I structures.

Attachment: List of COL Items for Ch. 3 (6/14)

COL Identifier	Description
COL 3.7(4)	The COL applicant is to apply the site-specific FIRS as seismic input motions and to establish a site-specific soil profile as a supporting media for the seismic analysis of the seismic Category II structures. The COL applicant is to apply the same seismic analysis procedure as the seismic Category I structures to the seismic Category II structures. The COL applicant is to perform the structural design of the seismic Category II structures using the design codes described in Subsection 3.7.2.8 and Table 3.2-1. The COL applicant is to check the potential effects of sliding and uplift for the seismic Category II structures using the same approach applied in the stability check for the seismic Category I structures.
COL 3.7(5)	The COL applicant is to perform any site-specific seismic design for dams that is required.
COL 3.7(6)	The COL applicant is to perform seismic analysis of buried seismic Category I conduits, and tunnels.
COL 3.7(7)	The COL applicant is to perform seismic analysis for the seismic Category I above-ground tanks.
COL 3.7(8)	The COL applicant that references the APR1400 design certification will determine whether essentially the same seismic response from a given earthquake is expected at each unit in a multi-unit site or each unit is to be provided with a separate set of seismic instruments.
COL 3.7(9)	The COL applicant is to confirm details of the locations of the triaxial time-history accelerographs.
COL 3.7(10)	The COL applicant is to identify the implementation milestones for the seismic instrumentation implementation program based on the discussion in Subsections 3.7.4.1 through 3.7.4.5.
COL 3.7(11)	The COL applicant is to prepare a procedure for the post shutdown inspection and plant restart in accordance with the guidance of NRC RG 1.167.

Attachment: List of COL Items for Ch. 3 (7/14)

COL Identifier	Description
COL 3.8(1)	The COL applicant is to perform concrete long-term material testing in a way which verifies physical properties of materials used during the design stage and the characteristics of long term deformation of concrete.
COL 3.8(2)	The COL applicant is to provide the detailed design results and evaluation of the ultimate pressure capacity of penetrations, including the equipment hatch, personnel airlocks, electrical and piping penetration in accordance with RG 1.216.
COL 3.8(3)	The COL applicant is to provide detailed analysis and design procedure for the equipment hatch, personnel airlocks, and electrical penetrations.
COL 3.8(4)	The COL applicant is to provide a detailed analysis and design procedure for the transfer tube assembly.
COL 3.8(5)	The COL applicant is to provide the design of site-specific seismic Category I structures such as the essential service water building and the component cooling water heat exchanger building, essential service waterconduits, component cooling water piping tunnel, and class 1E electrical duct runs.
COL 3.8(6)	The COL applicant is to evaluate any applicable site-specific loads such as explosive hazards in proximity to the site, projectiles and missiles generated from activities of nearby military installations, potential nonterrorism related aircraft crashes, and the effects of seiches, surges, waves, and tsunamis.
COL 3.8(7)	The COL applicant is to perform the analysis and design of the steel plate for the new fuel storage pit.
COL 3.8(8)	The COL applicant is to determine the environmental condition associated with the durability of concrete structures and provide the concrete mix design that prevents concrete degradation including the reactions of sulfate and other chemicals, corrosion of reinforcing bars, and influence of reactive aggregates.

ACRS SC Meeting (June 5, 2017)

Attachment: List of COL Items for Ch. 3 (8/14)

COL Identifier	Description
COL 3.8(9)	The COL applicant is to determine construction techniques to minimize the effects of thermal expansion and contraction due to hydration heat, which could result in cracking.
COL 3.8(10)	For safety and serviceability of seismic Category I structures during the operation of the plant, the COL applicant is to provide appropriate testing and inservice inspection programs to examine the condition of normally inaccessible, below-grade concrete for signs of degradation and to conduct periodic site monitoring of ground water chemistry. Inservice inspection of the accessible portion of concrete structures is also to be performed.
COL 3.8(11)	The COL applicant is to verify that the coefficient of friction between the lean concrete and waterproofing membrane is bounded by 0.55.
COL 3.8(12)	The COL applicant is to provide reasonable assurance that the design criteria listed in Table 2.0-1 are met or exceeded.
COL 3.8(13)	The COL applicant is to verify that the coefficient of friction between the lean concrete and the supporting medium at the site is equal to or higher than 0.55.
COL 3.8(14)	The COL applicant is to confirm that uneven settlement due to construction sequence of the NI basemat falls within the values specified in Table 2.0-1.
COL 3.8(15)	The COL applicant is to provide a site-specific monitoring program and to monitor differential settlement, tilt, and angular distortion are bounded by following values during construction and plant operation. Allowable differential settlement associated with tilt: 1/1200 Allowable differential settlement associated with angular distortion: 1/750
COL 3.8(16)	The COL applicant is to provide testing and inservice inspection program to examine inaccessible areas of the concrete structure for degradation and to monitor groundwater chemistry.

ACRS SC Meeting (June 5, 2017)

Attachment: List of COL Items for Ch. 3 (9/14)

COL Identifier	Description
COL 3.8(17)	The COL applicant is to provide the following soil information for the APR1400 site: 1) elastic shear modulus and Poisson's ratio of the subsurface soil layers, 2) consolidation properties including data from one-dimensional consolidation tests (initial void ratio, Cc, Ccr, OCR, and complete e-log p curves) and time-versus-consolidation plots, 3) moisture content, Atterberg limits, grain size analyses, and soil classification, 4) construction sequence and loading history, and 5) excavation and dewatering programs.

Attachment: List of COL Items for Ch. 3 (10/14)

COL Identifier	Description
COL 3.9(1)	The COL applicant is to provide the inspection results for the APR1400 reactor internals classified as non-prototype Category I in accordance with NRC RG 1.20.
COL 3.9(2)	<p>The COL applicant is to provide a summary of the maximum total stress, deformation, and cumulative usage factor values for each of the component operating conditions for ASME Code Class 1 components except for ASME Code Class 1 nine major components. For those values that differ from the allowable limits by less than 10 percent, the contribution of each loading category (e.g., seismic, deadweight, pressure, and thermal) to the total stress is provided for each maximum stress value identified in this range.</p> <p>The COL applicant is to also provide a summary of the maximum total stress and deformation values for each of the component operating conditions for Class 2 and 3 components required to shut down the reactor or mitigate consequences of a postulated piping failure without offsite power (with identification of those values that differ from the allowable limits by less than 10 percent).</p>
COL 3.9(3)	The COL applicant is to identify the site-specific active pumps.
COL 3.9(4)	The COL applicant is to provide an IST program including the type of testing and frequency of site-specific pumps subject to IST in accordance with the ASME Code.
COL 3.9(5)	The COL applicant is to provide an IST program including the type of testing and frequency of site-specific valves subject to IST in accordance with the ASME Code.
COL 3.9(6)	The COL applicant is to provide a table listing all safety-related components that use snubbers in their support systems.

ACRS SC Meeting (June 5, 2017)

Attachment: List of COL Items for Ch. 3 (11/14)

COL Identifier	Description
COL 3.10(1)	The COL applicant is to provide documentation that the designs of seismic Category I SSCs are analyzed for OBE, if OBE is higher than 1/3 SSE.
COL 3.10(2)	The COL applicant is to investigate if site-specific spectra generated for the COLA exceed the APR1400 design spectra in the high-frequency range. Accordingly, the COL applicant is to provide reasonable assurance if the functional performance of vibration-sensitive components in the high frequency range.
COL 3.10(3)	The COL applicant is to develop the equipment seismic qualification files that summarize the component's qualification, including a list of equipment classified as seismic Category I in Table 3.2-1 and SQSDS for each piece of seismic Category I equipment.
COL 3.10(4)	The COL applicant is to perform equipment seismic qualification for seismic Category I equipment and provide milestones and completion dates of equipment seismic qualification program.

ACRS SC Meeting (June 5, 2017)

Attachment: List of COL Items for Ch. 3 (12/14)

COL Identifier	Description
COL 3.11(1)	The COL applicant is to identify and qualify the site-specific mechanical, electrical, I&C, and accident monitoring equipment specified in RG 1.97.
COL 3.11(2)	The COL applicant is to identify the nonmetallic parts of mechanical equipment in procurement process.
COL 3.11(3)	The COL applicant is to address operational aspects for maintaining the environmental qualification status of components after initial qualification.
COL 3.11(4)	The COL applicant is to provide a full description of the environmental qualification of mechanical and electrical equipment program.
COL 3.11(5)	The COL applicant is to document the qualification test results and qualification status in an auditable file for each type of equipment in accordance with the requirements 10 CFR 50.49(j).
COL 3.11(6)	The COL applicant is to describe the EQP implementation milestones based on the APR1400 EQP.
COL 3.11(7)	The COL applicant is to provide room number designation for those unidentified rooms in Table 3.11-2

Attachment: List of COL Items for Ch. 3 (13/14)

COL Identifier	Description
COL 3.12(1)	If COL applicant finds it necessary to route ASME Class 1, 2, or 3 piping systems outside the structure, the wind and/or tornado load must be included in the plant design basis loads considering the site-specific loads.

Attachment: List of COL Items for Ch. 3 (14/14)

COL Identifier	Description
COL 3.13(1)	The COL applicant is to maintain quality assurance records including CMTRs on ASME Section III Class 1, 2, and 3 component threaded fasteners in accordance with the requirements of 10 CFR 50.71.
COL 3.13(2)	The COL applicant is to submit the preservice and inservice inspection programs for ASME Section III Class 1, 2, and 3 component threaded fasteners to the NRC prior to performing the inspections.

Attachment: Acronyms (1/4)

- **AB: Auxiliary Building**
- **ACI: American Concrete Institute**
- **ADAMS: Agency Wide Documents Access and Management System**
- **AISC: American Institute of Steel Construction**
- **ANS: American Nuclear Society**
- **ANSI: American National Standards Institute**
- **APR1400: Advanced Power Reactor 1400**
- **ASCE: American Society of Civil Engineers**
- **AOO: Anticipated Operational Occurrence**
- **ASCE: American Society of Civil Engineers**
- **ASME: American Society of Mechanical Engineers**
- **BAC: Boric Acid Corrosion**
- **BTP: Brach Techniacal Position**
- **CCW: Component Cooling Water**
- **CEDM: Control Element Drive Mechanism**
- **CFR: Code of Federal Regulations**
- **CSDRS: Certified Seismic Design Response**
- **COL: Combined License**
- **COLA: Combined License Applicant**

Attachment: Acronyms (2/4)

- **CRDS: Control Rod Drive System**
- **DBA: Design Basis Accident**
- **DCD: Design Control Document**
- **DFOT: Diesel Fuel Oil Tank**
- **DVI: Direct Vessel Injection**
- **EDG: Emergency Diesel Generator**
- **EOL: Emergency Overflow Line**
- **EPRI: Electric Power Research Institute**
- **EQ: Equipment Qualification**
- **ESW: Essential Service Water**
- **FHA: Fuel Handling Area**
- **FIRS: Foundation Input Response Spectra**
- **FW: Feed Water**
- **GDC: General Design Criteria**
- **GMRS: Ground Motion Response Spectra**
- **HELB: High-Energy Line Break**
- **HRHF: Hard Rock High Frequency**
- **HVAC: Heating, Ventilation, Air Conditioning**
- **HVT: Holdup Volume Tank**

Attachment: Acronyms (3/4)

- **IEEE: Institute of Electrical and Electronics Engineers**
- **ISI: Inservice Inspection**
- **IST: Inservice Testing**
- **IRWST: In-containment Refueling Water Storage Tank**
- **ISRS: In-Structure Response Spectra**
- **LBB: Leak Before Break**
- **LOCA: Loss of Coolant Accident**
- **MS: Main Steam**
- **MSLB: Main Steam Line Break**
- **MSVH: Main Steam Valve House**
- **NI: Nuclear Island**
- **NRC: U.S. Nuclear Regulatory Commission**
- **OBE: Operating Basis Earthquake**
- **PED: Piping Evaluation Diagram**
- **PGA: Peak Ground Acceleration**
- **PMF: Probable Maximum Flood**
- **POSRV: Pilot Operated Safety Relief Valve**
- **PSI: Preservice Inspection**
- **PSW: Primary Shield Wall**

Attachment: Acronyms (4/4)

- **PWR: Pipe Whip Restraints**
- **RAI: Request for Additional Information**
- **RCB: Reactor Containment Building**
- **RCS: Reactor Coolant System**
- **RG: Regulatory Guide**
- **RV: Reactor Vessel**
- **SC: Shutdown Cooling**
- **SEI: Structural Engineering Institute**
- **SCS: Shutdown Cooling System**
- **SQSDS: Seismic Qualification Summary Data Sheets**
- **SRP: Standard Review Plan**
- **SRSS: Square Root of the Sum of the Squares**
- **SSC: System, Structural and Component**
- **SSE: Safe Shutdown Earthquake**
- **SSI: Soil-Structure Interaction**
- **SSSI: Structure-Soil-Structure Interaction**
- **SSW: Secondary Shield Wall**
- **TID: Total Integrated Dose**
- **UPC: Ultimate Pressure Capacity**



Presentation to the ACRS Subcommittee

**Korea Hydro & Nuclear Power Co., Ltd (KHNP) and
Korea Electric Power Corporation (KEPCO)**

APR1400 Design Certification Application Review

Safety Evaluation Report with Open Items: Chapter 3

Design of Structures, Systems, Components, and Equipment

June 5, 2017

Staff Review Team

- **Technical Staff**

- ◆ **Jinsuo Nie**, Structural Engineer, Structural Engineering Branch
- ◆ **Robert Roche-Rivera**, Structural Engineer, Structural Engineering Branch
- ◆ **Vaughn Thomas**, Structural Engineer, Structural Engineering Branch
- ◆ **Ata Istar**, Structural Engineer, Structural Engineering Branch
- ◆ **David Heeszal**, Geophysicist, Geoscience and Geotechnical Engineering Branch
- ◆ **Yuken Wong**, Senior Mechanical Engineer, Mechanical Engineering Branch
- ◆ **Renee Li**, Senior Mechanical Engineer, Mechanical Engineering Branch
- ◆ **Tom Scarbrough**, Senior Mechanical Engineer, Mechanical Engineering Branch
- ◆ **Eric Reichelt**, Senior Materials Engineer, Materials and Chemical Branch
- ◆ **Jorge Cintron- Rivera**, Electrical Engineer, Electrical Engineering Branch, NRR

Staff Review Team

- **Technical Staff**

- ◆ **Edward Stutzcage**, Health Physicist, Radiation Protection and Accident Consequences Branch

- **Project Managers**

- ◆ **Bill Ward**, Lead Project Manager
- ◆ **Tomeka Terry**, Chapter Project Manager

APR1400 Seismic Analysis and Design Review Approach

- Conducted pre-application quality assurance audit
- Performed regulatory audit at the applicant facility
- Held bi-weekly public meetings (teleconferences or meetings) to facilitate the resolution of technical issues and to refine RAIs
- Integrated lessons learned from previous DC applications
- Compiled “list of clarification Issues” for minor findings (e.g., inconsistency, verification/justification needed, typo)
- Issued RAIs for significant staff findings (e.g., technical issue, incompleteness)
- Confirmed the methods and techniques used are appropriate
- Ensured consistency with other design certifications

Seismic Parameters & Analysis

SER Section 3.7

Robert Roche-Rivera

Seismic Parameters & Analysis

- Reviewed DCD Section 3.7, Appendices 3.7A and 3.7B, and six referenced technical reports
- Held bi-weekly public meetings with the applicant to discuss technical issues
- Performed independent confirmatory analysis of the acceleration time histories
- Conducted a seismic design audit to verify and investigate the implementation of the seismic design criteria, key calculations, and the safety significance of methods differing from SRP guidance
- Confirmed consistency with guidance in SRP, RGs, and referenced seismic standards
- With the exception of one open item, concluded that the seismic design parameters and seismic analysis procedures and criteria delineated by the applicant provides an acceptable basis for the seismic design

Seismic Design Parameters SER Section 3.7.1 and Seismic Subsystem Analysis SER Section 3.7.3

Jinsuo Nie

Certified Seismic Design Response Spectra (CSDRS)

- Both the CSDRS and the CSDRS at the foundation level in the free field ($CSDRS_{ff}$) are required to bound the minimum required response spectrum (MRRS) anchored to 0.1 g
- The envelope of $CSDRS_{ff}$ for all soil profiles, not the $CSDRS_{ff}$ for each soil profile, was initially used to compare with MRRS
- $CSDRS_{ff}$ for soil profiles S6 and S7 show large dips, which the applicant explained later were due to a soil layer interface close to the bottom of the foundation
- However, transfer functions from the ground surface to the outcrop foundation level did not appear to explain these large dips
- During the audit, the transfer functions were found to be from the outcrop bedrock to the outcrop foundation level
- RAI response and DCD markup were updated accordingly

Development of Target PSD

- Target PSD functions should be properly generated for design response spectra other than RG 1.60 spectral shapes
- APR1400 target PSD function in the horizontal direction below 9 Hz is specified as the same as the one for the RG 1.60 horizontal spectrum
- APR1400 target PSD function in the vertical direction was developed based on one-time scaling of the horizontal target PSD function
- Applicant showed that the PSD functions were in general agreement with those generated based on 30 simulated time histories
- Staff confirmatory analysis showed target PSD functions higher than the applicant's target PSD functions in some frequency ranges
- However, the applicant's minimum target PSD functions are very close to or more conservative than the staff's minimum target PSD functions (Applicant used a factor of 0.8, compared to 0.7 specified in SRP 3.7.1 Appendix B)

Acceleration Time Histories

- Seed records lack high frequency content and the Fourier phase spectra of some seed records are cyclic, constant, or with a gap in some frequency bands
- The design time histories was found to have high frequency content, and their phase spectra do not show the above issues
- Low-pass filters are applied to the design time histories with corner frequencies below 50 Hz, to remove artificial high frequency contents due to baseline correction and clipping
- However, the effect of the low-pass filters were determined to be insignificant
- The method used to estimate PSD functions is not consistent with the SRP guidance
- The updated PSD functions were shown to exceed the minimum target PSD functions

Seismic System Analysis SER

Section 3.7.2

Robert Roche-Rivera

Soil Structure Interaction (SSI) - Sensitivity Studies

- Original seismic system evaluation lacked sensitivity studies
- The applicant evaluated the effects of:
 - ◆ Separation of soil from sidewalls – design basis ISRS for the fixed-base case bound the ISRS for analysis cases considering separation of soil from sidewalls
 - ◆ Sensitivity to Poisson’s Ratio – analysis cases for several values of Poisson’s Ratio confirmed that no numerical instabilities exist in the design basis SSI analysis
 - ◆ Basemat Uplift (revised for consistency with SRP guidance) – ground contact ratios are greater than 80 percent, which meets the SRP Section 3.7.2.II.4 criterion for acceptability of linear SSI analysis

Structure-Soil-Structure Interaction Analysis (SSSI)

- Original SSSI evaluation assumed surface-mounted structures;
 - ◆ did not consider pressure distributions on exterior below grade walls due to SSSI effects
- Applicant performed SSSI analysis based on the embedded foundation configuration
- Lateral soil pressures computed from the SSSI and SSI analyses are higher than the dynamic soil pressure originally used in the design of exterior below grade walls in the AB and DFOT Room
- Applicant reevaluated the structural design of exterior below grade walls to consider the calculated maximum lateral soil pressures from the SSSI and SSI analyses

Concrete Containment SER Section 3.8.1, Containment Internal Structures SER Section 3.8.3, and Other Seismic Category I Structures SER Section 3.8.4

Vaughn Thomas

Structural Design of Category I Structures

- Ensured the applicant's design approach and methodology is reasonable and acceptable
 - ◆ Scope
 - ◆ Level of details
 - ◆ Technical adequacy
- Reviewed DCD Section 3.8 and associated Appendix 3.8A, the listed tables and figures, and the structural design report in accordance with applicable sections of SRP 3.8 acceptance criteria
- Held bi-weekly public meetings with the applicant to discuss technical issues and resolutions for resolving RAIs
- Examined and compared the applicant's results to the applicable code allowable
- Confirmed that the applicant's method for demonstrating the design adequacy of the structures are consistent with the agency's regulatory requirements

Hydrogen Generation Pressure Load

- Reviewed APR1400 DCD Section 3.8.1.3 in accordance with SRP 3.8.1 acceptance criteria
 - ◆ Analyses to demonstrate that the containment structural integrity is maintained when subjected to hydrogen generated pressure loads resulting from fuel cladding and water interaction
 - ◆ Description of the design and analysis procedures not provided
 - ◆ Acceptance criteria not provided
- Applicant performed additional calculation and sensitivity analysis of the 3-D finite element model of the containment structure
- The results demonstrated that the liner strains are below the ASME code allowable limits and the rebar and tendons remain in the elastic range
- The applicant's methodology for demonstrating the structural integrity of the containment subjected to hydrogen pressure load meets the NRC regulatory acceptance criteria
- Provided markup copies that describes the design and analysis approach, and the acceptance criteria for the hydrogen pressure load

Ultimate Pressure Capacity

- Reviewed APR1400 DCD Section 3.8.1.4 in accordance with SRP 3.8.1 acceptance criteria
 - ◆ Design and analysis procedures to determine the UPC of the containment at which structural integrity is retained
 - ◆ The applicant's approach and acceptance criteria, used to calculate the UPC of the containment, does is not appear to be in conformance with the approach described in Regulatory Position 1 of RG 1.216
- The design and analysis procedures for determining the UPC are performed in accordance with RG 1.216
- Applicant performed additional calculation and sensitivity analysis of the 3-D finite element model of the containment structure
- The results demonstrated that the rebar, tendon, and liner strains at the ultimate pressure level are below the strain limits
- Included a COL item (COL 3.8(11)) which requires the COL applicant to provide the detailed design results and evaluation of the penetrations

Leak Chase Channels

- Reviewed APR1400 DCD Section 3.8.3.1 and associated Appendix 3.8A in accordance with SRP 3.8.3 acceptance criteria
 - ◆ Design and analysis procedure for the IRWST of the containment internal structures, including leak chase channels and stainless steel liner plate
 - ◆ The applicant did not provide descriptions or associated design details of the leak chase channels in the IRWST
- The applicant is committed to using a leak chase channel system to monitor potential leakage of water from the IRWST
- The applicant provided mark copies of applicable section of the DCD that includes the description of the leak chase channel collection system that will be used in the design of the IRWST
- Included a COL item (COL 9.3(5)) for monitoring and inspection of the leak chase channel collection system

Dynamic Lateral Earth Pressure

- Reviewed APR1400 DCD Section 3.8.4.4 and associated Appendix 3.8A in accordance with SRP 3.8.4 acceptance criteria
 - ◆ Design and analysis procedure for the below grade walls in seismic Category I structures considering the governing dynamic lateral earth pressures
 - ◆ The applicant did not adequately describe the approach for developing dynamic earth pressure loads that are considered in the analysis and design of embedded walls
- For the AB and DFOT, the dynamic earth pressures determined from the SSI/SSSI FEA analysis results were higher than those calculated in accordance with ASCE 4-98
- The structural analysis of the AB and the DFOT are revised to use the dynamic earth pressure obtained from the SSI/SSSI analysis as the governing dynamic earth pressure
- The increase in the dynamic earth pressure led to revising the member forces of the exterior walls
- The applicant provided markup copies of applicable sections of the DCD that reflect these changes

Foundations

SER Section 3.8.5

Ata Istar

Tendon Gallery

- APR1400 DCD, Section 3.8.5.1, “Description of the Foundations,” and Section 3.8.5.4, “Design and Analysis Procedures”
- SRP 3.8.5, Section I.1.A, description of the arrangement of the gallery and means of either isolating it from the remainder of the base slab or relying on it for some function, such as resisting shears
- SRP 3.8.5, Section II.4.I, description of any unique design features that occur in the load path (e.g., any safety-related function that the tendon gallery may have as part of the function in the prestressed containment)
 - ◆ The applicant did not describe the tendon gallery, and the analysis and design approaches used for the tendon gallery
- The applicant provided the description of tendon gallery, and it was included in the analysis and design as part of the NI common basemat

Waterproofing Membrane

- APR1400 DCD, Section 3.8.5.1, “Description of the Foundations”
- SRP 3.8.5, Section I.1.A, if waterproofing membranes are used, the review addresses their effect on the shear resistance of the foundation
 - ◆ The applicant did not provide any description whether waterproofing membranes are used
- The applicant responded that waterproofing membranes will be used for exterior below grade horizontal and vertical surfaces of structures in APR1400 design
- The COL applicant (COL Item 3.8(13)) is to verify that the COF between the lean concrete and waterproofing membrane is greater than 0.55 used in design
- (Q 3.8.5-14 also addresses the smallest COF value between the various potential sliding interfaces in the evaluation of the NI common basemat)

Construction Sequence & Differential Settlements

- APR1400 DCD, Section 3.8.5.1, “Description of the Foundations,” Section 3.8.5.4, “Design and Analysis Procedures,” Appendix 3.8A, “Structural Design Summary,” and TR APR1400-E-S-NR-14006-P, “Stability Check for NI Common Basemat.”
- SRP 3.8.5, Section I.3. “Load and Load Combinations,” “..loads that are induced by construction sequence and the differential settlements...”
- The applicant did not include the superstructure of the RCB and AB in the construction sequence evaluation, and clearly not determine the settlement types of (1) max. vertical settlement, (2) tilt settlement, (3) differential settlement between buildings, and (4) angular distortion throughout the NI foundation.
- Currently, these issues are being addressed by the applicant.

Seismic Instrumentation

SER Section 3.7.4

David Heeszal

Seismic Instrumentation

- KHNP has adequately described
 - ◆ Location of seismic instrumentation
 - ◆ Requirements for development of implementation plan for a COL applicant
- KHNP referenced appropriate Regulatory Guides for
 - ◆ Determining exceedance of the OBE
 - ◆ COL applicant development of plan for plant inspection and restart following a seismic event

Dynamic Testing and Analysis of SSCs SER Section 3.9.2

Yuken Wong

Dynamic Testing and Analysis of SSCs

- The staff reviewed the methodology, testing procedure, inspection program, and dynamic analyses conducted by KHNP to ensure the structural integrity and functionality of piping systems, mechanical equipment, and their supports under vibratory loading
- Specifically, reviewed six main areas:
 1. piping vibration, thermal expansion, and dynamic effects testing including the initial test program for ASME BPV Code, Section III, Class 1, 2 and 3 piping.
 2. seismic analysis and qualification of seismic Category I components
 3. dynamic system analysis for reactor internals under operational flow transients and steady-state conditions
 4. preoperational flow-induced vibration testing of reactor internals
 5. dynamic system analysis of the reactor internals under faulted conditions
 6. correlations of reactor internals vibration tests with the analytical results

Dynamic Testing and Analysis of SSCs

- Also, reviewed the Comprehensive Vibration Assessment Program (CVAP) report for APR1400 steam generator flow induced vibration and reactor design in comparison with System 80 reactor design such that the Palo Verde Unit I design is prototype reactor and APR1400 is classified as non-prototype Category 1 reactor.
- Staff requested basis for using 33 Hz ZPA – Applicant revised to 50 Hz in DCD
- Staff inquired about tank contents in the analysis – applicant responded hydrodynamic forces exerted by the fluid on the tank walls is in the analysis.
- Staff inquired about the DPVIB computer code benchmarking – Applicant provided acceptable V&V information.

Reactor Pressure Vessel Internals SER Section 3.9.5

Yuken Wong

Reactor Pressure Vessel Internals

- NRC staff evaluated the arrangement of reactor internals, their functions, flow path through the reactor vessel, and design criteria.
- Comparisons were made between the APR1400 reactor design and the CE System 80+ reactor design, i.e. Palo Verde Units 1, 2 and 3, as the reactor designs are similar.
- Public meetings were held with the applicant early in the review stage to discuss issues. Many of these issues were addressed by the applicant early. Remaining or additional issues were raised via RAIs to which the applicant responded.
- Ensured the core support structures are constructed in accordance with ASME B&PV Code, Section III, Subsection NG. Internal structures are constructed in accordance with Subsection NG as guidelines.

Reactor Pressure Vessel Internals

- Open Item: Concern with guide tube structural integrity. KHNP has since provided valid calculation to show the guide tube structural integrity can be maintained at SSE. Concern is resolved. KHNP was also requested to look into operational history from operating plants with System 80+ design. KHNP investigated Young Gwang Unit 2 since July 1995 and found no failure data on any reactor internals or guide tubes. Staff asked KHNP to check Kori and Palo Verde. Status is ongoing.
- Open Item: Static o-ring at seal table for ICI support system. KHNP provided test data to validate o-ring design. Open item is closed.
- Open Item: Service level conditions that result in IRWST discharge. KHNP provided clarification to which events would result in IRWST discharge. Open item is closed.
- Open Item: Seismic category for reactor internals. KHNP provided clarification that all reactor internals (both core support structures and internal structures) are seismic category I. Confirmatory item.

Seismic & Dynamic Qualification of Equipment SER Section 3.10

Yuken Wong

Seismic & Dynamic Qualification of Equipment

- Reviewed DCD Tier 2, Section 3.10, 3.7B.7.4, and technical reports
- Verified equipment seismic qualification standards and methods
- Verified procedures to evaluate of effects of hard rock high frequency (HRHF) response spectra
 - For new equipment, qualification will envelop certified seismic design response spectra (CSDRS) and HRHF response spectra
 - Equipment undergone prior qualification
 - Applicant will verify test results envelop CSDRS and HRHF response spectra
 - Applicant will perform screening tests using required response spectra enveloping HRHF response spectra
- Conducted audit of procurement (design) specifications to verify seismic qualification methodologies

Seismic & Dynamic Qualification of Equipment

- Open item: Design Specification Follow-up Audit items for seismic qualification are acceptable. Applicant will update procurement specifications to address staff audit findings.

ASME Code Class 1, 2, and 3 Piping Systems and Associated Supports Design SER Section 3.12

Yuken Wong

Piping Analysis and Supports

- Confirmed APR1400 piping and supports analysis is in accordance with NRC guidance.
- Conducted audit of piping stress analysis and support designs to confirm consistency with DCD.
- Held public meetings with the applicant to discuss technical issues during audits and RAIs leading to proposed DCD markups, revisions to technical reports and added piping analyses.
- Identified that the environmentally assisted fatigue for the reactor coolant loop piping had not been performed. It has since been completed and is currently under review.
- Questioned the seismic analysis approach used. Calculations were revised and confirmed to be acceptable.

Piping Analysis and Supports

- The non-linear analysis using the time history method has been satisfactorily addressed by the applicant.
- The HRHF response spectrum seismic analysis of piping within the scope of the graded approach had been omitted. It has since been completed and will be included in a revision to technical report APR-E-S-NR-14004-P, which will be reviewed by the NRC staff.
- Requested from the applicant information regarding the structural integrity of piping and pipe supports that could be impacted by vibration and water hammer, which could potentially originate from the operation of the safety injection tank and its fluidic device. The applicant's response is pending.

Determination of Rupture Locations and Dynamic Effects Associated with the Postulated Rupture of Piping SER Section 3.6.2

Renee Li

Determination of Rupture Locations and Dynamic Effects Associated with the Postulated Rupture of Piping

Review Approach

- Reviewed the applicant's criteria used to define the pipe break/leakage crack locations and configurations.
- Reviewed the outlines of the information which will be included in the pipe break hazards analysis (PRHA) summary report and requested the applicant submit a PRHA summary report.
- Reviewed the applicant's methodology for addressing the potential non-conservatism of ANS 58.2 dynamic jet modeling described in a technical report.

Staff Findings

- With the exception of break exclusion area, the applicant's criteria to define the pipe break/leakage crack locations and configurations are found acceptable.
- PRHA report outlines are found acceptable. The results of the PRHA summary report will be submitted in the future and remains open.

Determination of Rupture Locations and Dynamic Effects Associated with the Postulated Rupture of Piping

- Technical Report (TR) methodologies in addressing jet plume expansion and distribution of the pressure within the jet plume are found acceptable. Evaluation of blast wave and potential feedback amplification and resonance effects remains open.

Open Items Status

- Break Exclusion Area and PRHA Summary Report

The design provisions to be employed in the break exclusion area are consistent with staff's guidance. However, the break exclusion areas are beyond the containment penetration area. The staff will review the applicant's justification with the results of pipe rupture analysis to be provided in the PRHA summary report.

- Blast Wave and Potential Feedback Amplification and Resonance Effects

The staff requested the applicant to clarify the CFD modeling for blast wave effects including V&V of computer code and the feedback amplification and resonance effects as presented in the current TR. Subsequently, the applicant indicated that the resulting dynamic load was too conservative in the current TR and, therefore, it will submit a TR revision with alternative approaches to address these issues.

Leak Before Break Evaluation Procedures SER Section 3.6.3

Eric Reichelt

Leak Before Break

- Reviewed applicable APR1400 DCD sections in 3.6.3
- Reviewed DCD references for applicability and use
- Held public meetings with KHNP/KEPCO staff about technical issues and RAIs leading to proposed DCD markups
- The staff found these DCD sections mostly acceptable
- Most of the technical issues and response to RAIs by KHNP were acceptable and were therefore closed.
- One RAI remains as an open item.

Leak Before Break

- The staff questioned the PICEP input file for the surge line fluid temperature against what is provided in the DCD. In addition, the PICEP source code was requested if available.
- This RAI remains as an open item.
- Confirmatory analysis will continue upon receiving a response to the open item.

Special Topics for Mechanical Components SER Section 3.9.1

Tom Scarbrough

Special Topics for Mechanical Components

- Design Transients: The APR1400 transient occurrences are conservatively designed, based on the certified System 80+ design transients.
- Computer Programs Used in Analyses: The NRC staff audited verification and validation (V&V) documents of the computer programs used in analyses.
DPVIB computer program is used to calculate fluctuating pressure distribution in the down-comer region caused by RCP pressure pulsation. The staff found the output of the DPVIB is in agreement with the test data. The description of DPVIB computer program is added into DCD Tier 2.
- Evaluated the Faulted Conditions: The evaluation of Faulted Conditions is in conformance with ASME BPV Code, Section III, Appendix F.

ASME Code Class 1, 2, and 3 Components, Component Supports, and Core Support Structures SER Section 3.9.3

Tom Scarbrough

ASME Code Class 1, 2, and 3 Components, Component Supports, and Core Support Structures

- Load combinations for ASME Code Class 1, 2 and 3 components and component supports conform to ASME BPV Code, Section III.
- Dynamic system and dynamic fluid loadings, respectively DF and DFL, explicitly are defined, and they conform to ASME BPV Code, Section III.
- Component supports are designed in accordance with ASME BPV Code, Section III, Subsection NF.

ASME Code Class 1, 2, and 3 Components, Component Supports, and Core Support Structures

- Audit conducted of component design specifications in accordance with 10 CFR 52.47 to establish that design criteria, analytical methods, and functional capability satisfy ASME Code requirements, and to confirm that design information from DCD is properly translated into design specifications
- As result of audit, design specifications and DCD being updated.
- RAI proposed to track design specification and DCD changes.
- Open item to be closed when RAI resolved.

Functional Design, Qualification, and IST Program SER Section 3.9.6

Tom Scarbrough

Functional Design, Qualification, and IST Program

- NRC staff evaluated APR1400 DCD Tier 2, Section 3.9.6, “Functional Design, Qualification, and Inservice Testing (IST) Programs for Pumps, Valves, and Dynamic Restraints,” using SRP Section 3.9.6
- DCD provision for functional qualification of pumps, valves, and snubbers specifying ASME Standard QME-1-2007 as endorsed by Regulatory Guide 1.100 (Revision 3) is acceptable.
- NRC staff conducted audit of design specifications of APR1400 components in accordance with 10 CFR 52.47
- DCD description of IST Program based on ASME OM Code (2004 Edition through 2006 Addenda) as incorporated in 10 CFR 50.55a is acceptable for reference in COL application.
- DCD Revision 1 will be reviewed to close Confirmatory Items.

Functional Design, Qualification, and IST Program

- Open Item: Design Specification Follow-up Audit items for functional design and qualification are acceptable. Follow-up Audit Report being prepared.
- Open Item: Proposed IST table revision in August 29, 2016, submittal is acceptable and will be confirmed by review of DCD Revision 1.
- Open Item: KHNP preparing responses to RAIs on pump and valve ITAAC.

Environmental Qualification of Mechanical and Electrical Equipment SER Section 3.11

Jorge A Cintron

Environmental Qualification of Mechanical and Electrical Equipment

- Section 3.11 provides the APR1400 approach for environmental qualification of mechanical and electrical equipment.
- Staff reviewed the environmental qualification of mechanical and electrical equipment to verify the equipment is capable of performing its design functions under all normal environmental conditions, anticipated operational occurrences, and accident and post-accident environmental conditions. This equipment includes:
 - Safety-related equipment
 - Non-safety-related equipment whose failure under postulated environmental conditions could prevent satisfactory accomplishment of specified safety functions
 - Certain post-accident monitoring equipment

Environmental Qualification of Mechanical and Electrical Equipment

Open Item

- Conformance with **Regulatory Guide (RG) 1.89**: provides the acceptable method for environmental qualification. Endorses IEEE 323-1974, “IEEE Standard for Qualifying Class IE Equipment for Nuclear Power Generating Stations.”
- The APR1400 deviates from RG 1.89 by using IEEE 323-2003, “IEEE Standard for Qualifying Class 1E Equipment for Nuclear Power Generating Stations,” for environmental qualification of mechanical and electrical equipment.
- Staff recognize the use of standards not endorsed by the regulatory guides if it is appropriately justified.
- The staff issued an RAI requesting justification why IEEE Std. 323-2003 is acceptable for qualification of Class 1E electrical equipment in the harsh environment

Environmental Qualification of Mechanical and Electrical Equipment

Open Item (Cont.)

- In response to the RAI, the applicant determined to use IEEE 323-2003 for environmental qualification stating that there are not technical differences, and it reflects current practices for environmental qualifications.
- The staff identified technical differences in the content of IEEE 323-2003 and issued a follow-up RAI requesting the applicant to provide justification of the technical difference between IEEE 323-1974 and IEEE 323-2003.
- Staff is currently evaluating the applicant revised response to the above RAI, which is an Open Item for Section 3.11

Radiological Equipment Qualification Review SER Section 3.11

Ed Stutzcage

Equipment Qualification (Radiological)

- Staff reviewed the applicant's methodology and results for calculating the total integrated dose (TID) to equipment within the EQ program.
- Normal operation doses for equipment are based on the highest dose within a room, using a similar methodology to that used to determine the Chapter 12 radiation zone maps, except based on an assumed 1% failed fuel percentage (instead of 0.25% assumed in Chapter 12), and a few other differences.
- Accident doses are based on the most limiting design basis accident for each area of the plant (for most areas the design basis LOCA is limiting).
- TIDs are the sum of the 60 year normal operation dose, plus the limiting accident doses.

Results and Conclusions (Equipment Qualification Radiological)

- For most areas of the plant, staff finds the applicant's normal operation dose values for equipment qualification to be acceptable.
- Outstanding issues include:
 - ♦ Inconsistencies with Chapter 12 information regarding normal operation neutron dose on the refueling floor.
 - ♦ Doses within the Auxiliary Building during accidents do not appear to adequately consider radiation streaming through containment penetrations.
 - ♦ Requested the applicant to provide additional information regarding how some of the post-accident gamma dose rate information was determined.
 - ♦ Unjustified assumptions for post-accident fluid leakage rate outside of containment.

ACRONYMS

- **3-D** – three dimensional
- **AB** – auxiliary building
- **CIS** – containment Internal structures
- **COF** – coefficient of friction
- **COL** – combined license application
- **CSDRS**- certified seismic design response spectra
- **DFOT** – diesel fuel oil tank
- **EDGB** – emergency diesel generator building
- **FEA** – finite element analysis
- **HRHF** – hard rock high frequency
- **IRWST** – in-containment refueling water storage tank
- **ISRS** – in structure response spectra
- **NI** – nuclear island
- **PSD** – power spectral density
- **RAI** – request for additional information
- **RG** – regulatory guide
- **RCB** – reactor containment building
- **SRP** – standard review plan
- **SSI** – soil-structure interaction
- **SSSI** – structure-soil-structure interaction
- **SSW** – secondary Shield Wall
- **UPC** – ultimate pressure capacity