



50-335

Project: TFPF

Channel: PCCF-ANP-ZNRC-00001

Date: 2017-06-30
Sender: LECOUR Hugues
eMail: hugues.lecour@areva.com
Tel: +33 1 34 96 74 51
Mobile: +33 6 30 49 02 85

Receiver:

**Document Control Desk
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, MD 20852
USA**

Reply Requested:	N	Work Package:	
Reply Due Date:			
Reply to Channel:			

Subject: Closure of Interim Report of an Evaluation of a Deviation Pursuant to 10 CFR 21.21(a)(2)

Ref. 1: Letter, Mr. Gary Peters (AREVA Inc.) to Document Control Desk (NRC), "Interim Report of an Evaluation of a Deviation Pursuant to 10 CFR 21.21(a)(2)," NRC:16:033, December 7, 2016.

Dear Sir or Madam,

On behalf of AREVA NP SAS, AREVA Inc. (AREVA) issued an Interim Report to the NRC on December 7, 2016 concerning the identification of an issue related to fabrication record anomalies at Creusot Forge (Reference 1), for the Sainte Lucie 1 pressurizer. This interim report set forth a completion date for the evaluation of June 30, 2017.

The evaluation is now complete. AREVA NP has concluded that the fabrication record anomalies identified through the evaluation of the Sainte Lucie 1 forgings manufacturing files would not create a substantial safety hazard and are therefore not reportable in accordance with 10 CFR Part 21.

Best regards,

AREVA NP
Pierre COLIN – Creusot Forge Conformance Project Manager

Copies: Mike Street, David Emond, Gary Peters
Attachments: N/A

IE19
NRR

AREVA NP
Head quarter : Tour AREVA 1, place Jean Millier – 92084 Paris La Défense cedex – France
Phone : 33 (0)1 34 96 00 00 – fax : 33 (0)1 34 96 00 01