



WECTEC LLC  
3735 Glen Lake Drive  
Charlotte, NC 28208  
Tel: +1 980 859 8000

10 CFR 21.21

June 19, 2017

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555-0001

**SUBJECT: INTERIM 10 CFR PART 21 REPORT REGARDING A REACTOR COOLANT  
SYSTEM PIPE SPOOL FOR V. C. SUMMER UNIT 3 AP1000® PROJECT**

This letter provides an interim report in accordance with 10 CFR 21.21 pertaining to one reactor coolant system pipe spool that is being supplied for V. C. Summer Unit 3 AP1000® project. Based on information contained in a nonconformance & disposition (N&D) report, a weld on a weldolet fitting was found with lack of fusion on the root of the weld.

Evaluation for reportability in accordance with 10 CFR Part 21 is not able to be completed within the 60-day evaluation period. It is currently expected that the evaluation of this condition will be completed by August 17, 2017.

If you have any questions pertaining to this information, please contact Curtis Castell, Licensing Manager, at 980-859-6373.

Sincerely,

A handwritten signature in black ink, appearing to read "Deborah A. Gustafson". The signature is written in a cursive style.

Deborah A. Gustafson  
Vice President Project Services  
WECTEC LLC

cc: Regional Administrator, USNRC, Region II