

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 Northwest Medical Isotopes Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, September 21, 2017

Work Order No.: NRC-3288

Pages 1-150

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

NORTHWEST MEDICAL ISOTOPES SUBCOMMITTEE

+ + + + +

THURSDAY

SEPTEMBER 21, 2017

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 8:30 a.m., Margaret Chu,
Chairman, presiding.

COMMITTEE MEMBERS:

MARGARET CHU, Chair

RONALD G. BALLINGER, Member

DENNIS C. BLEY, Member

CHARLES H. BROWN, JR., Member

MICHAEL CORRADINI, Member

WALTER L. KIRCHNER, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

JOSE MARCH-LEUBA, Member

DANA A. POWERS, Member

JOY REMPE, Member

GORDON R. SKILLMAN, Member

JOHN W. STETKAR, Member

MATTHEW W. SUNSERI, Member

DESIGNATED FEDERAL OFFICIAL:

KATHY WEAVER

ALSO PRESENT:

JOHN ATCHISON, ISL*

MICHAEL BALAZIK, NRR

GREGORY BOWMAN, NRR

MICHAEL CORUM, NWMI

GARY DUNFORD, NWMI

CAROLYN HAASS, NWMI

STEVE LYNCH, NRR

JAMES MASTERLARK, NWMI*

SAM SWAN, NWMI*

DAVID TIKTINSKY, NMSS

ANDREA VEIL, Executive Director, ACRS

*Present via telephone

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

AGENDA

Page

Opening Remarks

Margaret Chu.....4

Opening Remarks and Introductions

NRC Staff.....6

NWMI Discussion on Revisions/Changes to the
Construction Permit Application Preliminary Safety
Analysis Report (PSAR).....7

NRC Staff Discussion on Revisions/Changes to PSAR and
Draft SER.....64

Opportunity for Public Comment.....96

Adjourn.....97

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

(8:30 a.m.)

CHAIR CHU: Good morning. Good morning, this meeting will now come to order. This is a meeting of the Advisory Committee on Reactor Safeguards, Northwest Medical Isotopes, NWMI Subcommittee.

I'm Margaret Chu, Chairman of the Subcommittee. Members in attendance today are Ron Ballinger, Matt Sunseri, Gordon Skillman, Dana Powers, Dennis Bley, John Stetkar, Jose March-Leuba, Walt Kirchner, Charles Brown and Joy Rempe.

The purpose of today's meeting is for the Subcommittee to hear briefings from representatives of Northwest Medical Isotopes regarding their construction permit application for a radioisotope production facility in the City of Columbia, Missouri for producing Molybdenum-99. We also expect to hear from the NRC Staff regarding their review of this application.

This Subcommittee meeting will focus on revisions or changes made to the PSAR and the SER chapters, as noted in the agenda.

This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act. Rules of conduct of and participation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in the meeting have been published in the Federal
2 Register, as part of the notice for this meeting.

3 Kathy Weaver is the designated federal
4 official for this meeting.

5 Portions of this meeting may be closed to
6 the public to protect the information proprietary to
7 NWMI or its renderers, as shown on the agenda.

8 A transcript of the meeting is being kept,
9 therefore it is requested that all speakers first
10 identify them self, then speak with sufficient clarity
11 and volume so they can be readily heard.

12 During the open portion of the meeting,
13 a public bridge line will be open on mute so that those
14 individuals may listen in. At the appropriate time,
15 later in the meeting, we'll have an opportunity for
16 public comment from the bridge line and from members
17 of the public in attendance.

18 During the closed portion of the meeting
19 the public bridge line will be closed. However, at
20 the request NRC Staff, we'll have a phone line open
21 for some of their NRC contractors who contributed to
22 the NRC Staff review. During this period, please keep
23 this phone line on mute so as not to disrupt our meeting.

24 We'll now proceed with the meeting, and
25 then I'll call upon Steve Lynch, Acting Branch Chief,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Research and Test Reactor Licensing Branch, in the
2 Office of Nuclear Reactor Regulation, to open the
3 presentation today.

4 MR. LYNCH: Great, thank you. So, this
5 is our fourth ACRS Subcommittee meeting on the Northwest
6 Medical Isotopes construction permit application,
7 having met with the members each month this summer.
8 We appreciate your time and the priority you have given
9 to this important and somewhat novel project.

10 Your insights on the safe operation and
11 design of nuclear facilities and the use of nuclear
12 material has benefitted the Staffs review and better
13 informed our finding supporting the issuance of a
14 construction permit to Northwest Medical Isotopes.

15 As a result of our meetings with the
16 members, the NRC Staff has updated areas such as seismic
17 and accident analyses in our SER.

18 This morning we will provide the members
19 with a complete look at the enhancements modifications
20 and refinements of the Staff safety evaluation report.

21 We thank you again for your time and we look forward
22 to your continued feedback as we prepare for the
23 November full committee meeting.

24 CHAIR CHU: Go ahead.

25 MS. HAASS: Hi. I'm Carolyn Haass, I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the chief operating officer of Northwest Medical
2 Isotopes, and today I have with me Mike Corum, who is
3 our engineering lead, and Steve Reese, who is our
4 radiation lead for Northwest.

5 We're here for this morning to talk about
6 a summary of what we've done in the last three previous
7 meetings and to go through the revision and changes
8 we did to our construction permit application.

9 I'm not quite sure, today is a little
10 different, I know, then we had before and I didn't know
11 if there was some type, if there is any specific thing
12 or procedural thing you want us to follow or you just
13 want us to go through the presentation? I'm not quite
14 sure.

15 CHAIR CHU: I would suggest you go through
16 the presentation. If people have some specific things
17 they want to raise then please go ahead.

18 MS. HAASS: All right. So, this is setup
19 where I've identified here the major changes we did
20 to the construction permit application.

21 And Chapter 1, obviously there were changes
22 to, but that's based on the other changes that were
23 done on the other chapters. And most of the changes
24 in Chapter 1 had to do, when we summarized a nearby
25 facilities and any accidents associated with that and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some other minor changes. And so as I said, I'm only
2 going to go through the major changes.

3 And the first is Chapter 2. Mr. Stetkar,
4 I know that you had several comments when we went through
5 it in the first meeting.

6 On Page 2, on transient population, we did
7 update that. We have gone through, and unfortunately,
8 the university didn't have a good idea on how they
9 planned, on what the transient population growth was
10 going to be, so we did work with them verbally. And
11 so we did add that to that. And so we just wanted you
12 to know that that has been added.

13 Also since this was written, back in 2014,
14 we did do some updates.

15 MEMBER STETKAR: And that's, I wasn't
16 looking for precision, I was looking more for general
17 philosophy. The general philosophy is now there.

18 MS. HAASS: Correct. And so we appreciate
19 that. Just wanted you to know we had done that.

20 MEMBER SKILLMAN: Carolyn, let me ask you
21 please to go back to Chapter 1, even though you don't
22 have the slide.

23 MS. HAASS: Yes.

24 MEMBER SKILLMAN: As we were asked to
25 prepare for this meeting, we were asked to round up

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 our comments and be prepared to present those if we
2 wished.

3 And my comment is on your, actually, it's
4 in Revision 3, Page 1-26. And the Paragraph is 1.3.2.1.

5 And there on your application you express,
6 design will provide for adequate protection against
7 natural phenomena, with consideration of the, and
8 here's the highlighted area, the most severe documented
9 historical events for the site.

10 And here's my question, does that mean you
11 look back two millenniums and found a rainfall that's
12 greater than the standards that you were using or does
13 this simply mean, you took a look at convenient data
14 and that there just happen to be an incident that caught
15 your attention, you might give consideration to that,
16 but generally you're going to use all the codes and
17 standards that you've listed, in the application?

18 It seems to me it's really the latter.
19 But the way that text is worded it suggests that you
20 have been able to pluck out of an almost comprehensible
21 amount of data in fire, flood, earthquake, ground
22 motion, water, precipitation, ice, straight wind,
23 tornado. And you've chosen, among those, the worst
24 and included those. I don't think that that's what
25 you meant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. HAASS: You are correct on that. And

2 --

3 MEMBER SKILLMAN: Okay, I'll just leave
4 it there.

5 MS. HAASS: Okay.

6 MEMBER SKILLMAN: Thank you.

7 MS. HAASS: Thank you.

8 MEMBER SKILLMAN: Oh, one more.

9 MS. HAASS: Oh.

10 MEMBER SKILLMAN: Chapter 1. Boone
11 County sinkholes.

12 MS. HAASS: Yes.

13 MEMBER SKILLMAN: And I heard you say in
14 our last meeting, and we discussed this you'll be
15 vigilant in your borings to ensure that you don't site
16 this facility on top of one or several. I don't know
17 where that's written down, but it seems that that ought
18 to be something that you've codified somewhere.

19 I live in an area that is sinkhole prone.

20 We have major road closures right now because of these,
21 in Central Pennsylvania. So, I'm familiar with the
22 consequence.

23 MR. REESE: So, later in the geotechnical
24 slide we'll address that specifically actually.

25 MEMBER SKILLMAN: Thank you. Okay. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I draw that from Chapter 1 general, is why I raised
2 it here instead of later on. Thank you.

3 MS. HAASS: So Slide Number 3. So, the
4 modification we did on this slide, Mr. Stetkar, had
5 to do with Pipeline Number 1. Wasn't a line that wasn't
6 there previously, and it's about .4 miles away.

7 Pipeline Number 2 for Ameren was inactive
8 at the time and has now become active. And then there
9 was an additional line that's been put in, which is
10 the Magellan liquid hazardous waste pipeline. So, we
11 have done that, I wanted you to know.

12 Also, there was a bit of a misunderstanding
13 on the heliports.

14 MEMBER STETKAR: And I got that. This is,
15 as best as I can tell, accurate. There's a couple of
16 inaccuracies still in the text, both in Chapter 3 and
17 Chapter 1, where it still talks about three.

18 And for the Staff's benefit, the Staff
19 still believes there's three of them. That's fine.
20 I don't care about text and editing, I care about the
21 technical stuff.

22 MS. HAASS: Right. Correct.

23 MEMBER STETKAR: And the technical stuff
24 actually counts up the number of flights from each --

25 MS. HAASS: That's correct. And so when

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we go to the --

2 MEMBER STETKAR: Yes.

3 MS. HAASS: -- next slide on airports, I'm
4 going to have it over to Mike in a minute, but what,
5 to go get the proper flights per year, we went directly
6 to the airport and to the airport manager. We have
7 documented that through our references and through the
8 emails. So we do feel comfortable.

9 We got 2014, '15 and '16 on that. And what
10 you're seeing is the data for 2016, John. And also,
11 the percentages on types of operation came directly
12 from the airport manager as well.

13 So, I'll let you go, Mike.

14 MR. CORUM: Mike Corum with NWMI, I'm doing
15 this section of Chapter 2. And I think Carolyn kind
16 of summarized Slide 4 pretty well already.

17 The nearest airport to the RPF is the
18 Columbia Regional Airport, that's the one that has the
19 impact that we'll talk about on the next slide. Again,
20 the data is presented here that was obtained directly
21 from the airport administration.

22 And then can we have the Slide 5? So, we
23 do have two heliports. And I know in some of the text,
24 particularly in Chapter 2 on Page 52, where we're doing
25 the calculation for impact frequency, we still have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the three helipads and estimated at 1,825 flights per
2 year.

3 So that is an inconsistency with what we
4 have on the slide and the data that we've obtained.

5 The result is the same. We're going to
6 go back in the operating license application, as part
7 of the ISA external event analysis and look at the
8 general aviation crash.

9 So, next slide.

10 MEMBER STETKAR: Okay. I don't know where
11 to start on this. Let me just say I'm really
12 disappointed. The aircraft crash analysis in Rev 3
13 is wrong.

14 And let me point out, I use that term
15 because I don't know what other term to use. I can't
16 say it's conservative, I can't say it's optimistic,
17 it's wrong.

18 So, let me point out the things that I
19 found, just for your reference. First of all, your
20 Table, 2-16, which summarizes the results, I obviously
21 did not have a copy of your contractor's report, which
22 has details, I'm assuming in there, but all I had was
23 your summary of results.

24 I'll take, and thanks for going to the
25 airport and getting the actual number of takeoffs and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the distribution by aircraft type, that really helped
2 me a lot.

3 If you look at the number of flight
4 operations per year in Table 2-16, which were actually
5 used for your calculation, they don't add up to your
6 total of 21,894, they add up to 42,834. If you look
7 at all of the takeoffs and landings on all of the runways
8 that were used in the calculation.

9 And I thought, well, that's a strange
10 number. Is it twice, for example, because they double
11 counted?

12 Well, it's not quite twice. So I'm not
13 sure how, whoever did the analysis, came up with a number
14 of takeoffs and landings on each of the runways.

15 They are over counted by roughly a factor
16 of two. Which, in the sense of wrong in the high
17 direction, I will not use the term conservative, I will
18 use the term wrong in the high direction, it is wrong
19 in the high direction from that perspective.

20 Okay, so let's see, I got the number of
21 flight operations. The flight operation, according
22 to FAA by the way, is either a takeoff or a landing,
23 so it's not a flight. A flight is, involves both a
24 takeoff and a landing.

25 But as I said, it isn't precisely twice

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 so it wasn't just a double counting of, I don't know
2 what they did.

3 Also, there's a curiosity that on Runway
4 1331 air taxis seem to takeoff twice as often as they
5 land, which means that there's a net flux of air taxis
6 out. You must have a manufacturing facility there
7 somewhere.

8 It's just, make the numbers add up for
9 crying out loud.

10 Now, in the analysis it says the crash rates
11 for type of aircraft category were obtained from DOE
12 Standard 3014-2006, Table B-1. And indeed, they're
13 not.

14 I don't know where the crash, I'll give
15 you one example. The general aviation, which is the
16 biggest contributor in that table, the takeoff and
17 landing crash rate in the table is 2e to the minus 4,
18 the general, in our table, is 2e to the minus 4.

19 In Table B-1, from the cited reference,
20 there are four different types of general aviation
21 aircraft cited. The highest frequency of crash, per
22 takeoff, is 1.1e to the minus 5, roughly a factor of
23 18 lower. And per landing it's 2e to the minus, or
24 a factor of 10 lower.

25 So I don't know where -- and in the table

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in the cited DOE reference, there are different
2 frequencies for crashes on takeoff and landing. Your
3 table uses the same frequency for each type of aircraft.

4 So it's clear that you didn't take the crash
5 frequencies from the reference that you said you took
6 them from.

7 So, let's see, that's Number 7. I just
8 need to keep track of my whining here.

9 I checked the -- what kind of Military
10 aircraft use that airport? It's got a reasonable
11 amount of Military operations and I couldn't find any
12 information.

13 The reason that I ask is the methodology
14 and data distinguished between crashes of large
15 Military aircraft and small Military aircraft. Large
16 Military aircraft, this is a tradeoff because large
17 Military aircraft have lower crash rates, but they have
18 a large impact area, if you will.

19 And smaller Military aircraft have higher
20 crash rates but they have a smaller impact area. And
21 you know, so I did the analysis assuming all large and
22 all small, and it comes out about the same because I
23 had an exposure area for your facility for small
24 Military aircraft crashes. It's just about a tradeoff.

25 So, it really doesn't affect the overall

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 numbers, from at least the airport operations. But
2 I just found it curious that you used the smaller of
3 the two crash frequencies. You did use the larger of
4 the impact areas.

5 The summary of results that you have here
6 on the slide shows a 3.27e to the minus 11 frequencies
7 of crashes from air taxis. That is not even correct
8 based on your table because you missed a line item entry
9 in your table that's on the order of 10 to the minus
10 10. Not that it affects the overall results, but I
11 can add up numbers on a spreadsheet.

12 What I'm trying to build here is a symptom,
13 symptoms of a rather sloppy analysis. And I use that
14 term intentionally. And I don't know who reviewed the
15 analysis and I don't care.

16 The models that you used, I know what models
17 you used and I don't want to quibble over models, that's
18 a different issue because you did follow the models.

19 Accept for what I call bookkeeping stuff. The models
20 in the guidance in that DOE standard.

21 I'll just note for the record that I have
22 no confidence in that DOE standard for aircraft crashes,
23 from what's typically known as cruise operations in
24 airways. That standard has a model that says, every
25 square foot of the continuous 48 States in the United

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 States has an equal likelihood of getting whacked by
2 an airplane falling out of the sky.

3 The frequency is different depending on
4 the type of aircraft, so they do distinguish between
5 the types of aircraft, but it has no model for proximity
6 to airways, air traffic within an airway. And there
7 are other methodologies that do indeed account for that.

8 You do need, for those other methodologies,
9 to know the number of types of aircraft that are using
10 the airways and the proximity of the airways to your
11 particular facility.

12 As I said, I'll just note that for the
13 record because the crash rates in your analysis, for
14 aircraft falling out of the sky, I use that, this
15 terminology for cruise operations, were done
16 consistently with the guidance using frequencies and
17 that methodology. I just have a real problem believing
18 that somebody out in the middle of the Mojave Desert
19 has the same likelihood of getting whacked as somebody
20 who lives in New Jersey. It's just curious.

21 It was okay. I think the DOE standard and
22 the methodology was developed primarily to evaluate
23 Yucca Mountain.

24 Now, Yucca Mountain has a problem that it's
25 fairly close to some Military facilities and some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Military training areas. So, they focused a lot on
2 Military stuff. And it's probably the best of data
3 and models for Military type crashes.

4 It's probably conservative to say that an
5 averaged geometrical, a geometrically averaged crash
6 frequency for the entire United States might be
7 conservative for Yucca Mountain, maybe not so
8 conversation, for example, for New Jersey.

9 And I use New Jersey, I don't want to, I
10 have no idea what it would be for your facility, because
11 I don't know the air traffic in your airways. It can
12 be found.

13 It's difficult to do. The FAA doesn't,
14 FAA has the information. They don't give it out readily
15 for various reasons.

16 The last item that I want to mention is
17 that your preceding slide, the last little sub-bullet
18 here, I discovered that you have an air show at the
19 Columbia Airport every year, which I didn't go search
20 for before. And so I got interested in it because I
21 like air shows.

22 And indeed, if I looked at the program for
23 this year's air show it's held on Memorial Day Weekend.

24 I looked at the general types of aircrafts, so it looks
25 like a pretty interesting air show.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 They had the Canadian Forces Snowbirds come
2 in and give a fly through, and you have jet aerobatic
3 aircraft, you got an Osprey demonstration, F/A-18's
4 and the traditional historical Military aircraft.

5 You noted that the number of flight
6 operations from the airport, from the air show, were
7 added into, were included in your total. It strikes
8 me the crash rates during air shows are a little
9 different than crash rates during routine aircraft
10 operations.

11 So, you may want to take a re-look at the
12 air show effects. You're quite a ways away from the
13 airport for most crashes that happen during air shows.

14 They tend to be in pretty close proximity to the
15 runways.

16 I lived in Southern California for several
17 years, about five miles away from what was the El Toro
18 Marine Corps Air Station, and they had a huge air show
19 every year. And I like where I live because the Blue
20 Angels used to fly at the Marine Corps air shows.

21 And the Blue Angels used to stage over my
22 house. When they did their spectacular swoops in down
23 over the runways, they used to come out past where I
24 lived, and I they came screaming over my house. And
25 I was about five miles away.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So it was pretty exciting for me because
2 I didn't have to, I could see the Blue Angels up close
3 and person, get my windows rattled by them.

4 The point is that if the area around
5 Discovery Ridge is used for staging of any of the air
6 shows flybys and acrobatics, that can substantially
7 affect the crash frequencies, given the types of
8 aircraft and what they're doing. I have no idea. It
9 kind of aligns with one of the runways, but I have no
10 idea which way they do their staging.

11 So anyway, if I was going to redo the
12 analysis, and I think you should, for the FSAR, I would
13 pay some attention to the air show.

14 Now, this is a subcommittee meeting and
15 this is my own personal opinion, I did re-did the
16 aircraft crash analyses, focusing primarily on the
17 airport operations, because I didn't have flight
18 densities in your local airways there for the cruise
19 operations.

20 I looked at, I used the crash frequencies
21 from the DOE standard. I, as I said, I did a comparison
22 between large Military and small Military because I
23 didn't have the distinction.

24 And as far as everything that I can tweak,
25 the frequencies are small enough to justify, in my mind,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the construction permit. And find frequencies that
2 suddenly jumped up.

3 The contributions are distributed
4 differently than your contributions. So for example,
5 there's, in some of the analyses that I did, there's
6 much larger contribution, relatively larger
7 contribution, for Military aircraft branches than
8 general aviation.

9 So you're focusing, in the PSAR, you say,
10 well, you're going to go reexamine general aviation
11 aircraft crashes. And maybe helicopters, but they're
12 like a factor of three or four high, just by the
13 counting.

14 It's not clear to me that general aviation
15 is, it's probably the biggest, it's not clear that it's
16 greater than 1e to the minus 6e, or it might be.

17 I'd also caution you, when you reexamine
18 general aviation, if you do a more detailed analysis,
19 that general aviation isn't your grandfather's single
20 piston engine Piper Cub, it includes pre-doggone
21 high-performance business jets, and things like that,
22 which have a heck of a lot more energy and impact
23 capability. So, don't just say general aviation is
24 somebody's little plane.

25 That's all I can say on the aircraft

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 crashes. As I said, it was -- I don't know if you have
2 anything else to say. I was disappointed.

3 MS. HAASS: All I can say is wow. We will
4 go back and reexamine that. One of the things we had
5 thought about is going away from the DOE standard, as
6 you had suggested.

7 I will be honest, I don't know what type
8 of military goes in and out of there off the top of
9 my head.

10 MEMBER STETKAR: Yes.

11 MS. HAASS: And, you know, I can go get
12 more information on that.

13 MEMBER STETKAR: For general discussion,
14 and, again, it's not ACRS's purview to kind of recommend
15 what methods or data you should use. That's not what
16 we do.

17 I can give you kind of my experience, it's
18 really difficult to get military crash data and I think
19 that the DOE for Yucca has -- I don't know whether it's
20 real because I can't independently confirm their crash
21 rates, or their models, especially for crashes in the
22 vicinity of an airfield.

23 So I pretty much have to take that at face
24 value because I know that they looked at it quite a
25 bit for Yucca for military. Commercial stuff is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 different.

2 The NTSB, you can find good, contemporary
3 crash frequencies for each phase of operations, and,
4 you know, taxi, takeoff, climb, cruise, initial decent,
5 final decent, landing, by general type of carrier.

6 So you can get air taxis, you can get cargo,
7 you can get large commercial, you can get -- Generally
8 aviation is a little more difficult, you have to search
9 around.

10 There are models that, different models
11 for how you can distribute the crashes as a function
12 of, I call it crash exposure area, you know, how you
13 develop that, those are different geometrical models.

14 For in-flight operations there is a
15 different method that is recommended in some of the
16 NRC guidance that, again, I personally have a problem
17 with how they calculate the exposure area, but it
18 basically says take a flux of a certain type of aircraft
19 in an airway, the crash rate for that aircraft in terms
20 of crashes per aircraft type flight mile, which is
21 something you can get from NTSB, and then spread the
22 crashes out in some exposure area.

23 And that, regardless of how you calculate
24 the exposure area, is somewhat more appealing, at least
25 to me, because it says if your facility is located in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the reasonable proximity to high traffic airways you'll
2 have a higher crash frequency compared to more distant
3 from lower traffic airways.

4 The key there is though you have to get
5 the air traffic flow, the air traffic densities from
6 FAA, and as a private citizen I have had problems doing
7 that in the past.

8 I have worked with folks who are
9 governmental agencies who have been able to get it from
10 FAA. They don't publish that information in any public
11 places that I can find. And that's all I'll say.

12 CHAIR CHU: Let's keep going, okay,
13 thanks.

14 MEMBER STETKAR: Don't try to fix it up
15 before the -- Don't try to fix it up in REV-4. Please
16 don't.

17 MS. HAAS: Go ahead.

18 MR. CORUM: Okay. So Mike Corum moving
19 on now with the pipelines. There are three natural
20 gas transmission pipelines within five miles of the
21 RPF and basically we've done an analysis assuming a
22 complete break with the constant source available to
23 the break and using the ALOHA model and due to the
24 concentration of the gases below the LEL we concluded
25 that a delayed flammable vapor cloud ignition cannot

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 occur and there won't be any explosive over pressure.

2 Next slide. Okay, releases from trucks
3 on US 63 were analyzed and we used an accident frequency
4 of 2 times 10 to the minus 6 accidents per truck mile
5 where 20 percent of the accidents resulted in a spill
6 and then 20 percent of those spills were greater than,
7 I believe, 10 percent of the contents.

8 We did that for ammonia, chlorine, and
9 sulfur dioxide and the analysis is shown in the table
10 and the results of the analysis is shown in the table.

11 So, next slide.

12 MEMBER STETKAR: I don't know.

13 MEMBER BROWN: Can you, yes, stay with that
14 one. Did I interrupt, did somebody say something?
15 John?

16 MEMBER STETKAR: I did, but you were first
17 off the block, so --

18 MEMBER BROWN: No, this was just -- I was
19 just looking at the FEMA data, it's 1989. The
20 NUREG-6624, what's the date of that when it was
21 published, do we know, does anybody around here know?

22 I'm just asking, trucking is a lot heavier
23 now than it was in 1989, and yet you are basing all
24 your frequencies and the 20 percent accidents and spills
25 on 28, 29-year-old data.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Simultaneous speaking)

2 MEMBER STETKAR: I'll tell you my spin,
3 Charlie. That NUREG, we have, and I'll state it on
4 the record here for this meeting to alert you, the ACRS
5 has a working group that is looking at the general issue
6 of manmade hazards, and trucking is part of that.

7 We are looking at several of the methods
8 and data that have been cited. I personally have some
9 questions about both the methods and the data in that
10 particular reference. That isn't your issue.

11 MS. HAAS: Right.

12 MEMBER STETKAR: You did follow the
13 guidance in that NUREG and that NUREG is cited in the
14 NRC Staff's guidance.

15 So this is not, you know -- The pedigree,
16 if you will, of that crash rate and the pedigree of
17 those, the fraction of accidents that result in a spill
18 and the conditional probability of ignition is not your
19 problem.

20 MR. CORUM: Right.

21 MEMBER STETKAR: That's different from the
22 aircraft crashes where some of the counting was your
23 problem, but that's not your problem though, it's a
24 different issue and we are following that in a more
25 generic sense in a different activity.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, Charlie, you're right that that stuff
2 is outdated, but it's not NWMI's problem, it's more
3 of a general agency problem.

4 MEMBER BROWN: No, I understand that
5 point. It's just I just -- Based on other meetings
6 where we have gone back and used data for other, not
7 just highway stuff, but other, not with you all, and
8 I guess it seems to me that even though it's not your
9 fault you've still got to do an analysis that's based
10 on current application of your facilities, that's all,
11 and that while you can follow the guidelines it would,
12 I would just -- Highway accidents are not -- You read
13 about trucking stuff going on and they seem to be nastier
14 and nastier, including, and we haven't even talked about
15 railroads yet, but I don't know whether that's in here
16 or not, but they've been, you know, they're longer
17 hauls, they got longer trains, they've got more stuff
18 in them and the same thing with trucks.

19 So it just seems to me that that, what the,
20 how close the facility is to major highways where there
21 is major trucking going on. If I was doing it I would
22 try to give a little consideration of that.

23 Obviously, that's my personal opinion, not
24 a Committee opinion, but I just wanted to point that
25 out from that standpoint, it's a philosophy thing more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 than it is calling the rules.

2 Rules, I love rules, but if you didn't have
3 exceptions you wouldn't need rules, and that's kind
4 have been my philosophy now for 50 years.

5 MS. HAASS: Well, thank you for the input.
6 I mean definitely we will go back and look at it.

7 MEMBER REMPE: The NUREG was issued in
8 1999.

9 MEMBER BROWN: 1999, so it's 18 years.
10 It's 18 and 28, so, anyway, that was my only thought
11 process, more of a philosophy issue relative to how
12 we treat our new facilities and then do we follow the
13 rules or not.

14 MS. HAASS: Thank you.

15 MEMBER STETKAR: Okay, the only comment,
16 and, Charlie, I'm kind of glad you did bring that up,
17 the only comment that I would make on kind of following
18 the guidance from that NUREG is that they -- In your
19 analysis there are several fractions that you use.

20 You use that 2 times 10 to minus 6 accident
21 per truck mile crash rate, you use a 20 percent
22 conditional probability of a spill given an accident,
23 which is in your third bullet here.

24 There is a 20 percent probability that more
25 than 10 percent of the inventory is released, which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you highlight here. There's another curious one, and
2 that is there is a 20 percent conditional probability
3 of ignition given a release.

4 You haven't highlighted that one on here,
5 which I guess I can maybe understand for spills of liquid
6 things, you use that also for things like hydrogen and
7 propane and that might be optimistic.

8 I am not an expert on hydrogen, but it tends
9 to want to ignite and you may want to re-look at that
10 for your hydrogen and propane, because you do look at
11 hydrogen and propane, but I am not sure about the
12 liquids.

13 A bigger issue for me is that in our last
14 meeting I had two comments on the highway accidents.

15 One was regarding units, and you fixed that up. You
16 made estimates of the number of trucks per year that
17 passed the site so the units are now accidents per year.

18 I still think that your analysis does not
19 correctly account for the total frequency. It accounts
20 -- The way that the methodology, or the NUREG is
21 subdivided it says that 20 percent of the accidents
22 will result in a -- I have to look up my numbers here
23 so that I get it right for the record -- that there
24 is a 60 percent probability that you will get up to
25 a 10 percent release, a 20 percent probability that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 between 10 and 30 percent of the inventory will be
2 released, and a 20 percent probability that all of the
3 inventory will be released.

4 Now each of those releases, there is an
5 analysis that you have that looks at what I will call
6 a standoff distance or a damage distance, given a
7 release of a certain amount of the material and you
8 are a 1/4 of a mile away from the intersection of the
9 highway and for, I'll use hydrogen as an example because
10 I worked that one out, the damage distance for 10 percent
11 release is 1/3 of a mile.

12 So even if you get a 10 percent release
13 you are within the damage distance. The only part of
14 your calculation that you accounted for was the 20
15 percent probability that you had a complete release
16 that resulted in a damage radius, if I will, of 0.77
17 miles, which got the 1.54 linear distance along the
18 highway that you used.

19 So you only accounted for 20 percent, that
20 20 percent, that's the big booms. You didn't account
21 for the 20 percent what I'll call middle booms, which
22 has a smaller exposure distance, it's not 0.77 miles,
23 it's 0.49 miles.

24 And you didn't account for the 60 percent
25 of the 10 percent releases, which will still get you,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 which has even yet, it's only about 0.33 miles. If
2 you do the integral you come up with a, I'll just say
3 it's a higher number.

4 I don't want to be saying a much higher
5 number, it's countably higher than what you have. And
6 I made that comment about doing the integration the
7 last time around, you still haven't done the
8 integration.

9 So from my perspective I think you need
10 -- The summary in the PSAR is you've dismissed, and
11 I don't want to take up too much time looking at my
12 notes, you've dismissed a couple of the explosions,
13 you retained one of the explosions, I think you retained
14 the three toxic releases for further analysis.

15 I think you need to take a re-look at all
16 of them in the FSAR. And, again, from the calculations
17 that I did, from my personal opinion I didn't find
18 anything that rose to a level of concern that I would
19 say you have a problem, you know, for going ahead with
20 a construction permit, so this isn't something that
21 in my opinion is an issue for the construction permit
22 phase, but for the final FSAR when you look at
23 protections of structures or if you look at toxic gas
24 effects, you know, or toxic chemical effects, for
25 personnel onsite you probably need to look, to take

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 -- Just redo the highway analysis is what I am saying.

2 MS. HAASS: We plan on that. Thank you.

3 MEMBER STETKAR: Yes.

4 MEMBER REMPE: John?

5 MEMBER STETKAR: Yes?

6 MEMBER REMPE: This is twice you've
7 brought up things and you said I did a calculation,
8 I think things are okay, but with all due respect to
9 the integrity of your calculations I am kind of
10 wondering, I'm sitting back here wondering, well, did
11 the Staff do some independent analysis and --

12 MEMBER STETKAR: No, well, believe me,
13 when the Staff comes up --

14 (Simultaneous speaking)

15 MEMBER STETKAR: No, they didn't.

16 MEMBER REMPE: Yes, because I really think
17 more than one ACRS member should --

18 (Simultaneous speaking)

19 MEMBER STETKAR: No, that's right, and
20 that's why I am careful. This is a Subcommittee meeting
21 and that's why I am careful to say in my personal opinion
22 based on my calculations.

23 I would welcome anyone else on the
24 Subcommittee to do calculations. I would have hoped
25 that the Staff would have done independent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 calculations. It's clear to me they didn't.

2 MEMBER REMPE: Well, that's where I am
3 coming from that I think the Staff should have reviewed
4 this before the construction permit comes forward, so
5 when the Staff comes up I would have a lot of questions
6 about that because I mean even if a couple of us did
7 calculations and got the same number as you did it's
8 really the Staff's job to do that.

9 MEMBER STETKAR: That's right. When they
10 come up, I don't, you know, I'll say something to the
11 Staff when they come up, but I don't know what to say
12 to them.

13 CHAIR CHU: Okay, now due to schedule
14 constraint we need to -- okay, thanks. I just want
15 to let you know some of the folks, some of the Members
16 will have to leave before 12:00, so we'll make sure
17 we've got the significant stuff discussed before 12
18 o'clock.

19 MS. HAASS: Sorry. I think as we spoke
20 several times in the last three meetings that, you know,
21 we are doing a site-specific geotechnical investigation
22 at the site.

23 We have done certain things in conjunction
24 with the university, and I know that data is not
25 available, but we are doing that, and I wanted to make

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sure everyone understand that.

2 I also want to know that we are specifically
3 based on comments. We got -- You know, we're looking
4 at it from a sinkhole perspective and, you know, if
5 we believe that there is any reason that we think there
6 could be a sinkhole, a sinkhole could occur, you know,
7 we will be designing for that.

8 I am waiting for data to come in from that,
9 you know, from the geotechnical investigation, but,
10 you know, from a design perspective, you know, we have
11 people who understand how to design for sinkholes and
12 that we will be doing that and I think in the final
13 design you'll be seeing that, and that's where I was
14 just trying to go with this slide.

15 So, next slide. Other, this has to do with
16 Chapter 2. You asked us to do a couple of things.
17 One, we wanted you to know that the Maxwell probable
18 precipitation in a 1-hour period is 3.14 inches per
19 hour. That has been changed.

20 We have updated a lot of different things,
21 you know, tables in there, at your request, because
22 they were a bit dated based on when this was written,
23 so we have done that.

24 And then the very last one is the vibratory
25 ground motion. We are going to go in much more detail

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in a couple slides that I am just going to ignore that
2 right now, but we'll go forward.

3 One of the questions that I know that the
4 Staff has had as well as you guys is our design
5 evolution.

6 My point on this slide here is that we are
7 going to go from a preliminary, you know, design and
8 all of the documentation that goes with it, whether
9 it's the hazards analysis or the criticality, the
10 shielding program, everything like that, they were all
11 preliminary.

12 Everything we do, all of these documents
13 are going to updated based on the final design, and
14 that's very key for us. I mean I don't want you to
15 think that just because we've done a preliminary
16 shielding analysis we're done.

17 No, actually, we've taken our preliminary
18 shielding analysis and we have now separated it into
19 11 different shielding analysis because now we're going
20 area by area in the facility.

21 We're going to be doing the same thing with
22 -- Well, we already have already done the criticality
23 analysis based on the new USL, and you're going to see
24 that later on as well.

25 But we, you know, this design is evolving

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 as we go along and I think everyone understands that,
2 but I want everyone to know that, I mean we are working
3 very hard at that, making sure all these things evolve
4 and that they are all going to be consistent with one
5 another.

6 MEMBER REMPE: So before you leave that
7 slide --

8 MS. HAASS: Yes?

9 MEMBER REMPE: There were a couple items
10 that were brought up during our Subcommittee meetings
11 that Members mentioned and I believe either you or some
12 of your colleagues said, oh, yes, we will look at that.

13 They didn't get identified in the Appendix
14 A so I would like to bring them up here if you don't
15 mind.

16 One of them was the discussion about having
17 enough room for layup capabilities, and I believe
18 Northwest Medical Isotopes said, yes, we will look at
19 that, and maybe it's somewhere in your updated
20 documentation, but I didn't go through every chapter.

21 Is that somewhere that you have committed to do that?

22 MS. HAASS: What appendix are you
23 referring to?

24 MEMBER REMPE: The Staff had an SE and they
25 identified some items from ACRS discussions and they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 did not mention layup capabilities in their Appendix
2 A.

3 I will ask them about that later, but I
4 believe that you did agree to it on the transcript,
5 and so are you going to be looking at that capability
6 in your updated design?

7 MS. HAASS: Yes, we have to. We have to
8 have -- I mean when we do a design we look at it both
9 from a constructability and an operability perspective
10 and we do bring in experts to go do that and lay-up
11 is a very important thing for us.

12 MEMBER REMPE: And is that documented
13 somewhere in your updated REV-3?

14 MALE PARTICIPANT: No.

15 MEMBER REMPE: Because, again, I kind of
16 consider the construction permit in Appendix A and what
17 the Staff does in the SE kind of a commitment on what
18 has been agreed to in all these discussions and I didn't
19 see it anywhere and I think you said, yes, we'll do
20 that.

21 MS. HAASS: I completely agree it has to
22 be done. I don't know off the top of my head is in
23 there.

24 MEMBER REMPE: Well, again, it's on the
25 transcript.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. HAASS: Yes.

2 MEMBER REMPE: I hope Appendix A gets
3 updated to reflect that. The other thing was that I
4 believe it was Matt said what about an independent
5 control room, and I believe Steve said, oops, we didn't
6 do that, but we'll look at it, and I didn't see that
7 anywhere in Appendix A or in your documentation, so
8 I just wanted to bring both of those points up on the
9 transcript.

10 MS. HAASS: Well, and that was just to
11 evaluate an independent control room.

12 MEMBER REMPE: Yes.

13 MS. HAASS: Correct.

14 MEMBER REMPE: And so I would -- If I am
15 still on ACRS when you come back with your operating
16 license I've got my notes and I plan to bring it up
17 and say you guys said you'd do this, so thank you.

18 MEMBER SKILLMAN: I want to say amen to
19 what Dr. Rempe said, but I want to add one more that
20 I at least witnessed you rogering up on when I raised
21 it, and it is the capability, now we're in a construction
22 permit period right now, so the background of my comment
23 is making provision as you do your foundation and your
24 basement design, and that is the capability to absorb
25 fire protection water.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CORUM: Water, yes.

2 MS. HAASS: Yes.

3 MEMBER SKILLMAN: And I will tell you I
4 have been involved on a number of fires, one in
5 particular where we couldn't relieve the compartment
6 and that blocked our capability to further fight the
7 fire.

8 So what you don't want to have is a fire
9 that is an extended fire and by your fighting it you
10 can no longer gain access or by fighting it you have
11 precluded access.

12 You've got to have a way for that water
13 to drain, and I bring your attention to your document,
14 REV-3 of your application, it's 3.3.1.4.1, 3.3.1.4.1,
15 and I think that needs to be amended to say we've
16 confirmed that we can absorb a reasonable fighting of
17 fire and I think you've got to put some dimensions on
18 that --

19 MALE PARTICIPANT: Yes.

20 MEMBER SKILLMAN: -- 20 minutes at 500
21 gallons a minute, or 10 minutes at 500, whatever you
22 choose in accordance with your codes.

23 MS. HAASS: Right. We agree with you and
24 that we will be doing that in the final, yes.

25 MEMBER SKILLMAN: Thank you. Let me make

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 one more comment, and it also to do with fire, and that
2 is your capability to fight a fire in your ductwork.

3 It's easy to think the ventilation systems
4 are out of sight, out of mind, not accessible, but if
5 you get a fire in your ductwork and you are using water
6 you can get into a situation where you've got water
7 going everywhere and you need to think that through
8 at the construction stage. Thank you.

9 MS. HAASS: We agree, thank you. The next
10 slide, Slide 13, goes through design evolution. I did
11 a little bit of specificity here on flooding just
12 because we had a lot of discussion on flooding that
13 we are going to take that, obviously, into account just
14 like we are with fire, and that, you know, we will be
15 working through that and when you see our operating
16 license application you will be seeing that type of
17 information.

18 Slide 14, site grading. You know, I know
19 that there was a lot of discussions on site grading.

20 We understand that, you know, it is definitely a
21 primary goal that we are going to grade this site
22 appropriately to ensure that the stormwater flows away
23 from the site, you know, appropriately, and our
24 structural and civil engineers understand this and
25 that, you know, we are taking, we are being methodical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about how we go do this so we don't have water flow
2 into the site, it goes out.

3 And, you know, we don't want to flood our
4 facility for some reason. It's just like, you know,
5 firewater, how do you go deal with that, how do you
6 absorb that, and so we do understand that and they are
7 working through that.

8 You know, Mike's staff is very key in
9 getting that done for us.

10 MEMBER SKILLMAN: I would make one
11 comment, and this is from personal experience, after
12 the basic foundation layout of this particular facility
13 was confirmed as final we went back and suggested
14 raising the floor elevation by 12 inches, one foot,
15 to much the consternation, and this was the LES
16 centrifuge facility in Hobbs, New Mexico.

17 And there was some pushback, but finally
18 the site leadership agreed to raise one foot and grade
19 based on that changed elevation, and lo and behold,
20 just the way the weather began to unfold, big storms
21 coming up from the Gulf that found their way into Western
22 Texas and that corner of New Mexico, that extra foot
23 saved the day.

24 And my point is it's cheap to do it on the
25 front end, and if it's six or eight or ten inches it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 can be the difference between success and failure on
2 cliff effect for water in the basement or truck bays.

3 It's cheap to do it up front. Thank you.

4 MS. HAASS: Thank you. The next item we
5 are going to talk about is seismic, and I am going to
6 hand it over to Mike.

7 MR. CORUM: Okay. Based on the PSHA that
8 was performed by the NRC Staff for the MURR site we
9 have used that to infer that the seismic response
10 spectrum with the peak ground acceleration of 0.2G
11 envelopes the GMRS up to about 16 hertz and at that
12 point the GMRS exceeds the seismic response spectrum.

13 So based on the EPRI guidance the ground
14 motions greater than 10 hertz are not damaging to any
15 of the SSCs of the system except for those components
16 that are sensitive to vibration, such as, as was brought
17 up last time, electrical relays. So we will be taking
18 that into consideration going forward into our final
19 analysis.

20 Next slide. So we'll be doing both static
21 analysis during the final design phase, that will
22 include finite element modeling of the entire facility
23 as well as doing, well, that's the static load
24 computations, but we'll also look at shake table test
25 data and the existing earthquake experience using the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 EPRI database for equipment, in particular, as well
2 as looking at some of the most recent earthquakes in
3 Japan that have affected nuclear power plants. Onagawa
4 is one in fact that we will use during our analysis.

5 Let's see. Yes, so we are going to require
6 that all of our equipment, mechanical equipment,
7 electrical equipment, is seismically qualified
8 according to the standards, and even subsystems then,
9 equipment that are not relied on for safety will be
10 designed per the IBC-2012. I believe that's all that
11 we need to say on this one.

12 As far as tornadoes, tornado missiles are
13 assumed rigid for maximum penetration, we'll use the
14 tornado versus the hurricane at the same annual
15 frequency of exceedance, use the standard design
16 missile spectrum from Reg Guide 1.76, and the tornado
17 missile spectrum are shown on this table here.

18 MEMBER STETKAR: God, I hate to do this,
19 but my personality forces me to.

20 FEMALE PARTICIPANT: You have a choice.

21 MEMBER STETKAR: No, I don't, actually.
22 But that's okay. I brought this up before. There's
23 a Table 3-20, and it's not something that you
24 highlighted here, that lists probable maximum winter
25 precipitation amounts that you use for roof loading,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 okay. Trying to orient you there.

2 That table lists a 24-hour value of 18
3 inches, I'm rounding, 18 inches, a 72-hour value of
4 22 inches, and a 48-hour value of, and I'll be precise
5 here, 8.73 inches. And I observed earlier that -- I'm
6 sorry, in the text it says, well, the 48-hour was derived
7 from linear interpolation between the 24 and 72 hours.
8 Well, that's clearly not the case.

9 The updated PSAR admits that if you did
10 a linear interpolation you'd get 20 inches for 48 hours.
11 But you cite a completely different reference for that
12 8.73 inches. So I dutifully went and found the
13 reference.

14 And it's from something called NOAA Atlas
15 14 which is kind of an interesting document if you go
16 look it up. And it's got tables and numbers. And the
17 8.73 inches is the 100-year, two-day, mean value. In
18 other words it's NOAA's estimate of the amount of water
19 that will fall out of the sky in a 48 hour period once
20 in 100 years.

21 And NOAA actually gives you uncertainty
22 bands on that. It's from seven to 11 inches. Their
23 1,000-year estimate ranges from 9 to 16 inches. They
24 note in their table that these estimates were not
25 compared with probable maximum precipitation values.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So it's not clear to me why a 100-year mean
2 value is being advertised in your analysis as a probably
3 maximum precipitation. I'll just point that out. I
4 don't know how it affects your overall loading analysis.

5 You can work it out in the final FSAR.

6 But it's clear that you're taking one set
7 of numbers from one reference and another number from
8 another reference, characterizing them all as probable
9 maximum precipitation, and using 8.73 inches in your
10 analysis. It's an observation.

11 MR. REESE: All right. So the whole
12 purpose of this slide is to acknowledge something I
13 believe you had pointed out about the number of targets
14 and making sure that is consistent, recognizable,
15 understandable, and you can fold it into the heat
16 calculations in making sure our cooling systems can
17 cover those heat calculations. But we're just
18 acknowledging and recognize that that does have to be
19 cleaned up. There was an inconsistency there.

20 MEMBER REMPE: And a shading done. But
21 I noticed you didn't have one for Chapter 11 where you
22 also used those values. And I hope that that is
23 something --- I'll admit, I did not go back and look
24 at Chapter 11 to see if you updated it. Because I assume
25 you're going to do your optimization study later.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. REESE: Yes.

2 MEMBER REMPE: And so could you please also
3 acknowledge that ---

4 (Simultaneous speaking)

5 MEMBER REMPE: -- you're going to also do
6 this in Chapter 11? Because the release is in --- won't
7 it affect not only the air releases, which the staff
8 identified in Appendix A, but also the liquid and the
9 solid waste values? And so their condition or whatever
10 acknowledgment of Appendix A also needs to be updated.

11 MR. REESE: That's good.

12 MEMBER REMPE: But I kind of wanted you
13 to say that here too. So thank you.

14 MR. REESE: I agree.

15 MEMBER REMPE: Thank you.

16 MR. REESE: Our CAAS system, so we are very
17 much --- we're committing to endorsing that 8.3 and
18 also that which is required under 3.17, Reg Guide 3.17,
19 for how the CAAS system will be implemented.

20 So obviously the CAAS system hasn't been
21 finalized at this point. We have a draft of what it
22 looks like. But we will definitely have a complete
23 evaluation for the FSAR and the OL application.

24 We will have, as required by 8.3, we're
25 going to have coverage in all areas that exceed the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mass limits and, more to the point, in areas --- we're
2 going to have double detectors in areas where these
3 are, but we're also going to have --- and I think I
4 talked about this in the next slide. Yes, okay, I'll
5 wait on that.

6 The idea is that we'll have the ability
7 to prevent or we want to prevent material from going
8 into places that aren't covered by the CASS system.
9 And the capability of the system is, and I believe this
10 comes out of 8.3, is be able to calculate, or I'm sorry,
11 detect 20 rads of combined neutron gamma then
12 un-shield this as two meters within one minute.

13 So one of the concerns that came up, just
14 to make sure that we are cognizant of the fact that
15 shielding design will have to be, or the CASS system
16 and the shielding, the final shielding design will have
17 to be done together. You wouldn't want to create a
18 situation where you couldn't detect a criticality
19 accident because of shielding. And we recognize that.

20 So we realize that those two things go hand-in-hand.

21 And the idea is that operations will be
22 rendered safe by shutdown quarantine if necessary if
23 any area or CASS cover has been lost or not restored
24 in a specific number of hours.

25 So in addition to trying to prevent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 material from going to places it's not covered, we want
2 to be able to do this. We want to be able to stop work
3 and render safe any situation if part of the CASS system
4 failed, such that we weren't covered in areas we were
5 supposed to be.

6 And the whole thing will be provided an
7 uninterruptible power supply that has not admittedly
8 been designed at this point.

9 MEMBER SKILLMAN: Steve, please go back
10 to 20, Slide 20.

11 MR. REESE: You bet.

12 MEMBER SKILLMAN: The last bullet there,
13 "Ability to detect within one minute," is that one
14 minute part of a regulation or a guide? It seems like
15 that is --- 60 seconds is a long time for --

16 MR. REESE: A crit accident? Yes.

17 MEMBER SKILLMAN: I mean, that's a long
18 time. Shouldn't the detection time span be seconds
19 versus a minute?

20 MR. CORUM: Yes, this particular bullet
21 is just to set up the minimum accident of concern.
22 So it really has nothing to do with the detector
23 threshold itself. It's really creating the minimum
24 accident of concern that the detector is going to have
25 to respond to.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: Okay. What's the
2 normal response time? I'm thinking it's milliseconds?

3 MR. CORUM: It is, yes.

4 MEMBER SKILLMAN: All right, okay. Thank
5 you. Thank you.

6 MR. REESE: So for criticality safety, so
7 prior to the end of construction and submittal of the
8 operating license, we will ensure that all the processes
9 in the RPF are evaluated to be sub-critical under all
10 normal and credible abnormal conditions. And we'll
11 do that using the new USL that we developed in the
12 revised validation report.

13 Of the 11 or so degrees of freedom that
14 we have to work with, NWI is going to basically use
15 controls for mass geometry moderation volume and
16 interaction. And we will commit to the specific
17 criteria associated with each one of those parameters
18 that are listed in the guidance in New Reg 1520.

19 We're also going to, well, we acknowledge
20 that using a single NCS control to maintain values of
21 two or more control parameters, it only constitutes
22 one leg of double contingency. And double contingency
23 will be the method that we use primarily for the
24 evaluations of crit safety accidents.

25 Order of preference for NCS controls are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 listed here, passive being the most desired and
2 administrative controls, of course, being at the bottom
3 of the list.

4 So 23, Slide 23. And this just reinforces
5 that we're going to use passive engineer controls where
6 we possibly can and with preference toward engineered
7 geometry control to make criticality safe by geometry.

8 If we are going to do controls on a single
9 parameter, we'll commit to using diverse means of
10 control rather than just redundant means of control.

11 And we've got all the general criteria that are
12 established on controls on parameters that are listed
13 as guidance in New Reg 1520. We will be following those
14 during the final design phase.

15 This just reinforces that we will meet the
16 revised USL of 0.924. We're going to be updating all
17 the criticality safety evaluations during the final
18 design phase. And we'll establish the operating limits
19 based on the optimum and most reactive credible values
20 of the parameters. And we'll provide specific controls
21 and management measures necessary to make sure that
22 the controls are available and ready for operation when
23 called upon.

24 Next slide. So the point of this slide
25 is to reinforce three things. One is that, although

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some aspects of the control systems will be digital,
2 all of the safety functions we will have hardware or
3 analog logic or interlocks to control those processes.

4 The other thing is that we're going to make
5 sure -- because this entered into the discussion, I
6 can't remember with whom -- but this concept of what
7 we're calling interlocks and what we're calling
8 permissives.

9 So to be clear, this is how we interpret
10 it. An interlock is essentially, it's an engineering
11 control such that it prevents you from going into a
12 configuration that you shouldn't be going into.

13 Whereas, a permissive is essentially an
14 administrative switch that is allowed once actuation
15 --- some action is allowed by an independent person
16 by the actuation of a switch. So it requires a person
17 to intercede and override the ability to perform some
18 function. So that's how we're interpreting it. And
19 if it's okay, this is how we're going to go forward
20 on this.

21 MEMBER BROWN: Just for committee issues,
22 I went back and looked at the --

23 (Off-microphone comment)

24 MEMBER BROWN: Oh, thank you very much.
25 I'm getting as bad as Ron.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Laughter)

2 MEMBER BROWN: I did go back through Rev
3 3 and compared it, sometimes generally section by
4 section, sometimes line by line where necessary. So
5 this is fairly consistent with the changes the made
6 between Rev 0 and Rev 3, mostly clarifications and minor
7 edits.

8 The only thing that was kind of different
9 was the figure, in that they repositioned the controls
10 for a number of --- I don't know, I can't read it right
11 now, but it's plant process type stuff, not target and
12 other type things.

13 The left hand box, they moved them from
14 being under the FP, facility process control. They
15 put it under the building management system as opposed
16 to the facility process.

17 It's just an --- it's just a high level,
18 functional, doesn't really say much architecturally.

19 So it doesn't change anything of what we've done.
20 But it'll just have to be evaluated based on our other
21 comments when we finally get around to it for
22 independence control of access and things of that
23 nature. So other than that, it's pretty minor changes.

24 MS. HAASS: So, Dana, the next item we
25 wanted to talk a little bit about, uranium metal fires.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I know you brought that up. Just to let you know,
2 we've already done, over the last six weeks, a fairly
3 extensive, you know, our own white paper that's going
4 to support us in our final design and make sure that
5 there isn't any uranium metal fires.

6 But what you're doing is you're seeing some
7 snippets that come from this. But, you know, we gone
8 and evaluated it. You know, we understand how, you
9 know, potential areas, I mean, potential ways to go
10 extinguish a uranium metal fire. So that's what you're
11 seeing here. And we wanted to make sure that you know
12 that we wouldn't ---

13 MEMBER POWERS: I couldn't help but go
14 quickly examine it. The one thing that struck me is
15 have you ever seen a uranium metal fire?

16 MS. HAASS: I personally have not, but the
17 team has. I have not. And the people who wrote this
18 up have.

19 MEMBER POWERS: There is a formidable
20 aerosol generation associated with those fires. And
21 you didn't seem to address that.

22 MS. HAASS: It is addressed in the white
23 paper, because I read that. It was me ---

24 MEMBER POWERS: Probably ---

25 MS. HAASS: -- that, you know, developed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 these slides here. And I apologize, but that was not
2 in there. But we did look at the aerosol aspect.

3 MEMBER POWERS: Yes. The problem is
4 post-fire.

5 MS. HAASS: Understand.

6 MEMBER POWERS: You've got a kind of a
7 headache and what not. I don't know what you're
8 thinking of doing and, I mean, there're advantages if
9 your fire's going to be relatively small and
10 approachable.

11 I would have --- I have used graphite and
12 what not for those kinds of fires. Hydroid fires are
13 really interesting. Because you can't do anything with
14 them. They're over before --- as soon as you know
15 there's fire, it's over.

16 MS. HAASS: And so, I mean, I think the
17 key thing here is --- and I know that Margaret really,
18 I know she's trying to push us along --- is that, you
19 know, we have developed a document that goes and looks
20 at this specifically.

21 This information will be used in our
22 accident scenario for uranium metal fires, you know,
23 during target fabrication. We fell fairly comfortable
24 right now. We know where we need to go on that so we
25 can take it forward into the evaluation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER REMPE: So are you planning to
2 provide this white paper to us before the full committee
3 meeting?

4 MS. HAASS: No, this is something we are
5 developing for our final design and our FHA. It has
6 not been peer reviewed yet, anything. And so, you know,
7 I mean, it's not ready to go forward.

8 Margaret, that's it, thank you, unless
9 there's any other questions.

10 CHAIR CHU: Okay, any questions for NWMI?

11 MEMBER SKILLMAN: I did have several
12 comments that I would like to offer on the record.
13 And I'm following the direction of our subcommittee
14 chairman who asked us to round these up and make sure
15 we present them here as our last chance.

16 On Chapter 8. -- it's in Chapter 3, power
17 for, emergency power, "The diesel generator will
18 maintain power until the normal power system is
19 operating within acceptable limits." Just a caution,
20 wherever you place that, ensure that its exhaust does
21 not compromise your facility ventilation intake.

22 Next comment, it's in Chapter 9, Chapter
23 9.3.2. You state in your document, "Space has been
24 reserved that, if required, the fire protection system
25 can have a dedicated water storage facility onsite.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The need will be dependent on the reliability and flow
2 rate of the city water supply."

3 As I did before in the last meeting, I would
4 like to challenge that. I think you're betting on a
5 positive outcome. My sense for a facility of this value
6 and for what you are going to be doing, you should and
7 need to have your own no nonsense dedicated tank onsite.

8 I just don't think you can take the chance that, for
9 the unforgiving 30-minute timeframe that, for whatever
10 reason, the city water supply lets you down.

11 And the reason I make this comment and
12 reinforce it is it changes how you think about the
13 availability of your fire protection systems. You go
14 from thinking, well, I think it's available to being
15 able to say I know it's there, I can see the water level,
16 and I can see the, if you will, suction pressure on
17 the fire pump. It provides a benefit that is beyond
18 perhaps the value of the tank.

19 MS. HAASS: Thank you for that comment.

20 MEMBER SKILLMAN: And my final comment is
21 this. In Chapter 11, you give the data for your stack
22 data. You say it's 65 feet tall, it's so many feet
23 in diameter, so on, and so forth.

24 That is a foundation, a cement, concrete
25 building foundation question that has to do with your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 construction permit. You've got to make sure that that
2 number is correct. Is that the right stack height?
3 Does that meet your queue requirements? Is it the right
4 diameter for the flow rate that you intend?

5 And I raise this kind of in the spirit of
6 John's comment in challenging fine detailed data. This
7 has to do with your foundation, where this thing is
8 placed, how the ventilation systems feed into it.
9 You've got to get that one right, right in the beginning.

10 Thank you.

11 MEMBER BROWN: I had one comment, and you
12 reminded me of it, thank you. It was your --- it's
13 on. I made it this time.

14 On the diesel generator transfer, once your
15 power is back -- only I was hoping that there would
16 at least be some human interaction on before you
17 transfer back from your diesel over to -- back to
18 commercial power.

19 I bring that up, it just dawned on me
20 because I had a --- there's a tear-down next door to
21 me. They went out to try to get the power turned off,
22 transformer didn't work right. There was a problem
23 with it. They had to replace it.

24 When they put it back in service, my house
25 fluctuated four or five times before I had no idea what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 was going back in their substation. But it was not
2 fun. Lights went on and off, and clocks went bananas.

3 And fortunately my computer was on a UPS, so
4 I floated through those. But anyway, it was --- and
5 they were unpredictable. It lasted over about a half
6 an hour period.

7 So you need to have some thought, once
8 you've gone on it, that you know that you've got stable
9 tests not coming back within parameters. It needs to
10 be stable. So it's just an observation, that's all.

11 CHAIR CHU: I have a question, Carol. How
12 long do you anticipate the construction will last,
13 roughly?

14 MS. HAASS: It's right around 17 to 18
15 months.

16 CHAIR CHU: And when do you plan to submit
17 your operating license application?

18 MS. HAASS: We are not submitting the
19 operating license application until after approval of
20 the construction permit application.

21 CHAIR CHU: Yes, that's --

22 MS. HAASS: We want to make sure that --

23 CHAIR CHU: -- obvious.

24 MS. HAASS: -- you know, we're consistent
25 with everything that you guys say. And so we're looking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 --- I know that the NRC staff asked me this as well
2 -- and we're looking at somewhere between, you know,
3 the 60, 90, 120 days, and we're hoping after we get
4 approval on the construction application. I'm not
5 quite sure. It's going to depend on everything when
6 we get there. You're laughing at us, John.

7 CHAIR CHU: You know, the reason I'm asking
8 this is because there's still a lot of design evolution
9 that's ---

10 MS. HAASS: Well, and, you know, we're not
11 just sitting here waiting for approval here, then to
12 go do the final design. And, you know, unfortunately,
13 you know, we're having to be very specific on the
14 application at hand, even though we've done a lot more
15 work.

16 And so sometimes you'll, you know, you know
17 we've done something, but we don't really talk about
18 it. And so we are, especially from a process
19 perspective, we've done a lot of that type of external
20 hazards, those types of things, you know, getting into
21 the structural and civil. But we are moving along on
22 that.

23 CHAIR CHU: Okay, thank you. Anything
24 else for now? Yes?

25 MEMBER KIRCHNER: This is not a question,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it's not a statement, but just one personal opinion.
2 I know you've got a lot of experience on your team.
3 I was thinking on ducts, and uranium fires, and just
4 general contamination of them. And this is not a
5 comparison. Rocky Flats is -- your operation is
6 nothing like Rocky Flats.

7 (Laughter)

8 MEMBER KIRCHNER: But I was just thinking
9 back to how much plutonium was found in the duct work.
10 So anything that you can do in your operational plans
11 and design to prevent that is good from all kinds of
12 reasons.

13 Hopefully, it would never be enough to be
14 a criticality issue. But it certainly -- uranium
15 processing could be a fire issue. And you certainly
16 have to look at the contribution to source term. So
17 I just raised that, Margaret. It's not a criticism,
18 it's just maybe something can be learned from that.

19 MEMBER POWERS: I don't think that uranium
20 fires and the duct work are their problem. I think
21 they have an ammonium nitrite problem in the duct work,
22 potential problem.

23 And let's, you know, if I were doing the
24 design alternatives, I would go with metal HEPAs instead
25 of paper HEPAs for exactly that reason. Paper is, in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fact, for ammonium nitrate. But that's a tradeoff they
2 make based on a lot of considerations besides that
3 particular one.

4 MR. REESE: Related to what you were saying,
5 we also hope that we wouldn't find ourselves in a
6 condition where we'd be raided by the FBI.

7 (Laughter)

8 MEMBER POWERS: I don't know, they're
9 really nice guys. It can be a lot of fun.

10 CHAIR CHU: We're going to take a 15 minute
11 break and then come back at 10 after 10:00. Thank you.

12 (Whereupon, the above-entitled matter went
13 off the record at 9:55 a.m. and resumed at 10:11 a.m.)

14 CHAIR CHU: We are resuming the meeting.
15 And the NRC staff will be giving presentations.

16 MR. BALAZIK: Good morning. My name's
17 Mike Balazik. I'm the Project Manager for the
18 Northwest Medical Isotopes facility. I'm within
19 Division of Policy and Rulemaking in the Research and
20 Test Reactor Licensing Branch.

21 Next to me is Steven Lynch. He's Acting
22 Branch Chief for my branch.

23 And next to Steve is Dave Tiktinsky. He's
24 a Senior Project Manager in the Office of Nuclear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Material Safety and Safeguards.

2 So real quick, some of the topics we'd like
3 to discuss today is provide ACRS members a status of
4 the safety evaluation report for the Northwest Medical
5 Isotopes construction permit application. We're going
6 to discuss SER Appendix A because I think this is the
7 first time that the members have seen it, and to explain
8 it a little bit.

9 And, also, we would like to discuss the
10 plan for the full committee meeting that's scheduled
11 for November.

12 So, first, just a quick SER status. Right
13 now the SER that was provided to the committee is updated
14 to Revision 2 of the Northwest PSAR. Rev. 1
15 incorporated all the REA -- RAI responses. And then
16 during our subcommittee meetings we received Rev. 2.

17 I'd like to point out that Rev. 2 was
18 received after the discussion of, of those chapters.

19 So, for 2, 3, 6, 7, and 8 we received the PSAR after
20 we had already discussed those specific chapters.

21 So, the staff went back, looked at Revision
22 2 and we updated the SER status or just the information.

23 Just to put a couple examples: we evaluated the
24 additional information on the heliports and airport

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operations.

2 And then and also another example, an issue
3 that came up when we were talking about Chapter 13 is
4 that the staff will confirm additional analysis and
5 details in the ISA process for specific technical topics
6 such as IS team qualification, screening of credible
7 action sequences, admin. controls and supporting
8 measures.

9 Now, I'd just like to add that that second
10 part is not in the SER that you have but it was just
11 something that I discussed with one of the technical
12 reviewers prior to sending it up. But we will put that
13 in the SER.

14 MEMBER STETKAR: So, I'm the -- you heard,
15 you heard my comments on Chapter 2. I'm really
16 disappointed that the staff did not do a review of the
17 aircraft crash analysis. And it's clear that you
18 didn't do a review of the aircraft crash analysis.
19 Your guidance says that the staff should do an
20 independent review and confirmation. You didn't do
21 that.

22 So, I really hope in the final safety
23 analysis that the staff follows through on their mandate
24 to actually do a review, and independent confirmation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 That's all I'm going to say about it.

2 MEMBER REMPE: Well, I can go further.
3 This is a construction permit. If you approve a
4 construction permit and then it comes to the operating
5 license time and you find that because, you know, there
6 was an error in their analysis, some of the
7 information's incorrect, and although John did a check,
8 nobody's reviewing John's calculations, but you find,
9 hey, there's a problem because of this analysis, I think
10 Northwest Medical Isotopes could legitimately say, hey,
11 that was in the construction permit. You guys didn't
12 review it. You said go ahead and build.

13 And just doesn't seem like a fair
14 situation. I think you're obligated to do an
15 independent analysis at this time.

16 MR. LYNCH: Sure. I appreciate the, the
17 feedback and the comments on this.

18 As far for the construction permit
19 application we do need to go back and look through and
20 verify all of the numbers and inputs that Northwest
21 used in their calculations. Most of our focus at this
22 point was making sure that Northwest was using
23 appropriate methodology and using guidance that was
24 consistent with similar types of facilities. We do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 need to take a closer look at this.

2 MEMBER REMPE: So before we have the full
3 committee meeting we're going to have someone up from
4 the staff say we did an independent validation of the
5 analysis and we, even though there may be some numbers
6 wrong, we used correct numbers and we think it's fine
7 to go forward with the construction permit.

8 MR. LYNCH: Yes. We will.

9 MEMBER REMPE: That would be good. Thank
10 you.

11 MR. TIKTINSKY: Can I, can I add one other
12 point to this? Related to your question about finding
13 issues later on that, you know, might impact Northwest
14 Medical, this is a preliminary design. And the
15 preliminary design has -- they are not official
16 commitments to things like codes and standards. I mean
17 it has, we follow Part 50. They have suggested things
18 they are using for inputs.

19 So there is really no way at this point,
20 because we don't have a final design, we don't have
21 final commitments to exactly how they're going to build
22 something, you can't assure that later on when the
23 operating license is reviewed and the actual data on
24 the final design, and the actual commitments are there,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that they wouldn't need to do something else related
2 to construction.

3 MEMBER REMPE: However, some of the points
4 John raised were how many flights were in the air going
5 over at this location. That's not going to be impacted
6 by, unless they move the location of the sight.

7 I mean, these are things that should be
8 addressed in the construction permit. It's not based
9 on how the concrete's poured, it's basically where,
10 the location where they sit. And I think those things
11 ought to be settled now. It's just my understanding
12 of the process. Right?

13 MR. TIKTINSKY: We agree.

14 MEMBER REMPE: Thank you.

15 MR. BALAZIK: So Northwest provided a PSAR
16 Rev. 3 to support today's meeting. It is in ADAMS.
17 It was put in ADAMS on September 14th.

18 The staff doesn't anticipate major changes
19 to PSAR. However, we will take a look at Rev. 3 before
20 the full committee meeting and update the SER
21 accordingly.

22 MEMBER STETKAR: Mike, I have to apologize
23 because for some reason in hard copy we only got the
24 odd number pages. And I, on my goofy computer --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BALAZIK: Of your slides.

2 MEMBER STETKAR: Of your slides. And I
3 can't open the even number pages on my computer because
4 I don't have a compatible version.

5 Anyway, that's my problem, not yours.

6 MR. BALAZIK: I do have --

7 MEMBER STETKAR: It's fine. Just don't,
8 don't worry about it. I just wanted to intercept the
9 discussion before we get past kind of the details.

10 I have some comments on the SER on some
11 sections that I wanted to get on the record before we
12 get into path forward for the full committee meeting
13 and Appendix A. And I think this is the time to do
14 that, isn't it?

15 The next slide is, is --

16 MR. BALAZIK: Yeah.

17 MEMBER STETKAR: That's the only reason
18 why I wanted to intercept it here.

19 In Chapter 8 of your SER you seem to refer
20 to a review of Rev. 2 explicitly of the PSAR. Just
21 double check that you actually review Rev. 3 please.

22 That -- let me get my notes here -- that
23 similar comment applies to Chapter 9 where you only
24 refer to Rev. 1 and RAIs. So just, just make sure the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 final SER is written against the final version of the
2 PSAR that exists.

3 In Chapter 13 I had a few for you. And,
4 again, this is, you might consider them editorial.
5 Some of them are somewhat substantive. In the
6 interests of time I'll focus on the couple of
7 substantive ones.

8 Section 13.4.7 is Chapter 13. You still
9 refer to the old ASCE-7 seismic analysis with the 2,500
10 year return period. NWMI has for quite a while now
11 said that they're going to file -- follow Reg Guide
12 1.60. So you all have to really clean that up because
13 that's like Rev. 0 of the PSAR.

14 And, also, on 13.4.7, which to me indicates
15 that the person who wrote the seismic stuff for Chapter
16 13 didn't really look at Rev. 3 of the PSAR, which is,
17 again, troubling, says "the Applicant should also
18 determine impacts on safety-related SSCs on seismic
19 events with shorter return periods in order to determine
20 whether additional IROFS may be needed."

21 What you really mean is longer return
22 periods, which is a lower frequency. A shorter return
23 period is a higher frequency. So kind of, kind of get
24 your what you're looking for straightened out, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Those are the only ones that I have that
2 -- it, it's just there's no need for it. You know,
3 read. Read the stuff. I mean, if we read the stuff,
4 you guys, this is your job.

5 MR. LYNCH: Absolutely. And just to
6 clarify on some of the timing for the submissions and
7 idiosyncrasies with the nomenclature. So, with
8 respect to references, at the time that we provided
9 the current graphs of the chapters to the members we
10 had not received Revision 3 yet. So we are currently
11 in preparation for the full committee meeting.

12 MEMBER STETKAR: Okay.

13 MR. LYNCH: We'll have updated the
14 chapters for the full committee.

15 MEMBER STETKAR: Okay, that's great.
16 Okay, I didn't realize that because --

17 MR. LYNCH: Yeah.

18 MEMBER STETKAR: Well, no, we got the SER
19 after, two days after anyway Rev. 3.

20 MR. LYNCH: Okay.

21 MEMBER STETKAR: Thanks. That helps by
22 the way.

23 MR. LYNCH: No problem.

24 CHAIR CHU: Just want to double check.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So our letter will be based on that October 6th version
2 of the SER; right?

3 MR. LYNCH: That is correct.

4 MR. BALAZIK: That is correct.

5 There's one change I do want to bring up
6 about the SER, and that's the licensing conditions that
7 we had in Chapter 13. The staff is going to issue RAIs
8 to Northwest on aspects of criticality control. And
9 determining -- that is depending on Northwest's
10 responses we may remove those licensing conditions.

11 MEMBER STETKAR: Wait a minute. Wait a
12 minute.

13 Margaret needs to read this. The ACRS
14 needs to write a letter on something that has finality.

15 That, that thing has to be in the ACRS' hands 30 days
16 before the ACRS full committee meeting.

17 We can't have a Rev. 4 of one chapter of
18 the PSAR in a state of flux or the ACRS meeting has
19 to be put off. I mean, you know, so issuing the RAIs
20 now that can result in a change to the PSAR, which can
21 then result in a subsequent change to the SER to me
22 doesn't sound consistent with our process. We cannot
23 review something that is in a state of flux for the
24 full committee. Subcommittee's fine.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. LYNCH: Sure. Your comment is taken.
2 And we will ensure that the SER and PSAR are in a final
3 state by that October 6th date.

4 MR. BOWMAN: This is Greg Bowman --

5 CHAIR CHU: When would the final frozen
6 date be?

7 MR. LYNCH: The final frozen date for --
8 the final safety evaluation report from the staff with
9 no further changes to it will be provided on October
10 6th. So currently we are reviewing information
11 provided in Rev. 3 of the PSAR. We are -- Northwest
12 has indicated that they have some additional
13 information that they could provide to address some
14 of the proposed conditions by the staff.

15 We have agreed that we will look at this
16 information if they provide it to us, and we'll consider
17 whether those conditions could be removed. However,
18 at this point, based on the information we have, those
19 conditions remain in place, at least as a recommendation
20 from the staff.

21 MEMBER BLEY: October 6th. It isn't 30
22 days before October 6th. And that gives us no time
23 to review.

24 MEMBER STETKAR: We're in November.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Oh, we're set up for
2 November?

3 CHAIR CHU: Yeah, we're set for November.

4 MEMBER BLEY: Oh, that's right. We moved
5 it to November.

6 CHAIR CHU: Yes.

7 MEMBER BLEY: Never mind.

8 MEMBER REMPE: So you think, though,
9 you're going to get something that you haven't seen
10 yet from Northwest Medical Isotopes and make changes
11 to your SER and get it to legal or something and get
12 it to us by October 6th?

13 MR. LYNCH: Yes. So at this time chapters
14 are currently being reviewed by our legal team. We
15 are revising them based on feedback. Any changes that
16 we make based on feedback related to these conditions
17 we expect to be minor changes to the SER Chapter 6.

18 MEMBER REMPE: Removing a licensing
19 condition doesn't seem minor to me.

20 MR. BOWMAN: This is Greg Bowman. I just
21 want to go back to Steve and what Steve just said in
22 direct response to John's question. The SER that you
23 get on October 6th is, that's final from our standpoint.

24 If we aren't able to resolve the conditions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 by October 6th, then they will stay as conditions.

2 MEMBER REMPE: There will be the potential
3 that you may be deleting a condition. And you think
4 you can still turn it around by October 6th. And
5 that's, I just want to know --

6 MR. LYNCH: That is correct.

7 MEMBER REMPE: Okay.

8 MR. BALAZIK: So I just want to, really
9 quickly want to talk about Appendix A. Big picture,
10 what Appendix A does is it lists proposed licensing
11 conditions, Northwest commitments regarding contents
12 of the operating license application, and Northwest
13 research and development activities.

14 So, what are we going to use these items
15 for? They'll basically inform inspections and verify
16 design completion for the operating license stage.
17 And also demonstrates a shared understanding between
18 the staff and Northwest on the status of the design,
19 and sets expectations for future oversight,
20 construction inspection, and licensing activities.

21 So, just to break down Appendix A, here
22 are the main points: We identified commitments
23 identified during ACRS meetings. Our commitments are
24 identified in response to RAIs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 What North -- RAIs that Northwest has
2 responded to acceptably and incorporated in the PSAR:
3 ongoing research and development, and also proposed
4 construction permit conditions.

5 MEMBER REMPE: So during the meeting today
6 there were several items that were brought up by members
7 that didn't appear in Appendix A. Are you planning
8 to make any changes based on the discussion today?

9 MR. LYNCH: Yes.

10 MEMBER REMPE: Okay.

11 MR. LYNCH: And we can do that now, but
12 my plan was at the very end I would summarize all of
13 it. I'll just be making a summary later.

14 MEMBER REMPE: That would really be great.

15 MR. LYNCH: Yes.

16 MEMBER REMPE: Thank you.

17 MR. TIKTINSKY: Can I raise one more point
18 on this? So Appendix A, want to make sure it's clear,
19 when we get an operating license review we will do a
20 complete operating license review of everything, using
21 our regulatory guidance. So, just because something
22 isn't, you know, everything isn't, that we're going
23 to look at is not in Appendix A. We're going to look
24 at everything from A to Z in that final license review

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 as we lay out in 1537 and the ISG.

2 MEMBER REMPE: I understand that. But on
3 the prior slide is my understanding of what Appendix
4 A should do: a shared understanding on the status of
5 the design and setting expectations. And so, if there
6 are some things you know that are missing, I think it's
7 nice to identify those.

8 So that's why I'm emphasizing that.

9 MEMBER BLEY: I guess I also need to say
10 that these are subcommittee meetings. These are
11 individual thoughts of individual members. So they're
12 not guidance from the ACRS as such, which will only
13 come in our letter.

14 MR. BALAZIK: Yes.

15 MEMBER BLEY: Lest this be viewed as
16 direction from us. We can't do it in a subcommittee
17 meeting.

18 MR. BALAZIK: Yes, sir. I think what we
19 tried to do is look at, when we read the transcript,
20 look at the discussion and see --

21 MEMBER BLEY: Make your own decisions
22 based on that.

23 MR. BALAZIK: -- like numerous times that
24 something was missing, you know. We saw it in several

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 different places. And say, well, we need to identify
2 this as an item.

3 So that's what our, our -- I guess how we
4 look at it.

5 MEMBER BLEY: That's the right way to look
6 at it. It's your decision based on the things you hear.

7 MR. BALAZIK: So these were -- we listed
8 a couple of our commitments identified from the ACRS
9 subcommittee meeting. These commitments will be
10 submitted by Northwest and documented in the SER.

11 First item is on seismic. We had numerous
12 discussions on seismic, specifically the high frequency
13 impact. So we captured that as a commitment that
14 Northwest provide an evaluation on those high frequency
15 impacts in its final safety analysis report.

16 Also, we heard numerous times is grading,
17 local, I'll call it local flooding. So we captured
18 that on depending on how the site is graded that
19 Northwest will also provide that in the FSAR.

20 Another item that we identified was the
21 final, for the final hazard analysis, that we will
22 reexamine those accidents that were screened out of
23 the preliminary hazard analysis, just to ensure that
24 the final hazard analysis properly accounts for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 action sequences relevant to the final design.

2 The last item was that Northwest provide
3 an evaluation on the physical impacts of a facility
4 uranium fire in a target manufacturing facilities as
5 part of its FSAR.

6 So, those were the items that we captured
7 in the SER as identified during previous subcommittee
8 meetings.

9 And also, as Steve mentioned earlier, we've
10 got some that we're going to add. And we'll go over
11 those after the presentation.

12 Ah, we have one more. Apologize.

13 Also what was brought up a couple times
14 was electrical fires and how deranged equipment
15 interactions with safety systems, the evaluation of
16 that. So we also captured that as an item that was
17 discussed during ACRS meetings.

18 MEMBER STETKAR: Mike, where does the term
19 "deranged equipment" come from? This is the first time
20 that I've, I've seen that phrase used.

21 (Laughter.)

22 MR. BALAZIK: Well, that's a term that was
23 used on fires in any electrical panel. After you put
24 the fire out it's deranged equipment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I don't know, can somebody back me up on
2 the meaning?

3 MEMBER STETKAR: I've never seen it used
4 before. I mean, it's fine. You're captured, you've
5 captured the issue. It's just --

6 MR. BALAZIK: We can change that to
7 something that's more --

8 MEMBER BALLINGER: Does the electrical
9 grid have a soul?

10 (Laughter.)

11 MEMBER STETKAR: It's probably, and I'll
12 put this on the public, it's probably just a veiled
13 reference to me.

14 (Laughter.)

15 MR. BALAZIK: Next topic staff would like
16 to talk about is commitment to identify the response
17 to RAIs. What we did is we went through all the RAI
18 responses and we asked approximately about 150 RAIs
19 in total. And where Northwest committed to providing
20 something in the operating license we captured those
21 items.

22 So the staff concluded that deferring the
23 review of this information until the operating license
24 would not significantly impact construction. And the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff considers that these commitments is necessary
2 to demonstrate understanding of inputs needed to the
3 final design.

4 Just a couple examples. I know on our
5 first subcommittee meeting it was brought up about the
6 geotechnical analysis that we conducted on the site.

7 So that's also, that's captured in that appendix.

8 Also, seismic requirements and evaluations
9 of the RPF, Northwest committed to providing more
10 information after the license. So all these were
11 captured in the, in the appendix.

12 And the staff will verify completion during
13 the review of the operating license.

14 The next item in Appendix A is the full
15 regulatory commitments identified in response to RAIs.

16 So, big picture, these, the RAIs that the
17 staff had asked Northwest, Northwest responded and
18 incorporated PCR -- PSAR where the technical review
19 found acceptable. Again, there were 63 items that were
20 listed in Appendix A, A.3. And just a couple examples
21 again:

22 The quality assurance plan to clarify
23 difference between quality level 1 and 2.

24 And also from EP perspective, there was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 an error in identifying the primary contact for
2 radiological emergencies. And that was updated in
3 Chapter 12.

4 Next is ongoing research and development.

5 And this is required by 50.34(a)(8). And these items
6 were captured within the PSAR and within response to
7 RAIs. So the staff will verify research and
8 development is completed before the end of
9 construction, through inspection, and operating
10 license review.

11 So there were four items that we captured
12 here. First item is from the PSAR that Northwest
13 perform testing to validate the acceptable operating
14 conditions for material and target solutions,
15 compatibility with the University of Missouri research
16 reactor and DOE National Labs.

17 And they'll examine a corrosive
18 environment to examine the effects on properties of
19 select raw materials, welded samples of the targets.

20 The other item is to confirm whether a
21 pressure relief system is feasible for an ion exchange
22 column operating at the specified pressure, and the
23 uranium separation process approach will continue or
24 if a design change will happen.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And the third one is laboratory resins,
2 have to determine the interactions between solutions
3 and resins as a function of temperature. And this will
4 help define the hazard and accident controls.

5 And the fourth item is to evaluate the
6 release of resin extracted from the ion exchange column
7 media during operation. It poses both a thermal and
8 radiolytic decomposition concern and a potential
9 criticality concern if they were to collect in a
10 non-geothermal vessel.

11 So those are the four items that we captured
12 in R&D. And like I said, three of the items were RAIs,
13 and one was captured in a PSAR.

14 MEMBER STETKAR: Mike, can I interrupt you
15 here? And I apologize for this. I missed one of the
16 questions that I had. Something you said sort of
17 reminded me of it.

18 Back in Chapter 3, in Section 3.4.5 of the
19 SER, just to orient you, look at that section. That's
20 where you discuss the classifications and the seismic
21 and quality assurance classifications. I want to make
22 sure, and this is for clarity from NWMI. I didn't ask
23 it when they were up because I thought that I understood
24 it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 It's my understanding that all IROFS,
2 regardless of whether they're safety related or
3 non-safety related IROFS, all IROFS will be classified
4 as QA Level 1 and Seismic Category C-1.

5 And I went to get confirmation from NWMI,
6 if I could, that that is accurate. So, could I get
7 that? All IROFS are QA Level 1 and Seismic C-1?

8 MR. BALAZIK: Yeah. This is Mike. That
9 is correct.

10 MEMBER STETKAR: Okay. Then the staff
11 needs to correct the SER because the SER doesn't lead
12 you to believe that's the case.

13 MR. LYNCH: Staff made note of that.

14 MEMBER STETKAR: It gets convoluted with
15 non-safety related IROFS and safety related IROFS and
16 non-safety related other stuff or whatever, so.

17 Thank you, NWMI.

18 MR. BALAZIK: The next topic I'd like to
19 speak to is the proposed construction permit
20 conditions. Real quick, just want to go with the
21 purpose of conditions, that since design of SSCs can
22 significantly impact construction of safety related
23 components, proposed conditions will require periodic
24 updates on certain design elements to enable the staff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to confirm their adequacy during the construction
2 inspection.

3 So, for right now we have three proposed
4 construction permit conditions, and they all have to
5 do with criticality control.

6 And what I mentioned earlier is that the
7 staff plans on issuing RAIs that if Northwest provides
8 additional information the staff would evaluate that
9 information to determine if these licensing conditions
10 could be removed.

11 But I'd still like to go over the three
12 construction permit conditions. The first one talks
13 about that periodic reports to the NRC, at intervals
14 not to exceed six months from the date of the
15 construction.

16 And this one is that these reports shall
17 identify changes in the criticality safety evaluations
18 and any changes to those evaluations for processing
19 special nuclear material.

20 The next one talks about the --

21 MEMBER SKILLMAN: Mike, let me ask about
22 that. Regarding reporting, if the requirement that
23 you're imposing licensing condition is only report
24 change, I would suggest you're deficient in your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 guidance.

2 I think what you want is identify change
3 and equally confirm no change. It's got to be both,
4 otherwise I think you've left your, your flank wide
5 open.

6 MR. BALAZIK: I appreciate that feedback.

7 MEMBER SKILLMAN: Thank you.

8 MR. BALAZIK: When we discussed Chapter
9 6, one item that Northwest and the staff talked about
10 was a change, a revision in the upper subcritical limit.

11 So that was updated in the validation report. But
12 it carried forward to a lot of design calculations,
13 design input.

14 So another licensing condition that the
15 NRC is proposing is for Northwest will ensure that the
16 processes are evaluated to be subcritical under all
17 normal and critical conditions. And this
18 interpretation can be done Section 6311 of the PSAR,
19 and it should be consistent with the revised upper
20 subcritical limit.

21 The third proposed construction permit has
22 to do with the criticality accident alarm system, that
23 Northwest shall submit periodic reports, not to exceed
24 six months. These reports shall provide technical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 basis for the design of the criticality accident alarm
2 system.

3 Prior to completion of construction the
4 report shall demonstrate detector coverage as defined
5 in the requirements of 7024.

6 So, for right now just to plan for the full
7 committee meeting. Right now the SER is going through
8 internal reviews to finalize the SER.

9 The staff plans for the draft final SER
10 to be publicly available prior to ACRS full committee
11 meeting. And that meeting is scheduled for November
12 2nd, 2017.

13 The staff plans to present our findings
14 from the review that support issuance of a construction
15 permit. And also we'll update the members on the status
16 of the proposed licensing conditions if they've
17 changed.

18 MEMBER STETKAR: You'll have to update the
19 full ACRS on the licensing conditions even if they don't
20 change.

21 MR. BALAZIK: Yes, sir. We plan on doing
22 that.

23 So once the SER is finalized and made
24 publicly available to support the mandatory hearing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 following ACRS full committee meeting, and right now
2 the mandatory hearing could be held in late January
3 of 2018.

4 And that concludes the staff's
5 presentation. We can go over a couple of action items
6 that we've taken away from this.

7 MR. LYNCH: Sure. This is Steve Lynch again.

8 So, listening to the Northwest
9 presentation and feedback received from the ACRS both
10 while we were presenting and while Northwest was
11 presenting, we've made a list of items that we are going
12 to follow up, both internally and with the applicant.

13 And these could end up in Appendix A. Regardless,
14 we will address them all at the full committee meeting.

15 So, in preparing for that full committee
16 meeting and the updated SER, you will see by October
17 6th we will review and update our SER based on Revision
18 3 of the PSAR that we have recently received.

19 Other particular technical areas that we
20 will focus on in this update are looking at protections
21 of structures and toxic gas events on the staff and
22 the facility associated with highway hazards. And
23 we'll do this using the guidance in NUREG/CR-6624.

24 We will also provide an update on our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analysis and verification of the calculations used for
2 aircraft impact. That will be based on our guidance
3 provided in NUREG-1537 and the DOE Standard 3014-2006.

4 We'll also take a look at extended layout
5 provisions and ensure that that is documented, both
6 in our SER and in the PSAR.

7 We will work with the applicant to ensure
8 that appropriate considerations have been given for
9 future evaluation of an independent control room.

10 We'll also look at provisions for the
11 retention of fire water onsite and how that's considered
12 during construction, if necessary.

13 And the last item that I had here is that
14 we will also look at the numbers and inputs for maximum
15 precipitation at the facility.

16 And also, we will ensure that all chapters,
17 particularly Chapters 3, 8, 9, and 13, as brought up
18 by Member Stetkar, are updated editorially at the very
19 least to ensure that they reflect the most recent
20 revision of the PSAR.

21 MEMBER REMPE: So there was a condition or
22 something associated with just airborne releases in
23 Chapter 11 that would be consistent with the optimized
24 number of targets. And it should be more than just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 airborne releases. And that was brought up during the
2 discussions with Northwest as well.

3 MR. LYNCH: Thank you. I have added that
4 to our list.

5 MEMBER REMPE: And then as a mix, to make
6 Dennis happy, you did mention the subcommittee meeting
7 and that the ACRS-initiated updates were in your
8 Appendix A. But the title of it says "ACRS Meeting,"
9 and it really should change it to Subcommittee and he'll
10 be happier.

11 MEMBER STETKAR: And I wanted to
12 reemphasize, you characterize, and this is a public
13 meeting and we have a transcript, so I want to make
14 it very clear on the public record of this meeting it's
15 a subcommittee meeting. You characterize these as ACRS
16 action items. They are not.

17 What you have heard today is the babbling
18 of individual members of the Advisory Committee on
19 Reactor Safeguards. You need to consider the babbling
20 of individual members as the individual members'
21 opinions, questions, et cetera. They are nothing more
22 than that.

23 The full ACRS has not deliberated on any
24 items here. So you may decide to not consider specific

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 questions and comments from individual members.
2 That's your -- the whole reason we have the subcommittee
3 meetings is to facilitate individual member's ability
4 to raise issues, ask questions, have a discussion among
5 the subcommittee, and an exchange with both the
6 applicant and the staff so that both the applicant and
7 the staff can then go back and consider which issues
8 they feel need to be addressed. And it's not ACRS.

9 Until the ACRS writes a letter in November,
10 presuming we stick to that schedule, there is no ACRS
11 action item, there is no ACRS conclusion about anything.

12 MR. LYNCH: We understand. Thank you for
13 the clarification.

14 MR. BALAZIK: That ends the staff's
15 presentation.

16 MEMBER KIRCHNER: Margaret.

17 CHAIR CHU: Yes. Questions?

18 MEMBER KIRCHNER: Just a process question.

19 I'm looking at slides 20 through 21.

20 I think I understand the intent but I was
21 just curious. Obviously you don't want to be
22 surprised, or neither party wants to be surprised by
23 criticality safety issues. But rigorously, isn't that
24 required as part of the FSAR?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 What's -- the six month interval just
2 struck me as odd. Why wouldn't you ask that on seismic
3 and almost everything else? Is this just to prevent
4 surprises and allow time to conduct an in-depth
5 criticality safety review?

6 MR. LYNCH: Sure. So, the purpose of the
7 conditions is not to perform a detailed technical
8 review. Based on how the regulations are written, the
9 next technical review we will do of criticality safety
10 will be during the FSAR. However, what we will use
11 the information and the conditions for is to help inform
12 and prioritize our construction inspection, especially
13 as it relates to, for example, pouring concrete that
14 could affect the impact of detectors to perform their
15 job.

16 MEMBER KIRCHNER: Or passive safety.

17 MR. LYNCH: Yes. So, it will help us, you
18 know, with limited resources we want to look and make
19 sure we're focusing our inspections on the most
20 safety-significant items and getting these updates
21 periodically. Six months is consistent with what we
22 required of the SHINE review.

23 And, also, based on our general talks with
24 applicants on how quickly their design will evolve,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 requesting updates sooner may just be a greater
2 administrative burden. And we settled on six months
3 as an appropriate interval.

4 MEMBER KIRCHNER: Thank you.

5 CHAIR CHU: Any other questions?

6 MEMBER BROWN: Yeah, one other question.

7 I looked back at the revision of Chapter
8 7. This is just, this is more of an administrative
9 thing. And if I hadn't had it nailed or referenced
10 in my own filing system I would not have been able to
11 tell the difference between the version from -- that
12 we used in the subcommittee meeting and the new version
13 that you list as final. There's no, there's no date.
14 There's nothing that says "final" in the text or
15 anything else.

16 This is, this is not new by the way. The
17 staff is very consistent in being able to have
18 indistinguishable SERs from one version to the next.
19 I would personally, again it would be appreciated if
20 somehow that the dates, there be dates put on them or
21 some words that refer to them as another version based
22 on Rev. 3, or whatever they are.

23 Because I did look at it and went through
24 it, and it's largely a few editorial words missing and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stuff. There was no basic technical variation. All
2 the conclusions read roughly the same.

3 So I, that's, like I say, it's almost
4 indistinguishable unless you go do a word by word,
5 paragraph by paragraph comparison. And even then you
6 can't tell where which one's beginning and which one's
7 the initial and which one's -- it's just my filing that
8 allowed me to tell the difference.

9 So, anyway, that's strictly an
10 administrative tracking issue.

11 MR. BALAZIK: Appreciate that feedback.
12 Thank you.

13 MEMBER BROWN: I'm done.

14 CHAIR CHU: I have a question. You know,
15 in my prior lives I was trained in the high level waste
16 disposal area. One of the most important things for
17 us was what could go wrong. Okay? Just the scenarios,
18 eventually we had to do analysis.

19 So, to me one of the things I really pay
20 a lot of attention is say have you identified the right
21 stuff: the initiating events, you know; the what could
22 go wrong. Did you input parameters, the right ones?

23 And then we had to go through the kind of rigor, okay,
24 you -- I think that some of you may be familiar with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it -- you need to be so comprehensive and rigorous.
2 So you make sure absolutely you don't miss anything.

3 And just a comment and probably a question
4 for you. I think I encourage you to have that
5 mentality. And because if you have something missing
6 then the whole game is over, in my opinion.

7 And then I would almost require NWMI to
8 put down what is their methodology? How did they start
9 with the initial list? Was it conversation or was it
10 -- did it have basis? And then that needs to be
11 documented. And because, you know, later on when you
12 get new data or new information you need to go back.

13 And without good documentation you would not be able
14 to revise whatever you came to the conclusion.

15 Thank you.

16 MEMBER BROWN: Can I make one other
17 observations?

18 If you look at your slide 4 it says ACRS
19 provided the SER updated. I don't think we provided
20 an updated SER to the staff. I think it's the other
21 way around.

22 And I guess that SER that you issued is
23 based on Rev. 2 based on that slide. Is that correct?

24 MR. BALAZIK: Yes, sir. It's based on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Rev. 2. Rev. 3 --

2 MEMBER BROWN: I saw the subsequent slide.

3 MR. BALAZIK: Yes.

4 MEMBER BROWN: So that I just wanted to
5 confirm as to what, what we have. Okay, thank you.

6 MEMBER STETKAR: By the way, just because
7 it's a public meeting, and transcripts tend to take
8 on a life of their own, the ACRS cannot require anybody
9 to do anything. We're a body that makes recommendations.

10 CHAIR CHU: Always.

11 MEMBER STETKAR: So don't, please with a
12 public record don't interpret anything as ACRS stating
13 that something should be required.

14 CHAIR CHU: Anything else?

15 MEMBER BROWN: Hopefully I was clear when
16 I made my comment when I said it was just my personal
17 observation.

18 CHAIR CHU: Okay, thank you for your
19 presentation.

20 Now, according to our agenda this is public
21 comment period. I would like to know if there is
22 anybody in the audience would like to give comment?

23 (No response.)

24 CHAIR CHU: If no, I will ask is there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 anybody on the phone line who would like to make a
2 comment.

3 (No response.)

4 CHAIR CHU: No. Okay, thank you.

5 Now, according to our agenda we have, we
6 could have closed session and continue on discussion.

7 I would like to know is there anymore questions that
8 require the meeting to be closed to continue our
9 discussion? Or is everybody satisfied and happy?

10 MEMBER POWERS: That's two very rigorous
11 requirements, being satisfied and happy.

12 (Laughter.)

13 CHAIR CHU: Carolyn.

14 MS. HAASS: This is Carolyn Haass,
15 Northwest Medical Isotopes.

16 When Steve and Mike were talking about the
17 criticality potential conditions in the RAIs, we have
18 received those draft RAIs. And we have already responded
19 to the draft RAIs. And we have provided them, we
20 actually put them even in your Dropbox area.
21 And I have the copy for Document Control today.

22 So, I just wanted to say that, you know,
23 we're supporting the NRC staff as quickly as we can
24 so that the SER can be finalized on October 6th.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR CHU: Okay.

2 MEMBER STETKAR: Since you brought it up,
3 you are planning -- or I'll just ask you, are you
4 planning a Rev. 4 of the PSA -- no changes for the PSAR?

5 MS. HAASS: No changes. My understanding
6 is we just want to -- that's why I provided you the
7 letter, because the three of them, there's also a second
8 letter in there that talks about how we're going to
9 approach the things that we went over today that didn't
10 include the criticality.

11 MEMBER STETKAR: Thank you.

12 MS. HAASS: Sure.

13 CHAIR CHU: If there are no more comments
14 the meeting is adjourned.

15 (Whereupon, the above-entitled matter went
16 off the record at 10:56 a.m.)

17

18

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

U.S. Nuclear Regulatory Commission ACRS Subcommittee Review



Public Session – Revisions/Changes to Construction Permit Application

September 21, 2017

Chapter 2 – Transient Population

Total Project Transient Population


Year	Distance Band (km)					Total 0 – 8
	0 – 1	1 – 2	2 – 4	4 – 6	6 – 8	
2010	94	207	1,807	6,633	12,452	21,193
2014	100	395	1,912	7,033	13,207	22,647
2015	101	397	1,944	7,140	13,406	22,988
2019	107	486	2,060	7,566	14,210	24,429
2020	117	494	2,091	7,680	14,424	24,798
2045	341	657	2,562	9,426	17,669	30,447
2050	391	714	2,755	10,125	18,995	32,732

^a Includes Fr. Tolton Catholic High School and the Central Regional Conservation Office starting in 2013.

^b Includes Discovery Office Park starting in 2016.

^c Includes employment growth at Discovery Ridge Research Park starting 2020.

Calendar Year 2020



Location Map




Transient Population Distribution - 2020
Population estimates are labeled in the distance directional segments



- Proposed Location
- 1 km from site
- 2 km from site
- 4 km from site
- 6 km from site
- 8 km from site
- Directional Sectors
- Incorporated Area

Calendar Year 2050



Location Map



Transient Population Distribution - 2050
Population estimates are labeled in the distance directional segments



- Proposed Location
- 1 km from site
- 2 km from site
- 4 km from site
- 6 km from site
- 8 km from site
- Directional Sectors
- Incorporated Area

Chapter 2 – Nearby Industrial, Transportation and Military Facilities

Industrial Facilities

- Analytical Bio Chemistry Laboratories, Inc.
- Radil Discovery Ridge
- Gates Power Transmissions Materials Center
- MU South Farm
- MU Woman’s and Children’s Hospital
- Ryder Transportation
- Truegreen
- Schwan’s Home Service
- Petro Mart #44

Pipelines

- Southern Star Central Gas – Natural Gas Transmission Pipeline
- Magellan Pipeline Company – Non-HLV product Hazardous Pipeline
- Magellan Pipeline Company – Liquid Hazardous Pipeline
- Ameren Natural Gas – Transmission Pipeline #1
- Ameren Natural Gas – Transmission Pipeline #2

Fuel Storage Facilities

- Magellan Pipeline Company – Breakout Tank

Transportation Routes/Facilities

Heliports

- University of Missouri heliport
- Boone Hospital Center heliport

Land

- U.S. Highway 63
- U.S. Interstate 70
- State Route 163
- State Route 740
- State Route 763
- Waterways – None
- Railroads – COLT Transload

Military Bases

- *None*

Mining and Quarrying Operations

- *None*

Chapter 2 – Airports/Heliports

Three airports and two helicopter ports located within 10 mi of RPF

➤ Airports

- Columbia Regional Airport (COU) (public) located ~6.5 mi south of RPF
- Cedar Creek Airport (private) located ~6.6 mi northeast of RPF
- Sugar Branch Airport (private) located ~9.7 mi northwest of RPF

➤ Nearest airport to RPF is COU

- Commercial and privately owned aircraft
- Situated on approximately 1,314 acres and is owned and operated by City of Columbia
- January through December 2016 → 21,894 (22,439, including overflights) aircraft operations
 - 67.6 percent general aviation
 - 17.7 percent air taxi
 - 9.3 percent military
 - 4.8 percent air carrier
- City of Columbia has an annual airshow on Memorial weekend, activity included in COU annual flights per year

200 D² Limits

Airport	Distance km (mi)	Flights per year	200 d ² limits ^a
Columbia Regional Airport	10.4 (6.5 mi)	21,894	21,632
Cedar Creek	10.6 (6.6 mi)	730	22,472
Sugar Branch	15.6 (9.7 mi)	365	48,672

^a d is the distance in kilometers from the airport to the RPF site (200 × distance squared).

RPF = radioisotope production facility.

Chapter 2 – Airports/Heliports (con't)

➤ Heliports

- Two helicopter ports are located within 10 mi of RPF and support hospital operations
- Calendar year 2016 (January through December) → 654 flights annually
 - University of Missouri Hospital and Clinics located 3.7 mi northwest – 308 flights (Jones, 2017)
 - Boone Hospital Center heliport located 3.9 mi northwest – 346 flights (Eidson, 2017)
- Calculated crash impact frequency from heliport is less than NUREG-0800 requirements of being within an order of magnitude of 10^{-7} per year

- Summary → General aviation crash will be evaluated as part of integrated safety analysis (ISA) external event analysis and included in OL application

Crash Impact Probabilities for Airports and Heliports

	Airport operations	Overflights	Total
General Aviation	1.78E-07	6.77E-07	8.55E-07
Commercial Air Carrier	1.61E-11	6.27E-09	6.29E-09
Air Taxis	3.27E-11	1.30E-08	1.30E-08
Military Large	1.66E-08	3.12E-09	1.97E-08
Military Small	0.00E+00	2.82E-08	2.82E-08
Helicopters	–	9.70E-07	9.70E-07
Total	–	–	1.89E-06

Chapter 2 – Pipelines

- Three natural gas transmission pipelines within 5 mi of RPF
 - Southern Star Central Gas Pipeline, Inc. located ~1 mi from RPF
 - Ameren natural gas transmission pipeline #1 located ~0.40 mi from RPF
 - Ameren natural gas transmission pipeline #2 located ~3.75 mi from RPF
- Transmission pipelines are made of steel and generally operate at pressures ranging from 500 lb/in.² to 1,400 lb/in.² gauge
- Pipelines can measure anywhere from 6 in. to 48 in. in diameter (ANL/EVS/TM/08-5, *Natural Gas Pipeline Technology Overview*)
- Each natural gas pipeline was modeled as a complete break with a constant source of natural gas available to break
- An analysis was performed using ALOHA model
- Results: Due to concentration of any gases listed above are below LEL at RPF → therefore, a delayed flammable vapor cloud ignition cannot occur and there will be no explosive overpressure

Chapter 2 – Highways

- Releases from a truck on U.S. Highway 63 were analyzed using a probabilistic analysis
- Accident data were taken from NUREG/CR-6624 and FEMA (1989)
- Accident frequency used was 2×10^{-6} accidents per truck mile, where 20 percent of accidents result in a spill
- When a spill occurs, 20 percent of spills are between 10 and 30 percent of contents and 20 percent of spills are complete release

Flammable Vapor Cloud Explosion Analysis for Highway 63

Hazardous material	Quantity		Acceptable distance (LEL)		Probability ^a
	kg	lb	km	mi	
Ammonia	22,680	50,000	0.93	0.58	2.2×10^{-7}
Diesel	22,680	50,000	0.35	0.22	-
Gasoline	22,680	50,000	0.35	0.22	-
Glycol ether PM	22,680	50,000	0.06	0.04	-
Hydrogen	1,497	3,300	1.24	0.77	3.0×10^{-7}
JP-4 aviation fuel	22,680	50,000	0.35	0.22	-
Methyl ethyl ketone	22,680	50,000	0.19	0.12	-
Petroleum naphtha	22,680	50,000	0.35	0.22	-
Propane	22,680	50,000	1.37	0.85	$>1 \times 10^{-6}$
Toluene (32-8413)	22,680	50,000	0.13	0.08	-

Source: EDF-3124-0016, *Analysis of Potential Accidents at Facilities*, Rev. 2, Portage, Inc., Idaho Falls, Idaho, 2017.

^a Probability only calculated for chemicals with acceptable distances greater than 0.4 km (0.25 mi).

LEL = lower explosion limit.

Chapter 2 – Nearby Facilities

- Review of chemicals at nearby facilities did not contain any toxic materials that would be greater than those located on U.S. Highway 63
- Toxic chemicals released from a truck considered in analysis were ammonia, chlorine, and sulfur dioxide which were all greater than distance from U.S. Highway 63 to RPF of 0.25 mi
 - Distance to IDHL for an ammonia release on U.S. Highway 63 is 6 mi
 - Distance to IDHL for a chlorine release on U.S. Highway 63 is 1.1 mi
 - Distance to IDHL for a sulfur dioxide release on U.S. Highway 63 is 1.9 mi
- All releases from a truck on U.S. Highway 63 were analyzed using a probabilistic analysis
- Assumptions used in all analysis include:
 - Accident frequency $\rightarrow 2 \times 10^{-6}$ accidents per truck mi where 20 percent of accidents result in a spill
 - When a spill occurs \rightarrow 20 percent of spills are between 10 and 30 percent of contents and 20 percent of spills are complete release
 - Accident data were taken from NUREG/CR-6624 and FEMA (1989)
- Annual probability (i.e., when multiplied by only four trucks annually) is greater than 1×10^{-6} per year; therefore, this event will be evaluated as part of ISA external event analysis and included in OL Application

Chapter 2 – Fires in Adjacent Facilities

- Three natural gas transmission pipelines within 5 mi of RPF
 - Southern Star Natural Gas Transmission Pipeline
 - Ameren Natural Gas Transmission Pipeline #1
 - Ameren Natural Gas Transmission Pipeline #1
- Transmission pipelines are made of steel and generally operate at pressures ranging from 500 lb/in.² to 1,400 lb/in.² gauge
- Jet fire analysis that was performed using ALOHA model (EDF-3124-0016)
- Pipeline was modeled as a complete break, with a constant source of natural gas available to break
 - Pipeline jet fire is not considered a threat to RPF for any transmission pipeline

Chapter 2 – Geotechnical Investigation

- A site-specific geotechnical investigation of RPF site will be conducted to identify specific soil characteristics
 - If highly plastic clays are identified at site, design will include excavation of clays and then backfill with structural fill
 - RPF structural design will be completed during RPF final design and will be included as part of OL Application
- If sinkholes are identified, RPF final design would incorporate one of following alternatives:
 - Excavate site both vertically and horizontally to remove that potential and backfill with structural fill
 - Install piers to bedrock to support substructure

Chapter 2 – Other

- Maximum probable precipitation in a one-hour period is 3.14 in/hour
- Seasonal and annual frequency of historical tornadoes (1954 – 2016) updated
- Seasonal and annual thunderstorm wind events (1955 – 2016) updated
- Lighting events (1998 – 2016) updated
- Seasonal and annual hail events (1958 – 2016) updated
- Winter weather events (1996 – 2016) updated
- Recorded Missouri earthquake history updated
- Vibratory ground motion
 - NWMI has committed to using NRC Regulatory Guide 1.60, *Design Response Spectra for Seismic Design of Nuclear Power Plants*, for final RPF seismic design
 - Regulatory Guide 1.60 spectrum eliminates need for soil classifications used as part of IBC methodology
 - Estimated maximum ground acceleration at RPF site will meet Regulatory Guide 1.60 free-field response spectrum anchored to a peak ground acceleration of 0.20 g

Chapter 3 – Design Evolution

- RPF design is being completed in stages
- RPF preliminary design complete and final design initiated
- Final design is needed to develop OL Application and construction drawings
- Construction documentation consists of drawings and specifications
 - Describe quality, configuration, size, and relationship of all components of RPF
 - Serve as a basis for obtaining bids from contractors
- All supporting documentation will be finalized, which includes but is not limited to:
 - Final hazards analysis and associated qualitative risk assessment
 - Integrated safety analysis
 - Criticality safety evaluations and associated calculations
 - Criticality safety program
 - Criticality accident alarm system/dose analyses
 - Shielding analysis
 - Fire hazards analysis
 - Radiation protection program
 - Waste management program
 - Material control and accountability program
 - Natural phenomena hazards/external events analysis
 - Emergency preparedness program
 - Quality assurance program
 - Safeguards and security program

Chapter 3 – Design Evolution (con't)

- Primary areas of evaluation during final RPF design will include design bases for all SSCs that could be affected by predicted hydrological conditions at site
 - Structures resulting from force or submergence of flooding
 - Systems resulting from I&C, electrical or mechanical malfunction due to water
 - Equipment (e.g., fans, motors, and valves) resulting from degradation of electromechanical function due to water
- NWMI will provide reasonable assurance that SSCs would continue to perform required safety functions under credible water damage conditions
- Design will use applicable local building codes to help ensure that water damage to SSCs at RPF site would not:
 - Cause unsafe RPF operation
 - Prevent RPF safe shutdown
 - Cause or allow uncontrolled release of radioactive material

Chapter 3 – Site Grading

- NWMI's primary goal of proper grading design is to ensure that stormwater flows off of RPF site in a safe, efficient manner (i.e., grading is performed to ensure proper drainage)
- Primary design parameter of all grading designs is to maintain positive drainage
 - e.g., water always has an ability to flow away from site
- Grading of site will serve three basic purposes:
 - Re-form land surface to make it compatible with intended land use
 - Establish and controls new drainage patterns
 - Help define character and aesthetics
- Drainage analysis will serve as basis for design of all proposed drainage structures and will influence layout of site plan
 - Analysis will set basic parameters for grading design
 - NWMI will consider both runoff that starts on site and runoff that flows onto site from off-site
- NWMI will verify all features of site that could lead to flooding or other water-induced damage at site in drainage analysis
 - Information will cover possible hydrologic events, their causes, historic and predicted frequencies, and potential consequences to RPF
 - Water table will be located and potential for radioactive contamination of ground/surface waters will be considered

Chapter 3 – Seismic

- Probabilistic seismic hazard analysis (PSHA) was performed by NRC staff for University of Missouri Research Reactor (MURR) site to assess seismic safety of reactor facility using present-day methodologies
- Seismic hazard curves were estimated at control point (top of weathered rock layer)
 - 10^{-4} and 10^{-5} uniform hazard response spectra were also calculated using results of confirmatory PSHA and site response analyses and ground motion response spectra (GMRS) was computed using Regulatory Guide 1.208
- NWMI compared seismic GMRS with peak ground acceleration of 0.2 g
 - Used in Callaway Nuclear Plant and MURR
- GMRS is enveloped by seismic response spectrum with peak ground acceleration of 0.2 g up to about 16 hertz (Hz)
- GMRS exceeds seismic response spectrum above this frequency
- Based on EPRI guidance, ground motions at higher than approximately 10 Hz frequency are not damaging to SSCs of a nuclear reactor, except functional performance of components sensitive to vibration (e.g., electrical relays)
- If electrical relays are fail-safe on excess vibration or loss of power, safety function of such relays will not be compromised

Chapter 3 – Seismic (con't)

- NWMI will also evaluate dynamic analyses of RPF structural components
- Static analysis will be completed during final design by using:
 - Combination of static load computations to ensure that SSCs remain in place and intact
 - Combination of existing shake table test data and existing earthquake experience will be used to ensure that equipment functions following an earthquake
- Analysis of safety-related structures may be either completed by:
 - Linear-elastic response spectra method performed in accordance with ASCE 4, *Seismic Design of Safety-Related Nuclear Structures*, Section 3.2.3.1, and ASCE 43, *Seismic Design Criteria for Structures, Systems, and Components in Nuclear Facilities*, Section 3.2.2
 - Linear-elastic time history method performed in accordance with ASCE 4, Section 3.2.2, and ASCE 43, Section 3.2.2
- NWMI will also define specific acceptable qualification methods in procurement packages to demonstrate seismic qualifications
- Seismic qualification of IROFS will include:
 - Calculations/verification that main structural components of SSC can withstand seismic loads derived from in-structure floor response spectra at damping value derived from Regulatory Guide 1.61
 - Reference to available shake table testing that demonstrates seismic capacity of SSC or of multiple similar items
 - Demonstration of seismic capacity through performance of type of SSC in actual earthquakes

Chapter 3 – Seismic (con't)

- Per NRC Regulatory Guide 1.100, Seismic Qualification of Electrical and Active Mechanical Equipment and Functional Qualification of Active Mechanical Equipment for Nuclear Power Plants
 - Active mechanical equipment relied on for or important to nuclear safety will be required to be seismically qualified in accordance with Regulatory Guide 1.100
 - Active electrical equipment important to or relied on for nuclear safety will be required to be seismically qualified in accordance with IEEE 344, IEEE Standard for Seismic Qualification of Equipment for Nuclear Power Generating Stations
- Subsystems and equipment not relied on for nuclear safety but designated as a component of a seismic system per International Building Code (IBC) 2012, Chapter 17, will be required
 - Existing databases of past shake table tests will be used (e.g., Office of Statewide Health Planning and Development database provided by state of California)
 - Tests will be done based on ICC-ES AC156, Acceptance Criteria for Seismic Certification by Shake-Table Testing of Nonstructural Components, spectrum
- Seismic design will also include a check to ensure that pounding or sway impact will not occur between adjacent fixtures (e.g., rattle space)

Chapter 3 – Tornado-Generated Missile Impact Effects

- Missile is assumed rigid for maximum penetration
- Expected speed of tornado missiles is larger than expected speed of any hurricane-generated missiles at same annual frequency of exceedance
 - NUREG/CR-7005, *Technical Basis for Regulatory Guidance on Design-Basis Hurricane Wind Speeds for Nuclear Power Plants*
- Tornado-generated missile impact effects are based on standard design missile spectrum from NRC Regulatory Guide 1.76
 - Wind velocities in excess of 75 mi/hr are capable of generating missiles from objects lying within path of tornado wind and from debris of nearby damaged structures
- Recommended RPF roof and wall system design criteria are also taken from DOE-STD-1020, Table 3-4

Design-Basis Tornado Missile Spectrum

Description	Weight	Dimensions	Horizontal velocity	Vertical velocity
Automobile	4,000 lb	16.4 ft × 6.6 ft × 4.3 ft	92 mi/hr	62 mi/hr
Pipe	287 lb	6.625 in. diameter × 15 ft long	92 mi/hr	62 mi/hr
Steel Sphere	0.147 lb	1.0 in. diameter	18 mi/hr	12 mi/hr

Source: NRC Regulatory Guide 1.76, *Design-Basis Tornado and Tornado Missiles for Nuclear Power Plants*, U.S. Nuclear Regulatory Commission, Washington, D.C., March 2007.

Chapter 5 – Coolant Systems

- Weekly Irradiated Target Heat Generation rate added
- Thermal load is characterized by radial heat transfer in a vessel and uranium concentration of solutions held within vessels throughout RFP
- Number of targets to be irradiated will be optimized in Operating License (OL) Application

Chapter 6 – Criticality Accident Alarm System

- RPF criticality accident alarm system (CAAS) will meet Title 10 CFR 70.24, *Criticality Accident Requirements*
- NWMI commits to current endorsed version of ANSI/ANS-8.3, *Critically Accident Alarm System*, with modifications as noted in Regulatory Guide 3.71, *Nuclear Criticality Safety Standards for Fuels and Materials Facilities*
- CAAS evaluation will be completed during RPF final design and provided in OL Application
- CAAS coverage will be in all areas in which greater than 10 CFR 70.24 mass limits of SNM are handled, used, or stored, and in all shielding areas of RPF
 - Controls will be established to preclude such SNM from areas where coverage is not provided
 - Each monitored area will be covered by two criticality detectors
- CAAS monitoring system will be capable of detecting a nuclear criticality that produces an absorbed dose in soft tissue of 20 rad of combined neutron and gamma radiation at an unshielded distance of 2 meters (m) from material within 1 minute (min)

Chapter 6 – Criticality Accident Alarm System (con't)

- NWMI will establish a CAAS appropriate to RPF for type of radiation detected or shielding and magnitude of minimum accident of concern
 - Will consider potential damages from anticipated adverse events such as a fire, explosion, and corrosive atmosphere
 - Will be resistant to RPF design-basis earthquake
- Operations will be rendered safe, by shutdown and quarantine, if necessary, in any area where CAAS coverage has been lost and not restored within a specified number of hours
- Emergency power will be provided to CAAS by uninterruptable power supply system

Chapter 6 – Criticality Safety

- Prior to end of construction and with submittal of OL Application, NWMI will ensure that all processes containing SNM within RPF are evaluated to be subcritical under all normal and credible abnormal conditions
- NWMI will use nuclear criticality safety (NCS) controls for mass, geometry, moderation, volume, and interaction
 - NWMI commits to specific criteria for each on parameters under NCS control at RPF
- NWMI commits to evaluate controlled parameters at associated safety limits and to evaluate parameters that are not controlled at most reactive credible values
- NWMI acknowledges that use of a single NCS control to maintain values of two or more controlled parameters constitutes only one component necessary to meet double-contingency principle
- Order of preference for NCS controls will be:
 - Passive engineered
 - Active engineered
 - Enhanced administrative
 - Simple administrative controls

Chapter 6 – Criticality Safety (con't)

- NWMI will make every effort to use passive engineered controls, in particular, passive engineered geometry control
- If RPF operations rely on two or more controls on a single parameter, NWMI commits to using diverse over-redundant means of control
- Following general criteria will be used in establishing controls on parameters:
 - When a single-parameter limit is used, all other parameters will be evaluated at optimum or most reactive credible values → In determining single-parameter limits, specifying a particular physicochemical form and isotopic composition is permissible
 - When process variables can affect normal or most reactive credible values of parameters, controls to maintain parameters within specified ranges will be established
 - When measurement of a parameter is needed, instrumentation subject to facility management measures will be used
 - When criticality control is based on measuring a single parameter, independent means of measurement will be used
 - Safety limits on controlled parameters will be established, taking any tolerances and uncertainty into account

Chapter 6 – Update of USL and Criticality Safety Evaluations

- NWMI will ensure that all processes containing SNM under normal and credible abnormal conditions will meet revised USL of 0.9240
- Criticality safety evaluations (CSE) will be updated during RPF final design
- NCS operating limits will be established based on analyses assuming optimum or most reactive credible values of parameters unless specified controls are implemented to limit parameters to a range of values
 - e.g., most reactive conditions physically possible or bounding values limited by regulatory requirements
- Specific controls and management measures necessary to enforce NCS safety limits and/or operating limits will be specified in each CSE

Chapter 7 – Instrumentation and Control Systems

- FPC system will be a DCS that functions independently
- IROFS/ESF safety functions will be activated via hardwire (analog) interlocks
- Process control system includes interlocks (both hardwired [ESF] and computer logic) to implement an automatic action on a parameter approaching or being outside its setting
 - Interlocks defined as specific set of conditions or parameters that need to be met for an activity to occur
 - Example of an interlock is shutting down a pump on a tank high-level alarm signal or switching to a spare unit or process train based on a change in parameters (and corresponding alarm)
- RPF will also implement a permissive philosophy that allows HMI operations to be enabled once control room has confirmed prerequisites conditions have been completed
 - Permissives differ from interlocks in that permissives require manual approval via a switch (or similar) that must be satisfied for an activity to occur
 - Interlocks are engineered features, and permissives are administrative features
- Permissive and interlocks will be described in more detail in OL Application





Figure 7-1 Facility Instrumentation and Control System Configuration

Chapter 13 – Uranium Metal Fires

- Targets are fabricated from uranium (U) metal receipts (Y-12) during initial operation
 - U metal receipts are significantly reduced once target inventories have been developed to support reactor operations, and majority of U input to target fabrication can be acquired from recycled U
- NWMI's evaluated packing and shipping of U metal in compliance with ES-3100 container requirements and planned handling at RPF
 - NWMI-2015-SAFETY-007, *Quantitative Risk Analysis of Facility Fires and Explosions Leading to Uncontrolled Release of Fissile Material, High- and Low-Dose Radionuclides*
- NWMI will evaluate nonstandard payloads and configurations and failures of hardware/control at RPF as part of OL Application
 - Evaluate worker safety/exposure impact from potential U metal fires
 - Controls will be elevated to IROFS controls to meet 10 CFR 70.61, "Performance Requirements," for U exposure
- Evaluation in NWMI-2015-SAFETY-007 is based on an existing analysis in SNF-6192-FP, *Uranium Pyrophorocity Phenomena and Prediction*, of ignition test observations for U hydride powder with a characteristic particle diameter of 1.85 micron (μ)
 - SNF-6192-FP analysis concluded that a particle bed depth of 7 millimeters (mm) was required for ignition at ambient temperature, which was consistent with test observations

Chapter 13 – Uranium Metal Fires (con't)

- NWMI's current evaluation indicates that significant particle bed depths (greater than 7 mm) are required to observe ignition at ambient temperature
 - This bed depth to accumulate on a metal shape piece during shipping/storage is considered highly unlikely
- U metal handling activities will be reevaluated during RPF final design and provided in OL Application
- NWMI plans to implement appropriate controls in hood/glovebox to extinguish a U metal fire (e.g. magnesium oxide sand) per DOE-HDBK-1081-2014, Primer on Spontaneous Heating and Pyrophoricity
- Examples of extinguishing a U metal fire in a hood/glovebox include:
 - U metal fires will not be approached without protective clothing and respirators unless fire is enclosed in a glovebox → Most effective agent is magnesium oxide sand
 - Flood hood/glovebox with argon is effective extinguishing agent (if O₂ content is maintained at 4 percent or less) → Argon may be used effectively to cool burning U metal prior to use of magnesium oxide sand
 - Water is generally acceptable for use as an extinguishing agent for fires involving U metal unless criticality safety considerations preclude introduction of moderators



Calculated Ignition Temperature for Small Deposits of Fine Uranium Metal

Questions?



**Advisory Committee on Reactor Safeguards
Subcommittee Meeting
Northwest Medical Isotopes Construction Permit
Application**

Safety Evaluation Report Status

U.S. Nuclear Regulatory Commission Staff

September 21, 2017



Introductions

- **Michael Balazik** - Project Manager, Research and Test Reactors Licensing Branch (PRLB), Division of Policy and Rulemaking (DPR), Office of Nuclear Reactor Regulation (NRR)
- **Steve Lynch** - Acting Chief, PRLB, DPR, NRR
- **David Tiktinsky** - Senior Project Manager, Fuel Manufacturing Branch, Division of Fuel Cycle Safety, Safeguards, and Environmental Review, Office on Nuclear Material Safety and Safeguards

Discussion Topics

- Provide an update on the status of the Safety Evaluation Report (SER) for the Northwest Medical Isotopes (NWMI) construction permit application
- Discuss SER Appendix A
- Discuss the plan for the Advisory Committee on Reactor Safeguards (ACRS) Full Committee meeting

SER Status

- ACRS provided the SER updated to Revision (Rev.) 2 of the NWMI Preliminary Safety Analysis Report (PSAR)
 - PSAR Rev. 1 incorporated responses to requests for additional information (RAIs)
 - PSAR Rev. 2 incorporated feedback during ACRS meetings on SER Chapters 2, 3, 6, 7, 8, and 13

SER Status (continued)

- Section 2.4.2, Nearby Industrial, Transportation, and Military Facilities
 - SER evaluates the additional flight information on the heliports and airport operations.
- Section 13.4.1, Accident Analysis Methodology and Preliminary Hazards Analysis
 - The staff acknowledges that there will be differences between the preliminary design, as reviewed, and the final design. During the review of NWMI's FSAR, the staff will confirm additional analyses and details of the ISA process and specific technical topics, such as ISA team qualification, the process for screening credible accident sequences, administrative controls, and supporting management measures.

SER Status (continued)

- NWMI provided PSAR Rev. 3 to ACRS to support today's meeting
 - NWMI PSAR Rev. 3 in ADAMS on September 14th (Accession No. ML17257A019)
 - Staff does not anticipate major changes to PSAR Rev. 3
 - Staff will update the SER to reflect PSAR Rev. 3 before the ACRS Full Committee meeting in November 2017

SER Status (continued)

- Final draft SER to be provided to ACRS by October 6th
- RAI responses on aspects of criticality control based on progress in design maturity could remove need for proposed licensing conditions

SER Appendix A

- Appendix A lists proposed license conditions and NWMI commitments regarding the contents of its operating license application and NWMI research and development activities
 - Will be used to inform inspections and verify design completion for the operating license
 - Demonstrates shared understanding between staff and NWMI on status of design and sets expectations for future oversight and licensing activities

SER Appendix A (continued)

- SER Appendix A includes:
 - Commitments identified from ACRS meeting(s)
 - Commitments identified in response to RAIs
 - Fulfilled regulatory commitments identified in response to RAIs
 - Ongoing research and development
 - Proposed construction permit conditions

Commitments Identified from ACRS Meeting(s)

- These commitments will be submitted by NWMI and documented in the SER
 - 1) NWMI will provide an evaluation of the effects of high frequency spectral accelerations (i.e., > 10 hertz) on high-frequency sensitive structures, systems, and components during seismic events (e.g., electrical relays, instrumentation) in its final safety analysis report (FSAR).
 - 2) NWMI will provide details on the final grading of site, ensuring that storm water from localized downpours will be directed around and away from the Radioisotope Production Facility (RPF), in its FSAR.

Commitments Identified from ACRS Meeting(s) (continued)

- 3) NWMI will provide a final hazards analysis for its facility in its FSAR. This final hazard analysis will re-examine those accident sequences that were screened out of the preliminary hazards analysis, ensuring that the final hazard analysis properly accounts for the accident sequences relevant to the final design of the facility.
- 4) NWMI will provide an evaluation of the potential impacts on the RPF of a uranium fire in the target manufacturing facility licensed under 10 CFR Part 70 on the RPF as part of its FSAR.

Commitments Identified from ACRS Meeting(s) (continued)

- 5) NWMI will provide an evaluation of the possible effects of derangement of electrical equipment and resulting possible unexpected effects of interaction between otherwise unrelated, independent, and separate circuits, as part of its FSAR.

Commitments Identified in Response to RAIs

- All RAI responses that commit to providing information in the operating license application are listed in SER Appendix A.2 (78 items).
- Staff concludes that deferring review of this information until operating license submission would not significantly impact construction.
- Staff considers the commitments necessary for NWMI to demonstrate understanding of inputs needed for the final design.

Commitments Identified in Response to RAIs (continued)

- For example:
 - RAI 2.5-9 Response: Additional geotechnical analysis will be conducted on the liquefaction potential of the soils on site.
 - RAI 2.5-6b Response: Additional information on the seismic requirements and evaluations of the RPF and associated IROFS will be provided in the FSAR as part of the operating license application.
- Staff will verify completion during the operating license review

Fulfilled Regulatory Commitments Identified in Response to RAIs

- Commitments that are satisfied are reflected in updates to the PSAR Rev.2
- Sixty-three items listed in SER Appendix A.3
- For example:
 - RAI 3.5-3a Response: NWMI has revised its Quality Assurance (QA) Plan to clarify the difference between QL-1 and QL-2. PSAR Section 3.5.1.3 was modified to reflect the changes in the quality level definitions.
 - RAI 12A-2b Response: The listing of the Missouri Office of Emergency Coordination as the primary contact for radiological emergencies is in error. The Missouri Office of Emergency Coordination will be replaced with the Missouri State Emergency Management Agency in Section A3.1.2 of PSAR Chapter 12.0, Appendix A.

Ongoing Research and Development

- As described in 10 CFR 50.34(a)(8)
- Described in PSAR and responses to RAIs
- Staff will verify research and development is completed before the end of construction through inspection and the operating license review
- Four items listed in SER Appendix A.5
 - 1) NWMI will be performing testing to validate the acceptable operating conditions for material and target solution compatibility at MURR and the DOE national laboratories. The testing will include specific work involving irradiation in a corrosive environment to examine the effects on the properties of selected raw materials and welded samples in an as-received and as-fabricated state.

Ongoing Research and Development (continued)

- 2) Tests are being performed to confirm whether a pressure relief system is feasible for an ion exchange column operating at a specified pressure and the uranium separation process approach will continue, or if a design change to the system or implementation of additional controls/process parameters to reduce the likelihood of a reaction or change of separation technology is required.
- 3) Laboratory resin tests to determine the interactions between solutions and resin as a function of temperature. The results will help define necessary hazard and accident controls.

Ongoing Research and Development (continued)

- 4) Tests are being performed to evaluate the release of the resin extractant from the ion exchange column media during operation. Release of this extractant poses both a thermal/radiolytic decomposition concern (e.g., in concentrators) and a potential criticality concern if the extractant were to collect as a separate phase in a non-geometrically favorable vessel.

Proposed Construction Permit Conditions

- Purpose of conditions
 - Since the design of structures, systems, and components could significantly impact construction of safety-related components, proposed conditions would require periodic updates on certain design elements to enable staff to confirm their adequacy during construction inspection
 - Conditions address areas of criticality control that require additional maturity in the design
 - Additional information provided by NWMI could allow the staff to remove these conditions

Proposed Construction Permit Conditions (continued)

- Three licensing conditions proposed in Appendix A.1
 - 1) Prior to the completion of construction, NWMI shall submit periodic reports to the NRC, at intervals not to exceed 6 months from the date of the construction permit. As described in the proposed permit conditions in Appendix A of this SER, these reports shall provide the criticality safety evaluations and any changes to those evaluations for processes involving SNM.

Proposed Construction Permit Conditions (continued)

- 2) Prior to the completion of construction, NWMI shall ensure that processes are evaluated to be subcritical under all normal and credible abnormal conditions. This determination can be done for each area as described in Section 6.3.1.1 of the PSAR as it is completed, and shall be done consistent with the Upper Subcritical Limit.
- 3) Prior to the completion of construction, NWMI shall submit periodic reports to the NRC, at intervals not to exceed 6 months from the date of the construction permit. As described in the proposed permit conditions in Appendix A of this SER, these reports shall provide the technical basis for the design of the criticality accident alarm system (CAAS). Prior to the completion of construction, the reports shall demonstrate detector coverage as defined in the requirements of 10 CFR 70.24.

Plan for ACRS Full Committee Meeting

- Internal reviews to finalize the SER are ongoing
- Draft final SER will be publicly available prior to ACRS Full Committee meeting
- ACRS Full Committee meeting scheduled for November 2, 2017
- Staff will present on:
 - Findings from the review that support issuance of a construction permit
 - Update on the status proposed of licensing conditions

Plan for ACRS Full Committee Meeting (continued)

- SER will be finalized and made publicly available to support the mandatory hearing following the ACRS Full Committee meeting.
- Mandatory hearing could/to be held in late January 2018.