



U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

DCS-NRC-000468
17 October 2017

Subject: Docket Number 070-03098
CB&I AREVA MOX Services
Mixed Oxide Fuel Fabrication Facility
Closure of Interim Report Notification: Flanders

Reference: Letter from D. Del Vecchio to U.S. NRC Document Control Desk, DCS-NRC-000451, "Updated Interim Report Notification: Flanders," dated 28 February 2017

CB&I AREVA MOX Services, LLC (MOX Services), submitted an updated interim report (Reference) regarding non-conformances identified at the Mixed Oxide Fuel Fabrication Facility. The non-conformances pertained to welds located on the internal cross bracing of high depressurization exhaust system final filter housings. Evaluation of the conditions identified in the updated interim report has been completed. These conditions have been determined to not be reportable in accordance with 10 CFR Part 21.

If you have any questions, please feel free to contact me at (803) 442-6485 or our Licensing and Nuclear Safety Manager, Dealis Gwyn, at (803) 819-2780.

Sincerely,

A handwritten signature in black ink, appearing to read "David Del Vecchio", written over a horizontal line.

David Del Vecchio
President and Project Manager

Document Control Desk
U.S. Nuclear Regulatory Commission
DCS-NRC-000468
17 October 2017
Page 2 of 2

cc:

Scott Cannon, NNSA/SRS
Jason Eargle, USNRC/SRS
Michael Ernstes, USNRC/RII
David Faubert, NNSA/SRS
William Gloersen, USNRC/RII
Mark Gober, MOX Services
Dealys Gwyn, MOX Services
Catherine Haney, USNRC/RII
Chip Hicks, MOX Services
Dennis Ivey, MOX Services
Charles Nickell, MOX Services
Gilles Rousseau, MOX Services
Kathryn Sutton, ML&B
David Tiktinsky, USNRC/HQ
Paul Whittingham, MOX Services
Bryan Wilkes, MOX Services
Lauren Wylie, MOX Services
Doug Yates, MOX Services
MOX Project Management Office Document Control Administrator (moxpmodca@srs.gov)
EDMS: Corresp\Outgoing\NRC\2017 NRC