

November 17, 2017

10CFR21

VIA ELECTRONIC TRANSMISSION:
Nuclear Regulatory Commission
Operations Center
hoo.hoc@nrc.gov

Subject: Retraction of 10CFR21 Interim Report – Review of design changes to the commercially purchased Schneider I/A pressure transmitter

On October 27, 2017 Ultra Electronics, NSPI submitted an interim 10CFR Part 21 report concerning the discovery of a lapse in evaluation of design/document changes made by the manufacturer of product purchased commercial grade. An interim report was issued as a notification that the analysis of this condition had not been completed. An analysis was subsequently completed and it was determined that the design/document changes made by the manufacturer did not affect the seismic qualification of the product and therefore is not a defect reportable under 10CFR Part 21.

Based on the results of the evaluation, the interim report submitted by Ultra Electronics, NSPI dated October 27,2017 is retracted.

Regards

Adam Gaither
Vice President, Engineering
Ultra Electronics, NSPI