

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, November 2, 2017

Work Order No.: NRC-3353

Pages 1-158

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

648TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

OPEN SESSION

+ + + + +

THURSDAY

NOVEMBER 2, 2017

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the  
 Nuclear Regulatory Commission, Two White Flint  
 North, Room T2B1, 11545 Rockville Pike, at 8:30  
 a.m., Dennis C. Bley, Chairman, presiding.

COMMITTEE MEMBERS:

- DENNIS C. BLEY, Chairman
- MICHAEL L. CORRADINI, Vice Chairman
- PETER RICCARDELLA, Member-at-Large
- RONALD G. BALLINGER, Member
- CHARLES H. BROWN, JR., Member
- WALTER L. KIRCHNER, Member

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

JOSE MARCH-LEUBA, Member

DANA A. POWERS, Member

HAROLD B. RAY, Member

JOY L. REMPE, Member

JOHN W. STETKAR, Member

MATTHEW W. SUNSERI, Member

DESIGNATED FEDERAL OFFICIAL:

KATHY WEAVER

HOSSEIN NOURBAKHS

1 ALSO PRESENT:

2 ALEXANDER ADAMS, NRR

3 MICHAEL BALAZIK, NRR

4 KEITH COMPTON, RES

5 MICHAEL CORUM, Northwest Medical Isotopes

6 GARY DUNFORD, Northwest Medical Isotopes

7 HOSSEIN ESMAILI, RES

8 TINA GHOSH, RES

9 CAROLYN HAASS, Northwest Medical Isotopes

10 STEVE LYNCH, NRR

11 TYRONE NAQUIN, NMSS

12 MARY JANE ROSS-LEE, NRR

13 PATRICIA SANTIAGO, RES

14 RUTH THOMAS, Public Participant\*

15 ANDREA D. VEIL, Executive Director, ACRS

16

17 \*Present via telephone

18

19

20

21

22

23

24

25

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

T-A-B-L-E O-F C-O-N-T-E-N-T-S

Opening Remarks by the ACRS Chairman

Dennis Bley . . . . . 5

Northwest Medical Isotopes Mo-99 Radioisotope  
Production Facility

Dana Powers . . . . . 7

Mary Jane Ross-Lee, NRR . . . . . 8

Carolyn Haass, NWMI . . . . . 10

Michael Corum, NWMI . . . . . 21

Alexander Adams, NRR . . . . . 33

Michael Balazik, NRR . . . . . 40

Public Comment

Ruth Thomas . . . . . 79

State-of-the Art Consequence Analysis . . . . . 82

Public Comment . . . . . 158

Adjourn . . . . . 158

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIRMAN BLEY: The meeting will now come to order. This is the first day of the 648th meeting of the Advisory Committee on Reactor Safeguards.

During today's meeting the Committee will consider first Northwest Medical Isotopes Moly-99 Radiation Production Facility. Second, preparation of ACRS reports, and third the state-of-the-art reactor consequence analysis, SOARCA for Sequoyah.

The ACRS was established by statute and is governed by the Federal Advisory Committee Act. As such, this meeting is being conducted in accordance with the provisions of FACA. That means that the Committee can only speak through its published letter reports. We hold meetings to gather information to support our deliberations.

Interested parties who wish to provide comments can contact our offices requesting time after the *Federal Register* notice describing the meeting is published. That said, we also set aside 10 minutes for spur-of-the-moment comments from members of the public attending or listening to our meetings. Written comments are also welcome.

Ms. Kathy Weaver is the designated federal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 official for the initial portion of this meeting.

2 Portions of these sessions on Northwest  
3 Medical Isotopes may be closed in order to discuss and  
4 protect information designated as proprietary. If so,  
5 we'll do that at the end of the session.

6 The ACRS section of the U.S. NRC public  
7 web site provides our charter, bylaws, letter reports  
8 and full transcripts of Full and Subcommittee meetings  
9 including the slides presented at the meetings.

10 We have received no written comments or  
11 requests to make oral statements from members of the  
12 public regarding today's sessions.

13 There will be a -- there is a telephone  
14 bridge line. To preclude interruptions of the meeting  
15 the phone will be placed in the listen-in-only mode  
16 during presentations and Committee discussions.

17 Today there is also a web cast. Often the  
18 sound is better there than it is on the line, but you  
19 would not have the opportunity to make comments at the  
20 end unless you're on the phone line. Also, for the  
21 last two days there have been agency-wide problems  
22 with the web cast, so it might drop off on you. If  
23 so, you can come back in on the bridge line.

24 A transcript of portions of the meeting is  
25 being kept and it is requested that the speakers use

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 one of the microphones, identify themselves and speak  
2 with sufficient clarity and volume so that they can be  
3 readily heard for our transcript.

4 As an item of interest today we would like  
5 to announce and congratulate Dr. Steven Schultz,  
6 current consultant and former ACRS member, for being  
7 elected as a fellow of the American Nuclear Society.  
8 Wish Steve were here, but we send our congratulations  
9 to him.

10 At this time I will turn the meeting over  
11 to Dr. Powers for the discussion of the moly-99  
12 facility.

13 MEMBER POWERS: Good morning. I'm Dana  
14 Powers, a very poor substitute for the ever-lovely  
15 Margaret Chu, who is actually the chairman of this  
16 Subcommittee. She alas is basking on the beaches of  
17 Taiwan while the rest of us fever away.

18 We're going to discuss a construction  
19 permit application for Northwest Medical Isotopes for  
20 a radioisotope production facility. All nuclear  
21 facilities of course are unique. This is no  
22 different. It has its own peculiarities.

23 Margaret has proved to be a vicious task  
24 master and we've had some intensive Subcommittee  
25 meetings beginning in June, July, August, September.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 And then she gave us a break in October. So today  
2 we're here to get a summary, a vast amount of  
3 information. So at best we're going to get a synoptic  
4 summary of the facility and construction permit  
5 reviews.

6 We're going to hear both from the  
7 applicant and from the staff on this. I'm sure that  
8 the applicant will devote their time to a description  
9 of how they conceive this nuclear facility, and I will  
10 hope that the staff describes how they organized and  
11 conducted their review of this construction permit  
12 application.

13 Our intention today is to have a non-  
14 proprietary discussion. Should things come up that  
15 are proprietary, somebody will have to signal me; I'm  
16 not good at identifying things that are proprietary,  
17 and we will defer that discussion to the end of the  
18 meeting when we can close the session.

19 Without any additional to do, I'll ask  
20 Mary Jane Ross-Lee to open the discussion on this  
21 particular construction permit application.

22 MS. ROSS-LEE: Thank you, Dr. Powers. As  
23 you mentioned, my name is Mary Jane Ross-Lee. I am  
24 the new deputy director of the new Division of  
25 Licensing Projects in Office of Nuclear Reactor

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Regulation. This is my first week on the job, so I --  
2 though ironically I was a branch chief when the moly  
3 facilities first came about in their licensing process  
4 back many years, so I do have a little bit of a  
5 history in this.

6 Our staff in NRR and in the Office of  
7 Nuclear Materials Safety and Safeguards are pleased to  
8 be here today to brief the ACRS Full Committee on the  
9 staff's review of the construction permit application  
10 for the proposed Northwest Medical Isotopes production  
11 facility. With that being said, this work has been  
12 conducted by a large interagency group. The main  
13 contributors were NRR, NMSS, Office of Nuclear  
14 Security and Incident Response, Office of the General  
15 Counsel and Office of Congressional Affairs.

16 As was mentioned, the staff has conducted  
17 five ACRS Subcommittee meetings on the Northwest  
18 Medical Isotopes construction permit application,  
19 having met with ACRS members each month this summer.  
20 The staff also conducted a technology briefing of the  
21 Full Committee back in May of this year. We  
22 appreciate your time and the priority you have given  
23 to this important project.

24 I don't need to discuss the importance of  
25 having a domestic supplier of this essential

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 radioisotope as I'm sure all members are aware.

2           Your insights on the safe operation, the  
3 design of the nuclear facility and the use of nuclear  
4 materials has been benefitted the staff's review and  
5 better informed our finding supporting the issuance of  
6 a construction permit to Northwest Medical Isotopes.  
7 In addition to the NRC staff that is here today,  
8 Carolyn Haass and Mike Corum for the Northwest Medical  
9 Isotopes are here to present information on their  
10 application. They will begin the discussion going  
11 through their presentation on the application, and  
12 then the staff will present on the licensing process  
13 and where we're at on that following that.

14           So with that I'll turn the presentation  
15 over to Carolyn Haass.

16           MS. HAASS: Hi there. I think the  
17 majority of everyone was on the Subcommittee except I  
18 think for Peter and Michael. I know that you guys  
19 were here in the May time frame when we gave the  
20 overview. So today I'm going to do a quick overview  
21 of our facility and then we're going to go into what  
22 the changes of our construction permit application  
23 were based on the ACRS review. And obviously everyone  
24 has changes, and we wanted to go over those one more  
25 time with you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           Next page. So I think everyone's aware  
2 what our business model is, is that we're going to go  
3 design, construct, and operate a radioisotope  
4 production facility of which you see that in the  
5 circle where it says processing facility. In the  
6 process of that we're also going to have a captive  
7 network of universities' research reactors that are  
8 going to support us with irradiation of our targets.  
9 And the reason we're going to have a network of them  
10 is so we can have the reliability and assurance of the  
11 moly supply to the radiopharmaceutical companies,  
12 which then go to the end user.

13           We are looking at multiple shipments per  
14 week, and that is based upon what the  
15 radiopharmaceutical companies request. They usually  
16 request that they have a delivery like on Monday,  
17 Tuesday, Wednesday and Friday. And so --

18           MEMBER POWERS: When --

19           MS. HAASS: I have no --

20           MEMBER POWERS: -- fascinated what happens  
21 on Thursday.

22           MS. HAASS: I have no idea. They've never  
23 really told me that one, but that's what they do.

24           (Laughter.)

25           MS. HAASS: From an RPF -- from the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 radioisotope production facility perspective we have  
2 two primary activities that we do under the Part 50  
3 licensing of which -- why we were here, and one would  
4 be for the moly production and the second one is for  
5 uranium recycle and recovery. There will be a Part 70  
6 portion of this facility, which is target fabrication,  
7 and that will be in -- because it was not considered  
8 as part of this construction application, it will be  
9 considered -- we'll be submitting that with our  
10 operating license application when we do the Part 50  
11 side.

12           Next slide. So I think everyone's aware,  
13 you know, we have our unit reactor network and that  
14 our facility is going to be located in Columbia,  
15 Missouri. It's going to be about six miles from our  
16 primary reactor, which is the University of Missouri  
17 Research Reactor. We're also about five miles from  
18 the regional airport there. We have a second reactor  
19 identified, which is Oregon State University. And  
20 then we have a third reactor which we have not signed  
21 on the dotted line. We have it, but it's very, very  
22 similar to the OSU reactor.

23           Next. So our -- where we're going to be  
24 located in Columbia, Missouri, as I said, it's about  
25 six miles away from the University of Missouri

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Research Reactor. It is on university-owned land. It  
2 is in the Discovery Ridge Research Park. And our lot  
3 is about 7.4 acres. It contains no existing  
4 structures. It was -- this land was actually donated  
5 to the university system when -- a family donated it  
6 when someone passed away. And it was all agricultural  
7 land it had been used for agriculture for over 100  
8 years.

9 Also the research park is being developed  
10 under the master plan protective covenants that the  
11 University of Missouri has developed.

12 VICE CHAIRMAN CORRADINI: Just for  
13 clarification --

14 MS. HAASS: Yes.

15 VICE CHAIRMAN CORRADINI: -- where is the  
16 research reactor in comparison to this? Just so I  
17 understand.

18 MS. HAASS: I don't have that picture  
19 here.

20 VICE CHAIRMAN CORRADINI: Can you just  
21 kind of point?

22 MS. HAASS: Well, so this here, this is  
23 just the research park itself.

24 VICE CHAIRMAN CORRADINI: You can point  
25 with the mouse.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MS. HAASS: Oh, sorry. This is just the  
2 research park itself, the 550 acres.

3 VICE CHAIRMAN CORRADINI: Oh.

4 MS. HAASS: The research reactor is about  
5 six miles over here.

6 VICE CHAIRMAN CORRADINI: Oh, okay. Thank  
7 you.

8 MS. HAASS: Yes. So what you do is you go  
9 down Highway 63 for a bit, and if you know anything  
10 about their reactor, you go down and into Providence,  
11 but --

12 VICE CHAIRMAN CORRADINI: That's fine.  
13 Thank you.

14 MS. HAASS: Sure.

15 The primary assumptions for our  
16 radioisotope production facility is we're going to  
17 have one single facility. And as I stated earlier,  
18 the facility is going to have two primary items under  
19 the Part 50 licensing, which is moly production and  
20 uranium recycle and recovery. We'll also be doing  
21 target fabrication.

22 Our moly production is based on a fission-  
23 based method. It's kind of what everyone uses in the  
24 world now. I know that there's other technologies  
25 that they're trying to develop, but we believe we're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 going to be using the gold standard. We're also going  
2 to be using low-enriched uranium for our moly  
3 production. Our nominal capacity is about 3,500 six-  
4 day curies, and we have a surge capacity. Just in  
5 case some other facility worldwide came down, we would  
6 have the capability of producing more.

7 I think I've gone over the network  
8 university reactors, but two key things there is the  
9 target design is the same for all reactors. We  
10 understand power influx can be different, but we've  
11 gone through all the calculations, whether you're a 1,  
12 5 or a 10-megawatt reactor. Also we do have  
13 intellectual property and we've been going through the  
14 IP process, you know, or the patents for that. And  
15 you can see where -- who's allowed. Some are still  
16 pending, but we're in the process. We'll be --  
17 probably in the next three to four months we should  
18 have everything sewn up on that one, which is great.

19 This NRC licensing strategy page, page 6,  
20 talks about the different activities in a little more  
21 detail. What's going to be under Part 50. What's  
22 under Part 70. And then obviously you're going to  
23 have a Part 30 byproduct material handling portion of  
24 the license.

25 The other key thing here is each

1 university will have to do a license amendment to be  
2 able to irradiate our targets from a commercial  
3 perspective. They will be submitting their license  
4 applications separately. It will come through them  
5 with our support. Also there is one cask that we will  
6 have to go and evaluate and see if we have to have a  
7 license amendment because of a heat load. And that  
8 would be to transport the irradiated targets from the  
9 university back to the radioisotope production  
10 facility.

11 So what this diagram shows is we have four  
12 primary things that we do in this production facility:  
13 target fabrication, irradiated target disassembly and  
14 dissolution, then the moly production, and then the  
15 uranium recycle and recovery. The one item you see  
16 where the picture is, you see a picture of the  
17 University of Missouri research reactor here. That is  
18 the one item that we don't do in our facility is  
19 irradiate targets. That's all I was really trying to  
20 say on this. I think you guys are very familiar with  
21 this.

22 The facility description. It's about a  
23 52,000 square foot main floor, square foot facility.  
24 There is a basement, and that is where your hot cell  
25 -- your tank hot cell is, where all your critically

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 safe tanks are. That's also where we're going to be  
2 storing our high-integrity containers for decay prior  
3 to disposal at the appropriate disposal facility.

4 We also have a second floor, a mezzanine,  
5 and if I would talk to it, that's where we'll have our  
6 utilities, ventilation and our off-gas system. And,  
7 no, I don't think I need to talk about the rest. Cute  
8 little picture. You keep seeing the same one over and  
9 over.

10 Project schedule. We haven't talked about  
11 this a whole lot, but our goal is to start site  
12 preparation/construction in the second quarter of  
13 2018. We want to end construction about 15 months  
14 later. We want to start cold commissioning in mid-  
15 2019 with hot commissioning towards the end of 2019  
16 and the first quarter of 2020. And then obviously  
17 you've got to go through your FDA runs, but that  
18 doesn't -- that's not shown here, but that's after you  
19 get through your hot commissioning. And the reason I  
20 had the date of decommissioning, because it was one of  
21 the requirements that we had to put in the  
22 application. So it's around 2050.

23 So now I'm going to get to the meat of the  
24 presentation, and I know that most of you are aware of  
25 this, but we're going to go through what the major

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 changes were based on your input and comments.

2 And from chapter 2 I will say thank you  
3 again, John, for all your help. And we went and  
4 modified this. And what I did is I just listed the  
5 items. We've been through this in detail, but we  
6 modified transient population and the nearby  
7 industrial transportation, military facility, accident  
8 scenarios, the airports and heliports. We reevaluated  
9 the pipelines, the highways and the other nearby  
10 facilities for explosions and things like that. And  
11 we are working in -- we're finalizing all of that, so  
12 it will be in the operating license application.

13 MEMBER STETKAR: So I just want to  
14 clarify, Carolyn --

15 MS. HAASS: Oh, yes.

16 MEMBER STETKAR: -- you're going to carry  
17 those forward to the operating license?

18 MS. HAASS: All of this gets carried for.

19 MEMBER STETKAR: Yes, okay.

20 MS. HAASS: Anything that we have here or  
21 anything that we have stated we will be putting in the  
22 operating license application is carried forward.

23 MEMBER STETKAR: Okay. Because the kind  
24 of protracted discussions that we had during the  
25 Subcommittee meetings were focused primarily on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 justification for summarily screening out those  
2 hazards, which means they would not have been  
3 reexamined during the operating license --

4 (Simultaneous speaking.)

5 MS. HAASS: Correct.

6 MEMBER STETKAR: I understand that you are  
7 going to carry those forward.

8 MS. HAASS: Yes, we have actually  
9 completed a lot of those reexaminations. We did  
10 resubmit chapter 2. Yes, you find another mistake in  
11 there. And they've gone back and they have redone  
12 those calculations that we will be resubmitting in the  
13 operating license.

14 MEMBER STETKAR: Okay. Thank you.

15 MS. HAASS: So, but there's a whole list  
16 of things here in chapter 2. I don't need to read  
17 this for you, but we updated some of the historical  
18 data that was in there that you requested. So we did  
19 that.

Also one of the things that you  
20 guys asked about several times was our design  
21 evolution, and I just wanted to say our design is  
22 being completed in stages. We have completed our  
23 preliminary design. We're on our final design, and  
24 that final design is required for our -- the operating  
25 license application submission and to complete our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 construction drawings. And we understand how  
2 important it is to get this operating license in as  
3 soon as possible because we want to start getting the  
4 staff to start reviewing that. But obviously we  
5 couldn't get it in before we had approval here.

6 So after you do the final design, as I  
7 stated above, we start going into our construction  
8 drawings and specifications. And then there's a whole  
9 bunch of supporting documentation that is going to be  
10 finalized, and then a lot of this will go into the  
11 operating license application such as the final  
12 hazards analysis, the final CSEs and associated  
13 calculations. And it's everything we've talked about,  
14 but with the final design this will all be updated.  
15 I don't want anyone to think that we're going to leave  
16 it at a preliminary state, because every bit of this  
17 is so important to our final design. We understand  
18 how important fire is and criticality and emergency  
19 preparedness and waste management, and those things  
20 will be completed.

21 CHAIRMAN BLEY: Carolyn, just a --

22 MS. HAASS: Yes?

23 CHAIRMAN BLEY: -- point of information  
24 for the record. The Committee hasn't requested that  
25 you do anything. We only speak through our letters.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MS. HAASS: Right.

2 CHAIRMAN BLEY: Some members pointed  
3 out --

4 MS. HAASS: I apologize.

5 CHAIRMAN BLEY: -- things they saw as  
6 problems or missing information in your application.  
7 And that's why we went after it.

8 MS. HAASS: You've had wonderful  
9 suggestions.

10 MEMBER POWERS: Flattery, yes, it helps,  
11 but not a lot.

12 MS. HAASS: Okay.

13 (Laughter.)

14 MS. HAASS: Okay. But we know to be able  
15 to submit an operating license application all these  
16 items have to be final. They are only in preliminary  
17 and they will be updated.

18 So page 12. I'm going to hand this over  
19 to Mike.

20 MR. CORUM: Okay. In chapter 2 and  
21 chapter 3, that's where we get into seismic. And  
22 Northwest Medical Isotopes is going to use the  
23 response, seismic response spectrum from Reg. Guide  
24 1.6 with -- anchored in ground acceleration, peak  
25 ground acceleration of 0.2 g. And we've compared that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to the GMRS that was established through the PSHA that  
2 the staff, the NRC staff did on reviewing the Missouri  
3 research reactor submission.

4 And we found that the GMRS is enveloped by  
5 the Reg. Guide 1.6 seismic spectrum up to about 16  
6 hertz. Based on EPRI guidance we know that anything  
7 above 10 hertz in frequency is not going to damage the  
8 structural components of the facility. We will pay  
9 particular attention to the functional performance of  
10 components that are sensitive to vibration and we will  
11 evaluate those. If we have to seismically isolate  
12 them, we will. And that will all be part of our final  
13 design going forward in the operating license  
14 application.

15 MEMBER POWERS: Mike, just an item of  
16 curiosity. You've anchored 0.2 g, and the way it's  
17 stated up there you anchored it based on looking at  
18 Calloway and MURR.

19 MR. CORUM: Correct.

20 MEMBER POWERS: Did you do a trade study  
21 at all on what it cost you to go to construction at  
22 0.3 g versus 0.2 g?

23 MR. CORUM: We have not fully evaluated  
24 that at this point.

25 MEMBER POWERS: Just an item of curiosity

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 in your opinion. Nothing further.

2 MR. CORUM: Okay. Continuing on in  
3 chapter 3, the tornado missiles, that will be part of  
4 our natural phenomena hazards analysis that we will  
5 complete during final design. And I think that's  
6 really all we need to say here.

7 On chapter 5, the coolant systems, things  
8 that we've added, the weekly irradiated target heat  
9 generation rate we added. The thermal load we  
10 characterized by the radial heat transfer in a vessel  
11 and the uranium concentration of the solutions that  
12 are held within the vessels throughout the RPF. And  
13 we'll also add the number of targets to be irradiated,  
14 basically optimize those in the operating license  
15 application.

16 Moving onto chapter 6, the criticality  
17 accident alarm system. We will design that system to  
18 meet 10 CFR 70.24. We're going to commit to the  
19 current endorsed version of the ANSI/ANS-8.3 with the  
20 modifications that are noted in Reg. Guide 3.71. So  
21 we'll be using a slightly different source term based  
22 on Reg. Guide 3.71 versus 8.3.

23 We'll complete the evaluation during the  
24 final design. We'll also be working with a vendor  
25 that will supply the system to us during that final

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 design phase. And we are not going to take exception  
2 to any shielding in the hot cells. We are going to  
3 provide the CAAS system in those areas for evacuation  
4 purposes for personnel in the facility. And we will  
5 make sure that the emergency power that's provided to  
6 the system is going to be from a UPS.

7 From a criticality safety standpoint prior  
8 to the end of construction and before the operating  
9 license application we'll to make sure that all  
10 processes that contain SNM are evaluated to be  
11 subcritical under all normal and credible abnormal  
12 conditions. We'll specifically control the  
13 parameters: mass, geometry, moderation, volume and  
14 interaction, and we will commit to controlling those  
15 parameters at the safety limits and evaluate the  
16 parameters that are not controlled at their most  
17 reactive credible values.

18 We do acknowledge that if we use a single  
19 NCS control to maintain control over two or more  
20 control parameters, that that is only one constituent  
21 to meet the double contingency principle.

22 Order of preference for our controls, as  
23 we've always had, is passive engineered or passive  
24 design features followed by active, then enhanced  
25 administrative and finally simple administrative. And

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 one other point that if we do use two or more controls  
2 on a single parameter we'll commit to using diverse  
3 rather than redundant means of control.

4 Consistent with our revised validation,  
5 we'll make sure that we contain SNM under normal  
6 credible abnormal conditions to meet the revised USL  
7 0.924. The criticality safety evaluations will be  
8 updated during the RPF final design to reflect this.  
9 We've completed the criticality safety calculations  
10 already to show that all of our processes will remain  
11 below 0.924. We do have to formalize those and  
12 document them, but we have finished that part of the  
13 study. And I think that's -- I think we've said  
14 everything else that we needed to say about that one.

15 On chapter 7, the instrumentation and  
16 control systems, we'll make sure that the IROFS, the  
17 ESP safety functions are activated via hardwire  
18 interlocks and operate independent of the normal  
19 control system. The process control system will  
20 include interlocks that implement an automatic action  
21 on a parameter approaching or being outside of its  
22 setting, and we'll also implement a permissive  
23 philosophy that will allow operations to be enabled  
24 once the control room has confirmed prerequisite  
25 conditions have been completed for certain activities.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: So your operating  
2 philosophy is you request the control room, tell them  
3 what you're going to do. They check the permit, the  
4 conditions. And then you get permission to do it?

5 MR. CORUM: Correct. Yes.

6 MEMBER POWERS: And that's a feasibility  
7 simply because of the simplicity of the general  
8 system?

9 MR. CORUM: It is, yes.

10 MEMBER POWERS: It's somewhat cumbersome.

11 MR. CORUM: It would be in I guess a more  
12 complicated process, or layout.

13 MEMBER POWERS: Well, just a --

14 MR. CORUM: Yes.

15 MEMBER POWERS: More people running around  
16 asking things?

17 MR. CORUM: Exactly.

18 MEMBER POWERS: But basically you'll have  
19 one or two people perhaps asking for permission at any  
20 given stage in the operation?

21 MR. CORUM: Correct.

22 MEMBER POWERS: So you're just taking  
23 advantage of the simplicity of the system?

24 MR. CORUM: Yes, sir.

25 Okay. Then chapter 13, uranium metal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 fires. We do know that we're going to be fabricating  
2 the targets from uranium metal. Basically we've  
3 evaluated this a little bit, but we've got more  
4 evaluation to come.

5 MEMBER POWERS: Well, you're really not  
6 fabricating targets from uranium metal. You're  
7 just --

8 MS. HAASS: Broken metal.

9 MEMBER POWERS: -- dissolving it and  
10 then --

11 MR. CORUM: Yes, it's part -- yes, it's  
12 broken metal that comes in and --

13 MEMBER POWERS: And so you just have a  
14 transient period where you're handling it?

15 MR. CORUM: Correct. Correct.

16 MEMBER POWERS: It's not like you're  
17 making a metal fuel or something like that.

18 MR. CORUM: That's correct. That's  
19 correct, yes.

20 MEMBER POWERS: So I mean, this is -- and  
21 this is fairly episodic. I mean, it's not every day.

22 MR. CORUM: Not every -- it's not an  
23 everyday occurrence, but we do have to be prepared for  
24 it. We acknowledge that.

25 MEMBER POWERS: Well, it makes it a rare

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 evolution inside there. It requires some special  
2 attention.

3 MR. CORUM: Sure. Sure. And as part of  
4 our final design we plan to implement the appropriate  
5 controls in the areas where we're going to be handling  
6 this material and have available material that could  
7 extinguish a U metal fire such as magnesium oxide  
8 sand. It may be something else.

9 MEMBER POWERS: Yes, magnesium oxide I'm  
10 not fantastic about --

11 MR. CORUM: Yes.

12 MEMBER POWERS: -- because of the worst  
13 furnace fire I ever had was heating magnesium oxide  
14 because it involves oxygen at elevated temperatures  
15 and --

16 MR. CORUM: Very much.

17 MEMBER POWERS: -- not what you want  
18 around a reacting metal.

19 MR. CORUM: No, not what you want in a  
20 fire.

21 MEMBER POWERS: But there are materials to  
22 handle it. The real hazard here is not the fire per  
23 se. It's the aerosol production --

24 MR. CORUM: It's the off-gas, yes.

25 MEMBER POWERS: -- that you get. And

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 trust me, having burned my share of uranium metal  
2 those aerosols are absolutely nefarious in their  
3 ability to get into places you don't want them.

4 MR. CORUM: Absolutely.

5 MS. HAASS: And based on the questions  
6 that we have gotten over the last four or five months  
7 from the Committee, we have gone and done a trade  
8 study. Obviously it will be part of our operating  
9 license, but it will -- it's very specific T metal  
10 fires. And we'll be incorporating that into chapter  
11 13.

12 MEMBER POWERS: Yes, that's fine. That's  
13 good. I mean, it's -- these metal fires have had  
14 occasions when it's radioactive metal of shutting down  
15 facilities for a very long time because they're hard  
16 to clean up.

17 MS. HAASS: Right, and definitely it's not  
18 really suppressing the fire. It is the off-gas or the  
19 aerosols that come off the fire --

20 MEMBER POWERS: That is your hazard.

21 MS. HAASS: -- that become the issue. We  
22 completely agree.

23 MEMBER POWERS: Yes, quite right.

24 MR. CORUM: And that completes our  
25 presentation, if there's any questions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MS. HAASS: Yes, sorry it was short and  
2 sweet, but I know everyone probably here has heard and  
3 seen this many times. And that's why we were just  
4 going to open it up for questions.

5 MEMBER POWERS: I think you've covered  
6 what's expected. I mean, the essential point is that  
7 we need to understand conceptually. You're required  
8 to demonstrate a knowledge of the hazards here. I  
9 think that did it quite well. Thank you very much.

10 MEMBER STETKAR: Mike?

11 MEMBER POWERS: Do any members have  
12 additional questions they'd like to pose?  
13

14 MEMBER STETKAR: Yes.

15 MEMBER POWERS: You're shaking your head.  
16 (Laughter.)

17 MEMBER STETKAR: I'll be gentle.

18 Mike, during your discussion about IROFS  
19 you mentioned that your intent is to provide diverse  
20 rather than redundant IROFS, which is a good idea. We  
21 had during the Subcommittee meetings some discussions  
22 about your integrated safety assessment where you  
23 evaluate the benefit that you achieve from each of the  
24 IROFS. And in particular we had some discussions  
25 about the use of administrative controls: personnel

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 monitoring, personnel activities and so forth.

2 In several of those instances in the ISA  
3 there is; and I have to be careful here, credit taken  
4 for redundant personnel activities. Those are not  
5 particularly diverse necessarily.

6 MR. CORUM: No.

7 MEMBER STETKAR: So and I know the ISA is  
8 an evolving, kind of living sort of analysis, but do  
9 you have any comments on the area of administrative  
10 controls versus hardware-based things --

11 MR. CORUM: Right.

12 MEMBER STETKAR: -- without getting into  
13 details.

14 MR. CORUM: Our philosophy going into the  
15 final design is we're going to try to eliminate where  
16 possible as many of the administrative controls that  
17 we can and replace that with -- hopefully with --  
18 well, primarily with passive design --

19 MEMBER STETKAR: Yes.

20 MR. CORUM: -- and try to get away from  
21 that. With any handling operation in these types of  
22 facilities you're going to inevitably have to have  
23 some kind of administrative controls, but we certainly  
24 aren't going to use the same operator or the same I  
25 guess requirement and call that double contingency.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Two operators looking at something and say that's  
2 doubly contingent. That's not going to happen in the  
3 final design.

4 MEMBER STETKAR: Thanks. We look forward  
5 in the final design to see how you handled that.

6 MS. HAASS: We look forward to you  
7 reviewing.

8 (Laughter.)

9 MEMBER POWERS: Any other questions of the  
10 applicant?

11 (No audible response.)

12 MEMBER POWERS: Now we'll turn to the  
13 staff and they can explain to us how they went about  
14 reviewing this construction permit application.

15 And, Mike, we're particularly interested  
16 in areas where you felt it necessary to do independent  
17 investigations, calculations, analyses, audits and  
18 things like that and where you've relied on  
19 particularly Mr. Adams' vast experience with these  
20 facilities to identify areas of focus. But the floor  
21 is yours.

22 MR. BALAZIK: Thank you. So I'd like to  
23 start by just making a couple high-level comments  
24 about what we're going to be talking about.

25 First, happy to be here and --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: That's the first lie.

2 (Laughter.)

3 VICE CHAIRMAN CORRADINI: But he has vast  
4 experience.

5 MR. ADAMS: Happy to be here. And in this  
6 area I'm wondering where my vast experience is.

7 So we're going to focus on talking about  
8 the review process, the how we did it and why we've  
9 done it the way we did, because there's not a lot of  
10 recent examples of construction permit reviews outside  
11 of what we did for SHINE. And it is different. It's  
12 different than an operating license review. It's  
13 different than a combined license review. And I think  
14 those differences are important to understand because  
15 they guided us with what we looked at, how we looked  
16 at it. And so we're going to try to clarify what's  
17 different between an operating license and a  
18 construction permit.

19 We're going to tell you about the  
20 construction permit conditions. Those are probably  
21 the most important conditions that came out of our  
22 review because we're recommended to the Commission  
23 that they make it part of the license.

24 As we talked about looking forward, we'll  
25 be back with the operating license review. We plan to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 approach that as -- it's a different review. The  
2 yardsticks are different. The regulatory requirements  
3 are different. Obviously informed by what we've done  
4 here from the design philosophy and the basis, but  
5 it's a different review. However, it will be informed  
6 by the commitments that we are keeping track of that  
7 were part of this review.

8 If you look at Appendix A of our SER,  
9 you'll see two sets of commitments, and one set was  
10 based on RAI answers that Northwest gave us.  
11 Northwest said, well, this is something that we'll  
12 talk about more in the operating license or an issue  
13 that will close out the operating license. We noted  
14 it and listed it down. Also in that appendix is  
15 issues that came up during the Subcommittee meetings.  
16 And so those commitments are also listed and as  
17 reminder to the staff as they go through the operating  
18 license to make sure that each one of those are  
19 checked off.

20 MEMBER POWERS: To me the hardest step in  
21 doing this construction permit is the acceptance  
22 criteria. There's always a tendency to get -- to ask  
23 for more and more detail and more specificity and  
24 things like that. And that kind of qualitative sense  
25 of where they've met the actual requirement even

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       though there's residual uncertainty. It's not quite  
2       clear exactly how it will be done.

3               MR. ADAMS: Right, and that's the biggest  
4       challenge is where do you draw that line? We are --  
5       we've gained some experience doing that because this  
6       is the second time we've done it, but it's based a lot  
7       on the judgment of the staff. Also guided by the  
8       regulations. The regulations tell us what the  
9       applicant needs to give us. For example, measurements  
10      don't need to be exact. They could be in the  
11      ballpark. So we try to be guided by the regulations.

12              But you're right, there's always --  
13      there's a tendency to keep wanting to go down the  
14      path, wanting to know -- wanting to have knowledge,  
15      wanting to have those details. And we have to stop  
16      ourselves and remind ourselves that this is a  
17      construction permit. We're not making any safety  
18      findings here. We're not making -- we're not  
19      approving this -- we're not approving any aspects of  
20      the safety of this facility.

21              What we're doing is we're saying that  
22      there's enough preliminary information that the  
23      applicant has thought about what they're doing, that  
24      they've covered it from a design philosophy, a design  
25      basis, that they are thinking along the right lines

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and there's enough there to allow -- to say to them,  
2 okay, go ahead and start construction.

3           During construction we have a Construction  
4 Inspection Program that will watch carefully what is  
5 being done like with the application of their QA  
6 Program. And of course the operating license is where  
7 the rubber meets the road and all the loose ends are  
8 tied together.

9           So the applicant does understand that they  
10 move forward with some level risk on these issues that  
11 are commitments or taking a philosophy or licensing  
12 basis and turning it into how thick a wall is or how  
13 many -- or what the pipes look like. They understand  
14 that clearly and we understand that, too, which is why  
15 we're looking forward and why we'll be back.

16           MR. BALAZIK: This is Mike Balazik, Dr.  
17 Powers. Also just within our guidance, NUREG-1537 and  
18 the Interim Staff Guidance, the review of each chapter  
19 took a look at the acceptance criteria. And if they  
20 could say that, yes, Northwest met that acceptance  
21 criteria, we documented that in the SER.

22           Now of course, all the acceptance criteria  
23 aren't met, but if with the information that we had we  
24 looked at that to see if we could meet it and come to  
25 a finding.

1 MEMBER POWERS: Yes, it just strikes as  
2 thinking about putting myself in your shoes that it  
3 would be a continual reminder of where I've got cut  
4 things off in here. I mean, it would be a struggle.  
5 I mean, I don't envy your job here.

6 MR. BALAZIK: Yes, sir. And like I said,  
7 our technical reviewers, in some cases they had to use  
8 engineering judgment --

9 MEMBER POWERS: Sure.

10 MR. BALAZIK: -- to make that  
11 determination.

12 MEMBER POWERS: Yes.

13 MR. ADAMS: And like I say, this is the  
14 second time we've done this, so we are gaining some --  
15 we did gain some lessons learned from the first time  
16 we'd done it.

17 Given our limited time there's a lot of  
18 technical things we could have talked about. We're  
19 going to focus on one of those and tell you how we  
20 followed up on the -- in the area of aircraft impact,  
21 because that was an area where we did have a lot of  
22 discussion and we did get a lot of help from the  
23 Subcommittee.

24 CHAIRMAN BLEY: Al, before you go forward  
25 with that, I agree this is a tough piece you've been

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 doing, but I wonder, it's been a long time since we  
2 did these. We're just doing our second. There's been  
3 a longer time since we went from construction permit  
4 to an operating license, and maybe the answer to my  
5 next question is hidden and we didn't make any safety  
6 findings. But how are you going to ensure when you  
7 get to the operating license that we don't carry over  
8 our biases from this review, because we've made  
9 findings based on somewhat incomplete information and  
10 I think the temptation would be to say, oh, I kind of  
11 closed that issue before. I don't need to dig into  
12 that very hard this time around.

13 MR. ADAMS: And you're right. That is a  
14 very important aspect and that's why we are going to  
15 approach the operating license from sort of a clean  
16 sheet of paper. It's a different yardstick. And so  
17 we can be informed from the construction permit in  
18 that, yes, there is philosophies and design bases that  
19 were discussed in the construction permit and we're  
20 going to see those were carried forward into the  
21 operating license. But one important thing is that  
22 things that -- that very little is closed at this  
23 point, that we come back and we take a fresh look  
24 because it's a different yardstick.

25 MEMBER POWERS: Very different from an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 earlier site permit --

2 MR. ADAMS: Yes, it's a different  
3 yardstick.

4 MEMBER POWERS: -- where we're not closing  
5 anything out.

6 MR. ADAMS: Yes. Different yardstick and  
7 a different set of conclusions we need to reach. So  
8 I mean, that's the answer.

9 MR. LYNCH: Yes, the staff also recognizes  
10 that there is a potential for the design of the  
11 facility to change substantially between the issuance  
12 of the construction permit and when we receive the  
13 operating license, and that's to a certain extent  
14 expected as the design evolves.

15 One of the ways we'll address that as we  
16 get to the operating license application is -- our  
17 expectation is we will continue to have preapplication  
18 meetings going into the operating license application  
19 and during construction where Northwest will highlight  
20 some of the significant design changes so the staff,  
21 when we get the operating license application, has a  
22 good understanding going into that review what has  
23 changed from our previous review and we'll be  
24 informing that review somewhat from those commitments  
25 that were made.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. ADAMS: And one thing we did was the  
2 development of a non-power and production facility  
3 Construction Inspection Program that -- the program  
4 that existed was very old. Last time it was exercised  
5 was in the early 80s at the University of Texas. So  
6 given all the insights and everything we've learned  
7 since then, we made the decision to write a completely  
8 new program. And the Office of New Reactors took the  
9 lead for that along with the folks down in Region II  
10 and the construction inspection folks. And so that is  
11 another important part to making sure at the end where  
12 we need to be.

13 To issue an operating license, there are  
14 a lot of things we need to look at, but one of them is  
15 that the Construction Program determines that the  
16 facility was built as described in the FSAR. So  
17 that's a very important yardstick, that what was  
18 reviewed, what the Committee is going to look at also  
19 is what is sitting there.

20 So with that I'll -- any other initial  
21 questions? If not, I'll turn it over to Mike.

22 MR. BALAZIK: Thank you, Al. I'll go  
23 ahead and start the presentation. First of all, just  
24 a quick overview of Northwest Medical Isotopes'  
25 application. Submitted a Part 50 construction permit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 application for a production facility for the  
2 following activities: disassemble and dissolve the  
3 low-enriched uranium targets; recover and purify  
4 molybdenum-99; and recover and recycle uranium.

5 It was a two-part construction permit.  
6 The environmental report was docketed in May of 2015  
7 and the preliminary safety analysis report, otherwise  
8 known as the PSAR, was docketed in December of 2015.

9 Also; and I know this has been the  
10 discussion of a lot of Subcommittee discussions about  
11 the target fabrication, I just wanted to put out that  
12 we expect a Part 70 application for the possession and  
13 use of special nuclear material to be submitted in the  
14 future. And this facility, as Northwest stated  
15 earlier, is going to be constructed in Columbia,  
16 Missouri.

17 MEMBER STETKAR: Mike?

18 MR. BALAZIK: Yes, sir.

19 MEMBER STETKAR: You brought it up, and we  
20 had -- we did have some discussions about this. And  
21 how does the staff -- because there will be a Part 50  
22 license and there will be a Part 70, and yet it's a  
23 facility that lives under the same roof and is  
24 operated by the same people, has common what I'll call  
25 support systems: cooling water ventilation, electric

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 power, AC/DC, all that kind of stuff. How does the  
2 staff treat in the final reviews the integrated safety  
3 assessment, because the integrated safety assessment  
4 can't be a distinct Part 50 separate from the Part 70  
5 integrated safety assessment because then it's not  
6 integrated. So how does the staff -- how do you do  
7 that in your reviews?

8 MR. BALAZIK: Well, I think that would be  
9 a --

10 MEMBER STETKAR: Because this is unique.  
11 (Laughter.)

12 MR. BALAZIK: No, no. No, sir, I totally  
13 agree it's unique. And just from the standpoint of  
14 the construction permit we kind of looked --

15 MEMBER STETKAR: Not -- I'm not talking  
16 about a construction permit. I'm asking you looking  
17 forward --

18 MR. BALAZIK: I understand.

19 MEMBER STETKAR: -- because we haven't  
20 seen any of the -- we, the ACRS Subcommittee at least,  
21 hasn't seen any of the Part 70 licensing information,  
22 if you will.

23 MR. BALAZIK: Correct.

24 MEMBER STETKAR: So I'm asking you going  
25 forward, because we're talking about how you're going

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to accomplish this task.

2 MR. BALAZIK: Correct. So --

3 MEMBER STETKAR: How do you that?

4 MR. LYNCH: So our -- so one thing, based  
5 on what Northwest has told us, they are intending to  
6 submit a single application at the operating license  
7 stage that will cover the Part 50 operations and the  
8 Part 70 operations. So during our review we will have  
9 an opportunity to look at how those two areas: the  
10 target fabrication area and the hot cell processing  
11 area interrelate. So our expectation is that we will  
12 be conducting essentially a single review of all of  
13 those operations within the facility to understand how  
14 they interact with each other. So it will be  
15 everything under a single roof evaluated together  
16 under that ISA.

17 MR. ADAMS: And I think you've seen an  
18 indication of the -- how we look at the interaction  
19 and that the accident scenarios that were looked at.  
20 One of them was is there something that the target  
21 fabrication area could do that would impact the  
22 production facility? So that -- we're already  
23 starting down that path, but --

24 MR. BALAZIK: And, Member Stetkar, just  
25 one more item to add to this is for this review we've

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 used NMSS significantly. So these are the same  
2 reviewers that are going to be looking at the Part 70,  
3 and that benefits us significantly in this type of  
4 review.

5 MEMBER STETKAR: Okay. Good. Thanks.  
6 But again, we kind of look forward to see how you work  
7 all that out.

8 MR. BALAZIK: Yes, sir.

9 So on slide 4 the Northwest facility  
10 includes several hot cell structures which meets the  
11 requirement, or the definition I should say, of a  
12 production facility. A production facility is defined  
13 as any facility designed for processing of irradiated  
14 materials containing special nuclear material. And  
15 there's also a threshold for that, so if the material  
16 processed in batches is greater than 100 grams of  
17 uranium-235, it's a production facility.

18 So while the NRC has historically licensed  
19 Part 50 production facilities, no such facility is  
20 currently operating. We did issue a construction  
21 permit for SHINE in early 2016. And we also had a  
22 Part 50 license for West Valley, which was  
23 reprocessing fuel. I think that was back in the '60s  
24 time frame.

25 MR. ADAMS: In the '60s. And there was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 domestic production of moly-99 in the United States of  
2 cintycam in New York. It was not a production  
3 facility because of that 100-gram discussion in the  
4 definition. Their batches are less than 100 grams, so  
5 actually the area where the moly and the uranium were  
6 separated was done under a Part 70 license. So the  
7 technology here, the chemistry here is actually long-  
8 established and similar to what's used throughout the  
9 world for the production of fission product moly-99.

10 MR. BALAZIK: Okay. So this next slide,  
11 slide 5, I kind of wanted to touch on the scope of the  
12 review. Even though there was a lot of information in  
13 the application, some of this information we didn't  
14 consider for our findings for the production facility.  
15 So the radioisotope production facility has a  
16 production facility which we're reviewing now and a  
17 target fabrication area.

18 So for target fabrication it's the  
19 processing of un-irradiated uranium that does not meet  
20 the definition of either a utilization facility or a  
21 production facility. So these processes and hazards  
22 associated with this target fabrication are more like  
23 fuel cycle. So Northwest, they'll need a license for  
24 receipt and possession of fresh LEU. It will be  
25 greater than a critical mass. And they'll also be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 doing scrap recovery of special nuclear material.

2 And in the PSAR it states that the target  
3 fabrication will be -- the license will be applied for  
4 under a separate Part 70 license application.

5 So when the staff --

6 MEMBER KIRCHNER: Just for the record when  
7 do you expect that application?

8 MR. BALAZIK: Well, as Mr. Lynch mentioned  
9 earlier, right now we expect that application with the  
10 operating license. And Northwest can correct me, we  
11 expect that in the second quarter of 2018. I mean,  
12 that's what they had on the board earlier, too. But  
13 there's nothing that prevents them from submitting  
14 them separately.

15 So in the staff's review of testifying  
16 SSCs they weren't considered unless they were shared  
17 with a production facility. No safety findings were  
18 made on their adequacy for the target fabrication.  
19 And what Northwest pointed out earlier is that these  
20 targets identical are going out to research reactors.  
21 So each research reactor would have to submit a  
22 license amendment before they could irradiate these  
23 targets.

24 CHAIRMAN BLEY: And I'll add we have not  
25 seen any of those amendment applications as of today.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. BALAZIK: So big picture on the scope  
2 of the review. The SER findings are limited to the  
3 Part 50 production facility.

4 Regulatory Guidance. I'll just touch on  
5 this real quick. I know that we presented this a lot  
6 during the Subcommittee meetings, but the primary  
7 guidance that the staff used was NUREG-1537, which is  
8 preparing and reviewing applications for non-power  
9 reactors. But once we -- I should say early on the  
10 staff developed generator because we saw all kind of  
11 gaps in the NUREG-1537 on production facilities.

12 So we came up with the Interim Staff  
13 Guidance that kind of addresses the production  
14 facility -- licensing of production facilities. And  
15 a lot of that information that we incorporated came  
16 from NUREG-1520, which is the Standard Review Plan for  
17 a fuel cycle facility. And there's also a lot of  
18 other guidance that the staff used. For example, ANSI  
19 Standard 15.8, which is quality assurance, and 15.16,  
20 which is EP for RTRs.

21 These are the areas that the staff  
22 presented on. Well, we didn't present on all of them,  
23 but we presented on chapters 1 through 9 and 11  
24 through 13. These were all discussions during the  
25 Subcommittee meetings.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           Just wanted to touch on some of the  
2 construction permit requirements. I would say some of  
3 the more important ones are 50.34 on what is needed  
4 for a preliminary safety analysis report; in other  
5 words, what does Northwest to include? Also, the  
6 occupational dose limits and public dose limits in 10  
7 CFR 20. And also for what findings the staff needs to  
8 make in order to issue a construction permit in 50.35.  
9 And we'll talk about that a little bit later. And  
10 we'll also touch upon 50.40 and 50.50.

11           Just a note here. In the ISG, in the  
12 guidance it states that the staff has accepted 70.61  
13 for performance requirements, that it may be used to  
14 demonstrate adequate safety of a medical isotope  
15 production facility. And that's what Northwest has  
16 done. So that's kind of unique and I think that's  
17 maybe one of the first times that we've actually used  
18 an ISA methodology for a Part 50 facility.

19           MR. LYNCH: There's a -- and real quick,  
20 one thing I want to highlight in terms of our -- that  
21 may be unique in terms of our review of the  
22 consequences of this facility to the public. Using  
23 the Part 20 occupational and public dose limits, we're  
24 also using that public dose limit of up to 500  
25 millirem as an accident criteria, which is more

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 conservative than is typically used for power reactors  
2 under Part 100.

3 MR. BALAZIK: And just to continue on,  
4 also I just want to point out a couple regulations  
5 that --

6 MEMBER POWERS: Well, it's not at all  
7 surprising that you would use a more conservative  
8 criterion, because you don't meet all the other  
9 requirements.

10 MR. LYNCH: Well, I will -- part of this  
11 is the absence of accident dose criteria for non-power  
12 production and utilization facilities. The staff is  
13 addressing this separately as a rulemaking. We do  
14 have a proposed rule that will set an accident dose  
15 criteria of one rem for these facilities. And we're  
16 moving forward on that. We expect the final rule to  
17 be published and implemented by 2019 or 2020.

18 MR. ADAMS: But you're right, Dr. Powers,  
19 that all of the additional siting requirements that  
20 come with Part 100 are not applicable to this  
21 facility.

22 MEMBER POWERS: So I mean --

23 MR. ADAMS: So it's logical that the doses  
24 would not be the same, that --

25 (Simultaneous speaking.)

1 MEMBER POWERS: Yes, it's not at all  
2 surprising. You picked one that's good enough for --

3 MR. BALAZIK: Just a quick note on the  
4 bottom two bullets. There are a number of regulations  
5 that don't apply to the Northwest facility. One of  
6 those is the -- or one of the more significant ones is  
7 the General Design Criteria of Appendix A, but  
8 Northwest is still required to have a General Design  
9 Criteria in accordance with 50.34. Also Appendix B,  
10 quality assurance, doesn't apply.

11 As I mentioned earlier, the staff's review  
12 consisted of the ANSI Standard 15.8. And also Part  
13 100 also doesn't apply. And what the staff did is  
14 within NUREG-1537 there's specific criteria for site  
15 characteristics that we use that's equivalent to the  
16 Part 100.

17 MEMBER POWERS: Well, parallel perhaps.

18 MR. BALAZIK: Yes, I'd say parallel, not  
19 equivalent. If it was equivalent, then I guess they  
20 would use it.

21 MR. ADAMS: But the same concepts are  
22 there. We looked at meteorology, we looked at  
23 weather, we looked at seismology, we looked at the  
24 dirt, we looked at the rocks. So the same -- it's a  
25 parallel. It's the same waterfront, so to speak, but

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the purpose is a little bit different than -- well, is  
2 different than Part 100.

3 MR. BALAZIK: Just real quick I'll touch  
4 on the construction permit application contents. The  
5 PSAR needs to include a preliminary design of the  
6 facility, principal design criteria, design bases and  
7 approximate dimensions, a preliminary analysis of  
8 structures, systems and components including the  
9 ability to prevent and mitigate accidents, probably  
10 subjects of tech specs, preliminary emergency opinion,  
11 a Quality Assurance Program, and research and  
12 development.

13 And I just want to kind of contrast that  
14 the operating license which Northwest -- when they  
15 submit that, it will be the final safety analysis.  
16 And also they'll supplement the environmental report  
17 if needed. And what they need to include in the  
18 operating license is the emergency plan, tech specs,  
19 physical security plans and plans for operation.

20 MR. ADAMS: Can I step back a second? So  
21 this is the heart of the difference between a  
22 construction permit and an operating license is those  
23 words on the last slide: preliminary design,  
24 preliminary analysis, probable subjects of tech specs,  
25 preliminary emergency plan. A Quality Assurance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Program, because that is so important to make sure the  
2 facility is constructed properly. That's one that's  
3 not preliminary. And research and development.  
4 Again, you'll find in Appendix A there is a list of --  
5 there are some issues that are still research and  
6 development issues for Northwest, and those issues  
7 need to be brought to a satisfactory close that the  
8 staff will accept before the operating license is  
9 granted.

10 MR. BALAZIK: I think Al may have covered  
11 most of this, so we'll skip it unless there's any  
12 questions. It just talks about a construction permit  
13 versus an operating license.

14 So I just want to touch on the NRC review  
15 methodology. The construction permit only allows  
16 construction. The level of detail in the application,  
17 the staff's SER is different than what you would see  
18 for a combined license or an operating license  
19 application.

20 For issuing a construction permit, the  
21 facility may be adequately described at a functional  
22 or a conceptual level in the PSAR. And I think from  
23 the Subcommittee meetings we've seen that. For  
24 example, chapter 7 was more of a conceptual or  
25 functional level, which we didn't really have a lot of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 details.

2 Northwest has deferred providing many  
3 design and analysis details until the submission of  
4 its final analysis report with its operating license  
5 application. And the staff review was tailored to  
6 unique and novel technology described in Northwest's  
7 construction permit application using appropriate  
8 regulatory guidance.

9 And for that last bullet I can just say  
10 that's the whole Part 70/Part 50 piece that we talked  
11 about earlier.

12 MR. LYNCH: A lot of our review  
13 methodology too was to make sure that we understood  
14 that the applicant had an appreciation for where are  
15 they going when the operating license application is  
16 submitted. So we may have requested additional  
17 information from the applicant with respect to holes  
18 we identified in the application or we found that  
19 acceptable responses were -- the applicant understood  
20 that this is something they needed to do later, but  
21 didn't have the information now so that we had that  
22 information docketed that they understood the full  
23 scope of what was to come. And that's part of what we  
24 based our conclusions on is did the applicant  
25 understand what the -- where they needed to get for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the final design and how to path forward to getting  
2 there.

3 CHAIRMAN BLEY: I think in the next few  
4 slides you have a place to answer this question, but  
5 maybe an overview answer at this point would be  
6 helpful. When you reviewed the safety analysis  
7 section, what were you really looking for there? Were  
8 you looking for completeness? Were you looking for  
9 their knowledge of how to carry out those kind of  
10 analyses? What were you looking for in the safety  
11 analysis?

12 MR. ADAMS: Well, I think some of it was  
13 just looking at their methodology to make sure that  
14 they were using the correct guidance, the correct  
15 standards, looking at some of their inputs and  
16 ensuring that -- well, I guess --

17 MR. LYNCH: Some of it will depend on the  
18 chapter. For example, chapter 2 when we're looking at  
19 siting requirements, that's an example --

20 CHAIRMAN BLEY: The chapter on safety  
21 analysis is the chapter I asked about.

22 MR. LYNCH: Sure. With the safety  
23 analysis that was more methodology that we wanted.  
24 Have they identified initiating events? Did they look  
25 at the different types of accidents that could occur

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 at the facility?

2 CHAIRMAN BLEY: Were you interested in the  
3 completeness in their look for initiating events or  
4 just that they --

5 (Simultaneous speaking.)

6 MR. LYNCH: We were looking for what we  
7 call a vertical slice or a cross-section. Do they  
8 have a representative example of the different types  
9 of initiating events? In terms of the completeness of  
10 those events, that's something we'll look at when the  
11 full ISA is submitted with the operating license  
12 application. But, yes, the focus for the preliminary  
13 safety analysis report in the accident analysis  
14 section was the methodology to make sure that they  
15 gave the staff confidence that they were technically  
16 qualified to carry out the full review at the  
17 operating license stage.

18 MR. ADAMS: And that's an area where we  
19 did look -- we did take a slice and look at what they  
20 were doing in detail for that slice. And it's an area  
21 where for example the application did not talk about  
22 some aspects of chemical hazards and the staff  
23 independently calculated for example over-pressures of  
24 detonations within hot cells to satisfy ourselves that  
25 we were in the right place as far as the designs of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the SSCs go.

2 MEMBER KIRCHNER: Do you do an independent  
3 analysis on the source terms that kind of bound the  
4 applicant in some bounding analyses? Do you do an  
5 independent check on that, because that basically is  
6 what's used to say they can meet the siting  
7 requirements with regard to radiation exposure and  
8 such?

9 MR. LYNCH: Sure, we have done some  
10 limited evaluation of this and at the construction  
11 permit stage I would characterize that as more  
12 qualitative. What we did look at were the applicant's  
13 ability to define their safety-related SSCs, the IROFS  
14 to establish that methodology for putting these  
15 controls on different processes within the facility  
16 that would be within a certain bound.

17 And right now Northwest in their  
18 application has stated that under accident conditions  
19 they're intending to meet the 10 CFR Part 20 limits of  
20 500 millirem for those accidents with the engineered  
21 and administrative controls placed on them. So once  
22 we get to the operating license application review, we  
23 will be looking at these accidents with that in mind.

24 MR. ADAMS: But that was an area where we  
25 did have a discussion with the applicant to understand

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that they clearly define the basis for the source  
2 term, because there was some question. Was it eight  
3 MURR targets? Thirty Oregon State targets? What type  
4 of decay did those targets receive before they were  
5 handled in the facility? If you look, you'll see  
6 there was RAIs in that area and discussion of what  
7 appeared to be some inconsistencies across the  
8 application. So that's one thing we do at that stage  
9 was to make sure that there was a clear basis for a  
10 source term that we understood and found to be  
11 agreeable.

12 MR. BALAZIK: So in the staff's review of  
13 the PSAR and resolving technical deficiencies there  
14 was a couple options. Staff determined that such  
15 technical issues must be resolved prior to issuance of  
16 a construction permit. And also there are other items  
17 that can be left until submission of the operating  
18 license or the FSAR. And also that they required  
19 technical issues be resolved prior to completion of  
20 construction, but after the issuance of a construction  
21 permit.

22 So in all these cases staff asked a  
23 considerable amount of RAIs, but in the second and  
24 third options a lot of these are tracked as  
25 commitments or identified as licensing conditions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 And we'll talk about those a little bit later.

2 So let's talk about --

3 MEMBER POWERS: How do you -- I mean,  
4 you've got three options that you lay out there. Is  
5 it largely engineering judgment on those or --

6 MR. BALAZIK: It is. I'd say it's part of  
7 it, but also the reviewers wanted to look at or ask  
8 the question what do they think would actually impact  
9 construction of this facility? What may make them  
10 have to pour concrete or stuff like that? Larger  
11 items, not -- I would say that is more of the view on  
12 looking at that.

13 MEMBER POWERS: It really boils down to if  
14 I got a -- if I'm going to have to chip out or pour  
15 concrete to correct something here, then it better be  
16 part -- it better be resolved now. If I'm not going  
17 to have to do that now, I got two options.

18 MR. BALAZIK: Yes, that's a good  
19 characterization.

20 MR. ADAMS: That's a good  
21 characterization. It's engineering judgment, but also  
22 applying that engineering judgment to the particular  
23 yardstick for construction permits, which we talked  
24 about. You know, preliminary, preliminary,  
25 preliminary.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   Sometimes that first option of asking an  
2 RAI, again it was to make sure there was a complete  
3 understanding. It would be a case where, geez, they  
4 didn't say much of anything about this and we'd ask an  
5 RAI. And then they could come back and say, yes,  
6 we're aware of this, but it's something that we're  
7 going to put off for the FSAR.

8                   So it's -- that's part of it, too, making  
9 -- again, making sure that they had a comprehensive  
10 understanding. And that's guided by NUREG-1537. And  
11 the reviewers looked at -- did they talk about this?  
12 Did they talk about this? Did they talk about this?  
13 And then that would generate questions to make sure  
14 there was a --

15                   (Simultaneous speaking.)

16                   MEMBER POWERS: No, I'm just trying to  
17 understand how you decide between them. And I can  
18 understand that first between resolve it now, resolve  
19 it later where it goes in as a commitment. The  
20 selection between those two I'm a little hazy on right  
21 now.

22                   MR. LYNCH: Sure, and I think some of that  
23 -- and issues that need to be resolved prior to the  
24 completion of construction we'll go into more detail  
25 in a couple slides, but those are those issues that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 we've created conditions for. And a lot of that has  
2 to do with criticality controls. And that's where we  
3 fall on a lot of those items that need to be resolved  
4 before the completion of construction.

5 For example, with the CAAS, making sure  
6 that -- while they -- it may be conservatively  
7 designed such that workers are protected from  
8 radiation exposure, but if they go overboard, maybe  
9 the alarm system doesn't work as it's intended to  
10 because it's also shielded from the radiation.

11 So those are the kind of items that we  
12 want to highlight during our Construction Inspection  
13 Program for those items that we maybe don't need to  
14 see until the operating license application. That may  
15 be specifics with their -- any digital systems they  
16 might use. That isn't going to necessarily impact the  
17 pouring the concrete.

18 MR. BALAZIK: So I just want to go over  
19 the Appendix A that's in the SER and just highlight  
20 the different areas.

21 Appendix A.1 is the proposed licensing  
22 conditions, and we'll talk about some of these in a  
23 minute.

24 A.2 was the regulatory commitments  
25 identified in response to RAIs. So if we asked an RAI

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and Northwest said that we can supply that information  
2 with the operating license, we captured that in  
3 Appendix Alpha.2.

4 Alpha.3 identifies the regulatory  
5 commitments that were fulfilled by Northwest, in  
6 saying that their response to the RAI was complete and  
7 it was accepted by the NRC.

8 Alpha.4 were commitments that we  
9 identified during the ACRS Subcommittees. And we'll  
10 look at a table real quick that has a couple of those  
11 items and we'll touch on a couple of them.

12 And Alpha.5 is just the ongoing research  
13 and development.

14 So let's talk about the proposed licensing  
15 conditions. These first two are on criticality. The  
16 first one is on the upper subcritical limit. As a  
17 result of requests for additional information,  
18 Northwest revised their upper subcritical limit,  
19 however, that new limit has not been incorporated into  
20 all their design calculations. It will take a little  
21 bit -- awhile to do that. So we came up with -- this  
22 licensing condition was proposed to ensure that  
23 Northwest incorporates that revised upper subcritical  
24 limit in their design. And this has the potential of  
25 impacting construction.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           For example, for a certain tank or certain  
2 spacing to get to that new upper subcritical limit the  
3 dimensions could change. Right now it's not, no, but  
4 it could actually impact that. So this first  
5 licensing condition addresses that item.

6           The second one, as Steve mentioned  
7 earlier, was on the CAAS. If you pour a certain  
8 amount of concrete, the CAAS might not be able to  
9 detect a criticality. So we wanted to address this  
10 one that they will provide a technical basis for the  
11 design of the CAAS and notify the NRC prior to  
12 completion of construction.

13           MR. LYNCH: And with each of these  
14 conditions while we are asking that the applicant  
15 provide us periodic updates on the status of their  
16 design as they resolve these items, the staff will not  
17 be performing technical reviews based on the  
18 information provided with these conditions. They will  
19 be ministerial in nature. And what we will use them  
20 for is input into our Construction Inspection Program.  
21 It will help us provide information to our inspectors  
22 to help them prioritize those most safety-significant  
23 items when they are on the site and conducting  
24 inspections.

25           MEMBER KIRCHNER: This sounds -- on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 surface it looks okay. The problem that I see is that  
2 you have six-month intervals and they're on a rather  
3 ambitious construction schedule. I'm just looking at  
4 start of site prep construction, second quarter of  
5 '18, end of construction, second quarter of '19. So  
6 basically they're planning on a year to build the  
7 facility. So how does this work in practice?

8 MR. BALAZIK: Well, one thing that --  
9 to --

10 MEMBER KIRCHNER; And again --

11 MR. BALAZIK: -- for a licensing condition  
12 you have to have --

13 MEMBER KIRCHNER: And one other comment  
14 I --

15 MR. BALAZIK: Yes.

16 MEMBER KIRCHNER: -- should make first.  
17 Following the applicant's design philosophy of first  
18 going with passive measures, passive measures means  
19 space basically and piping dimensions. And that  
20 sooner or later impacts concrete and so on if you  
21 don't have enough space.

22 So I'm just -- although this makes sense,  
23 in practice it looks like they're on a pretty fast  
24 track schedule.

25 MR. BALAZIK: Yes, sir.

1           MEMBER KIRCHNER: Can you take information  
2 from them, review it quick enough to actually have an  
3 impact before you get an unwanted result that may  
4 cause back -- I don't want to use that word -- change  
5 in the design or the construction?

6           MR. LYNCH: Sure. So in addition to  
7 responses to these conditions the staff will have  
8 other opportunities to look at these -- the design as  
9 it evolves. We have an expectation that the applicant  
10 will maintain a -- some sort of either physical  
11 library or digital library documenting their design  
12 control and design changes as they go through  
13 construction so that when inspectors arrive on the  
14 facility, they have more than just the preliminary  
15 safety analysis report to go by. They need to have  
16 what does the current design at the facility look  
17 like?

18           So all of these design changes should be  
19 documented, whether it's been submitted to the NRC  
20 within the six-month interval. That should be  
21 available on site so that inspectors can look at that.  
22 And it's expected that they will be keeping this  
23 documentation up to date on site even if they haven't  
24 submitted it to the NRC. Part of the selection of the  
25 six-month interval is to try to allow the applicant to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 focus on their design changes instead of being  
2 burdened with administrative preparation of documents.  
3 So while they may not submit every six months, the  
4 expectation is that this information is continuously  
5 updated and available on site for inspectors to look  
6 at in the preparation of their inspections.

7 MEMBER KIRCHNER: This implies then you  
8 have dedicated staff to this while they're doing the  
9 construction --

10 MR. LYNCH: We do have --

11 MEMBER KIRCHNER: -- not just the  
12 inspectors, but criticality experts, etcetera?

13 MR. LYNCH: Yes, we do have staff both in  
14 NMSS for -- that are criticality experts that are  
15 supporting us and providing ongoing support. We also  
16 have staff out of Region II, inspectors that are  
17 helping us develop inspection plans. And we meet  
18 monthly to discuss the updates of what we've been  
19 looking at in preparation for construction --

20 (Simultaneous speaking.)

21 MEMBER KIRCHNER: What I'm just probing is  
22 this requires a commitment from you. You asked for  
23 this information on this interval. They're on a  
24 rather fast track schedule. It's going to require a  
25 responsiveness by the regulatory group.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. BALAZIK: Yes, sir. And one thing I'd  
2 like to add to Steve's point is there's also a  
3 termination for both of these licensing conditions.  
4 Basically when Northwest submits the final design,  
5 these can go away because we have all the information.  
6 We have their final design and we can start reviewing  
7 it. So both of these licensing conditions, I use the  
8 word "terminate" once they submit their FSAR or  
9 operating license also.

10 All right. So we talked about technical  
11 license conditions. The third one is more  
12 administrative. Now Northwest is required to have a  
13 Quality Assurance Program in accordance with 50.34,  
14 however, Appendix B of Part 50 does not apply to them.  
15 So this licensing condition kind of holds Northwest to  
16 their Quality Assurance Program. And if they make  
17 changes to that Quality Assurance Program, they need  
18 to notify the NRC. And this licensing condition is  
19 similar to the requirements in 50.55(f) for  
20 implementing approved change to a Quality Assurance  
21 Program, which is applicable to power reactors and  
22 fuel processing permit holders.

23 And I'll say that during our discussions  
24 in construction inspection in lessons learned we kind  
25 of came up with this licensing condition to hold them

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to their quality assurance, because it's the basis for  
2 construction and if they're changing it, we want to  
3 know.

4 MR. ADAMS: And this is one of the first  
5 areas where the inspectors will focus to verify that  
6 this Quality Assurance Plan is up and running and  
7 being effective.

8 MEMBER KIRCHNER: So much is made of the  
9 fact that this is not -- Appendix B is not applicable,  
10 but I scratch my head in a sense because I can't  
11 imagine a Quality Assurance Program that you would  
12 accept that wouldn't essentially be the ANSI/ASME  
13 standard, and hence the 18 parts to the program,  
14 etcetera.

15 MR. LYNCH: If you look at our --

16 MEMBER KIRCHNER: So I assume you're --

17 MR. LYNCH: The ANSI standard, yes.

18 MEMBER KIRCHNER: You're going to the ANSI  
19 standard, right?

20 MR. LYNCH: Correct, ANSI Standard 15.8 if  
21 you compare it to Appendix B, there's been a lot of --  
22 it's maybe 90 percent the exact same language, same  
23 criteria.

24 MEMBER KIRCHNER: It's derivative of  
25 the --

1 MR. LYNCH: But what the differences are  
2 it acknowledges that staffing at these facilities may  
3 be different than at a large company and that the  
4 technology may be different as well.

5 MR. BALAZIK: It talks about experiments  
6 also --

7 (Simultaneous speaking.)

8 MEMBER KIRCHNER: We hear this also from  
9 new reactors, and I just again scratch my head and say  
10 but what's really different other than --

11 MR. ADAMS: Well, this -- so I'm on the  
12 ANS Standards Committee and this standard was written  
13 because Appendix B didn't apply. So there was a  
14 vacuum that needed to be filled in and it was filled  
15 in by the standard. And as Steve and Mike said, if  
16 you read the standard, you're going to see a lot of  
17 parallels to Appendix B.

18 MR. BALAZIK: All right. Real quick I  
19 just want to go through Appendix A.4, which is the  
20 regulatory commitments identified through ACRS  
21 Subcommittee meetings. I'll just touch on the first  
22 item; Northwest mentioned this earlier, is the  
23 seismic, about the high-frequency impact to the site.

24 And on the next one I just want to touch  
25 upon the third one which will reexamine the accuracy

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of its estimates for aircraft takeoff and landings at  
2 the Columbia Regional Airport. That's another item.  
3 And I want to talk about that real quick.

4 So during the Subcommittee meetings there  
5 were several errors that were identified in the  
6 Northwest aircraft impact analysis, so the staff  
7 performed a confirmatory analysis. And see the table  
8 below with Northwest compared to the NRC staff, that  
9 the total impact frequency calculated by the NRC staff  
10 is on the same order of magnitude calculated by  
11 Northwest and that the staff concludes that Northwest  
12 should evaluate the impact of a general aviation  
13 crash.

14 And the reviewer for this identified a lot  
15 of errors: inconsistent flight operations; and these  
16 were brought up during the Subcommittee meeting,  
17 incorrect crash rates for specific aircraft,  
18 inconsistent non-airport crash frequencies. And then  
19 there was just errors between tables. In other words,  
20 the information was developed and the incorrect  
21 information was put in another table. But we came  
22 relatively close to what Northwest had on their total  
23 aircraft impact frequency.

24 So captures in A.4 that Northwest will  
25 examine and ensure. I kind of already mentioned this.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 And Northwest commits to resolve all the discrepancies  
2 in the data during the final design and be operating  
3 license application. And the staff will further  
4 review that the aircraft impact analysis and the FSAR  
5 to ensure that these deficiencies are corrected.

6 MEMBER STETKAR: Mike, this morning you  
7 highlighted the aircraft crash, but we had quite a bit  
8 of discussion certainly about the aircraft crash, but  
9 we also had discussions about the analysis of  
10 pipeline accidents where the staff has not identified  
11 a pipeline that's in fact closest to the facility. We  
12 also had discussions about highway accidents and the  
13 methodology and values that were used to quantify the  
14 frequency of those highway accidents.

15 It's my understanding that Northwest is  
16 going to re-perform all of those analyses, not just  
17 the aircraft crash. You highlighted the aircraft  
18 crash this morning as something that's continuing, but  
19 that all of those kind of -- I'll throw them in the  
20 ballpark of manmade external hazards, if you will --  
21 will be revisited for the operating license, at least  
22 the three that I mentioned: the pipeline, the highway  
23 transportation and the aircraft.

24 And the reason that I focused on these is  
25 that this is an area where there is guidance and there

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 are -- I hate to use the word "criteria." There are  
2 values that are applied where if during the  
3 construction permit application process and review the  
4 applicant can justify, for example, that based on  
5 their analyses the frequency of an aircraft impact is  
6 less than 10 to the minus 7 per year, that will not be  
7 revisited. I mean, that's something that the staff  
8 does not reopen during the operating license process  
9 because it's a conclusion that's made.

10 And that's one of the reasons why I think  
11 that we focus during the Subcommittee meetings on  
12 those issues, because quite frankly it's not fair to  
13 them to come back and say, oh, wait a minute, what's  
14 -- let's redo an analysis that the staff has already  
15 accepted that meets some sort of criteria, a site-  
16 related analysis. So that was one of the reasons that  
17 we paid particular attention, the errors and omissions  
18 notwithstanding.

19 MR. ADAMS: And again, taking --  
20 approaching the operating license from a clean look at  
21 things, we will take another look at the site  
22 criteria.

23 MR. BALAZIK: Just real quick I want to  
24 mention the status of the Northwest review. As of  
25 October of this year Northwest has adequately

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 responded to all requests for additional information.  
2 also PSAR Rev. 3 is in ADAMS. It was put in ADAMS on  
3 September 14th, 2017, and there's the ADAMS accession  
4 number for that.

5 The final Environmental Impact Statement  
6 was published in May of 2017 in NUREG-2209. And the  
7 Safety Evaluation Report is in concurrence and the  
8 staff is set for issuance of that in November 2017.  
9 As of right now the mandatory hearing for the  
10 construction permit is scheduled for January 23rd of  
11 next year.

12 I just kind of want to go through these  
13 relatively quick because I know we're running behind,  
14 but just talk about a couple of the findings.

15 MEMBER POWERS: We're in fine shape.

16 MR. BALAZIK: We're okay? Okay. All  
17 right.

18 MEMBER POWERS: Yes, take your time.

19 MR. ADAMS: Thank you.

20 MEMBER POWERS: I know you want to get out  
21 of here.

22 (Laughter.)

23 MEMBER POWERS: But Al tells us that he is  
24 so happy to be here that I don't want to deprive him  
25 of a single minute of the pleasure that he's providing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to --

2 MR. ADAMS: Full happiness.

3 MEMBER POWERS: Yes.

4 MR. BALAZIK: All right. So for the  
5 regulatory basis for the construction permit the  
6 following findings need to be made based on 50.35,  
7 that the facility design has been described including  
8 the principal design and engineering criteria for the  
9 design. The technical and design information that may  
10 be required to complete the safety analysis can be  
11 reasonable left for later. And that safety features  
12 or components requiring research and development have  
13 been identified and they will be conducted in a  
14 Research and Development Program designed to answer  
15 these questions. And that all safety questions will  
16 be resolved prior to completion of construction of the  
17 proposed facility. Also there's some conclusions that  
18 we need to make in 50.40 and 50.50, and we'll talk  
19 about those in a second.

20 So for 50.35(a)(1) the facility design has  
21 been described. The staff evaluated the preliminary  
22 design to ensure sufficiency of the principal design  
23 criteria, design bases, materials of construction,  
24 general arrangement, and approximate dimensions.  
25 Also, when necessary if the staff needed more

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 information, it was requested. And the staff finds  
2 that there is reasonable assurance that the final  
3 design will conform to the design basis, provide an  
4 adequate margin for safety, provide for the prevention  
5 and mitigation of accidents, and meets applicable  
6 regulatory requirements and acceptance criteria.

7 35(a)(2) findings, that such technical or  
8 design information may be required to complete the  
9 safety analysis can be left for later consideration.  
10 Staff evaluated the sufficiency of the preliminary  
11 design of the production facility based on Northwest's  
12 design methodology and ability to provide reasonable  
13 assurance that the final design will conform to the  
14 design basis with adequate margin of safety.

15 Throughout the PSAR and in response to the  
16 RAIs Northwest has indicated that there are areas that  
17 require further technical design information. And the  
18 staff is tracking all these items as I mentioned  
19 earlier in Appendix Alpha. So staff finds that  
20 Northwest has provided reasonable assurance that  
21 further technical or design information can reasonably  
22 be left for the submittal of the FSAR.

23 The 50.35(a)(3) finding, which is safety  
24 features or components requiring research and  
25 development. Northwest has identified four research

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and development activities, and they're documented in  
2 the appendix. Irradiation and corrosion testing.  
3 There was some resin testing, ion column pressure  
4 relief testing, and the evaluation release of -- I'm  
5 just going to call it DAP from the ion exchange column  
6 during operation.

7 Staff finds that Northwest has adequately  
8 described Research and Development Program and that  
9 additional information needed on certain matters  
10 related to nuclear criticality safety, and these were  
11 included in the licensing conditions.

12 For the (a)(4) finding that there's  
13 reasonable assurance that safety questions will be  
14 satisfactorily resolved at or before the latest date  
15 specified in the application for completion of  
16 construction. Right now the date, the latest date for  
17 construction is December 31st, 2022. So based on  
18 research and development schedules Northwest expects  
19 to resolve these safety questions prior to completion  
20 of construction. And also that the permit conditions  
21 must be satisfied prior to completion of construction.  
22 And that's more for the two criticality licensing  
23 conditions.

24 Staff finds there's reasonable assurance  
25 that Northwest's research and development activities

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 will be satisfactorily completed at or before the  
2 latest date of completion of construction of the  
3 production facility.

4 Another one of the findings is that there  
5 is reasonable assurance that taking into consideration  
6 site criteria contained in 100 that the proposed  
7 facility can be constructed and operated at the  
8 proposed location without undue risk to the health and  
9 safety of the public. So while -- we kind of  
10 mentioned this earlier about the Part 100 site  
11 criteria not applying to this facility, but we  
12 considered similar site-specific conditions in SER  
13 chapter 2, and also in SER chapter 3.

14 Staff confirmed that chapters 11 and 13 of  
15 radiological releases during normal and accident  
16 scenarios would be within the Part 20 limits based on  
17 the reviews of applicant's use of 10 CFR Part 70  
18 integrated safety analysis methodologies.

19 MEMBER KIRCHNER: May I ask my question  
20 from earlier again? When staff confirmed, you  
21 confirmed methodologies or you independently did a  
22 calculation of the bounding source terms that then are  
23 used to demonstrate that you're within the 10 CFR Part  
24 20 limits? And which could did you use, if you did  
25 it?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. LYNCH: So at this time we did focus  
2 on confirming methodologies.

3 MEMBER KIRCHNER: In other words, what  
4 code they're going to use to calculate the source  
5 term? They actually did estimates of the -- of a  
6 bounding source term.

7 MR. BALAZIK: Well, I know that the code  
8 was looked at. I know that we looked at inputs, but  
9 right now we just looked more of the methodology that  
10 they used and did not do an independent confirmatory  
11 calculation.

12 MEMBER KIRCHNER: I guess I'm surprised  
13 because chapter 13 hangs on coming in within this  
14 bounding estimate that they provided you. Otherwise,  
15 you're just checking process. I know they have a nice  
16 thorough listing of all accident categories and such,  
17 but that's more a process than actually confirming.

18 MR. ADAMS: I think there were some  
19 calculations done. I'd have to go and take a look at  
20 the SER. Unfortunately that technical reviewer  
21 couldn't be with us today. I'll try to take a look  
22 and see.

23 MEMBER KIRCHNER: And, Al, when you look  
24 at that, could you also inquire which code you used?  
25 That's a leading question for --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. ADAMS: Yes.

2 MEMBER KIRCHNER: -- our research review.

3 Thank you.

4 MR. NAQUIN: I'm Ty Naquin. I did the RP  
5 review for chapter 11. I can't speak for chapter 13,  
6 but for the normal operating conditions I used the  
7 RASCAL code for assessing what they've done and found  
8 that they were consistent.

9 MEMBER KIRCHNER: Thank you.

10 MR. BALAZIK: So this is our last slide.  
11 As I mentioned earlier, there were some other  
12 regulations: 50.40, 50.50 considerations, and these  
13 are that the construction of the facility will not  
14 endanger the health and safety in the public and that  
15 construction activities can be conducted in compliance  
16 with the Commission's regulations, that Northwest is  
17 technically and financially qualified to engage in  
18 construction and the issuance of the construction  
19 permit will not be inimical to the common defense and  
20 security of the health and safety of the public, and  
21 that the application meets the standards and  
22 requirements of the Atomic Energy Act and the  
23 Commission's regulations.

24 And with that, that ends the staff's  
25 presentations, and I guess we'll open it up for more

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 questions.

2 MEMBER POWERS: Do any of the members have  
3 any additional questions?

4 (No audible response.)

5 MEMBER POWERS: I don't see anybody with  
6 additional questions. We have now a protocol for  
7 calling out comments from the audience. Are there  
8 anybody in -- is there anybody in the audience that  
9 would care to make a comment?

10 (No audible response.)

11 MEMBER POWERS: I don't see a massive rush  
12 to the phone.

13 We now have a protocol for people making  
14 a comment on the line, and I don't remember what that  
15 is, so I will defer to Mr. Bley to go through that  
16 litany.

17 CHAIRMAN BLEY: The protocol is simply to  
18 ask if someone on the line would like to make a  
19 comment. identify yourself and make your comment,  
20 please.

21 MS. THOMAS: Does that include members of  
22 the public?

23 CHAIRMAN BLEY: Absolutely. Please go  
24 ahead.

25 MS. THOMAS: This is Ruth Thomas and I was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 -- had some questions about what this is based on,  
2 like what the pilot is or the model. Is this based on  
3 other facilities that have done recovery of molybdenum  
4 like there was in Canada?

5 CHAIRMAN BLEY: Ruth, this is a time just  
6 for public comments, so we -- it's for our gathering  
7 information, not a time for the public to ask  
8 questions. I'm sorry. If you have any comment  
9 though, we'd be glad to consider it.

10 MS. THOMAS: I thought you were asking for  
11 anybody's questions.

12 CHAIRMAN BLEY: Not questions. Just  
13 comments. But if there are things you'd like us to  
14 consider, please tell us and we will consider them in  
15 our deliberations.

16 MS. THOMAS: Oh, you mean it should be in  
17 the form of a comment --

18 CHAIRMAN BLEY: That's right.

19 MS. THOMAS: -- instead of a question?

20 CHAIRMAN BLEY: That's correct.

21 MS. THOMAS: Well, the comment that I have  
22 is it's not clear what the basis for all this is. Is  
23 this completely new -- let's see, how can I form that  
24 as a statement? That this is not -- this is new  
25 technology.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BLEY: All right. Thank you. We  
2 will consider that. Anything else? Or there anyone  
3 else on the line who would like to make a comment?

4 (No audible response.)

5 CHAIRMAN BLEY: Dr. Powers, are you  
6 complete?

7 MEMBER POWERS: Thank you, Mr. Bley, You  
8 admirably carried out our protocol.

9 CHAIRMAN BLEY: Thank you, Dr. Powers.

10 MEMBER POWERS: I thank the staff. It was  
11 a very useful presentation. I thank the applicant.  
12 An equally useful presentation.

13 Mr. Bley, I turn the meeting over to you.

14 CHAIRMAN BLEY: Thank you very much.

15 At this time we will take a break for 15  
16 minutes. You're ready to go through the letter, sir?

17 MEMBER POWERS: We want to make some  
18 adjustments to the letter, so we may not be instantly  
19 ready, but shortly.

20 CHAIRMAN BLEY: Fifteen-twenty minutes  
21 enough?

22 MEMBER POWERS: I think so.

23 CHAIRMAN BLEY: We will come back at 10:30  
24 to reconvene, but we are off the record until 1:00.

25 (Whereupon, the above-entitled matter went

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 off the record at 10:07 a.m. and resumed at 12:59  
2 p.m.)

3 CHAIRMAN BLEY: We are back in session for  
4 the afternoon. Just a reminder to everybody, since we  
5 didn't go into closed session, the webcast continues  
6 this afternoon.

7 I'm going to turn the meeting over to Mr.  
8 Stetkar at this time for the SOARCA discussion.

9 MEMBER STETKAR: Thank you, Mr. Chairman.  
10 I'll keep this brief. For those of you who have not  
11 been around for the last decade, this is the third  
12 installment of the SOARCA series, the Sequoyah plant.  
13 We've been reviewing this material at the subcommittee  
14 level for almost a year and a half. We had meetings  
15 back in May of last year, June of this year, and  
16 latest one of October of this year. And we'll let the  
17 staff explain the current status of the project, and  
18 I'll turn it over to Pat Santiago from Research. Pat.

19 MS. SANTIAGO: Thank you. Good afternoon.  
20 I'm Pat Santiago. I'm Chief of the Accident Analysis  
21 Branch in the Office of Nuclear Regulatory Research,  
22 and today I have with me Dr. Hossein Esmaili from the  
23 Fuel and Source Term Code Development Branch and Dr.  
24 Tina Ghosh also with the Accident Analysis Branch who  
25 will be presenting.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           We appreciate all the feedback, as Dr.  
2           Stetkar indicated, over the last year and a half and,  
3           in particular, from the October 18th, 2017  
4           subcommittee review meeting. The SOARCA team has been  
5           working diligently over the last number of months to  
6           respond and address many of the comments that were  
7           provided to us, and we continue to work on them.

8           I want to acknowledge once again the  
9           numerous team members that have supported and  
10          contributed to this Sequoyah SOARCA project. We have  
11          a slide toward the end of the briefing that lists  
12          these team members, and we have a handful of them in  
13          the audience here from NRC, as well as Sandia, and we  
14          have several on the bridgeline.

15          As a short outline for today's  
16          presentation, I'm going to do an overview and I'll  
17          discuss the uses of the SOARCA modeling, and Hossein  
18          will discuss the Sequoyah short-term station blackout  
19          analysis, and Tina will discuss lessons learned, and  
20          then we'll conclude.

21          This slide provides a quick overview. We  
22          had several goals and objectives for the SOARCA  
23          project when we initiated it. John says ten years  
24          ago. I wasn't here ten years ago, but we'll give you  
25          that. I'm sure it has --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           MEMBER STETKAR: I was surprised. I was  
2 looking it up, and I didn't go way back, but I know  
3 the last letter that the ACRS wrote on it was 2012,  
4 which is five years ago, and it was --

5           MS. SANTIAGO: And I joined the team in  
6 late 2010, I think. But it's been a heroic effort, I  
7 have to say. So I've listed two key goals and  
8 objectives we had for the SOARCA project. And for the  
9 Sequoyah analysis, we had two additional objectives.  
10 One was to also develop knowledge on how the ice  
11 condenser containment design responds in severe  
12 accidents, as well as develop technical insights to  
13 support the Agency's Near-Term Task Force (NTTF)  
14 recommendations, specifically 5.2 which was related to  
15 reliable venting for other than Mark I and II  
16 containments and 6 related to hydrogen control and  
17 mitigation.

18           After the completion of the Peach Bottom  
19 and Surry pilot plant analyses in 2012, staff had  
20 recommended a limited analysis for this third plant  
21 with an ice condenser containment, as well as a  
22 scenario for Surry uncertainty analysis in order to  
23 extend the BWR uncertainty analysis insights to a PWR  
24 with a large dry containment.

25           And the Commission approved the staff

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 recommendations in SRM-SECY-2012-0092, noting that  
2 these additional limited analyses should complement  
3 and support the Level 3 probabilistic risk assessment  
4 project and certain NTF activities. The Surry UA is  
5 helping the Level 3 PRA project by identifying key  
6 sources of uncertainty, and the Sequoyah analysis has  
7 helped generate the technical basis for staff's  
8 closure of the NTF recommendations 5.2 and 6.

9 Our Sequoyah analysis is going to be  
10 published as NUREG CR and is due to the Commission on  
11 November 30th. We also will be sending that report to  
12 publications at the same time.

13 It's essential, I think, to identify the  
14 importance of the SOARCA methodologies and analyses  
15 that we've been conducting over the last number of  
16 years. These analyses and approved models have  
17 supported numerous Agency activities, and we  
18 appreciate the ACRS's recommendations over the years  
19 and the review of this project, as well as the  
20 research program. And you've encouraged the NRC to  
21 focus on modernizing the severe accident analysis  
22 codes and accelerate efforts to implement improved  
23 models, which we are doing.

24 The list on this slide and the next is not  
25 comprehensive, but I've tried to categorize the work

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and how essential it is to support the Agency's safety  
2 and security mission. Some general categories include  
3 technical bases, licensing reviews, informing severe  
4 accident guidelines, and insight for emergent issues  
5 as was done during the Fukushima event.

6 Most recently, the newer MELCOR MACCS  
7 models were used for the containment protection and  
8 release reduction analysis, which I think you also  
9 were briefed on about a year ago. And MACCS is  
10 currently being used to support the economic cost  
11 benefit analyses performed for regulatory analysis and  
12 updates to that guidance. We use these models to  
13 understand what's occurring so we can answer the  
14 questions to the best of our current knowledge and  
15 capability, and there's still more work to be done.  
16 As you know, we'll be seeing you in another two weeks  
17 on the Level 3 PRA.

18 In future analyses that we looking to  
19 consider, we're considering the new small modular  
20 reactor designs due to the single and multiple module  
21 issues that affect accident progression, mitigation,  
22 emergency planning, and off-site consequences. And  
23 we've had several questions that have come out of the  
24 topical report reviews we've done.

25 This slide talks again about the work

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 we've used the MELCOR MACCS models for in support of  
2 the response to the Fukushima events. The SOARCA  
3 analyses are used in our training classes provided at  
4 the NRC. We understand industry also offers training,  
5 and they use these different analyses.

6 We have international groups also pursuing  
7 SOARCA-like studies. Korea Hydro and Nuclear Power  
8 Company is completing a SOARCA-like effort on the  
9 APR1400 design at the Shin Kori site, and we're  
10 following that, as well.

11 So to better understand these new designs,  
12 our staff benefit by these analyses for knowledge,  
13 development, and to maintain core competencies in  
14 severe accident capabilities. In the mid-2000s, our  
15 capability was limited, and after 2010 it has  
16 improved. And, yet, as you realize, it's not a  
17 technical expertise that you can really develop  
18 easily. We really need to maintain this capability  
19 since you can't develop it in the middle of an  
20 emergency.

21 In light of this, we continue to support  
22 a lot of accident knowledge management initiatives,  
23 and we are continuing to engage in domestic and  
24 international activities.

25 At this time, I'd like to turn it over to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Hossein to talk about the short-term station blackout.

2 MR. ESMAILI: Okay. So this is just, as  
3 a reminder, an overview of the high-level observation  
4 we made back in, I guess June it was and also last  
5 month. I wanted to give you what are the things that  
6 stand out and, you know, how these things are  
7 controlling what we are seeing in terms of overall  
8 conclusions.

9 The first one is intuitive. The  
10 consequences are strongly dependent on early versus  
11 late containment failure, so later failures are less  
12 consequential. But the next three bullets in terms of  
13 hydrogen combustion and the behavior of the safety  
14 valves are more interesting, and this is the one that  
15 we are going to focus on.

16 So the second bullet is saying early  
17 containment failure occurs only under forced hydrogen  
18 burn. So we have to remember this, as I go through  
19 the slides, is that the subsequent hydrogen burns do  
20 not have enough hydrogen or energy to fail the  
21 containment. So you either get it at the first burn  
22 or you're going to have later burns that are not  
23 sufficient to cause the containment to fail. So this  
24 is important.

25 So bullet number three is kind of related

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to this. When you have protracted safety valve  
2 cycling, that means that the safety valve is cycling  
3 up to the time of hot leg failure, etcetera. In  
4 general, you are producing lower in-vessel hydrogen by  
5 the time of the first phase, so this is tied to how  
6 much hydrogen we produce by the time we burn it.

7           There are a number of reasons for it. You  
8 know, we can go through some of the calculations. The  
9 core heat-up is actually slower. There is more  
10 efficient heat transfer from the core to the  
11 boundaries to the hot leg in particular, and there is  
12 less temperature difference between the core and hot  
13 leg, and this is the same as a high pressure. So the  
14 creep rupture occurs relatively soon, and the hydrogen  
15 is less. So at that time, you know, you have  
16 accumulator injection that kind of arrests, you know,  
17 whatever oxidation that you're going to get after  
18 that.

19           On the other side, if the pressurizer  
20 fails to close, you have, you know, depressurization  
21 of the primary system, what happens is that you have  
22 longer time, you produce more hydrogen, there is more  
23 steam available to produce hydrogen, and there's  
24 access to the steam. And as the system is  
25 depressurizing, accumulators can intermittently inject

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 so there is fresh water for oxidation. So in these  
2 cases, when we have pressurization of the primary  
3 system, we produce more hydrogen. At the same time,  
4 because now the system is at lower pressure, we have  
5 to get these things hotter for any failure of the  
6 pressure boundary.

7 VICE CHAIRMAN CORRADINI: So can I just  
8 say it back to you on two, three, and four? Because  
9 I'm trying to key on a couple of key events. But the  
10 key event is the accumulator discharges. My  
11 impression of three and four is that, if I have held  
12 it at a high enough pressure, I don't get essentially  
13 a fresh supply of water, or is it more than that?

14 MR. ESMAILI: No, if you have -- so the  
15 third bullet is that you are cycling at system  
16 pressure, 16 megapascal, until your hot leg fails. So  
17 you don't have any accumulator injection in these  
18 cases. At that point, you have a sudden injection of  
19 the accumulator.

20 By that time, by that time, when this  
21 happens, and I think this one was what Casey showed  
22 you last time, is that you have lower in-vessel  
23 hydrogen generation and, at the same time, the core is  
24 relatively intact. So you are heating up the --

25 MEMBER STETKAR: Well, but, also, Hossein,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the hydrogen that was generated, by definition, burns  
2 when the hot leg fails, so you get no further  
3 accumulation anywhere.

4 MR. ESMAILI: Right, yes. So the hydrogen  
5 that is -- it can go out, but most of the hydrogen is  
6 actually bottled up inside the RPV. And then when the  
7 hot leg fails, it just rushes up. But by that time,  
8 you already have an ignition source, which is the hot  
9 leg --

10 MEMBER STETKAR: Yes, and it burns.

11 MR. ESMAILI: Yes, and it burns. I don't  
12 know whether that answered your --

13 VICE CHAIRMAN CORRADINI: Well, my way of  
14 thinking about things are physical events that lead me  
15 up a certain branch point. And so the branch point  
16 for four is that -- I'm sorry -- for three, excuse me,  
17 is that I don't get a depressurization early due to  
18 safety valve. They keep on cycling --

19 MR. ESMAILI: Just keep on cycling.

20 VICE CHAIRMAN CORRADINI: -- so that I,  
21 when I do get it, I get an ignition source just where  
22 I'm essentially releasing.

23 MR. ESMAILI: Right.

24 VICE CHAIRMAN CORRADINI: So it's a  
25 combination of no extra water early and an ignition

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 source when I do get the hydrogen out into  
2 containment.

3 MR. ESMAILI: Right.

4 VICE CHAIRMAN CORRADINI: Okay.

5 MR. ESMAILI: And during this process --

6 VICE CHAIRMAN CORRADINI: Adversely, in  
7 four, I get it open early, I get more water, and look  
8 out.

9 MR. ESMAILI: Right. It's a little bit  
10 more into it because when you have lower in-vessel  
11 hydrogen, when it's cycling, you're actually  
12 transferring more heat more efficiently to the hot  
13 leg. So heat is just inside the vessel, and then you  
14 have less time from the time that hydrogen generation  
15 occurs until you have the hot leg failure and the  
16 hydrogen burn. So we have to keep these three in mind  
17 that these are the big items that actually we were  
18 focusing on.

19 VICE CHAIRMAN CORRADINI: And so now can  
20 I take bullets three and four and connect them to two,  
21 given that we --

22 MR. ESMAILI: Yes, yes.

23 VICE CHAIRMAN CORRADINI: -- think we --

24 MR. ESMAILI: That's the --

25 VICE CHAIRMAN CORRADINI: -- three and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 four. When I have an early cycling failure, that then  
2 drives it --

3 MR. ESMAILI: Right.

4 VICE CHAIRMAN CORRADINI: Okay.

5 MR. ESMAILI: So, actually, I'm going to  
6 go to slide number -- so the last one is tied to the  
7 first two, you know, the leg containment failure are  
8 less consequential and you have more time for fission  
9 products to settle.

10 So next slide, please. Okay. So this one  
11 I have already shown you. This is trying to capture  
12 what I said in that, what I said before about bullets  
13 two, three, and four, that when you are depressurizing  
14 you are producing more hydrogen. You have more time.  
15 You have more time to vent this hydrogen into the  
16 containment. So by the time you have a failure or you  
17 have an ignition source that becomes available, then  
18 you have enough hydrogen to fail the containment.

19 On the left-hand side, you know, less than  
20 about 300, those are the high-pressure cases. The  
21 system is cycling that high pressure. So everything  
22 to the left of the figure, you know, everything to the  
23 left of the figure are high-pressure cases, everything  
24 to the right of the figure are low-pressure cases.

25 And what we found out in the new

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 uncertainty analysis is that we have less points  
2 because of this behavior of the safety valves. And I  
3 have to say this because we discussed extensively last  
4 time, and Tina was on the hot seat. So we have  
5 limited data. This does not allow high confidence in  
6 terms of the distribution for safety failure. So you  
7 can see in the draft UA we had 62 percent of the cases  
8 leading to failure to close. In the new one, we only  
9 have 4 percent.

10 But what it does show us is that if we  
11 know how these safety valves behave, I know where I'm  
12 going to be in --

13 MEMBER STETKAR: Hossein, I'll try to be  
14 good. To me, the evolution of this information, going  
15 from the bar on the left to the bar on the right,  
16 shows the importance of doing a realistic integrated  
17 engineering uncertainty analysis because the only  
18 difference in these results is driven by the  
19 uncertainties. It's not driven by the valve failure  
20 rate. The valve failure rate, the fundamental valve  
21 failure rate has remained essentially the same. It's  
22 the change in the uncertainty and the uncertainty in  
23 the size of the open area, given the fact that it does  
24 fail to re-close. And that's, I think, one of the  
25 messages from this study that's really important, that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 the uncertainty analysis is integral to the results.  
2 It's not something that's an afterthought that you  
3 say, well, I do the analysis with something that I'll  
4 call a number -- I won't give it a characterization --  
5 and then, as an afterthought, do the uncertainty  
6 analysis and say, okay, I did an uncertainty analysis.  
7 It honestly has had a measurable, a measurable effect  
8 on the results of the study and the conclusions that  
9 you've drawn from the study.

10 MR. ESMAILI: Absolutely. I 100-percent  
11 agree.

12 MEMBER STETKAR: So regardless of, you  
13 know, what the level of uncertainty is and what the  
14 actual failure rate might be, I think it's something  
15 that we've collectively learned over the last couple  
16 of years that we've been looking at this, this  
17 particular study.

18 MR. ESMAILI: And this is very helpful for  
19 us as we try to understand these accidents. Now,  
20 remember during the Fukushima that people were having,  
21 you know, opening up the SOARCA, you know, for Peach  
22 Bottom and trying to see where we are. So this type  
23 of analysis, this is a very simple map that tells you  
24 if I'm in this space, you know, maybe I am producing  
25 less hydrogen. So I can go ahead and check against

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 other measurements, etcetera. So it's useful in a  
2 number of ways.

3 And the reason we did this, actually, is  
4 that we were struggling to describe what happens  
5 because we had less failures this time compared to the  
6 last time. But everything falls into place.

7 So on the next figure, so this one we  
8 didn't show last time, but I added the beginning of  
9 the cycle and then I superimposed the long-term  
10 station blackout. And here I just wanted to make a  
11 point that, so this is all the current UA. And in the  
12 insert, you see the K curve. So you see the  
13 clustering of the yellow and the pink on the left-hand  
14 side of the figure. This is where the decay heat are  
15 more similar, and it takes -- so, basically, when you  
16 have the decay heat lower, you know, it takes a lot  
17 longer time for it to boil off and heat transfer,  
18 etcetera. And then when you see the middle of cycle  
19 and the end of the cycle, you know, those behave, more  
20 or less, the same. So the green and the blue behave  
21 similarly in this figure because you have the same  
22 decay curve, and the yellow, which is the beginning of  
23 the cycle, and the pink behave more similarly.

24 The other thing I wanted to show you is  
25 that this came up a few times last time, but you see

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 there are some beginning of the cycle, there's some  
2 guys sitting over there in the 400 region. And we did  
3 not get any early containment failure from the  
4 beginning of cycle cases, but this one clearly shows  
5 that it is quite possible. There are cases that could  
6 lead us to vessel depressurization and put us in the  
7 region that we can -- it's just that we didn't have  
8 enough samples.

9 MEMBER STETKAR: You're not going to talk  
10 about the focus study. You picked up a few beginning  
11 of the cycle --

12 MR. ESMAILI: Right.

13 MEMBER STETKAR: -- cases when you looked  
14 in that regime.

15 MR. ESMAILI: Yes, yes. So I'm going to  
16 get into that later. But this is, what it shows that  
17 -- and, actually, the shape of the curve is also  
18 important. As you can see, you go to the left, it's  
19 trying to go towards infinity, you know, because  
20 you're producing less hydrogen, so, obviously, you  
21 don't have time. Deflagration is going to go up.

22 Next slide, please. All right. So here  
23 is the -- so we got questioned last time because of  
24 these code failures. So I want to say a few words  
25 about these code failures and try to convince you that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 this is not going to change our overall conclusions,  
2 and I think my last takeaway from the last meeting was  
3 that use engineering judgment in trying to explain.  
4 And this is what we have been trying to do because of  
5 the, you know, the time limitation.

6 So just to give you a little bit of  
7 background, for each uncertainty analysis that we do,  
8 what the code development team does is it looks at the  
9 input deck and looks at the code and tries to shake  
10 down the input model, the code, etcetera, and the aim  
11 is actually to reduce errors to lead to code failure  
12 because, once you submit 600 cases, then it's out of  
13 your hands. We don't want to go back and try to baby  
14 each one of these realizations.

15 So during this process, our focus is on  
16 the common-cause failures. And I think you pointed  
17 out that, whether it's in this region or whether in  
18 the focus study, when we are in this high hydrogen  
19 cases, you know, to the right of the figure, we have  
20 more failures, as opposed to when we are to the left  
21 of the figure because in this one we are producing  
22 more hydrogen, the core is more damaged, your  
23 accumulators are injecting, etcetera. So it's more  
24 challenging to do the calculations, so we expect more  
25 errors.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER STETKAR: Hossein, just before we  
2 get too much into the details here, not all of our  
3 members attended all of the subcommittee meetings. So  
4 what Hossein is trying to address here is there was an  
5 observation that, round numbers, about 40 percent of  
6 the MELCOR attempted realizations in the area that  
7 he's going to focus on, in other words if I can call  
8 it a regime of the accident progression, about 40  
9 percent of the runs failed to complete. And that's  
10 kind of troubling because you don't necessarily know  
11 what might happen if those runs did go to completion.  
12 For the runs that did complete, a certain fraction of  
13 those runs went to early containment failure and  
14 another fraction didn't go to early containment  
15 failure.

16                   So the question is, well, number one, why  
17 didn't the runs complete? And number two, is there  
18 anything that can be done to infer what fraction of  
19 those runs that didn't complete would go to early  
20 containment failure? Is it the same fraction, or is  
21 it wildly different? That's just background for the  
22 folks who weren't here.

23                   MR. ESMAILI: Absolutely. But I just want  
24 to emphasize the point that I get a little bit  
25 defensive, I guess, when this 60-percent success rate.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 The overall success rate of these calculations that we  
2 did was 95 percent. So when we submitted 600 runs, we  
3 got 567 of them going to completion over three days.  
4 It was just in that particular region that the code  
5 had issues.

6 MEMBER STETKAR: If I tried to drive to  
7 the grocery store five times a day every day, and most  
8 of the time it's sunny and dry, I succeed most of the  
9 time. If it's really bad, then I might have a much  
10 higher failure rate. So counting up successes in the  
11 areas of the transient that are not necessarily  
12 challenging the code doesn't really --

13 MEMBER KIRCHNER: What was the source of  
14 failed to complete? I'm waiting to hear the answer  
15 why it didn't complete.

16 MR. ESMAILI: So as I said, as I said,  
17 these cases are challenging because the core is  
18 severely damaged. And so what you have is that you  
19 have, you have relocation of the core. At the same  
20 time, you have accumulator injection, etcetera.  
21 Sometimes, we have convergence problems because, you  
22 know, part of the core cell is occupied by a lot of  
23 molten material and particulate debris. And so you  
24 have to, this is nothing --

25 MEMBER KIRCHNER: What is it in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 physical modeling that prevents it from completing the  
2 run?

3 MR. ESMAILI: As I said, so --

4 MEMBER KIRCHNER: It's not the physics of  
5 what's happening. It's something in the calculational  
6 methodology.

7 MR. ESMAILI: Right. And then there could  
8 be some errors also. Remember, when we did the draft  
9 UA, we were able to go ahead and fix those errors, so  
10 we got a better success rate. Here, we did not think  
11 it was -- first of all, we didn't have time and  
12 resources to go back and do it, go back to Larry at  
13 Sandia and fix all of those cases that led to failure.  
14 The one that --

15 MEMBER KIRCHNER: When you first said  
16 failure to complete, I was thinking that the code was  
17 just grinding along and wasn't getting to an answer,  
18 and so you just truncated it after running so many CPU  
19 hours.

20 MR. ESMAILI: Yes, sometimes it tries to,  
21 it asks for lower and lower time steps because it  
22 cannot converge in one particular cell because there's  
23 not that much hydrodynamic volume. What we really do  
24 is that, if we are not doing uncertainty analysis,  
25 sometimes you are able to go back, change the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 parameters, iteration parameters, etcetera, change the  
2 time step and let the code move forward.

3 Sometimes, since this is systematic, since  
4 what we saw here is systematic that we saw also in the  
5 focused SV, that means that there must be some errors  
6 in how the relocation is occurring. So but --

7 MEMBER KIRCHNER: Errors in the code?

8 MR. ESMAILI: Errors in the card  
9 potentially.

10 MEMBER KIRCHNER: I think what you need to  
11 be careful about is separating out what's a numerical  
12 difficulty from the physical result, and I'm not  
13 getting quite the distinction.

14 MR. ESMAILI: And, again, as I said, we  
15 did not go back and look at every single one of these  
16 cases. Part of the reason was that now, when we did  
17 this calculation, we did these calculations with a  
18 certain version of the code. Now we are past that  
19 version. We have done multiple corrections to the  
20 code. So we were just making an engineering, you  
21 know, judgment. Do we want to go back and try to  
22 resolve all these cases. When I talked to Larry,  
23 Larry said, yes, we could, we could go back and those  
24 ten cases that you see here with the red, we could go  
25 back and look at all those individual cases and see

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 what happened and make them go to completion.  
2 Sometimes, it would be take, it would be a matter of  
3 maybe a few hours. Sometimes, it would take weeks to  
4 uncover what led to that failure. So we did not have  
5 the time and we did not think this would affect our  
6 overall conclusions, in terms of having, you know,  
7 what is the potential for early containment failure.

8 So what I'm showing you is that those red  
9 dots that I'm showing you right now, these are the  
10 phases that failed, that failed to run to completion  
11 because of the convergence problems, but they produced  
12 this much hydrogen by the time that the first  
13 deflagration occurred. So this is what engineering  
14 judgment comes in and see, you know, do we want to  
15 back to the earlier version of the code and debug it,  
16 or do we want to move forward and do this?

17 CHAIRMAN BLEY: Hossein, you seem  
18 reluctant to say we don't know.

19 MR. ESMAILI: Yes, we don't know. Yes,  
20 yes, we don't know because we didn't go back and --

21 CHAIRMAN BLEY: That's the first thing.  
22 The second thing is, and it's related to what Walt  
23 just asked, were these cases where it keeps trying to  
24 run, or did it actually stop running? Did it blow up  
25 on something --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. ESMAILI: That actually makes a very  
2 -- the code, most of the time, it has a number of  
3 iterations. For example, it says, you know, I have  
4 hit my number of -- I cannot move forward, I need  
5 lower time steps. Sometimes, if I'm not doing UA,  
6 sometimes, if I'm doing these things, I go back before  
7 it fails, I change the time step, and it changes the  
8 core relocation and I can go past it. This is what  
9 usually users do. They shake down the model. For the  
10 UA, we could do not do that, so we decided to look at,  
11 you know, start running it and see whether it makes  
12 any difference in our overall conclusions.

13 You are right, we don't know. We can go  
14 back and look at these things. We did not think that  
15 it was important because, by the time -- so the thing  
16 is if I wanted to answer how many early containment  
17 failures I have, I already know I have very, very few  
18 early containment failure cases because it's tied to  
19 how my safety valves behave. I'm already, in this  
20 case, I already have few cases. I have 23 of these  
21 cases that actually led, that went to completion, you  
22 know, in the 350 to 450 range. Out of this 23, four  
23 of them led to containment failure, early containment  
24 failure.

25 MEMBER STETKAR: Hossein, please, please,

1 this is a public record. Don't confuse the public  
2 record by saying 23 out of 300 or whatever. Twenty-  
3 three out of forty in the regime where it might have  
4 gone to containment failure completed. Twenty-three  
5 out of forty.

6 MR. ESMAILI: Yes, 23 out of 40. But what  
7 I'm saying is, out of this 23 that are in this range  
8 that could fail the containment, out of this 23, four  
9 of them, four of them actually led to early  
10 containment failure, meaning that, even out of this  
11 23, not all of them are going to lead to containment  
12 failure because what is important is that -- and we  
13 already know that -- what is important is how much  
14 hydrogen you produce --

15 MEMBER STETKAR: Hossein, I'm trying to  
16 get simple here without getting into jargon. Out of  
17 the 40 cases that had the right characteristics, a  
18 stuck-open safety valve with more than 30 percent open  
19 area, there were about 40 cases, as I recall.

20 MR. ESMAILI: Right.

21 MEMBER STETKAR: Twenty-three ran to  
22 completion. Four of them went to an early containment  
23 failure. Why do we have confidence that the 17 that  
24 did not complete, 17 did not complete, that the same  
25 fraction, 4/24, of those 17 would go to early

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 containment failure and not 17 out of 17 or 13 out of  
2 17? That's what we're trying to get at.

3 MR. ESMAILI: That's right. It's still a  
4 very, very low number, in terms of the overall --

5 MEMBER STETKAR: If it's 13 out of 17, it  
6 makes it four times the early containment failure  
7 frequency. The risk might still be very low, but it's  
8 four times higher.

9 VICE CHAIRMAN CORRADINI: Hossein, I think  
10 what John is getting at, let me ask his question a  
11 little differently. What if -- you assume 17 out of  
12 17. How does that change the uncertainty?

13 MR. ESMAILI: So you would have, if it's  
14 17 out of 17, you would have 20 early containment  
15 failure, as opposed to -- of the overall, it's still  
16 we are really, we are really limited by how the safety  
17 valves work. The uncertainty is on that, not in --

18 VICE CHAIRMAN CORRADINI: I understand  
19 that. But I think another way to say it or a way to  
20 say it is to bound the uncertainty on the failure to  
21 execute, that's the bound.

22 MR. ESMAILI: Right.

23 VICE CHAIRMAN CORRADINI: Okay.

24 MS. GHOSH: Can I just, I might be  
25 stealing Hossein's thunder, but I do want to address

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 this point of how many of the incomplete realizations  
2 may have gone to early containment failure. We've  
3 actually looked at that at this point because most of  
4 the incomplete realizations, as you can tell from  
5 Hossein's graph, this so far is only showing the  
6 integrated UA. We also did, we had 361 additional  
7 successful runs in the focused study --

8 MEMBER STETKAR: And 249 didn't succeed.

9 MS. GHOSH: That's right, so a lot of data  
10 points. And we've gone back and looked at those  
11 incomplete realizations, and most of them did run to  
12 first deflagration and the percentage that went to  
13 early containment failure at that first deflagration,  
14 which we already know, if you survive that first  
15 deflagration, then you survive to late containment  
16 failure, was exactly the same percentage as the  
17 completed.

18 MR. ESMAILI: So we can go to the next  
19 slide. This is coming on the next, at the next --

20 MS. GHOSH: Yes, I'm sorry to steal your  
21 thunder, but this was going and going. I just wanted  
22 to get that point out.

23 MR. ESMAILI: So this is, what the  
24 triangle that you see here, the triangles that you see  
25 here are the ones that traded the focused study. We

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 are still in the same space. That means that I'm  
2 still producing this much hydrogen. The phenomenology  
3 tells me that I have to produce this much of hydrogen  
4 and be able to transport it to the containment. There  
5 is no, there is nothing that tells me that the cases  
6 that failed -- by the way, these cases that failed,  
7 the red ones, they failed after you had the first  
8 hydrogen burn. So this is a very important fact.

9 MEMBER STETKAR: That's no news for us.  
10 How come we haven't heard this since May of this year?

11 MR. ESMAILI: Because I think it was  
12 stated last time. I think it just didn't register.  
13 So I wanted to, so --

14 MS. GHOSH: We didn't add it to the report  
15 yet that you got, so it's going to be, it's new  
16 information that will be in the final but,  
17 unfortunately, that we hadn't included in --

18 MEMBER STETKAR: I mean, even orally, we  
19 haven't heard this insight.

20 MR. ESMAILI: Yes, I think that was --

21 MEMBER STETKAR: And, quite honestly, it  
22 does not come through very clearly with a whole mess  
23 of little different-colored triangles. It just  
24 doesn't.

25 MR. ESMAILI: Right.

1 MEMBER SUNSERI: So could you say it again  
2 then?

3 MEMBER BALLINGER: Yes, restate it for the  
4 --

5 MR. ESMAILI: All right. So this is, so  
6 when I talked about those high-level observations, I  
7 said I have to get this much hydrogen, I have to get  
8 to the first burn. So when you see -- the triangles  
9 were the focused study. We only focused on the cases  
10 where we had system depressurization, where we knew we  
11 are going to be in a sample space where we could  
12 potentially have early containment failure.

13 So the purple triangles are the cases that  
14 actually went to completion. There were 361 of them,  
15 the purple triangles from the focused study. I was  
16 actually thinking of changing it because everything  
17 falls on the same graph. So there were 361 -- it's  
18 explained in the report -- 361 of them that actually  
19 went to completion. Out of this 361, 17 percent of  
20 those led to early containment failure.

21 Now, we have the red triangles. The red  
22 triangles are also in the same sample space. They  
23 went actually past the first hydrogen deflagration  
24 because I don't care what happens after the first  
25 hydrogen deflagration because that is the one that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 determines whether the containment fails early or not.

2 Out of this -- let me see. Out of this  
3 155 red triangles that I had, 15 percent of them also  
4 led to early containment failure. So whatever the  
5 code error or whatever that was producing this was a  
6 systematic error that was showing in the original UA  
7 that you have 10 out of, 17 out of 23 or here. But  
8 the important thing is that we have gotten more than  
9 500 of the cases here that show that I'm producing  
10 enough hydrogen and only 17 percent of these cases  
11 have early containment failure.

12 VICE CHAIRMAN CORRADINI: So can I say it  
13 in less words? So you've gone through an event,  
14 you're looking at events as time passes and you've  
15 gotten through the event which you think --

16 MR. ESMAILI: Yes.

17 VICE CHAIRMAN CORRADINI: -- is the  
18 contributory to early containment failure.

19 MR. ESMAILI: Yes.

20 VICE CHAIRMAN CORRADINI: So just to be  
21 not mean to you all but comprehensive, it seems to me,  
22 if you ask Sandia, since they're the keepers of the  
23 thing, I know for every run MELCOR prevents an event  
24 summary sequence. I'm curious if you went further  
25 with an event analysis and find out what event do you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 get past before you crash, stop, fail, whatever the  
2 word you want to use.

3 MR. ESMAILI: This happens inside the  
4 core, as I said again.

5 VICE CHAIRMAN CORRADINI: I understand  
6 that, but what I guess I'm saying is, just so we're  
7 clear on this, if you get the valve failure, you get  
8 a release, and still it continues to chunk along, and  
9 then it fails to execute. Is it at the time or before  
10 creep rupture? Is it at or before accumulator dump?  
11 That would be another piece of interesting information  
12 to find out for later on.

13 MR. ESMAILI: We can make that clear. But  
14 was this, I'm trying to say if this information is  
15 helpful to you right now because now we have gone  
16 past, we have gone past when you have the first  
17 deflagration. And even those cases that failed, they  
18 did not fail the containment because they went past  
19 the first deflagrations, okay? So in other words,  
20 whatever there is, that systematic error that it's at  
21 17 percent, whether it went all the way to completion.  
22 And, actually, this figure is very revealing because,  
23 in terms of overall hydrogen production, you know,  
24 because we have other uncertainties, we have rupture,  
25 pressure, that are just totally random, so I can

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 sample this whether I am in the purple triangle or the  
2 red triangle. I can just sample this, sampling with  
3 the containment pressure, and I'm still going to be  
4 within that range that I don't think I'm going to get  
5 all that 17 cases lead to the containment failure.

6 This is one piece of evidence that we had.  
7 The other piece was the draft UA. If you remember, we  
8 did the draft UA. That one, we had a much, much  
9 better success rate and we had many more of the cases  
10 that we were in this space. But we were able to shake  
11 down the input, shake down the test, and get a much  
12 better success rate. Even those cases are suggesting  
13 that our early containment failure is in the 20  
14 percent, 25 percent range.

15 So in other words, in other words, we are  
16 not expecting all the 17, let's say, of those cases to  
17 go to failure but a fraction of them. And just to  
18 drive this point, even if all the 17 goes to failure,  
19 it's still a small fraction. We are still, as I said,  
20 we have limited data on how this SV works. If I'm  
21 somewhere in the middle, it matters how I'm going to  
22 model this safety valve, I can increase that.

23 MEMBER KIRCHNER: Hossein, could I  
24 interrupt you here? Since I'm not immersed in this,  
25 I only, I've been to the subcommittee meetings, I've

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 watched this and heard the presentations. My takeaway  
2 from this is the code is doing a good job at  
3 predicting in-vessel hydrogen. I don't see how I draw  
4 a lot of confidence about the deflagration time  
5 because that's an assumption in the code, isn't it?  
6 What's the assumption? When it --

7 MR. ESMAILI: No, hydrogen, so this is --

8 MEMBER KIRCHNER: You get a combustible --

9 MR. ESMAILI: Right. So this is --

10 MEMBER KIRCHNER: -- and then you assume  
11 there's a detonation source --

12 MR. ESMAILI: No. So you produce  
13 hydrogen, you produce hydrogen in-vessel so --

14 MEMBER KIRCHNER: You get a lot of good  
15 agreement on producing hydrogen, so that part gives me  
16 some confidence. Now, tell me about what confidence  
17 I should take on the vertical access when you said 17  
18 percent.

19 MR. ESMAILI: So the hydrogen that  
20 produced in-vessel, the hydrogen that's produced in-  
21 vessel most of the time, it's either going through the  
22 rupture on the pressurizer relief tank going into the  
23 containment. What this is telling you is that, for  
24 all the cases that we had before, when there was  
25 failure to close, look at the time. We've got about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 one hour, right? I mean, one hour from the time that  
2 you produce hydrogen up until the time you have the  
3 first deflagration, but that wasn't enough time for me  
4 to vent all the hydrogen that was produced into vessel  
5 into the containment.

6 What this is telling you is that, not only  
7 am I producing more hydrogen, but I have more time to  
8 vent this hydrogen inside the containment. So by the  
9 time that an ignition source becomes available, and  
10 this ignition source, we have known ignition sources.  
11 It's either the hot gasses issuing from the  
12 pressurizer relief tank; hot gasses issuing from the  
13 hot leg; or whatever happens inside the cavity, if  
14 there are, you know, if it comes into the cavity.

15 And so once this happens, you have that  
16 ignition source. So this is telling me that this is  
17 how much hydrogen I have, some of it I have vented  
18 into the containment. Now my ignition source becomes  
19 available, depending on how much hydrogen I had at  
20 that time, what I could produce that could potentially  
21 fail the containment.

22 MEMBER KIRCHNER: Pardon my saying it like  
23 this, but what I still get from this is a reasonable  
24 systematic and repeatable estimate of hydrogen  
25 produced. What I have is tremendous variability when

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 it detonates.

2 MR. ESMAILI: Yes, you have that. You  
3 have this. Some of it is driven by -- and I think we  
4 discussed this at the last, I think the --

5 MEMBER KIRCHNER: No, I understand all the  
6 reasons.

7 MR. ESMAILI: So there is variability.

8 MEMBER KIRCHNER: The simplistic takeaway  
9 for me is we've got a challenge to the containment, a  
10 high probability of an early failure.

11 MR. ESMAILI: This is actually, this is  
12 because we focused on that. We focused on the cases  
13 where we have high probability of failure. Remember,  
14 the high -- if you go back, Pat, to the previous one.

15 MEMBER KIRCHNER: Let me say it in a  
16 different way. So you made a lot of assumptions about  
17 the valve functioning, right? You got good  
18 reproducibility in the amount of hydrogen that was  
19 available as a source term. Now the question is where  
20 it is and whether it's a combustible amount of  
21 material or it will ignite, but you get a tremendous  
22 variability when it goes off, goes bang.

23 MR. ESMAILI: In the timing. In the  
24 timing of when that happens, and the conditions inside  
25 the lower containment, inside the upper containment,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and how the ignition that's ignited --

2 MEMBER KIRCHNER: So you've done an  
3 uncertainty analysis, and my takeaway is there's a  
4 large uncertainty when the containment is going to be  
5 challenged. You're producing an enormous amount of  
6 challenges there.

7 CHAIRMAN BLEY: Well, I think they did  
8 these, you know this, they did these special cases to  
9 get these portions. But when they actually do a run,  
10 they're generating the hydrogen, it's leaking in the  
11 containment, and then, at some point in time, in that  
12 run, they know how much of it is in there, and then  
13 they get the ignition source and say is it --

14 MEMBER KIRCHNER: I understand all that.  
15 I'm just saying there's tremendous variability.

16 CHAIRMAN BLEY: So over a ten-hour period  
17 or so, so still pretty early.

18 MEMBER REMPE: Leave that slide. Were the  
19 code versions different on the slide with all the  
20 different dots? That one, yes.

21 MR. ESMAILI: We are running the same  
22 MELCOR 2.2 version for all of these cases. Again, we  
23 should have known. So previous slide tells us that I  
24 have 60-percent success rate in this range, right? If  
25 I go and run 600 cases, I'm going to have the same

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 success rate because the errors were systematic. We  
2 could go back and fix them, but then that would put us  
3 in a success rate of 100 percent, and, you know, you  
4 have to go back and keep repeating these calculations.  
5 The question was is it worthwhile to do that, or do I  
6 have enough information to tell me that I have a low  
7 likelihood of early containment failure if the valves  
8 are behaving like this. And, again, as Tina pointed  
9 out, we have some uncertainties of how these valves  
10 work because of limited data.

11 So if I'm going from 62 percent failure to  
12 close an area of greater than 0.324 percent, if I'm  
13 somewhere in the middle, I would have many more early  
14 containment failures. So I'm really limited by my  
15 limited data and lack of knowledge on the safety.

16 But in terms of phenomenology, we have a  
17 better grasp of what happens. You know, we can  
18 reproduce this. We understand what conditions lead to  
19 less hydrogen, what conditions lead to more hydrogen,  
20 and what conditions lead to early containment failure  
21 versus late containment failure.

22 MEMBER KIRCHNER: Okay.

23 MR. ESMAILI: So this is what happens to  
24 the -- this is the containment pressure for all the  
25 cases, for all the short-term station blackout cases.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 What you notice is that we can divide into three  
2 categories. You either have early containment  
3 failure. You have cases that you have early  
4 containment failure, as I mentioned. You have cases  
5 that we have late containment failure. These cases  
6 that are late containment failure are driven by, you  
7 know, core-concrete interaction, non-condensable gas  
8 generation, etcetera.

9 And then you have cases -- this mainly  
10 happens for beginning of the cycle, they have lower  
11 decay heat -- that you don't have containment failure  
12 within 72 hours. That does not mean that I'm never  
13 going to have containment failure. If I just increase  
14 this, I can, you know, it's going to be on the upward  
15 slope and then I can predict what the time would be to  
16 have the late containment failure.

17 The other thing I want to mention is that  
18 this is a short-term station blackout. We don't have  
19 igniters. But what we can see is that you see this  
20 pulses. Up to about 20 hours, we see these pressure  
21 pulses. This means that you get some of these cases  
22 led to containment failure, and we have that early  
23 containment. Some of them you still get hydrogen  
24 combustion. It's not enough to fail the containment,  
25 but you get periodic burns. At some point, we don't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 get any more burns here because we have produced a  
2 hydrogen. I'm actually producing a lot more hydrogen  
3 when I go ex-vessel compared to what I have in-vessel.  
4 But I just don't have the oxygen. I run out of oxygen  
5 inside the containment, so you see those pressure  
6 spikes are stopped. And so --

7 MEMBER KIRCHNER: After those early  
8 spikes, you don't assume any leakage into the  
9 containment. It's always over-pressurized so it's --

10 MR. ESMAILI: Yes, the containment, yes,  
11 the containment --

12 MEMBER KIRCHNER: So there's no oxygen  
13 source.

14 MR. ESMAILI: Yes, we don't have any --  
15 yes. Even if there is a leakage, it's not enough  
16 oxygen. Just maybe a few more of these pulses, and  
17 then it would just die. But you're standing by our  
18 first insight that you can only get this thing, we can  
19 get a whole bunch of hydrogen into the containment.  
20 And if you can burn that hydrogen early enough, then  
21 you can fail it. If not, then the other ones are not,  
22 you know, which actually acting like an igniter  
23 because it's just periodically burning hydrogen as  
24 it's being produced. And so we don't get any  
25 subsequent failures.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           So, hopefully, this answered, you know,  
2           some -- again, as I told you, we go back and the code  
3           is always under, you know, improvement. We can go  
4           back and look at these cases. At some point, we just  
5           did not want to go back to that particular version of  
6           the code, and it was not necessary for us to. You  
7           know, whatever conclusion we have, we have based on  
8           the cases that we have run.

9           VICE CHAIRMAN CORRADINI: So you didn't do  
10          it, but Tina did it, so I'll repeat it because I  
11          thought it was a wonderful volunteer. She's  
12          volunteering, I thought, to somehow take and generate  
13          a write-up that explains what we just went through in  
14          the last 20 minutes so that it's very clear as to --

15          MR. ESMAILI: Yes.

16          VICE CHAIRMAN CORRADINI: -- how you guys  
17          did the detective work in terms of what event you got  
18          past --

19          MR. ESMAILI: Right.

20          VICE CHAIRMAN CORRADINI: -- that allowed  
21          you to still feel that you're approximately in the  
22          same proportion of early failure.

23          MR. ESMAILI: Yes, we are going to explain  
24          that in the --

25          VICE CHAIRMAN CORRADINI: And since you're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 doing that, it sure would be nice if you went further  
2 and did a little more detective work to figure out  
3 what events you further have so that you actually can  
4 maybe analyze failure to execute downstream because I  
5 just have this funny feeling, I can't prove it, that  
6 when your accumulators discharge -- MELCOR is not a  
7 re-flood heat-transfer computer model so that when you  
8 dump a bunch of water in, you've got a blazing hot set  
9 of hot structures that has a very difficult time  
10 coming to conclusion of an execution. So my guess is  
11 it's somewhere the time when you're starting to  
12 depressurize and dump accumulators is where a lot of  
13 these failures are occurring. That's just a guess.  
14 But looking at an event analysis, as you've already  
15 done a bit, would be worthwhile.

16 MR. ESMAILI: Yes. Some of those cases  
17 that you saw that we are producing a lot of hydrogen,  
18 those cases, those cases are the system is  
19 depressurizing. So as the system is depressurized and  
20 the accumulator continues to inject. But I want to  
21 again emphasize is that this particular containment is  
22 very, very sensitive to how much hydrogen. So in  
23 other words, if I can delay, if I can delay the  
24 combustion of the hydrogen by that time, I still get  
25 the burn. But I have burnt enough hydrogen that, even

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 if that accumulator comes a little bit later and  
2 produces more hydrogen, it's not going to, just like  
3 these pressure pulses are not going to fail the  
4 containment.

5 VICE CHAIRMAN CORRADINI: I'm not  
6 disagreeing with you. I'm just simply saying that,  
7 from the standpoint of understanding the root cause of  
8 failure to execute, that would help. That's all.

9 MR. ESMAILI: Yes.

10 MEMBER KIRCHNER: And could you just  
11 summarize what was the major reason for such a tighter  
12 convergence with the MELCOR 2.2 versus 2.1?

13 MR. ESMAILI: What slide there?

14 MEMBER KIRCHNER: Pick any one. Seven.

15 MR. ESMAILI: Okay. Yes, let's go to  
16 seven. So this is, again, this is the safety valves.  
17 You see the red?

18 MEMBER KIRCHNER: No, I'm not talking  
19 about the codes. I understand. I'm just trying to  
20 understand or see if you understand why 2.2 is getting  
21 a tighter --

22 MR. ESMAILI: No, but 2.2 -- okay. Maybe  
23 I can answer you.

24 MEMBER KIRCHNER: -- a tighter spread than  
25 2.1.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. ESMAILI: 2.2 -- well, because, first  
2 of all, we have less, we have less points in there.  
3 Go back to the SV study. That --

4 MEMBER KIRCHNER: The trend I see in the  
5 points you have shows a tighter result.

6 MEMBER STETKAR: But isn't it, I mean,  
7 what you're missing here is they ran the April version  
8 of the study, April 2016 version of the study, which  
9 had the left-hand bar performance of the safety valve,  
10 they ran that study using MELCOR 2.1. They ran the  
11 right-hand bar with MELCOR 2.2. So it isn't  
12 completely a MELCOR versus MELCOR. It's more safety  
13 valve versus safety valve.

14 MR. ESMAILI: But there is one thing, and  
15 Larry mentioned it when he was here on April 18th,  
16 that they said there was actually, in MELCOR 2.1, a  
17 draft UA, even though the safety valves, but what we  
18 had is that we were not quenching properly. So it was  
19 possible for us, even after accumulator injection and  
20 the reflux, we were producing more hydrogen.

21 In this new UA, after the accumulator  
22 injects, it properly quenches, and we don't get that  
23 much hydrogen. But what this figure is trying to show  
24 you is that, again, it's up to the time of first  
25 deflagration that --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER KIRCHNER: Yes, but this was my  
2 point earlier. So what in the model has changed that  
3 you described it that you're doing quenching better  
4 and, hence, you don't get as much hydrogen? I  
5 understand -- what's different in the codes, not just  
6 the results?

7                   MR. ESMAILI: This was -- there were a  
8 couple of errors, if you remember. We came back on  
9 April 18th and we said that, first of all -- no, it  
10 was April 18th that Larry came here and gave a -- yes,  
11 it was the springtime. So the orange circles, the  
12 draft UA on MELCOR 2.1, they had a couple of issues.  
13 I think they have it in one of the -- first of all, we  
14 were not quenching, so some of the cases we were not  
15 quenching, so they were still producing hydrogen. So  
16 we were producing more hydrogen. The other one was  
17 that, as it was coming, we were applying a dry-up heat  
18 flux that we should not be applying to what was on the  
19 core plate. So once that one fixed, we went to MELCOR  
20 2.2 and reproduced.

21                   But the point is that, even with those  
22 errors, we are still in the same sample in the same  
23 region because what is important is how much hydrogen  
24 you produce by the time of first deflagration. And so  
25 this figure was very telling, and, as you can see,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 yes, you are right, we are getting tighter on the blue  
2 ones because after hot leg failure we are not  
3 producing anymore hydrogen and this is clear. Again,  
4 you know, we could go back and --

5 MEMBER KIRCHNER: No, I'm not asking that.  
6 Just a clarification. Thank you.

7 MS. GHOSH: Okay. So we're going to shift  
8 gears now. Hossein, we don't have time today to talk  
9 about all of the results in our very thick report, but  
10 we just picked out a few to highlight. And the  
11 containment, what we call the horsetails are the  
12 distributions for the containment pressure,  
13 pressurization, and failure is one of them. And I  
14 hope you have that figure in mind.

15 VICE CHAIRMAN CORRADINI: Well, we just  
16 wanted to make sure we gave ample time to Hossein.

17 MS. GHOSH: If you want to keep going with  
18 him, that's fine with me. But we're going to switch  
19 now to the off-site consequence portion of the  
20 analysis that comes out of the MACCS code, and I hope  
21 you have that containment pressure curves in your mind  
22 still because it helps explain one of the interesting  
23 features of the consequence results.

24 So I've had a lot of people come to me and  
25 say what is this, this is a complimentary cumulative

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 distribution function, which most of the time doesn't  
2 look like this where you have this big hump in the  
3 middle. And the reason that our -- in this case,  
4 we're graphing the population-weighted latent cancer  
5 fatality risks at different distances from the plant.  
6 So these are annular rings that are centered on the  
7 plant. You see the red line is the zero to ten miles,  
8 and the other ones are labeled.

9 And these are the means, the distribution  
10 of the means over all the weather trials. So,  
11 basically, these are --

12 CHAIRMAN BLEY: Now, can I stop you right  
13 there?

14 MS. GHOSH: Yes, go ahead.

15 CHAIRMAN BLEY: Because we didn't go  
16 through the Level 3 analysis, I don't think, in a  
17 subcommittee, but we did go through, to some extent,  
18 the Level 3 for the Level 3 PRA, which the words and  
19 things seem very similar to me. And we had a problem  
20 over there, which maybe you can explain to me right  
21 now. When you say population-weighted latent cancer  
22 fatality risk, is this the expected number of deaths  
23 over a lifetime following an accident? Is this the  
24 expected dose? Is this expected cancers per year?  
25 What is this?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MS. GHOSH: So this is the -- okay. This  
2 is conditional on the event occurring.

3 CHAIRMAN BLEY: Given the accident, this  
4 is what?

5 MS. GHOSH: Yes. Given the accident, this  
6 is the risk of, technically, it's population weighted,  
7 but you can think of it as an individual who lives in  
8 this annular ring around the plant, their risk of  
9 incurring a latent cancer fatality due to the accident  
10 having --

11 CHAIRMAN BLEY: Over their lifetime.

12 MS. GHOSH: Over their lifetime, yes.

13 CHAIRMAN BLEY: So this is the individual  
14 likelihood of a person. It's not the expected number  
15 of deaths, it's essentially the probability of one  
16 person getting a latent cancer event or a latent  
17 cancer fatality? A latent cancer fatality?

18 MS. GHOSH: Fatality, right. And --

19 CHAIRMAN BLEY: With or without treatment.

20 MS. GHOSH: -- it gets a little tricky  
21 because you can also count up the numbers, which can  
22 end up being less than one, and then divide by the  
23 population in that ring that you're looking at.

24 CHAIRMAN BLEY: I'll tell you what, when  
25 I read chapter six, all I have notes all over it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 saying exactly what is this. So what you just  
2 explained to me isn't explained in that report, near  
3 as I can tell.

4 MS. GHOSH: So we should spell it out --

5 CHAIRMAN BLEY: You know, these are risks,  
6 but they can be almost anything, and you have to tell  
7 us what they are.

8 MS. GHOSH: Okay, yes. Thank you for the  
9 comment.

10 CHAIRMAN BLEY: In the Level 3 report,  
11 there was great confusion, and there was expected  
12 deaths mixed in with other things.

13 MS. GHOSH: Okay.

14 CHAIRMAN BLEY: So this isn't expected  
15 deaths within the population. This is probability per  
16 person over their lifetime following this one  
17 exposure.

18 MS. GHOSH: Yes, that is, that is --

19 CHAIRMAN BLEY: Do you know if they  
20 modeled treatment or not?

21 MS. GHOSH: Oh, okay. Well, this is a  
22 very simple calculation, and I might call on --

23 CHAIRMAN BLEY: The answer could be either  
24 way, depending, even if it is simple.

25 MS. GHOSH: We add up all the organ-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 specific doses that the population got, and those  
2 doses get multiplied by a cancer mortality risk given  
3 that dose. And we have distribution --

4 CHAIRMAN BLEY: Given treatment or without  
5 treatment?

6 MS. GHOSH: That's a complicated question.

7 CHAIRMAN BLEY: It's a simple question.  
8 The answer might be complicated.

9 MS. GHOSH: Yes, I don't think we assume  
10 treatment but --

11 CHAIRMAN BLEY: But you don't know, and I  
12 don't think it says here because it doesn't even tell  
13 me that this is what this.

14 MS. GHOSH: I don't think we get into  
15 whether they were treated or not. Yes, I see my  
16 colleagues are shaking their heads.

17 CHAIRMAN BLEY: It's built into that  
18 number you use to translate from one to the other.  
19 Hi.

20 MR. COMPTON: Hi. Keith Compton, Office  
21 of Research. I will say this --

22 CHAIRMAN BLEY: It's working.

23 MR. COMPTON: The short answer to that is  
24 that I don't know the precise answer. Like you said,  
25 it would be baked into whatever the mortality risk

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 coefficient would be, yes.

2 CHAIRMAN BLEY: You guys ought to know the  
3 answer to that question.

4 MR. COMPTON: We need to go back and see  
5 where the --

6 CHAIRMAN BLEY: Okay.

7 MR. COMPTON: -- stem from. For acute  
8 health effects, that is a consideration because you  
9 have to make an assumption about what level of  
10 treatment is given. But I'll take that as an action  
11 to go back and find out what the underlying  
12 assumptions of that are.

13 CHAIRMAN BLEY: For different kinds of  
14 cancer, it makes a big difference.

15 MR. COMPTON: Right, right. So you do see  
16 there's a distinction between incidents and  
17 fatalities, so, yes, I'll take that as an action to go  
18 back and find out.

19 MS. GHOSH: Okay. So --

20 CHAIRMAN BLEY: Not so complicated, but  
21 thanks.

22 MS. GHOSH: So these are the CCDFs, the  
23 complementary cumulative distribution functions, at  
24 those annular, for the populations in the annular  
25 rings around the site. And the reason that you see

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 this bimodal distribution where you have about 13  
2 percent that's spread out in the upper left corner and  
3 then you have three orders of magnitude where nothing  
4 is happening and then you get onto a new curve to the  
5 right has to do with the fact that in about 13 percent  
6 of our cases we don't have containment failure.

7           So most of those were from the beginning  
8 of the refueling cycle cases where you saw in the  
9 graph Hossein showed those yellow curves that are  
10 still going up at the end of the 72-hour simulation  
11 time and have not failed containment yet. You get  
12 some very low risks just from leakage. And then, if  
13 you do fail containment, then you end up on the part  
14 of the curve that's over to the right that kind of  
15 strikes beyond the ten to the minus five number at the  
16 bottom. And there were a handful of middle of cycle  
17 cases that also hadn't failed containment by 72 hours,  
18 so it's primarily the beginning of cycle cases and  
19 then a handful where the middle of cycle cases hadn't  
20 failed yet.

21           MEMBER STETKAR: Just for the benefit of  
22 folks that haven't been around, the report currently  
23 does better at trying to explain this than it did  
24 before. There are still some cases where there are  
25 statements saying, well, the population latent cancer

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 fatality risk ranges from ten to the minus three to  
2 ten to the minus tenth, which, on this plot, that's  
3 true and that, you know, the observation is the  
4 further you are away from the plant the lower the risk  
5 is. Well, that's true if you're on the left-hand side  
6 of the curve, not so much if you're on the right-hand  
7 side of the curve.

8 So it's a pretty subtle but important when  
9 you're interpreting the results to kind of explain it  
10 pretty clearly, pretty much as clearly as you tried to  
11 do orally today.

12 MS. GHOSH: Yes. And, certainly, the risk  
13 curves with the annular rings, they're pretty tight  
14 together, in fact tighter together than we had seen in  
15 some of the past studies when you get out to the part  
16 where you have failed containment. And we did try to  
17 analyze why that was the case, and there is some  
18 discussion in chapter six on that.

19 But in terms of, you know, the overall  
20 range of, you know, health effects, again, these are  
21 the conditional risks, so they're still fairly small,  
22 even in the cases where you had an early containment  
23 failure. And we tried to fill out, add some data  
24 points in that regime, as well, with that focused  
25 safety valve study where we did add some health

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 consequence results in that appendix.

2 MEMBER KIRCHNER: One more time. So in  
3 the middle ranges, when all the curves collapse  
4 together, that's simply because the release is so  
5 large that it exceeds the threshold for saying that  
6 the persons at risk of getting cancer.

7 MS. GHOSH: Yes. Actually, maybe it would  
8 be better to show no lines in that because there's a  
9 discontinuity because really there's two curves.  
10 There's one set of curves where those 13 percent of  
11 the cases where we didn't get containment failure and  
12 we have very low risks, and then there's nothing in  
13 the middle. And then if you do fail containment --

14 MEMBER STETKAR: The probability density  
15 functions, it would be clear that there's two humps  
16 and that there's nothing in between.

17 MS. GHOSH: There's nothing in the middle.

18 MEMBER STETKAR: But as a CCDF, it's  
19 saying what's the probability that it's this amount or  
20 greater, so you get rid of the first set and then it  
21 just hangs there.

22 MEMBER KIRCHNER: Oh, I understand it, but  
23 it might be counterintuitive to the public.

24 MEMBER STETKAR: Oh, it is.

25 CHAIRMAN BLEY: But the CCDFs have become

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the language of this kind of stuff.

2 MEMBER RICCARDELLA: Well, why did you  
3 choose not to plot it as probability density?

4 MS. GHOSH: Well, I guess we hadn't  
5 traditionally done that. I suppose if there's  
6 interest in doing that we could but --

7 MEMBER STETKAR: There are benefits and  
8 drawbacks from it. The problem is that the left-hand  
9 side of this, you get this really, really broad kind  
10 of little low mound of thing and then, over on the  
11 right-hand side, you get something that looks like  
12 more of a bigger hill, and those can be misleading.

13 CHAIRMAN BLEY: Well, they can, but at  
14 least you get a sense that the one is very unlikely  
15 and the other one is still unlikely but not nearly so  
16 unlikely. The text talks about the bimodal nature,  
17 but it talks about it as if you were actually showing  
18 density functions, which would have made it easier to  
19 understand that part of it.

20 MS. GHOSH: And this is just a very high-  
21 level summary of the off-site consequences. Very  
22 similar to what we have seen in past studies. Even  
23 when we get an early containment failure, the early  
24 fatality risks are negligible and, essentially, zero.  
25 We get, actually, identically zero for the cases where

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 we didn't fail containment early. And in those three  
2 realizations, in the four realizations that we did,  
3 out of those, three of those had a number of the  
4 weather trials, not even all the weather trials, where  
5 you could compute a non-zero number. So we continue  
6 to say there's, essentially, zero individual early  
7 fatality risk that was calculated.

8 For the latent cancer fatality risks,  
9 they're small, even in the cases where we had early  
10 releases to the environment. And they're generally  
11 dominated by the intermediate and long-term phase  
12 exposures compared to emergency-phase exposures,  
13 although we do have a minority of realizations where  
14 the emergency phase exposures are more important. And  
15 we didn't show the regression results for the MELCOR  
16 results, but you see that the things that are  
17 important to the source term also pop up as important  
18 to, they translate to being important to consequences,  
19 as well.

20 Hands down, the most important thing for  
21 the latent cancer fatality risk was where in the  
22 refueling cycle you happen to be when the accident  
23 occurs, and this really has a dual effect on the off-  
24 site consequences. It affects the source terms  
25 because of decay heat.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           And then, in terms of health effects, you  
2           have also the fact that you have an ingrowth of the  
3           long-lived isotopes, such as cesium-137, which is a  
4           second level of effects for the health effects. So  
5           that makes sense.

6           And then for the cancer fatality risk  
7           factors, I mentioned that those are calculated by  
8           organs, and we have eight sets or organs. The  
9           residual organ is kind of a catch-all for all the ones  
10          we don't explicitly model, and it's an important one  
11          because cesium as an external ground-shine dose  
12          contributor delivers a lot of dose, for example, to  
13          the pancreas, the soft tissues, and so it makes sense  
14          that that shows up as important.

15          The lungs, again, because we have some  
16          cases where the emergency-phase risks are important,  
17          the lung factor makes sense because you're getting  
18          inhalation doses from the emergency phase. Colon is  
19          another soft tissue.

20          Containment rupture pressure. I think  
21          that's self-explanatory. That affects both whether  
22          you might get early containment failure. If you  
23          sampled a lower rupture pressure, you're more likely  
24          to get the early containment failure from that early  
25          deflagration of hydrogen. And even if you get into

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the late regime, you're on those gradual  
2 pressurization curves, and it's beneficial to fail  
3 later because you can have more settling of  
4 radionuclides before the containment fails.

5 CHAIRMAN BLEY: Now, you do shine dose and  
6 inhalation dose and you make some arguments -- I think  
7 it's in this study and probably in the other one, too  
8 -- that you don't have to look at ingestion dose  
9 because food comes for all these funny places. But  
10 you just ignore it then, and it seems like you ought  
11 to at least have a calculation done that assumes you  
12 get all your food from this area and would it be a big  
13 deal or not a big deal so one could at least tell  
14 that.

15 MS. GHOSH: We have considered the  
16 ingestion dose in other studies. For example, some of  
17 the reg analyses we did --

18 CHAIRMAN BLEY: Yes, I know.

19 MS. GHOSH: -- such as the filter --

20 CHAIRMAN BLEY: It's just here the  
21 argument is a one-sentence, well, people won't eat  
22 this stuff, you won't . . .

23 MS. GHOSH: Yes, maybe that's satisfying.  
24 Maybe it would be better just to say we don't, state  
25 that we don't include it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BLEY: Well, you do say that.

2 MS. GHOSH: Yes. I think the past studies  
3 have shown that food pathway is not a huge  
4 contributor, actually, to the --

5 CHAIRMAN BLEY: It would be better to do  
6 a sensitivity case and show that, if, in fact, that's  
7 true, to show that than just to ignore it because it  
8 leaves the question open of how big a dose could it  
9 be? What if I did eat this stuff? What if I had  
10 trouble getting out of the area and I had to eat stuff  
11 that was outside or try to decon it on my own or  
12 something. But it's not a very convincing treatment.  
13 It's a non-treatment that kind of wishes it away.

14 MS. GHOSH: Okay. Number of safety valve  
15 cycles. I think we've talked a lot about why that's  
16 important, so I won't say anything more about that.

17 Next slide, please. So we wanted to just  
18 wrap up with some of the lessons learned from this  
19 study. And the handful of bullets I have are all kind  
20 of related. And, you know, one of the things we've  
21 learned in the past several years, it's hard to do a  
22 single best estimate severe accident simulation just  
23 because it's a very complex system, there are a lot of  
24 synergistic effects, there are a lot of threshold  
25 effects, and it's hard to kind of pick a best estimate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 simulation.

2 Now that we have included the  
3 uncertainties and explicit uncertainty analysis as  
4 we're doing this, we find that it's been very  
5 beneficial and it's definitely an iterative process.  
6 We've never gone through the first time through and  
7 said this is our final analysis. We've had to repeat  
8 it many times and I think for good reason. And you  
9 really do need kind of a team of both subject matter  
10 experts who understand the phenomenology and really  
11 physically what's going on, as well as kind of the UA  
12 folks who can tell a part of the statistical story.  
13 And we've tried to use both the statistical methods,  
14 you know, complimented with the phenomenological  
15 explanations to be able to tell the story.

16 So we didn't talk a lot about the  
17 regression analyses we did, but the statistical  
18 regression analyses are very valuable because they  
19 tell us from a statistical standpoint what is showing  
20 up as important. And then we can -- and if you do  
21 enough, you know, variations and runs, you can kind of  
22 pick out individual cases that the subject matter  
23 experts can really study in detail and help explain  
24 what's going on in those cases to be able to show  
25 phenomenologically what's causing variations in your

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 accident progression and releases. So we found that  
2 to be very valuable.

3 Next slide, please. And, again,  
4 considering uncertainty from the beginning of the  
5 project, I think we touched on this a little bit  
6 earlier, it's helped us to sharpen our pencil in areas  
7 that matter to the outcome. And this is just one  
8 example. In last year's draft uncertainty analysis,  
9 we didn't know a lot about what the safety valve open-  
10 area fraction ought to be if it failed to close, and  
11 we kind of said, well, we'll assume a uniform  
12 distribution. Well, it turns out that that open-area  
13 fraction distribution is very important to the outcome  
14 of the analysis. So we decided to go back and see  
15 whether we could collect some more information, and we  
16 talked to subject matter experts who know valves  
17 better than we do. We re-evaluated the very limited  
18 operating experience information that we did have, and  
19 we found that we were able to come up with something  
20 that was, we felt was more defensible than just it  
21 could be anything between one person and one. And it  
22 does have an impact on the analysis, so I think it was  
23 worthwhile to go back and do that.

24 The other thing is that, again, with these  
25 complex systems, it's important to have an integrated

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 modeling perspective. And just as an example, you  
2 know, for the MACCS model, we had assumed a seismic  
3 initiator. How you get into the short-term station  
4 blackout situation in the first place is a very bad  
5 day, and, you know, based on the PRA information that  
6 we have, it seemed that a seismic initiator was  
7 probably a high chance of how you get to this very bad  
8 day. And so we thought carefully about what that  
9 would mean for evacuating people from the plant.

10 So that's just one example of we tried to  
11 take an integrated perspective. In this case, we  
12 assumed that all the bridges would be unusable and  
13 then modeled the evacuation network and calculated the  
14 evacuation times based on that all the bridges are  
15 just not usable from the impact of the seismic event.  
16 So that's just one example.

17 And I think I'm going to turn it back over  
18 to --

19 CHAIRMAN BLEY: Well, before you turn it  
20 over, I stumbled across a sentence that I need your  
21 help with in section 6.3.1 of your report. It's  
22 talking about these special realizations that give you  
23 information on cesium and other things, and it says  
24 that it should be noted that realization 36 uses a  
25 mock MOC inventory and, even though its release

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 fraction is the largest, the highest cesium,  
2 realization 395 releases a larger total mass of  
3 cesium. How can you get more cesium out of a case  
4 that has a smaller release fraction? I don't get  
5 that.

6 MS. GHOSH: Okay. So the release fraction  
7 is what it sounds like. It's the fraction of the  
8 inventory that you had in the core at the time of the  
9 accident.

10 CHAIRMAN BLEY: Yes, that's where the  
11 cesium lives, too.

12 MS. GHOSH: That's where the cesium goes,  
13 right. And the cesium inventory steadily grows from  
14 the beginning of cycle to the end of cycle.

15 CHAIRMAN BLEY: Okay. So one of these  
16 cases it's growing outside? Go ahead. You explain it  
17 to me.

18 MS. GHOSH: So the end of cycle case has  
19 maybe, has more cesium in the inventory. So 75  
20 percent of more is more. So we were always, for the  
21 MELCOR analysis, we're always looking at the fraction  
22 of what's in the core. But you have more in the core  
23 at the end of cycle. So you can have a smaller  
24 fraction at the end of core that is more than a higher  
25 fraction in the middle of cycle.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 CHAIRMAN BLEY: Okay. That makes sense.  
2 I mean, the sentence isn't well explained.

3 MEMBER STETKAR: That's why Hossein kind  
4 of showed the red, yellow, and blues, and it said,  
5 well, from his part of the world, blue and red didn't  
6 make too much difference whether you're in the middle  
7 or end of cycle because, no, from thermal hydraulics  
8 because the decay heat is about the same. Yellow was  
9 much different. Tina had one bullet that said, oh,  
10 one of the most important parameters for latent cancer  
11 effect is the time in cycle, and that's because of  
12 that inventory.

13 CHAIRMAN BLEY: Well, but it's certainly  
14 a balanced --

15 MEMBER STETKAR: Oh, yes.

16 CHAIRMAN BLEY: It's the product of the  
17 two that gets you where you're going. Okay.

18 MEMBER KIRCHNER: So you have this  
19 holistic result. What, in your mind, have you learned  
20 from this in terms of improvements for MELCOR and  
21 MACCS?

22 MS. SANTIAGO: I think we've had a number  
23 of discussions, and I think we had Hossein come in  
24 about a couple of months ago talking --

25 MEMBER KIRCHNER: I'm not trying to reopen

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that, just a summary.

2 MS. SANTIAGO: For the MELCOR in  
3 particular --

4 MEMBER KIRCHNER: What would you look to  
5 improve in those models? What had the biggest impact  
6 in the models versus the output, the results?

7 MR. ESMAILI: From my perspective, the  
8 more calculations you do, the more you expose where  
9 you could potentially improve the code.

10 MEMBER KIRCHNER: And you've done that, so  
11 I'm trying to get to that --

12 MR. ESMAILI: So, yes, when we went from  
13 the draft UA, as I explained, when we went from the  
14 draft UA to this current UA, we did many, many, many  
15 code changes. This was some of the cases that really  
16 showed that, yes, the model that we had for quenching  
17 was not working properly, you know. The model that we  
18 had for the dry-up model was not working properly.

19 These were coming out of other  
20 calculations, just to be honest, but there were more  
21 subtle things. So when Larry, when he was here, when  
22 he goes and looks at these things, it's not that we  
23 are going to totally forget about, you know -- there  
24 are cases where, you know, again, with these core  
25 relocations, sometimes it's logic based, so it's how

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you want to transfer this particular debris from this  
2 particular -- now we have many components. We have  
3 molten material, we have particulate debris, we have  
4 material that has frozen over some -- so you come up  
5 with some, in a cell, you come up with a situation  
6 where it doesn't make sense, the logic does not make  
7 sense, and this is something you have never thought  
8 about. Then you say, oh, wait a minute, I cannot have  
9 a case where I have, you know, like a solid rock  
10 sitting on top of a particulate debris. So these  
11 calculations, when we do these calculations, these  
12 failures, etcetera, help us go ahead and improve upon  
13 our code.

14 And if I go a little bit further, you  
15 know, I think our success rate is improving. So when  
16 we did the calculations back in 2015, our success rate  
17 was 84 percent. I understand that, you know, it's  
18 still not 100 percent because 17 of those cases, but  
19 from 2015 going to 2017 our success rate is improving.  
20 So the code is actually becoming more and more robust  
21 until we actually have another input that we have to  
22 go back and look at those things.

23 So this is helping us in a lot of ways  
24 and, not only this, we have about a thousand code  
25 users throughout the world from 28 countries. So

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 anytime they do calculations, they report problems.  
2 What we learn here, we report back to them. We give  
3 them a different version.

4 MEMBER MARCH-LEUBA: So is it safe to say  
5 that, at the end of this exercise, you have a code  
6 that is good enough to run this exercise, not a list  
7 of improvements? You already have the code --

8 MR. ESMAILI: Say that again.

9 MEMBER POWERS: Many, many jobs in this  
10 world. Once you've done it, you know how to do it.

11 MR. ESMAILI: I just don't want to be very  
12 defensive. I was accused yesterday of being very  
13 defensive about --

14 MEMBER MARCH-LEUBA: The purpose of this  
15 exercise was not to generate a list of things you want  
16 to improve in the code but to generate a code that is  
17 good enough to run this exercise, and you already have  
18 that.

19 MR. ESMAILI: And we already have that.  
20 And, again, again, I hate to say this again, but I  
21 don't want to go back to these failure cases, but, you  
22 know, but people, not everybody goes through this  
23 level of detail to run 600 calculations. People  
24 usually do a few calculations, plus sensitivity  
25 calculations. They are able to go back and check. So

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the code can overcome some of these failures. It's  
2 just that when we hit something that's physically  
3 unreasonable, and I actually had one case a couple of  
4 where the time and temperature failure was not working  
5 properly. This was for the cases that I had this  
6 heat-up going on for days and days and days and  
7 suddenly failed. So there were actual errors.

8 But, yes, you are right, the code becomes  
9 more and more robust for future use. We are able to  
10 run this scheme for longer and longer time. There was  
11 a time that, you know, we were running these kinks for  
12 about 24 days and said, okay, that's enough. Now we  
13 are running it for three days. Level 3 is running it  
14 for seven days. So, you know, we are pushing the  
15 envelope on how --

16 MEMBER REMPE: I guess I was wondering if  
17 this integrated sensitivity analysis has led you to  
18 determine that some of the input parameters might have  
19 a more significant effect so that you might want to  
20 improve models in the future and are there some  
21 examples like that you want to cite?

22 MR. ESMAILI: One of the things that came  
23 out and, again, I had to go back to the failures. So  
24 one of the things that came out, again, when the code  
25 becomes challenging, we're at low pressure, we have a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 lot of code that will be going into one cell and  
2 you've been into this MELCOR map crosswalk and see  
3 what happens. So we have situations where one core  
4 cell is not much material. You know, there is maybe  
5 less than a percentage of the core cell that's  
6 available for me to just put in water and steam  
7 through it.

8 So part of this exercise is telling me  
9 what am I going to do in those cases? Should I forget  
10 about that material and move on? Because those are  
11 the cases that the code really tries to go to very,  
12 very smaller time steps.

13 So we are improving the models by making  
14 the code smoother so we can actually do more of these  
15 calculations in a more reasonable amount of time.  
16 Does that answer your question about how these things  
17 --

18 MEMBER REMPE: Well, it's not exactly the  
19 answer I wanted, but it was the question --

20 MR. ESMAILI: So tell me what answer you  
21 wanted, and I'll give that.

22 MEMBER REMPE: I was hoping you might say  
23 that your decision to emphasize the liquefaction might  
24 have stemmed from this because of the sensitivity  
25 analyses where it came out to be, you know, if there

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 were similarities in the sensitivity analysis that  
2 came out to be important, you might decide to refine  
3 that model a bit. That's what I was kind of expecting  
4 to hear.

5 MR. ESMAILI: Right. And, again, to be  
6 honest, not everything, you know, again, there are  
7 some of these cases that Larry mentioned that and I  
8 gave you that that we knew that there were these  
9 models in the code that was varying the code from  
10 early 90s that never worked, and we are resurrecting  
11 them. Yes, some of this had to do with what you're  
12 suggesting, but this was not the only input into the  
13 code --

14 MEMBER REMPE: Not the only one, but maybe  
15 it highlights --

16 MR. ESMAILI: Oh, yes, absolutely.

17 MEMBER REMPE: -- it's become more  
18 important to maybe fix this --

19 MR. ESMAILI: Absolutely, yes, yes.

20 MEMBER REMPE: -- because in the past, oh,  
21 it doesn't matter that much or something and it wasn't  
22 a higher priority. That's what I was wondering.

23 MR. ESMAILI: Or it was difficult to do.

24 MS. SANTIAGO: Well, we understand in  
25 different designs what you need to look at closer.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 And so a lot of what we learned from this analysis, as  
2 well as some of the prior ones, we're implementing in  
3 the Level 3 PRA. What metrics should we report? How  
4 do we communicate clearly?

5 So we've learned a lot. The organ dose  
6 coefficient factors we might need to update in MACCS  
7 because we may want to isolate the pancreas or  
8 something and not just have it grouped.

9 MEMBER MARCH-LEUBA: At the end of the  
10 day, what was the largest change that you made between  
11 the draft and the current? That slide, the top right  
12 figure right there, is what you assume for your safety  
13 valve, the yellow and blue. And I have to say that we  
14 don't have any basis for yellow or blue. Blue looks  
15 more reasonable. If you are going to use the one with  
16 the two column, it's clearly the biggest effect. You  
17 can ignore everything in the code. It's what you  
18 assume for the safety valve.

19 MR. ESMAILI: Yes, and it's very  
20 intuitive, right, because that's the only place where  
21 hydrogen is coming out of the vessel. You know,  
22 that's where --

23 MEMBER KIRCHNER: So is Research proposing  
24 a program to, an experimental program to get data on  
25 safety valve performance?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. ESMAILI: Not necessarily.

2 MS. GHOSH: I think if somebody wanted to  
3 do that, that would be very satisfying if we could  
4 collect more information. From NRC's perspective, all  
5 of these things, all of the outcomes that we've come  
6 up with are still showing very low risk outcomes. So  
7 the question is where does the motivation come from to  
8 spend more money to keep looking at this.

9 MEMBER MARCH-LEUBA: The first time I saw  
10 the safety valve failure rates from the LERs, I would  
11 expect that most of the failures to close were  
12 leakage, as opposed to one-third of the valve not  
13 closing.

14 MS. GHOSH: Right, right, right.

15 MEMBER MARCH-LEUBA: And so even on the  
16 blue line, we are underestimating. It will be even  
17 lower if we knew this information. Most of the  
18 failures are going to be leakage.

19 MR. ESMAILI: So the other part is that,  
20 you know, this is, as far as igniters are concerned,  
21 even four is one too many, right? I mean, so, in  
22 other words, you still want to prevent any hydrogen  
23 burns. So whether it's 4 out of 600 or 100 out of  
24 600, you know, what you want to do is that this is  
25 telling us that this is what you have to do in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 short time, make the igniters available, you know.  
2 And so I don't think safety valve is going to  
3 necessarily change that aspect of the problem.

4 MEMBER KIRCHNER: So were plants going to  
5 an uninterruptible power supply for igniters as a  
6 mitigating feature?

7 MR. ESMAILI: I don't want to get into the  
8 operations. I think that part of the FLEX is that you  
9 would always have batteries. I mean, even as GSI 189,  
10 you know, some of these plans, they already have  
11 dedicated AC power to power up these igniters and  
12 they're going to have more success with the FLEX, I  
13 suppose.

14 MS. GHOSH: Can I just answer? I think  
15 two of you asked what did we learn also from the MACCS  
16 side. If you want an example from our side, I think,  
17 you know, Pat mentioned we want to take a closer look  
18 at some of the organs that matter a lot for all the  
19 scenarios we've looked at. We know cesium doses,  
20 external cesium doses to soft tissues are important.  
21 We could probably do better in modeling that.

22 With the MACCS code, and I know we've had  
23 past presentations, maybe years ago at this point, on  
24 improvements that were made at the start of SOARCA,  
25 you know, for MACCS. That was based on kind of an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 expert panel that reviewed the code and, you know,  
2 made some recommendations on what we could do.

3 But more recently, the results of our past  
4 and the first two uncertainty analyses kind of drove  
5 some of the input improvements that we've made,  
6 basically from Peach Bottom to Surry and then from  
7 Surry to Sequoyah. And I'll just give you one  
8 example. The dry deposition velocity distributions,  
9 which are based on the size of the particles that are  
10 traveling, they were originally very, very wide. They  
11 spanned three orders of magnitude because they were  
12 taken from an international expert elicitation on non-  
13 site specific parameters for off-site consequence  
14 analyses from the mid-90s. And, generally, that was  
15 referred to, well, that's kind of the best that we  
16 have. But that was driving a lot of our uncertainty  
17 in the Peach Bottom results.

18 So when we went back and looked at what  
19 was the basis for the experts coming up with their  
20 distributions, we realized that they were taking into  
21 account the weather variability, in addition to the  
22 state of knowledge or epistemic aspects of the, you  
23 know, what is the true velocity for a given size  
24 particle as it's going a certain speed or whatever.  
25 And when we realized that, you know, we thought about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 it and our experts in this area came up with a revised  
2 distribution to reflect that we actually take weather  
3 variability into account when we then apply that  
4 velocity.

5 So that's just one example of, you know,  
6 these studies help us hone in on this is showing up to  
7 be very important, can we sharpen our pencil and do  
8 better at describing this parameter of uncertainties,  
9 and that's just another example.

10 MS. SANTIAGO: I think it also told us  
11 that it's really site-specific information that makes  
12 a difference in these analyses, and so weather being  
13 one of those. And I think, because of a number of  
14 different questions we've gotten from the Committee  
15 members, we've also improved our discussion on  
16 emergency preparedness and things like that. So  
17 that's another thing that I think we've improved since  
18 the original SOARCA analyses.

19 MEMBER RICCARDELLA: FLEX is real. It's  
20 implemented or being implemented in most plants. Are  
21 there any plans to look at, to re-look at the effects  
22 on this study of having FLEX equipment in place?

23 MR. ESMAILI: I guess not this one. This  
24 was unmitigated phases.

25 MEMBER RICCARDELLA: I understand that.

1 MR. ESMAILI: So we did some sensitivity  
2 to see if you have the igniters available, of course  
3 you are going to prevent. But as far as our insights  
4 are concerned, yes, it's not going to change, it's not  
5 going to change the conclusions of our --

6 MEMBER RICCARDELLA: Of an unmitigated  
7 study but . . .

8 MEMBER STETKAR: This is not a risk  
9 assessment. This is a stylized analysis of one  
10 specific sequence, a short-term station blackout.  
11 That's all it is. It's nothing more and --

12 MEMBER RICCARDELLA: Oh, I thought it said  
13 long term.

14 MEMBER STETKAR: So Level 3 PRAs should  
15 look at stuff like this. We've got a couple more  
16 slides here, and we're kind of running late on time  
17 here.

18 CHAIRMAN BLEY: Before we would start  
19 trying to whittle down the consequence numbers, I'd  
20 rather see us be systematic about the modeling  
21 uncertainties and trying to deal with them to see how  
22 --

23 MEMBER STETKAR: And there's things on the  
24 consequence analysis that we haven't discussed. They  
25 didn't treat Chattanooga very well or evacuation in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Chattanooga, for example. They treated evacuation  
2 within ten miles.

3 You know, so there are pluses and minuses  
4 that you could argue about, you know, in this whole,  
5 even within the context of this focused little study.  
6 It accomplished what it wanted to accomplish, an  
7 integrated assessment of MELCOR and MACCS challenging  
8 hydrogen releases in a particular type of containment.

9 MS. SANTIAGO: And to do that study, it  
10 took a lot of different folks with a lot of different  
11 technical disciplines. And I want to thank our  
12 program office staff, as well as our Sandia National  
13 Lab partners, for working with us diligently over the  
14 last 18 months. And I invited them today, a number of  
15 them. Andy Hahn, who is the project manager for the  
16 Sequoyah site, he got us out to the public meeting and  
17 we had a successful public meeting about a year and a  
18 half ago. Dr. Salman Haq organized it. I see Ed  
19 Roach and Todd Smith from our interoffice who helped  
20 diligently answer some questions that Dick Skillman  
21 asked us on emergency preparedness. And I want to  
22 thank Hossein, Casey Wagner, a lot of folks from  
23 Sandia, Randy Gauntt that worked on the MELCOR model  
24 and improved it. Kyle Ross, as well.

25 So this list, again, you've seen Dr.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Bixler, Keith Compton. But we couldn't have  
2 accomplished this particular technical analysis, as  
3 complex as it is, in the 18 months without this cadre  
4 of folks, and I really am honored to work with them.

5 The last is just a summary saying that we  
6 believe we met the objectives for the pilot analyses.  
7 And, John, I think you mentioned that. And I do think  
8 it was a wonderful recommendation that the ACRS gave  
9 us to do the Sequoyah analysis as an integrated  
10 analysis, doing the uncertainty analysis alongside of  
11 the deterministic analysis. It really gave us a lot  
12 of knowledge, and it helped us identify what  
13 parameters were important and most important. I think  
14 we've already talked about the improvements in the  
15 modeling capability over the last number of years.

16 And I want to thank each and every one of  
17 you for the challenging questions you've asked us in  
18 every meeting we've had with the subcommittee, as well  
19 as today. And I think it's only going to improve the  
20 documentation and the discussion in these reports. So  
21 it's a heartfelt thank you for listening to us over  
22 the years and giving us several recommendations.

23 And that concludes the presentation by the  
24 staff.

25 MEMBER STETKAR: Thank you. Any of the

1 members have any kind of final questions? If not, are  
2 there any, is there anyone in the room who would like  
3 to make a statement? If so, come on up to the  
4 microphone, identify yourself, and do so. Seeing no  
5 rush to the microphones.

6 If there are any members of the public on  
7 the bridgeline who would like to make a statement,  
8 just please speak up, identify yourself, and make a  
9 statement.

10 MR. BROWN: It's open.

11 MEMBER STETKAR: Okay. Any? Apparently  
12 not. Again, staff, thank you very much. You crammed  
13 a heck of a lot of material into the hour and a half,  
14 plus nine minutes, that we've had. And with that, Mr.  
15 Chairman, it's back to you.

16 CHAIRMAN BLEY: Thank you very much. At  
17 this point, we are going off the record for the week.

18 (Whereupon, the above-entitled matter went  
19 off the record at 2:38 p.m.)

20

21

22

23

24

25





**U.S. NRC**

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

# **State-of-the-Art Reactor Consequence Analyses (SOARCA) Project: Sequoyah Integrated Deterministic and Uncertainty Analyses**

Full Committee Briefing  
November 2, 2017

Patricia A. Santiago, Chief, Accident Analysis Branch  
Hossein Esmaili, Fuel and Source Term Code Development Branch  
Tina Ghosh, Accident Analysis Branch  
Division of Systems Analysis  
NRC Office of Nuclear Regulatory Research

# Outline

- Overview and Objectives
- Uses of SOARCA Modeling
- Short-Term Station Blackout Analyses
  - Severe Accident Progression Observations
  - Insights on Hydrogen and Containment
  - Offsite Consequence Analysis Summary
- Lessons Learned
- Summary

# Overview and Objectives

- SOARCA goals and objectives
  - Develop body of knowledge on the realistic outcomes of severe reactor accidents
  - Incorporate state of the art modeling (MELCOR/MACCS)
- SRM SECY-2012-0092
  - Limited to station blackouts (SBOs)
  - Focused on issues unique to ice condenser containment and hydrogen challenges
- SOARCA Sequoyah NUREG/CR report due to the Commission on November 30, 2017

# Uses of SOARCA Modeling to Support Agency Activities

## Technical Bases for Regulatory Framework

- MELCOR and MACCS analyses BWR Mark I filtered vent analysis and CPRR (Tier 1 – 5.1)
- Other containments and hydrogen (Tier 3 – 5.2 and 6)
  - Sequoyah SOARCA analyses supported closure of these items
  - SECY-15-0137 and SECY-16-0041
- Expedited spent fuel transfer (MACCS)
- Emergency preparedness – decommissioning exemption requests
- Uncertainty analyses determine most influential parameters
- MACCS parameter guidance supports new and advanced reactor designs, knowledge management for severe accident analysis

## Licensing and Environmental Review Uses of MACCS

- Environmental assessment and impact statement analyses
- Waste Confidence technical bases for spent fuel fires and D/FGEIS
- Hearing support for technical analyses (Indian Point; Seabrook)

# Uses of SOARCA Modeling to Support Agency Activities and Knowledge Management

## Insights for Emergent Issues with MELCOR and MACCS

- Supported NRC incident response to Fukushima event
- Fukushima Forensic Analysis to better understand BWR accident progression

## Knowledge management for Severe Accident Analyses

### SOARCA model and results


- Used in NRC training classes
- Used for staff knowledge about plant models
- Informs L3 PRA in modeling and analysis of severe accidents and consequences
- Updates the input decks for future needs and timely response in-house
  - MACCS and MELCOR decks can be applied to many scenarios beyond SBO
- Inform international research planning and benchmarking
  - MAAP-MELCOR-ASTEC crosswalk of Fukushima Unit 1 melt progression

***\*SOARCA studies cited in >270 publications domestically and internationally***

# Severe Accident Progression STSB0 High Level General Observations


- Consequences strongly (and intuitively) affected by *early vs. late* containment failure. Early containment failure dominated by hydrogen combustion, and late containment failure results mainly from ex-vessel phenomena (e.g., CCI)
- Early containment failures occur *only on the first hydrogen burn* (subsequent burns do not challenge containment integrity)
- Protracted safety valve (SV) cycling produces *lower in-vessel hydrogen* by the time of first burn
- Pressurizer SV failure to close (with large open area) results in greater hydrogen production and transport to the containment prior to the first burn, which increases the potential for early containment failure
- Late containment failures generally have reduced source term release benefiting from gravitational settling

# STSBO (Effect of SV)





# STSBO (Effect of SV)








# Containment Failure Outcomes


Long-term containment over-pressurization failure due to prolonged steam production and non-condensable gas generation



Early containment overpressure failures due to sufficiently large burns in containment

No BOC cases exhibit long-term overpressure failure before 72 hours

# Latent Cancer Fatality Risk (mean over weather trials), Conditional on the STSBO accident Occurring (per event)



# Offsite Consequence Analysis Summary

- Essentially zero individual early fatality risk was calculated for Sequoyah STSBO
- Individual, conditional LCF risks:
  - Small, even for cases resulting in early release to environment
  - Generally dominated by intermediate and long-term phase exposures compared to emergency phase exposures
- Parameters most important to uncertainty in LCF risk:
  - Time during fuel cycle when accident occurs
  - Cancer fatality risk factors for “residual” organ, lungs, and colon
  - Containment rupture pressure
  - Number of safety valve cycles prior to failing open (more important at shorter distances)
  - Normal relocation time (important beyond 10-mile EPZ)

# Lessons Learned



- A single “best-estimate” severe accident simulation is elusive due to many and varied uncertainties
- UA is an iterative process requiring complementary statistical and phenomenological expertise and analyses

## Cesium Regression Table

Sequoyah\_Final\_RegResults\_R2\_Cesium  
Data: RegData\_Final.xlsx

	Rank Regression		Quadratic		Recursive Partitioning		MARS		Main Contribution	Conjoint Contribution
	Final R <sup>2</sup>	0.40	0.77		0.51		0.77			
Input	R <sup>2</sup> contr.	SRRC	S <sub>I</sub>	T <sub>I</sub>	S <sub>I</sub>	T <sub>I</sub>	S <sub>I</sub>	T <sub>I</sub>		
<i>priSVcyc</i>	0.26	-0.53	0.32	0.86	0.58	0.96	0.41	0.76	0.280	0.294
<i>Cycle</i>	0.01	0.15	0.04	0.10	0.01	0.02	0.21	0.21	0.051	0.019
<i>Rupture</i>	0.05	-0.22	0.01	0.14	---	---	0.01	0.09	0.016	0.051
<i>Eu_Melt_T</i>	0.02	-0.15	0.02	0.27	0.02	0.40	0.01	0.30	0.013	0.205
<i>Shape_Fact</i>	0.04	0.21	---	---	0.00	0.00	0.00	0.00	0.010	0.000
<i>Ox_Model</i>	0.01	0.09	0.01	0.16	---	---	0.00	0.00	0.004	0.039
<i>Fseal_Pressure</i>	---	---	0.00	0.02	---	---	0.01	0.01	0.002	0.005
<i>Seal_Open_A</i>	0.01	-0.07	0.00	0.01	---	---	0.00	0.00	0.002	0.004
<i>Burn_Dir</i>	0.00	0.07	0.00	0.02	---	---	0.00	0.01	0.001	0.006





\* highlighted if main contribution larger than 0.02 or conjoint contribution larger than 0.1



**The case with earliest containment rupture – RLZ 554**

# Lessons Learned (cont.)

- Important to consider uncertainty within the overall analysis
  - SV Open Area Fraction distribution updated
- Integrated modeling important
  - Impact of assumed seismic initiator on evacuation





- MELCOR and severe accident progression: Kyle Ross, Jeff Cardoni, Chris Faucett, Troy Haskin, Randy Gauntt (SNL); Casey Wagner (dycoda); Hossein Esmaili, Trey Hathaway, Allen Notafrancesco, Salman Haq, Ed Fuller (NRC)
- MELMACCS: Nathan Bixler, Doug Osborn\*\* (SNL); Trey Hathaway (NRC)
- MACCS, consequence analysis and emergency response: Nathan Bixler, Matthew Dennis, Joe Jones, Doug Osborn\*\*, Fotini Walton (SNL); Trey Hathaway, Jonathan Barr, Keith Compton, Todd Smith, Edward Roach (NRC);
- UA methodology: Dusty Brooks, Matthew Denman (SNL); Tina Ghosh\*\*, Trey Hathaway (NRC)
- Accident scenario development: Selim Sancaktar, Jose Pires (NRC)

\*\**Co-leads*

# Summary

- Objectives met for pilot analyses
- Major step forward in realistic, integrated approach
- SOARCA important reference domestically and internationally
- Improved accident codes and models
- Key knowledge development and experience for staff

# References

- SECY-12-0092, “State-of-the-Art Reactor Consequence Analyses – Recommendation for Limited Additional Analysis” (July 2012)
- NUREG-1935, State-of-the-Art Reactor Consequence Analyses (SOARCA) Report (November 2012)
- NUREG/CR-7110, Vol. 1, SOARCA Project Peach Bottom Integrated Analysis, Rev. 1, (May 2013)
- NUREG/CR-7110, Vol. 2, SOARCA Project Surry Integrated Analysis, Rev. 1 (August 2013)
- NUREG/CR-7008, MELCOR Best Practices as Applied in the SOARCA Project (August 2014)
- NUREG/CR-7009, MACCS Best Practices as Applied in the SOARCA Project (August 2014)
- NUREG/CR-7155, SOARCA Project Uncertainty Analysis of the Unmitigated Long-Term Station Blackout of the Peach Bottom Atomic Power Station (May 2016)
- NUREG/BR-0359, Modeling Potential Reactor Accident Consequences, Rev. 1 (December 2012, update in progress)



# Acronyms & Abbreviations


AC	Alternating Current	MSIV	Main Steam Isolation Valve
BOC	Beginning of Cycle	NTTF	Fukushima Near-Term Task Force
CCDF	Complementary Cumulative Distribution Function	PDF	Probability Density Function
CCI	Core Concrete Interactions	PGA	Peak Ground Acceleration
CDF	Core Damage Frequency	PRA	Probabilistic Risk Assessment
CST	Condensate Storage Tank	PRT	Pressurizer Relief Tank
DC	Direct Current	PZR	Pressurizer
EOC	End of Cycle	RCP	Reactor Coolant Pump
EPZ	Emergency Planning Zone	RCS	Reactor Coolant System
EF	Early Fatality	RLZ	Realization
GE	General Emergency	RPV	Reactor Pressure Vessel
HL	Hot Leg	RtePM	Real Time Evacuation Planning Model
FLEX	Diverse and Flexible Coping Strategies	SBO	Station Blackout
FTC	Failure to Close	SG	Steam Generator
FTO	Failure to Open	SAE	Site Area Emergency
LCF	Latent Cancer Fatality	SIP	Shelter in Place
LNT	Linear No Threshold	SME	Subject Matter Expert
LTSBO	Long-Term Station Blackout	SNL	Sandia National Laboratories
MACCS	MELCOR Accident Consequence Code System	SOARCA	State-of-the-Art Reactor Consequence Analysis
MCR	Main Control Room	STSBO	Short-Term Station Blackout
MELCOR	Not an acronym - accident progression code	SV	Safety Valve
MeIMACCS	MELCOR to MACCS Source Term Converter	TDAFW	Turbine Driven Auxiliary Feedwater System
MOC	Middle of Cycle	TVA	Tennessee Valley Authority
		UA	Uncertainty Analysis



# Backup Slides

# Ice Condenser Containment

- Relatively low design pressure and smaller volume leads to potential susceptibility to early failure from hydrogen combustion in a station blackout
- Analyzed in Generic Safety Issue program (GSI-189)



# Code Updates

## *Draft vs. current UA*

- Various MELCOR 2.2 code updates including
  - Corrections to the reflood quench model
  - Lipinski dryout model not used above the core support plate
  - Decay heat transfer to small fluid volumes
  - Correction to fuel rod collapse modeling (temperature failure criteria)
  - Ex-vessel debris cooling and spreading models
- Presentation to ACRS on April 18, 2017
  - Changes in early containment failures in current UA (MELCOR 2.2) calculations are mainly due to modifications in the safety valve failing to close
  - Reduction in hydrogen generated in-vessel due to code changes not as important as model input changes

# MELCOR Model Parameters (STSBO)

Figures of merit studied include cesium/iodine release magnitude, in-vessel hydrogen generation, containment failure time, and time of initial release


**Table ES-1 Uncertain MELCOR parameters used in unmitigated STSBO UA**

Sequence Related Parameters
Primary safety valve stochastic number of cycles until failure-to-close Primary safety valve open area fraction
Secondary safety valve stochastic number of cycles until failure-to-close Secondary safety valve open area fraction
In-Vessel Accident Progression
Melting temperature of the eutectic formed of fuel and zirconium oxides Oxidation kinetics model
Ex-Vessel Accident Progression
Lower flammability limit hydrogen ignition criterion for an ignition source in lower containment Containment rupture pressure Barrier seal open area Barrier seal failure pressure Ice chest door open fraction Particle dynamic shape factor
Time within the Fuel Cycle
Time-in-cycle

Orange indicates additional parameters considered in current UA  
 Blue indicated updated parameters considered in the current UA




# STSBO - Effect of SV area fraction





# STSBO – Early Containment Failure Map



- In the 600 total UA calculations, 567 completed to 72 hours
- Of the completed calculations
  - 4 failed containment early on a sudden increase in pressure immediate to the first hydrogen deflagration
  - 492 failed containment between 36 and 72 hours after a gradual monotonic progression in pressure to rupture
  - 71 did not fail containment by 72 hours
    - 65 had a BOC reactor core represented
- In the 600 total UA calculations, 85 had a pressurizer SV FTC; of these 85:
  - 40 had a fractionally open position of the failed valve greater than 0.3
    - 17 failed to complete, meaning that only 23 of the total 600 UA calculations actually had potential to fail containment early
- First burns were ignited by hot gas issuing from the PRT in 23 of the successful 567 UA calculations and among these 23 there were 2 early containment failures



## Early Containment Failures (4 out of 567)

- Consequences strongly (and intuitively) affected by *early vs. late* containment failure
- Early containment failures occur *only on the first hydrogen burn* from in-vessel generated hydrogen
- In-vessel generated hydrogen is maximized when pressurizer SV sticks open early at greater than 30% open and with higher temperature fuel collapse criteria
- First burns that fail containment initiated in lower compartment from HL rupture or PRT venting and propagate to dome where more than 150kg hydrogen was present
- Some early burns were just under the sampled containment failure pressure
- Early containment failure source terms generally higher due to unsettled airborne fission products

## Late Containment Failures (492 out of 567)

- Protracted SV cycling produces *lower in-vessel hydrogen*
- Ex-vessel CCI-generated hydrogen greatly exceeds in-vessel hydrogen but produces ongoing small burns
- Ex-vessel burns in cavity prevent large dome hydrogen concentrations from accumulating
- Late hydrogen burns are terminated by insufficient oxygen for combustion
- Late containment failures from static overpressure: increasing temperature, rising steam pressure, accumulating gases
- BOC and some MOC did not fail containment before 72 hours due to lower decay heat and slower pressurization
- Late failures generally have reduced source term release benefiting from gravitational settling

# Sequoyah STSBO: MACCS Uncertain Parameter Groups

## Deposition

- Wet Deposition
- Dry Deposition Velocities

## Dispersion

- Crosswind Dispersion Linear Coefficient
- Vertical Dispersion Linear Coefficient
- Time-Based Crosswind Dispersion Coefficient

## Latent Health Effects

- Dose and Dose Rate Effectiveness Factor
- Lifetime Cancer Fatality Risk Factors
- Long Term Inhalation Dose Coefficients

## Early Health Effects

- Threshold Dose
- Lethal Dose to 50% of population
- Hazard Function Shape Factor

## Shielding Factors

- *Groundshine Shielding Factors\**
- *Inhalation Protection Factors\**

## Emergency Response

- *Evacuation Delay\**
- *Evacuation Speed\**
- Hotspot Relocation Time and Dose Criteria
- Normal Relocation Time and Dose Criteria
- Keyhole Forecast Time

## Aleatory Uncertainty

- Weather Trials

\*Blue text indicates parameters updated from earlier draft Sequoyah SOARCA report (ML16096A374)

# Mean, Individual, LCF Risk Regression Results within 0 – 10 mile and 0 – 50 mile for STSBO Based on LNT

<b>0 – 10 Mile</b>								Main Contribution	Conjoint Contribution		
		Rank Regression		Quadratic		Recursive Partitioning				MARS	
Final R <sup>2</sup>		0.67		0.86		0.58				0.78	
Input	R <sup>2</sup> contr.	SRRC	S <sub>i</sub>	T <sub>i</sub>	S <sub>i</sub>	T <sub>i</sub>	S <sub>i</sub>	T <sub>i</sub>			
Cycle	0.36	0.58	0.23	0.29	0.40	0.60	0.20	0.20	0.237	0.056	
priSVcyc	---	---	0.04	0.15	0.12	0.15	0.14	0.31	0.070	0.083	
CFRISK(8)	0.09	0.29	0.07	0.12	0.08	0.23	0.10	0.09	0.068	0.042	
Rupture	0.06	-0.24	0.06	0.08	0.07	0.18	0.09	0.15	0.054	0.046	
CFRISK(7)	0.03	0.19	0.06	0.10	0.05	0.11	0.08	0.10	0.040	0.031	
GSHFAC_6(2)	0.05	0.22	0.02	0.06	0.01	0.05	0.04	0.03	0.026	0.021	
CFRISK(6)	0.01	0.09	0.04	0.11	---	---	0.04	0.07	0.018	0.029	
CFRISK(3)	0.02	0.11	---	---	0.00	0.01	0.03	0.10	0.011	0.018	
DDREFA(8)	0.01	-0.11	0.03	0.04	---	---	---	---	0.010	0.002	

\* highlighted if main contribution larger than 0.02 or conjoint contribution larger than 0.1

<b>0 – 50 Mile</b>								Main Contribution	Conjoint Contribution		
		Rank Regression		Quadratic		Recursive Partitioning				MARS	
Final R <sup>2</sup>		0.59		0.86		0.65				0.75	
Input	R <sup>2</sup> contr.	SRRC	S <sub>i</sub>	T <sub>i</sub>	S <sub>i</sub>	T <sub>i</sub>	S <sub>i</sub>	T <sub>i</sub>			
Cycle	0.23	0.52	0.24	0.31	0.36	0.44	0.21	0.21	0.208	0.038	
CFRISK(8)	0.06	0.24	0.09	0.13	0.05	0.14	0.09	0.08	0.059	0.029	
Rupture	0.05	-0.21	0.06	0.10	0.05	0.22	0.10	0.25	0.052	0.086	
CFRISK(4)	0.05	0.23	0.07	0.10	0.04	0.15	0.08	0.09	0.048	0.037	
CFRISK(7)	0.04	0.22	0.05	0.07	0.02	0.10	0.08	0.11	0.040	0.028	
TIMNRM	0.04	0.22	0.04	0.07	0.06	0.30	0.05	0.06	0.038	0.061	
CYSIGA(1)	0.03	0.19	0.03	0.04	0.01	0.05	---	---	0.015	0.013	
DDREFA(4)	0.02	-0.13	0.02	0.02	0.00	0.04	0.02	0.02	0.013	0.011	
CFRISK(6)	0.01	0.08	0.03	0.12	---	---	0.02	0.08	0.012	0.042	

\* highlighted if main contribution larger than 0.02 or conjoint contribution larger than 0.1

# Mean (over weather variation) individual early fatality risk , conditional on accident occurring (per event)

	0 - 1 miles	0 - 1.3 miles	0 - 2 miles
<b>Mean</b>	3.0E-09	1.8E-09	8.6E-10
<b>Median</b>	0.0E+00	0.0E+00	0.0E+00
<b>5th percentile</b>	0.0E+00	0.0E+00	0.0E+00
<b>95th percentile</b>	0.0E+00	0.0E+00	0.0E+00


- Nonzero early fatality risk within 1 mile for three realizations
- No early fatality risk beyond 2 miles for any realization
- Only 3 realizations out of 567 resulted in non-zero early fatalities

# U.S. Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards



**Public Session**  
**November 2, 2017**

# Business Model



➤ Captive Network of University Research Reactors

- Reliability/assurance of supply
- Multiple shipments/week

➤ Radioisotope Production Facility (RPF)

- Fabrication of LEU targets
- Mo-99 production
- Uranium recycle and recovery

➤ Domestic Mo-99 Generator Distributors

- Hold FDA Drug Master File
- No changes to generators
- No changes to supply chain



# University Reactor Network and NWMI Location



- 6 mi to MURR
- 5 mi to regional airport
- 3<sup>rd</sup> Reactor selection complete but not yet socialized
- 100 mi to Mallinckrodt
- Anchor of isotope “ecosystem”



# Siting – Discovery Ridge Research Park

- University system owned 550 acre research park
- NWMI “anchor” for radioisotope ecosystem; two existing companies (RADIL and ABC Laboratories)
- RPF would be located in Lot 15 of the Discover Ridge Phase II section (54.9 acres)
- Lot 15 is 7.4 acres and contains no existing structures
- Research Park being developed under guidance of the Master Plan Protective Covenants (MU, 2009)




Source: MU, 2011, “Phasing Overview,” Maps and Roads, Research Parks & Incubators, Discovery Ridge, [www.umsystem.edu/umrpi/discoveryridge/maps](http://www.umsystem.edu/umrpi/discoveryridge/maps), University of Missouri, Columbia, Missouri, accessed July 2013.



# Primary Assumptions

- Single radioisotope production facility (RPF)
  - RPF includes target fabrication, Mo-99 production, and uranium recycle & recovery
    - Simple/straightforward chemistry processes
  - Mo-99 produced using a fission-based method – “Gold Standard” using LEU
  - Nominal capacity 3,500 6-day Ci; surge capacity of 1,500 6-day Ci
- Use network of university reactors
  - Use same target design for all reactors
  - Intellectual Property obtained
    - U.S., Australia, Russia, South Africa, Korea → Allowed
    - India, Europe, China → Pending



# NRC Licensing Strategy

- Combine several license activities and submit one application that covers all applicable regulations for construction/operation of the RPF under 10 CFR 50

## 10 CFR 50 Activities

- Irradiated target receipt
- Irradiated target disassembly
- Target dissolution
- <sup>99</sup>Mo separations, purification, and packaging
- Uranium (U) recycle and recovery
- Waste management
- Associated laboratory and support


## 10 CFR 70 Activities

- Receipt of low-enriched uranium (LEU) (from DOE)
- Production of LEU microspheres
- Target fabrication and testing
- Shipping/loading of fabricated targets
- Laboratory and support areas


## 10 CFR 30 Activities

- Handling of byproduct material

- University reactor(s) and cask licensee(s) will amend their current operating licenses



# RPF Process Flow Diagram



- 1 LEU target material is fabricated (both fresh LEU and recycled U)
- 2 LEU target material encapsulated using metal cladding → LEU target
- 3 LEU targets are packaged and shipped to university reactors for irradiation
- 4 After irradiation, targets are shipped back to RPF
- 5 Irradiated LEU targets disassembled
- 6 Irradiated LEU targets dissolved into a solution for processing
- 7 Dissolved LEU solution is processed to recover and purify <sup>99</sup>Mo
- 8 Purified <sup>99</sup>Mo is packaged/shipped to a radiopharmaceutical distributor
- 9 LEU solution is treated to recover U and is recycled back to Step 1

# Facility Description

- First level footprint ~52,000 ft<sup>2</sup>
  - Target fabrication area
  - Hot cell processing area (dissolution, <sup>99</sup>Mo, and <sup>235</sup>U recovery)
  - Waste management, laboratory and utility areas
- Basement ~2,000 ft<sup>2</sup> (tank hot cell, decay vault)
- Second level ~17,000 ft<sup>2</sup> (utility, ventilation, offgas equipment)
- Waste Management Building ~1,200 ft<sup>2</sup>
- Administration Building (outside of secured RPF area) ~10,000 ft<sup>2</sup>
- High bay roof – 65 ft
- Mechanical area, second floor – 46 ft
- Top of exhaust stack – 75 ft
- Loading dock (back) roof – 20 ft
- Support and admin (front) roof – 12 ft
- Depth below grade for hot cell/high-integrity container (HIC) storage – 15 ft



# Project Schedule (Calendar Year)

- Start date of site preparation/construction → Q2 2018
- End date of construction → Q2 2019
- Start date of facility startup and cold commissioning (pre-operational) → Q3 2019
- Date of hot commissioning and commercial operations → Q4 2019/Q1 2020
- Date of decommissioning: 2050



# Chapter 2 – Miscellaneous

- Transient population
- Nearby industrial, transportation, and military facilities
  - Airports/Heliports
  - Pipelines
  - Highways
  - Nearby facilities
- Geotechnical investigation
- Maximum probable precipitation in a one-hour period is 3.14 in/hour
- Seasonal and annual frequency of historical tornadoes (1954 – 2016) updated
- Seasonal and annual thunderstorm wind events (1955 – 2016) updated
- Lighting events (1998 – 2016) updated
- Seasonal and annual hail events (1958 – 2016) updated
- Winter weather events (1996 – 2016) updated
- Recorded Missouri earthquake history updated

# Chapter 3 – RPF Design Evolution

- RPF design is being completed in stages
- RPF preliminary design complete and final design initiated
- Final design is needed to develop Operating License (OL) Application and construction drawings
- Construction documentation consists of drawings and specifications
  - Describe quality, configuration, size, and relationship of all components of RPF
  - Serve as a basis for obtaining bids from contractors
- All supporting documentation will be finalized, which includes but is not limited to:
  - Final hazards analysis and associated qualitative risk assessment
  - Integrated safety analysis
  - Criticality safety evaluations and associated calculations
  - Criticality safety program
  - Criticality accident alarm system/dose analyses
  - Shielding analysis
  - Fire hazards analysis
  - Radiation protection program
  - Waste management program
  - Material control and accountability program
  - Natural phenomena hazards/external events analysis
  - Emergency preparedness program
  - Quality assurance program
  - Safeguards and security program

# Chapter 2 and 3 – Seismic

- Probabilistic seismic hazard analysis (PSHA) was performed by NRC staff for University of Missouri Research Reactor (MURR) site to assess seismic safety of reactor facility using present-day methodologies
- Seismic hazard curves were estimated at control point (top of weathered rock layer)
  - $10^{-4}$  and  $10^{-5}$  uniform hazard response spectra were also calculated using results of confirmatory PSHA and site response analyses and ground motion response spectra (GMRS) was computed using Regulatory Guide 1.208
- NWMI compared seismic GMRS with peak ground acceleration of 0.2 g
  - Used in Callaway Nuclear Plant and MURR
- GMRS is enveloped by seismic response spectrum with peak ground acceleration of 0.2 g up to about 16 hertz (Hz)
- Based on EPRI guidance, ground motions at higher than approximately 10 Hz frequency are not damaging to SSCs of a nuclear reactor, except functional performance of components sensitive to vibration (e.g., electrical relays)
- If electrical relays are fail-safe on excess vibration or loss of power, safety function of such relays will not be compromised
- NWMI will evaluate dynamic analyses of RPF structural components
- NWMI will define specific acceptable qualification methods in procurement packages to demonstrate seismic qualifications



# Chapter 3 – Tornado-Generated Missile Impact Effects

- Missile is assumed rigid for maximum penetration
- Expected speed of tornado missiles is larger than expected speed of any hurricane-generated missiles at same annual frequency of exceedance
  - NUREG/CR-7005, *Technical Basis for Regulatory Guidance on Design-Basis Hurricane Wind Speeds for Nuclear Power Plants*
- Tornado-generated missile impact effects are based on standard design missile spectrum from NRC Regulatory Guide 1.76
  - Wind velocities in excess of 75 mi/hr are capable of generating missiles from objects lying within path of tornado wind and from debris of nearby damaged structures
- DOE-STD-1020 (Table 3-4) recommends RPF roof and wall system design criteria

*Design-Basis Tornado Missile Spectrum*

Description	Weight	Dimensions	Horizontal velocity	Vertical velocity
Automobile	4,000 lb	16.4 ft × 6.6 ft × 4.3 ft	92 mi/hr	62 mi/hr
Pipe	287 lb	6.625 in. diameter × 15 ft long	92 mi/hr	62 mi/hr
Steel Sphere	0.147 lb	1.0 in. diameter	18 mi/hr	12 mi/hr

Source: NRC Regulatory Guide 1.76, *Design-Basis Tornado and Tornado Missiles for Nuclear Power Plants*, U.S. Nuclear Regulatory Commission, Washington, D.C., March 2007.

# Chapter 5 – Coolant Systems

---

- Weekly Irradiated Target Heat Generation rate added
- Thermal load is characterized by radial heat transfer in a vessel and uranium concentration of solutions held within vessels throughout RFP
- Number of targets to be irradiated will be optimized in Operating License (OL) Application

# Chapter 6 – Criticality Accident Alarm System

- RPF criticality accident alarm system (CAAS) will meet Title 10 CFR 70.24, *Criticality Accident Requirements*
- NWMI commits to current endorsed version of ANSI/ANS-8.3, *Critically Accident Alarm System*, with modifications as noted in Regulatory Guide 3.71, *Nuclear Criticality Safety Standards for Fuels and Materials Facilities*
- CAAS evaluation will be completed during RPF final design and provided in OL Application
- CAAS coverage will be in all areas in which greater than 10 CFR 70.24 mass limits of SNM are handled, used, or stored, and in all shielding areas of RPF
  - Controls will be established to preclude such SNM from areas where coverage is not provided
  - Each monitored area will be covered by two criticality detectors
- NWMI will establish a CAAS appropriate to RPF for type of radiation detected or shielding and magnitude of minimum accident of concern
  - Will consider potential damages from anticipated adverse events (e.g., fire, explosion)
  - Will be resistant to RPF design-basis earthquake
- Operations will be rendered safe, by shutdown and quarantine, if necessary, in any area where CAAS coverage has been lost and not restored within a specified number of hours
- Emergency power will be provided to CAAS by uninterruptable power supply system

# Chapter 6 – Criticality Safety

- Prior to end of construction and with submittal of OL Application, NWMI will ensure that all processes containing SNM within RPF are evaluated to be subcritical under all normal and credible abnormal conditions
- NWMI will use nuclear criticality safety (NCS) controls for mass, geometry, moderation, volume, and interaction
  - NWMI commits to specific criteria for each on parameters under NCS control at RPF
- NWMI commits to evaluate controlled parameters at associated safety limits and to evaluate parameters that are not controlled at most reactive credible values
- NWMI acknowledges that use of a single NCS control to maintain values of two or more controlled parameters constitutes only one component necessary to meet double-contingency principle
- Order of preference for NCS controls will be
  - Passive engineered
  - Active engineered
  - Enhanced administrative
  - Simple administrative controls
- NWMI will make every effort to use passive engineered controls, in particular, passive engineered geometry control
- If RPF operations rely on two or more controls on a single parameter, NWMI commits to using diverse over-redundant means of control

# Chapter 6 – Update of USL and Criticality Safety Evaluations

- NWMI will ensure that all processes containing SNM under normal and credible abnormal conditions will meet revised USL of 0.9240
- Criticality safety evaluations (CSE) will be updated during RPF final design
- NCS operating limits will be established based on analyses assuming optimum or most reactive credible values of parameters unless specified controls are implemented to limit parameters to a range of values
  - e.g., most reactive conditions physically possible or bounding values limited by regulatory requirements
- Specific controls and management measures necessary to enforce NCS safety limits and/or operating limits will be specified in each CSE

# Chapter 7 – Instrumentation and Control Systems

- FPC system will be a DCS that functions independently
- IROFS/ESF safety functions will be activated via hardwire (analog) interlocks
- Process control system includes interlocks (both hardwired [ESF] and computer logic) to implement an automatic action on a parameter approaching or being outside its setting
  - Interlocks defined as specific set of conditions or parameters that need to be met for an activity to occur
  - Example of an interlock is shutting down a pump on a tank high-level alarm signal or switching to a spare unit or process train based on a change in parameters (and corresponding alarm)
- RPF will also implement a permissive philosophy that allows HMI operations to be enabled once control room has confirmed prerequisites conditions have been completed
  - Permissives differ from interlocks in that permissives require manual approval via a switch (or similar) that must be satisfied for an activity to occur
  - Interlocks are engineered features, and permissives are administrative features
- Permissive and interlocks will be described in more detail in OL Application




Figure 7-1 Facility Instrumentation and Control System Configuration

# Chapter 13 – Uranium Metal Fires

- Targets are fabricated from uranium (U) metal receipts (Y-12) during initial operation
- Evaluated packing and shipping of U metal in compliance with ES-3100 container requirements and planned handling at RPF
  - NWMI-2015-SAFETY-007, *Quantitative Risk Analysis of Facility Fires and Explosions Leading to Uncontrolled Release of Fissile Material, High- and Low-Dose Radionuclides*
- As part of OL application, nonstandard payloads and configurations and failures of hardware/control will be evaluated including worker safety/exposure from potential U metal fires
  - Controls will be elevated to IROFS for U exposure → 10 CFR 70.61, *Performance Requirements*
- Evaluation in NWMI-2015-SAFETY-007 is based on an existing analysis in SNF-6192-FP, *Uranium Pyrophorocity Phenomena and Prediction*, of ignition test observations for U hydride powder with a characteristic particle diameter of 1.85 micron ( $\mu$ )
  - Current evaluation indicates that significant particle bed depths (greater than 7 mm) are required to observe ignition at ambient temperature
  - Bed depth to accumulate on a metal shape piece during shipping/storage is considered highly unlikely
- U metal handling activities will be reevaluated and provided in OL Application
- NWMI plans to implement appropriate controls in hood/glovebox to extinguish a U metal fire (e.g. magnesium oxide sand) per DOE-HDBK-1081-2014, *Primer on Spontaneous Heating and Pyrophoricity*

# Questions?






**Advisory Committee on Reactor Safeguards  
Meeting on Northwest Medical Isotopes Construction Permit Application**

**Northwest Medical Isotopes  
Production Facility Construction Permit  
Application Review**

Office of Nuclear Reactor Regulation  
Office of Nuclear Material Safety and Safeguards  
U.S. Nuclear Regulatory Commission  
November 2, 2017



# Introductions

- **Michael Balazik** - Project Manger, Research and Test Reactors Licensing Branch, Division of Licensing Projects, Office of Nuclear Reactor Regulation
- **David Tiktinsky** - Senior Project Manager, Fuel Manufacturing Branch, Division of Fuel Cycle Safety, Safeguards, and Environmental Review, Office of Nuclear Material Safety and Safeguards
- **Alexander Adams, Jr.** - Chief, Research and Test Reactors Licensing Branch, Division of Licensing Projects, Office of Nuclear Reactor Regulation

# Overview of the NWMI Application

- NWMI has submitted a 10 CFR Part 50 construction permit application for a *production facility* to:
  - Disassemble and dissolve low-enriched uranium (LEU) targets
  - Recover and purify molybdenum-99 ( $^{99}\text{Mo}$ )
  - Recover and recycle uranium
- Two-part construction permit application
  - Environmental Report docketed May 2015
  - Preliminary Safety Analysis Report (PSAR) docketed Dec 2015
- According to NWMI, a 10 CFR Part 70 application for possession and use of special nuclear material (SNM) will be submitted in the future
- Proposes to construct facility in Columbia, MO

# NRC Licensing Approach

- NWMI facility includes several hot cell structures, which meet the 10 CFR 50.2 definition of *production facility*
- 10 CFR 50.2 defines *production facility*, in part, as:
  - Any facility designed or used for the processing of irradiated materials containing special nuclear material...
  - If material processed in batches greater than 100 grams of uranium-235
- While NRC has historically licensed Part 50 production facilities, no such facilities are currently operating
  - SHINE was issued a construction permit (for *utilization* and *production* facilities)

# NWMI Activities Noted in Application, but Not Part of Construction Permit Safety Review

- Radioisotope production facility (RPF) building would also have a production facility and a target fabrication area
- Target fabrication
  - Processing of unirradiated uranium does not meet the definition of either a *utilization* or a *production facility* (10 CFR Part 50)
  - Processes, activities, and hazards similar to fuel-cycle facility
  - Receipt and possession of fresh LEU (greater than a critical mass), use of SNM, and scrap recovery of SNM
- PSAR Chapter 1 (Rev. 3) states that target fabrication will be applied for under a separate 10 CFR Part 70 license application

# **NWMI Activities Noted in Application, but Not Part of Construction Permit Safety Review**

- Target fabrication SSCs not considered unless shared with the production facility, but no safety findings made on their adequacy for target fabrication
- Target irradiation at research reactors separate application submitted by reactor licensee
- SER findings limited to the 10 CFR Part 50 production facility

# Regulatory Guidance and Acceptance Criteria

- NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors”
- Interim Staff Guidance Augmenting NUREG-1537
  - Production facilities
  - Incorporates relevant non-reactor guidance from NUREG-1520, Rev. 1, “Standard Review Plan for the Review of a License Application for a Fuel Cycle Facility”
- Other guidance (e.g., regulatory guides and ANSI/ANS standards) and engineering judgment used, as appropriate, to make construction permit findings

# NUREG-1537 and ISG Review Areas

1. The Facility/Introduction
2. Site Characteristics
3. Design of Structures, Systems, and Components
4. Facility Description
5. Coolant Systems
6. Engineered Safety Features
7. Instrumentation and Control
8. Electrical Power Systems
9. Auxiliary Systems
10. Experimental Facilities\*
11. Radiation Protection and Waste Management
12. Conduct of Operations
13. Accident Analysis
14. Technical Specifications
15. Financial Qualifications
16. Other License Considerations\*
17. Decommissioning\*
18. Uranium Conversions\*
19. Environmental Review

\*Not applicable to the NWMI construction permit application



# Construction Permit Requirements

- Some regulations applicable to NWMI construction permit:
  - 10 CFR 50.22 (licenses for commercial and industrial facilities)
  - 10 CFR 50.30 (filing of application and Environmental Report)
  - 10 CFR 50.34(a), “Preliminary safety analysis report”
  - 10 CFR 20.1201, “Occupational dose limits for adults”
  - 10 CFR 20.1301 (public and accident dose limits)
  - 10 CFR 50.35, “Issuance of construction permits”
  - 10 CFR 50.40, “Common standards”
  - 10 CFR 50.50, “Issuance of licenses and construction permits”
- Per the ISG Augmenting NUREG-1537, 10 CFR 70.61, “Performance Requirements,” may be used by applicants to demonstrate adequate safety of a medical isotopes production facility
- 10 CFR Part 50, Appendices A, “General Design Criteria....,” and B, “Quality Assurance Criteria...,” apply to nuclear power and fuel reprocessing plants
- 10 CFR Part 100, “Reactor Site Criteria,” siting and accident dose criteria apply to nuclear power reactors and testing reactors

# Construction Permit Application Contents

- Consists primarily of environmental report and preliminary safety analysis report (PSAR), as required by 10 CFR 50.30 and 50.34
- PSAR includes:
  - Preliminary design of the facility, including principal design criteria, design bases, general arrangement, and approximate dimensions
  - Preliminary analysis of structures, systems, and components, including ability to prevent and mitigate accidents
  - Probable subjects of technical specifications
  - Preliminary emergency plan
  - Quality assurance program
  - Research and development

# Operating License Application Contents

- Must include final safety analysis report and supplement, if needed, to environmental report
- Must include final design and analyses that conforms to the design bases of the facility as well as:
  - Plans for operation
  - Emergency Plan
  - Technical Specifications
  - Physical Security Plan

# Construction Permit vs. Operating License

- Construction permit (10 CFR 50.35)
  - Allows licensee to proceed with construction based on preliminary design information
  - Does not approve of the safety of any design feature or specification unless specifically requested by the applicant
- Operating license (10 CFR 50.57)
  - Allows licensee to operate the facility based on final design
  - Issued when, among other things, construction of the facility is substantially completed in accordance with NRC requirements and there is reasonable assurance that the activities authorized by the license will not endanger the public health and safety

# NRC Review Methodology

- Since construction permit only allows construction, level of detail needed in application and staff's SER is different than for combined operating license or operating license applications
- For the purposes of issuing a construction permit, the NWMI production facility may be adequately described at a functional or conceptual level in the PSAR
- NWMI has deferred providing many design and analysis details until the submission of its final safety analysis report (FSAR) with its operating license application
- Staff's review tailored to unique and novel technology described in NWMI's construction permit application using appropriate regulatory guidance

# Resolving Technical Deficiencies

- For technical areas requiring additional information, the staff has several options:
  - The staff may determine that such technical issues must be resolved prior to the issuance of a construction permit
  - The staff may determine that such information may be left until the submission of the FSAR
  - The staff may require that such technical issues be resolved prior to the completion of construction, but after the issuance of the construction permit
- In all cases, staff may issue requests for additional information
- In the second and third options, staff may track regulatory commitments or identify necessary license conditions

# Tracking Commitments and License Conditions

- SER Appendix A
  - Appendix A.1 – Proposed license conditions
  - Appendix A.2 – Regulatory commitments identified in responses to RAIs
  - Appendix A.3 – Fulfilled regulatory commitments identified in responses to RAIs
  - Appendix A.4 – Commitments identified through meeting with the ACRS Subcommittee
  - Appendix A.5 – Ongoing research and development

# Proposed License Conditions – Criticality

- Prior to the completion of construction, NWMI shall ensure that all nuclear processes are evaluated to be subcritical under all normal and credible abnormal conditions. This determination shall be done for each area as described in Section 6.3.1.1 of the NWMI PSAR prior to each area being completed, and shall be done consistent with the Upper Subcritical Limit (USL) established in Revision 2 of NWMI's Validation Report. NWMI shall submit periodic reports to the NRC, at intervals not to exceed 6 months from the date of the construction permit, summarizing any changes or indicate no change to the criticality safety evaluations as a result of the revised USL.
- Prior to the completion of construction, NWMI shall submit periodic reports to the NRC, at intervals not to exceed 6 months from the date of the construction permit. These reports shall provide the technical basis for the design of the CAAS or notify the NRC of no change. Prior to the completion of construction, the reports shall demonstrate detector coverage as defined in the requirements of 10 CFR 70.24(a).



# Proposed License Conditions – Quality Assurance

- NWMI shall implement the quality assurance program described, pursuant to 10 CFR 50.34(a)(7), in revision 3 of the NWMI preliminary safety analysis report, including revisions to the quality assurance program. NWMI may make a change to its previously accepted quality assurance program description provided the change does not reduce the commitments in the program description previously accepted by the NRC. Changes to the quality assurance program description that do not reduce the commitments must be submitted to the NRC within 90 days. Changes to the quality assurance program description that do reduce the commitments must be submitted to the NRC and receive NRC approval before implementation.
- Similar to the requirements of 10 CFR 50.55(f) for implementing and changing an approved quality assurance program (applicable to power and fuel processing plant permit holders)

## Appendix A.4 –Regulatory Commitments Identified Through ACRS Subcommittee Meetings

Date and ADAMS Accession Number for Correspondence	Description
September 18, 2017 ML17265A048	NWMI will provide an evaluation of the effects of high frequency spectral accelerations (i.e., > 10 hertz) on high-frequency sensitive structures, systems, and components during seismic events (e.g., electrical relays, instrumentation) in its FSAR.
September 18, 2017 ML17265A048	NWMI will provide details on the final grading of site, ensuring that stormwater from localized downpours will be directed around and away from the Radioisotope Production Facility (RPF), in its FSAR.
September 18, 2017 ML17265A048	NWMI will provide a final hazards analysis (FHA) for its facility as part of its FSAR. This FHA will re-examine those accident sequences that were screened out of the preliminary hazards analysis, ensuring that the FHA properly accounts for the accident sequences relevant to the final design of the facility.
September 18, 2017 ML17265A048	NWMI will provide an evaluation of the potential impacts of a uranium fire in the target manufacturing facility licensed under 10 CFR Part 70 on the RPF.
September 18, 2017 ML17265A048	NWMI will provide an evaluation the possible effects of damaged electrical equipment and resulting in possible unexpected effects of interaction between otherwise unrelated, independent, and separate circuits

## Appendix A.4 –Regulatory Commitments Identified Through ACRS Subcommittee Meetings (continued)

Date and ADAMS Accession Number for Correspondence	Description
September 28, 2017 ML17283A108	NWMI will determine during RPF final design whether facility operations will use an on-site dedicated fire water supply and/or use the City of Columbia fire water supply.
September 28, 2017 ML17283A108	NWMI will resolve the discrepancy in the maximum estimated precipitation for the 24-hour and 48-hour period during the RPF final design and provide the information in the operating license application.
September 28, 2017 ML17283A108	NWMI will reexamine and ensure the accuracy of its estimates for aircraft take-offs and landings at the Columbia Regional Airport and for the surrounding heliports during the RPF final design.
September 28, 2017 ML17283A108	NWMI will provide its strategy for addressing an extended shutdown of the NWMI production facility during the final design.
September 28, 2017 ML17283A108	NWMI will further assess the need for an independent control room as part of our RPF final design.

# Aircraft Impact Analysis

- ACRS Subcommittee identified errors in NWMI's aircraft impact analysis
- NRC Staff performed a confirmatory analysis
  - Total aircraft impact frequency calculated by the NRC staff is of the same order of magnitude as that calculated by NWMI
  - NRC staff finds that the applicant should evaluate the impact of a general aviation crash (greater than order of magnitude  $10^{-7}$ )
  - Errors identified include inconsistent flight operations, incorrect crash rates for specific aircraft, inconsistent non-airport crash frequency, transposition errors in crash impact probabilities, and incorrect runway bearings

Type of Aircraft	Impact Frequency (yr <sup>-1</sup> )	
	NWMI	NRC Staff
General aviation	1.78E-07	3.22E-07
Commercial air carrier	1.61E-11	2.55E-10
Air taxis	3.27E-11	4.38E-09
Military large	1.66E-08	2.60E-08
Helicopter	9.7E-07	5.1E-07
Airways	1.0E-06	1.1E-06
Total	2.2E-06	1.9E-06

# Aircraft Impact Analysis (continued)

- SER Appendix A.4 - NWMI will reexamine and ensure the accuracy of its estimates for aircraft take-offs and landings at the Columbia Regional Airport and for the surrounding heliports
- NWMI commits to resolve the discrepancies in the data during the final design and will be provided in the operating license application
- The staff will further review the aircraft impact analysis in the FSAR as part of the OL application to ensure that these deficiencies are corrected

# Status of the NWMI Review

- As of October 2017, NWMI has adequately responded to all requests for additional information
- NWMI PSAR Rev. 3 in ADAMS on September 14, 2017 (ADAMS Accession No. ML17257A019)
- Final environmental impact statement published in May 2017 (NUREG-2209)
- Safety evaluation report in concurrence and set for issuance in November 2017
- Mandatory hearing on construction permit application scheduled for January 23, 2018

# Regulatory Basis for Construction Permit

- The following findings must be made to issue a construction permit, based on 10 CFR 50.35:
  - Facility design has been described, including the principal architectural and engineering criteria for the design
  - Further technical or design information as may be required to complete the safety analysis can reasonably be left for later consideration, and will be provided, in the FSAR
  - Safety features or components requiring research and development have been identified and there will be conducted a research and development program reasonably designed to resolve any associated safety questions
  - Safety questions will be resolved prior to the completion of construction and the proposed facility can be constructed and operated at the proposed location without undue risk to the health and safety of the public
- Staff's conclusions also based on the considerations in 10 CFR 50.40 and 50.50

# 10 CFR 50.35(a)(1) Findings

- *Facility design has been described, including the principal architectural and engineering criteria for the design, and major features or components have been identified for protection of public health and safety*
  - Staff evaluated preliminary design to ensure sufficiency of principal design criteria; design bases; and information relative to materials of construction, general arrangement, and approximate dimensions
  - When necessary, staff issued requests for additional information and performed confirmatory calculations
- Staff finds that there is reasonable assurance that final design will 1) conform to design basis, 2) provide adequate margin for safety, 3) provide for the prevention and mitigation of accidents, and 4) meets applicable regulatory requirements and acceptance criteria



## 10 CFR 50.35(a)(2) Findings

- *Such further technical or design information as may be required to complete the safety analysis, and which can reasonably be left for later consideration, will be supplied in the final safety analysis report*
  - The staff evaluated the sufficiency of the preliminary design of the NWMI production facility based on NWMI's design methodology and ability to provide reasonable assurance that the final design will conform to the design bases with adequate margin for safety
  - Throughout PSAR and in response to RAIs, NWMI has indicated areas that require further technical or design information
  - Staff is tracking this information as regulatory commitments as identified in Appendix A of the SER.
- Staff finds that NWMI has provided reasonable assurance that further technical or design information, which can reasonably be left for later consideration, will be provided in the FSAR

## 10 CFR 50.35(a)(3) Findings

- *Safety features or components requiring research and development have been described and the applicant has identified, and there will be conducted, a program reasonably designed to resolve any safety questions*
  - NWMI has identified four ongoing research and development activities related to 1) irradiation and corrosion testing, 2) resin testing, 3) ion column pressure relief testing, and 4) evaluation of the release of diamylamylphosphonate from the ion exchange column during operation
- Staff finds NWMI has adequately described research and development programs
- Staff has determined additional information needed on certain matters related to nuclear criticality safety
  - Staff recommends inclusion of conditions in construction permit

## 10 CFR 50.35(a)(4)(i) Findings

- *There is reasonable assurance that such safety questions will be satisfactorily resolved at or before the latest date stated in the application for completion of construction of the proposed facility*
  - Latest date of construction completion proposed to be December 31, 2022
  - Based on research and development schedules, NWMI expected to resolve safety questions prior to completion of construction
  - Permit conditions must also be satisfied prior to completion of construction
- Staff finds that there is reasonable assurance that NWMI's research and development activities will be satisfactorily completed at or before the latest date for the completion of construction of the NWMI production facility

## 10 CFR 50.35(a)(4)(ii) Findings

- *There is reasonable assurance that, taking into consideration the site criteria contained in 10 CFR Part 100, the proposed facility can be constructed and operated at the proposed location without undue risk to the health and safety of the public*
  - While 10 CFR Part 100 site criteria are applicable to power reactors and testing facilities, staff considered similar site-specific conditions in SER Chapter 2
  - Staff confirmed, in SER Chapters 11 and 13, that radiological releases during normal and accident scenarios would be within 10 CFR Part 20 limits based on review of applicant's use of 10 CFR Part 70 Integrated Safety Analysis methodologies
  - Preliminary emergency plan meets requirements of Appendix E to 10 CFR Part 50
- Staff finds that there is reasonable assurance that the proposed facility can be constructed and operated at the proposed location without undue risk to the health and safety of the public

# 10 CFR 50.40 and 50.50 Considerations

- Based on the findings of 10 CFR 50.35 and the proposed license conditions, the staff concludes that there is sufficient information to issue a construction permit, as guided by the considerations in 10 CFR 50.40 and 50.50:
  - There is reasonable assurance: (i) that the construction of the NWMI production facility will not endanger the health and safety of the public, and (ii) that construction activities can be conducted in compliance with the Commission's regulations
  - NWMI is technically and financially qualified to engage in the construction of its proposed production facility
  - The issuance of a permit for the construction of the NWMI production facility would not be inimical to the common defense and security or to the health and safety of the public
  - The application meets the standards and requirements of the AEA and the Commission's regulations, and notifications, if any, to other agencies or bodies have been duly made