

UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

June 27, 2018

Dr. Michael L. Corradini, Chairman Advisory Committee on Reactor Safeguards U.S. Nuclear Regulatory Commission Washington, DC 20555-0001

SUBJECT: RESPONSE TO THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS'

LETTER REGARDING DRAFT SECY PAPER, "FUNCTIONAL CONTAINMENT PERFORMANCE CRITERIA FOR NON-LIGHT WATER REACTOR DESIGNS"

Dear Dr. Corradini:

I am responding to your letter dated May 10, 2018 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML18108A404), in which the Advisory Committee on Reactor Safeguards (ACRS) provided its findings and recommendations concerning the U.S. Nuclear Regulatory Commission draft SECY paper, "Functional Containment Performance Criteria for Non-Light Water Reactor Designs" (ADAMS Accession No. ML18031A721).

The staff appreciates the Committee's review of the draft SECY paper and associated references as well as the thoughtful discourse during the February 22, 2018, Future Plant Designs Subcommittee and April 5, 2018, ACRS Full Committee meetings. In its letter, the Committee noted several conclusions. Specifically, the concepts of containment, confinement, and functional containment, as well as the need for them, have been under discussion for decades. With one exception (Fort St. Vrain), no commercial reactor has been licensed without a [pressure-retaining or pressure-suppression] containment. Licensing a plant under functional containment performance criteria will be a major change in the implementation of regulations. Also, the non-light water reactor functional containment principles proposed in the staff paper provide a vision for setting licensing policy and developing functional containment performance criteria. Finally, a technology-inclusive, risk-informed, performance-based methodology should be adopted for establishing performance criteria for structures, systems, and components, and corresponding programs serving to limit the release of radioactive materials from non-light water reactor designs.

The Committee recommended that a functional containment should include multiple barriers as defense-in-depth features that should be minimally dependent upon each other and diverse in nature. The staff notes that diversity and defense-in-depth as it relates to functional containment performance will be addressed in future interactions and papers such as the current activities related to the Licensing Modernization Project.

Based on the Committee's recommendation, the staff will finalize the draft SECY paper and send it to the Commission for approval. The staff appreciates the ACRS' review and feedback. The staff looks forward to further interaction with the Committee on other upcoming advanced non-light water topics.

Sincerely,

/RA/

Victor M. McCree Executive Director for Operations

cc: Chairman Svinicki
Commissioner Baran
Commissioner Burns
Commissioner Caputo
Commissioner Wright
SECY

SUBJECT: RESPONSE TO THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS'

LETTER REGARDING DRAFT SECY PAPER, "FUNCTIONAL CONTAINMENT PERFORMANCE CRITERIA FOR NON-LIGHT WATER REACTOR DESIGNS"

DATED JUNE 27, 2018

DISTRIBUTION: LTR-18-0205-1

PUBLIC
JMazza, NRO
WReckley, NRO
ACubbage, NRO
JSegala, NRO
JMonninger, NRO
RidsAcrsAncw_MailCTR Resource
RidsNroMailCenter Resource
RidsOcaMailCenter
RidsOpaMailCenter
RidsSecyMailCenter

ADAMS Accession Number: ML18138A306 Pkg *via email EDO-002

OFFICE	NRO/DSRA	NRO/DSRA	NRO/DNRL*	TechEditor*
NAME	JMazza	WReckley	RButler	JDougherty
DATE	06/06/2018	06/06/2018	06/06/2018	06/08/2018
OFFICE	NRO/DSRA	NRO/DSRA	NRO	EDO
NAME	JSegala	JMonninger	FBrown	VMcCree
DATE	06/13/2018	06/14/2018	06/22/2018	06/27/2018

OFFICIAL RECORD COPY