

1717 Wakonade Drive
Welch, MN 55089

800.895.4999
xcelenergy.com



AUG 06 2018

L-PI-18-047
10 CFR 21.21(a)(2)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Prairie Island Nuclear Generating Plant, Unit 2
Docket No. 50-306
Renewed Facility Operating License No. DPR-60

Follow-up to Interim Report of a Deviation or Failure to Comply

Reference: 1. Letter from Scott Sharp (NSPM), to Document Control Desk (NRC), "Interim Report of a Deviation or Failure to Comply," L-PI-18-034, dated May 30, 2018 (ADAMS Accession No. ML18150A689)

Northern States Power Company, a Minnesota Corporation, (NSPM), doing business as Xcel Energy, hereby submits this follow-up report to the interim report (Reference 1) submitted pursuant to 10 CFR 21.21(a)(2) regarding a failed pressure switch manufactured by AMOT; model 4140CR1E32AA0, purchased from Paragon (formerly ATC) under their 10 CFR 50 Appendix B program.

NSPM returned the pressure switch to Paragon to evaluate. Paragon performed an as-found inspection to verify the part was manufactured to design requirements. Paragon has assurance that there was no manufacturing defect or deviation from design on this part. Paragon has provided Prairie Island 52 pressure switch units and only one has failed in this manner. As a result, this condition is not reportable under 10 CFR 21.

If there is any question or if additional information is needed, please contact Jeff Kivi at (651) 267-7309.

Summary of Commitments

This letter makes no new commitments and no revisions to existing commitments.

A handwritten signature in cursive script that reads "Scott Sharp".

Scott Sharp
Site Vice President, Prairie Island Nuclear Generating Plant
Northern States Power Company – Minnesota

cc: Regional Administrator, Region III, USNRC
Project Manager, Prairie Island Nuclear Generating Plant, USNRC
Resident Inspector, Prairie Island Nuclear Generating Plant, USNRC