



LAKE ENGINEERING CO.

P.O. Box 296
10 Austin Avenue
Greenville, RI 02828
Tel: 401-949-4733
Fax: 401-949-0220

March 1, 2019

U S Nuclear Regulatory Commission
Attn: Document Control Room
Washington, DC 20555-0001

Subject: Corrected Letter

Please disregard the previously sent letter dated March 1, 2019 with subject: "Potentially Degraded Snubber SF1154 Hydraulic Fluid Batch 11KLVS146 Final Report per 10 CFR Part 21" which was in error and replace it with the enclosed letter.

Very truly yours,

LAKE ENGINEERING COMPANY

D. P. Brown, P.E.
President

DPB/d/NOTE030119.nrc

cc: P. Guay - QA Mgr.



LAKE ENGINEERING CO.

P.O. Box 296
10 Austin Avenue
Greenville, RI 02828
Tel: 401-949-4733
Fax: 401-949-0220

March 1, 2019

U S Nuclear Regulatory Commission
Attn: Document Control Room
Washington, DC 20555-0001

Subject: Potentially Degraded Snubber SF1154 Hydraulic Fluid Batch 11KLVS146
Final Report per 10 CFR Part 21

We have completed our evaluation pertaining to fluid from the subject batch that was provided by Lake Engineering Company and have concluded that it does not represent a substantial safety hazard at any of the US nuclear plants to which it was provided or at which it was ultimately used. The plant specific status in this regard is summarized in the below table:

FACILITY	STATUS RE: BATCH 11KLVS146 FLUID	COMMENTS
Duane Arnold	Fluid used in some installed snubbers	No substantial safety hazards
Millstone	Fluid used in some installed snubbers	No substantial safety hazards
Three Mile Island	Fluid used in some installed snubbers	No substantial safety hazards
Clinton	Fluid not used	No substantial safety hazards
Indian Point 2 ¹	Fluid used in some installed snubbers	No substantial safety hazards
Peach Bottom	Fluid used in some installed snubbers	No substantial safety hazards

- 1) Fluid was originally provided to Wyle Laboratories (currently NTS) and was subsequently installed in snubbers at Indian Point 2.

Very truly yours,

LAKE ENGINEERING COMPANY

D. P. Brown, P.E.
President

DPB/d/let030119.nrc

cc: P. Guay - QA Mgr.