

APR 15 2019

Kevin Cimorelli
Site Vice President

Susquehanna Nuclear, LLC
769 Salem Boulevard
Berwick, PA 18603
Tel. 570.542.3795 Fax 570.542.1504
Kevin.Cimorelli@TalenEnergy.com



U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

10 CFR 50.4

**SUSQUEHANNA STEAM ELECTRIC STATION
ANNUAL RADIOLOGICAL ENVIRONMENTAL
OPERATING REPORT
PLA-7769**

**Docket No. 50-387
50-388**

In accordance with the Susquehanna Steam Electric Station (SSES) Units 1 and 2 Technical Specification 5.6.2, the SSES Annual Radiological Environmental Operating Report is hereby submitted for the 2018 calendar year.

There are no new or revised regulatory commitments contained in this submittal.

If you have any questions regarding this report, please contact Ms. Melisa Krick, Manager – Nuclear Regulatory Affairs, at (570) 542-1818.

A handwritten signature in black ink, appearing to read "Kevin Cimorelli", written in a cursive style.

Kevin Cimorelli

Attachment: 2018 Annual Radiological Environmental Operating Report

Copy: NRC Region I
Ms. T. E. Hood, NRC Project Manager
Ms. J. Tobin, NRC Project Manager
Ms. L. H. Micewski, NRC Sr. Resident Inspector
Mr. M. Shields, PA DEP/BRP
Mr. J. Furia, NRC Region 1 Health Physicist

Attachment to PLA-7769


**2018 Annual Radiological Environmental
Operating Report**

**SUSQUEHANNA STEAM ELECTRIC STATION
UNITS 1 and 2**

**Annual Radiological
Environmental Operating Report**

2018

Prepared by:



F.J. Hickey, Sr. Health Physicist

Reviewed by:



K.M. Ervin, Sr. Environmental Scientist

Approved by:



Jeffery N. Grisewood, Manager - Plant Chemistry/Environmental

Susquehanna Nuclear, LLC
769 Salem Boulevard
Berwick, Pennsylvania 18603

SUSQUEHANNA STEAM ELECTRIC STATION

Units 1 & 2

2018 ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT

JANUARY 1 TO DECEMBER 31, 2018

Susquehanna Nuclear, LLC
Berwick, PA
April, 2019

TABLE OF CONTENTS

| | |
|--|----|
| I. Summary..... | 1 |
| II. The Radiological Environmental Monitoring Program..... | 5 |
| A. Objectives of the Operational REMP..... | 6 |
| B. Implementation of the Objectives..... | 6 |
| III. Program Description..... | 8 |
| A. Data Interpretation..... | 8 |
| B. Program Exceptions..... | 9 |
| C. Program Changes..... | 9 |
| D. Quality Assurance Program..... | 20 |
| E. Summary of Results – Inter-Laboratory Comparison Program..... | 20 |
| IV. Results and Discussion..... | 23 |
| A. Atmospheric..... | 24 |
| 1. Air Particulates..... | 24 |
| 2. Air Iodine..... | 25 |
| B. Direct Radiation..... | 25 |
| C. Terrestrial..... | 26 |
| 1. Milk..... | 26 |
| 2. Groundwater..... | 27 |
| 3. Drinking Water..... | 29 |
| 4. Food Products..... | 30 |
| D. Aquatic..... | 31 |
| 1. Surface Water..... | 31 |
| 2. Fish..... | 33 |
| 3. Shoreline Sediment..... | 34 |
| E. Land Use Census..... | 35 |
| V. Annotations to Previous AREOR..... | 36 |
| VI. Conclusions..... | 36 |
| VII. References..... | 38 |

TABLE OF CONTENTS (cont'd)

| | |
|--|-----|
| Appendix A – Program Summary | A-1 |
| Appendix B – Sample Designation and Locations | B-1 |
| Appendix C – Data Tables | C-1 |
| Appendix D – Summary of Results from Analytics, Environmental Resource Associates (ERA) and Department of Energy (DOE) – Mixed Analyte Performance Evaluation Program (MAPEP)..... | D-1 |
| Appendix E – REMP Sample Equipment Operability Trending | E-1 |

LIST OF TABLES

| | |
|--|------|
| Exceptions Table..... | 11 |
| Appendix A Tables | |
| Table A Summary of Data for SSES..... | A-2 |
| Appendix B Tables | |
| Table B-1 Sampling Locations | B-3 |
| Table B-2 Susquehanna Steam Electric Station Radiological Environmental Monitoring Program | B-8 |
| Appendix C Tables | |
| Table C-1 Gross Beta Analyses of Air Particulate Filters Susquehanna Steam Electric Station | C-2 |
| Table C-2 Gamma Spectroscopic Analyses of Composited Air Particulate Filters Susquehanna Steam Electric Station..... | C-4 |
| Table C-3 Iodine-131 Analyses of Air Iodine Samples Susquehanna Steam Electric Station | C-5 |
| Table C-4 Environmental Optically Stimulated Luminescence Dosimetry Results Susquehanna Steam Electric Station..... | C-7 |
| Table C-5 Iodine-131 and Gamma Spectroscopic Analyses of Milk Susquehanna Steam Electric Station..... | C-10 |
| Table C-6 Tritium and Gamma Spectroscopic Analyses of Groundwater Susquehanna Steam Electric Station..... | C-12 |

LIST OF TABLES (cont'd)

| | | |
|-------------------|--|------|
| Table C-7 | Annual Average Tritium Concentration in Precipitation, Monitoring Wells and Lake Took-a-While (LTAW) Surface Water Data Susquehanna Steam Electric Station..... | C-15 |
| Table C-8 | Gross Beta, Tritium and Gamma Spectroscopic Analyses of Drinking Water Susquehanna Steam Electric Station | C-16 |
| Table C-9 | Gamma Spectroscopic Analyses of Food Products (Fruits, Vegetables, and Broadleaf) Susquehanna Steam Electric Station | C-17 |
| Table C-10 | Tritium and Gamma Spectroscopic Analyses of Surface Water Susquehanna Steam Electric Station..... | C-19 |
| Table C-11 | Gamma Spectroscopic Analyses of Fish Susquehanna Steam Electric Station | C-21 |
| Table C-12 | Gamma Spectroscopic Analyses of Shoreline Sediment Susquehanna Steam Electric Station..... | C-22 |
| Appendix D Tables | | |
| Table D-1 | Analytics Environmental Radioactivity Cross Check Program Teledyne Brown Engineering Environmental Services | D-2 |
| Table D-2 | DOE's Mixed Analyte Performance Evaluation Program (MAPEP) Teledyne Brown Engineering Environmental Services..... | D-6 |
| Table D-3 | ERA Environmental Radioactivity Cross Check Program Teledyne Brown Engineering Environmental Services | D-7 |

LIST OF TABLES (cont'd)

Appendix E Table

| | | |
|-----------|---|-----|
| Table E-1 | REMP Sample Equipment Operability Trending Susquehanna Steam Electric Station | E-2 |
|-----------|---|-----|

LIST OF MAPS

| | | |
|---------|--|------|
| Map B-1 | Direct Radiation Monitoring Locations Within One Mile..... | B-10 |
| Map B-2 | Direct Radiation Monitoring Locations From One to Five Miles..... | B-11 |
| Map B-3 | Direct Radiation Monitoring Locations Greater than Five Miles..... | B-12 |
| Map B-4 | Environmental Sampling Locations Within One Mile | B-13 |
| Map B-5 | Environmental Sampling Locations From One to Five Miles..... | B-14 |
| Map B-6 | Environmental Sampling Locations Greater than Five Miles | B-15 |

LIST OF FIGURES

| | | |
|------------|--|------|
| Figure C-1 | Gross Beta Activity in Air Particulates..... | C-23 |
| Figure C-2 | Ambient Radiation Levels Based on Environmental Dosimetry Data | C-24 |
| Figure C-3 | Iodine-131 Activity in Milk | C-25 |
| Figure C-4 | Annual Average Tritium Activity in Precipitation and Surface Water Versus Ground Water | C-26 |

LIST OF FIGURES (cont'd)

| | | |
|------------|--|------|
| Figure C-5 | Gross Beta Activity in Drinking Water..... | C-27 |
| Figure C-6 | Tritium Activity in Surface Water..... | C-28 |

I. Summary

During normal operations of a nuclear power generating station there are permitted releases of small amounts of radioactive material to the environment. To monitor and determine the effects of these releases a Radiological Environmental Monitoring Program (REMP) has been established around the Susquehanna Steam Electric Station (SSES). The results of the REMP are published annually, providing a summary and interpretation of the data collected.

Applied Ecoscience, Inc. was responsible for the collection of environmental samples during 2018. Teledyne Brown Engineering (TBE) was responsible for the analysis of environmental samples during 2018. The results are discussed in this report. Landauer provided the dosimetry services for SSES during 2018.

This Annual Radiological Environmental Operating Report (AREOR) conducted for SSES covers the period January 1, 2018 through December 31, 2018. During that time period, 1444 analyses were performed on 1234 samples.

Tritium (H-3) is the only man-made radionuclide detected in the environment by the Susquehanna Steam Electric Station (SSES) Radiological Environmental Monitoring Program (REMP) that is attributable to station operations. The whole body and organ dose to members of the public attributable to tritium identified in REMP cooling tower blowdown samples was $3.17\text{E-}04$ mRem. Tritium was included in the dose calculation because it was identified in the REMP samples of permitted water being discharged to the Susquehanna River. The 2018 average concentration of tritium in the cooling tower blowdown water and the 2018 average cooling tower blowdown flow were used to determine the amount of tritium released. The presumed exposure pathways to the public from this radionuclide were

drinking water taken from the Susquehanna River at Danville, PA and eating fish caught near the SSES discharge to the river. Dose from ground plane deposition (shoreline exposure) is not applicable because tritium does not emit gamma radiation and the beta radiation emitted by tritium is not sufficiently penetrating to reach an individual on the shore.

Based on the above outlined methodology, the total tritium activity released from the SSES to the Susquehanna River in 2018 was 35.3 curies.

The 2018 average dilution factor for the Susquehanna River was 1,036, based on the annual average river flow of $1.14\text{E}+07$ gpm and the annual average cooling tower blowdown flow of $1.10\text{E}+04$ gpm.

The REMP Sample Equipment Operability and year-to-year trend comparison is located in Appendix E, Table E-1.

The REMP was conducted in accordance with the SSES Technical Requirements Manual (TRM) and the respective station Offsite Dose Calculation Manual (ODCM) which are based on the design objectives in 10CFR Part 50, Appendix I, Sections IV.B.2, IV.B.3 and IV.C. The Lower Limit of Detection (LLD) values required by the TRM and SSES ODCM were achieved for the 2018 reporting period. The REMP objectives were also met during this period. The concentration of radioactive material in the environment that could be attributable to SSES operations was only a small fraction of the concentration of naturally occurring and man-made radioactivity. Since these results were comparable to the results obtained during the preoperational phase of the program and combined with historical results collected since commercial operation, it can be concluded that the levels and fluctuations were as expected and that the operation of the SSES had no significant radiological impact on the environment. Additionally, the REMP sample results for 2018 verify the adequacy of the SSES radioactive effluent control systems.

Samples of air particulates, air iodine, milk, groundwater, drinking water, vegetation, surface water, fish and sediment were collected and analyzed. External radiation dose measurements were also made in the vicinity of SSES using passive dosimeters.

Air particulate samples were analyzed for concentrations of gross beta weekly and gamma emitting nuclides quarterly. Gross beta and cosmogenically produced beryllium-7 (Be-7) were detected at levels consistent with those detected in previous years. No fission or activation products were detected.

High sensitivity iodine-131 (I-131) analyses were performed on weekly air samples. All results were less than the minimum detectable concentration.

Environmental gamma radiation measurements were performed quarterly using optically stimulated luminescent dosimeters (OSLD). The levels of radiation detected were consistent with those observed in previous years.

Cow milk samples were analyzed for concentrations of I-131 and gamma emitting nuclides. All I-131 results were below the minimum detectable concentration. Naturally occurring potassium-40 (K-40) was detected at levels consistent with those detected in previous years. No fission or activation products were detected.

Groundwater samples were analyzed for concentrations of tritium and gamma emitting nuclides. Tritium activities and naturally occurring thorium-228 (Th-228) were detected at levels consistent with those detected in previous years. No fission or activation products were detected.

Drinking water samples were analyzed for concentrations of tritium, gross beta and gamma emitting nuclides. Gross beta activities detected were consistent with those detected in previous years. No fission or activation

products were detected.

Food product (fruits, vegetables and broadleaf vegetation) samples were analyzed for concentrations of gamma emitting nuclides. Naturally occurring Be-7 and K-40 were detected at levels consistent with those detected in previous years. No fission or activation products were detected.

Soil sample collection was discontinued in 2018. Historical and preoperational data consistently indicates that Cs-137 previously detected in the soil is due to residual fallout from atmospheric nuclear weapons testing in the 1970s and early 1980s, and the Chernobyl and Fukushima events, and is not attributable to station operations.

Surface water samples were analyzed for concentrations of tritium and gamma emitting nuclides. Tritium activities detected were consistent with those detected in previous years. Naturally occurring K-40 and Th-228 was detected in several samples at levels that are consistent with results in previous years. No fission or activation products were detected.

Fish and shoreline sediment samples were analyzed for concentrations of gamma emitting nuclides. Naturally occurring K-40 was detected at levels consistent with those detected in previous years. Naturally occurring Ra-226, Ac-228 and Th-228 were detected in shoreline sediment at levels consistent with results in previous years. No fission or activation products were detected in fish or sediment samples.

II. The Radiological Environmental Monitoring Program

The Susquehanna Steam Electric Station (SSES) is a nuclear electrical generating facility with two boiling-water reactors and generators located just west of the Susquehanna River, approximately 5 miles northeast of Berwick, in Luzerne County, Pennsylvania. The station was constructed in the 1970's, with Unit 1 beginning commercial operation on June 8, 1983, and Unit 2 beginning commercial operation on February 12, 1985. Units 1 and 2 each generate a net 1,350 megawatts (MWe), for a total station output of 2,700 MWe.

In total Susquehanna Nuclear, LLC presently owns 2,347 acres of land on both sides of the Susquehanna River. Generally, this land is characterized by open deciduous woodlands interspersed with grasslands.

On the west side of the river, 1,605 (1,670 minus 65 acre Gould Island) acres of land is jointly owned between Susquehanna Nuclear, LLC (90%) and Allegheny Electric Cooperative (10%). The land use on the west side of the river includes generation and associated maintenance facilities, laydown areas, parking lots, roads, a nature preserve (the Susquehanna Riverlands), and agricultural leases to local farmers.

To the north of the station along the river, Susquehanna Nuclear, LLC owns 100% of the 65-acre Gould Island. On the east side of the river, and across the river from the station, Susquehanna Nuclear, LLC is the 100% owner of 677 acres that are maintained as undeveloped land, natural recreational areas, wildlife areas, and leases to local farmers.

More specific information on the demography, hydrology, meteorology, and land use characteristics of the area in the vicinity of the SSES can be found in the Environmental Report [Reference 1], the Final Safety Analysis Report

[Reference 2] and the Final Environmental Statement [Reference 3] for the SSES.

Radioanalytical data from samples collected under the REMP were compared with results from the preoperational phase and historical results during operations. Differences between these periods were examined statistically to determine the effects of station operations. This report presents the results from January 1 through December 31, 2018, for the SSES Radiological Environmental Monitoring Program (REMP).

A. Objectives of the Operational REMP

The objectives of the Operational REMP are to:

1. Document compliance with SSES REMP Technical Requirements and radiological environmental surveillances.
2. Verify proper implementation of SSES radiological effluent controls.
3. Identify, measure and evaluate trends of radionuclide concentrations in environmental pathways near SSES.
4. Assess impact of SSES Effluents on the Environment and the public.
5. Verify that SSES operations have no detrimental effects on the health and safety of the public or on the environment.

B. Implementation of the Objectives

1. In order to meet the objectives, an operational REMP was developed. Samples of various media were selected for monitoring due to the radiological dose impact to humans and other organisms. The selection of samples was based on:

- (a) Established critical pathways for the transfer of radionuclides through the environment to man, and
 - (b) Experience gained during the preoperational phase. Sampling locations were determined based on site meteorology, Susquehanna River hydrology, local demography, and land uses.
2. Sampling locations were divided into two classes, indicator and control. Indicator locations were sited where it is expected that radiation and radioactive material that might originate from the station would be detectable. Control locations were selected in areas where they would be unaffected by station operations (i.e. Susquehanna River upstream from the station, >10 miles from the station in least prevalent wind directions). Fluctuations in the levels of radionuclides and direct radiation at indicator locations were evaluated with respect to analogous fluctuations at control locations. Indicator and control location data were also evaluated relative to preoperational data.
 3. Appendix A, Program Summary, describes and summarizes the analytical results in accordance with the SSES Technical Specifications.
 4. Appendix B, Sample Designation and Locations, describes the coding system which identifies sample type and location. Table B-1 lists the location codes, locations, latitude, longitude, and the types of samples collected at each location. Table B-2 contains sample medium, analysis and sampling details.

5. The sampling locations are indicated on the following maps:

Map B-1, Direct Radiation Monitoring Locations Within One Mile

Map B-2, Direct Radiation Monitoring Locations From One to Five Miles

Map B-3, Direct Radiation Monitoring Locations Greater Than Five Miles

Map B-4, Environmental Sampling Locations Within One Mile

Map B-5, Environmental Sampling Locations From One to Five Miles

Map B-6, Environmental Sampling Locations Greater Than Five Miles

III. Program Description

A. Data Interpretation

Results of analyses are grouped according to sample type and presented in Appendix C, Data Tables. All results above the Lower Limit of Detection (LLD) are at a confidence level of ± 2 sigma. This represents the range of values into which 95% of repeated analyses of the same sample should fall. As defined in U.S. Nuclear Regulatory Commission Regulatory Guide 4.8, LLD is the smallest concentration of radioactive material in a sample that will yield a net count (above system background) that will be detected with 95% probability, with only 5% probability of falsely concluding that a blank observation represents a "real signal." LLD is normally calculated as 4.66 times the standard deviation of the background counting rate, or of the blank sample count, as appropriate, divided by counting efficiency, sample size, 2.22 (dpm per picocurie), the radiochemical yield when applicable, the radioactive decay constant and the elapsed time

between sample collection and time of counting. LLD represents the capability of the measurement system.

The Minimum Detectable Concentration (MDC) is defined as the smallest concentration of radioactive material that can be detected at a given confidence level. The MDC differs from the LLD in that the MDC takes into consideration the interference caused by the presence of other nuclides while the LLD does not. MDC is an indicator of the performance of the measurement system. The MDC is set to be below the LLD.

The grouped data were averaged and standard deviations calculated. Thus, the ± 2 sigma of the averaged data represent sample and not analytical variability. For reporting and calculation of averages, any result occurring at or below the LLD is considered to be at the LLD level.

B. Program Exceptions

Surface water auto-composite sampler at station 6S6 was removed from service for approximately 1 hour on the following dates for routine maintenance (sample line cleaning): May 21, 2018; June 18, 2018; September 17, 2018; December 17, 2018. The auto-composite sampler was successfully returned to service following the routine maintenance work on each of the dates referenced above.

See Exceptions Table 2018 REMP Atypical Sampling Occurrences

B. Program Changes

The program changes for 2018 are as follows. Changes were part of REMP program consolidation efforts by Talen Energy.

Soil collection from all stations was discontinued in 2018.

Precipitation collection from stations 3S2, 12S1, 8G1, and 10S3 was discontinued as of May 30th 2018.

Air particulate and Charcoal collection from station 6G1 was discontinued as of May 30th 2018.

Groundwater collection from stations 12F3, 2S2, 4S4, 6S10, and 11S2 was discontinued as of May 30th 2018.

Surface water collection from stations 4S7, LTAW, 5S12, and 7S12 was discontinued as of May 30th 2018.

Exceptions Table

2018 REMP Atypical Sampling Occurrences

| Date | Sample Type | Location Code(s) | Sample Period Reason for Occurrence(s) | Corrective Action |
|------|---------------|------------------|---|--|
| JAN | Air | 10S3 | <p>12/27/17 to 01/03/18 Flow rate upon arrival was 1.6 cfm, below the procedural range of 2.0-2.4 cfm. This was due to a loose fitting on the pump.</p> <p>Continuous sampling during sample period.</p> | <p>CA #18-01 CR 2018-00148 01/03/18: Loose fitting was tightened, and air flow restored to 2.2 cfm. 01/03/18: Operability verified @ 0925 hours.</p> <p><i>Ideal sample collected for sample period: 20,100 cf.</i></p> |
| | Air | 10S3 | <p>01/03/18 to 01/10/18 (loss of 0.2 hours) Power outage date and time unknown. Loss of 0.2 hours as determined by timer box during weekly collection.</p> <p>Non-continuous sampler operation.</p> | <p>CA #18-03 CR 2018-01082 01/10/18: No action required. Air monitor resumed normal operation when power was restored. 01/10/18: Operability verified @ 0919 hours.</p> <p><i>Ideal sample collected for sample period: 22,500 cf.</i></p> |
| | Surface Water | 2S7 | <p>01/09/18 to 01/15/18 (week 3 January composite) ACS automatically shut off on 01/14/18 @ approximately 0300 hours when the float weight was tripped. Greater than normal volume of water collected for week, possibly due to air bubbles in the sample line.</p> | <p>CA #18-04 CR 2018-01333 01/15/18: Sample line tubing was cleared of air. Sampler was calibrated to within procedural range. 01/15/18: Operability verified @ 1344 hours.</p> <p><i>Ideal sample collected for sample period.</i></p> |

Exceptions Table (continued)

| Date | Sample Type | Location Code(s) | Sample Period Reason for Occurrence(s) | Corrective Action |
|--------------------|---------------|------------------|--|--|
| JAN (cont.) | Surface Water | 2S7 | 01/23/18 to 01/30/18 (week 1 February composite) ACS sample line presumably blocked with sediment and will not draw liquid. Calibration/volume verification not possible due to lack of water in line. | CA #18-05 CR 2018-02015 01/30/18: Grab samples collected at 2S7 and 6S6 for comparative analysis. 02/01/18: FIN unsuccessful in clearing sample line. Sample line switched to Chemistry's side of sampling station. Delayed start for week 2 February composite. 02/01/18: Operability verified @ 1354 hours. <i>Ideal sample collected for sample period.</i> |
| FEB | Air | 10S3 | 01/31/18 to 02/06/18 (loss of 0.8 hours) Power outage date and time unknown. Loss of 0.8 hours as determined by timer box during weekly collection. Non-continuous sampler operation. | CA #18-06 CR 2018-02429 02/06/18: No action required. Air monitor resumed normal operation when power was restored. 02/06/18: Operability verified @ 0856 hours. <i>Ideal sample collected for sample period: 19,600 cf.</i> |
| | Surface Water | 6S6 | 02/13/18 to 02/20/18 (week 4 February composite) ACS out of service for approximately 1 hour for routine maintenance by I&C. | CA #18-07 CR 2018-02986 02/20/18: CR generated by I&C. No corrective action required since this was routine maintenance. PM date will be noted on sample collection form. 02/20/18: Operability verified @ 1132 hours <i>Ideal sample collected for sample period.</i> |

Exceptions Table (continued)

| Date | Sample Type | Location Code(s) | Sample Period Reason for Occurrence(s) | Corrective Action |
|--------------------|-------------|------------------|---|--|
| FEB (cont.) | Air | 3S2 | <p>02/14/18 to 02/21/18 Timer box #6 failed to advance past 1.0 for sample period. Timer box malfunction did not affect normal sample collection.</p> <p>Continuous sampling during sample period.</p> | <p>CA #18-08 CR 2018-03069 02/21/18: Timer box #6 was replaced with timer box #2. 02/21/18: Operability verified @ 0829 hours.</p> <p><i>Ideal sample collected for sample period: 21,200 cf.</i></p> |
| MAR | Air | 12S1 | <p>02/28/18 to 03/06/18 (loss of 13.3 hours) 12kV Power outage occurred @ 2200 hours on 03/01/18. Loss of 13.3 hours as determined by timer box.</p> <p>Non-continuous sampler operation.</p> | <p>CA #18-09 CR 2018-03535 03/02/18: No action required. Air monitor resumed normal operation when power was restored. 03/02/18: Operability verified @ 1158 hours.</p> <p><i>Ideal sample collected for sample period: 16,400 cf.</i></p> |
| | Air | 12S1 | <p>03/06/18 to 03/14/18 (loss of 9.0 hours) 12kV Power outage due to scheduled repair work (RLW02158245) occurred on 03/10/18. Loss of 9.0 hours as determined by timer box.</p> <p>Non-continuous sampler operation.</p> | <p>CA #18-10 CR 2018-03856 03/10/18: No action required. Air monitor resumed normal operation when power was restored. 03/12/18: Operability verified @ 0920 hours.</p> <p><i>Ideal sample collected for sample period: 22,700 cf.</i></p> |

Exceptions Table (continued)

| Date | Sample Type | Location Code(s) | Sample Period Reason for Occurrence(s) | Corrective Action |
|--------------------|-------------|------------------|--|---|
| MAR (cont.) | Air | 13S6 & 13S6Q | 03/06/18 to 03/14/18 (loss of 4.5 hours) Power outage date and time unknown. Loss of 4.5 hours as determined by timer boxes during weekly collection. Non-continuous sampler operation. | CA #18-11 CR 2018-04011 03/14/18: No action required. Air monitors resumed normal operation when power was restored. 03/14/18: Operability verified @ 0802 hours for 13S6 and 13S6Q. <i>Ideal samples collected for sample period: 24,800 cf.- 13S6 25,100 cf.- 13S6Q</i> |
| APR | Air | 9B1 | 03/28/18 to 04/04/18 Air flow verification failure due to defective coupler on air sampler. Defective coupler allowed a small amount of air to bypass the sample head. Air flow verification of <0.1 cf/30 seconds unachievable. Continuous sampling during sample period. | CA #18-12 CR 2018-05238 04/05/18: All four O-rings and one (quick connect) coupler were replaced. Equipment restored to service and air flow verification successfully performed. 04/05/18: Operability verified @ 1530 hours. <i>Ideal sample collected for sample period: 22,600 cf.</i> |
| MAY | Air | 12S1 | 04/25/18 to 05/02/18 Flow rate upon arrival was 1.8 cfm, below the procedural range of 2.0-2.4 cfm. Procedural range unachievable with pump settings at maximum due to pump malfunction. Continuous sampling during sample period. | CA #18-13 CR 2018-07291 05/02/18: Pump was replaced, and air flow verification was performed. 05/02/18: Operability verified @ 0931 hours. <i>Ideal sample collected for sample period: 17,000 cf.</i> |

Exceptions Table (continued)

| Date | Sample Type | Location Code(s) | Sample Period Reason for Occurrence(s) | Corrective Action |
|--------------------|-------------|------------------|--|--|
| MAY (cont.) | Air | 12S1 | <p>05/09/18 to 05/16/18 (momentary loss of 12kV power) Momentary loss of power on 05/15/18. No loss of sampling time as determined by timer box during weekly collection.</p> <p>Non-continuous sampler operation.</p> | <p>CA #18-14 CR 2018-07883 05/15/18: No action required. Air monitor resumed normal operation when power was restored. 05/16/18: Operability verified @ 0839 hours.</p> <p><i>Ideal sample collected for sample period: 21,900 cf.</i></p> |
| | Air | 10S3 | <p>05/09/18 to 05/16/18 (loss of 3.9 hours) Power outage date and time unknown. Loss of 3.9 hours as determined by timer box during weekly collection.</p> <p>Non-continuous sampler operation.</p> | <p>CA #18-15 CR 2018-07949 05/16/18: No action required. Air monitor resumed normal operation when power was restored. 05/16/18: Operability verified @ 0852 hours.</p> <p><i>Ideal sample collected for sample period: 21,300 cf.</i></p> |
| | Air | 3S2 | <p>05/23/18 to 05/30/18 Timer box failed to advance past 0.1 for sample period. Due to placement and pump vibration, the power toggle was bumped to the "off" position. Timer box malfunction did not affect normal sample collection.</p> <p>Continuous sampling during sample period.</p> | <p>CA #18-16 CR 2018-08622 05/30/18: Timer box was placed away from pump and was monitored. 05/30/18: Operability verified @ 0749 hours.</p> <p><i>Ideal sample collected for sample period: 21,700 cf.</i></p> |

Exceptions Table (continued)

| Date | Sample Type | Location Code(s) | Sample Period Reason for Occurrence(s) | Corrective Action |
|--------------------|---------------|------------------|--|--|
| MAY (cont.) | Surface Water | 2S7 | 05/30/18 (week 1 June composite) CTBD secured on 05/30/18 for clean out of MH-PD-07. No effect on continuous sampler operation. | CA #18-17 OP 142-001 05/30/18: No corrective action required. Sampler maintained normal operation while blowdown was secured. 05/30/18: Operability verified @ 0912 hours. <i>Ideal sample collected for sample periods.</i> |
| JUN | Surface Water | 6S6 | 06/05/18 to 06/12/18 (week 2 June composite) Diminished sample flow (<0.1 gpm) at ACS as discovered during weekly collection. | CA #18-18 CR 2018-09248 06/12/18: Adequate sample volume collected during sample period. Maintenance requested. 06/18/18: Maintenance performed by I&C and sample flow restored to 1.5 gpm. 06/19/18: Operability verified @ 0843 hours. <i>Ideal sample collected for sample periods.</i> |
| | Air | 12S1 | 06/13/18 to 06/20/18 (momentary loss of 12kV power) Momentary loss of power on 06/14/18. No loss of sampling time as determined by timer box. Non-continuous sampler operation. | CA #18-19 CR 2018-09406 06/14/18: No action required. Air monitor resumed normal operation when power was restored. 06/14/18: Operability verified @ 1512 hours. <i>Ideal sample collected for sample period: 21,700 cf.</i> |

Exceptions Table (continued)

| Date | Sample Type | Location Code(s) | Sample Period Reason for Occurrence(s) | Corrective Action |
|--------------------|-------------|------------------|--|---|
| JUN (cont.) | Air | 12S1 | 06/20/18 to 06/27/18 Timer box failed to advance for sample period due to reset button being stuck in depressed state. Continuous sampling during sample period. | CA #18-20 CR 2018-09862 06/27/18: Timer box reset button was fixed and monitored to ensure it was advancing. 06/27/18: Operability verified @ 0903 hours. <i>Ideal sample collected for sample period: 21,600 cf.</i> |
| | Air | 12S1 | 06/27/18 to 07/03/18 (loss of 2.3 hours) 12kV Power outage occurred @ 1023 hours on 06/27/18. Loss of 2.3 hours as determined by timer box. Non-continuous sampler operation. | CA #18-21 CR 2018-09859 06/27/18: No action required. Air monitor resumed normal operation when power was restored. 06/27/18: Operability verified @ 1334 hours. <i>Ideal sample collected for sample period: 17,900 cf.</i> |
| JUL | Air | 3S2 | 06/27/18 to 07/03/18 Timer box #2 failed to advance past 1.8 for sample period. Continuous sampling during sample period. | CA #18-22 CR 2018-10132 07/03/18: Timer box #2 replaced with timer box #6. 07/03/18: Operability verified @ 0900 hours. <i>Ideal sample collected for sample period: 18,500 cf.</i> |
| | Air | 12S1 | 07/11/18 to 07/18/18 (momentary loss of 12kV power) Momentary loss of power on 07/15/18 @ 0715 hours and 0809 hours. Non-continuous sampler operation. | CA #18-23 CR 2018-10553 07/15/18: No action required. Air monitor resumed normal operation when power was restored. 07/17/18: Operability verified @ 0900 hours. <i>Ideal sample collected for sample period: 23,300 cf.</i> |

Exceptions Table (continued)

| Date | Sample Type | Location Code(s) | Sample Period Reason for Occurrence(s) | Corrective Action |
|--------------------|-------------|------------------|--|--|
| JUL (cont.) | Air | 12S1 | <p>07/11/18 to 07/18/18 On 07/17/18 timer box #9 was found to be running in reverse while performing operability verification following a momentary loss of 12 kV power on 07/15/18.</p> <p>Non-continuous sampler operation during sample period due to momentary loss of 12 kV power on 07/15/18 (CA #18-23, CR 2018-10553).</p> | <p>CA #18-24 CR 2018-10688 07/17/18: Timer box #9 replaced with timer box #5. 07/17/18: Operability verified @ 0943 hours.</p> <p><i>Ideal sample collected for sample period: 23,300 cf.</i></p> |
| | Air | 12S1 | <p>07/18/18 to 07/25/18 (momentary loss of 12kV power) Momentary loss of power on 07/23/18 @ 1300 hours. No loss of sampling time as determined by timer box.</p> <p>Non-continuous sampler operation.</p> | <p>CA #18-25 CR 2018-10930 07/23/18: No action required. Air monitor resumed normal operation when power was restored. 07/24/18: Operability verified @ 0925 hours.</p> <p><i>Ideal sample collected for sample period: 23,800 cf.</i></p> |
| | Air | 10S3 | <p>07/18/18 to 07/25/18 Flow rate upon arrival was 1.0 cfm, below the procedural range of 2.0-2.4 cfm. This was due to a loose fitting on the pump.</p> <p>Continuous sampling during sample period.</p> | <p>CA #18-26 CR 2018-11048 07/25/18: Loose fitting was tightened, and air flow restored to 2.2 cfm. 07/25/18: Operability verified @ 0825 hours.</p> <p><i>Ideal sample collected for sample period: 16,400 cf.</i></p> |

Exceptions Table (continued)

| Date | Sample Type | Location Code(s) | Sample Period Reason for Occurrence(s) | Corrective Action |
|-------------|-------------|----------------------|--|---|
| JUL (cont.) | Air | 12S1 | <p>07/25/18 to 08/01/18 (loss of 0.2 hours) 12kV Power outage occurred on 07/25/18. Loss of 0.2 hours as determined by timer box.</p> <p>Non-continuous sampler operation.</p> | <p>CA #18-27 CR 2018-11066 07/25/18: No action required. Air monitor resumed normal operation when power was restored. 07/26/18: Operability verified @ 0820 hours.</p> <p><i>Ideal sample collected for sample period: 23,700 cf.</i></p> |
| AUG | Air | 3S2, 13S6, 9B1 | <p>07/25/18 to 08/01/18 Power outage dates and times unknown. Loss of 2.5 hours at 3S2 and 9B1, and loss of 2.7 hours at 13S6, as determined by timer boxes during weekly collection.</p> <p>Non-continuous sampler operation.</p> | <p>CA #18-28 CR 2018-11422 08/01/18: No action required. Air monitors resumed normal operation when power was restored. 08/01/18: Operability verified @ 0801 hours for 3S2, @ 0814 hours for 13S6, and @ 1118 hours for 9B1.</p> <p><i>Ideal samples collected for sample period: 22,500 cf.- 3S2 22,200 cf.- 13S6 22,600 cf.- 9B1</i></p> |
| NOV | Air | 8G1 | <p>10/31/18 to 11/07/18 (loss of 1.1 hours) Power outage date and time unknown. Loss of 1.1 hours as determined by timer box during weekly collection.</p> <p>Non-continuous sampler operation.</p> | <p>CA #18-29 CR 2018-15506 11/07/18: No action required. Air monitor resumed normal operation when power was restored. 11/07/18: Operability verified @ 1038 hours.</p> <p><i>Ideal sample collected for sample period: 22,800 cf.</i></p> |

D. Quality Assurance Program

Teledyne Brown Engineering

The quality of the results obtained by TBE is ensured by the implementation of the Quality Assurance Program as described in the Teledyne Brown Engineering Quality Assurance Manual and the Teledyne Brown Engineering Procedure Manual.

E. Summary of Results – Inter-Laboratory Comparison Program

The TBE Laboratory analyzed Performance Evaluation (PE) samples of air particulate, air iodine, milk, soil, vegetation, and water matrices for various analytes. The PE samples supplied by Analytics Inc., Environmental Resource Associates (ERA) and Department of Energy (DOE) Mixed Analyte Performance Evaluation Program (MAPEP), were evaluated against the following pre-set acceptance criteria:

1. Analytics Evaluation Criteria

Analytics' evaluation report provides a ratio of TBE's result and Analytics' known value. Since flag values are not assigned by Analytics, TBE evaluates the reported ratios based on internal QC requirements based on the DOE MAPEP criteria.

2. ERA Evaluation Criteria

ERA's evaluation report provides an acceptance range for control and warning limits with associated flag values. ERA's acceptance limits are established per the USEPA, National Environmental Laboratory Accreditation Conference (NELAC), state-specific Performance Testing (PT) program requirements or ERA's SOP for

the Generation of Performance Acceptance Limits, as applicable. The acceptance limits are either determined by a regression equation specific to each analyte or a fixed percentage limit promulgated under the appropriate regulatory document.

3. DOE Evaluation Criteria

MAPEP's evaluation report provides an acceptance range with associated flag values. MAPEP defines three levels of performance:

- Acceptable (flag = "A") - result within $\pm 20\%$ of the reference value
- Acceptable with Warning (flag = "W") - result falls in the $\pm 20\%$ to $\pm 30\%$ of the reference value
- Not Acceptable (flag = "N") – bias is greater than 30% of the reference value

Note: The Department of Energy (DOE) Mixed Analyte Performance Evaluation Program (MAPEP) samples are created to mimic conditions found at DOE sites which do not resemble typical environmental samples obtained at commercial nuclear power facilities.

Teledyne Brown Engineering

For the TBE laboratory, 164 out of 172 analyses performed met the specified acceptance criteria. Six analyses did not meet the specified acceptance criteria for the following reasons and were addressed through the TBE Corrective Action Program.

1. TBE was unable to report the February 2018 DOE MAPEP vegetation Sr-90 result due to QC failure and limited sample amount. (NCR 18-09)

2. The Analytics September 2018 milk Fe-59 result was evaluated as Not Acceptable (Ratio of TBE to known result at 133%). The reported value was 158 ± 17.6 pCi/L and the known value was 119 ± 19.9 pCi/L. No cause for the failure could be determined. TBE has passed 24 of the previous 27 milk cross-check results since 2012. This sample was run in duplicate on a different detector with comparable results (162 ± 16 pCi/L). NOTE: TBE's 4th Qtr. result passed at 105%. (NCR 18-20)

3. The Analytics September milk I-131 result was evaluated as Not Acceptable (Ratio of TBE to known result at 143%). Due to a personnel change in the gamma prep lab, the sample was not prepped/counted in a timely manner such as to accommodate the I-131 8-day half-life. Analysts have been made aware of the urgency for this analysis and it will be monitored more closely by QA. NOTE: TBE's 4th Qtr. result passed at 101% (NCR 18-24)

4. The Analytics September soil Cr-51 result was evaluated as Not Acceptable (Ratio of TBE to known result at 131%). As with #3 above, the sample was not prepped/counted in a timely manner such as to accommodate the Cr-51 27-day half-life. The same corrective action applies here as in #3. (NCR 18-21)

5. The MAPEP November vegetation Sr-90 result of 0.338 Bq/sample was evaluated as Not Acceptable (Lower acceptable range was 0.554 Bq/sample). It appears that there has been incomplete dissolution of Sr-90 due to the composition of the MAPEP vegetation "matrix". To resolve this issue, the TBE-2018 procedure has been modified to add

H₂O₂ to assist in breaking down the organic material that comprises this “matrix”. This corrective action will be monitored closely by QA. (NCR 18-25).

6. The ERA November 2018 water Sr-90 sample was evaluated as Not Acceptable. TBE’s initial reported result of 36.8 pCi/L exceeded the upper acceptance range (22.9 – 36.4 pCi/L). After reviewing the data for this sample, it was discovered that there was a typographical error at the time the results were entered at the ERA website. The correct result in LIMS of 36.2 should have been submitted instead. This result is within ERA’s acceptance limits. In addition to the typo error, ERA’s very stringent upper acceptance limit of 116% is not a reflection of TBE’s ability to successfully perform this analysis. (NCR 18-23)

The Inter-Laboratory Comparison Program provides evidence of “in control” counting systems and methods, and that the laboratories are producing accurate and reliable data.

IV. Results and Discussion

The analytical results of the 2018 REMP samples are divided into categories based on exposure pathways: atmospheric, direct radiation, terrestrial, and aquatic. The analytical results for the 2018 REMP are summarized in Appendix A, Program Summary. The data for individual samples are presented in Appendix C, Data Tables. The data are compared to the formal preoperational environmental monitoring program data (April 1972 to September 1982) and to data during operations. The data collected demonstrates that the SSES REMP was conducted in compliance with the TRM and the SSES ODCM.

A. Atmospheric

Atmospheric REMP sampling included the collection of air particulates, air iodine and direct radiation samples.

1. Air Particulates

Air particulate samples were collected weekly at six indicator locations (3S2, 9B1, 10S3, 12E1, 12S1 and 13S6) and two control locations (6G1 and 8G1). Station 6G1 was discontinued after May 3th 2018. Each of the samples collected for the year were analyzed for gross beta. Quarterly composites of the weekly samples from each location were analyzed for specific gamma emitters.

Gross Beta

Gross beta activity was detected in 312 of 312 of the indicator location samples at concentrations ranging from 5 to 23 E-3 pCi/m³ with an average concentration of 12 E-3 pCi/m³, and in 73 of 73 of the control location samples at concentrations ranging from 4 to 24 E-3 pCi/m³ with an average of 12 E-3 pCi/m³. The maximum preoperational level detected was 102 E-3 pCi/m³ with an average concentration of 62 E-3 pCi/m³. (Table C-1, Appendix C); Historical levels of gross beta are shown in Figure C-1. Results for gross beta analysis from 1974 to current year are plotted.

Gamma Spectrometry

Gamma spectrometry was performed on each of the 30 quarterly composite samples. Beryllium-7, attributed to cosmic ray activity in the atmosphere, was detected in all 24 indicator

location composites at concentrations ranging from 58 E-3 to 161 E-3 pCi/m³ with an average concentration of 97 E-3 pCi/m³, and in the six control location composites ranging in concentration from 90 to 108 E-3 pCi/m³ with an average concentration of 97 E-3 pCi/m³.

The maximum preoperational level detected was 85 E-3 pCi/m³ with an average concentration of 74 E-3 pCi/m³. (Table C-2, Appendix C)

All other gamma emitters were less than the LLD.

2. Air Iodine

Filtered air iodine samples were collected weekly at six indicator locations (3S2, 9B1, 10S3, 12E1, 12S1, and 13S6) and two control locations (6G1 and 8G1). Station 6G1 was discontinued after May 3th 2018. Each of the samples collected for the year were analyzed for I-131.

Iodine-131

Iodine-131 was not detected in any indicator location samples or control location samples. Preoperational data is not available for comparison. (Table C-3, Appendix C)

B. Direct Radiation

Ambient radiation levels in the environs were measured with a pair of optically stimulated luminescent dosimeters (OSLD) composed of aluminum oxide crystals supplied and processed by Landauer. Packets containing OSLDs for quarterly exposure were placed in the owner-controlled area and around the site at various distances and in

each land-based meteorological sector. Emphasis was placed on special interest areas such as population centers, nearby residences, and schools.

A total of 57 locations were monitored for direct radiation during 2018, including 32 site boundary locations, 14 outer distant locations, six special interest locations and five control locations.

The indicator locations annual average dose rate was 16.3 milliroentgen per standard quarter. The annual average dose rate for the control locations was 14.4 milliroentgen per standard quarter. The preoperational average for the quarterly direct radiation readings was 17.6 milliroentgen per standard quarter. The results of the direct radiation measurements for 2018 confirmed that the radiation levels in the vicinity of the SSES were similar to previous years. (Table C-4, Appendix C); Figure C-2 – Ambient Radiation Levels Based on Environmental Dosimetry Data from 1973 to current year are plotted as quarterly averages.

C. Terrestrial

Terrestrial REMP sampling included the collection of milk, groundwater, drinking water, and vegetation.

1. Milk

Milk samples were collected biweekly when cows were on pasture and monthly when cows were not grazing on pasture. Animals are considered on pasture from April to October of each year. Samples were collected in new polyethylene containers and transported in ice chests with preservatives added to the milk.

Milk samples were collected at local dairy farms from 2 indicator locations (5E2 and 13E3) and one control location (10G1). Each sample was analyzed for I-131 and gamma emitters.

Iodine-131

Iodine-131 was not detected above minimum detectable concentration in any of the 60 samples analyzed.

Preoperational data is not available for comparison. (Table C-5, Appendix C); Figure C-3 – Iodine-131 Activity in Milk results from 1976 to 2018 are plotted.

Gamma Spectrometry

Naturally occurring K-40 was detected in all 60 samples with concentrations for the 40 indicator location samples ranging from 1,055 to 1,623 pCi/L with an average concentration of 1,268 pCi/L, and the 20 control location sample concentrations ranging from 1,055 to 1,458 pCi/L with an average concentration of 1,277 pCi/L. The maximum preoperational level detected was 1,500 pCi/L with an average concentration of 1,358 pCi/L.

All other gamma emitters were less than the LLD.

2. Groundwater

An expanded groundwater monitoring network was initiated in 2006 for the SSES as part of a site-wide hydrogeological investigation in accordance with the Nuclear Energy Institute (NEI) Groundwater Protection Initiative (GPI). The additional groundwater monitoring wells are sampled as part of the

Radiological Environmental Monitoring Program (REMP) to regularly assess groundwater quality and provide early detection of any inadvertent leaks or spills of radioactive materials that could reach groundwater. Groundwater is sampled quarterly and analyzed for H-3 and gamma activity. Additionally, precipitation sampling was initiated in 2007 and analyzed for H-3 activity to assess the influence of station airborne H-3 emissions on groundwater H-3 activities.

Precipitation washout monitoring data is not used in dose calculations; however, the data does give a gross indication of H-3 which makes its way into surface water and soil where it eventually seeps into shallow groundwater. The annual average H-3 concentrations in precipitation, groundwater monitoring wells and surface water are summarized in Table C-7 and graphically depicted in Figure C-4 - Annual Average Tritium Activity (pCi/L) in Precipitation and Surface Water Versus Groundwater.

Groundwater samples were collected quarterly at 14 indicator locations (2S2, 4S4, 6S10, 11S2, 1S3, 4S8, 4S9, 8S4, 7S10, 13S7, 2S8, 6S11A, 6S12 and 7S11) and one control location, (12F3). Stations 12F3, 2S2, 4S4, 6S10, and 11S2 were discontinued after May 30th 2018. Each sample was analyzed for H-3 and gamma emitters.

Tritium

Tritium activity was detected above the minimum detectable concentration in 11 of the 48 indicator location samples with concentrations ranging from 147 to 354 pCi/L with an average concentration of 200 pCi/L. No H-3 was detected in the control

location sample. The maximum preoperational level detected was 119 pCi/L. (Table C-6, Appendix C); Figure C-4 – Annual Average Tritium Activity (pCi/L) in Precipitation and Surface Water Versus Groundwater results from 2007 to 2018 are plotted.

Gamma Spectrometry

Naturally occurring K-40 was not detected in any of the indicator or control samples. Preoperational data is not available for comparison. (Table C-6, Appendix C)

Naturally occurring Th-228 was detected in one of the 48 indicator samples at a concentration of 9 pCi/L. Preoperational data is not available for comparison. (Table C-6, Appendix C)

All other gamma emitters were less than the LLD.

3. Drinking Water

Drinking water samples were collected monthly from one location (12H2). Each sample was analyzed for gross beta, H-3 and gamma emitters.

Gross Beta

Gross beta activity was detected in four of the 12 drinking water samples. Sample concentrations ranged from 2 to 3 pCi/L with an average concentration of 3 pCi/L. The maximum preoperational level detected was 2.8 pCi/L with an average concentration of 1.8 pCi/L. (Table C-8, Appendix C); Figure C-5 – Gross Beta Activity in Drinking Water results from 1977 to 2018 are plotted.

Tritium

Tritium activity was not detected in any of the samples. The maximum preoperational level detected was 194 pCi/L with an average of 132 pCi/L. (Table C–8, Appendix C)

Gamma Spectrometry

Naturally occurring K-40 was not detected in any of the samples. Preoperational data is not available for comparison. (Table C–8, Appendix C)

All other gamma emitters were less than the LLD.

4. Food Products

Food products from four indicator locations (3S3, 12F7, 11D1, and 11S6) and one control location (8G1) were collected throughout the growing season. All samples (fruit, vegetable, and broadleaf) were analyzed for gamma emitters and included soy beans, field corn, pumpkin, kale, swiss chard and collards.

Gamma Spectrometry

Naturally occurring Be-7, attributed to cosmic ray activity in the atmosphere, was detected in 23 of the 34 indicator location samples with concentrations ranging from 313 to 1,038 pCi/kg wet with an average concentration of 581 pCi/kg wet, and in 11 of the control location samples with concentrations ranging from 246 to 850 pCi/kg wet with an average concentration of 540 pCi/kg wet. Preoperational data is not available for comparison.

Naturally occurring K-40 was detected in all 34 indicator location samples with concentrations ranging from 1,688 to 16,720 pCi/kg wet with an average concentration of 4,355 pCi/kg wet, and in all 15 control location samples with concentrations ranging from 2,599 to 4,927 pCi/kg wet with an average concentration of 3,815 pCi/kg wet. The maximum preoperational level detected was 4,800 pCi/kg wet with an average concentration of 2,140 pCi/kg wet.

Naturally occurring Ac-228 was not detected in any of the indicator or control locations. Preoperational data is not available for comparison.

Naturally occurring Th-228 was not detected in any of the indicator or control locations. Preoperational data is not available for comparison. (Table C-9, Appendix C)

All other gamma emitters were less than the LLD.

D. Aquatic

Aquatic samples include surface water, fish and sediment samples.

1. Surface Water

Surface water samples were collected routinely at six indicator locations (6S5, 2S7, LTAW, 4S7, 5S12, 5S9 and 7S12) and one control location (6S6). Stations 4S7, LTAW, 5S12, and 7S12 were discontinued after May 30th 2018. Samples were not collected at station 5S9 in 2018. Each sample was analyzed for H-3 and gamma emitters.

Tritium

Tritium activity was detected in 16 of 33 indicator location samples with concentrations ranging from 169 to 6,170 pCi/L with an average concentration of 1,217 pCi/L. The range of H-3 levels in surface water are biased high due to inclusion of samples from the cooling tower blowdown line (CTBD; location 2S7). Routine station operation includes infrequent batch releases of slightly radioactive water which are discharged into the CTBD. When the H-3 concentration from CTBD samples is averaged with those obtained from Susquehanna River downstream monitoring locations, the result is an overall indicator location average that is higher than the actual average H-3 levels of the downstream river water. No radioactivity attributable to station operations was identified above analysis detection levels in any samples from the Susquehanna River in 2018. Tritium was not detected in any of the control location samples. The maximum preoperational level detected was 319 pCi/L, with an average concentration of 140 pCi/L. (Table C-10, Appendix C) Figure C-6 – Tritium Activity in Surface Water, results from 1972 to 2018 are plotted.

Gamma Spectrometry

Naturally occurring K-40 was detected in two of the indicator location samples with concentrations ranging from 45 pCi/L to 101 pCi/L with an average concentration of 73 pCi/L and one control location sample with a concentration of 47 pCi/L. Preoperational data is not available for comparison.

Naturally occurring Th-228 was detected in two indicator location samples with concentrations ranging from 5.6 pCi/L to

5.8 pCi/L with an average concentration of 5.7 pCi/L, and was detected in one of the control location samples with a concentration of 12 pCi/L. Preoperational data is not available for comparison. (Table C-10, Appendix C)

Iodine-131

Iodine-131 was not detected in any of the indicator or control samples. The maximum preoperational level detected was 0.43 pCi/L, with an average concentration of 0.33 pCi/L. (Table C-10, Appendix C)

All other gamma emitters were less than the LLD.

2. Fish

Edible species of fish were collected in the spring and fall of 2018 at two indicator locations (IND [Susquehanna River] and LTAW (only collected in the fall)) and one control location (2H [Susquehanna River]). Each sample was analyzed for gamma emitters.

Gamma Spectrometry

Naturally occurring K-40 was detected in all indicator location samples at concentrations ranging from 2,666 to 5,034 pCi/kg wet with an average concentration of 3,597 pCi/kg wet, and in all control location samples at concentrations ranging from 2,913 to 4,598 pCi/kg wet with an average concentration of 3,517 pCi/kg wet. The maximum preoperational level detected was 3,600 pCi/kg dry with an average concentration of 3,871 pCi/kg dry. (Table C-11, Appendix C)

All other gamma emitters were less than the LLD

3. Shoreline Sediment

Sediment samples were collected from the Susquehanna River in the spring and fall at two indicator locations (7B and 12F) and one control location (2B). Each sample was analyzed for gamma emitters.

Gamma Spectroscopy

Naturally occurring K-40 was detected in all four of the indicator location samples at concentrations ranging from 7,160 to 10,320 pCi/kg dry with an average concentration of 8,323 pCi/kg dry, and in all of the control location samples with concentrations ranging from 10,830 to 14,350 pCi/kg dry with an average concentration of 12,590 pCi/kg dry. The maximum preoperational level detected was 11,000 pCi/kg dry with an average concentration of 8,500 pCi/kg dry.

Cesium-137 was not detected in any of the indicator or control location samples. The maximum preoperational level detected was 210 pCi/kg dry with an average concentration of 110 pCi/kg dry.

Naturally occurring Ra-226 was detected in three of the indicator location samples with concentrations ranging from 1,524 pCi/kg to 2,800 pCi/kg a concentration of 2,003 pCi/kg dry, and one control location sample with a concentration of 1,547 pCi/kg. The maximum preoperational level detected was 1,900 pCi/kg dry with an average concentration of 700 pCi/kg dry.

Naturally occurring Ac-228 was detected in all four indicator location samples at concentrations ranging from 605 to 1,024

pCi/kg dry with an average concentration of 835 pCi/kg dry, and in both of the control location samples at concentrations ranging from 912 to 1,184 pCi/kg dry with an average concentration of 1,048 pCi/kg dry. Preoperational data is not available for comparison. (Table C-12, Appendix C)

Naturally occurring Th-228 was detected in all of the four indicator location samples at concentrations ranging from 776 to 965 pCi/kg dry with an average concentration of 863 pCi/kg dry, and in both of the control location samples at concentrations ranging from 956 and 1,429 pCi/kg dry with an average concentration of 1,193 pCi/kg dry. The maximum preoperational level detected was 3,200 pCi/kg dry with an average concentration of 1,300 pCi/kg dry.

All other gamma emitters were less than the LLD.

E. Land Use Census

SYNOPSIS OF 2018 LAND USE CENSUS

Applied Ecoscience, Inc. conducted a Land Use Census during the 2018 growing season around SSES to comply with the ODCM. The purpose of the survey was to document the nearest milk animal, residence and garden greater than 50 m² (approximately 500 ft²) producing broad leaf vegetation within a distance of 8 km (approximately 5 miles) in each of the 16 meteorological sectors surrounding the SSES.

| Distance in Miles from the SUSQUEHANNA NUCLEAR Reactor Buildings | | | | |
|--|-----|--|---------------------------------------|---|
| Meteorological Sector | | Nearest Residence Sept, 2018 miles | Nearest Garden Sept, 2018 miles | Nearest Dairy Farm Sept, 2018 miles |
| 1 | N | 1.3 | 3.2 | >5.0 |
| 2 | NNE | 1.0 | 2.3 ^{a,b,c,e} | >5.0 |
| 3 | NE | 0.9 | 2.7 | >5.0 |
| 4 | ENE | 2.1 | 2.4 ^{a,c,f} | >5.0 |
| 5 | E | 1.4 | 4.9 | 4.5 ^d |
| 6 | ESE | 0.5 | 3.1 | >5.0 |
| 7 | SE | 0.6 | 0.6 | >5.0 |
| 8 | SSE | 0.6 | 2.9 | >5.0 |
| 9 | S | 1.0 | 3.5 | >5.0 |
| 10 | SSW | 0.9 | 1.3 ^{a,c} | >5.0 ^d |
| 11 | SW | 1.5 | 1.9 | >5.0 |
| 12 | WSW | 1.3 | 1.3 | 1.7 ^d |
| 13 | W | 1.2 | 3.2 | 5.0 |
| 14 | WNW | 1.1 | 1.3 | >5.0 |
| 15 | NW | 0.8 | 2.3 ^{a,c} | >5.0 |
| 16 | NNW | 0.6 | 4.0 | >5.0 |

- a Chickens raised for consumption at this location
- b Ducks raised for consumption at this location
- c Eggs consumed from chickens at this location
- d Fruits/vegetables raised for consumption at this location
- e Beef cattle raised for consumption at this location
- f Rabbits raised for consumption at this location.

The 2018 Land Use Census results are summarized in the above table.

V. Annotations to Previous AREOR

There are no annotations to the previous AREOR.

VI. Conclusions

The Radiological Environmental Monitoring Program for SSES was conducted during 2018 in accordance with the SSES TRM and ODCM. The LLD values required by the TRM and ODCM were achieved for this reporting period (See Appendix A and Appendix C). The objectives of the program

were also met during this period. The data collected assists in demonstrating that SSES was operated in compliance with TRM and ODCM requirements.

The concentration of radioactive material in the environment that could be attributable to SSES operations was only a small fraction of the concentration of naturally occurring and man-made radioactivity. Since these results were comparable to the results obtained during the preoperational phase of the program, which ran from 1972 to 1982, and with results collected since commercial operation, it is concluded that operation of the SSES had no significant radiological impact on the health and safety of the public or the environment.

From the results obtained, it can be concluded that the levels and fluctuations of radioactivity in environmental samples were as expected for the environment surrounding the SSES.

VII. References

- [1] Annual Radiological Environmental Operating Report, January 1 to December 31, 2016, prepared by Teledyne Brown Engineering, Knoxville TN.
- [2] Final Safety Analysis Report
- [3] Final Environmental Statement
- [4] Susquehanna Steam Electric Station, 2018 Land Use Census. Prepared for Susquehanna Nuclear, LLC, Berwick, PA. December 2018. Applied Ecoscience, Inc. Berwick, PA.
- [5] Google Earth. 2016. Website: <http://earth.google.com>.
- [6] Pennsylvania Department of Transportation. 1990. Columbia County General Highway Map. PA DOT, Harrisburg, PA.
- [7] Pennsylvania Department of Transportation. 1990. Luzerne County General Highway Map. PA DOT, Harrisburg, PA.
- [8] Susquehanna Nuclear, LLC. 2015. Radiological Environmental Monitoring Program, ODCM-QA-008, Rev. 18.
- [9] Susquehanna Steam Electric Station, 5-mile radius aerial photograph, REMPE-182244-0. Susquehanna Nuclear, Berwick, PA
- [10] United States Geological Survey. 1976. Berwick Quadrangle Topographic Map. 7.5 minute series. USGS, Reston, VA.
- [11] United States Geological Survey. 1977. Sybertsville Quadrangle Topographic Map. 7.5 minute series. USGS, Reston, VA.

- [12] United States Nuclear Regulatory Commission. "An Acceptable Radiological Environmental Monitoring Program." Radiological Assessment Branch Technical Position. November 1979, Revision 1. USNRC, Washington, DC.
- [13] Susquehanna Nuclear, "Engineering Study, EC-ENVR-1012 (Revision 2, February 2013)", Interpretation of Environmental Direct Radiation Results.
- [14] Susquehanna Nuclear, Tritium Release REMP Calculation (RETDAS) V.3.6.6) – March 2017.
- [15] NCRP Report No. 160, "Ionizing Radiation Exposure of the Population of the United States", (2009).

APPENDIX A

PROGRAM SUMMARY

TABLE A
SUMMARY OF DATA FOR SSES
OPERATIONAL RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM
NAME OF FACILITY: SUSQUEHANNA STEAM ELECTRIC STATION
LOCATION OF FACILITY: LUZERNE COUNTY, PENNSYLVANIA

Reporting Period: December 28, 2017 to January 01, 2019

| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT) | ANALYSIS AND TOTAL NUMBER OF ANALYSIS PERFORMED (1) | LOWER LIMIT OF DETECTION (LLD) (2) | ALL INDICATOR LOCATIONS MEAN (3) RANGE | LOCATION WITH HIGHEST MEAN NAME DISTANCE AND DIRECTION | MEAN (3) RANGE | CONTROL LOCATION MEAN (3) RANGE | NUMBER OF NONROUTINE REPORTED MEASUREMENTS (4) | |
|---|--|---|--|--|-----------------------|--|---|---|
| Air Particulates (E-3 pCi/m ³) | GR-B | 385 | 10 | 1.202E+01 (312/312) (4.600E+00 - 2.300E+01) | 12E1 4.7 MILES WSW | 1.256E+01 (52/52) (4.680E+00 - 2.250E+01) | 1.167E+01 (73/73) (4.490E+00 - 2.400E+01) | 0 |
| | GAMMA BE-7 | 30 | N/A | 9.717E+01 (24/24) (5.845E+01 - 1.611E+02) | 9B1 1.3 MILES SSW | 1.055E+02 (4/4) (6.403E+01 - 1.315E+02) | 9.673E+01 (6/6) (8.995E+01 - 1.079E+02) | 0 |
| | K-40 | 30 | N/A | 1.287E+00 (24/24) (-1.192E+01 - 1.145E+01) | 9B1 1.3 MILES SSW | 8.983E+00 (4/4) (3.822E+00 - 1.145E+01) | -1.553E+00 (6/6) (-1.098E+01 - 6.878E+00) | 0 |
| | CS-134 | 30 | 50 | 2.923E-01 (24/24) (-1.188E+00 - 1.044E+00) | 3S2 0.5 MILES NE | 4.285E-01 (4/4) (-9.589E-02 - 1.044E+00) | -2.613E-01 (6/6) (-7.604E-01 - 5.060E-01) | 0 |
| | CS-137 | 30 | 60 | 1.249E-01 (24/24) (-6.628E-01 - 6.448E-01) | 12E1 4.7 MILES WSW | 2.268E-01 (4/4) (-5.574E-02 - 5.511E-01) | -2.010E-01 (6/6) (-5.804E-01 - 1.354E-01) | 0 |
| Charcoal (E-3 pCi/m ³) | GAMMA I-131 | 385 | 70 | -4.568E-02 (312/312) (-9.475E+00 - 7.800E+00) | 3S2 0.5 MILES NE | 2.686E-01 (52/52) (-9.292E+00 - 7.570E+00) | -7.010E-01 (73/73) (-9.482E+00 - 6.876E+00) | 0 |
| Ambient Radiation (mR/std. qtr.) | OSLD | 227 | N/A | 1.632E+01 (208/208) (7.717E+00 - 3.509E+01) | 9S2 0.2 MILES S | 3.267E+01 (4/4) (2.634E+01 - 3.509E+01) | 1.437E+01 (19/19) (1.049E+01 - 1.820E+01) | 0 |
| Milk (pCi/Liter) | I-131 | 60 | 1 | -1.055E-01 (40/40) (-9.780E-01 - 3.590E-01) | 10G1 14 MILES SSW | -7.297E-02 (20/20) (-4.510E-01 - 1.870E-01) | -7.297E-02 (20/20) (-4.510E-01 - 1.870E-01) | 0 |
| | GAMMA K-40 | 60 | N/A | 1.268E+03 (40/40) (1.055E+03 - 1.623E+03) | 10G1 14 MILES SSW | 1.277E+03 (20/20) (1.055E+03 - 1.458E+03) | 1.277E+03 (20/20) (1.055E+03 - 1.458E+03) | 0 |
| | CS-134 | 60 | 15 | -1.382E+00 (40/40) (-1.143E+01 - 4.901E+00) | 13E3 5.0 MILES W | -1.141E+00 (20/20) (-9.320E+00 - 3.501E+00) | -2.522E+00 (20/20) (-8.041E+00 - 3.629E+00) | 0 |

TABLE A
SUMMARY OF DATA FOR SSES
OPERATIONAL RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM
NAME OF FACILITY: SUSQUEHANNA STEAM ELECTRIC STATION
LOCATION OF FACILITY: LUZERNE COUNTY, PENNSYLVANIA

Reporting Period: December 28, 2017 to January 01, 2019

| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT) | ANALYSIS AND TOTAL NUMBER OF ANALYSIS PERFORMED (1) | LOWER LIMIT OF DETECTION (LLD) (2) | ALL INDICATOR LOCATIONS MEAN (3) RANGE | LOCATION WITH HIGHEST MEAN NAME DISTANCE AND DIRECTION | MEAN (3) RANGE | CONTROL LOCATION MEAN (3) RANGE | NUMBER OF NONROUTINE REPORTED MEASUREMENTS (4) | |
|---|--|---|--|--|-----------------------|---|---|---|
| Milk (cont'd) (pCi/Liter) | CS-137 | 60 | 18 | 6.255E-01 (40/40) (-4.459E+00 - 9.184E+00) | 5E2 4.5 MILES E | 9.618E-01 (20/20) (-3.355E+00 - 5.406E+00) | 5.447E-01 (20/20) (-3.411E+00 - 5.147E+00) | 0 |
| | BA-140 | 60 | 60 | -7.073E-01 (40/40) (-1.937E+01 - 1.622E+01) | 13E3 5.0 MILES W | 2.166E+00 (20/20) (-1.244E+01 - 1.622E+01) | -9.601E-01 (20/20) (-2.115E+01 - 1.810E+01) | 0 |
| | LA-140 | 60 | 15 | -2.935E-03 (40/40) (-7.808E+00 - 9.135E+00) | 5E2 4.5 MILES E | 8.134E-01 (20/20) (-3.851E+00 - 9.135E+00) | 1.551E-01 (20/20) (-4.260E+00 - 5.553E+00) | 0 |
| | TH-228 | 60 | N/A | 5.549E-01 (40/40) (-1.083E+01 - 7.394E+00) | 5E2 4.5 MILES E | 1.256E+00 (20/20) (-7.198E+00 - 7.053E+00) | 1.941E-01 (20/20) (-1.092E+01 - 1.658E+01) | 0 |
| Ground Water (pCi/Liter) | H-3 | 50 | 2000 | 9.431E+01 (48/48) (-3.630E+01 - 3.540E+02) | 1S3 0.1 MILES N | 2.178E+02 (4/4) (1.360E+02 - 3.540E+02) | 8.185E+01 (2/2) (7.740E+01 - 8.630E+01) | 0 |
| | GAMMA K-40 | 50 | N/A | 2.720E+00 (48/48) (-8.691E+01 - 6.754E+01) | 4S8 0.1 MILES ENE | 2.470E+01 (4/4) (-3.416E+01 - 6.754E+01) | -8.606E+00 (2/2) (-1.593E+01 - -1.281E+00) | 0 |
| | MN-54 | 50 | 15 | -6.542E-01 (48/48) (-8.122E+00 - 2.792E+00) | 7S10 0.3 MILES SE | 7.614E-01 (4/4) (-7.994E-01 - 2.497E+00) | 3.344E-01 (2/2) (-2.339E-01 - 9.027E-01) | 0 |
| | CO-58 | 50 | 15 | -5.217E-01 (48/48) (-5.521E+00 - 2.651E+00) | 6S10 0.4 MILES ESE | 1.012E+00 (2/2) (9.705E-01 - 1.054E+00) | -5.037E-01 (2/2) (-7.648E-01 - -2.425E-01) | 0 |
| | FE-59 | 50 | 30 | 3.626E-01 (48/48) (-1.176E+01 - 1.497E+01) | 4S9 0.3 MILES ENE | 4.621E+00 (4/4) (-1.817E+00 - 1.497E+01) | 9.365E-01 (2/2) (-2.840E-01 - 2.157E+00) | 0 |
| | CO-60 | 50 | 15 | 5.891E-01 (48/48) (-4.156E+00 - 5.657E+00) | 4S4 0.5 MILES ENE | 3.852E+00 (2/2) (2.047E+00 - 5.657E+00) | 6.749E-01 (2/2) (-7.112E-03 - 1.357E+00) | 0 |

TABLE A
SUMMARY OF DATA FOR SSES
OPERATIONAL RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM
NAME OF FACILITY: SUSQUEHANNA STEAM ELECTRIC STATION
LOCATION OF FACILITY: LUZERNE COUNTY, PENNSYLVANIA

Reporting Period: December 28, 2017 to January 01, 2019

| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT) | ANALYSIS AND TOTAL NUMBER OF ANALYSIS PERFORMED (1) | LOWER LIMIT OF DETECTION (LLD) (2) | ALL INDICATOR LOCATIONS MEAN (3) RANGE | LOCATION WITH HIGHEST MEAN NAME DISTANCE AND DIRECTION | MEAN (3) RANGE | CONTROL LOCATION MEAN (3) RANGE | NUMBER OF NONROUTINE REPORTED MEASUREMENTS (4) | |
|---|--|---|--|--|---|---|---|----------|
| Ground Water (cont'd) (pCi/Liter) | ZN-65 | 50 | 30 | -3.005E+00 (48/48) (-2.447E+01 - 7.517E+00) | 2S8 | 1.161E+00 (4/4) (-2.974E+00 - 7.517E+00) | -3.115E+00 (2/2) (-4.430E+00 - -1.800E+00) | 0 |
| | NB-95 | 50 | 15 | 1.252E+00 (48/48) (-7.108E+00 - 1.300E+01) | 2S8 | 5.645E+00 (4/4) (2.184E+00 - 1.189E+01) | 3.571E+00 (2/2) (1.643E-01 - 6.978E+00) | 0 |
| | ZR-95 | 50 | 30 | -1.294E-01 (48/48) (-6.888E+00 - 6.467E+00) | 4S4 0.5 MILES ENE | 4.429E+00 (2/2) (2.627E+00 - 6.230E+00) | 2.220E+00 (2/2) (1.022E+00 - 3.417E+00) | 0 |
| | I-131 | 50 | 15 | -2.183E-01 (48/48) (-5.428E+00 - 7.161E+00) | 13S7 0.2 MILES W | 2.256E+00 (4/4) (-1.064E+00 - 7.161E+00) | -5.720E-01 (2/2) (-1.930E+00 - 7.860E-01) | 0 |
| | CS-134 | 50 | 15 | -7.348E-01 (48/48) (-6.565E+00 - 6.949E+00) | 2S8 | 1.597E+00 (4/4) (-2.212E+00 - 6.949E+00) | 1.157E+00 (2/2) (5.294E-01 - 1.784E+00) | 0 |
| | CS-137 | 50 | 18 | -6.578E-01 (48/48) (-5.735E+00 - 3.740E+00) | 7S11 | 1.960E+00 (4/4) (1.182E+00 - 3.449E+00) | -3.257E+00 (2/2) (-6.390E+00 - -1.240E-01) | 0 |
| | BA-140 | 50 | 60 | -1.363E+00 (48/48) (-2.626E+01 - 1.723E+01) | 4S4 0.5 MILES ENE | 8.252E+00 (2/2) (1.893E+00 - 1.461E+01) | 4.441E+00 (2/2) (2.426E+00 - 6.456E+00) | 0 |
| | LA-140 | 50 | 15 | -2.142E-01 (48/48) (-6.066E+00 - 8.363E+00) | 4S4 0.5 MILES ENE | 2.816E+00 (2/2) (1.385E+00 - 4.247E+00) | -1.647E+00 (2/2) (-2.046E+00 - -1.247E+00) | 0 |
| | TH-228 | 50 | N/A | 4.919E-01 (48/48) (-2.105E+01 - 1.554E+01) | 11S2 0.4 MILES SW | 7.179E+00 (2/2) (7.164E+00 - 7.194E+00) | 3.380E+00 (2/2) (1.975E+00 - 4.784E+00) | 0 |
| | Drinking Water (pCi/Liter) | GR-B | 12 | 4 | 1.493E+00 (12/12) (-2.210E-01 - 3.320E+00) | 12H2 26 MILES WSW | 1.493E+00 (12/12) (-2.210E-01 - 3.320E+00) | .000E+00 |
| H-3 | | 12 | 2000 | 6.120E+01 (12/12) (-1.640E+01 - 1.410E+02) | 12H2 26 MILES WSW | 6.120E+01 (12/12) (-1.640E+01 - 1.410E+02) | .000E+00 | 0 |

TABLE A
SUMMARY OF DATA FOR SSES
OPERATIONAL RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM
NAME OF FACILITY: SUSQUEHANNA STEAM ELECTRIC STATION
LOCATION OF FACILITY: LUZERNE COUNTY, PENNSYLVANIA

Reporting Period: December 28, 2017 to January 01, 2019

| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT) | ANALYSIS AND TOTAL NUMBER OF ANALYSIS PERFORMED (1) | LOWER LIMIT OF DETECTION (LLD) (2) | ALL INDICATOR LOCATIONS MEAN (3) RANGE | LOCATION WITH HIGHEST MEAN NAME DISTANCE AND DIRECTION | MEAN (3) RANGE | CONTROL LOCATION MEAN (3) RANGE | NUMBER OF NONROUTINE REPORTED MEASUREMENTS (4) | |
|---|--|---|--|--|--|---|---|---|
| Drinking Water (cont'd) (pCi/Liter) | GAMMA | 12 | | | | | | |
| | K-40 | 12 | N/A | 5.744E+00 (12/12) (-1.705E+01 - 2.533E+01) | 12H2 26 MILES WSW | 5.744E+00 (12/12) (-1.705E+01 - 2.533E+01) | .000E+00 | 0 |
| | MN-54 | 12 | 15 | -1.352E-01 (12/12) (-9.694E-01 - 1.394E+00) | 12H2 26 MILES WSW | -1.352E-01 (12/12) (-9.694E-01 - 1.394E+00) | .000E+00 | 0 |
| | CO-58 | 12 | 15 | -3.226E-01 (12/12) (-1.386E+00 - 6.350E-01) | 12H2 26 MILES WSW | -3.226E-01 (12/12) (-1.386E+00 - 6.350E-01) | .000E+00 | 0 |
| | FE-59 | 12 | 30 | 1.386E+00 (12/12) (-1.437E+00 - 3.170E+00) | 12H2 26 MILES WSW | 1.386E+00 (12/12) (-1.437E+00 - 3.170E+00) | .000E+00 | 0 |
| | CO-60 | 12 | 15 | 8.358E-01 (12/12) (-1.953E-01 - 2.044E+00) | 12H2 26 MILES WSW | 8.358E-01 (12/12) (-1.953E-01 - 2.044E+00) | .000E+00 | 0 |
| | ZN-65 | 12 | 30 | -2.156E+00 (12/12) (-4.949E+00 - -5.172E-02) | 12H2 26 MILES WSW | -2.156E+00 (12/12) (-4.949E+00 - -5.172E-02) | .000E+00 | 0 |
| | NB-95 | 12 | 15 | 8.353E-01 (12/12) (1.403E-01 - 2.851E+00) | 12H2 26 MILES WSW | 8.353E-01 (12/12) (1.403E-01 - 2.851E+00) | .000E+00 | 0 |
| | ZR-95 | 12 | 30 | 3.198E-02 (12/12) (-1.829E+00 - 9.189E-01) | 12H2 26 MILES WSW | 3.198E-02 (12/12) (-1.829E+00 - 9.189E-01) | .000E+00 | 0 |
| | I-131 | 12 | 15 | -1.124E+00 (12/12) (-7.265E+00 - 5.808E+00) | 12H2 26 MILES WSW | -1.124E+00 (12/12) (-7.265E+00 - 5.808E+00) | .000E+00 | 0 |
| CS-134 | 12 | 15 | -5.774E-01 (12/12) (-4.875E+00 - 1.981E+00) | 12H2 26 MILES WSW | -5.774E-01 (12/12) (-4.875E+00 - 1.981E+00) | .000E+00 | 0 | |

TABLE A
SUMMARY OF DATA FOR SSES
OPERATIONAL RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM
NAME OF FACILITY: SUSQUEHANNA STEAM ELECTRIC STATION
LOCATION OF FACILITY: LUZERNE COUNTY, PENNSYLVANIA

Reporting Period: December 28, 2017 to January 01, 2019

| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT) | ANALYSIS AND TOTAL NUMBER OF ANALYSIS PERFORMED (1) | LOWER LIMIT OF DETECTION (LLD) (2) | ALL INDICATOR LOCATIONS MEAN (3) RANGE | LOCATION WITH HIGHEST MEAN NAME DISTANCE AND DIRECTION | MEAN (3) RANGE | CONTROL LOCATION MEAN (3) RANGE | NUMBER OF NONROUTINE REPORTED MEASUREMENTS (4) | |
|---|--|---|--|--|-----------------------|--|---|---|
| Drinking Water (cont'd) (pCi/Liter) | CS-137 | 12 | 18 | -2.346E-01 (12/12) (-1.041E+00 - 9.905E-01) | 12H2 26 MILES WSW | -2.346E-01 (12/12) (-1.041E+00 - 9.905E-01) | .000E+00 | 0 |
| | BA-140 | 12 | 60 | -4.225E-01 (12/12) (-8.566E+00 - 7.367E+00) | 12H2 26 MILES WSW | -4.225E-01 (12/12) (-8.566E+00 - 7.367E+00) | .000E+00 | 0 |
| | LA-140 | 12 | 15 | -1.624E-01 (12/12) (-4.702E+00 - 5.896E+00) | 12H2 26 MILES WSW | -1.624E-01 (12/12) (-4.702E+00 - 5.896E+00) | .000E+00 | 0 |
| Food/Garden Crops (pCi/kg wet) | GAMMA BE-7 | 49 | N/A | 4.429E+02 (34/34) (-6.537E+01 - 1.038E+03) | 11S6 0.5 MILES SW | 5.252E+02 (15/15) (6.367E+01 - 1.038E+03) | 4.375E+02 (15/15) (2.411E+01 - 8.497E+02) | 0 |
| | K-40 | 49 | N/A | 4.355E+03 (34/34) (1.688E+03 - 1.672E+04) | 11D1 3.3 MILES SW | 7.369E+03 (3/3) (1.688E+03 - 1.672E+04) | 3.815E+03 (15/15) (2.599E+03 - 4.927E+03) | 0 |
| | MN-54 | 49 | N/A | 2.293E+00 (34/34) (-8.966E+00 - 1.514E+01) | 12F7 8.3 MILES WSW | 3.774E+00 (1/1) (3.774E+00) | -1.877E+00 (15/15) (-1.674E+01 - 9.911E+00) | 0 |
| | CO-58 | 49 | N/A | -1.420E+00 (34/34) (-1.554E+01 - 8.786E+00) | 11S6 0.5 MILES SW | 6.612E-01 (15/15) (-6.675E+00 - 7.400E+00) | -1.386E+00 (15/15) (-1.840E+01 - 1.148E+01) | 0 |
| | FE-59 | 49 | N/A | -2.839E+00 (34/34) (-6.522E+01 - 4.750E+01) | 12F7 8.3 MILES WSW | 2.287E+01 (1/1) (2.287E+01) | 4.330E+00 (15/15) (-2.334E+01 - 4.061E+01) | 0 |
| | CO-60 | 49 | N/A | 1.964E+00 (34/34) (-1.059E+01 - 1.531E+01) | 11D1 3.3 MILES SW | 4.858E+00 (3/3) (-8.475E+00 - 1.166E+01) | 1.462E+00 (15/15) (-1.052E+01 - 1.865E+01) | 0 |
| | ZN-65 | 49 | N/A | -1.647E+01 (34/34) (-3.965E+01 - 1.609E+01) | 11S6 0.5 MILES SW | -1.233E+01 (15/15) (-3.880E+01 - 1.609E+01) | -1.435E+01 (15/15) (-4.234E+01 - 3.317E+01) | 0 |

TABLE A
SUMMARY OF DATA FOR SSES
OPERATIONAL RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM
NAME OF FACILITY: SUSQUEHANNA STEAM ELECTRIC STATION
LOCATION OF FACILITY: LUZERNE COUNTY, PENNSYLVANIA

Reporting Period: December 28, 2017 to January 01, 2019

| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT) | ANALYSIS AND TOTAL NUMBER OF ANALYSIS PERFORMED (1) | LOWER LIMIT OF DETECTION (LLD) (2) | ALL INDICATOR LOCATIONS MEAN (3) RANGE | LOCATION WITH HIGHEST MEAN NAME DISTANCE AND DIRECTION | MEAN (3) RANGE | CONTROL LOCATION MEAN (3) RANGE | NUMBER OF NONROUTINE REPORTED MEASUREMENTS (4) | |
|---|--|---|--|--|-----------------------|---|---|---|
| Food/Garden Crops (cont'd) (pCi/kg wet) | NB-95 | 49 | N/A | 2.322E+00 (34/34) (-1.312E+01 - 1.603E+01) | 11D1 3.3 MILES SW | 9.372E+00 (3/3) (2.665E+00 - 1.479E+01) | -1.004E+00 (15/15) (-1.489E+01 - 1.395E+01) | 0 |
| | ZR-95 | 49 | N/A | 1.227E+00 (34/34) (-1.885E+01 - 1.931E+01) | 12F7 8.3 MILES WSW | 1.439E+01 (1/1) (1.439E+01) | 1.571E+00 (15/15) (-2.573E+01 - 2.038E+01) | 0 |
| | I-131 | 49 | 60 | -5.852E-01 (34/34) (-2.303E+01 - 2.742E+01) | 11S6 0.5 MILES SW | 1.483E+00 (15/15) (-1.547E+01 - 2.742E+01) | -2.953E-01 (15/15) (-2.710E+01 - 2.024E+01) | 0 |
| | CS-134 | 49 | 60 | -5.875E+00 (34/34) (-3.573E+01 - 2.277E+01) | 12F7 8.3 MILES WSW | 4.634E+00 (1/1) (4.634E+00) | -2.020E+00 (15/15) (-1.448E+01 - 3.668E+01) | 0 |
| | CS-137 | 49 | 80 | 1.169E+00 (34/34) (-1.067E+01 - 1.465E+01) | 12F7 8.3 MILES WSW | 5.471E+00 (1/1) (5.471E+00) | 2.384E+00 (15/15) (-7.459E+00 - 1.917E+01) | 0 |
| | BA-140 | 49 | N/A | 4.286E+00 (34/34) (-4.523E+01 - 7.972E+01) | 12F7 8.3 MILES WSW | 7.479E+01 (1/1) (7.479E+01) | 7.165E+00 (15/15) (-6.188E+01 - 6.115E+01) | 0 |
| | LA-140 | 49 | N/A | -1.729E+00 (34/34) (-2.133E+01 - 1.483E+01) | 12F7 8.3 MILES WSW | 8.278E+00 (1/1) (8.278E+00) | -1.598E-01 (15/15) (-1.913E+01 - 2.445E+01) | 0 |
| | AC-228 | 49 | N/A | 1.998E+00 (34/34) (-4.865E+01 - 8.463E+01) | 11D1 3.3 MILES SW | 5.580E+01 (3/3) (3.785E+01 - 8.463E+01) | 3.494E+00 (15/15) (-5.636E+01 - 5.234E+01) | 0 |
| | TH-228 | 49 | N/A | 3.679E+00 (34/34) (-2.757E+01 - 6.547E+01) | 11D1 3.3 MILES SW | 8.529E+00 (3/3) (-6.513E+00 - 2.633E+01) | -5.979E+00 (15/15) (-2.524E+01 - 1.297E+01) | 0 |

TABLE A
SUMMARY OF DATA FOR SSES
OPERATIONAL RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM
NAME OF FACILITY: SUSQUEHANNA STEAM ELECTRIC STATION
LOCATION OF FACILITY: LUZERNE COUNTY, PENNSYLVANIA

Reporting Period: December 28, 2017 to January 01, 2019

| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT) | ANALYSIS AND TOTAL NUMBER OF ANALYSIS PERFORMED (1) | LOWER LIMIT OF DETECTION (LLD) (2) | ALL INDICATOR LOCATIONS MEAN (3) RANGE | LOCATION WITH HIGHEST MEAN NAME DISTANCE AND DIRECTION | MEAN (3) RANGE | CONTROL LOCATION MEAN (3) RANGE | NUMBER OF NONROUTINE REPORTED MEASUREMENTS (4) | |
|---|--|---|--|--|----------------------|---|---|---|
| Surface Water (pCi/Liter) | H-3 | 46 | 2000 | 6.617E+02 (33/33) (-1.900E+01 - 6.170E+03) | 2S7 0.1 MILES NNE | 1.501E+03 (13/13) (1.350E+02 - 6.170E+03) | 5.688E+01 (13/13) (-3.470E+01 - 1.230E+02) | 0 |
| | GAMMA K-40 | 46 | N/A | 2.840E+00 (33/33) (-1.138E+02 - 1.008E+02) | LTAW 0.7 MILES NE | 5.772E+01 (2/2) (1.463E+01 - 1.008E+02) | -1.063E+01 (13/13) (-1.611E+02 - 4.680E+01) | 0 |
| | MN-54 | 46 | 15 | 3.246E-02 (33/33) (-2.044E+00 - 2.661E+00) | 2S7 0.1 MILES NNE | 3.862E-01 (13/13) (-8.110E-01 - 1.448E+00) | -1.856E-01 (13/13) (-1.809E+00 - 1.040E+00) | 0 |
| | CO-58 | 46 | 15 | -2.622E-01 (33/33) (-4.348E+00 - 1.155E+00) | 7S12 0.3 MILES SE | 3.404E-01 (2/2) (1.534E-01 - 5.274E-01) | -2.530E-01 (13/13) (-1.538E+00 - 7.882E-01) | 0 |
| | FE-59 | 46 | 30 | 9.063E-01 (33/33) (-4.165E+00 - 1.210E+01) | 4S7 0.4 MILES ENE | 8.290E+00 (2/2) (4.480E+00 - 1.210E+01) | 2.386E-01 (13/13) (-2.734E+00 - 3.225E+00) | 0 |
| | CO-60 | 46 | 15 | 4.710E-01 (33/33) (-2.090E+00 - 1.501E+00) | LTAW 0.7 MILES NE | 1.097E+00 (2/2) (8.236E-01 - 1.370E+00) | 5.243E-01 (13/13) (-6.191E-01 - 1.461E+00) | 0 |
| | ZN-65 | 46 | 30 | -1.431E+00 (33/33) (-1.032E+01 - 5.775E+00) | 5S12 0.4 MILES E | 1.344E+00 (2/2) (-3.087E+00 - 5.775E+00) | -2.446E+00 (13/13) (-5.173E+00 - -4.381E-02) | 0 |
| | NB-95 | 46 | 15 | 3.281E-01 (33/33) (-1.864E+00 - 2.986E+00) | 7S12 0.3 MILES SE | 2.135E+00 (2/2) (1.633E+00 - 2.636E+00) | 5.375E-01 (13/13) (-5.906E-01 - 1.886E+00) | 0 |
| | ZR-95 | 46 | 30 | 9.105E-03 (33/33) (-4.492E+00 - 8.268E+00) | 7S12 0.3 MILES SE | 4.766E+00 (2/2) (1.264E+00 - 8.268E+00) | 1.316E-01 (13/13) (-1.011E+00 - 1.767E+00) | 0 |
| | I-131 | 46 | 15 | 4.466E-01 (33/33) (-5.021E+00 - 7.821E+00) | 5S12 0.4 MILES E | 1.961E+00 (2/2) (1.288E+00 - 2.634E+00) | 2.001E-01 (13/13) (-6.769E+00 - 1.004E+01) | 0 |

TABLE A
SUMMARY OF DATA FOR SSES
OPERATIONAL RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM
NAME OF FACILITY: SUSQUEHANNA STEAM ELECTRIC STATION
LOCATION OF FACILITY: LUZERNE COUNTY, PENNSYLVANIA

Reporting Period: December 28, 2017 to January 01, 2019

| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT) | ANALYSIS AND TOTAL NUMBER OF ANALYSIS PERFORMED (1) | LOWER LIMIT OF DETECTION (LLD) (2) | ALL INDICATOR LOCATIONS MEAN (3) RANGE | LOCATION WITH HIGHEST MEAN NAME DISTANCE AND DIRECTION | MEAN (3) RANGE | CONTROL LOCATION MEAN (3) RANGE | NUMBER OF NONROUTINE REPORTED MEASUREMENTS (4) | |
|---|--|---|--|--|--|---|---|---|
| Surface Water (cont'd) (pCi/Liter) | CS-134 | 46 | 15 | -5.181E-01 (33/33) (-4.965E+00 - 2.457E+00) | 5S12 0.4 MILES E | 7.386E-01 (2/2) (3.832E-01 - 1.094E+00) | -1.155E+00 (13/13) (-3.627E+00 - 5.297E-01) | 0 |
| | CS-137 | 46 | 18 | -1.861E-01 (33/33) (-1.949E+00 - 1.427E+00) | 5S12 0.4 MILES E | 9.282E-01 (2/2) (4.294E-01 - 1.427E+00) | -1.827E-01 (13/13) (-1.432E+00 - 6.841E-01) | 0 |
| | BA-140 | 46 | 60 | -1.680E-01 (33/33) (-1.405E+01 - 1.648E+01) | 7S12 0.3 MILES SE | 3.341E+00 (2/2) (-9.798E+00 - 1.648E+01) | 9.303E-01 (13/13) (-1.176E+01 - 1.565E+01) | 0 |
| | LA-140 | 46 | 15 | -1.058E-01 (33/33) (-4.917E+00 - 5.430E+00) | 5S12 0.4 MILES E | 2.133E+00 (2/2) (-1.164E+00 - 5.430E+00) | -1.476E+00 (13/13) (-5.809E+00 - 2.790E+00) | 0 |
| | TH-228 | 46 | N/A | 5.809E-02 (33/33) (-7.898E+00 - 6.555E+00) | 6S6 0.8 MILES ESE | 9.781E-01 (13/13) (-3.632E+00 - 1.199E+01) | 9.781E-01 (13/13) (-3.632E+00 - 1.199E+01) | 0 |
| Fish (pCi/kg wet) | GAMMA | 14 | | | | | | |
| | K-40 | 14 | N/A | 3.597E+03 (8/8) (2.666E+03 - 5.034E+03) | LTAW 0.7 MILES NE | 3.954E+03 (2/2) (3.911E+03 - 3.996E+03) | 3.517E+03 (6/6) (2.913E+03 - 4.598E+03) | 0 |
| | MN-54 | 14 | 130 | 9.567E+00 (8/8) (-1.285E+01 - 2.918E+01) | LTAW 0.7 MILES NE | 1.030E+01 (2/2) (8.435E+00 - 1.216E+01) | 8.021E+00 (6/6) (-1.171E+01 - 3.363E+01) | 0 |
| | CO-58 | 14 | 130 | -1.800E+01 (8/8) (-4.791E+01 - 6.103E+00) | IND 0.9-1.4 MILES ESE | -8.228E+00 (6/6) (-3.649E+01 - 6.103E+00) | -8.255E+00 (6/6) (-5.256E+01 - 4.438E+01) | 0 |
| FE-59 | 14 | 260 | -2.162E+01 (8/8) (-1.006E+02 - 5.599E+01) | 2H 30 MILES NNE | -8.013E+00 (6/6) (-9.866E+01 - 1.442E+02) | -8.013E+00 (6/6) (-9.866E+01 - 1.442E+02) | 0 | |
| CO-60 | 14 | 130 | -8.805E+00 (8/8) (-4.541E+01 - 2.389E+01) | 2H 30 MILES NNE | -9.345E-01 (6/6) (-2.854E+01 - 4.128E+01) | -9.345E-01 (6/6) (-2.854E+01 - 4.128E+01) | 0 | |

TABLE A
SUMMARY OF DATA FOR SSES
OPERATIONAL RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM
NAME OF FACILITY: SUSQUEHANNA STEAM ELECTRIC STATION
LOCATION OF FACILITY: LUZERNE COUNTY, PENNSYLVANIA

Reporting Period: December 28, 2017 to January 01, 2019

| MEDIUM OR PATHWAY SAMPLED (UNIT OF MEASUREMENT) | ANALYSIS AND TOTAL NUMBER OF ANALYSIS PERFORMED (1) | LOWER LIMIT OF DETECTION (LLD) (2) | ALL INDICATOR LOCATIONS MEAN (3) RANGE | LOCATION WITH HIGHEST MEAN NAME DISTANCE AND DIRECTION | MEAN (3) RANGE | CONTROL LOCATION MEAN (3) RANGE | NUMBER OF NONROUTINE REPORTED MEASUREMENTS (4) | |
|---|--|---|--|--|--------------------------|--|---|---|
| Fish (cont'd) (pCi/kg wet) | ZN-65 | 14 | 260 | -4.219E+01 (8/8) (-1.002E+02 - 4.228E+01) | LTAW 0.7 MILES NE | -2.473E+01 (2/2) (-8.039E+01 - 3.094E+01) | -4.415E+01 (6/6) (-6.566E+01 - -9.410E+00) | 0 |
| | CS-134 | 14 | 130 | -2.136E+01 (8/8) (-7.832E+01 - 1.582E+01) | LTAW 0.7 MILES NE | 5.345E-01 (2/2) (-6.943E+00 - 8.012E+00) | -3.161E+01 (6/6) (-6.360E+01 - -6.567E+00) | 0 |
| | CS-137 | 14 | 150 | 1.094E+00 (8/8) (-3.277E+01 - 3.311E+01) | IND 0.9-1.4 MILES ESE | 6.517E+00 (6/6) (-6.778E+00 - 3.311E+01) | 3.592E+00 (6/6) (-1.703E+01 - 2.624E+01) | 0 |
| Sediment (pCi/kg dry) | GAMMA | 6 | | | | | | |
| | K-40 | 6 | N/A | 8.323E+03 (4/4) (7.160E+03 - 1.032E+04) | 2B 1.6 MILES NNE | 1.259E+04 (2/2) (1.083E+04 - 1.435E+04) | 1.259E+04 (2/2) (1.083E+04 - 1.435E+04) | 0 |
| | CS-134 | 6 | 150 | 3.159E+00 (4/4) (-1.176E+01 - 2.021E+01) | 7B 1.2 MILES SE | 4.225E+00 (2/2) (-1.176E+01 - 2.021E+01) | -7.880E+00 (2/2) (-3.191E+01 - 1.615E+01) | 0 |
| | CS-137 | 6 | 180 | 2.873E+01 (4/4) (1.025E+01 - 5.042E+01) | 7B 1.2 MILES SE | 4.546E+01 (2/2) (4.050E+01 - 5.042E+01) | 1.644E+01 (2/2) (9.317E+00 - 2.357E+01) | 0 |
| | RA-226 | 6 | N/A | 1.587E+03 (4/4) (3.371E+02 - 2.800E+03) | 7B 1.2 MILES SE | 2.243E+03 (2/2) (1.686E+03 - 2.800E+03) | 1.614E+03 (2/2) (1.547E+03 - 1.681E+03) | 0 |
| | AC-228 | 6 | N/A | 8.346E+02 (4/4) (6.048E+02 - 1.024E+03) | 2B 1.6 MILES NNE | 1.048E+03 (2/2) (9.121E+02 - 1.184E+03) | 1.048E+03 (2/2) (9.121E+02 - 1.184E+03) | 0 |
| | TH-228 | 6 | N/A | 8.634E+02 (4/4) (7.761E+02 - 9.653E+02) | 2B 1.6 MILES NNE | 1.193E+03 (2/2) (9.564E+02 - 1.429E+03) | 1.193E+03 (2/2) (9.564E+02 - 1.429E+03) | 0 |

1. The total number of analyses does not include duplicates, splits or repeated analyses.
2. The Technical Requirement LLDs are shown when applicable.
3. The mean and range are based on all available measure results. The ratio indicated in parentheses is the total number of results used to calculate the mean to the total number of samples.
4. USNRC Reporting Levels are specified in the Technical Requirements (i.e., when Reporting Levels in Technical Requirements are exceeded).

Intentionally left blank

APPENDIX B

SAMPLE DESIGNATION AND LOCATIONS

SAMPLE DESIGNATION

All distances from the SSES to monitoring locations are measured from the standby gas treatment vent at 44200/N34117 (Pa. Grid System). The location codes are based on both distance and direction from the SSES. The letters in the location codes indicate if the monitoring locations are on site (within the site boundary) or, if they are not on site, the approximate distances of the location from the SSES as described below:

| | | | |
|---|---------------|---|-----------------|
| S | = On site | E | = 4 – 5 miles |
| A | = < 1 mile | F | = 5 – 10 miles |
| B | = 1 – 2 miles | G | = 10 – 20 miles |
| C | = 2 – 3 miles | H | = > 20 miles |
| D | = 3 – 4 miles | | |

The numbers preceding the letters in the location codes provide the direction of the monitoring locations from the SSES by indicating the sectors in which they are located. A total number of 16 sectors (numbered one through 16) equally divide an imaginary circle on a map of the SSES and its vicinity, with the SSES at the center of the circle. The middle of sector one is directed due North (N). Moving clockwise from sector one, the sector immediately adjacent to sector one is sector two, the middle of which is directed due north, north east (NNE). Continuing to move clockwise the sector number increases to 16, which is the north northwest sector (NNW).

TABLE B-1

SAMPLING LOCATIONS

Specific information about the individual sampling locations are given in Table B-1. Maps B-1 through B-6 show the locations of sampling stations with respect to the Site. A Portable Global Positioning System (GPS) was used to provide the coordinates of sampling locations.

| STATION CODE | STATION LOCATION | LATITUDINAL | LONGITUDINAL | SAMPLE TYPE |
|---|------------------|-------------|--------------|---------------|
| LESS THAN ONE MILE FROM THE SSES | | DEG. | DEG. | |
| 2S7 | 0.1 mi.NNE | 41.093540 | -76.144773 | Surface water |
| 5S9 | 0.8 mi.E; | 41.093292 | -76.130472 | Surface water |
| 5S12 | 0.4 mi.E; | 41.092540 | -76.138704 | Surface water |
| 7S12 | 0.3 mi.SE; | 41.088507 | -76.143270 | Surface water |
| 6S5 | 0.9 mi.ESE; | 41.084639 | -76.130642 | Surface water |
| 6S6 ** | 0.8 mi.ESE; | 41.088115 | -76.131637 | Surface water |
| LTAW | 0.7 mi.NE-ESE; | 41.098356 | -76.135401 | Surface water |
| 4S7 | 0.4 mi.ENE; | 41.094418 | -76.138236 | Surface water |
| LTAW | 0.7 mi.NE-ESE; | 41.098356 | -76.135401 | Fish |
| 10S3 | 0.6 mi. SSW; | 41.085264 | -76.152128 | Air |
| 12S1 | 0.4 mi.WSW; | 41.088436 | -76.154314 | Air |
| 13S6 | 0.4 mi.W; | 41.091771 | -76.153869 | Air |
| 3S2 | 0.5 mi NE; | 41.095716 | -76.140207 | Air |
| 2S8 | 0.1 mi.NNE; | 41.094991 | -76..044207 | Ground water |
| 2S2 | 0.9 mi.NNE; | 41.102243 | -76.136702 | Ground water |
| 4S4 | 0.5 mi.ENE; | 41.095471 | -76.138798 | Ground water |
| 6S10 | 0.4 mi.ESE; | 41.090511 | -76.137802 | Ground water |
| 6S11A | 0.4 mi.ESE; | 41.083448 | -76.133412 | Ground water |
| 6S11B | 0.4 mi.ESE; | 41.083448 | -76.133411 | Ground water |
| 6S12 | 0.8 mi.ESE; | 41.083411 | -76.116935 | Ground water |
| 7S11 | 0.3 mi.SE; | 41.083527 | -76.133513 | Ground water |
| 11S2 | 0.4 mi.SW; | 41.088816 | -76.152793 | Ground water |
| 1S3 | 0.1 mi N; | 41.093640 | -76.146076 | Ground water |

** Control Location

TABLE B-1 (cont'd)
SAMPLING LOCATIONS

| STATION CODE | STATION LOCATION | LATITUDINAL DEG. | LONGITUDINAL DEG. | SAMPLE TYPE |
|---|------------------|---------------------|----------------------|---------------|
| LESS THAN ONE MILE FROM THE SSES | | | | |
| 4S8 | 0.1 mi.ENE; | 41.092306 | -76.144283 | Ground water |
| 4S9 | 0.3 mi.E; | 41.093369 | -76.141644 | Ground water |
| 8S4 | 0.1 mi.SSE; | 41.091424 | -76.145531 | Ground water |
| 7S10 | 0.3 mi.SE; | 41.089736 | -76.142783 | Ground water |
| 13S7 | 0.2 mi.W; | 41.091236 | -76.149647 | Ground water |
| 11S6 | 0.5 mi.SW; | 41.085305 | -76.152022 | Broadleaf |
| 3S3 | 0.9 mi.NE; | 41.101856 | -76.133090 | Broadleaf |
| 5S10 | 0.7 mi.E; | 41.0.93899 | -76.132814 | Broadleaf |
| Site 1 | 0.1 mi.ESE; | 41.092275 | -76.145022 | Precipitation |
| Site 2 | 0.1 mi.SSE; | 41.091309 | -76.145708 | Precipitation |
| Site 3 | 0.1 mi.WSW; | 41.091243 | -76.147345 | Precipitation |
| Site 4 | 0.1 mi.NW; | 41.093321 | -76.147316 | Precipitation |
| FROM ONE to FIVE MILES FROM THE SSES | | | | |
| IND | 0.9 mi.ESE; | 41.085141 | -76.130174 | Fish |
| IND | 1.4 mi.ESE; | 41.075618 | -76.132682 | Fish |
| 2B ** | 1.6 mi.NNE; | 41.112441 | -76.134758 | Sediment |
| 7B | 1.2 mi.SE; | 41.078924 | -76.131548 | Sediment |
| 9B1 | 1.3 mi. SSW; | 41.085264 | -76.152128 | Air |
| 12E1 | 4.7 mi.WSW; | 41.072418 | -76.230554 | Air |
| 5E2 | 4.5 mi.E; | 41.085184 | -76.061099 | Milk |
| 8C1 | 2.9 mi.SSE; | 41.054518 | -76.129027 | Broadleaf |
| 10B5 | 1.3 mi.SSW; | 41.075404 | -76.157422 | Broadleaf |
| 13E3 | 5.0 mi.W; | 41.100259 | -76.241102 | Milk |
| 11D1 | 3.3 mi.SW; | 41.055212 | -76.186797 | Food Products |
| 11D2 | 3.5 mi.SW; | 41.054827 | -76.205081 | Food products |

** Control Location

TABLE B-1 (cont'd)
SAMPLING LOCATIONS

| STATION CODE | STATION LOCATION | LATITUDINAL DEG. | LONGITUDINAL DEG. | SAMPLE TYPE |
|--|------------------|------------------|-------------------|----------------|
| GREATER THAN FIVE MILES FROM THE SSES | | | | |
| 12H2 | 26 mi.WSW; | 40.947192 | -76.604524 | Drinking water |
| 2H ** | 30 mi.NNE; | 41.459508 | -75.853096 | Fish |
| 12F | 6.9 mi.WSW; | 41.041323 | -76.255396 | Sediment |
| 6G1 ** | 13.5 mi.ESE; | 41.018989 | -75.906515 | Air |
| 8G1 ** | 12 mi.SSE; | 40.928886 | -76.055092 | Air, Broadleaf |
| 10G1 ** | 14 mi.SSW; | 40.934847 | -76.284449 | Milk |
| 12F3 ** | 5.2 mi.WSW; | 41.054491 | -76.232176 | Ground water |
| 12F7 | 8.3 mi.WSW; | 41.036689 | -76.286776 | Food Products |
| 11F2 | 5.5 mi.SW; | 41.045741 | -76.242128 | Food products |
| 15G1 ** | 11.4 mi.NW; | 41.188578 | -76.324598 | Broadleaf |
| OSLD LOCATIONS | | | | |
| LESS THAN ONE MILE FROM THE SSES | | | | |
| 1S2 | 0.2 mi.N; | 41.09566 | -76.146121 | OSLD |
| 2S2 | 0.9 mi.NNE; | 41.10207 | -76.141192 | OSLD |
| 2S3 | 0.2 mi.NNE; | 41.09486 | -76.144101 | OSLD |
| 3S2 | 0.5 mi.NE; | 41.09574 | -76.140086 | OSLD |
| 3S3 | 0.9 mi.NE; | 41.10183 | -76.133127 | OSLD |
| 4S3 | 0.2 mi.ENE; | 41.09322 | -76.141934 | OSLD |
| 4S6 | 0.7 mi.ENE; | 41.09687 | -76.133807 | OSLD |
| 5S4 | 0.8 mi.E; | 41.09286 | -76.131604 | OSLD |
| 5S7 | 0.3 mi.E; | 41.09199 | -76.141165 | OSLD |
| 6S4 | 0.2 mi.ESE; | 41.09132 | -76.142616 | OSLD |
| 6S9 | 0.2 mi.ESE; | 41.09067 | -76.142966 | OSLD |
| 7S6 | 0.2 mi.SE; | 41.08972 | -76.14359 | OSLD |

** Control Location

TABLE B-1 (cont'd)
SAMPLING LOCATIONS

| STATION CODE | STATION LOCATION | LATITUDINAL DEG. | LONGITUDINAL DEG. | SAMPLE TYPE |
|---|------------------|---------------------|----------------------|-------------|
| LESS THAN ONE MILE FROM THE SSES | | | | |
| 7S7 | 0.4 mi.SE; | 41.08745 | -76.142033 | OSLD |
| 8S2 | 0.2 mi.SSE; | 41.08907 | -76.14437 | OSLD |
| 9S2 | 0.2 mi.S; | 41.08952 | -76.14322 | OSLD |
| 10S1 | 0.4 mi.SSW; | 41.08663 | -76.150082 | OSLD |
| 10S2 | 0.2 mi.SSW; | 41.08894 | -76.147881 | OSLD |
| 11S7 | 0.4 mi.SWN; | 41.08832 | -76.15297 | OSLD |
| 12S1 | 0.4 mi.WSW; | 41.0887 | -76.154112 | OSLD |
| 12S3 | 0.4 mi.WSW; | 41.08968 | -76.153192 | OSLD |
| 13S2 | 0.4 mi.W; | 41.09198 | -76.153166 | OSLD |
| 13S5 | 0.4 mi.W; | 41.09179 | -76.153167 | OSLD |
| 13S6 | 0.4 mi.W; | 41.09177 | -76.154073 | OSLD |
| 14S5 | 0.5 mi.WNW; | 41.09503 | -76.153787 | OSLD |
| 15S5 | 0.4 mi.NW; | 41.09576 | -76.15103 | OSLD |
| 16S1 | 0.3 mi.NNW; | 41.09611 | -76.147388 | OSLD |
| 16S2 | 0.3 mi.NNW; | 41.09599 | -76.148922 | OSLD |
| 6A4 * | 0.6 mi.ESE; | 41.08791 | -76.136795 | OSLD |
| 8A3 | 0.9 mi.SSE; | 41.07982 | -76.1139078 | OSLD |
| 15A3 * | 0.9 mi.NW; | 41.10003 | -76.1585 | OSLD |
| 16A2 * | 0.8 mi.NNW; | 41.1025 | -76.151595 | OSLD |
| FROM ONE to FIVE MILES FROM THE SSES | | | | |
| 12S7 | 1.1 mi.WSW; | 41.08621 | -76.165914 | OSLD |
| 8B2 * | 1.4 mi.SSE; | 41.07483 | -76.130724 | OSLD |
| 9B1 | 1.3 mi.S; | 41.07356 | -76.147874 | OSLD |
| 10B3 * | 1.7 mi.SSW; | 41.07064 | -76.156646 | OSLD |
| 1D5 | 4.0 mi.N; | 41.14936 | -76.144346 | OSLD |
| 8D3 | 4.0 mi.SSE; | 41.03824 | -76.121683 | OSLD |

* Special Interest Area (other than controls)

TABLE B-1 (cont'd)
SAMPLING LOCATIONS

| STATION CODE | STATION LOCATION | LATITUDINAL | LONGITUDINAL | SAMPLE TYPE |
|--|------------------|-------------|--------------|-------------|
| FROM ONE to FIVE MILES FROM THE SSES | | DEG. | DEG. | |
| 9D4 | 3.6 mi.S; | 41.04015 | -76.144529 | OSLD |
| 10D1 | 3.0 mi.SSW; | 41.05446 | -76.175026 | OSLD |
| 12D2 | 3.7 mi.WSW; | 41.07363 | -76.213306 | OSLD |
| 14D1 | 3.6 mi.WNW; | 41.10706 | -76.211891 | OSLD |
| 3E1 | 4.7 mi NE; | 41.13953 | -76.082398 | OSLD |
| 4E2 | 4.7 mi.ENE; | 41.12157 | -76.064115 | OSLD |
| 5E2 | 4.5 mi. E; | 41.08539 | -76.060486 | OSLD |
| 6E1 | 4.7 mi.ESE; | 41.07275 | -76.059529 | OSLD |
| 7E1 | 4.2 mi.SE; | 41.04891 | -76.090309 | OSLD |
| 11E1 | 4.7 mi. SW; | 41.05188 | -76.218713 | OSLD |
| 12E1 * | 4.7 mi.WSW; | 41.0725 | -76.230331 | OSLD |
| 13E4 | 4.1 mi.W; | 41.08962 | -76.223726 | OSLD |
| GREATER THAN FIVE MILES FROM THE SSES | | | | |
| 2F1 | 5.9 mi.NNE; | 41.16796 | -76.09146 | OSLD |
| 15F1 | 5.4 mi.NW; | 41.15595 | -76.202506 | OSLD |
| 16F1 | 7.8 mi.NNW; | 41.18985 | -76.229283 | OSLD |
| 3G4 ** | 17 mi.NE; | 41.23431 | -76.869061 | OSLD |
| 4G1 ** | 14 mi.ENE; | 41.13898 | -75.885121 | OSLD |
| 7G1 ** | 14 mi.SE; | 40.94636 | -76.974184 | OSLD |
| 12G1 ** | 15 mi.WSW; | 41.0262 | -76.411566 | OSLD |
| 12G4 ** | 10 mi. WSW; | 40.03868 | -76.327731 | OSLD |

* Special Interest Area (other than controls)

** Control Location

TABLE B-2**SUSQUEHANNA STEAM ELECTRIC STATION RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM**


| Sample Medium | Analysis | Sampling Method | Collection Procedure Number | Analytical Procedure Number |
|--------------------------|------------|--|--|--|
| Ambient Radiation | Dosimeter | Quarterly | SSES, HP-TP-205 | Landauer Procedure L313, Inlight Dosimeter Analysis |
| Air | Gross Beta | Weekly | Applied Ecoscience, Appendix 2 | TBE-2008 Gross Alpha and/or Gross Beta Activity in Various Matrices. |
| Air | I-131 | Weekly | Applied Ecoscience, Appendix 2 | TBE-2012 Radioiodine in Various Matrices |
| Air | Gamma | Quarterly | Applied Ecoscience, Appendix 2 | TBE-2007 Gamma Emitting Radioisotope Analysis |
| Drinking Water | Gross Beta | Monthly | Applied Ecoscience, Appendix 5 | TBE-2008 Gross Alpha and/or Gross Beta Activity in Various Matrices. |
| Surface & Drinking Water | Tritium | Monthly (LTAW, 4S7, 5S12 and 7S12 Quarterly) | Applied Ecoscience, Appendix 3, 4, 5, 6, & 7 | TBE-2010 Tritium and Carbon-14 Analysis by Liquid Scintillation. |
| Surface & Drinking Water | Gamma | Monthly (LTAW, 4S7, 5S12 and 7S12 Quarterly) | Applied Ecoscience, Appendix 3, 4, 5, 6, & 7 | TBE-2007 Gamma Emitting Radioisotope Analysis. |
| Ground Water | Tritium | Quarterly | Applied Ecoscience, Appendix 8 | TBE-2010 Tritium and Carbon-14 Analysis by Liquid Scintillation |
| Ground Water | Gamma | Quarterly | Applied Ecoscience, Appendix 8 | TBE-2007 Gamma Emitting Radioisotope Analysis |

TABLE B-2 (cont'd)**SUSQUEHANNA STEAM ELECTRIC STATION RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM**

| Sample Medium | Analysis | Sampling Method | Collection Procedure Number | Analytical Procedure Number |
|---------------------|----------|---------------------------------|--|---|
| Precipitation | Tritium | Monthly (Apr – Nov) / Quarterly | Applied Ecoscience, Appendix 10 | TBE-2010 Tritium and Carbon-14 Analysis by Liquid Scintillation |
| Milk | Gamma | Monthly/Bi-Weekly | Applied Ecoscience, Appendix 9 | TBE-2007 Gamma Emitting Radioisotope Analysis |
| Milk | I-131 | Monthly/Bi-Weekly | Applied Ecoscience, Appendix 9 | TBE-2012 Radioiodine in Various Matrices |
| Fish | Gamma | Semi-Annually (Spring/Fall) | Applied Ecoscience, Appendix 11 | TBE-2007 Gamma Emitting Radioisotope Analysis |
| Sediment | Gamma | Semi-Annually (Spring/Fall) | Applied Ecoscience, Appendix 12 | TBE-2007 Gamma Emitting Radioisotope Analysis |
| Fruits & Vegetables | Gamma | In Season (When available) | Applied Ecoscience, Appendix 13 Applied Ecoscience, Appendix 15 | TBE-2007 Gamma Emitting Radioisotope Analysis |


MAP B-1

Direct Radiation Monitoring Locations Within One Mile




MAP B-2

Direct Radiation Monitoring Locations From One to Five Miles




MAP B-3

Direct Radiation Monitoring Locations Greater Than Five Miles




MAP B-4

Environmental Sampling Locations Within One Mile




MAP B-5
Environmental Sampling Locations
From One to Five Miles



MAP B-6

Environmental Sampling Locations Greater Than Five Miles



Intentionally left blank

APPENDIX C

DATA TABLES

TABLE C-1

**GROSS BETA ANALYSES OF AIR PARTICULATE FILTERS
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in units of E-03 pCi/cu.m. \pm 2 sigma

| COLLECTION PERIOD | 3S2 | *6G1 | 8G1 | 12E1 | 12S1 | 13S6 |
|---------------------|------------|------------|------------|------------|------------|------------|
| 01/03/18 - 01/10/18 | 11 \pm 2 | 12 \pm 2 | 12 \pm 2 | 13 \pm 2 | 13 \pm 2 | 11 \pm 2 |
| 01/10/18 - 01/16/18 | 13 \pm 3 | 13 \pm 3 | 13 \pm 3 | 11 \pm 3 | 12 \pm 3 | 13 \pm 3 |
| 01/16/18 - 01/24/18 | 18 \pm 2 | 15 \pm 2 | 15 \pm 2 | 16 \pm 2 | 16 \pm 2 | 18 \pm 2 |
| 01/24/18 - 01/31/18 | 9 \pm 2 | 11 \pm 2 | 9 \pm 2 | 12 \pm 2 | 13 \pm 2 | 9 \pm 2 |
| 01/31/18 - 02/06/18 | 11 \pm 2 | 12 \pm 2 | 11 \pm 2 | 10 \pm 2 | 12 \pm 2 | 11 \pm 2 |
| 02/06/18 - 02/14/18 | 12 \pm 2 | 11 \pm 2 | 11 \pm 2 | 14 \pm 2 | 13 \pm 2 | 12 \pm 2 |
| 02/14/18 - 02/21/18 | 12 \pm 2 | 12 \pm 2 | 11 \pm 2 | 15 \pm 2 | 14 \pm 2 | 16 \pm 2 |
| 02/21/18 - 02/28/18 | 8 \pm 2 | 9 \pm 2 | 10 \pm 2 | 8 \pm 2 | 9 \pm 2 | 7 \pm 2 |
| 02/28/18 - 03/06/18 | 11 \pm 2 | 13 \pm 2 | 13 \pm 2 | 14 \pm 2 | 14 \pm 3 | 13 \pm 2 |
| 03/06/18 - 03/14/18 | 7 \pm 2 | 4 \pm 1 | 5 \pm 1 | 5 \pm 1 | 6 \pm 2 | 6 \pm 2 |
| 03/14/18 - 03/20/18 | 14 \pm 3 | 14 \pm 2 | 14 \pm 3 | 14 \pm 3 | 14 \pm 3 | 15 \pm 3 |
| 03/20/18 - 03/28/18 | 9 \pm 2 | 9 \pm 2 | 10 \pm 2 | 9 \pm 2 | 9 \pm 2 | 11 \pm 2 |
| 03/28/18 - 04/04/18 | 9 \pm 2 | 8 \pm 2 | 10 \pm 2 | 11 \pm 2 | 9 \pm 2 | 10 \pm 2 |
| 04/04/18 - 04/11/18 | 11 \pm 2 | 11 \pm 2 | 11 \pm 2 | 12 \pm 2 | 11 \pm 2 | 12 \pm 2 |
| 04/11/18 - 04/18/18 | 9 \pm 2 | 10 \pm 2 | 10 \pm 2 | 12 \pm 2 | 10 \pm 2 | 10 \pm 2 |
| 04/18/18 - 04/25/18 | 12 \pm 2 | 10 \pm 2 | 14 \pm 2 | 13 \pm 2 | 12 \pm 2 | 9 \pm 2 |
| 04/25/18 - 05/02/18 | 12 \pm 2 | 14 \pm 2 | 14 \pm 2 | 12 \pm 2 | 12 \pm 3 | 12 \pm 2 |
| 05/02/18 - 05/09/18 | 14 \pm 2 | 13 \pm 2 | 13 \pm 2 | 13 \pm 2 | 15 \pm 2 | 13 \pm 2 |
| 05/09/18 - 05/16/18 | 12 \pm 2 | 11 \pm 2 | 15 \pm 2 | 15 \pm 2 | 13 \pm 2 | 13 \pm 2 |
| 05/16/18 - 05/23/18 | 7 \pm 2 | 7 \pm 2 | 8 \pm 2 | 7 \pm 2 | 10 \pm 2 | 7 \pm 2 |
| 05/23/18 - 05/30/18 | 14 \pm 2 | 17 \pm 2 | 14 \pm 2 | 14 \pm 2 | 15 \pm 2 | 13 \pm 2 |
| 05/30/18 - 06/06/18 | 8 \pm 2 | | 7 \pm 2 | 6 \pm 2 | 7 \pm 2 | 6 \pm 2 |
| 06/06/18 - 06/13/18 | 11 \pm 2 | | 15 \pm 2 | 12 \pm 2 | 12 \pm 2 | 13 \pm 2 |
| 06/13/18 - 06/20/18 | 11 \pm 2 | | 9 \pm 2 | 10 \pm 2 | 11 \pm 2 | 11 \pm 2 |
| 06/20/18 - 06/27/18 | 10 \pm 2 | | 11 \pm 2 | 10 \pm 2 | 10 \pm 2 | 10 \pm 2 |
| 06/27/18 - 07/03/18 | 17 \pm 3 | | 14 \pm 2 | 16 \pm 3 | 16 \pm 3 | 16 \pm 3 |
| 07/03/18 - 07/11/18 | 16 \pm 2 | | 15 \pm 2 | 15 \pm 2 | 14 \pm 2 | 16 \pm 2 |
| 07/11/18 - 07/18/18 | 14 \pm 2 | | 15 \pm 2 | 17 \pm 2 | 15 \pm 2 | 17 \pm 2 |
| 07/18/18 - 07/25/18 | 7 \pm 2 | | 7 \pm 2 | 9 \pm 2 | 6 \pm 2 | 8 \pm 2 |
| 07/25/18 - 08/01/18 | 13 \pm 2 | | 11 \pm 2 | 11 \pm 2 | 11 \pm 2 | 15 \pm 2 |
| 08/01/18 - 08/08/18 | 18 \pm 2 | | 23 \pm 3 | 22 \pm 3 | 20 \pm 2 | 18 \pm 2 |
| 08/08/18 - 08/15/18 | 14 \pm 2 | | 11 \pm 2 | 14 \pm 2 | 13 \pm 2 | 12 \pm 2 |
| 08/15/18 - 08/22/18 | 13 \pm 2 | | 14 \pm 2 | 14 \pm 2 | 14 \pm 2 | 13 \pm 2 |
| 08/22/18 - 08/29/18 | 22 \pm 3 | | 24 \pm 3 | 23 \pm 3 | 22 \pm 3 | 22 \pm 3 |
| 08/29/18 - 09/05/18 | 11 \pm 2 | | 11 \pm 2 | 12 \pm 2 | 10 \pm 2 | 11 \pm 2 |
| 09/05/18 - 09/12/18 | 9 \pm 2 | | 10 \pm 2 | 11 \pm 2 | 12 \pm 2 | 12 \pm 2 |
| 09/12/18 - 09/19/18 | 8 \pm 2 | | 7 \pm 2 | 9 \pm 2 | 7 \pm 2 | 9 \pm 2 |
| 09/19/18 - 09/26/18 | 8 \pm 2 | | 9 \pm 2 | 11 \pm 2 | 8 \pm 2 | 11 \pm 2 |
| 09/26/18 - 10/03/18 | 12 \pm 2 | | 15 \pm 2 | 17 \pm 2 | 13 \pm 2 | 14 \pm 2 |
| 10/03/18 - 10/10/18 | 16 \pm 2 | | 13 \pm 2 | 14 \pm 2 | 12 \pm 2 | 15 \pm 2 |
| 10/10/18 - 10/17/18 | 9 \pm 2 | | 11 \pm 2 | 10 \pm 2 | 9 \pm 2 | 10 \pm 2 |
| 10/17/18 - 10/24/18 | 9 \pm 2 | | 12 \pm 2 | 11 \pm 2 | 8 \pm 2 | 11 \pm 2 |
| 10/24/18 - 10/31/18 | 6 \pm 2 | | 7 \pm 2 | 9 \pm 2 | 8 \pm 2 | 8 \pm 2 |
| 10/31/18 - 11/07/18 | 12 \pm 2 | | 10 \pm 2 | 15 \pm 2 | 12 \pm 2 | 11 \pm 2 |
| 11/07/18 - 11/14/18 | 12 \pm 2 | | 10 \pm 2 | 12 \pm 2 | 11 \pm 2 | 11 \pm 2 |
| 11/14/18 - 11/20/18 | 11 \pm 2 | | 13 \pm 2 | 13 \pm 2 | 12 \pm 2 | 11 \pm 2 |
| 11/20/18 - 11/28/18 | 13 \pm 2 | | 12 \pm 2 | 14 \pm 2 | 11 \pm 2 | 10 \pm 2 |
| 11/28/18 - 12/05/18 | 9 \pm 2 | | 10 \pm 2 | 9 \pm 2 | 9 \pm 2 | 9 \pm 2 |
| 12/05/18 - 12/12/18 | 15 \pm 2 | | 13 \pm 2 | 18 \pm 2 | 17 \pm 2 | 15 \pm 2 |
| 12/12/18 - 12/19/18 | 16 \pm 2 | | 14 \pm 2 | 19 \pm 3 | 16 \pm 2 | 18 \pm 2 |
| 12/19/18 - 12/26/18 | 11 \pm 2 | | 11 \pm 2 | 12 \pm 2 | 11 \pm 2 | 12 \pm 2 |
| 12/26/18 - 01/02/19 | 11 \pm 2 | | 11 \pm 2 | 12 \pm 2 | 11 \pm 2 | 12 \pm 2 |
| AVERAGE | 12 \pm 6 | 11 \pm 6 | 12 \pm 7 | 13 \pm 7 | 12 \pm 6 | 12 \pm 6 |

*Station 6G1 is discontinued as of 5/30/18.

TABLE C-1

**GROSS BETA ANALYSES OF AIR PARTICULATE FILTERS
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in units of E-03 pCi/cu.m. \pm 2 sigma

| COLLECTION PERIOD | 9B1 | 10S3 |
|---------------------|------------|------------|
| 01/03/18 - 01/10/18 | 13 \pm 2 | 13 \pm 2 |
| 01/10/18 - 01/16/18 | 13 \pm 3 | 12 \pm 2 |
| 01/16/18 - 01/24/18 | 20 \pm 2 | 16 \pm 2 |
| 01/24/18 - 01/31/18 | 10 \pm 2 | 11 \pm 2 |
| 01/31/18 - 02/06/18 | 10 \pm 2 | 10 \pm 2 |
| 02/06/18 - 02/14/18 | 13 \pm 2 | 12 \pm 2 |
| 02/14/18 - 02/21/18 | 12 \pm 2 | 13 \pm 2 |
| 02/21/18 - 02/28/18 | 9 \pm 2 | 8 \pm 2 |
| 02/28/18 - 03/06/18 | 14 \pm 2 | 14 \pm 2 |
| 03/06/18 - 03/14/18 | 5 \pm 1 | 6 \pm 2 |
| 03/14/18 - 03/20/18 | 14 \pm 3 | 16 \pm 3 |
| 03/20/18 - 03/28/18 | 13 \pm 2 | 9 \pm 2 |
| 03/28/18 - 04/04/18 | 8 \pm 2 | 10 \pm 2 |
| 04/04/18 - 04/11/18 | 7 \pm 2 | 12 \pm 2 |
| 04/11/18 - 04/18/18 | 10 \pm 2 | 10 \pm 2 |
| 04/18/18 - 04/25/18 | 13 \pm 2 | 11 \pm 2 |
| 04/25/18 - 05/02/18 | 11 \pm 2 | 11 \pm 2 |
| 05/02/18 - 05/09/18 | 14 \pm 2 | 15 \pm 2 |
| 05/09/18 - 05/16/18 | 11 \pm 2 | 13 \pm 2 |
| 05/16/18 - 05/23/18 | 7 \pm 2 | 7 \pm 2 |
| 05/23/18 - 05/30/18 | 17 \pm 2 | 15 \pm 2 |
| 05/30/18 - 06/06/18 | 7 \pm 2 | 8 \pm 2 |
| 06/06/18 - 06/13/18 | 12 \pm 2 | 14 \pm 2 |
| 06/13/18 - 06/20/18 | 11 \pm 2 | 9 \pm 2 |
| 06/20/18 - 06/27/18 | 11 \pm 2 | 11 \pm 2 |
| 06/27/18 - 07/03/18 | 17 \pm 3 | 15 \pm 2 |
| 07/03/18 - 07/11/18 | 13 \pm 2 | 15 \pm 2 |
| 07/11/18 - 07/18/18 | 15 \pm 2 | 15 \pm 2 |
| 07/18/18 - 07/25/18 | 7 \pm 2 | 9 \pm 2 |
| 07/25/18 - 08/01/18 | 13 \pm 2 | 11 \pm 2 |
| 08/01/18 - 08/08/18 | 21 \pm 3 | 19 \pm 2 |
| 08/08/18 - 08/15/18 | 11 \pm 2 | 12 \pm 2 |
| 08/15/18 - 08/22/18 | 15 \pm 2 | 12 \pm 2 |
| 08/22/18 - 08/29/18 | 23 \pm 3 | 21 \pm 3 |
| 08/29/18 - 09/05/18 | 12 \pm 2 | 11 \pm 2 |
| 09/05/18 - 09/12/18 | 10 \pm 2 | 13 \pm 2 |
| 09/12/18 - 09/19/18 | 7 \pm 2 | 8 \pm 2 |
| 09/19/18 - 09/26/18 | 9 \pm 2 | 10 \pm 2 |
| 09/26/18 - 10/03/18 | 13 \pm 2 | 16 \pm 2 |
| 10/03/18 - 10/10/18 | 13 \pm 2 | 14 \pm 2 |
| 10/10/18 - 10/17/18 | 9 \pm 2 | 10 \pm 2 |
| 10/17/18 - 10/24/18 | 9 \pm 2 | 8 \pm 2 |
| 10/24/18 - 10/31/18 | 8 \pm 2 | 9 \pm 2 |
| 10/31/18 - 11/07/18 | 12 \pm 2 | 12 \pm 2 |
| 11/07/18 - 11/14/18 | 10 \pm 2 | 13 \pm 2 |
| 11/14/18 - 11/20/18 | 11 \pm 2 | 11 \pm 2 |
| 11/20/18 - 11/28/18 | 12 \pm 2 | 13 \pm 2 |
| 11/28/18 - 12/05/18 | 9 \pm 2 | 10 \pm 2 |
| 12/05/18 - 12/12/18 | 18 \pm 2 | 18 \pm 2 |
| 12/12/18 - 12/19/18 | 15 \pm 2 | 15 \pm 2 |
| 12/19/18 - 12/26/18 | 12 \pm 2 | 12 \pm 2 |
| 12/26/18 - 01/02/19 | 12 \pm 2 | 11 \pm 2 |
| AVERAGE | 12 \pm 7 | 12 \pm 6 |

**TABLE C-2 GAMMA SPECTROSCOPIC ANALYSES OF COMPOSITED AIR PARTICULATE FILTERS
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in units of E-03 pCi/cu.m. \pm 2 sigma

| SITE | COLLECTION PERIOD | Be-7 | K-40 | Cs-134 | Cs-137 |
|------|---------------------|--------------|------|--------|--------|
| *6G1 | 01/03/18 - 04/04/18 | 108 \pm 23 | < 19 | < 1 | < 1 |
| | 04/04/18 - 05/30/18 | 92 \pm 39 | < 25 | < 1 | < 1 |
| | AVERAGE | 100 \pm 22 | - | - | - |
| 8G1 | 01/03/18 - 04/04/18 | 94 \pm 17 | < 13 | < 1 | < 1 |
| | 04/04/18 - 07/03/18 | 90 \pm 23 | < 24 | < 1 | < 1 |
| | 07/03/18 - 10/03/18 | 106 \pm 24 | < 16 | < 2 | < 1 |
| | 10/03/18 - 01/02/19 | 90 \pm 17 | < 18 | < 1 | < 1 |
| | AVERAGE | 95 \pm 15 | - | - | - |
| 3S2 | 01/03/18 - 04/04/18 | 73 \pm 16 | < 14 | < 1 | < 1 |
| | 04/04/18 - 07/03/18 | 114 \pm 26 | < 25 | < 2 | < 2 |
| | 07/03/18 - 10/03/18 | 81 \pm 20 | < 12 | < 1 | < 1 |
| | 10/03/18 - 01/02/19 | 70 \pm 14 | < 18 | < 1 | < 1 |
| | AVERAGE | 85 \pm 41 | - | - | - |
| 12E1 | 01/03/18 - 04/04/18 | 83 \pm 17 | < 15 | < 1 | < 1 |
| | 04/04/18 - 07/03/18 | 127 \pm 24 | < 20 | < 1 | < 1 |
| | 07/03/18 - 10/03/18 | 107 \pm 23 | < 20 | < 1 | < 1 |
| | 10/03/18 - 01/02/19 | 75 \pm 16 | < 22 | < 1 | < 1 |
| | AVERAGE | 98 \pm 48 | - | - | - |
| 12S1 | 01/03/18 - 04/04/18 | 80 \pm 19 | < 17 | < 1 | < 1 |
| | 04/04/18 - 07/03/18 | 123 \pm 21 | < 21 | < 1 | < 1 |
| | 07/03/18 - 10/03/18 | 108 \pm 29 | < 30 | < 2 | < 2 |
| | 10/03/18 - 01/02/19 | 58 \pm 13 | < 18 | < 1 | < 1 |
| | AVERAGE | 92 \pm 57 | - | - | - |
| 13S6 | 01/03/18 - 04/04/18 | 89 \pm 22 | < 20 | < 1 | < 1 |
| | 04/04/18 - 07/03/18 | 161 \pm 29 | < 23 | < 1 | < 1 |
| | 07/03/18 - 10/03/18 | 89 \pm 21 | < 19 | < 1 | < 1 |
| | 10/03/18 - 01/02/19 | 63 \pm 18 | < 15 | < 1 | < 1 |
| | AVERAGE | 101 \pm 84 | - | - | - |
| 10S3 | 01/03/18 - 04/04/18 | 86 \pm 30 | < 22 | < 2 | < 1 |
| | 04/04/18 - 07/03/18 | 139 \pm 22 | < 19 | < 1 | < 1 |
| | 07/03/18 - 10/03/18 | 108 \pm 26 | < 23 | < 2 | < 1 |
| | 10/03/18 - 01/02/19 | 76 \pm 16 | < 11 | < 1 | < 1 |
| | AVERAGE | 102 \pm 56 | - | - | - |
| 9B1 | 01/03/18 - 04/04/18 | 114 \pm 24 | < 34 | < 1 | < 2 |
| | 04/04/18 - 07/03/18 | 132 \pm 24 | < 23 | < 1 | < 1 |
| | 07/03/18 - 10/03/18 | 113 \pm 22 | < 28 | < 2 | < 1 |
| | 10/03/18 - 01/02/19 | 64 \pm 17 | < 16 | < 1 | < 1 |
| | AVERAGE | 105 \pm 58 | - | - | - |

*Station was discontinued as of 05/30/18.

TABLE C-3

**IODINE-131 ANALYSES OF AIR IODINE SAMPLES
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in units of E-03 pCi/cu.m. \pm 2 sigma

| COLLECTION PERIOD | 3S2 | *6G1 | 8G1 | 12E1 | 12S1 | 13S6 |
|---------------------|------|------|------|------|------|------|
| 01/03/18 - 01/10/18 | < 10 | < 6 | < 6 | < 7 | < 11 | < 11 |
| 01/10/18 - 01/16/18 | < 13 | < 7 | < 7 | < 8 | < 13 | < 13 |
| 01/16/18 - 01/24/18 | < 12 | < 6 | < 8 | < 8 | < 12 | < 11 |
| 01/24/18 - 01/31/18 | < 18 | < 14 | < 14 | < 15 | < 19 | < 18 |
| 01/31/18 - 02/06/18 | < 18 | < 10 | < 10 | < 11 | < 19 | < 18 |
| 02/06/18 - 02/14/18 | < 9 | < 6 | < 7 | < 7 | < 9 | < 9 |
| 02/14/18 - 02/21/18 | < 18 | < 8 | < 10 | < 10 | < 18 | < 17 |
| 02/21/18 - 02/28/18 | < 11 | < 8 | < 8 | < 7 | < 12 | < 11 |
| 02/28/18 - 03/06/18 | < 11 | < 7 | < 7 | < 7 | < 12 | < 10 |
| 03/06/18 - 03/14/18 | < 16 | < 10 | < 10 | < 9 | < 17 | < 16 |
| 03/14/18 - 03/20/18 | < 14 | < 9 | < 9 | < 9 | < 14 | < 14 |
| 03/20/18 - 03/28/18 | < 18 | < 11 | < 12 | < 11 | < 18 | < 17 |
| 03/28/18 - 04/04/18 | < 5 | < 7 | < 8 | < 8 | < 13 | < 13 |
| 04/04/18 - 04/11/18 | < 19 | < 10 | < 10 | < 10 | < 19 | < 19 |
| 04/11/18 - 04/18/18 | < 20 | < 8 | < 10 | < 10 | < 20 | < 20 |
| 04/18/18 - 04/25/18 | < 17 | < 18 | < 18 | < 15 | < 17 | < 17 |
| 04/25/18 - 05/02/18 | < 12 | < 17 | < 17 | < 7 | < 15 | < 12 |
| 05/02/18 - 05/09/18 | < 5 | < 16 | < 16 | < 8 | < 12 | < 12 |
| 05/09/18 - 05/16/18 | < 8 | < 12 | < 12 | < 12 | < 8 | < 7 |
| 05/16/18 - 05/23/18 | < 19 | < 19 | < 19 | < 19 | < 19 | < 18 |
| 05/23/18 - 05/30/18 | < 6 | < 10 | < 10 | < 10 | < 6 | < 6 |
| 05/30/18 - 06/06/18 | < 9 | | < 10 | < 11 | < 9 | < 8 |
| 06/06/18 - 06/13/18 | < 5 | | < 6 | < 6 | < 5 | < 5 |
| 06/13/18 - 06/20/18 | < 9 | | < 6 | < 5 | < 9 | < 8 |
| 06/20/18 - 06/27/18 | < 6 | | < 8 | < 3 | < 8 | < 5 |
| 06/27/18 - 07/03/18 | < 10 | | < 6 | < 7 | < 11 | < 10 |
| 07/03/18 - 07/11/18 | < 5 | | < 8 | < 8 | < 5 | < 5 |
| 07/11/18 - 07/18/18 | < 15 | | < 20 | < 20 | < 14 | < 15 |
| 07/18/18 - 07/25/18 | < 7 | | < 16 | < 17 | < 7 | < 7 |
| 07/25/18 - 08/01/18 | < 20 | | < 16 | < 16 | < 8 | < 20 |
| 08/01/18 - 08/08/18 | < 15 | | < 11 | < 11 | < 19 | < 19 |
| 08/08/18 - 08/15/18 | < 15 | | < 11 | < 11 | < 16 | < 16 |
| 08/15/18 - 08/22/18 | < 5 | | < 9 | < 8 | < 6 | < 6 |
| 08/22/18 - 08/29/18 | < 15 | | < 9 | < 9 | < 15 | < 16 |
| 08/29/18 - 09/05/18 | < 4 | | < 10 | < 10 | < 10 | < 10 |
| 09/05/18 - 09/12/18 | < 5 | | < 8 | < 3 | < 6 | < 6 |
| 09/12/18 - 09/19/18 | < 5 | | < 8 | < 8 | < 5 | < 5 |
| 09/19/18 - 09/26/18 | < 5 | | < 8 | < 8 | < 4 | < 5 |
| 09/26/18 - 10/03/18 | < 15 | | < 16 | < 16 | < 16 | < 16 |
| 10/03/18 - 10/10/18 | < 16 | | < 20 | < 19 | < 17 | < 17 |
| 10/10/18 - 10/17/18 | < 15 | | < 11 | < 11 | < 18 | < 17 |
| 10/17/18 - 10/24/18 | < 12 | | < 6 | < 6 | < 12 | < 12 |
| 10/24/18 - 10/31/18 | < 6 | | < 9 | < 9 | < 6 | < 6 |
| 10/31/18 - 11/07/18 | < 18 | | < 17 | < 17 | < 18 | < 18 |
| 11/07/18 - 11/14/18 | < 10 | | < 18 | < 16 | < 11 | < 10 |
| 11/14/18 - 11/20/18 | < 17 | | < 19 | < 18 | < 17 | < 17 |
| 11/20/18 - 11/28/18 | < 17 | | < 15 | < 15 | < 17 | < 16 |
| 11/28/18 - 12/05/18 | < 19 | | < 16 | < 17 | < 18 | < 19 |
| 12/05/18 - 12/12/18 | < 6 | | < 9 | < 9 | < 6 | < 7 |
| 12/12/18 - 12/19/18 | < 7 | | < 4 | < 10 | < 7 | < 7 |
| 12/19/18 - 12/26/18 | < 10 | | < 5 | < 6 | < 4 | < 10 |
| 12/26/18 - 01/02/19 | < 5 | | < 5 | < 5 | < 5 | < 5 |
| AVERAGE | - | - | - | - | - | - |

*Station 6G1 is discontinued as of 5/30/18.

TABLE C-3

**IODINE-131 ANALYSES OF AIR IODINE SAMPLES
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in units of E-03 pCi/cu.m. \pm 2 sigma

| COLLECTION PERIOD | 9B1 | 10S3 |
|----------------------|------|------|
| 01/03/18 - 01/10/18 | < 7 | < 10 |
| 01/10/18 - 01/16/18 | < 8 | < 12 |
| 01/16/18 - 01/24/18 | < 8 | < 11 |
| 01/24/18 - 01/31/18 | < 14 | < 17 |
| 01/31/18 - 02/06/18 | < 10 | < 7 |
| 02/06/18 - 02/14/18 | < 5 | < 8 |
| 02/14/18 - 02/21/18 | < 10 | < 17 |
| 02/21/18 - 02/28/18 | < 8 | < 11 |
| 02/28/18 - 03/06/18 | < 7 | < 10 |
| 03/06/18 - 03/14/18 | < 9 | < 15 |
| 03/14/18 - 03/20/18 | < 7 | < 13 |
| 03/20/18 - 03/28/18 | < 11 | < 7 |
| 03/28/18 - 04/04/18 | < 6 | < 12 |
| 04/04/18 - 04/11/18 | < 8 | < 18 |
| 04/11/18 - 04/18/18 | < 10 | < 19 |
| 04/18/18 - 04/25/18 | < 18 | < 16 |
| 04/25/18 - 05/02/18 | < 17 | < 9 |
| 05/02/18 - 05/09/18 | < 14 | < 12 |
| 05/09/18 - 05/16/18 | < 11 | < 8 |
| 05/16/18 - 05/23/18 | < 17 | < 20 |
| 05/23/18 - 05/30/18 | < 4 | < 6 |
| 05/30/18 - 06/06/18 | < 4 | < 9 |
| 06/06/18 - 06/13/18 | < 4 | < 5 |
| 06/13/18 - 06/20/18 | < 5 | < 8 |
| 06/20/18 - 06/27/18 | < 8 | < 5 |
| 06/27/18 - 07/03/18 | < 5 | < 10 |
| 07/03/18 - 07/11/18 | < 8 | < 6 |
| 07/11/18 - 07/18/18 | < 8 | < 15 |
| 07/18/18 - 07/25/18 | < 16 | < 10 |
| 07/25/18 - 08/01/18 | < 15 | < 16 |
| 08/01/18 - 08/08/18 | < 11 | < 19 |
| 08/08/18 - 08/15/18 | < 10 | < 15 |
| 08/15/18 - 08/22/18 | < 9 | < 5 |
| 08/22/18 - 08/29/18 | < 9 | < 4 |
| 08/29/18 - 09/05/18 | < 10 | < 10 |
| 09/05/18 - 09/12/18 | < 8 | < 5 |
| 09/12/18 - 09/19/18 | < 8 | < 5 |
| 09/19/18 - 09/26/18 | < 8 | < 5 |
| 09/26/18 - 10/03/18 | < 16 | < 15 |
| 10/03/18 - 10/10/18 | < 19 | < 16 |
| 10/10/18 - 10/17/18 | < 11 | < 11 |
| 10/17/18 - 10/24/18 | < 6 | < 5 |
| 10/24/18 - 10/31/18 | < 9 | < 6 |
| 10/31/18 - 11/07/18 | < 17 | < 16 |
| 11/07/18 - 11/14/18 | < 7 | < 10 |
| 11/14/18 - 11/20/18 | < 18 | < 19 |
| 11/20/18 - 11/28/18 | < 15 | < 16 |
| 11/28/18 - 12/05/18 | < 17 | < 19 |
| 12/05/18 - 12/12/18 | < 9 | < 6 |
| 12/12/18 - 12/19/18 | < 10 | < 7 |
| 12/19/18 - 12/26/18 | < 6 | < 10 |
| 12/26/18 - 01/02/19 | < 5 | < 5 |
| AVERAGE | - | - |

**TABLE C-4 ENVIRONMENTAL OPTICALLY STIMULATED LUMINESCENCE DOSIMETRY RESULTS
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results (1) are in mR/std. qtr (2) \pm 2 sigma (3)

| LOCATION | First Quarter 1/10/2018 to 3/22/2018 | Second Quarter 3/22/2018 to 7/5/2018 | Third Quarter 7/5/2018 to 10/9/2018 | Fourth Quarter 10/9/2018 to 1/11/2019 |
|-----------------|---|---|--|--|
| ONSITE | | | | |
| 1S2 | 20.9 \pm 1.5 | 15.4 \pm 0.1 | 23.6 \pm 3.9 | 22.0 \pm 0.8 |
| 2S2 | 14.5 \pm 0.6 | 12.8 \pm 1.8 | 14.6 \pm 1.1 | 14.6 \pm 0.1 |
| 2S3 | 17.4 \pm 0.6 | 14.9 \pm 0.7 | 19.4 \pm 0.4 | 20.3 \pm 2.6 |
| 3S2 | 13.0 \pm 0.3 | 12.8 \pm 1.8 | 15.2 \pm 1.1 | 14.6 \pm 1.4 |
| 3S3 | 11.6 \pm 0.5 | 10.1 \pm 0.1 | 13.6 \pm 0.3 | 14.3 \pm 0.6 |
| 4S3 | 16.9 \pm 1.9 | 16.7 \pm 0.0 | 20.2 \pm 1.0 | 20.3 \pm 1.5 |
| 4S6 | 13.9 \pm 0.2 | 12.7 \pm 0.6 | 13.7 \pm 0.0 | 15.0 \pm 0.0 |
| 5S4 | 10.7 \pm 0.6 | 10.7 \pm 0.6 | 11.5 \pm 0.3 | 13.3 \pm 1.5 |
| 5S7 | 14.1 \pm 1.8 | 13.7 \pm 0.8 | 16.3 \pm 0.1 | 18.0 \pm 0.4 |
| 6S4 | 24.2 \pm 4.1 | 19.3 \pm 1.5 | 22.8 \pm 2.6 | 23.7 \pm 1.8 |
| 6S9 | 20.6 \pm 0.5 | 16.7 \pm 0.7 | 22.9 \pm 1.9 | 21.9 \pm 0.9 |
| 7S6 | 18.8 \pm 2.8 | 18.2 \pm 2.4 | 20.2 \pm 1.5 | 21.6 \pm 0.8 |
| 7S7 | 12.2 \pm 0.0 | 11.3 \pm 0.2 | 12.5 \pm 0.7 | 13.2 \pm 0.3 |
| 8S2 | 19.0 \pm 1.6 | 16.5 \pm 0.2 | 22.4 \pm 0.6 | 22.0 \pm 1.1 |
| 9S2 | 35.1 \pm 0.4 | 26.3 \pm 1.7 | 34.8 \pm 0.3 | 34.4 \pm 5.7 |
| 10S1 | 13.3 \pm 1.7 | 11.4 \pm 0.8 | 13.9 \pm 0.8 | 14.9 \pm 0.1 |
| 10S2 | 31.7 \pm 1.5 | 24.8 \pm 1.5 | 29.4 \pm 0.9 | 29.6 \pm 0.8 |
| 11S7 | 13.4 \pm 0.5 | 12.2 \pm 0.6 | 13.8 \pm 1.1 | 14.4 \pm 1.9 |
| 12S1 | 15.8 \pm 1.6 | 13.2 \pm 0.6 | 16.9 \pm 0.8 | 16.6 \pm 0.3 |
| 12S3 | 17.0 \pm 3.0 | 17.8 \pm 0.2 | 17.9 \pm 0.1 | 17.7 \pm 3.0 |
| 12S7 | 13.0 \pm 0.5 | 12.4 \pm 0.1 | 13.9 \pm 1.3 | 14.8 \pm 2.4 |
| 13S2 | 24.9 \pm 2.3 | 21.2 \pm 2.1 | 26.5 \pm 4.0 | 22.3 \pm 3.4 |
| 13S5 | 24.0 \pm 1.5 | 19.2 \pm 0.6 | 30.6 \pm 3.5 | 25.4 \pm 3.6 |
| 13S6 | 18.1 \pm 0.1 | 16.0 \pm 0.8 | 20.2 \pm 0.8 | 21.0 \pm 0.8 |
| 14S5 | 17.3 \pm 0.3 | 17.1 \pm 0.9 | 19.6 \pm 0.2 | 20.0 \pm 1.9 |
| 15S5 | 16.3 \pm 1.3 | 13.7 \pm 0.1 | 17.8 \pm 3.4 | 16.6 \pm 2.3 |
| 16S1 | 19.0 \pm 0.3 | 14.9 \pm 1.3 | 20.2 \pm 1.1 | 19.4 \pm 0.4 |
| 16S2 | 18.4 \pm 0.6 | 15.7 \pm 1.4 | 19.9 \pm 1.1 | 20.9 \pm 1.6 |

See the comments at the end of this table.

**TABLE C-4 ENVIRONMENTAL OPTICALLY STIMULATED LUMINESCENCE DOSIMETRY RESULTS
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results (1) are in mR/std. qtr (2) \pm 2 sigma (3)

| <u>LOCATION</u> | First Quarter 1/10/2018 to 3/22/2018 | Second Quarter 3/22/2018 to 7/5/2018 | Third Quarter 7/5/2018 to 10/9/2018 | Fourth Quarter 10/9/2018 to 1/11/2019 |
|--------------------------|---|---|--|--|
| 0-1 MILE OFFSITE | | | | |
| 6A4 | 16.8 \pm 1.5 | 13.5 \pm 1.5 | 16.1 \pm 1.0 | 19.3 \pm 0.2 |
| 8A3 | 11.0 \pm 0.3 | 10.9 \pm 0.0 | 13.0 \pm 0.7 | 15.5 \pm 0.5 |
| 15A3 | 11.2 \pm 0.4 | 11.8 \pm 0.5 | 13.8 \pm 0.3 | 13.4 \pm 0.2 |
| 16A2 | 10.9 \pm 1.0 | 9.8 \pm 0.4 | 13.2 \pm 1.0 | 13.0 \pm 0.8 |
| 1-2 MILES OFFSITE | | | | |
| 8B2 | 11.3 \pm 2.0 | 11.7 \pm 1.1 | 14.6 \pm 2.4 | 13.7 \pm 1.2 |
| 9B1 | 16.8 \pm 0.8 | 15.6 \pm 0.2 | 18.3 \pm 0.3 | 17.2 \pm 0.1 |
| 10B3 | 12.0 \pm 0.7 | 10.8 \pm 0.6 | 13.9 \pm 0.1 | 13.0 \pm 1.2 |
| 3-4 MILES OFFSITE | | | | |
| 1D5 | 14.0 \pm 0.2 | 14.1 \pm 1.0 | 16.2 \pm 0.8 | 16.0 \pm 0.5 |
| 8D3 | 12.2 \pm 1.3 | 13.0 \pm 0.4 | 15.4 \pm 1.0 | 13.3 \pm 0.1 |
| 9D4 | 12.5 \pm 0.9 | 13.3 \pm 1.0 | 15.7 \pm 0.7 | 15.6 \pm 0.8 |
| 10D1 | 13.6 \pm 0.0 | 13.7 \pm 2.2 | 15.8 \pm 0.1 | 14.2 \pm 1.4 |
| 12D2 | 16.8 \pm 0.0 | 15.7 \pm 0.4 | 21.3 \pm 1.8 | 17.8 \pm 0.5 |
| 14D1 | 12.4 \pm 0.1 | 14.3 \pm 0.2 | 16.0 \pm 0.3 | 16.8 \pm 0.2 |
| 4-5 MILES OFFSITE | | | | |
| 3E1 | 9.8 \pm 1.1 | 9.9 \pm 0.2 | 11.8 \pm 0.9 | 11.4 \pm 1.4 |
| 4E2 | 13.2 \pm 0.3 | 14.4 \pm 0.7 | 14.3 \pm 0.8 | 14.8 \pm 0.5 |
| 5E2 | 12.1 \pm 0.1 | 12.4 \pm 1.0 | 16.5 \pm 2.1 | 14.6 \pm 2.1 |
| 6E1 | 14.3 \pm 0.9 | 15.0 \pm 0.3 | 16.6 \pm 0.7 | 17.0 \pm 1.1 |
| 7E1 | 13.5 \pm 0.2 | 13.5 \pm 0.3 | 16.5 \pm 1.0 | 15.7 \pm 0.6 |
| 11E1 | 9.7 \pm 0.6 | 9.6 \pm 0.0 | 12.8 \pm 1.7 | 7.7 \pm 4.0 |
| 12E1 | 11.9 \pm 1.0 | 11.0 \pm 1.1 | 12.9 \pm 1.3 | 14.9 \pm 1.6 |
| 13E4 | 17.2 \pm 0.2 | 15.3 \pm 0.4 | 17.9 \pm 0.2 | 18.1 \pm 0.7 |

See the comments at the end of this table.

**TABLE C-4 ENVIRONMENTAL OPTICALLY STIMULATED LUMINESCENCE DOSIMETRY RESULTS
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results (1) are in mR/std. qtr (2) \pm 2 sigma (3)

| | First Quarter 1/10/2018 to 3/22/2018 | Second Quarter 3/22/2018 to 7/5/2018 | Third Quarter 7/5/2018 to 10/9/2018 | Fourth Quarter 10/9/2018 to 1/11/2019 |
|----------------------------|---|---|--|--|
| LOCATION | | | | |
| 5-10 MILES OFFSITE | | | | |
| 2F1 | 14.1 \pm 0.7 | 12.2 \pm 0.3 | 14.4 \pm 0.3 | 14.7 \pm 0.3 |
| 15F1 | 14.5 \pm 0.8 | 14.5 \pm 0.1 | 16.7 \pm 1.6 | 17.4 \pm 1.9 |
| 16F1 | 17.1 \pm 2.0 | 14.3 \pm 0.8 | 17.6 \pm 0.0 | 18.6 \pm 0.7 |
| 10-20 MILES OFFSITE | | | | |
| 3G4 | 15.2 \pm 0.4 | 14.0 \pm 0.7 | 16.3 \pm 0.2 | 16.4 \pm 0.4 |
| 4G1 | 15.7 \pm 1.5 | 14.7 \pm 0.6 | 18.2 \pm 1.7 | 17.5 \pm 0.1 |
| 7G1 | 12.9 \pm 1.2 | 12.1 \pm 0.3 | 15.8 \pm 0.3 | 15.2 \pm 0.4 |
| 12G1 | 11.4 \pm 0.3 | 10.5 \pm 0.5 | 14.2 \pm 0.1 | 13.3 \pm 0.6 |
| 12G4 | 12.7 \pm 0.1 | 11.4 \pm 0.7 | 14.5 \pm 0.1 | 12.9 \pm 2.1 |

See the comments at the end of this table.

LOCATION

INDICATOR

| | | | | |
|-------------|-----------------|----------------|----------------|----------------|
| Average (5) | 15.8 \pm 10.1 | 14.4 \pm 6.9 | 17.6 \pm 9.7 | 17.4 \pm 9.1 |
|-------------|-----------------|----------------|----------------|----------------|

CONTROL

| | | | | |
|-------------|----------------|----------------|----------------|----------------|
| Average (5) | 13.6 \pm 3.7 | 12.5 \pm 3.5 | 15.8 \pm 3.2 | 15.1 \pm 4.0 |
|-------------|----------------|----------------|----------------|----------------|

COMMENTS

- (1) Individual monitor location results are normally the average of the elemental doses of four elements from the two dosimeters assigned to each monitoring location.
- (2) A standard (std.) quarter (qtr.) is considered to be 91.25 days. Results obtained for monitoring periods of other durations are normalized by multiplying them by 91.25/x, where x is the actual duration in days of the period.
- (3) Uncertainties for individual monitoring location results are two standard deviations of the elemental doses of four elements from the two dosimeters assigned to each monitoring location, representing the variability between the elemental doses of each of the four dosimeter elements.
- (4) No measurement could be made at this location because the dosimeters were lost, stolen, or damaged. Refer to Section III, Program Description, of the Annual Radiological Environmental Operating Report for an explanation of program exceptions to REMP.
- (5) Uncertainties associated with quarterly indicator and control averages are two standard deviations, representing the variability between the results of the individual monitoring locations.

TABLE C-5

**IODINE-131 AND GAMMA SPECTROSCOPIC ANALYSES OF MILK
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in pCi/Liter \pm 2 sigma

| SITE | COLLECTION DATE | I-131 | <-----GAMMA EMITTERS-----> | | | | | |
|----------|-----------------|----------------|----------------------------|--------|--------|--------|--------|--------|
| | | | K-40 | Cs-134 | Cs-137 | Ba-140 | La-140 | Th-228 |
| 10G1 | 01/08/18 | < 0.8 | 1421 \pm 163 | < 6 | < 7 | < 23 | < 7 | < 14 |
| | 02/05/18 | < 0.5 | 1458 \pm 154 | < 8 | < 9 | < 28 | < 8 | < 16 |
| | 03/05/18 | < 0.4 | 1330 \pm 223 | < 11 | < 12 | < 41 | < 11 | < 18 |
| | 04/09/18 | < 0.4 | 1055 \pm 206 | < 8 | < 8 | < 31 | < 11 | < 15 |
| | 04/23/18 | < 0.6 | 1231 \pm 181 | < 6 | < 8 | < 29 | < 6 | < 15 |
| | 05/07/18 | < 0.5 | 1239 \pm 161 | < 7 | < 6 | < 33 | < 10 | < 14 |
| | 05/21/18 | < 0.5 | 1313 \pm 181 | < 6 | < 7 | < 29 | < 7 | < 14 |
| | 06/04/18 | < 0.5 | 1230 \pm 188 | < 8 | < 9 | < 37 | < 15 | < 14 |
| | 06/18/18 | < 0.4 | 1224 \pm 183 | < 6 | < 9 | < 28 | < 14 | < 15 |
| | 07/02/18 | < 0.4 | 1189 \pm 156 | < 6 | < 6 | < 29 | < 9 | < 13 |
| | 07/16/18 | < 0.5 | 1359 \pm 190 | < 8 | < 9 | < 35 | < 12 | < 16 |
| | 07/30/18 | < 0.5 | 1368 \pm 180 | < 7 | < 7 | < 29 | < 7 | < 11 |
| | 08/13/18 | < 0.7 | 1329 \pm 151 | < 6 | < 7 | < 38 | < 10 | < 13 |
| | 08/27/18 | < 0.3 | 1201 \pm 189 | < 7 | < 9 | < 31 | < 10 | < 15 |
| | 09/10/18 | < 0.8 | 1228 \pm 187 | < 7 | < 8 | < 38 | < 14 | < 15 |
| | 09/24/18 | < 0.7 | 1181 \pm 169 | < 8 | < 8 | < 39 | < 13 | < 13 |
| | 10/08/18 | < 0.7 | 1331 \pm 176 | < 6 | < 9 | < 39 | < 12 | < 14 |
| | 10/22/18 | < 0.6 | 1296 \pm 114 | < 5 | < 5 | < 22 | < 6 | < 8 |
| | 11/05/18 | < 0.4 | 1444 \pm 202 | < 8 | < 7 | < 37 | < 10 | < 18 |
| 12/10/18 | < 0.5 | 1118 \pm 209 | < 7 | < 8 | < 44 | < 14 | < 15 | |
| | AVERAGE | - | 1277 \pm 213 | - | - | - | - | - |
| 13E3 | 01/08/18 | < 0.5 | 1623 \pm 212 | < 7 | < 9 | < 31 | < 9 | < 19 |
| | 02/05/18 | < 0.6 | 1192 \pm 181 | < 6 | < 7 | < 29 | < 8 | < 15 |
| | 03/05/18 | < 0.5 | 1372 \pm 184 | < 7 | < 8 | < 28 | < 7 | < 15 |
| | 04/09/18 | < 0.5 | 1223 \pm 174 | < 8 | < 11 | < 26 | < 11 | < 16 |
| | 04/23/18 | < 0.4 | 1102 \pm 169 | < 8 | < 8 | < 31 | < 10 | < 14 |
| | 05/07/18 | < 0.3 | 1055 \pm 124 | < 5 | < 6 | < 31 | < 8 | < 11 |
| | 05/21/18 | < 0.2 | 1297 \pm 124 | < 6 | < 6 | < 23 | < 6 | < 11 |
| | 06/04/18 | < 0.5 | 1291 \pm 205 | < 8 | < 9 | < 41 | < 12 | < 16 |
| | 06/18/18 | < 0.4 | 1215 \pm 169 | < 9 | < 7 | < 31 | < 12 | < 16 |
| | 07/02/18 | < 0.6 | 1184 \pm 133 | < 5 | < 6 | < 21 | < 6 | < 11 |
| | 07/16/18 | < 0.7 | 1298 \pm 176 | < 8 | < 10 | < 32 | < 6 | < 17 |
| | 07/30/18 | < 0.6 | 1292 \pm 186 | < 8 | < 8 | < 32 | < 9 | < 16 |
| | 08/13/18 | < 0.4 | 1217 \pm 188 | < 7 | < 9 | < 38 | < 10 | < 16 |
| | 08/27/18 | < 0.3 | 1305 \pm 239 | < 7 | < 8 | < 31 | < 6 | < 17 |
| | 09/10/18 | < 0.7 | 1530 \pm 212 | < 8 | < 8 | < 41 | < 12 | < 15 |
| | 09/24/18 | < 0.5 | 1256 \pm 163 | < 8 | < 9 | < 40 | < 15 | < 16 |
| | 10/08/18 | < 0.6 | 1249 \pm 175 | < 7 | < 9 | < 44 | < 13 | < 16 |
| | 10/22/18 | < 0.7 | 1263 \pm 125 | < 5 | < 5 | < 25 | < 8 | < 8 |
| | 11/05/18 | < 0.5 | 1308 \pm 199 | < 9 | < 10 | < 48 | < 13 | < 16 |
| 12/10/18 | < 0.8 | 1170 \pm 210 | < 8 | < 7 | < 47 | < 10 | < 15 | |
| | AVERAGE | - | 1272 \pm 257 | - | - | - | - | - |

TABLE C-5

**IODINE-131 AND GAMMA SPECTROSCOPIC ANALYSES OF MILK
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in pCi/Liter ± 2 sigma

| SITE | COLLECTION DATE | I-131 | <-----GAMMA EMITTERS-----> | | | | | |
|----------|-----------------|------------|----------------------------|--------|--------|--------|--------|--------|
| | | | K-40 | Cs-134 | Cs-137 | Ba-140 | La-140 | Th-228 |
| 5E2 | 01/08/18 | < 0.7 | 1274 ± 171 | < 6 | < 8 | < 22 | < 7 | < 14 |
| | 02/05/18 | < 0.4 | 1228 ± 172 | < 8 | < 10 | < 32 | < 6 | < 14 |
| | 03/05/18 | < 0.5 | 1303 ± 221 | < 9 | < 8 | < 30 | < 11 | < 18 |
| | 04/09/18 | < 0.3 | 1310 ± 160 | < 6 | < 9 | < 31 | < 10 | < 15 |
| | 04/23/18 | < 0.3 | 1284 ± 140 | < 5 | < 6 | < 25 | < 6 | < 13 |
| | 05/07/18 | < 0.5 | 1179 ± 143 | < 6 | < 6 | < 33 | < 9 | < 11 |
| | 05/21/18 | < 0.3 | 1213 ± 148 | < 5 | < 7 | < 25 | < 7 | < 13 |
| | 06/04/18 | < 0.5 | 1235 ± 148 | < 6 | < 6 | < 28 | < 5 | < 13 |
| | 06/18/18 | < 0.4 | 1202 ± 194 | < 7 | < 8 | < 31 | < 10 | < 15 |
| | 07/02/18 | < 0.4 | 1279 ± 164 | < 6 | < 8 | < 24 | < 8 | < 13 |
| | 07/16/18 | < 0.7 | 1411 ± 206 | < 8 | < 9 | < 36 | < 11 | < 17 |
| | 07/30/18 | < 0.5 | 1284 ± 202 | < 8 | < 8 | < 31 | < 12 | < 18 |
| | 08/13/18 | < 0.6 | 1210 ± 165 | < 6 | < 8 | < 41 | < 7 | < 14 |
| | 08/27/18 | < 0.4 | 1349 ± 171 | < 7 | < 8 | < 32 | < 9 | < 16 |
| | 09/10/18 | < 0.7 | 1308 ± 169 | < 7 | < 9 | < 38 | < 12 | < 15 |
| | 09/24/18 | < 0.6 | 1388 ± 164 | < 6 | < 7 | < 34 | < 9 | < 15 |
| | 10/08/18 | < 0.5 | 1248 ± 162 | < 6 | < 6 | < 30 | < 15 | < 13 |
| | 10/22/18 | < 0.7 | 1273 ± 130 | < 4 | < 6 | < 22 | < 8 | < 10 |
| 11/05/18 | < 0.5 | 1205 ± 195 | < 7 | < 9 | < 29 | < 10 | < 13 | |
| 12/10/18 | < 0.5 | 1077 ± 171 | < 6 | < 6 | < 31 | < 13 | < 12 | |
| AVERAGE | - | - | 1263 ± 151 | - | - | - | - | - |

**TABLE C-6 TRITIUM AND GAMMA SPECTROSCOPIC ANALYSES OF GROUNDWATER
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in pCi/Liter ± 2 sigma

| SITE | COLLECTION DATE | H-3 | <-----GAMMA EMITTERS-----> | | | | | | | | | | | | | |
|-------|-----------------|----------|----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|--------|
| | | | K-40 | Mn-54 | Co-58 | Fe-59 | Co-60 | Zn-65 | Nb-95 | Zr-95 | I-131 | Cs-134 | Cs-137 | Ba-140 | La-140 | Th-228 |
| *12F3 | 01/22/18 | < 143 | < 106 | < 6 | < 6 | < 13 | < 6 | < 12 | < 8 | < 10 | < 8 | < 7 | < 6 | < 26 | < 7 | < 12 |
| | 05/03/18 | < 132 | < 55 | < 3 | < 3 | < 11 | < 4 | < 6 | < 4 | < 7 | < 11 | < 3 | < 4 | < 23 | < 7 | < 6 |
| | AVERAGE | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| *2S2 | 01/22/18 | < 143 | < 116 | < 7 | < 8 | < 19 | < 10 | < 14 | < 9 | < 14 | < 8 | < 7 | < 9 | < 27 | < 10 | < 14 |
| | 05/09/18 | < 132 | < 89 | < 5 | < 4 | < 12 | < 5 | < 10 | < 5 | < 9 | < 8 | < 4 | < 4 | < 22 | < 8 | < 9 |
| | AVERAGE | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 2S8 | 01/22/18 | < 140 | < 82 | < 10 | < 10 | < 27 | < 10 | < 24 | < 13 | < 15 | < 13 | < 13 | < 12 | < 34 | < 13 | < 26 |
| | 05/01/18 | < 143 | < 54 | < 3 | < 3 | < 7 | < 3 | < 6 | < 3 | < 5 | < 5 | < 3 | < 3 | < 15 | < 5 | < 5 |
| | 08/02/18 | < 140 | < 62 | < 6 | < 7 | < 17 | < 6 | < 12 | < 7 | < 13 | < 11 | < 6 | < 6 | < 31 | < 9 | < 15 |
| | 10/31/18 | < 148 | < 72 | < 6 | < 6 | < 15 | < 8 | < 13 | < 7 | < 10 | < 10 | < 6 | < 6 | < 29 | < 11 | < 12 |
| | AVERAGE | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| *4S4 | 01/22/18 | < 141 | < 151 | < 7 | < 7 | < 26 | < 11 | < 18 | < 10 | < 18 | < 10 | < 9 | < 10 | < 37 | < 14 | < 16 |
| | 05/03/18 | < 128 | < 43 | < 4 | < 4 | < 13 | < 4 | < 8 | < 4 | < 8 | < 11 | < 4 | < 4 | < 25 | < 10 | < 7 |
| | AVERAGE | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| *6S10 | 01/22/18 | < 146 | < 142 | < 5 | < 6 | < 13 | < 6 | < 10 | < 7 | < 10 | < 9 | < 6 | < 7 | < 23 | < 7 | < 11 |
| | 05/03/18 | < 131 | < 36 | < 5 | < 5 | < 11 | < 3 | < 9 | < 5 | < 10 | < 15 | < 4 | < 5 | < 30 | < 11 | < 8 |
| | AVERAGE | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| *11S2 | 01/22/18 | < 140 | < 112 | < 5 | < 8 | < 22 | < 8 | < 10 | < 6 | < 12 | < 9 | < 6 | < 9 | < 27 | < 10 | < 19 |
| | 05/03/18 | < 131 | < 36 | < 4 | < 4 | < 11 | < 4 | < 8 | < 4 | < 8 | < 13 | < 4 | < 4 | < 28 | < 9 | < 7 |
| | AVERAGE | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 13S7 | 01/26/18 | 151 ± 92 | < 124 | < 7 | < 8 | < 24 | < 8 | < 16 | < 8 | < 11 | < 11 | < 8 | < 7 | < 29 | < 11 | < 14 |
| | 04/30/18 | < 145 | < 13 | < 1 | < 1 | < 2 | < 1 | < 2 | < 1 | < 1 | < 2 | < 1 | < 1 | < 5 | < 2 | < 2 |
| | 07/30/18 | < 149 | < 48 | < 4 | < 5 | < 14 | < 4 | < 8 | < 4 | < 8 | < 10 | < 4 | < 3 | < 23 | < 8 | < 9 |
| | 10/30/18 | < 150 | < 56 | < 7 | < 7 | < 18 | < 8 | < 13 | < 6 | < 11 | < 12 | < 6 | < 6 | < 31 | < 11 | < 13 |
| | AVERAGE | 151 ± 0 | - | - | - | - | - | - | - | - | - | - | - | - | - | - |

*Station was discontinued as of 05/30/18.

**TABLE C-6 TRITIUM AND GAMMA SPECTROSCOPIC ANALYSES OF GROUNDWATER
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in pCi/Liter ± 2 sigma

| SITE | COLLECTION DATE | <-----GAMMA EMITTERS-----> | | | | | | | | | | | | | | |
|-------|-----------------|----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|--------|
| | | H-3 | K-40 | Mn-54 | Co-58 | Fe-59 | Co-60 | Zn-65 | Nb-95 | Zr-95 | I-131 | Cs-134 | Cs-137 | Ba-140 | La-140 | Th-228 |
| 1S3 | 01/26/18 | 354 ± 103 | < 141 | < 7 | < 7 | < 19 | < 7 | < 14 | < 9 | < 12 | < 11 | < 7 | < 7 | < 36 | < 13 | < 13 |
| | 04/30/18 | 161 ± 94 | < 34 | < 3 | < 4 | < 10 | < 4 | < 6 | < 4 | < 6 | < 8 | < 3 | < 3 | < 22 | < 7 | < 7 |
| | 07/30/18 | 220 ± 97 | < 104 | < 5 | < 5 | < 15 | < 5 | < 11 | < 6 | < 10 | < 10 | < 5 | < 5 | < 27 | < 8 | < 10 |
| | 10/30/18 | < 150 | < 44 | < 5 | < 6 | < 13 | < 5 | < 12 | < 5 | < 10 | < 8 | < 5 | < 5 | < 24 | < 8 | < 9 |
| | AVERAGE | 245 ± 198 | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 4S8 | 01/26/18 | 280 ± 97 | < 153 | < 10 | < 10 | < 23 | < 9 | < 18 | < 10 | < 15 | < 14 | < 9 | < 9 | < 43 | < 15 | < 17 |
| | 04/30/18 | 169 ± 97 | < 32 | < 5 | < 6 | < 15 | < 6 | < 9 | < 6 | < 10 | < 12 | < 5 | < 6 | < 24 | < 10 | < 10 |
| | 07/30/18 | 198 ± 96 | < 42 | < 5 | < 5 | < 15 | < 5 | < 8 | < 5 | < 8 | < 10 | < 5 | < 6 | < 27 | < 10 | < 11 |
| | 10/30/18 | < 149 | < 48 | < 6 | < 5 | < 14 | < 4 | < 11 | < 6 | < 8 | < 9 | < 5 | < 5 | < 26 | < 8 | < 9 |
| | AVERAGE | 216 ± 115 | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 4S9 | 01/25/18 | 194 ± 93 | < 104 | < 5 | < 6 | < 18 | < 7 | < 14 | < 7 | < 12 | < 9 | < 6 | < 7 | < 34 | < 10 | < 12 |
| | 04/27/18 | < 146 | < 24 | < 2 | < 3 | < 7 | < 3 | < 6 | < 3 | < 5 | < 11 | < 3 | < 3 | < 20 | < 7 | < 5 |
| | 07/27/18 | < 148 | < 51 | < 3 | < 3 | < 10 | < 4 | < 6 | < 4 | < 6 | < 9 | < 3 | < 3 | < 20 | < 7 | < 6 |
| | 10/29/18 | < 128 | < 64 | < 6 | < 5 | < 21 | < 6 | < 12 | < 7 | < 10 | < 10 | < 6 | < 5 | < 30 | < 10 | < 11 |
| | AVERAGE | 194 ± 0 | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 6S11A | 02/01/18 | < 145 | < 122 | < 5 | < 6 | < 16 | < 5 | < 13 | < 5 | < 11 | < 10 | < 5 | < 6 | < 28 | < 10 | < 13 |
| | 05/02/18 | < 142 | < 122 | < 6 | < 6 | < 13 | < 6 | < 12 | < 6 | < 11 | < 12 | < 6 | < 5 | < 31 | < 10 | < 13 |
| | 08/02/18 | < 148 | < 136 | < 5 | < 6 | < 18 | < 7 | < 13 | < 7 | < 12 | < 11 | < 7 | < 7 | < 29 | < 13 | < 13 |
| | 10/31/18 | < 127 | < 55 | < 6 | < 5 | < 18 | < 6 | < 12 | < 7 | < 10 | < 9 | < 6 | < 6 | < 24 | < 10 | < 12 |
| | AVERAGE | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 6S12 | 02/08/18 | < 146 | < 61 | < 8 | < 10 | < 25 | < 13 | < 18 | < 9 | < 18 | < 11 | < 9 | < 10 | < 33 | < 9 | < 18 |
| | 05/01/18 | < 147 | < 26 | < 3 | < 3 | < 8 | < 3 | < 5 | < 3 | < 4 | < 6 | < 3 | < 3 | < 14 | < 5 | 9 ± 4 |
| | 07/26/18 | < 145 | < 100 | < 4 | < 5 | < 13 | < 4 | < 10 | < 5 | < 8 | < 15 | < 4 | < 4 | < 36 | < 9 | < 7 |
| | 10/29/18 | < 149 | < 120 | < 6 | < 6 | < 20 | < 6 | < 12 | < 7 | < 12 | < 12 | < 5 | < 5 | < 29 | < 11 | < 12 |
| | AVERAGE | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 7S10 | 01/29/18 | 176 ± 94 | < 161 | < 9 | < 8 | < 17 | < 9 | < 20 | < 11 | < 16 | < 10 | < 9 | < 8 | < 33 | < 13 | < 19 |
| | 04/27/18 | < 145 | < 17 | < 1 | < 1 | < 2 | < 1 | < 1 | < 1 | < 1 | < 2 | < 1 | < 1 | < 5 | < 2 | < 1 |
| | 07/31/18 | < 138 | < 60 | < 6 | < 5 | < 16 | < 7 | < 15 | < 7 | < 10 | < 12 | < 6 | < 6 | < 32 | < 9 | < 12 |
| | 11/01/18 | < 130 | < 154 | < 8 | < 7 | < 15 | < 8 | < 15 | < 8 | < 14 | < 13 | < 7 | < 8 | < 33 | < 15 | < 14 |
| | AVERAGE | 176 ± 0 | - | - | - | - | - | - | - | - | - | - | - | - | - | - |

**TABLE C-6 TRITIUM AND GAMMA SPECTROSCOPIC ANALYSES OF GROUNDWATER
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in pCi/Liter ± 2 sigma

| SITE | COLLECTION DATE | H-3 | <-----GAMMA EMITTERS-----> | | | | | | | | | | | | | |
|------|--------------------|----------|----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|--------|
| | | | K-40 | Mn-54 | Co-58 | Fe-59 | Co-60 | Zn-65 | Nb-95 | Zr-95 | I-131 | Cs-134 | Cs-137 | Ba-140 | La-140 | Th-228 |
| 7S11 | 01/29/18 | 147 ± 91 | < 65 | < 8 | < 9 | < 22 | < 8 | < 18 | < 8 | < 12 | < 11 | < 9 | < 9 | < 31 | < 11 | < 17 |
| | 04/27/18 | < 144 | < 52 | < 3 | < 3 | < 10 | < 3 | < 6 | < 3 | < 6 | < 12 | < 3 | < 3 | < 26 | < 9 | < 6 |
| | 07/31/18 | < 143 | < 109 | < 5 | < 5 | < 14 | < 6 | < 10 | < 4 | < 10 | < 11 | < 5 | < 7 | < 30 | < 11 | < 12 |
| | 11/01/18 | < 149 | < 91 | < 8 | < 6 | < 13 | < 7 | < 18 | < 6 | < 10 | < 9 | < 6 | < 9 | < 29 | < 12 | < 13 |
| | AVERAGE | 147 ± 0 | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 8S4 | 01/26/18 | 155 ± 95 | < 50 | < 7 | < 7 | < 16 | < 4 | < 16 | < 6 | < 9 | < 9 | < 5 | < 8 | < 31 | < 9 | < 12 |
| | 04/30/18 | < 144 | < 47 | < 5 | < 5 | < 14 | < 6 | < 11 | < 6 | < 10 | < 12 | < 4 | < 5 | < 28 | < 9 | < 10 |
| | 07/30/18 | < 148 | < 71 | < 6 | < 5 | < 16 | < 7 | < 13 | < 6 | < 12 | < 12 | < 6 | < 7 | < 34 | < 12 | < 11 |
| | 10/30/18 | < 150 | < 67 | < 5 | < 5 | < 13 | < 4 | < 9 | < 4 | < 8 | < 8 | < 4 | < 4 | < 24 | < 7 | < 9 |
| | AVERAGE | 155 ± 0 | - | - | - | - | - | - | - | - | - | - | - | - | - | - |

TABLE C-7

**ANNUAL AVERAGE TRITIUM CONCENTRATION IN PRECIPITATION,
MONITORING WELLS AND LAKE TOOK-A-WHILE (LTAW) SURFACE WATER DATA
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in pCi/Liter ± 2 sigma

| SITE | 2008 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 |
|---|---------------|---------------|---------------|----------|----------|----------|----------|----------|----------|----------|----------|
| Precip Sites 3S2, 12S1, 8G1 (offsite, controls) | 62* | 49 | 40 | 38 | 82 | 63 | 51 | 39 | 45 | 32 | 45 |
| Precip Sites 1 and 2 (onsite, East of Station Reactor Bldgs) | 370 | 230* | 193 | 216 | 242 | 182 | 142 | 250 | 206 | 251 | 325 |
| Precipitation Sites 3 and 4 (onsite, West of Station Reactor Bldgs) | 414 | 404* | 350 | 233 | 169 | 151 | 231 | 258 | 197 | 383 | 494 |
| 1S3 - MW-1 (43') | 248 | 150 | 252 | 131 | 164 | 197 | 115 | 169 | 175 | 130 | 218 |
| 4S8 - MW-2 (45') | 292 | 154 | 190 | 173 | 137 | 202 | 187 | 138 | 154 | 138 | 191 |
| 4S9 - MW-3 (94') | 127 | 54 | 150 | 64 | 80 | 135 | 94 | 180 | 125 | 55 | 109 |
| 8S4 - MW-4 (111') | 172 | 66 | 105 | 68 | 81 | 109 | 60 | 162 | 145 | 91 | 102 |
| 7S10 - MW-5 (36') | 171 | 69 | 96 | -6 | 74 | 106 | 68 | 70 | 73 | 51 | 93 |
| 13S7 - MW-6 (16') | 142 | 134 | 143 | 34 | 80 | 111 | 71 | 79 | 111 | 107 | 122 |
| 2S8 - MW-7 (85') | Not installed | Not installed | Not installed | 22 | 54 | 72 | 70 | 70 | 74 | 56 | 37 |
| 6S11A - MW-8A (14') | 177 | 82 | 165 | 58 | 15 | 72 | 103 | 110 | 63 | 38 | 50 |
| 6S11B - MW-8B (19') | Dry well | Dry well | Dry well | Dry well | Dry well | Dry well | Dry well | Dry well | Dry well | Dry well | Dry well |
| 6S12 - MW-9 (28') | 30 | -44 | 45 | 18 | 6 | 60 | 21 | 57 | 70 | 5 | 27 |
| 7S11 - MW-10 (132') | 3 | -27 | -9 | 1 | -1 | 23 | 29 | 55 | 13 | 1 | 33 |
| **12F3 - Groundwater Control | 26 | -53 | -2 | 5 | -6 | 45 | -26 | 20 | 41 | 61 | 82 |
| **LTAW - Surface Water | 179 | 104 | 110 | 132 | 132 | 145 | 27 | 73 | 89 | 77 | 135 |

* Revised values to reflect full scope of precipitation data.

** Station was discontinued after 5/30/18.

**TABLE C-8 GROSS BETA, TRITIUM AND GAMMA SPECTROSCOPIC ANALYSES OF DRINKING WATER
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in pCi/Liter ± 2 sigma

| SITE | COLLECTION PERIOD | | Gr-B | H-3 | <-----GAMMA EMITTERS-----> | | | | | | | | | | | | |
|------|-------------------|------------|-----------|-------|----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|
| | START | STOP | | | K-40 | Mn-54 | Co-58 | Fe-59 | Co-60 | Zn-65 | Nb-95 | Zr-95 | I-131 | Cs-134 | Cs-137 | Ba-140 | La-140 |
| 12H2 | 12/26/17 | - 01/23/18 | < 2.0 | < 143 | < 22 | < 2 | < 3 | < 8 | < 3 | < 4 | < 3 | < 5 | < 9 | < 2 | < 2 | < 20 | < 6 |
| 12H2 | 01/23/18 | - 02/27/18 | < 2.1 | < 130 | < 14 | < 2 | < 2 | < 6 | < 2 | < 3 | < 2 | < 3 | < 12 | < 2 | < 2 | < 19 | < 6 |
| 12H2 | 02/27/18 | - 03/27/18 | < 1.8 | < 137 | < 17 | < 2 | < 2 | < 6 | < 2 | < 4 | < 2 | < 4 | < 11 | < 2 | < 2 | < 19 | < 6 |
| 12H2 | 03/27/18 | - 04/24/18 | < 2.1 | < 145 | < 13 | < 1 | < 1 | < 5 | < 1 | < 3 | < 2 | < 3 | < 14 | < 1 | < 1 | < 19 | < 5 |
| 12H2 | 04/24/18 | - 05/29/18 | < 2.1 | < 137 | < 42 | < 2 | < 2 | < 8 | < 2 | < 4 | < 2 | < 4 | < 15 | < 2 | < 2 | < 24 | < 10 |
| 12H2 | 05/29/18 | - 06/26/18 | 2.4 ± 1.4 | < 143 | < 29 | < 2 | < 2 | < 5 | < 2 | < 3 | < 2 | < 3 | < 9 | < 1 | < 2 | < 16 | < 6 |
| 12H2 | 06/26/18 | - 07/24/18 | 2.8 ± 1.6 | < 138 | < 13 | < 1 | < 2 | < 5 | < 1 | < 3 | < 2 | < 3 | < 9 | < 1 | < 1 | < 14 | < 5 |
| 12H2 | 07/24/18 | - 08/28/18 | < 2.0 | < 144 | < 33 | < 2 | < 2 | < 6 | < 2 | < 4 | < 2 | < 3 | < 15 | < 2 | < 2 | < 22 | < 8 |
| 12H2 | 08/28/18 | - 09/25/18 | 3.3 ± 1.4 | < 137 | < 38 | < 2 | < 3 | < 7 | < 3 | < 4 | < 3 | < 5 | < 14 | < 2 | < 2 | < 26 | < 8 |
| 12H2 | 09/25/18 | - 10/23/18 | < 1.9 | < 149 | < 50 | < 3 | < 3 | < 6 | < 3 | < 6 | < 3 | < 5 | < 14 | < 3 | < 3 | < 26 | < 9 |
| 12H2 | 10/23/18 | - 11/27/18 | 2.2 ± 1.3 | < 149 | < 15 | < 2 | < 2 | < 5 | < 2 | < 4 | < 2 | < 3 | < 13 | < 2 | < 2 | < 21 | < 7 |
| 12H2 | 11/27/18 | - 12/31/18 | < 2.0 | < 141 | < 33 | < 2 | < 2 | < 7 | < 2 | < 4 | < 2 | < 3 | < 13 | < 2 | < 2 | < 20 | < 9 |
| | | AVERAGE | 2.7 ± 1.0 | - | - | - | - | - | - | - | - | - | - | - | - | - | - |

TABLE C-9

**GAMMA SPECTROSCOPIC ANALYSES OF FOOD PRODUCTS (FRUITS, VEGETABLES AND BROADLEAF)
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in pCi/kg (wet) \pm 2 sigma

| SITE | COLLECTION DATE | Be-7 | K-40 | I-131 | Cs-134 | Cs-137 | Ac-228 | Th-228 |
|------|-----------------|----------------|------------------|------------------|--------|--------|--------|--------|
| 8G1 | 06/25/18 | 246 \pm 106 | 2599 \pm 398 | < 22 | < 17 | < 17 | < 58 | < 33 |
| | 06/25/18 | < 151 | 4503 \pm 440 | < 22 | < 15 | < 14 | < 71 | < 33 |
| | 06/25/18 | < 198 | 4927 \pm 582 | < 24 | < 17 | < 21 | < 71 | < 32 |
| | 07/23/18 | 338 \pm 198 | 3974 \pm 435 | < 26 | < 18 | < 18 | < 72 | < 38 |
| | 07/23/18 | < 317 | 3910 \pm 531 | < 44 | < 47 | < 31 | < 142 | < 67 |
| | 07/23/18 | 408 \pm 201 | 2975 \pm 643 | < 35 | < 17 | < 28 | < 79 | < 44 |
| | 08/27/18 | 667 \pm 346 | 4926 \pm 628 | < 56 | < 29 | < 32 | < 127 | < 54 |
| | 08/27/18 | 796 \pm 185 | 3551 \pm 497 | < 47 | < 25 | < 27 | < 111 | < 44 |
| | 08/27/18 | 850 \pm 253 | 4630 \pm 634 | < 36 | < 22 | < 15 | < 99 | < 40 |
| | 09/17/18 | 357 \pm 145 | 2787 \pm 346 | < 31 | < 16 | < 17 | < 81 | < 35 |
| | 09/17/18 | 452 \pm 196 | 3684 \pm 612 | < 45 | < 23 | < 26 | < 111 | < 44 |
| | 09/17/18 | 706 \pm 190 | 3504 \pm 494 | < 42 | < 17 | < 22 | < 78 | < 34 |
| | 10/15/18 | 478 \pm 212 | 3314 \pm 536 | < 48 | < 19 | < 30 | < 82 | < 39 |
| | 10/15/18 | < 239 | 3927 \pm 532 | < 49 | < 24 | < 27 | < 85 | < 37 |
| | 10/15/18 | 642 \pm 216 | 4007 \pm 533 | < 50 | < 29 | < 29 | < 108 | < 49 |
| | | AVERAGE | 540 \pm 403 | 3815 \pm 1451 | - | - | - | - |
| 11D1 | 10/05/18 | < 166 | 1688 \pm 361 | < 55 | < 22 | < 23 | < 110 | < 37 |
| | 12/10/18 | < 246 | 3700 \pm 533 | < 54 | < 25 | < 28 | < 96 | < 40 |
| | 12/10/18 | < 297 | 16720 \pm 1053 | < 58 | < 35 | < 31 | < 132 | < 55 |
| | | AVERAGE | - | 7369 \pm 16320 | - | - | - | - |
| 11S6 | 06/25/18 | 313 \pm 156 | 2294 \pm 436 | < 25 | < 13 | < 21 | < 70 | < 32 |
| | 06/25/18 | < 166 | 5314 \pm 542 | < 23 | < 17 | < 20 | < 69 | < 33 |
| | 06/25/18 | < 163 | 4387 \pm 467 | < 20 | < 14 | < 20 | < 67 | < 26 |
| | 07/23/18 | 722 \pm 204 | 3857 \pm 553 | < 28 | < 23 | < 23 | < 69 | < 40 |
| | 07/23/18 | 593 \pm 309 | 4828 \pm 573 | < 35 | < 28 | < 27 | < 113 | < 55 |
| | 07/23/18 | 802 \pm 207 | 4105 \pm 475 | < 26 | < 19 | < 23 | < 77 | < 38 |
| | 08/27/18 | 1038 \pm 228 | 6022 \pm 579 | < 39 | < 23 | < 22 | < 87 | < 41 |
| | 08/27/18 | 782 \pm 221 | 5347 \pm 594 | < 34 | < 14 | < 19 | < 81 | < 35 |
| | 08/27/18 | < 200 | 3703 \pm 539 | < 39 | < 19 | < 20 | < 96 | < 39 |
| | 09/17/18 | 410 \pm 136 | 3091 \pm 433 | < 29 | < 14 | < 18 | < 69 | < 32 |
| | 09/17/18 | 762 \pm 185 | 5980 \pm 511 | < 38 | < 18 | < 18 | < 79 | < 34 |
| | 09/17/18 | 733 \pm 205 | 3962 \pm 456 | < 37 | < 21 | < 22 | < 93 | < 39 |
| | 10/15/18 | 414 \pm 177 | 2978 \pm 409 | < 52 | < 22 | < 22 | < 92 | < 40 |
| | 10/15/18 | < 147 | 4424 \pm 567 | < 40 | < 17 | < 18 | < 88 | < 33 |
| | 10/15/18 | 422 \pm 228 | 4015 \pm 548 | < 50 | < 20 | < 24 | < 97 | < 38 |
| | | AVERAGE | 635 \pm 445 | 4287 \pm 2153 | - | - | - | - |

TABLE C-9

**GAMMA SPECTROSCOPIC ANALYSES OF FOOD PRODUCTS (FRUITS, VEGETABLES AND BROADLEAF)
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in pCi/kg (wet) \pm 2 sigma

| SITE | COLLECTION DATE | Be-7 | K-40 | I-131 | Cs-134 | Cs-137 | Ac-228 | Th-228 |
|------|-----------------|---------------|-----------------|-------|--------|--------|--------|--------|
| 12F7 | 01/10/18 | < 198 | 3004 \pm 470 | < 29 | < 21 | < 27 | < 90 | < 45 |
| | AVERAGE | - | 3004 \pm 0 | - | - | - | - | - |
| 3S3 | 06/25/18 | < 158 | 2539 \pm 392 | < 26 | < 16 | < 21 | < 62 | < 27 |
| | 06/25/18 | < 231 | 4794 \pm 581 | < 30 | < 21 | < 26 | < 84 | < 39 |
| | 06/25/18 | < 194 | 3814 \pm 442 | < 28 | < 19 | < 23 | < 91 | < 36 |
| | 07/23/18 | 702 \pm 167 | 3492 \pm 485 | < 30 | < 24 | < 23 | < 82 | < 43 |
| | 07/23/18 | 567 \pm 278 | 4031 \pm 578 | < 30 | < 23 | < 27 | < 113 | < 36 |
| | 07/23/18 | 683 \pm 201 | 4493 \pm 503 | < 36 | < 35 | < 32 | < 119 | < 47 |
| | 08/27/18 | 639 \pm 207 | 4063 \pm 490 | < 37 | < 14 | < 20 | < 79 | < 34 |
| | 08/27/18 | 476 \pm 273 | 5928 \pm 678 | < 57 | < 27 | < 27 | < 110 | < 53 |
| | 08/27/18 | 495 \pm 141 | 4970 \pm 507 | < 28 | < 17 | < 18 | < 79 | < 34 |
| | 09/17/18 | 458 \pm 157 | 2286 \pm 417 | < 39 | < 18 | < 23 | < 80 | < 38 |
| | 09/17/18 | 395 \pm 173 | 4616 \pm 552 | < 38 | < 21 | < 25 | < 105 | < 43 |
| | 09/17/18 | 769 \pm 200 | 3470 \pm 492 | < 29 | < 19 | < 19 | < 74 | < 35 |
| | 10/15/18 | 386 \pm 160 | 3094 \pm 431 | < 51 | < 25 | < 27 | < 108 | < 44 |
| | 10/15/18 | 343 \pm 200 | 3654 \pm 543 | < 51 | < 24 | < 24 | < 105 | < 43 |
| | 10/15/18 | 471 \pm 226 | 3423 \pm 554 | < 47 | < 23 | < 26 | < 109 | < 45 |
| | AVERAGE | 532 \pm 276 | 3911 \pm 1906 | - | - | - | - | - |

TABLE C-10

TRITIUM AND GAMMA SPECTROSCOPIC ANALYSES OF SURFACE WATER
SUSQUEHANNA STEAM ELECTRIC STATION, 2018

Results in pCi/Liter ± 2 sigma

| SITE | COLLECTION PERIOD | H-3 | <-----GAMMA EMITTERS-----> | | | | | | | | | | | | | |
|-------|---------------------|-------------|----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|--------|
| | | | K-40 | Mn-54 | Co-58 | Fe-59 | Co-60 | Zn-65 | Nb-95 | Zr-95 | I-131 | Cs-134 | Cs-137 | Ba-140 | La-140 | Th-228 |
| 6S6 | 12/26/17 - 01/23/18 | < 143 | < 22 | < 2 | < 2 | < 6 | < 2 | < 4 | < 3 | < 4 | < 9 | < 2 | < 2 | < 18 | < 5 | < 4 |
| | 01/23/18 - 02/27/18 | < 130 | < 30 | < 2 | < 2 | < 6 | < 2 | < 4 | < 2 | < 4 | < 15 | < 2 | < 2 | < 21 | < 8 | 12 ± 3 |
| | 01/30/18 - 01/30/18 | < 134 | < 24 | < 1 | < 1 | < 3 | < 1 | < 1 | < 1 | < 2 | < 15 | < 1 | < 1 | < 16 | < 5 | < 2 |
| | 02/27/18 - 03/27/18 | < 137 | < 14 | < 1 | < 2 | < 5 | < 2 | < 3 | < 2 | < 3 | < 9 | < 1 | < 2 | < 16 | < 5 | < 3 |
| | 03/27/18 - 04/24/18 | < 146 | 47 ± 28 | < 1 | < 2 | < 4 | < 1 | < 3 | < 2 | < 3 | < 15 | < 1 | < 1 | < 22 | < 7 | < 3 |
| | 04/24/18 - 05/29/18 | < 142 | < 27 | < 1 | < 2 | < 6 | < 2 | < 3 | < 2 | < 3 | < 14 | < 2 | < 2 | < 21 | < 6 | < 4 |
| | 05/29/18 - 06/26/18 | < 144 | < 30 | < 1 | < 2 | < 5 | < 2 | < 3 | < 2 | < 3 | < 8 | < 1 | < 1 | < 14 | < 6 | < 2 |
| | 06/26/18 - 07/24/18 | < 142 | < 32 | < 2 | < 2 | < 5 | < 2 | < 3 | < 2 | < 3 | < 10 | < 2 | < 2 | < 17 | < 5 | < 4 |
| | 07/24/18 - 08/28/18 | < 150 | < 14 | < 2 | < 2 | < 6 | < 2 | < 3 | < 2 | < 3 | < 14 | < 1 | < 2 | < 22 | < 6 | < 3 |
| | 08/28/18 - 09/25/18 | < 148 | < 16 | < 2 | < 2 | < 5 | < 2 | < 3 | < 2 | < 4 | < 12 | < 2 | < 2 | < 20 | < 6 | < 3 |
| | 09/25/18 - 10/23/18 | < 130 | < 35 | < 2 | < 2 | < 7 | < 2 | < 4 | < 2 | < 4 | < 14 | < 2 | < 2 | < 23 | < 7 | < 3 |
| | 10/23/18 - 11/27/18 | < 149 | < 37 | < 2 | < 2 | < 6 | < 2 | < 3 | < 2 | < 3 | < 13 | < 1 | < 2 | < 19 | < 6 | < 3 |
| | 11/27/18 - 12/31/18 | < 139 | < 29 | < 2 | < 2 | < 7 | < 2 | < 3 | < 2 | < 3 | < 13 | < 1 | < 2 | < 21 | < 7 | < 3 |
| | AVERAGE | - | 47 ± 0 | - | - | - | - | - | - | - | - | - | - | - | - | 12 ± 0 |
| **5S9 | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| | AVERAGE | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 2S7 | 12/26/17 - 01/23/18 | 344 ± 109 | < 23 | < 2 | < 3 | < 7 | < 3 | < 5 | < 3 | < 5 | < 10 | < 2 | < 3 | < 21 | < 7 | < 5 |
| | 01/23/18 - 02/27/18 | 438 ± 108 | < 18 | < 2 | < 2 | < 7 | < 2 | < 3 | < 2 | < 4 | < 13 | < 1 | < 2 | < 21 | < 9 | 6 ± 3 |
| | 01/30/18 - 01/30/18 | < 137 | < 19 | < 1 | < 1 | < 3 | < 1 | < 1 | < 1 | < 2 | < 14 | < 1 | < 1 | < 13 | < 5 | < 2 |
| | 02/27/18 - 03/27/18 | 1140 ± 176 | < 25 | < 2 | < 2 | < 5 | < 2 | < 3 | < 2 | < 3 | < 10 | < 1 | < 2 | < 16 | < 5 | < 3 |
| | 03/27/18 - 04/24/18 | 6170 ± 674 | < 35 | < 1 | < 2 | < 6 | < 2 | < 3 | < 2 | < 3 | < 14 | < 2 | < 2 | < 22 | < 9 | < 3 |
| | 04/24/18 - 05/29/18 | 2890 ± 281 | < 10 | < 1 | < 1 | < 4 | < 1 | < 2 | < 1 | < 2 | < 14 | < 1 | < 1 | < 19 | < 6 | < 2 |
| | 05/29/18 - 06/26/18 | 204 ± 98 | < 35 | < 1 | < 2 | < 5 | < 2 | < 3 | < 2 | < 3 | < 9 | < 1 | < 2 | < 15 | < 5 | < 3 |
| | 06/26/18 - 07/24/18 | 190 ± 96 | < 18 | < 2 | < 2 | < 7 | < 2 | < 4 | < 2 | < 4 | < 12 | < 2 | < 2 | < 20 | < 6 | < 4 |
| | 07/24/18 - 08/28/18 | 2890 ± 276 | < 13 | < 2 | < 2 | < 5 | < 2 | < 3 | < 2 | < 3 | < 13 | < 1 | < 1 | < 20 | < 7 | < 2 |
| | 08/28/18 - 09/25/18 | 3950 ± 357 | < 9 | < 1 | < 1 | < 3 | < 1 | < 2 | < 1 | < 2 | < 6 | < 1 | < 1 | < 11 | < 3 | < 2 |
| | 09/25/18 - 10/23/18 | 592 ± 125 | < 38 | < 2 | < 2 | < 8 | < 2 | < 5 | < 2 | < 5 | < 15 | < 2 | < 2 | < 24 | < 8 | 6 ± 3 |
| | 10/23/18 - 11/27/18 | 221 ± 102 | < 32 | < 2 | < 2 | < 5 | < 2 | < 3 | < 2 | < 3 | < 13 | < 2 | < 2 | < 20 | < 7 | < 3 |
| | 11/27/18 - 12/31/18 | 354 ± 100 | < 14 | < 2 | < 2 | < 5 | < 2 | < 3 | < 2 | < 3 | < 15 | < 2 | < 2 | < 22 | < 6 | < 4 |
| | AVERAGE | 1615 ± 3874 | - | - | - | - | - | - | - | - | - | - | - | - | - | 6 ± 0 |
| 6S5 | 01/02/18 - 01/23/18 | < 144 | < 55 | < 3 | < 3 | < 9 | < 3 | < 6 | < 3 | < 6 | < 8 | < 3 | < 3 | < 19 | < 6 | < 5 |
| | 01/30/18 - 02/27/18 | < 133 | < 40 | < 2 | < 2 | < 6 | < 2 | < 4 | < 3 | < 5 | < 14 | < 2 | < 2 | < 24 | < 8 | < 4 |
| | 03/06/18 - 03/27/18 | < 137 | < 21 | < 2 | < 3 | < 7 | < 2 | < 5 | < 3 | < 4 | < 10 | < 2 | < 2 | < 19 | < 6 | < 4 |
| | 04/03/18 - 04/24/18 | < 148 | < 16 | < 2 | < 2 | < 6 | < 2 | < 4 | < 2 | < 3 | < 13 | < 2 | < 2 | < 20 | < 6 | < 3 |
| | 05/01/18 - 05/29/18 | < 147 | 45 ± 26 | < 2 | < 2 | < 6 | < 2 | < 4 | < 2 | < 4 | < 13 | < 2 | < 2 | < 21 | < 7 | < 3 |
| | 06/05/18 - 06/26/18 | < 147 | < 22 | < 1 | < 1 | < 4 | < 1 | < 3 | < 1 | < 3 | < 6 | < 1 | < 1 | < 11 | < 4 | < 2 |

TABLE C-10

TRITIUM AND GAMMA SPECTROSCOPIC ANALYSES OF SURFACE WATER
SUSQUEHANNA STEAM ELECTRIC STATION, 2018

Results in pCi/Liter ± 2 sigma

| SITE | COLLECTION PERIOD | H-3 | <-----GAMMA EMITTERS-----> | | | | | | | | | | | | | |
|----------|---------------------|-----------|----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|--------|
| | | | K-40 | Mn-54 | Co-58 | Fe-59 | Co-60 | Zn-65 | Nb-95 | Zr-95 | I-131 | Cs-134 | Cs-137 | Ba-140 | La-140 | Th-228 |
| 6S5 | 07/02/18 - 07/24/18 | < 145 | < 14 | < 2 | < 2 | < 5 | < 2 | < 3 | < 2 | < 3 | < 7 | < 1 | < 2 | < 13 | < 4 | < 3 |
| (cont'd) | 07/31/18 - 08/28/18 | 210 ± 94 | < 21 | < 2 | < 2 | < 7 | < 2 | < 5 | < 2 | < 4 | < 14 | < 2 | < 2 | < 23 | < 8 | < 4 |
| | 09/04/18 - 09/25/18 | < 143 | < 17 | < 2 | < 2 | < 6 | < 2 | < 4 | < 2 | < 4 | < 9 | < 2 | < 2 | < 17 | < 5 | < 3 |
| | 10/02/18 - 10/23/18 | < 150 | < 34 | < 2 | < 2 | < 6 | < 2 | < 4 | < 2 | < 4 | < 9 | < 2 | < 2 | < 18 | < 6 | < 4 |
| | 10/30/18 - 11/27/18 | < 145 | < 31 | < 2 | < 2 | < 7 | < 2 | < 4 | < 2 | < 4 | < 11 | < 2 | < 2 | < 19 | < 6 | < 3 |
| | 12/04/18 - 12/31/18 | < 142 | < 24 | < 2 | < 3 | < 10 | < 4 | < 6 | < 3 | < 6 | < 14 | < 3 | < 3 | < 28 | < 11 | < 5 |
| | AVERAGE | 210 ± 0 | 45 ± 0 | - | - | - | - | - | - | - | - | - | - | - | - | - |
| *4S7 | 02/15/18 - 02/15/18 | 390 ± 100 | < 66 | < 8 | < 7 | < 27 | < 7 | < 15 | < 6 | < 14 | < 12 | < 8 | < 8 | < 39 | < 13 | < 12 |
| | 05/03/18 - 05/03/18 | 187 ± 87 | < 85 | < 4 | < 4 | < 13 | < 5 | < 10 | < 4 | < 8 | < 10 | < 3 | < 4 | < 27 | < 10 | < 6 |
| | AVERAGE | 289 ± 287 | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| *LTAW | 02/15/18 - 02/15/18 | < 149 | 101 ± 42 | < 6 | < 7 | < 20 | < 7 | < 14 | < 9 | < 14 | < 15 | < 8 | < 8 | < 39 | < 9 | < 14 |
| | 05/03/18 - 05/03/18 | < 143 | < 97 | < 4 | < 4 | < 10 | < 4 | < 7 | < 4 | < 7 | < 13 | < 4 | < 4 | < 32 | < 8 | < 8 |
| | AVERAGE | - | 101 ± 0 | - | - | - | - | - | - | - | - | - | - | - | - | - |
| *5S12 | 02/15/18 - 02/15/18 | < 143 | < 141 | < 8 | < 6 | < 19 | < 7 | < 14 | < 7 | < 9 | < 13 | < 5 | < 6 | < 30 | < 14 | < 13 |
| | 05/03/18 - 05/03/18 | < 143 | < 43 | < 4 | < 4 | < 10 | < 5 | < 10 | < 5 | < 8 | < 11 | < 4 | < 5 | < 29 | < 8 | < 8 |
| | AVERAGE | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| *7S12 | 02/15/18 - 02/15/18 | < 150 | < 115 | < 6 | < 6 | < 13 | < 7 | < 11 | < 7 | < 13 | < 12 | < 6 | < 6 | < 34 | < 8 | < 12 |
| | 05/03/18 - 05/03/18 | 169 ± 86 | < 58 | < 4 | < 4 | < 12 | < 3 | < 6 | < 4 | < 7 | < 10 | < 4 | < 4 | < 22 | < 8 | < 8 |
| | AVERAGE | 169 ± 0 | - | - | - | - | - | - | - | - | - | - | - | - | - | - |

* Station was discontinued after 5/30/18.
** No samples taken from station in 2018.

TABLE C-11

GAMMA SPECTROSCOPIC ANALYSIS OF FISH
SUSQUEHANNA STEAM ELECTRIC STATION, 2018

Results in pCi/kg (wet) ± 2 sigma

| SITE | COLLECTION DATE | K-40 | Mn-54 | Co-58 | Fe-59 | Co-60 | Zn-65 | Cs-134 | Cs-137 |
|--------------------|-----------------|-------------|-------|-------|-------|-------|-------|--------|--------|
| 2H | | | | | | | | | |
| Channel Catfish | 05/10/18 | 3059 ± 690 | < 49 | < 32 | < 142 | < 62 | < 94 | < 52 | < 44 |
| Smallmouth Bass | 05/10/18 | 3387 ± 1208 | < 79 | < 69 | < 162 | < 99 | < 163 | < 77 | < 91 |
| Shorthead Redhorse | 05/10/18 | 4598 ± 978 | < 53 | < 59 | < 158 | < 41 | < 93 | < 48 | < 58 |
| Walleye | 10/19/18 | 3693 ± 1079 | < 78 | < 58 | < 230 | < 54 | < 148 | < 62 | < 63 |
| Shorthead Redhorse | 10/19/18 | 2913 ± 811 | < 61 | < 59 | < 113 | < 45 | < 116 | < 47 | < 56 |
| Smallmouth Bass | 10/19/18 | 3453 ± 951 | < 67 | < 79 | < 155 | < 61 | < 148 | < 61 | < 65 |
| | AVERAGE | 3517 ± 1198 | - | - | - | - | - | - | - |
| IND | | | | | | | | | |
| Channel Catfish | 05/09/18 | 3440 ± 877 | < 40 | < 50 | < 171 | < 43 | < 71 | < 45 | < 39 |
| Shorthead Redhorse | 05/09/18 | 5034 ± 1033 | < 61 | < 63 | < 168 | < 45 | < 123 | < 61 | < 67 |
| Smallmouth Bass | 05/09/18 | 3009 ± 1066 | < 62 | < 58 | < 178 | < 62 | < 149 | < 70 | < 67 |
| Smallmouth Bass | 10/18/18 | 2988 ± 812 | < 47 | < 36 | < 119 | < 67 | < 91 | < 49 | < 44 |
| Walleye | 10/18/18 | 2666 ± 1286 | < 93 | < 76 | < 215 | < 68 | < 168 | < 84 | < 99 |
| Shorthead Redhorse | 10/18/18 | 3730 ± 1008 | < 62 | < 57 | < 203 | < 75 | < 158 | < 58 | < 62 |
| | AVERAGE | 3478 ± 1698 | - | - | - | - | - | - | - |
| LTAW | | | | | | | | | |
| Rainbow Trout | 10/19/18 | 3911 ± 1003 | < 87 | < 77 | < 249 | < 65 | < 145 | < 76 | < 91 |
| Largemouth Bass | 10/19/18 | 3996 ± 1128 | < 80 | < 76 | < 220 | < 78 | < 205 | < 80 | < 89 |
| | AVERAGE | 3954 ± 120 | - | - | - | - | - | - | - |


TABLE C-12

**GAMMA SPECTROSCOPIC ANALYSES OF SHORELINE SEDIMENT
SUSQUEHANNA STEAM ELECTRIC STATION, 2018**

Results in pCi/kg (dry) \pm 2 sigma

| SITE | COLLECTION DATE | K-40 | Cs-134 | Cs-137 | Ra-226 | Ac-228 | Th-228 |
|------|-----------------|------------------|--------|--------|-----------------|----------------|----------------|
| 2B | 04/24/18 | 10830 \pm 1157 | < 44 | < 57 | 1547 \pm 959 | 912 \pm 238 | 956 \pm 89 |
| | 10/25/18 | 14350 \pm 2345 | < 140 | < 151 | < 2999 | 1184 \pm 421 | 1429 \pm 238 |
| | AVERAGE | 12590 \pm 4978 | - | - | 1547 \pm 0 | 1048 \pm 385 | 1193 \pm 668 |
| 7B | 04/24/18 | 8009 \pm 1007 | < 44 | < 62 | 1686 \pm 980 | 796 \pm 203 | 832 \pm 87 |
| | 10/25/18 | 10320 \pm 1396 | < 70 | < 91 | 2800 \pm 1269 | 913 \pm 300 | 965 \pm 143 |
| | AVERAGE | 9165 \pm 3268 | - | - | 2243 \pm 1575 | 855 \pm 166 | 899 \pm 188 |
| 12F | 04/24/18 | 7801 \pm 781 | < 49 | < 55 | 1524 \pm 778 | 605 \pm 193 | 776 \pm 67 |
| | 10/25/18 | 7160 \pm 1700 | < 115 | < 108 | < 2656 | 1024 \pm 485 | 880 \pm 182 |
| | AVERAGE | 7481 \pm 907 | - | - | 1524 \pm 0 | 814 \pm 593 | 828 \pm 147 |

FIGURE C-1 - GROSS BETA ACTIVITY IN AIR PARTICULATES



**FIGURE C-2 - AMBIENT RADIATION LEVELS
BASED ON ENVIRONMENTAL DOSIMETRY DATA**




FIGURE C-3 - IODINE-131 ACTIVITY IN MILK




FIGURE C-4 - ANNUAL AVERAGE TRITIUM ACTIVITY IN PRECIPITATION AND SURFACE WATER VERSUS GROUND WATER




FIGURE C-5 - GROSS BETA ACTIVITY IN DRINKING WATER





FIGURE C-6 - TRITIUM ACTIVITY IN SURFACE WATER



Intentionally left blank

APPENDIX D

SUMMARY OF RESULTS FROM ANALYTICS, ENVIRONMENTAL RESOURCE ASSOCIATES (ERA), AND DEPARTMENT OF ENERGY (DOE) – MIXED ANALYTE PERFORMANCE EVALUATION PROGRAM (MAPEP)

**Table D-1 Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering Environmental Services**

| Month/Year | Identification Number | Matrix | Nuclide | Units | TBE Reported Value | Known Value ^(a) | Ratio of TBE to Analytics Result | Evaluation ^(b) | | |
|------------|-----------------------|--------|---------|----------|--------------------|----------------------------|----------------------------------|---------------------------|------|---|
| March 2018 | E12133 | Milk | Sr-89 | pCi/L | 76.1 | 90.1 | 0.84 | A | | |
| | | | Sr-90 | pCi/L | 12.2 | 12.5 | 0.98 | A | | |
| | E12134 | Milk | Ce-141 | pCi/L | 77.8 | 77.0 | 1.01 | A | | |
| | | | Co-58 | pCi/L | 105 | 114 | 0.92 | A | | |
| | | | Co-60 | pCi/L | 181 | 187 | 0.97 | A | | |
| | | | Cr-51 | pCi/L | 298 | 326 | 0.92 | A | | |
| | | | Cs-134 | pCi/L | 150 | 180 | 0.84 | A | | |
| | | | Cs-137 | pCi/L | 164 | 172 | 0.95 | A | | |
| | | | Fe-59 | pCi/L | 140 | 139 | 1.01 | A | | |
| | | | I-131 | pCi/L | 105 | 108.0 | 0.97 | A | | |
| | | | Mn-54 | pCi/L | 133 | 131 | 1.01 | A | | |
| | | | Zn-65 | pCi/L | 242 | 244 | 0.99 | A | | |
| | | | E12135 | Charcoal | I-131 | pCi | 93.7 | 95.4 | 0.98 | A |
| | | | E12136 | AP | Ce-141 | pCi | 92.6 | 85.3 | 1.09 | A |
| Co-58 | pCi | 130 | | | 126 | 1.03 | A | | | |
| Co-60 | pCi | 237 | | | 207 | 1.14 | A | | | |
| Cr-51 | pCi | 411 | | | 361 | 1.14 | A | | | |
| Cs-134 | pCi | 194 | | | 199 | 0.98 | A | | | |
| Cs-137 | pCi | 200 | | | 191 | 1.05 | A | | | |
| Fe-59 | pCi | 160 | | | 154 | 1.04 | A | | | |
| Mn-54 | pCi | 152 | | | 145 | 1.05 | A | | | |
| Zn-65 | pCi | 267 | | | 271 | 0.99 | A | | | |
| E12137 | Water | Fe-55 | pCi/L | 1990 | 1700 | 1.17 | A | | | |
| E12138 | Soil | Ce-141 | pCi/g | 0.148 | 0.118 | 1.26 | W | | | |
| | | Co-58 | pCi/g | 0.171 | 0.174 | 0.98 | A | | | |
| | | Co-60 | pCi/g | 0.297 | 0.286 | 1.04 | A | | | |
| | | Cr-51 | pCi/g | 0.537 | 0.498 | 1.08 | A | | | |
| | | Cs-134 | pCi/g | 0.274 | 0.275 | 1.00 | A | | | |
| | | Cs-137 | pCi/g | 0.355 | 0.337 | 1.05 | A | | | |
| | | Fe-59 | pCi/g | 0.243 | 0.212 | 1.15 | A | | | |
| | | Mn-54 | pCi/g | 0.228 | 0.201 | 1.14 | A | | | |
| Zn-65 | pCi/g | 0.395 | 0.374 | 1.06 | A | | | | | |

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

**Table D-1 Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering Environmental Services**

| Month/Year | Identification Number | Matrix | Nuclide | Units | TBE Reported Value | Known Value ^(a) | Ratio of TBE to Analytics Result | Evaluation ^(b) | | | |
|------------|-----------------------|--------|-----------|--------|--------------------|----------------------------|----------------------------------|---------------------------|------|------|---|
| June 2018 | E12205 | Milk | Sr-89 | pCi/L | 74.9 | 84.6 | 0.89 | A | | | |
| | | | Sr-90 | pCi/L | 10.5 | 11.4 | 0.92 | A | | | |
| June 2018 | E12206 | Milk | Ce-141 | pCi/L | 89.2 | 82.2 | 1.08 | A | | | |
| | | | Co-58 | pCi/L | 94.8 | 89 | 1.07 | A | | | |
| | | | Co-60 | pCi/L | 125 | 113 | 1.10 | A | | | |
| | | | Cr-51 | pCi/L | 256 | 239 | 1.07 | A | | | |
| | | | Cs-134 | pCi/L | 112 | 114 | 0.99 | A | | | |
| | | | Cs-137 | pCi/L | 107 | 98.8 | 1.08 | A | | | |
| | | | Fe-59 | pCi/L | 95.9 | 86.0 | 1.12 | A | | | |
| | | | I-131 | pCi/L | 69.8 | 71.9 | 0.97 | A | | | |
| | | | Mn-54 | pCi/L | 138 | 130 | 1.06 | A | | | |
| | | | Zn-65 | pCi/L | 186 | 157 | 1.18 | A | | | |
| | | | June 2018 | E12207 | Charcoal | I-131 | pCi | 69.6 | 72.2 | 0.96 | A |
| | | | June 2018 | E12208 | AP | Ce-141 | pCi | 151 | 165 | 0.92 | A |
| Co-58 | pCi | 174 | | | | 178 | 0.98 | A | | | |
| Co-60 | pCi | 290 | | | | 227 | 1.28 | W | | | |
| Cr-51 | pCi | 452 | | | | 478 | 0.95 | A | | | |
| Cs-134 | pCi | 215 | | | | 227 | 0.95 | A | | | |
| Cs-137 | pCi | 206 | | | | 198 | 1.04 | A | | | |
| Fe-59 | pCi | 180 | | | | 172 | 1.05 | A | | | |
| Mn-54 | pCi | 265 | | | | 260 | 1.02 | A | | | |
| Zn-65 | pCi | 280 | | | | 315 | 0.89 | A | | | |
| June 2018 | E12209 | Water | Fe-55 | pCi/L | 1790 | 1740 | 1.03 | A | | | |
| June 2018 | E12210 | AP | Sr-89 | pCi | 77.8 | 90.3 | 0.86 | A | | | |
| | | | Sr-90 | pCi | 9.54 | 12.2 | 0.78 | W | | | |

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

**Table D-1 Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering Environmental Services**

| Month/Year | Identification Number | Matrix | Nuclide | Units | TBE Reported Value | Known Value ^(a) | Ratio of TBE to Analytics Result | Evaluation ^(b) |
|----------------|-----------------------|----------|---------|-------|--------------------|----------------------------|----------------------------------|---------------------------|
| September 2018 | E12271 | Milk | Sr-89 | pCi/L | 79.4 | 81.7 | 0.97 | A |
| | | | Sr-90 | pCi/L | 12.2 | 14.8 | 0.82 | A |
| | E12272 | Milk | Ce-141 | pCi/L | 152 | 128 | 1.19 | A |
| | | | Co-58 | pCi/L | 161 | 144 | 1.12 | A |
| | | | Co-60 | pCi/L | 208 | 190 | 1.10 | A |
| | | | Cr-51 | pCi/L | 244 | 265 | 0.92 | A |
| | | | Cs-134 | pCi/L | 124 | 123 | 1.01 | A |
| | | | Cs-137 | pCi/L | 166 | 147 | 1.13 | A |
| | | | Fe-59 | pCi/L | 158 | 119 | 1.32 | N ⁽¹⁾ |
| | | | I-131 | pCi/L | 83.1 | 58.2 | 1.43 | N ⁽²⁾ |
| | | | Mn-54 | pCi/L | 191 | 167 | 1.14 | A |
| | | | Zn-65 | pCi/L | 229 | 201 | 1.14 | A |
| | E12273 | Charcoal | I-131 | pCi | 83.0 | 80.7 | 1.03 | A |
| | E12274 | AP | Ce-141 | pCi | 101 | 85.6 | 1.18 | A |
| | | | Co-58 | pCi | 92.7 | 96.0 | 0.97 | A |
| | | | Co-60 | pCi | 142 | 127 | 1.12 | A |
| | | | Cr-51 | pCi | 218 | 177 | 1.23 | W |
| | | | Cs-134 | pCi | 81.2 | 81.9 | 0.99 | A |
| | | | Cs-137 | pCi | 99.0 | 98.5 | 1.01 | A |
| | | | Fe-59 | pCi | 93.7 | 79.7 | 1.18 | A |
| | | | Mn-54 | pCi | 116 | 112 | 1.04 | A |
| | Zn-65 | pCi | 139 | 134 | 1.04 | A | | |
| | E12302 | Water | Fe-55 | pCi/L | 2120 | 1820 | 1.17 | A |
| | E12276 | Soil | Ce-141 | pCi/g | 0.259 | 0.221 | 1.17 | A |
| | | | Co-58 | pCi/g | 0.279 | 0.248 | 1.12 | A |
| | | | Co-60 | pCi/g | 0.367 | 0.328 | 1.12 | A |
| | | | Cr-51 | pCi/g | 0.597 | 0.457 | 1.31 | N ⁽³⁾ |
| Cs-134 | | | pCi/g | 0.261 | 0.212 | 1.23 | W | |
| Cs-137 | | | pCi/g | 0.376 | 0.330 | 1.14 | A | |
| Fe-59 | | | pCi/g | 0.248 | 0.206 | 1.20 | A | |
| Mn-54 | | | pCi/g | 0.317 | 0.289 | 1.10 | A | |
| Zn-65 | pCi/g | 0.407 | 0.347 | 1.17 | A | | | |

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

(1) See **NCR 18-20**

(2) See **NCR 18-24**

(3) See **NCR 18-21**

**Table D-1 Analytics Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering Environmental Services**

| Month/Year | Identification Number | Matrix | Nuclide | Units | TBE Reported Value | Known Value ^(a) | Ratio of TBE to Analytics Result | Evaluation ^(b) | | | |
|---------------|-----------------------|--------|---------|---------|--------------------|----------------------------|----------------------------------|---------------------------|------|------|---|
| December 2018 | E12313 | Milk | Sr-89 | pCi/L | 71.9 | 91.9 | 0.78 | W | | | |
| | | | Sr-90 | pCi/L | 12.1 | 13.3 | 0.91 | A | | | |
| | E12314 | Milk | Ce-141 | pCi/L | 124 | 133 | 0.93 | A | | | |
| | | | Co-58 | pCi/L | 110 | 119 | 0.93 | A | | | |
| | | | Co-60 | pCi/L | 202 | 212 | 0.95 | A | | | |
| | | | Cr-51 | pCi/L | 292 | 298 | 0.98 | A | | | |
| | | | Cs-134 | pCi/L | 146 | 171 | 0.85 | A | | | |
| | | | Cs-137 | pCi/L | 118 | 121 | 0.98 | A | | | |
| | | | Fe-59 | pCi/L | 120 | 114 | 1.05 | A | | | |
| | | | I-131 | pCi/L | 94.2 | 93.3 | 1.01 | A | | | |
| | | | Mn-54 | pCi/L | 151 | 154 | 0.98 | A | | | |
| | | | Zn-65 | pCi/L | 266 | 264 | 1.01 | A | | | |
| | | | | E12315 | Charcoal | I-131 | pCi | 94.8 | 89.9 | 1.05 | A |
| | | | | E12316A | AP | Ce-141 | pCi | 92.3 | 94.0 | 0.98 | A |
| Co-58 | pCi | 73.4 | | | | 83.8 | 0.88 | A | | | |
| Co-60 | pCi | 137 | | | | 150 | 0.91 | A | | | |
| Cr-51 | pCi | 202 | | | | 210 | 0.96 | A | | | |
| Cs-134 | pCi | 115 | | | | 121 | 0.95 | A | | | |
| Cs-137 | pCi | 85.0 | | | | 85.4 | 1.00 | A | | | |
| Fe-59 | pCi | 83.1 | | | | 80.8 | 1.03 | A | | | |
| Mn-54 | pCi | 104 | | | | 109 | 0.96 | A | | | |
| Zn-65 | pCi | 168 | | | | 187 | 0.90 | A | | | |
| | E12317 | Water | Fe-55 | pCi/L | 2110 | 1840 | 1.15 | A | | | |
| | E12318 | AP | Sr-89 | pCi | 81.1 | 83.0 | 0.98 | A | | | |
| | | | Sr-90 | pCi | 11.4 | 12.0 | 0.95 | A | | | |

(a) The Analytics known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) Analytics evaluation based on TBE internal QC limits:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

**Table D-2 DOE's Mixed Analyte Performance Evaluation Program (MAPEP)
Teledyne Brown Engineering Environmental Services**

| Month/Year | Identification Number | Matrix | Nuclide | Units | TBE Reported Value | Known Value ^(a) | Acceptance Range | Evaluation ^(b) |
|---------------|-----------------------|------------|------------|-----------|--------------------|----------------------------|------------------|---------------------------|
| February 2018 | 18-MaS38 | Soil | Ni-63 | Bq/kg | 9.94 | | (1) | A |
| | | | Sr-90 | Bq/kg | 0.846 | | (1) | A |
| | 18-MaW38 | Water | Am-241 | Bq/L | 0.785 | 0.709 | 0.496 - 0.922 | A |
| | | | Ni-63 | Bq/L | 12.6 | 14.0 | 9.8 - 18.2 | A |
| | | | Pu-238 | Bq/L | 0.0214 | 0.023 | (2) | A |
| | | | Pu-239/240 | Bq/L | 0.544 | 0.600 | 0.420 - 0.780 | A |
| | 18-RdF38 | AP | U-234/233 | Bq/sample | 0.111 | 0.124 | 0.087 - 0.161 | A |
| | | | U-238 | Bq/sample | 0.123 | 0.128 | 0.090 - 0.166 | A |
| | 18-RdV38 | Vegetation | Cs-134 | Bq/sample | 2.46 | 3.23 | 2.26 - 4.20 | W |
| | | | Cs-137 | Bq/sample | 3.14 | 3.67 | 2.57 - 4.77 | A |
| | | | Co-57 | Bq/sample | 4.12 | 4.42 | 3.09 - 5.75 | A |
| | | | Co-60 | Bq/sample | 1.86 | 2.29 | 1.60 - 2.98 | A |
| | | | Mn-54 | Bq/sample | 2.21 | 2.66 | 1.86 - 3.46 | A |
| | | | Sr-90 | Bq/sample | | | | NR ⁽³⁾ |
| | | | Zn-65 | Bq/sample | -0.201 | | (1) | A |
| November 2018 | 18-MaS39 | Soil | Ni-63 | Bq/kg | 703 | 765 | 536 - 995 | A |
| | | | Sr-90 | Bq/kg | 137 | 193 | 135 - 251 | W |
| | 18-MaW39 | Water | Am-241 | Bq/L | 0.0363 | | (1) | A |
| | | | Ni-63 | Bq/L | 6.18 | 7.0 | 4.9 - 9.1 | A |
| | | | Pu-238 | Bq/L | 0.73 | 0.674 | 0.472 - 0.876 | A |
| | | | Pu-239/240 | Bq/L | 0.89 | 0.928 | 0.650 - 1.206 | A |
| | 18-RdF39 | AP | U-234/233 | Bq/sample | 0.159 | 0.152 | 0.106 - 0.198 | A |
| | | | U-238 | Bq/sample | 0.162 | 0.158 | 0.111 - 0.205 | A |
| | 18-RdV39 | Vegetation | Cs-134 | Bq/sample | 1.85 | 1.94 | 1.36 - 2.52 | A |
| | | | Cs-137 | Bq/sample | 2.5 | 2.36 | 1.65 - 3.07 | A |
| | | | Co-57 | Bq/sample | 3.53 | 3.31 | 2.32 - 4.30 | A |
| | | | Co-60 | Bq/sample | 1.6 | 1.68 | 1.18 - 2.18 | A |
| | | | Mn-54 | Bq/sample | 2.61 | 2.53 | 1.77 - 3.29 | A |
| | | | Sr-90 | Bq/sample | 0.338 | 0.791 | 0.554 - 1.028 | N ⁽⁴⁾ |
| | Zn-65 | Bq/sample | 1.32 | 1.37 | 0.96 - 1.78 | A | | |

(a) The MAPEP known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation

(b) DOE/MAPEP evaluation:

A = Acceptable - reported result falls within ratio limits of 0.80-1.20

W = Acceptable with warning - reported result falls within 0.70-0.80 or 1.20-1.30

N = Not Acceptable - reported result falls outside the ratio limits of < 0.70 and > 1.30

(1) False positive test

(2) Sensitivity evaluation

(3) See **NCR 18-09**

(4) See **NCR 18-25**

Table D-3

**ERA Environmental Radioactivity Cross Check Program
Teledyne Brown Engineering Environmental Services**

| Month/Year | Identification Number | Matrix | Nuclide | Units | TBE Reported Value | Known Value ^(a) | Acceptance Limits | Evaluation ^(b) |
|----------------|-----------------------|--------|---------|------------|--------------------|----------------------------|-------------------|---------------------------|
| March 2018 | MRAD-28 | AP | GR-A | pCi/sample | 65.7 | 43.4 | 22.7 - 71.5 | A |
| | | | GR-B | pCi/sample | 57.2 | 52 | 31.5 - 78.6 | A |
| April 2018 | RAD-113 | Water | Ba-133 | pCi/L | 91.2 | 91.5 | 77.1 - 101 | A |
| | | | Cs-134 | pCi/L | 70.4 | 75.9 | 62.0 - 83.5 | A |
| | | | Cs-137 | pCi/L | 122 | 123 | 111 - 138 | A |
| | | | Co-60 | pCi/L | 64.8 | 64.3 | 57.9 - 73.2 | A |
| | | | Zn-65 | pCi/L | 98.6 | 86.7 | 78.0 - 104 | A |
| | | | GR-A | pCi/L | 32.8 | 28.6 | 14.6 - 37.5 | A |
| | | | GR-B | pCi/L | 62.9 | 73.7 | 51.4 - 81.1 | A |
| | | | U-Nat | pCi/L | 6.7 | 6.93 | 5.28 - 8.13 | A |
| | | | H-3 | pCi/L | 17100 | 17200 | 15000 - 18900 | A |
| | | | Sr-89 | pCi/L | 38.6 | 48.8 | 38.3 - 56.2 | A |
| | | | Sr-90 | pCi/L | 27.1 | 26.5 | 19.2 - 30.9 | A |
| | | | I-131 | pCi/L | 26.7 | 24.6 | 20.4 - 29.1 | A |
| September 2018 | MRAD-29 | AP | GR-A | pCi/sample | 49.7 | 55.3 | 28.9 - 91.1 | A |
| | | | GR-B | pCi/sample | 75.3 | 86.5 | 52.4 - 131 | A |
| October 2018 | RAD-115 | Water | Ba-133 | pCi/L | 15.2 | 16.3 | 11.9 - 19.4 | A |
| | | | Cs-134 | pCi/L | 85.9 | 93.0 | 76.4 - 102 | A |
| | | | Cs-137 | pCi/L | 229 | 235 | 212 - 260 | A |
| | | | Co-60 | pCi/L | 81.9 | 80.7 | 72.6 - 91.1 | A |
| | | | Zn-65 | pCi/L | 348 | 336 | 302 - 392 | A |
| | | | GR-A | pCi/L | 38.9 | 60.7 | 31.8 - 75.4 | A |
| | | | GR-B | pCi/L | 36.5 | 41.8 | 27.9 - 49.2 | A |
| | | | U-Nat | pCi/L | 17.48 | 20.9 | 16.8 - 23.4 | A |
| | | | H-3 | pCi/L | 2790 | 2870 | 2410 - 3170 | A |
| | | | I-131 | pCi/L | 26.9 | 27.2 | 22.6 - 32.0 | A |
| | | | Sr-89 | pCi/L | 57.2 | 56.9 | 45.5 - 64.6 | A |
| | | | Sr-90 | pCi/L | 36.8 | 31.4 | 22.9 - 36.4 | N ⁽¹⁾ |

(a) The ERA known value is equal to 100% of the parameter present in the standard as determined by gravimetric and/or volumetric measurements made during standard preparation.

(b) ERA evaluation:

A = Acceptable - Reported value falls within the Acceptance Limits

N = Not Acceptable - Reported value falls outside of the Acceptance Limits

(1) See **NCR 18-23**

Intentionally left blank

APPENDIX E

REMP SAMPLE EQUIPMENT OPERABILITY TRENDING

**TABLE E-1
REMP SAMPLING EQUIPMENT OPERABILITY TRENDING
SUSQUEHANNA STEAM ELECTRIC STATION**

Percent (%) Operability

| SAMPLING MEDIA | SAMPLE LOCATION | DESCRIPTION | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 |
|-------------------------------|-----------------|--|------|------|------|-------|------|------|------|------|------|
| Air Particulate & Charcoal | 3S2 | SSES Backup Met. Tower | 99.9 | 99.3 | 98.9 | 99.9 | 100 | 99 | 100 | 99.9 | 99.9 |
| | 12S1 | West Building | 99.9 | 100 | 99.9 | 99.9 | 100 | 100 | 100 | 99.1 | 99.7 |
| | 13S6 | Former Laydown Area, West of Confers Lane | 100 | 99.7 | 99.1 | 99.9 | 100 | 97 | 100 | 100 | 99.9 |
| | 12E1 | Berwick Hospital | 100 | 100 | 99.9 | 100.0 | 100 | 98 | 99.1 | 100 | 100 |
| | 6G1 | Freeland Substation | 100 | 100 | 99.9 | 99.9 | 100 | 90* | 100 | 100 | 100 |
| | 8G1 | PPL System Facilities Center, Humboldt Industrial Park | 99.7 | 100 | 99.8 | 99.9 | 100 | 100 | 99.2 | 99.9 | 99.9 |
| | 10S3 | E of Confers Lane, S of Towers Club | - | - | - | - | - | - | 100 | 99.5 | 99.9 |
| | 9B1 | Transmission Line, E of Route 11 | - | - | - | - | - | - | 100 | 99.9 | 99.9 |
| Drinking Water | 12H2 | Danville Water Company | 100 | 100 | 100 | 100.0 | 100 | 100 | 100 | 100 | 100 |
| Surface Water | 2S7 | Cooling Tower Blowdown Discharge Line | 98.0 | 99.1 | 98.1 | 98.1 | 69** | 100 | 99.1 | 100 | 100 |
| | 6S6 | River Water Intake Line | 100 | 95.5 | 93.4 | 93.2 | 93 | 98 | 99.7 | 99.9 | 99.9 |

* Planned power outage by Electric Utilities

** Auto- Compsite sampler problems, March through June. New Auto- Compsite sampler installed in July.