



Tennessee Valley Authority, Post Office Box 2000, Decatur, Alabama 35609-2000

October 29, 2019

10 CFR 21.21(a)(2)  
10 CFR 50.4

ATTN: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001


Browns Ferry Nuclear Plant, Units 1, 2, and 3  
Renewed Facility Operating License Nos. DPR-33, DPR-52, and DPR-68  
NRC Docket Nos. 50-259, 50-260, and 50-296

Subject: **Interim Report of a Deviation or Failure to Comply**

In accordance with Title 10 of the Code of Federal Regulations 21.21(a)(2), the Tennessee Valley Authority is submitting this interim report for Browns Ferry Nuclear Plant, Units 1, 2, and 3. The deviation to be evaluated is a General Electric Hitachi (GEH) terminal board clip block, part number 228B2374P003, which was found to be out of tolerance with regard to vendor manufacturing specifications. GEH is performing an investigation of the defective clip block. Evaluation of the failure is expected to be complete by November 27, 2019. This condition is being tracked under BFN Condition Report 1521607 and GEH tracking number 19-06.

There are no new regulatory commitments contained within this letter. If you have any questions, please contact J. L. Paul at (256) 729-2636.

Respectfully,



S. M. Bono  
Site Vice President

cc:

NRC Regional Administrator – Region II  
NRC Senior Resident Inspector – Browns Ferry Nuclear Plant  
NRC Project Manager – Browns Ferry Nuclear Plant