



LAKE ENGINEERING CO.

P.O. Box 296
10 Austin Avenue
Greenville, RI 02828
Tel: 401-949-4733
Fax: 401-949-0220

March 3, 2022

U S Nuclear Regulatory Commission
Attn: Document Control Room
Washington, DC 20555-0001

Subject: Second Interim Notification per 10 CFR Part 21
Degraded Snubber SF1154 Hydraulic Fluid Batch No. 18CLVS431

This letter is a follow up to our initial notification letter dated December 28, 2021 pertaining to the above subject.

The following table reflects the status of US facilities to which SF1154 fluid from Batch 18CLVS431 was shipped by Lake Engineering Company (LEC) in accordance with purchase orders which specified that the requirements of 10 CFR Part 21 are applicable.

FACILITY	STATUS RE: BATCH 17BLVS293 FLUID	COMMENTS
Waterford 3	Fluid used in some installed snubbers	No substantial safety hazards
ANO	Use status to be determined by facility	Evaluation ongoing
Beaver Valley	Fluid used in some installed snubbers	No substantial safety hazards
So. Texas Project	Fluid used in some installed snubbers	No substantial safety hazards
Sequoyah	Fluid not used in installed snubbers	No substantial safety hazards
NTS	Use status to be determined by facility	Evaluation ongoing
Seabrook	Fluid used in some installed snubbers	No substantial safety hazards

Lake Engineering Company shall continue in its evaluation to determine whether the subject anomalies represent defects which could create a substantial safety hazard. Determination in this regard shall continue to involve interaction between Lake Engineering Company and the facilities listed above.

Our goal is to complete our evaluation by May 2, 2022 at which time a determination will have been made as to whether a substantial safety hazard exists. If additional time is required for the above determination, an interim report shall be submitted that shall include an updated completion date.

IE19
NRR

U S Nuclear Regulatory Commission
Second Interim Notification per 10 CFR Part 21
Degraded Snubber SF1154 Hydraulic Fluid Batch No. 18CLVS431

March 3, 2022
Page 2

If there are any questions or if additional information is required, please contact the writer using the contact information provided above or by email at dbrown@lakeengineeringri.com.

Very truly yours,

LAKE ENGINEERING COMPANY



D. P. Brown, P.E.
President

DPB/d/let030322.nrc

cc: P. Guay - QA Mgr.