

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
Kairos Power Licensing Subcommittee

Docket Number: (n/a)

Location: teleconference

Date: Thursday, March 23, 2023

Work Order No.: NRC-2322

Pages 1-256

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
1716 14th Street, N.W.  
Washington, D.C. 20009  
(202) 234-4433

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

KAIROS POWER LICENSING SUBCOMMITTEE

+ + + + +

THURSDAY

MARCH 23, 2023

+ + + + +

The Subcommittee met via Teleconference,  
at 8:30 a.m. EDT, David A. Petti, Chair, presiding.

COMMITTEE MEMBERS:

- DAVID A. PETTI, Chair
- RONALD G. BALLINGER, Member
- VICKI M. BIER, Member
- CHARLES H. BROWN, JR., Member
- VESNA B. DIMITRIJEVIC, Member
- GREGORY H. HALNON, Member
- WALTER L. KIRCHNER, Member
- JOY L. REMPE, Member

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

ACRS CONSULTANTS :

DENNIS BLEY

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL :

WEIDONG WANG

CONTENTS

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

Page

ACRS Chairman Introductory Remarks . . . . .

NRC Staff Introductory Remarks . . . . .

Hermes PSAR Chapter 1 . . . . .

Hermes SE Chapter 1 . . . . .

Hermes Chapter 1 Memo . . . . .

Hermes PSAR Sections 2.1-2.4, 3.2, and 3.3 . . . . .

Hermes SE Sections 2.1-2.4, 3.2 and 3.2 . . . . .

Hermes PSAR Sections 2.5, 3.4, and 3.5 . . . . .

Hermes SE Sections 2.5, 3.4, and 3.5 . . . . .

Hermes Chapter 2 Memo . . . . .

Hermes PSAR Sections 3.1 and 3.6 . . . . .

Hermes SE Sections 3.1 and 3.6 . . . . .

Hermes Chapter 3 Memo . . . . .

Hermes PSAR Section 4.2 . . . . .

Hermes SE Section 4.2 . . . . .

Hermes PSAR Section 4.5 . . . . .

Hermes SE Section 4.5 . . . . .

Public Comments . . . . .

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIR PETTI: Welcome, everyone. The meeting will now come to order.

This is a meeting of the Kairos Power Licensing Subcommittee of the Advisory Committee on Reactor Safeguards. I'm David Petti, Chairman of today's Subcommittee meeting.

ACRS members in attendance are: Charles Brown, Jose March-Leuba -- nope, Jose is not here; sorry -- Joy Rempe, Ron Ballinger, Walt Kirchner, Vicki Bier, and Greg Halnon.

ACRS Consultants Dennis Bley and Steve Schultz are also present.

Weidong Wang of the ACRS staff is the Designated Federal Official for the meeting.

During today's meeting, the Subcommittee will continue our review on the staff's safety evaluation of the Kairos Hermes Non-Power Reactor Preliminary Safety Analysis. The Subcommittee will hear presentations by, and hold discussions with, the NRC staff, Kairos Power representatives, and other interested persons regarding this matter.

Part of presentations by the Applicant and the NRC staff may be closed in order to discuss

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 information that is proprietary to the Licensee and  
2 its contractors, pursuant to 5 USC 552b(c)(4).  
3 Attendance at the meeting that deals with such  
4 information will be limited to the NRC staff and its  
5 consultants, Kairos Power, and those individuals and  
6 organizations who have entered into an appropriate  
7 confidentiality agreement with them. Consequently, we  
8 will need to confirm that we have only eligible  
9 observers and participants in the closed part of the  
10 meeting.

11 The rules for participation in all ACRS  
12 meetings, including today's, were announced in The  
13 Federal Register on June 13th, 2019. The ACRS section  
14 of the U.S. NRC public website provides our Charter,  
15 Bylaws, agendas, Letter Reports, and full transcripts  
16 of all full and subcommittee meetings, including  
17 slides presented there. The meeting notice and the  
18 agenda for this meeting were posted there.

19 We've received no written statements or  
20 requests to make an oral statement from the public.

21 The Subcommittee will gather information,  
22 analyze relevant issues and facts, and formulate  
23 proposed positions and actions, as appropriate for  
24 deliberation by the full Committee.

25 A transcript of the meeting is being and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 will be made available.

2 Today's meeting is being held in-person  
3 and over Microsoft Teams for ACRS staff and members,  
4 NRC staff, and the Applicant. There's also a  
5 telephone bridgeline and a Microsoft Teams link  
6 allowing participation of the public.

7 When addressing the Subcommittee,  
8 participants should, first, identify themselves and  
9 speak with sufficient clarity and volume, so that they  
10 may be readily heard.

11 When not speaking, we request that  
12 participants mute their computer microphone or phone  
13 by pressing \*6.

14 So, before we start the meeting, I wanted  
15 to tell members sort of how it's going to go. We're  
16 going to hear different sections. Unfortunately, it's  
17 not whole chapters by whole chapters, trying to  
18 accommodate different people's time constraints and  
19 schedule constraints.

20 But, then, we will have our time to talk  
21 about our memos. We're not going to edit the memos  
22 here. We'll just have the lead members or their  
23 designee go through the memo.

24 I will, early next week, go through --  
25 because I've already read them and just found some

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 small, tiny nits -- and I will send them back to the  
2 authors, and then, hopefully, be able to finalize  
3 them. And then, they end up having to go through --  
4 we have to sign them through the system. So, that's  
5 sort of the plan.

6 With that, let me ask Ed Helvenston from  
7 NRR to start us off.

8 MR. HELVENSTON: Yes, thank you and good  
9 morning.

10 I'm Ed Helvenston. I'm one of the NRC  
11 Project Managers for the Hermes review in the Division  
12 of Advanced Reactors and Non-Power Production and  
13 Utilization Facilities in the NRC's Office of Nuclear  
14 Reactor Regulation.

15 Staff briefed you three weeks ago on its  
16 review strategy for the Hermes construction permit  
17 application. The staff looks forward to presenting  
18 its review to the Subcommittee in today's and  
19 subsequent meetings.

20 And to start off today, I would like to  
21 emphasize a few points from the previous briefing.

22 Although the application provided only the  
23 preliminary design of a testing facility, the mission  
24 of staff is unchanged. We must have reasonable  
25 assurance of adequate protection of public health and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 safety.

2 Review guidance for testing facilities  
3 does not differentiate between the level of detail  
4 needed for a construction permit versus an operating  
5 license application or provide specific guidance on  
6 what may be deferred to the license application.

7 In making its determination on the types  
8 of things that may be reasonably deferred versus what  
9 is required for a construction permit, the staff used  
10 its technical judgment and, also, considered the  
11 requirements in 10 CFR 50.34(a) and 50.34(b) regarding  
12 information that must be included in Preliminary  
13 versus in Final Safety Analysis Reports.

14 As stated in 10 CFR 50.35, not all safety  
15 questions need to be resolved for the issuance of a  
16 permit, but an applicant is required to identify  
17 research and development which is to be completed  
18 prior to the completion of construction in order to  
19 resolve these questions.

20 The staff used NUREG-1537, which is the  
21 licensing guidance for non-power reactors, to perform  
22 its review. The review depth and scope were  
23 commensurate with the safety significance of areas  
24 being reviewed -- considering the small size of  
25 Hermes, the short operating life, and the safety case

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 with low radiological consequences.

2 We are glad to present our review to you  
3 and look forward to your feedback and recommendations.

4 MEMBER HALNON: Ed, given that, I just  
5 noticed in the SER, the Draft SER, there was a lot of  
6 places where you referred to, "Yes, we'll see that in  
7 the operating license application." And there's some  
8 places that seemed like we could have said that. Is  
9 that just to kind of generalize we're going to get  
10 more detail or are they really just held to where you  
11 said --

12 MR. HELVENSTON: I think it's not just  
13 limited to where we said it. There might be  
14 additional things we needed to know as well. I think  
15 where we said that in the SE, it was generally because  
16 there was a particular point that we wanted to make or  
17 something we thought that was particularly important  
18 we wanted to emphasize.

19 MEMBER HALNON: Okay.

20 MR. HELVENSTON: But, no, it's not an  
21 exhaustive --

22 MEMBER HALNON: Okay. Great. Thank you.

23 MEMBER REMPE: I appreciate your remarks  
24 this way to clarify how you did this review. And  
25 also, I really appreciate you providing Appendix A of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the SE to us because it helps me with what I did with  
2 Chapter 10 a couple of weeks ago, whenever it was.

3 I'm just thinking about in the future, and  
4 part of my thoughts are because of some interaction we  
5 had with some folks in Finland. And I'm just  
6 wondering, do you think that at some point that there  
7 needs to be more guidance on what's done? Or are you  
8 thinking, aw, just let it go? Because I can remember  
9 with the SHINE they made some significant changes in  
10 their processes when they saw what needed to be  
11 addressed. And maybe this is the way to go, is just  
12 have that flexibility. Or do you think more guidance  
13 or structure is needed to decide on how much you need  
14 to know for a construction permit?

15 MR. HELVENSTON: I think the flexibility  
16 is good, and having the staff and the Applicant both  
17 be able to use their judgment in terms of what's  
18 needed now versus what can be deferred. I know we  
19 don't have any specific guidance at this point, and  
20 NUREG-1537 does not distinguish between the CP versus  
21 the OL. But, at this point, you know, I do think  
22 that, as we do these reviews, the SHINE and Northwest  
23 Medical Isotopes, the Hermes review -- you know, we  
24 have a construction permit application for Abilene  
25 Christian University now -- I think we are getting

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 some experience and establishing some precedent in  
2 terms of what sorts of things we really do need in the  
3 CP and what we can defer.

4 I'm not aware of any plans to develop  
5 specific guidance at this time. You know, there is a  
6 NUREG-1537 revision ongoing. That is something that  
7 it may be worthwhile for the staff to think about in  
8 terms of something that would supplement or clarify  
9 some of what's in the guidance, you know, to give some  
10 insights on what we need in the CP versus the OL.

11 MEMBER REMPE: I really like Appendix A  
12 and that option, really having a place where they can  
13 find everything.

14 Anyway, thank you.

15 MR. HELVENSTON: I think, with that, I'll  
16 turn it over to Kairos to present Chapter 1.

17 MR. PEEBLES: All right. Thank you, Ed.

18 This is Drew Peebles. I'm a Senior  
19 Licensing Manager at Kairos Power.

20 Can you hear me okay?

21 CHAIR PETTI: Yes, we can hear you.

22 MR. PEEBLES: Okay. While Rachel is  
23 bringing up the slides, I wanted to thank the ACRS for  
24 the opportunity to present this overview of the Hermes  
25 PSAR, as well as the Committee's reviews of previously

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 submitted Kairos Topical Reports.

2 As you know, we've been very active in  
3 pre-application engagement. So, at this point, we  
4 have NRC approval of 10 Topical Reports that we've --  
5 I'm sorry -- 11 Topical Reports that we've submitted  
6 in pre-application space. And we look forward to  
7 further engagement as we continue through the  
8 licensing process.

9 Sorry, we're having technical difficulties  
10 with the slides.

11 (Pause.)

12 Sorry, there's a bit of a delay on the  
13 connection. We're trying to bring up the slides.

14 (Pause.)

15 Oh, there it is. Okay.

16 So, as I said, my name is Drew Peebles.  
17 I'm the Senior Licensing Manager at Kairos Power.

18 Next slide, please. You've seen this  
19 slide in all of our presentations to the Commission,  
20 but we are a very mission-focused company. So, we  
21 like to begin every presentation reiterating our  
22 mission statement, which is: "to enable the world's  
23 transition to clean energy, with the ultimate goal of  
24 dramatically improving people's quality of life while  
25 protecting the environment."

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           And we firmly believe we can't achieve  
2 this mission unless we develop a technology that is  
3 both affordable and, most importantly, safe.

4           So, just a little bit about Kairos Power.  
5 I mentioned our mission statement on the previous  
6 slide, and we intend to meet that mission by deploying  
7 our fluoride-cooled, high-temperature reactor that we  
8 refer to as a KP-FHR.

9           We're based in Alameda, California with  
10 several locations around the country, including a  
11 large manufacturing facility in Albuquerque, New  
12 Mexico. We have over 300 full-time employees, and  
13 those are mostly engineering-focused positions

14           We have aggressive cost and schedule  
15 targets for deploying the KP-FHR in order to provide  
16 a clean energy alternative the number of gas plants  
17 that are set to retire in the 2030s.

18           So now, I'll move on to the reason that  
19 we're here, our non-power reactor Hermes. Kairos is  
20 following the two-step licensing pathway provided in  
21 10 CFR 50 for Hermes. We submitted the construction  
22 permit application in September of 2021, consisting of  
23 the Environmental Report and the subject of today, a  
24 Preliminary Safety Analysis Report, or PSAR.

25           It's worth mentioning that the next step

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 in the licensing process will be the operating license  
2 application, which will include the Final Safety  
3 Analysis Report, which will contain design and safety  
4 information with much more finality than you will see  
5 in the PSAR.

6 We used the Non-power Reactor Standard  
7 Review Plan, NUREG-1537, to format our application,  
8 and there are a few chapters in that format that don't  
9 really apply to Hermes, which I'll touch on in the  
10 next slide.

11 But, as Ed mentioned before, the Standard  
12 Review Plan doesn't always differentiate between  
13 content that's required for the PSAR versus content  
14 that will be required for the FSAR. However,  
15 10 CFR 50.34(a) does have a list of what is explicitly  
16 required to be in the PSAR.

17 I'm mentioning this upfront because there  
18 may be several areas that you might be interested in  
19 more detail across the application that we will not  
20 have until the operating license application phase of  
21 the licensing process.

22 I've included the text from 10 CFR 50.35,  
23 which states that the NRC will not be approving the  
24 safety of any SSC at the PSAR stage, unless  
25 specifically requested by the Applicant. Kairos did

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 not request safety approval of any item in the PSAR.  
2 So, that should be kept in mind when judging the  
3 preliminary safety and design information that you'll  
4 see presented throughout the next few weeks.

5 Next slide, please. So as I mentioned on  
6 the previous slide, we used the Non-Power Standard  
7 Review Plan to format our application. And this slide  
8 shows the titles of the chapters, which are consistent  
9 with that NUREG. Most of the titles are self-  
10 explanatory. So, I won't read through them all, but  
11 I will point out that the chapters with an asterisk on  
12 the side are not applicable to Hermes.

13 There's no Chapter 10 content because,  
14 although this is a test reactor, the testing is a  
15 demonstration of KP-FHR technology covered by the  
16 system design and analysis envelopes covered in the  
17 other chapters, not separate experimental facilities.

18 There is no content in Chapters 16 or 17  
19 or 18 because we are not asking for a license on any  
20 of those items.

21 I also pointed out several of the chapters  
22 that have minimal content. I probably should have  
23 included Chapter 11 in that list as well. These  
24 chapters apply to Hermes, but there is little  
25 information required at the construction permit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 application phase. For example, the Radiation  
2 Protection Program, most of the programmatic elements  
3 aren't explicitly required in 50.34(a) for the PSAR,  
4 but they are required for 50.34(b) when we submit the  
5 FSAR.

6 Next slide, please. So I mentioned the  
7 Topical Reports that we have submitted in pre-  
8 application space. Before I talk to this slide, I  
9 want to point out an error. KP-TR-007, "Quality  
10 Assurance Plan," is not referenced in the PSAR. That  
11 Quality Assurance Plan was developed for the  
12 commercial reactor, based on an NQA-1 program. We are  
13 using an ANS 15.8 QA program for Hermes, which we'll  
14 discuss in more detail during the Chapter 12  
15 presentation.

16 So, as I mentioned, all of these Topical  
17 Reports are approved. They all have Final Safety  
18 Evaluation Reports issued. We leverage these heavily  
19 throughout the application.

20 We have two Technical Reports, "Core  
21 Design Methods" and "Postulated Event Methodology,"  
22 that are referenced in Chapters 4 and 13,  
23 respectively.

24 Next slide, please. So I only have two  
25 slides for an overview of Chapter 1, because it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 mostly a summary chapter with pointers to the rest of  
2 the chapters in the PSAR. So, a lot of the detail on  
3 any of the items in Chapter 1 will be discussed in the  
4 presentations over the next few weeks.

5 So, starting off, the purpose of Hermes is  
6 to test and demonstrate the key technologies, design  
7 features, and safety functions of KP-FHR technology.  
8 And as I mentioned, for not having much content in  
9 Chapter 10, that is why -- we're testing and  
10 demonstrating the technology design features and  
11 safety functions, not any external experiments or  
12 anything that we need to clarify in Chapter 10.

13 It's a 35-megawatt, thermal, non-power  
14 reactor facility and we're licensing it for a four-  
15 year lifetime. The operating parameters will be  
16 discussed a little more in the Chapter 4  
17 presentations.

18 The location that we've selected is the  
19 Oak Ridge, Tennessee, East Tennessee Technology Park,  
20 which is the former site of the Oak Ridge Gaseous  
21 Diffusion Plant. And we'll talk a little bit more  
22 about that later today in the Chapter 2 presentation.

23 The principal design criteria for Hermes  
24 are based on the principal design criteria we have in  
25 our approved Topical Report KP-TR-003. And those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 principal design criteria are based on the advanced  
2 reactor design criteria in Reg Guide 1.232. And I'll  
3 talk a little bit more about those in the Chapter 3  
4 presentation after this one.

5 We have low consequences from this  
6 facility due to the inherit safety features. I  
7 pointed out two major ones there: the robust fuel  
8 design and the flibe coolant. And I'll talk more  
9 about the functional containment strategy in both the  
10 Chapter 3 and Chapter 6 presentations.

11 Our engineered safety features that we  
12 describe in Chapter 6 are the functional containment  
13 strategies as well as the passive Decay Heat Removal  
14 System that we call the DHRS. And we'll discuss that  
15 in more detail during the Chapter 6 presentation.

16 Our Instrumentation and Control System  
17 monitors and controls plant operations, and that will  
18 be discussed during the Chapter 7 presentation.

19 Our non-safety-related electrical system  
20 provides the normal and backup power to the facility,  
21 and that will be discussed during the Chapter 8  
22 discussion.

23 All of our auxiliary systems are not-  
24 safety-related, including things like the chemistry  
25 control, inert gas, and tritium management systems.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Those will be discussed in more detail in the Chapter  
2 9 discussion.

3 Next slide, please.

4 MEMBER BALLINGER: This is Ron Ballinger.  
5 I have a question. The license is for four years?

6 MR. PEEBLES: That's correct.

7 MEMBER BALLINGER: Let's say something  
8 happens and you need to go further. What's the long  
9 pole in the tent to increase the number? In other  
10 words, let's say you have to use it for six years.

11 MR. PEEBLES: Yes, we would have to amend  
12 the license. So, we'd have to submit another revision  
13 to the application.

14 MEMBER BALLINGER: Yes, I mean, I know  
15 that, but, I mean, is there something in this current  
16 application which would have to be very significant to  
17 go an extra two years?

18 MR. PEEBLES: I don't think we've done  
19 that delta analysis, because we really are planning a  
20 short lifetime for this reactor. It's just to  
21 demonstrate that we can produce a low-cost nuclear  
22 heat iteration or technology. So, we're not really  
23 looking to go further than that. If something did  
24 happen, we'd look into that with the effort required  
25 for a license amendment.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BALLINGER: Thank you.

2 CHAIR PETTI: But, just to follow on, if  
3 experience and capacity factor was really low, lower  
4 than you anticipated, and you were at least hoping to  
5 get so many effective full-power days, that might be  
6 a reason you would want to go longer than four  
7 calendar years.

8 MR. PEEBLES: We fully expect the capacity  
9 factor to not be high, being a first-of-a-kind and a  
10 test reactor. I'm not sure that that would be the  
11 driver, but I don't know if I can speculate on reasons  
12 why we would extend the lifetime right now.

13 MEMBER REMPE: Some countries give credit  
14 for the fact that the reactor was shut down; for  
15 example, if you couldn't get the fuel and it was  
16 delayed, new fuel, for three months. The NRC, though,  
17 does not. They have a calendar date, right? And so,  
18 if you say you're going to start up on year one day  
19 one, at the end of your four 365 days, you must shut  
20 down, right? The NRC doesn't give credit for  
21 downtime.

22 MR. PEEBLES: That's correct.

23 So, on this next slide, pointing out that  
24 we have two nuclear safety classifications. It's  
25 binary. All the SSCs are safety-related or non-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 safety-related. We'll discuss that a little bit more  
2 in the Chapter 3 presentation after this one,  
3 including some modifications we made to the safety-  
4 related definition.

5 Any potential events for this facility, we  
6 call postulated events, and those are evaluated using  
7 a deterministic safety analysis with a maximum  
8 hypothetical accident to demonstrate dose compliance.  
9 And we'll discuss that a bit more in the Chapter 13  
10 presentation.

11 Radioactive waste management and radiation  
12 protection, I discuss that on one of the previous  
13 slides, that there's little content, but we do have a  
14 lot of text in Chapter 11 discussing how the programs  
15 will comply with the Part 20 requirements.

16 Experimental capabilities. I mentioned  
17 that before, that we don't have any external  
18 experimental needs. So, the capability to perform the  
19 testing associated with the purpose of the reactor is  
20 included in normal system design, which we describe in  
21 all of the PSAR chapters. No additional facilities or  
22 capabilities are required.

23 We also have a list of research and  
24 development programs that Ed mentioned in 1.3.9 to  
25 resolve safety questions, and we've committed to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 resolving those before the completion of construction  
2 of the facility.

3 And then, finally, in Chapter 1, I'll  
4 mention that Hermes is a single unit. So, any of the  
5 shared systems requirements, such as the PDC for  
6 shared systems, don't apply to Hermes because it's a  
7 single unit plant.

8 And that concludes my material on Chapter  
9 1. I'm happy to take any questions.

10 MEMBER KIRCHNER: Drew, this is Walt  
11 Kirchner. I'm sorry I'm not there in person.

12 On experimental capabilities, to include  
13 testing of fuel irradiation, that was something that  
14 was implicit in the Fuel Qualification TR. Do you  
15 have an estimate of what kind of burnup you might  
16 achieve? We just discussed that it may be a low  
17 capacity factor, but are you looking to do, in effect,  
18 or try to achieve a burnup that would be comparable to  
19 what you would see in the power reactor?

20 MR. PEEBLES: No, we think it will be  
21 pretty low. I'm looking at one of our Chapter 4  
22 people. So, it's 6 percent, about 6 percent. It's  
23 percent (audio interference).

24 MEMBER KIRCHNER: How would that compare  
25 for a target burnup in an actual power plant?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MR. PEEBLES: Yes, we don't have our core  
2 design people in the room yet. So, can we get back to  
3 you on that?

4 MEMBER KIRCHNER: Yes. Sure. That's  
5 fine. Thank you.

6 MEMBER BROWN: Hey, Walt, are you talking  
7 about full life burnup when they say 6 percent? Or  
8 are you talking something smaller?

9 This is Charlie.

10 MEMBER KIRCHNER: No, I was just looking  
11 for a comparison -- because it includes fuel  
12 irradiation -- just what kind of burnup they would  
13 achieve versus what they're looking to achieve when  
14 they go to an actual power plant application.

15 MR. GARDNER: Walt, this is Darrell  
16 Gardner, Senior Director of Licensing with Kairos.  
17 Just a quick comment.

18 I think I understand the question. It's  
19 important for us communicate that Hermes isn't  
20 intended to be necessarily the sole way that we  
21 qualify fuel. We have other ways of qualifying fuel  
22 for the burnup onboard the commercial reactor.

23 So, while we do talk about fuel  
24 irradiation testing, there is data that we will  
25 recover from operating Hermes, but it isn't the only

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 dataset that we need for qualifying commercial fuel.

2 MEMBER KIRCHNER: No, it's just that it's  
3 a great opportunity to try, you know, to qualify the  
4 actual fuel form in its final configuration; i.e., a  
5 manufactured pebble in a flibe environment.

6 MR. SCHMIDT: This is Jeff Schmidt from  
7 the staff.

8 I just wanted to give you some context.  
9 So, they're limited to 13.2 for that, based on the AGR  
10 kernel size. So, you're getting, roughly,  
11 potentially, 6 percent out of the 13.2 limit.

12 DR. SCHULTZ: This is Steve Schultz.

13 The same type of question may be asked  
14 about materials corrosion. Over the period of  
15 operation, you listed here that the capabilities will  
16 include of materials corrosion and irradiation. Are  
17 you going to speak later about the details there  
18 associated with the evaluations that will be done in  
19 that area?

20 MR. GARDNER: So, Darrell Gardner again.

21 I think the short answer is we're not  
22 planning to. The details of our materials  
23 qualification program are in the Topical Report that  
24 was approved, the High Temperature Materials Topical  
25 Report. Again, Hermes will be collecting data in a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 number of areas. It's not necessarily intended to be  
2 the sole vehicle to achieve the complete set of  
3 answers described in the Topical Reports for fuel  
4 qualification or materials qualification or graphite  
5 qualification.

6 DR. SCHULTZ: I understand that. I'm just  
7 asking about what you mean by experimental  
8 capabilities in these areas -- the fuel irradiation,  
9 materials corrosion and irradiation. What will you do  
10 to support the statement here?

11 MR. GARDNER: Yes, I think what we're  
12 intending to describe is operating the facility is  
13 recovering data. There's not anything special -- it's  
14 what Drew mentioned before -- there's not special  
15 experiments that are being run by the facility. It's  
16 simply operating the facility and collecting and  
17 examining components and data.

18 DR. SCHULTZ: And that's a good way to  
19 express it. Thank you.

20 MR. GARDNER: Yes, sir.

21 MEMBER REMPE: And also, have you had a  
22 chance to look at Appendix A of the SE? The staff  
23 actually points out many places where additional  
24 details must be provided in the OL along that track.  
25 And that's kind of where I was at when I was trying to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 say we need more details. And the staff, basically,  
2 gave me some confidence that they also feel that way.

3 DR. SCHULTZ: Good. Thank you.

4 MEMBER HALNON: This is Greg.

5 Just to finish off the four-year operating  
6 license discussion, I started thinking about what that  
7 would do. When you get issued the license, you'll be  
8 within some decommissioning windows that are already  
9 established. For instance, about five years before  
10 the end of the operating license, you're supposed to  
11 submit a decommissioning plan.

12 So, I would suggest really looking at  
13 50.82 and 50.75 and make sure that this short  
14 operating window is not going to put you in a period  
15 of scrambling to get your decommissioning stuff in  
16 place, both funding and plans relative to the four  
17 years, especially since you decided not to go for a  
18 possession-only license at the end of this, which  
19 means you'll have to have a continuation of the  
20 operating license.

21 So, it's an interesting thing. I think  
22 make sure that you've done that homework and  
23 established the matrices and make sure you're not  
24 going to get yourself in a non-compliant situation.

25 MR. PEEBLES: Appreciate the comment.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Thank you.

2 CHAIR PETTI: Okay. Ed?

3 MR. HELVENSTON: And with that, I think  
4 I'll go ahead and present Chapter 1, the staff's  
5 review. I'll get the slides up here. Thanks, Ben.

6 Yes, so next slide, please.

7 So, yes, I'll be presenting the staff's  
8 review of Chapter 1 following the presentation from  
9 Kairos. I'll just give a very brief introduction and  
10 overview of the regulatory requirements that we  
11 primarily used to conduct our review, as well as a  
12 very brief overview of the review.

13 As Drew mentioned, Chapter 1 is primarily  
14 a summary chapter. So, there aren't a lot of specific  
15 staff conclusions on Chapter 1, but I will briefly go  
16 over the findings and conclusions that we do have in  
17 that chapter as well.

18 Next slide, please. So as Drew already  
19 stated, Kairos has requested a construction permit for  
20 a 35-megawatt, thermal, non-power reactor facility  
21 that will be called Hermes. The purpose is to test  
22 and demonstrate key technologies, design features, and  
23 safety functions for Kairos' KP-FHR technology and its  
24 SSCs. The reactor will be located in the East  
25 Tennessee Technology Park near Oak Ridge, Tennessee.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           Based on the information in the  
2 application, Hermes would be licensed as a non-power  
3 reactor under 10 CFR Part 50, under a Class 104<sup>©</sup>  
4 license, for a facility that's used for testing,  
5 research, and development.

6           Next slide, please. So as I mentioned,  
7 this is a summary of the primary regulations in Part  
8 50 that we used, that are applicable, that we used to  
9 conduct our review of the Hermes CP application. Just  
10 a few of these I'll just point out.

11           10 CFR 50.33/50.34 lay out the information  
12 that's required to be in an application for a  
13 construction permit.

14           10 CFR 50.35 is the specific findings that  
15 the staff is required to make for the issuance of a  
16 construction permit that we make in our SER to support  
17 our conclusions.

18           10 CFR 50.40 includes common standards  
19 that are findings that the staff has to make for any  
20 type of application, whether it's a CP or an OL, or a  
21 combined operating license, or some other types.

22           And then, a few of these others are  
23 regulations that we considered in our review as well.

24           Next slide. So one thing I do want to  
25 emphasize, over the course of our review, in our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 audits and requests for additional information that we  
2 asked, Kairos did submit some supplements to the NRC  
3 in response to our requests, and the bulk of this  
4 information is primarily incorporated and updated in  
5 the latest revision of the PSAR, Revision 2, which was  
6 dated February 24th. And that's the document that  
7 primarily forms the basis for the findings in the NRC  
8 staff's Safety Evaluation.

9 In terms of the construction permit, I  
10 think, as we've mentioned, that will allow Kairos to  
11 proceed with construction based on the preliminary  
12 design information provided in the application. But,  
13 as stated in 10 CFR 50.35, and based on Kairos'  
14 request, it will not approve a final approval of the  
15 safety of any design feature or specification, unless  
16 specifically requested by the Applicant, which Kairos  
17 has not requested at this point.

18 In terms of the primary guidance for our  
19 review, we used NUREG-1537, which is the SRP for non-  
20 power reactors such as Hermes. We also used other  
21 guidance, such as Regulatory Guides and ANSI standards  
22 and engineering judgment, as applicable, to make the  
23 findings in the CP, as we discuss and identify in the  
24 SE.

25 Next slide, please. So, next, I'll just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 say a little bit about what we did look at in Chapter  
2 1 in our review and some of the findings and  
3 conclusions that we made.

4 You know, there's a few sections that were  
5 just introductory, general material and PSAR at 1.1  
6 and 1.3. The staff did review that information and  
7 summarize it, but we didn't make any specific findings  
8 on it.

9 In PSAR Section 1.2, Kairos provided some  
10 information on the overall safety case for Hermes,  
11 which we reviewed that information, and in addition to  
12 the rest of the information in the PSAR. And in our  
13 SE Section 1.2, we describe our overall findings that  
14 support our conclusion that the applicable standards  
15 and requirements of the AEA and the NRC regulations  
16 have been met for the issuance of a construction  
17 permit.

18 In terms of PSAR, our Section 1.4, we  
19 found, based on the fact that it's going to be,  
20 essentially, a standalone facility, and any offsite  
21 infrastructure, like offsite power, is not needed to  
22 perform a safety function, that there was no  
23 additional information that was needed what was  
24 provided for that item.

25 Next slide. PSAR Section 1.6, a summary

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 of operations, we found that, based on the information  
2 in the PSAR on how they'll operate the facility -- for  
3 example, the four-year lifespan -- we found that  
4 that's consistent with relevant assumptions and  
5 analysis later in the PSAR in which the safety  
6 implications of the proposed operations and how  
7 they'll operate the facility are evaluated.

8 In PSAR Section 1.7, we determined that,  
9 based on the evidence of good-faith negotiation with  
10 DOE and terms of the disposition of used fuel and  
11 high-level waste from Hermes, that they've satisfied  
12 the requirements of that Act for the issuance of a  
13 construction permit.

14 In PSAR Section 1.8, because it's,  
15 essentially, a new facility, there's no existing  
16 facilities or modifications, that section is not  
17 really applicable.

18 Next slide. So as we pointed out, the  
19 regulation in 10 CFR 50.34(a)(8) requires an applicant  
20 for a construction permit to identify SSCs requiring  
21 R&D and describe what their program for that will be.  
22 In PSAR Section 1.3.9, Kairos did identify a number of  
23 research and development activities -- fuel pebble  
24 behavior; developing a material surveillance/sampling  
25 program; qualification testing of high-temperature

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 material; analysis of potential graphite oxidation in  
2 postulated events; validation of computer codes; the  
3 fluidic diode; thermodynamic data, and pressure  
4 correlations used in the coolant system design;  
5 process sensor technology, as well as the reactor  
6 coolant chemical monitoring instrumentation. And  
7 those systems, they're listed in Chapter 1, but  
8 they're discussed in more detail in some of the later  
9 sections of the PSAR as well.

10 And this section, we found it consistent  
11 with Regulation 50.34(a)(8). Kairos committed that  
12 they will complete these R&D activities prior to the  
13 completion of construction, which the expected date  
14 for that is December 2026.

15 And as we identify in Appendix A of our  
16 SE, we do have these activities listed and tracked in  
17 there, and we'll verify that those activities get  
18 completed prior to the completion of construction.

19 MEMBER REMPE: I have a question. I was  
20 really glad to see you also have focused on their need  
21 to have something to monitor the level of the coolant,  
22 since flibe is considered part of their containment  
23 strategy, functional containment strategy. In your  
24 discussions with Kairos, have you thought about  
25 whether this needs to be safety-related or not, this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 coolant-level sensor?

2 MR. HELVENSTON: I think some of the  
3 sensors will be safety-related. I'm wouldn't want to  
4 speak to that specific one.

5 I don't know if you have any information  
6 further on that, Jeff.

7 MR. SCHMIDT: Yes. This is Jeff Schmidt  
8 from the staff.

9 Yes, I would expect that to be safety-  
10 related because it forms part of their functional  
11 containment. Plus, it also maintains coolant to the  
12 pebble and TRISO. So, yes.

13 MEMBER REMPE: I'm glad to hear that  
14 because, again, that level sensor isn't even  
15 identified in their Chapter 7 PSAR table. It's  
16 something that you guys have focused on. And so, I  
17 was glad to see that -- unless it's in the revised  
18 PSAR. I didn't see it in the -- I think it's like  
19 Table 7-3 or something. I may have it wrong.

20 MR. HELVENSTON: I don't recall, but I  
21 know it's mentioned throughout the PSAR, the level  
22 sensor, but I don't know --

23 MEMBER REMPE: Yes, it's not one of the  
24 process ones that they identified. But, again, I was  
25 looking at an old one and maybe I need to check the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 update.

2 MEMBER HALNON: Ultimately, it was  
3 described, and there's other functional aspects of  
4 different systems that protect the level, like the  
5 anti-siphoning stuff. And that level of detail, you  
6 know, you want it now, but, obviously, it's just not  
7 there yet.

8 So, we'll be looking, definitely, at  
9 what's safety-related versus non-safety-related, not  
10 just interfaces, but some of those systems that  
11 clearly look like they are -- I mean, we all know what  
12 large light water reactors are supposed to do and how  
13 those instrumentations work, but, at least from my  
14 perspective, I'll be looking at equivalencies in what  
15 I would consider safety-related to protect the reactor  
16 core versus how it's described now. Because, right  
17 now, you just can't tell. You just want to know.

18 And that was the hard thing about doing  
19 this review, was you want that next step of level of  
20 detail. And that's one of my questions earlier, is  
21 there's just so much of the details that come back  
22 from the operating license. You just can't even  
23 imagine Appendix A being of everything because it  
24 would be so large, what you needed.

25 And we don't want to do the design for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1       them.  So, it would be interesting to get it, you  
2       know, as soon as we can.

3                   CHAIR PETTI:  I just had a question on the  
4       anti-siphon.  It's not on the list.  Is there going to  
5       have to be testing to prove that?

6                   MR. HELVENSTON:  This is a list of  
7       specific research and development programs that Kairos  
8       has identified.  It's not an exhaustive list of  
9       everything that they are going to need to maybe learn  
10      more about or make a final determination on before the  
11      operating license.

12                   And I think our Appendix A maybe is even  
13      broken into like A1 and A2, where we have, you know,  
14      one of them lists the specific R&D and one is other  
15      sort of commitments to provide information on  
16      something.

17                   MR. SCHMIDT:  Again, this is Jeff Schmidt  
18      from the staff.

19                   So, we did look at that.  We didn't think  
20      it made the list for research and development because  
21      they're very simple devices that are passive, that  
22      effectively use like elevation differences and the  
23      cover gas.  So, we didn't think it fell into research  
24      and development.

25                   MEMBER KIRCHNER:  May I ask what fluidic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 diode device, then, does this refer to? I thought  
2 this was the anti-siphon device.

3 MR. SCHMIDT: Again, this is Jeff Schmidt  
4 from the staff.

5 No, there's two separate -- well, there's  
6 two anti-siphon devices, effectively, on the hot leg,  
7 if you want to call it that, and the cold leg. And  
8 then, the fluidic diode is what prevents, say, reverse  
9 flow going into our normal operations, but allows flow  
10 when you have the decay heat removal system in  
11 operation. So, you have lost your primary heat  
12 transport, and the fluidic diode allows flow in one  
13 direction to remove decay heat. They're separate  
14 systems.

15 MEMBER HALNON: It's key to natural  
16 circulation.

17 MR. SCHMIDT: Yes, that's right.

18 MEMBER HALNON: And that's the important  
19 part. The fluidic diode is very essential to the  
20 natural circulation.

21 MR. HELVENSTON: Next slide. So I think  
22 my last slide on this chapter, just one other section  
23 I wanted to mention is, in PSAR Section 1.5, Kairos  
24 did identify a number of reactors that have operated  
25 in the past; that, although there's never been a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 reactor exactly like this one, you know, there is  
2 operating experience with a number of the technologies  
3 -- the salt coolant, the TRISO, and the graphite  
4 moderator -- that are similar to what's being planned  
5 for Hermes.

6 We did review this information, in  
7 conjunction with what's in the remainder of the PSAR,  
8 you know, in accordance with the NUREG-1537 acceptance  
9 criteria. We did find that, based on what they  
10 provided, they've compared the design basis and safety  
11 considerations of Hermes with similar facilities, and  
12 there is some expectation that some of these aspects  
13 can perform in a similar manner, due to these  
14 comparable features, as well as that the test data and  
15 experience from these has been appropriately applied  
16 in the design of Hermes, as practicable.

17 I think that was all I had. So, I'm happy  
18 to take any further questions.

19 MEMBER REMPE: Could I explore what Greg  
20 brought up about this five-year limit for  
21 decommissioning, and has that come into your review  
22 process?

23 MR. HELVENSTON: So, I'll say that, at the  
24 CP stage, looking at decommissioning is, typically,  
25 more of an operating license application. I think

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 they will need to submit a decommissioning report with  
2 the OL that will have some information on kind of the  
3 timelines and the funding and areas like that. So,  
4 that's something that we'll probably take a closer  
5 look at at OL, to make sure that those things are in  
6 place and that all that is going to work out in terms  
7 of the timing of the requirements.

8 I'd have to check 50.82, but there may be  
9 a requirement -- the timeframes, I know for an RTR I  
10 believe are a little different than they are for other  
11 reactors. So, I'm not certain about the five-year  
12 requirement. I'd have to look at that.

13 MEMBER HALNON: Yes, I was just looking at  
14 1537, and at least it said go look at 50.82 and 50.37.

15 MR. HELVENSTON: Yes.

16 MEMBER HALNON: And it does say about five  
17 years for a decommissioning plant submission. And  
18 Chapter 17 in this PSAR was left kind of open-ended,  
19 so we do expect more detail. But if you just gave it  
20 a four-year operating license, you're already well  
21 into that five-year window; plus, then, you get a two-  
22 year window for other things that you have to do. So,  
23 the amount of detail in that Chapter 17 is going to be  
24 beyond even what you would expect in a normal RTR  
25 which is going to operate for many years.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MR. HELVENSTON: Yes. Well, we'll  
2 probably have to consider that 1537 and the regulation  
3 were not written with a reactor that's going to  
4 operate for four years in mind.

5 MEMBER REMPE: And I did have the table  
6 wrong. It was identified as a safety-related sensor,  
7 but there's a lot of "we don't know what the sensor  
8 is" type of stuff. So, I stand corrected about what  
9 I said there.

10 CHAIR PETTI: Okay. Thank you, Ed.

11 MR. HELVENSTON: Thank you.

12 CHAIR PETTI: At this point, we should  
13 probably turn to the memo.

14 Okay. So, Chapter 1, just to go through,  
15 I, basically, summarize in the background. It's a  
16 test reactor; mention NUREG-1537; that the reactor  
17 uses salt flibe functional containment; relies on  
18 passive heat removal. Does not need enriched cross-  
19 cooling system.

20 Talk about what the key inherent safety  
21 features are, functional containment, atmospheric  
22 pressure, all reactivity coefficients being negative,  
23 except for the reflectors will be, typically, slightly  
24 positive. The vessel and other safety-related  
25 components within the seismic (audio interference)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 structure; shielding to minimize the occupational  
2 exposure, and a ventilation system to make sure we  
3 protect the workers.

4 The SER summary is, basically, the second  
5 paragraph talks about the R&D that Ed just mentioned,  
6 and I actually list the key measure areas and the  
7 staff is tracking these activities.

8 The relevant experience, which I was happy  
9 to see the slide on because that's something that we  
10 talk about a lot. And just note that they did that.  
11 They did a good job of looking at what had been done  
12 in the past.

13 Applicable standards. Discuss what  
14 they've got so far. Mention the disposition of waste,  
15 the DOE discussions, and that the staff found it  
16 sufficient.

17 So, I didn't identify (audio interference)  
18 but sort of a high-level summary. In fact, the only  
19 thing I will do is I'm going to mention to review;  
20 this is add 104<sup>®</sup> license. I think that would be  
21 important, but I didn't mention that. So, I've got a  
22 note to myself to do that.

23 Pretty straightforward.

24 MEMBER REMPE: Do you want to mention  
25 something about the discussion that Greg had about the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 decommissioning concerns or something that we may want  
2 to think about, since it is a four-year license? Or  
3 is this the right chapter to do that?

4 CHAIR PETTI: Well, probably it would be  
5 in Chapter 17.

6 MEMBER REMPE: Okay.

7 MEMBER HALNON: And that's my chapter, and  
8 I don't know if I point that out. So, I'll go back  
9 and revise it.

10 CHAIR PETTI: Yes, that's a good thing to  
11 put in on the revision.

12 Okay. I guess we're up to Chapter 2 and  
13 3, sort of hybrid; 2.1 through 2.4, 3.2, and 3.3.

14 Kairos?

15 MR. PEEBLES: So, we had 3.1 and 3.6 next  
16 up on the agenda.

17 MR. HELVENSTON: Yes, I think we moved  
18 things around a little bit, due to some staff  
19 availability.

20 MR. PEEBLES: Okay.

21 CHAIR PETTI: As long as we cover them  
22 all.

23 So, that's all of Chapter 3, though,  
24 right?

25 MR. HELVENSTON: So, we're doing 3.1 and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 3.6, and then, there will be a presentation that  
2 combines parts of 2 with parts of 3.

3 CHAIR PETTI: Okay. Okay. And then,  
4 we'll do the 2 and 3 memos together, because they  
5 won't be done until -- I'm just looking at our agenda;  
6 it's different.

7 MEMBER BIER: Yes, I would be curious to  
8 know when Chapter 2 is going to be up, so I can plan  
9 ahead maybe.

10 MR. PEEBLES: Chapter 2 is after this one.

11 MEMBER BIER: Oh, okay. Great. Thank  
12 you.

13 CHAIR PETTI: Okay.

14 MR. PEEBLES: All right. So, this first  
15 presentation is just on 3.1 and 3.6. As Ed mentioned,  
16 the rest of Chapter 3 will be discussed with the  
17 related portions of Chapter 2. 3.1 is the  
18 introduction and design criteria, and then, 3.6 is  
19 systems and components classification discussions.

20 Next slide, please. Oh, and this is Drew  
21 Peebles again, Senior Licensing Manager for Kairos.

22 So as I mentioned in the Chapter 1  
23 presentation, we're pursuing a construction permit for  
24 Hermes reactor under the two-step process in  
25 10 CFR 50.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           We did an analysis of all of the NRC  
2 regulations in Title 10 for applicability to KP-FHRs,  
3 both a power reactor and a non-power reactor. So, we  
4 are utilizing the non-power reactor application-  
5 applicable regulations from that report. And again,  
6 that's another approved Topical, KP-TR-004, which is  
7 the regulatory analysis for a KP-FHR.

8           Table 3.1-1 identifies the design-related  
9 regulations from that Topical that are applicable to  
10 the Hermes test reactor. It's notable that we didn't  
11 find any specific exemptions from the regulations that  
12 we identified, but that's not to say that we didn't  
13 find some that weren't technically relevant. So, the  
14 example there is for combustible gas control.

15           And I'll mention another change for the  
16 safety-related definition which is a change because of  
17 the basis of the rule, not because we need a specific  
18 exemption.

19           The evaluated NRC Regulatory Guides for  
20 applicability to the Hermes test reactor, all of the  
21 Reg Guides in Division 1 are not explicitly applicable  
22 to research and test reactors, but we do use them to  
23 inform different areas. It's just noting that they're  
24 not explicitly required for a research and test  
25 reactor.

1 Divisions 2, 4, and 8 apply, and we  
2 consider those in the Hermes test reactor, as shown in  
3 Section 3.1.

4 Next slide, please. So for the principal  
5 design criteria for Hermes, I mentioned before that we  
6 submitted a Topical Report on the PDC for KP-FHRs.  
7 And that's a typo there. It should be KP-TR-003. And  
8 that Topical Report was also approved.

9 We've taken the PDC from that Topical  
10 Report and applied them to the Hermes test reactor  
11 with two departures. One, there's two that don't  
12 apply, and then, another, we changed the terminology  
13 from some of the PDC.

14 So, the two PDCs that we've identified as  
15 not being applicable to Hermes are PDC 5, which is the  
16 sharing SSCs, and that's not applicable because there  
17 is only one reactor and no SSCs are shared with  
18 another facility, and then, PDC 73, which deals with  
19 the interface between reactor coolant systems. That's  
20 not applicable to Hermes because we have no secondary  
21 coolant fluid.

22 Then, the changes in terminology, as I  
23 mentioned before, we have binary safety  
24 classification. All of the SSCs are either safety-  
25 related or not. So, the term "safety-significant" is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 not relevant to the Hermes classification system. So,  
2 we changed the words "safety-significant" throughout  
3 the PDC to "safety-related."

4 Also, anywhere the PDC mentioned  
5 "anticipated operational occurrences or accidents,"  
6 those terms were replaced with "postulated events," to  
7 be consistent with the non-power reactor regulatory  
8 framework, where you don't bin the accidents according  
9 to frequency.

10 Next slide, please. So you can map any  
11 safety case license through the NRC to fundamental  
12 safety functions, and the Hermes safety case is no  
13 different. So, the three fundamental safety functions  
14 of preventing the release of radionuclides, removing  
15 an adequate amount of decay heat, and controlling  
16 reactivity are all satisfied by the safety case of  
17 Hermes.

18 So, preventing the uncontrolled release of  
19 radionuclides, we do that through our functional  
20 containment approach, which takes advantage of the  
21 primary barriers to release, which are the TRISO  
22 layers and the fuel, and the secondary barrier, which  
23 is the flibe coolant. And TRISO fuel will be  
24 discussed in the 4.2 presentation, and the flibe  
25 coolant will be discussed in the Chapter 5 discussion.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           Any safety-related fluid systems that  
2 contain circulating radioactivity are designed as in  
3 Section 3, and non-safety systems that may contain  
4 circulating activity are designed as in Section 8 for  
5 applicable API standards.

6           In removing decay heat in the event of a  
7 postulated event, we rely on natural circulation  
8 within the vessel and the passive decay heat removal  
9 system to reject or transfer heat from the reactor  
10 core to the atmosphere.

11           And then, finally, controlling reactivity  
12 in the reactor core, we rely on our reactivity control  
13 and shutdown system, which we will discuss in the  
14 Chapter 4.2 discussion. And that controls reactivity  
15 during normal and postulated events.

16           So, as I mentioned, we have only two  
17 classifications, that being is safety-related or not  
18 safety-related. We did make a modification to the  
19 definition of safety-related. The basis for that  
20 definition was light-water-reactor-specific. So, we  
21 had to change a couple of things.

22           The original definition said that safety-  
23 related SSCs are those that you rely on to remain  
24 functional during and following design basis events to  
25 ensure, one, the integrity of the reactor coolant

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 pressure boundary; two, the capability to shut down  
2 the core, maintain it in a shutdown condition, and  
3 then, the capability to prevent or mitigate the  
4 consequences of accidents.

5           So, the first bullet there, first, we took  
6 out the word "pressure" because our system is not  
7 pressurized. So, it's not relevant to the Hermes or  
8 any KP-FHR design. And then, we specified that not  
9 the entire reactor coolant boundary is important to  
10 the safety case. We don't have to have the integrity  
11 of the entire reactor coolant boundary in order to  
12 meet our safety metrics. We clarified that the  
13 integrity of the portions of that boundary that we  
14 rely on and the specific goal is to maintain coolant  
15 level above the active core.

16           And again, we didn't have to take an  
17 exemption to 50.2 because the basis of the rule was  
18 light-water-reactor-specific. So, it was not  
19 technically-relevant. We could propose our own  
20 definition to 50.2.

21           I think that's it on this slide.

22           The classifications of every SSC is shown  
23 in the PSAR Table 3.6-1.

24           Next slide, please. So for seismic  
25 classifications, which we'll talk a little bit more in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the Chapter 3 discussions, safety-related SSCs are  
2 classified as SDC 3, in accordance with ASCE 43-19.  
3 All of the safety-related SSCs are located in the  
4 safety-related portion of the reactor building, and  
5 non-safety-related SSCs are designed to local building  
6 codes.

7 Quality classifications. Anything that's  
8 safety-related is considered quality-related.  
9 Anything non-safety-related is classified as not  
10 quality-related. And the quality-related SSCs conform  
11 to the requirements of the Quality Assurance Program,  
12 which is based on an ANS-15.8 standard.

13 And the seismic and quality classification  
14 of the SSCs are shown in PSAR Table 3.6-1.

15 I believe that is the least slide for 3.1  
16 and 3.6. I'm happy to take your questions.

17 MEMBER KIRCHNER: Dave, this is Walt.

18 I'd like to go back to the slide on safety  
19 the definition of "safety-related." I'll start by  
20 observing the following: it's not a high-pressure  
21 system, but it is a low-pressure system. So, you do  
22 have a boundary to maintain, so that you don't have  
23 free access of air, for example.

24 Secondly, low-pressure systems leak as  
25 well as high-pressure systems, maybe not with the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 higher probability of leakage, but there have been  
2 low-pressure reactor systems that have developed leaks  
3 -- liquid metal systems, to be precise, which are like  
4 your system, essentially, operating at a low pressure  
5 with some kind of cover gas.

6 When you make the split like you have  
7 defined it here, then that suggests that the remainder  
8 of the primary coolant system boundary is not safety-  
9 related. Yet, you depend on that to prevent  
10 unmitigated or uncontrolled access of the air, for  
11 example, to the primary system and the core.

12 So, I would have thought you would have,  
13 for this particular reactor, which is like a  
14 prototype, that you would have made your arguments on  
15 safety classification, safety-related or not, based on  
16 the third bullet, not the first one.

17 Would you like to comment on that?  
18 Because I think your functional containment will  
19 satisfy the third bullet, in that your potential  
20 offsite exposures are far less than the applicable  
21 guideline exposures in 10 CFR 50.34.

22 MR. PEEBLES: So, you mentioned the rest  
23 of the reactor coolant boundary not being safety-  
24 related, and that is accurate. We are not relying on  
25 the boundary, for instance, for the primary heat

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 transport system piping. Our safety case assumes that  
2 it fails and we release the entire inventory of the  
3 primary heat transport system, and we're still able to  
4 meet our very low dose metrics.

5 As far as mitigating air ingress, we do  
6 also accommodate air ingress in the safety case, which  
7 I think we'll discuss, then, in the Chapter 13  
8 discussion as well.

9 CHAIR PETTI: I thought -- and again, I  
10 may have read this in the previous revision PSAR -- I  
11 thought it was beyond design basis. Has that changed?

12 MR. PEEBLES: It's within the design  
13 basis.

14 CHAIR PETTI: It's within the design  
15 basis?

16 MR. PEEBLES: Yes.

17 CHAIR PETTI: Okay.

18 MEMBER KIRCHNER: So, then, uncontrolled  
19 access of air to the reactor vessel is not a beyond  
20 design basis accident? You think that's a design  
21 basis event? Because, depending on the level that the  
22 fluidic diode and anti-siphon devices as a system  
23 leave, whatever the level is, your design objective is  
24 to keep the active core covered. But this will expose  
25 significant amounts of high-temperature graphite to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 air, as well as the free surface of the flibe.

2 MR. PEEBLES: So, it does expose some  
3 graphite, but not the portion that's needed to  
4 maintain the natural circulation flow path.

5 MEMBER KIRCHNER: But, then, you have a  
6 graphite-air reaction as well to deal with.

7 MR. PEEBLES: Again, we're not depending  
8 on that exposed graphite for it to maintain its  
9 structural integrity or anything. We have hold-down  
10 plates for the flibe-wetted graphite that maintains  
11 the natural circulation flow path.

12 MEMBER KIRCHNER: No, I get that part.  
13 So, then, the estimates of potential reaction of air  
14 with flibe and/or graphite will not exacerbate release  
15 of radionuclides?

16 MR. PEEBLES: Correct.

17 MEMBER KIRCHNER: I mean, or is that going  
18 to be something that's demonstrated in the R&D  
19 programs?

20 MR. PEEBLES: No. It's all included  
21 within the scope of the materials qualification that  
22 we'll do testing to quantify how much is oxidized.  
23 But we do, in the safety analysis, consider almost a  
24 complete failure of what is exposed.

25 MEMBER KIRCHNER: Okay. Well, my concern

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 is that this is precedent to stop -- divide up a  
2 primary coolant system in this manner, such that the  
3 vessel is safety-related and the remainder of the  
4 coolant envelope is not.

5 MR. GARDNER: So, this is Darrell Gardner  
6 again.

7 We don't disagree with that. It's a new  
8 technology, advanced reactors. Again, this definition  
9 is based entirely on the understanding of light water  
10 reactor technology. So, we went into this fully  
11 expecting we would need to make adjustments to this  
12 definition to be meaningful for our design and our  
13 safety strategy.

14 MEMBER KIRCHNER: No, I appreciate that.  
15 I'm just flagging it because this is a good time, I  
16 think, to have the conversation at this early  
17 juncture. Otherwise, it creates significant  
18 complications at the OL stage, if, indeed, the  
19 classification of equipment were to be changed, for  
20 whatever reason.

21 MEMBER BROWN: Walt, this is Charlie.

22 Does some of this definition apply because  
23 their decay heat removal system is relied on for  
24 almost all heat removal, once you're below -- well,  
25 it's on all the time after you exceed 10 megawatts

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 thermal. So, is the DHRS tied up in this definition  
2 as well?

3 MEMBER KIRCHNER: No, it's a separate  
4 system from the cooling system.

5 MEMBER BROWN: I know that, but, I mean,  
6 does its performance allow this to be done? That's  
7 the only question I'm saying. You're ahead of me on  
8 some of the aspects you're talking about, but the  
9 overheating is not one of them, is what you're saying?

10 MR. PEEBLES: This is Drew Peebles.

11 So, the third bullet captures why the DHRS  
12 is safety-related and its performance. So, its  
13 capability --

14 MEMBER BROWN: No, I understand that. You  
15 know, I've read that already in Chapter 6 and, also,  
16 it's a discussion in Chapter 7. I was just wondering  
17 how it tied into this other new definition.

18 All right. I'll stop there.

19 MR. PEEBLES: Well, I just want to point  
20 out, we didn't change the third bullet there. So,  
21 anything that we rely on to mitigate the effects of  
22 an accident -- or excuse me -- a postulated event are  
23 considered safety-related.

24 MEMBER BROWN: Okay. But it's stated in  
25 the later chapters?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. PEEBLES: So, that third subbullet  
2 under "Safety-Related" -- I don't know if you can use  
3 the mouse there. Sorry. That bullet there, that  
4 captures everything that is relied upon to mitigate  
5 the consequences of events.

6 CHAIR PETTI: So, does that by the letter  
7 of the law make the flibe itself a safety system?  
8 Because it prevents a lot of stuff from happening, in  
9 terms of functional containment.

10 MR. PEEBLES: Essentially, it's a safety-  
11 related barrier.

12 CHAIR PETTI: Yes.

13 MR. PEEBLES: So, not unlike the flibe --  
14 or excuse me -- the TRISO barriers, it's more of a  
15 commodity than it is a particular SSC, but, yes, it  
16 would still have the rigor to change the (audio  
17 interference).

18 CHAIR PETTI: I had another question on  
19 the classification. I just couldn't remember. The  
20 piping in the pebble-handling system, is that safety-  
21 related?

22 MR. PEEBLES: No, that's non-safety-  
23 related.

24 CHAIR PETTI: So, then, you assume you've  
25 got an accident where you've got an ingress with the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 pebbles?

2 MR. PEEBLES: Correct.

3 CHAIR PETTI: Do you have more slides?

4 MR. PEEBLES: Oh, no. Sorry, I was just  
5 taking questions.

6 CHAIR PETTI: Okay. Yes. I don't see any  
7 more here in the room. So, why don't we go to the  
8 staff?

9 MR. LE: Good morning.

10 My name is Tuan Le. I'm a Reactor  
11 Engineer in the (audio interference) Division.

12 Today, I will go over the staff review on  
13 the PSAR, Section 3.1 and 3.6.

14 CHAIR PETTI: Speak a little closer to the  
15 mic. Pull the microphone closer. It's really hard  
16 to -- you're very faint.

17 MR. LE: Can you hear me?

18 So, the Sections 3.1. and 3.6, I will go  
19 over the staff review and the validation of Section  
20 3.1 and Section 3.6.

21 Next slide, please. The agenda, our role  
22 is Sections both 3.1 and 3.6. The agenda will be the  
23 same: the overview, regulatory basis, staff technical  
24 evaluation and conclusions, and regulatory findings.

25 Next slide, please. The overview for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Section 3.1. Section 3.1 is the design criteria. The  
2 Hermes reactor used the principal design criteria  
3 based on the approval of the Topical Report, the KP-  
4 TR-003-NP, the principal design criteria for the  
5 Kairos power fluoride, salt-cooled, high-temperature  
6 reactor.

7 In this Section 3.1, Kairos identified  
8 relevant regulations and PDCs for the Hermes reactor,  
9 as well as the NRC guidance considered in the design.

10 Next slide, please. The basis for this,  
11 the regulatory basis for this Section 3.1 is  
12 10 CFR 50.34(a), "Preliminary Safety Analysis Report;  
13 10 CFR 50.3, "Issuance of Construction Permits, and  
14 10 CFR 50.43, "Common Standards."

15 Next, please. For the review process of  
16 this section, the staff evaluation, staff used the  
17 following guidance, initial evaluation for the Hermes  
18 design criteria: relevant parts of the NUREG-1537,  
19 and used the title for this NUREG is "Guidelines for  
20 Preparing and Reviewing the Application for the  
21 Licensing of Non-Power Reactors."

22 The staff also used the following  
23 guidance: Reg Guide 1.232 entitled, "Guidance for  
24 Developing Principal Design Criteria for Advanced Non-  
25 Light Reactors," Revision 0. That review included

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 consideration of limitations and conditions for the  
2 staff SE for the Topical Report, the KP-TR-003-NP.

3 MEMBER HALNON: Tuan, how did that go when  
4 you looked at the existing guidance to what they  
5 provided? Is that work good or do we need to tweak  
6 any of the guidance in 1.232 or for the NUREG? Did it  
7 work well? I know there's only two exceptions, or  
8 whatever they took, that they mentioned.

9 But I guess my thought was, we're learning  
10 each time we'll get one of these new technology  
11 reactors in front of us. I'm just wondering if we  
12 learned anything significant that might inform some of  
13 the other reactors that we'll be doing in the future.

14 MR. LE: Yes, this is similar, comes back  
15 to the question of whether the chicken or the egg came  
16 first.

17 MEMBER HALNON: Yes.

18 MR. LE: We're learning through the  
19 process, using the 1537, and I would say the relevant  
20 part of 1537 we applied to this Hermes reactor review.  
21 So, there is a number guidance documents to be  
22 included --

23 MEMBER HALNON: Some learnings? Because  
24 I know that 1537 is -- what? -- a 1998 document, or  
25 something, was the last time it was revised. So, it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 20-plus years old.

2 And I think you mentioned that 1537 is in  
3 revision, or at least gathering information. I was  
4 just wondering if there is anything significant that  
5 came out of this review that we might, when the  
6 revision comes out, consider applying in the near-term  
7 reactors that we're looking at.

8 MR. LE: I don't see any significant -- I  
9 was just saying that they are using 1537 for review in  
10 the Hermes reactor. Some information that we can  
11 improve later on for the guidance will be more on the  
12 non-light-water reactor guidance.

13 MEMBER HALNON: Okay. So, no  
14 showstoppers, though? I mean, we went through the  
15 SHINE and the same thing. We found that it was  
16 relatively okay, with some exceptions. Similar, I  
17 guess, in this situation.

18 MR. LE: Yes.

19 MEMBER HALNON: Thanks.

20 MEMBER BALLINGER: Yes, this is Ron  
21 Ballinger.

22 I have to chime in here. I mean, to my  
23 mind, the key documents are 03 and 04, the TRs, which  
24 go through the design analysis and, especially, the  
25 PDCs, and how they match up and everything.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           They'll learn a lot from that, from going  
2 through that exercise.

3           MEMBER DIMITRIJEVIC:     This is Vesna  
4 Dimitrijevic.

5           I wanted to actually add something to this  
6 discussion. I mean, Ron, you are right, those TRs are  
7 very good guidance, but they are done for the reactor,  
8 not for the test; I mean for the power reactors. So,  
9 there is a difference there.

10          And in this discussion about what has  
11 changed, it is that 1537 is not risk-informed. So, as  
12 you can see, the definition of safety and the  
13 accidents. So, the Regulatory Guide 1.232, which is  
14 risk-informed, there is big exemptions which staff  
15 made here; that it is not necessary to use NEI 18-04  
16 guide, which is from the risk-informed principles.  
17 And it's okay to use 1537, which is purely  
18 deterministic.

19          So, there is -- I mean, I don't know  
20 whether I call it "an exemption," but sort of like,  
21 you know, in the big step difference between what  
22 1.232 is.

23          MR. LE:   Shall I continue?

24          So, in staff evaluations for Section 3.1,  
25 the staff also considered the limitations and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 conditions from the staff SE for the use KP-TR-003-NP  
2 for design criteria. The limitation and condition for  
3 the following:

4 The key design feature for Hermes, the  
5 system, were those in the KP-TR-003-NP.

6 Secondly, the relevant manufacturing  
7 license scope is not applicable to Hermes.

8 The third one is the NEI 18-04 titled,  
9 "Risk-Informed Performance-Based Technology-Inclusive  
10 Guidance for Non-Light Water Reactors. Licensing  
11 Basis Development," Revision 1. It's not applicable  
12 to the Hermes design, the Hermes reactor. Instead,  
13 staff used the guidance of 1537.

14 The use of the term "safety-related," as  
15 was mentioned before, Hermes uses "safety-related"  
16 consistent with 10 CFR 50.2.

17 Terminology-wise, they consider safety-  
18 related use instead of the safety-significant, as  
19 indicated in NEI 18-04.

20 "Postulated event" is used consistently  
21 within NUREG-1537.

22 For the conclusion, the staff had the  
23 regulatory findings. The NRC staff found the design  
24 information was consistent with the guidance in Reg  
25 Guide 1.232 and applicable criteria for the NUREG-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 1537.

2 The staff concludes that the information  
3 in the Hermes PSAR Section 3.1 is sufficient for  
4 issuance of a construction permit, in accordance with  
5 the 10 CFR 50.35 and 50.40.

6 Further information can be provisionally  
7 left for the OL, the application stage.

8 That is the conclusion of my Section 3.1.  
9 If there are no other questions, I will continue to  
10 Section 3.6.

11 MEMBER KIRCHNER: I have a question. This  
12 is Walt Kirchner.

13 Can we go back to safety-related? The  
14 slide on safety-related. Yes, Item 4. Yes.

15 Okay. So, you know, your definition, the  
16 staff's definition, in the current regulations, under  
17 safety-related structures in 50.2, includes, for  
18 design basis events, the integrity of the reactor  
19 coolant pressure boundary.

20 Now, we can argue whether that means high  
21 pressure or not, but, certainly, the intent is that  
22 this primary coolant boundary gives you a layer of  
23 defense-in-depth.

24 Now, for an LWR, one postulates that you  
25 lose that, and yet, demonstrate that you can meet the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 requirements of the third part of the definition,  
2 which are the dose limits found in, essentially,  
3 50.34.

4 So, how do you reconcile this when this  
5 interpretation by the Applicant is applied to the  
6 primary coolant boundary? Because, again, in the case  
7 of an LWR, you postulate a double-ended guillotine  
8 break, and you, then, depend on the fuel design active  
9 systems, in the case of the large of the large PWRs,  
10 to ensure that you keep the dose below the 50.34  
11 requirements.

12 MR. SCHMIDT: This is Jeff Schmidt from  
13 the staff.

14 So, if you look at the Chapter 13 event,  
15 salt spill --

16 CHAIR PETTI: A little closer.

17 MR. SCHMIDT: Okay. Sorry. Sorry.

18 If you look at the Chapter 13 event, salt  
19 spill, there is a series of breaks that will be  
20 analyzed. And I think they did a double-ended  
21 guillotine break in this, in the example problem. And  
22 it will drain down until the anti-siphon devices  
23 prevent further drain-down.

24 And as Drew mentioned, the exposed  
25 surfaces, including graphite, will oxidize due to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 air ingress, and that is part of their analysis for  
2 the salt spill accident, which should be less bounding  
3 than the MHA. So, that air ingress is, effectively,  
4 analyzed, and the results of that air ingress are  
5 analyzed.

6 Does that answer your question?

7 MEMBER KIRCHNER: No, I -- yes, I have  
8 read that part of Chapter 13 as well, and I understand  
9 that the staff's position seems to be that they will  
10 demonstrate, the Applicant will demonstrate to you  
11 that air ingress unmitigated will not lead to dose  
12 consequences, as per the guidelines. But I just  
13 submit that that line of defense that the primary  
14 coolant boundary provides is safety-related in LWR  
15 systems. But I understand this is new technology.  
16 So, I'm not stuck in the past.

17 But I'm trying to understand, Jeff, at  
18 this point, the logic that says, okay, we're going to  
19 split this system and say that ex-vessel will design  
20 to what may be perceived by the public a lower quality  
21 than is required of the reactor vessel.

22 I'm just trying to kind of test, Jeff, the  
23 staff's logic here in accepting the Applicant's  
24 proposal as to how they're going to divide up the  
25 system.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. SCHMIDT: Yes, I think one thing that  
2 has to be considered -- again, this is Jeff Schmidt  
3 from the staff; sorry -- one thing that has to be  
4 considered is that, you know, there is also the flibe  
5 component, which doesn't exist in the light water  
6 reactors, right? So, maybe you're trading the primary  
7 coolant boundary system for now the flibe retention,  
8 right?

9 So, it's not necessarily an apples-to-  
10 apples comparison. They have a different technology  
11 which will pick up different aspects that maybe don't  
12 require the integrity of the primary coolant. So, I  
13 would just submit that as a consideration.

14 MEMBER KIRCHNER: Yes. So, then, Jeff,  
15 though, by logic -- you know, Dave brought this point  
16 up earlier -- then, does that make the flibe safety-  
17 related? Because, obviously, you've got limiting  
18 conditions of operation in tech specs about impurities  
19 of flibe which would be a concern for transmutation  
20 products, as well as retention of impurities may have  
21 an impact on retention of fission products in  
22 solution. And then, there's the whole question of,  
23 what does the presence of air in contact with the  
24 flibe due to its retention capabilities -- things that  
25 are part of the R&D or the materials qualification

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 aspects of the program the Applicant has laid out?

2 So, that's my concern. It does create a  
3 rather new precedent. And at this point, yes, I would  
4 say, then, okay, I certainly understand from a  
5 technical standpoint the functional containment  
6 argument. So, I'm not contesting that. I'm just  
7 exploring, and this set of presentations gives us an  
8 opportunity to, you know, discuss this.

9 So, does the flibe, then, become, quote-  
10 unquote, "a safety-related system"?

11 MR. SCHMIDT: So, again, this is Jeff  
12 Schmidt from the staff.

13 You know, I think the short answer is,  
14 yes, it's part of -- it's just like fuel; that's a  
15 safety-related function.

16 MEMBER KIRCHNER: Right.

17 MR. SCHMIDT: It has certain  
18 characteristics for fission product retention.  
19 They're crediting flibe for certain fission product  
20 retention. So, I consider that safety-related.

21 CHAIR PETTI: So, basically, with the  
22 exception of the small amount of release in the spill,  
23 functional containment is largely maintained, even  
24 though it's not in the vessel?

25 MR. SCHMIDT: That's correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR PETTI: I mean, that's sort of the -  
2 -

3 MR. SCHMIDT: Right.

4 MEMBER KIRCHNER: Okay. Thank you.

5 CHAIR PETTI: Let's keep going.

6 MR. LE: So again, the overview of Section  
7 3.6. 3.6 is regarding systems and components. This  
8 section describes the design basis for systems and  
9 components required to function for safe reactor  
10 operation and shutdown.

11 This includes Section 3.6.1. The title is  
12 "General Design Basis Information." This section is  
13 described as safety functions that are performed by  
14 safety-related SSCs.

15 The following are the safety-related  
16 functions of the SSCs:

17 The first one is preventing the  
18 uncontrollable release of radionuclides.

19 The second safety function is performed to  
20 remove decay heat following the successful reactor  
21 trip.

22 And a third safety function is control of  
23 reactivity.

24 Section 3.6.2, classifications of  
25 structural systems and components are described, how

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the SSCs are classified.

2 So, in this process, for each section, the  
3 staff evaluation used the following guidance for each  
4 evaluation:

5 Similar like to 3.3.1, the relevant parts  
6 of NUREG-1537 titled, "Guidelines for Preparing and  
7 Reviewing the Application for the Licensing of Non-  
8 Power Reactors."

9 Also, Reg Guide 1.129 titled, "Seismic  
10 Design Classification for Nuclear Power Plant,"  
11 Revision 6.

12 Reg Guide 1.143, "Design Guidance for  
13 Radioactive Waste Management Systems, Structures, and  
14 Components Installed in Light-Water-Cooled Nuclear  
15 Power Plants," Revision 2.

16 Also, Reg Guide 1.87, "Acceptability of  
17 the ASME Codes, Section III, Division 5, High  
18 Temperature Reactors," Revision 2.

19 Staff reviews cover the design basis,  
20 safety seismic qualification, declassification, design  
21 basis review of the staff evaluation, design  
22 construction code and standards for fluid system,  
23 considered with Reg Guide 1.143 as acceptable.

24 I will go over the high level of the  
25 safety function that the Hermes design met. They met

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 it because the reactor vessel internal support  
2 coolable core geometry and natural circulation for the  
3 heat transfer to the decay heat removal system. The  
4 decay heat removal system operates to remove the heat  
5 from the core for at least 72 hours following the  
6 postulated event when normal cooling systems are  
7 unavailable.

8 Passive fuel pebbles and the coolant  
9 contain fission products. The reactivity control and  
10 shutdown system shut down the reactor and maintains  
11 reactor shutdown after an event.

12 And lastly is the safety-related portion  
13 of the reactor building to protect the reactor vessel  
14 and other safety-related SSCs for natural phenomena.

15 CHAIR PETTI: So, I had a question which  
16 may be for the Applicant. So, I've got the vessel,  
17 but the top of the vessel is non-safety-related and  
18 would be designed to a different ASME Section VIII  
19 versus the vessel, Section III. When you impose the  
20 seismic standard, is there any inconsistency there  
21 because of the different classifications from the ASME  
22 in terms of the seismic? I mean, you know, the  
23 nuclear stuff is fine during the seismic event, but  
24 the non-nuclear stuff -- and they're connected  
25 together -- is there an issue there? Or is it because

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 it's seismic isolated and all that sort of goes away?

2 DR. DORON: This is Oded Doron from  
3 Kairos, Director of our Reactor Systems.

4 So, the entire vessel will be designed  
5 with the intent of Section III --

6 CHAIR PETTI: Ah, okay.

7 DR. DORON: -- including the head --

8 CHAIR PETTI: Okay.

9 DR. DORON: -- and nozzles up to the first  
10 connection surface, per Section III.

11 CHAIR PETTI: Okay. Thanks.

12 MR. LE: Next slide. So, in this portion,  
13 it is in the staff technical evaluation on the safety  
14 and seismic qualifications.

15 The safety classification, as was just  
16 mentioned before, the safety classification of the  
17 ASCs in Table 3.6-1 meets the definition requirements  
18 for 10 CFR 50.2 with one exception, the integrity of  
19 the portion of the reactor coolant boundary relied  
20 upon to maintain the coolant level above the active  
21 core.

22 Secondly, I will go to the seismic  
23 classification. The NRC staff finds that the safety  
24 and seismic classification conforms with the guidance  
25 of Reg Guide 1.29 because the safety classifications

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 are assigned correctly through Seismic Classification  
2 SD 3-3, according to the ASCE 43-19 standard.

3 Some analysis and testing we perform in  
4 accordance with the Section 8.2 and 8.3 of the  
5 ASCE 43-19.

6 MEMBER HALNON: This is Greg.

7 Did that review include the interfacing  
8 portions of the non-safety systems, looking at the  
9 interfaces? There was a lot of non-safety systems  
10 close to or in the vicinity of, or connected to. And  
11 did your review of the seismic go into the non-safety  
12 systems to make sure that they were appropriately  
13 designed to that code as well?

14 MR. LE: I believe this code is relevant  
15 to the seismic qualification designed to the ASCE 43-  
16 19 as a classified safety-related portion, the  
17 component of equipment with the safety-related  
18 classification.

19 MEMBER HALNON: So, you only looked at the  
20 safety-related classes at this point -- the system?

21 MR. LE: No.

22 MEMBER KIRCHNER: Just a follow-on to  
23 Greg's question. This is Walt Kirchner.

24 My big concern here would be, again, the  
25 largest component attached to the vessel is the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 primary heat transport system and its piping. So, I  
2 presume that the analysis has to include, just to  
3 elaborate on Greg's question, whether those systems  
4 are -- by the way, I would note, as Dave noted  
5 earlier, it's nice you've got the whole reactor system  
6 on a seismic isolation. That clearly should reduce  
7 the loads that are seen by all the structure.

8 But have you looked at -- I'll give you  
9 one scenario to make my question a little more  
10 specific. Is the potential for the primary heat  
11 transport system loop to rupture the vessel examined?  
12 Because it's not safety-related in this classification  
13 system. In other words, you've got a significantly  
14 large mass attached to the reactor vessel. Is it  
15 designed to fail, so that it doesn't endanger or  
16 somehow rupture the reactor vessel and lead to a loss  
17 of flibe and uncovering of the active core?

18 MR. LE: I believe that the design of the  
19 Hermes reactor, it is designed to the criteria 2.2.1.  
20 They designed towards non-safety-related components --  
21 piping, for instance -- risk. For example, if the  
22 non-safety-related piping failed, they designed such  
23 that the failing of the non-safety-related will not  
24 affect the safety-related components of the 2.2.1  
25 criteria. And the 2.2.1 criteria, it's also they do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 it with the design, the non-safety-related components  
2 protecting the safety-related components. They do  
3 design to that criteria aspect.

4 MEMBER KIRCHNER: Well, see, this is where  
5 we're facing a new precedent. Because, typically, in  
6 the seismic analyses you look at non-safety and other  
7 components that could endanger the safety function of  
8 a safety-related system due to seismic loadings, or et  
9 cetera.

10 Here, you've got the primary heat  
11 transport system welded onto the reactor vessel. So,  
12 it's not a question of, for example, displacement and  
13 collision of two components. Now, you've got an  
14 integral system. So, typically, what would be done  
15 for LWRs is that the piping and the support systems  
16 for the entire primary loop would be designed to  
17 withstand a safe shutdown earthquake.

18 Here, if you're designing your safety-  
19 related components to seismic classification SDC 3,  
20 but you have an integral system, and the other part of  
21 the system is not designed to that, then that raises  
22 questions about whether that system could, in fact,  
23 affect the safety performance of the system it's  
24 connected to.

25 So, this is kind of, again, kind of an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 unusual situation. I'm presuming that the PHTS is  
2 going to actually be designed as if it was SDC 3  
3 because it's connected to the reactor vessel.

4 MEMBER HALNON: So, Walt, this is Greg.

5 There are in the auxiliary systems -- I  
6 can't speak to the PHTS -- but in the auxiliary  
7 systems there were descriptions of the interfaces and  
8 passing nearbys, and the stuff like that, where the  
9 seismic was addressed as SDC 3, as appropriate. I did  
10 not go through that in detail to make sure that every  
11 connection and locale -- because there's really no  
12 spatial other than, you know, the conceptual  
13 descriptions.

14 So, I know that, at least in the auxiliary  
15 system, there is that consideration. But my question,  
16 again, was more generalized, but yours is very  
17 specific, but it's the same question. It is, did you  
18 trace that through to make sure that the seismic  
19 design from the connected systems, nearby systems, and  
20 others, is appropriate to the safety class that needs  
21 to be done to protect the safety-related system?

22 So, I know that it's in there. I just  
23 don't know if it was all comprehensively looked at.

24 MR. HELVENSTON: Yes, this is Ed  
25 Helvenston from the staff.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           If it's helpful for clarification, you  
2 know, the PDCs of Hermes, they apply to the non-safety  
3 systems in some cases, as well as the safety systems.  
4 And this may be discussed in some of the other PSAR  
5 chapters, but there is discussion of how some of those  
6 non-safety systems, such as the PHTS, meet associated  
7 SSC -- or associated PDCs. And there are PDCs to the  
8 effect of, you know, that non-safety systems have to  
9 be designed such that their operation, you know, or  
10 anything that could happen to them, won't interfere  
11 with a safety-related system.

12           MEMBER KIRCHNER:     Yes, well, that's  
13 standard practice, of course. It's just that we have  
14 a rather unique situation here.

15           Well, I'm not trying to help the Applicant  
16 here, but I will. I mean, the penetrations of the  
17 auxiliary systems that Greg mentioned, by and large,  
18 are on the upper reactor vessel head, so that a break  
19 in any of those systems doesn't drain the flibe from  
20 the system below the top of the active core.

21           My specific concern is how the PHTS  
22 system, which is significantly larger than all those  
23 other support systems, like the Argonne cover gas, and  
24 so on, is designed seismically, so that it doesn't  
25 threaten the integrity of the reactor vessel.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. SCHMIDT: This is Jeff Schmidt from  
2 the staff.

3 So, I used that same non-safety-related to  
4 safety-related criteria for the primary heat transport  
5 system as well. So, it can't endanger the safety-  
6 related components of the vessel. We don't know how  
7 that's designed at this point, but the assumption is  
8 that that failure does not lead to the failure of,  
9 say, the vessel, such that the flibe is kept above the  
10 active fuel.

11 I guess that will be an area, obviously,  
12 we'll look at during the OL, when we have specific  
13 design details. So, that failure cannot lead to the  
14 failure of the vessel.

15 MEMBER KIRCHNER: Right, right. I'm just  
16 flagging it now, Jeff. There, obviously, isn't enough  
17 -- or I shouldn't say, "obviously." But I didn't find  
18 in the PSAR enough detail to know what the design  
19 strategy is on this particular matter, but it  
20 certainly would be a concern at the OL stage to look  
21 at this. Thank you very much.

22 MR. LE: Okay. Next slide. Yes.

23 I want to go to quality requirements. The  
24 staff evaluation in this area, that all the safety-  
25 related SSCs are assigned to the quality-related

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 classification. This conforms to Reg Guide 1.29  
2 guidance and is acceptable to the NRC staff.

3 ASME Code, Section III, Division 5, would  
4 be used to design and fabricate the safety-related  
5 mechanical components. And the ANSI/ANS-15.8,  
6 standard 1995 edition, the Quality Assurance Program  
7 used in the earlier reactors a quality program rather  
8 than the NQA-1.

9 The methodology of loading flow  
10 combinations conform to Reg Guide 1.143, Table 3,  
11 "Design Loading Combinations." The design trends in  
12 loading and number of cycles will be included in the  
13 OL applications.

14 Staff finds that the non-condensable gas  
15 in the reactor coolant system would not cause loss of  
16 function, and then, undue risk because the design  
17 already includes inert gas (audio interference)  
18 coolant.

19 Next slide, please. For the conclusion,  
20 the staff had the regulatory findings. Staff finds  
21 that the preliminary design information is consistent  
22 with the applicable criteria in NUREG-1537.

23 Staff concludes that the information on  
24 the Hermes PSAR Section 3.6 is sufficient for the  
25 assurance of the construction permit, in accordance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 with 10 CFR 50.35 and 50.40. And further information  
2 can be reasonably left for the OL application process.

3 Now, I will take any questions for Section  
4 3.6.

5 CHAIR PETTI: Comments, Members?

6 Okay. I'm not hearing any. We're due for  
7 a break. Let us recess until 40 minutes -- oh, I have  
8 a hand up. Yes, Kairos?

9 MR. PEEBLES: Hi. This is Drew Peebles.

10 I just wanted to address some conversation  
11 that was a little back and forth on whether the PHTS  
12 was committing to a requirement to not affect the  
13 vessel during a seismic event. So, I wanted to point  
14 everyone to Section 5.1.3 in the PSAR. I'll just read  
15 it quickly.

16 "The design of the non-safety-related PHTS  
17 is such that a failure of components of the PHTS does  
18 not affect the performance of safety-related SSCs due  
19 to a design basis earthquake. In addition to  
20 protective barriers, the PHTS pipe connections to the  
21 reactor vessel nozzles have sufficiently small wall  
22 thickness, such that if loaded beyond elastic limits,  
23 inelastic response occurs in the PHTS piping which is  
24 non-safety-related. These features, along with the  
25 seismic design described in Section 3.5 of the PSAR,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 demonstrate conformance with the requirements of  
2 PDC 2."

3 So, I wanted to point that out because it  
4 sounded like we weren't sure if that was in the  
5 application or not.

6 MEMBER KIRCHNER: Drew, thank you for  
7 pointing that out. This is Walt Kirchner.

8 Yes, I saw that. And so, it sounded like,  
9 to me, the design philosophy is that you'll  
10 intentionally take a break there.

11 MR. PEEBLES: Correct.

12 MEMBER KIRCHNER: Which is an interesting  
13 design approach. What does that mean, then, for the  
14 support of the rest of the structure in terms of the  
15 rest of the loop then? I know this is Chapter 5.  
16 We're getting ahead of tomorrow. But why don't you  
17 just save that for tomorrow and I'll ask the question  
18 again?

19 MR. PEEBLES: Okay.

20 MR. GARDNER: This is Darrell Gardner.

21 CHAIR PETTI: Actually, we're not doing  
22 Chapter 5 until April 4th, I believe.

23 MR. GARDNER: This is Darrell Gardner. I  
24 wanted to add one more clarification.

25 There was a discussion about whether flibe

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 is safety-related. I just wanted to point to Table  
2 3.6-1 where the reactor coolant is identified as  
3 safety-related.

4 CHAIR PETTI: Okay.

5 MEMBER BALLINGER: We have, effectively,  
6 done Chapter 3 now, right?

7 CHAIR PETTI: No, there's Sections 3.2,  
8 3.3, 3.4, and 3.5 coming.

9 MEMBER BALLINGER: Gee.

10 CHAIR PETTI: We'll be back at 45 minutes  
11 after the hour. Thank you.

12 (Whereupon, the above-entitled matter went  
13 off the record at 10:26 a.m. and resumed at 10:45  
14 a.m.)

15 CHAIR PETTI: Okay, we're back.

16 We're going to hear about Chapter 2 and  
17 some sections on Chapter 3. Kairos, please start.

18 MR. BRYAN: Hi, Dave. This is Marty  
19 Bryan. I'm the Senior Manager for Site Licensing for  
20 Kairos, and I'll be taking us through Sections 2.1  
21 through 2.3. And then, Brian Song, our Senior Manager  
22 with Civil Structures, will be covering the remainder  
23 of the presentation.

24 Next slide, please. So, as has been  
25 mentioned, the Hermes site is located in Oak Ridge,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Tennessee. It's in Roane County and within the East  
2 Tennessee Technology Park. And the Hermes test  
3 reactor will be located on the former DOE K-33  
4 building site.

5 So, if you look at the bottom lefthand  
6 picture, we're talking about the area in the yellow  
7 circle. And just to get you oriented, the Oak Ridge  
8 National Laboratory there is off to the right. The  
9 actual city of Oak Ridge would be up to the sort of  
10 upper right there as well. And down at the bottom, we  
11 did reference some material from the Clinch River  
12 Nuclear Project, and the Clinch River site is about 3  
13 and a half miles away.

14 So, if you look at --

15 MEMBER HALNON: Hold on. The Clinch River  
16 site, is that where they did their characterization  
17 for the SMRs that they're right now thinking about?

18 MR. BRYAN: Yes, that's correct.

19 MEMBER HALNON: Okay. I might have  
20 questions later on, but that's fine. I just wanted to  
21 get a spatial. Thanks.

22 MR. BRYAN: Yes, we used some regional  
23 geology from that effort and it's about 3 and a half  
24 miles away from the Hermes site.

25 Over on the right hand side is the insert

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 there. You can see the yellow line is the boundary of  
2 our property, and you can see that the rectangular  
3 field there is the former K-33 facility, at which  
4 Hermes will be located down in the southeastern  
5 corner. And at the bottom is the former K-31  
6 facility.

7 And so, it would be, as I said,  
8 approximately 185 acres. About 30 acres of this would  
9 be permanently disturbed.

10 MEMBER HALNON: Is there any residual  
11 radioactive material there right now from the  
12 previous --

13 MR. BRYAN: Not really. I mean, it's been  
14 released for industrial use by the DOE.

15 MEMBER HALNON: Okay. So, from your  
16 perspective on decommissioning down the road, there's  
17 nothing to be concerned about? I guess that was a  
18 question rather than a statement.

19 MR. BRYAN: Not from what's there.  
20 Obviously, during decommissioning, we would have to  
21 address anything from the Hermes site itself.

22 MEMBER HALNON: Right. Okay. But when  
23 you have decommissioning, you have to, I mean, if  
24 you're going to release it -- maybe that's not the  
25 plan -- of course, you'll have to work through that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 But you have to go below the level of the foundations,  
2 and whatnot, to a certain depth.

3 And this is another question, I guess.  
4 And you're confident that there's nothing from  
5 previous facilities there that would be of concern  
6 when you get to the decommissioning of Clinch -- I  
7 mean of Hermes?

8 MR. BRYAN: That's correct, based on the  
9 information we have from the Department of Energy.

10 MEMBER HALNON: Okay.

11 MR. BRYAN: And it's been released for  
12 industrial use now.

13 MEMBER HALNON: All right. Thanks.

14 MR. BRYAN: Next slide, please.

15 So, I like this slide because it really  
16 gives you a picture of what used to be there versus  
17 what is there today. So, on the lefthand side, you  
18 can see the K-33 building. This was about a 40-acre  
19 field. So, a large structure. You can see K-31 off  
20 to the right. And then, across Poplar Creek is the K-  
21 25, which is now a National Historic Park.

22 And the K-33 building was originally  
23 constructed in 1954. The enrichment facility ceased  
24 operations in 1985. DOE began re-industrialization of  
25 the whole East Tennessee Technology Park in 1996, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 then, it's released for industrial use in 2011.

2 If you look at the picture on the right  
3 side, this is what it looks like today. It's all been  
4 reclaimed and it is a true brownfield. This rectangle  
5 is the area where Hermes will be, particularly down  
6 here in the lower southeastern corner, which you can  
7 see in another slide.

8 Next slide, please. So if you look over  
9 at the right hand side, you can see the square down  
10 there in the southeastern corner of the former K-33.  
11 That's where the Hermes site will be located.

12 So, just to cover some of the boundary and  
13 zone area details, the site boundary is defined by the  
14 area owned, leased, or controlled, and the exclusion  
15 area is defined as the area within the site boundary  
16 where the reactor site management has direct authority  
17 over all activities. Our site boundary and  
18 exclusionary boundary are coincident, as is the  
19 emergency planning zone. They're all coincident to  
20 the site boundary.

21 The low population zone is conservatively  
22 set at 800 meters from the reactor. You could see, up  
23 in the northwest corner, the nearest resident is  
24 approximately .7 miles from the boundary. And then,  
25 the PSAR includes population data five miles from the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 reactor.

2           Next slide, please. Okay. So we looked  
3 at the nearby industrial, transportation, and military  
4 facilities within five miles of the site to identify  
5 potential external hazards, such as explosions,  
6 flammable vapor clouds, toxic chemicals, and fires.  
7 And the potential external hazards within five miles  
8 were determined to not work for the analysis, with the  
9 exception of ammonia and chlorine.

10           And that's because the distance to  
11 Tennessee Highway 58 was less than the safe distance  
12 calculated for shipments. Therefore, the main control  
13 room will be designated and designed with detectors  
14 for these chemicals.

15           Regarding airports, there's no existing  
16 commercial airports within 10 miles of the site.  
17 However, a general aviation airport is proposed to be  
18 located approximately one mile southeast of the site.

19           So, we did a screening analysis for the  
20 annual probability of aircraft crashing into the  
21 facility using DOE Standard 3014-2006. And the total  
22 crash frequency for small, non-military aircraft from  
23 general aviation or helicopter operations was above  
24 the screening, except its frequency threshold.  
25 Therefore, the safety-related portion of the reactor

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 building structure will be designed to withstand the  
2 impact of small, non-military general aviation  
3 aircraft.

4 Next slide, please.

5 MEMBER HALNON: So the size of the  
6 aircraft is important. Is there enough information on  
7 the proposed airport to be able to size that aircraft  
8 that you would be using in your analysis?

9 MR. BRYAN: Yes, good question. There was  
10 an environmental assessment performed and it listed  
11 the types of aircraft anticipated for the airport.  
12 And so, we factored that into our screening analysis.

13 MEMBER HALNON: Okay.

14 MR. BRYAN: It had quite a few details  
15 about what the proposed aircraft would be.

16 MEMBER HALNON: Okay. It would be  
17 interesting to see what kind of margin you build into  
18 that, just in case the airport expands beyond its  
19 dream right now.

20 MR. BRYAN: Yes. There's no construction  
21 been started yet, but, yes, you're right, it's been  
22 postulated for some time. But if we become aware of  
23 additional details, we'll certainly factor that into  
24 the operating license application.

25 MEMBER HALNON: Got it. Thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. BRYAN: Okay. Next slide, please.

2 Okay. This slide is showing -- you know,  
3 we're going to talk about Chapter 2 and we mixed in  
4 Chapter 3. And the reason we did that is we wanted to  
5 show the relationship between the two.

6 So, in Chapter 2, we're discussing the  
7 design basis parameter input envelope. In Chapter 3,  
8 we define the methods to translate those inputs into  
9 design loads.

10 And then, in Section 3.5, we define the  
11 protections for safety-related SSCs using design  
12 loads.

13 Next slide, please. So the first one of  
14 these we're going to talk about is meteorology. As is  
15 mentioned -- sorry, was there a question?

16 CHAIR PETTI: No, keep going.

17 MR. BRYAN: Okay. So, as we mentioned,  
18 the Hermes site is located on the prior Department of  
19 Energy Nuclear Facility site within the DOE-managed  
20 Oak Ridge Reservation. And the ORR has an extensive  
21 network of meteorological towers.

22 And there was two studies done in 1953 and  
23 2011, meteorological studies. We used newer data.  
24 But these studies indicate the basic flow patterns  
25 that have been in place during the recorded weather

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 history of the ORR area.

2 And if you've been to the area, you know  
3 that it's influenced a lot by the mountainous terrain,  
4 and specifically, the Cumberland Mountains to the  
5 northwest and the Great Smoky Mountains to the  
6 southeast. And therefore, the prevailing winds in the  
7 region reflect channeling of airflow from southwest to  
8 northeast, caused by the orientation of the valleys  
9 and ridges.

10 Next slide, please. So extreme winds are  
11 based on the climatological data from Oak Ridge and  
12 Knoxville and observations from the Met Tower J and L  
13 on the ORR. And for a 100-year return period, the  
14 maximum wind speed is 90 miles an hour.

15 Now, hurricane winds are factored in.  
16 They're mainly a concern for coastal locations, but we  
17 used the contours in Reg Guide 1.221. And the  
18 probability of a tornado occurring at the site is low,  
19 based on records from the National Weather Service  
20 Morristown Tornado Database.

21 Regarding precipitation, historical  
22 precipitation data for the site was obtained from  
23 several National Weather Service and Tennessee Valley  
24 Authorities sites. Storms with ice greater than 1  
25 inch occurred five times in 50 years and storms with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 ice greater than 2 inches occurred two times in 50  
2 years. And the maximum historical snowfall event for  
3 a 40-hour period was determined to be 28 inches in  
4 Westbourne, Tennessee, which is up on the border with  
5 Kentucky. And this was back in February of 1916.

6 Next slide. So if there's no questions,  
7 I will turn it over to Brian Song, who will go through  
8 the remainder of the presentation.

9 MR. SONG: All right. Thank you, Marty.

10 This is Brian Song from Kairos Power. I'm  
11 Senior Manager in Civil Structures, and I will present  
12 Chapter 2.4, 3.2, and 3.3.

13 For Chapter 2.4, "Hydrology," the site is  
14 located near Clinch River and Poplar Creek, as you see  
15 on the right side of the graph. And TVA manages the  
16 water levels year around for dam safety and flood  
17 control to these two rivers. Both Clinch River and  
18 Poplar Creek are considered to be potential flooding  
19 resources to our site.

20 The current grade level that we have is  
21 765 feet above mean sea level. And the normal water  
22 surface level at the Poplar Creek, which is on the  
23 right side, is about 21 feet lower than our site  
24 grade.

25 Next slide, please. There's two previous

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 flood studies that we looked into. And there's one  
2 that's the FEMA Flood Insurance Study for Roane  
3 County, Tennessee. This includes 10-, 50-, 100-, and  
4 500-year return periods. All the flood level  
5 elevations from these studies indicate that the Hermes  
6 site, the flood level is below the Hermes site grade,  
7 which is 765 feet above mean sea level.

8 Another study that we looked into is the  
9 Flood Hazard Evaluation for UCOR that they updated on  
10 April of 2015. There's a large range of return period  
11 that was investigated in this study, from 25-year to  
12 100,000-year, that was modeled and estimated. The  
13 results are assessed during our review, and we are  
14 identifying the preliminary design basis flood based  
15 on these studies.

16 Next slide, please. So for the credible  
17 hydrology event that we defined as a design basis for  
18 the Hermes site, it's selected as 25,000-year return  
19 period, This is consistent with the Flood Design  
20 Category 4, FDC 4, which is a DOE-based criteria.

21 The results in a design basis flooding  
22 level for the site with using a 25,000-year return  
23 period result comes up to 759.9 feet mean sea level.  
24 This is based on these studies. And that is actually  
25 5.1 feet below the plant grade level of 765 mean sea

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 level.

2 And also, this Hermes site layout, we have  
3 some advantages, that the existing site topography  
4 shows the stormwater runoff naturally drains to the  
5 east, south, and west of the -- west to flow towards  
6 the Poplar Creek.

7 Next slide, please. So this is about  
8 Chapter 3.2 in regards to meteorological damage. The  
9 design basis of SSCs is considering meteorological  
10 damage, which includes rain, snow, wind, tornado, and  
11 tornado- and wind-borne missiles at the site.

12 And the safety-related portion of the  
13 reactor building provides protection to the safety-  
14 related systems and components from this  
15 meteorological damage. Currently, no credit is taken,  
16 based on the PSAR, no credit is taken from the non-  
17 safety-related portion of the reactor building, which  
18 is the exterior shell.

19 The design basis meteorological permit  
20 applicable to the design of the safety-related portion  
21 of the reactor building are established for normal  
22 winds and high wind modes, which includes tornado and  
23 hurricanes, and precipitation modes.

24 For the normal wind load design basis, we  
25 are following the local protocol which sites ASCE 7-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 10, and we are using Risk Category 4, which is for the  
2 hazardous substances; that includes in the building.  
3 And this is the most stringent design basis that is  
4 used in ASCE 7. So, that is used for our safety-  
5 related portion of the reactor building.

6 That results in design basis wind load  
7 velocity of 120 miles per hour, and this is based on  
8 a 1700-year mean recurrence interval, which is more  
9 conservative than the 100-year return period.

10 Also, we applied normal wind modes that  
11 are determined using ASCE 7-10, Risk Category 4, and  
12 also, Exposure Category C.

13 Okay. Next slide, please. And high wind  
14 and load are based on two Reg Guides. The first Reg  
15 Guide is 1.76, Revision 1. This determines the  
16 characteristics of the design basis tornado. And the  
17 tornado winds are determined using the same methods in  
18 ASCE 7-10 with the wind speeds from Reg Guide 1.76,  
19 Revision 1.

20 And the loads from tornado-generated  
21 missile impacts are transformed into an effective or  
22 equivalent static load consistent with NUREG-0800,  
23 Section 3.5.3, Subsection (ii), using missile spectrum  
24 and maximum horizontal speeds provided in Table 2 of  
25 Reg Guide 1.76, Revision 1.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The other guidance is Reg Guide 1.221,  
2           Rev. 0, and this design gives us the design parameters  
3           for hurricane loads. And applied hurricane wind loads  
4           are determined also using ASCE 7-10, the maximum wind  
5           speed of 138 miles per hour, and velocity pressure is  
6           based on the Reg Guide 1.221 for the site location.

7           Loads from hurricane-generated missile  
8           impacts are transformed into an effective or  
9           equivalent static load consistent with NUREG-0800,  
10          Section 3.5.3, Subsection (ii), using the missile  
11          spectrum from Reg Guide 1.221.

12          All right. Next slide, please. A  
13          precipitation note. The grading and drainage design  
14          for the site will include loads from precipitation  
15          accumulation on the ground affecting the safety-  
16          related portion of the reactor building. And the non-  
17          safety-related exterior shell of the reactor building  
18          has a slope of the roof. So, the loads due to rain  
19          accumulation are not considered as a structural load  
20          in the structural design.

21          And similarly, because of the lack of rain  
22          accumulation, the load due to ice is anticipated to be  
23          very minimal, and is, therefore, enveloped by the snow  
24          load that we're going to use. And the snow load  
25          parameters are based on Chapter 1 and ASCE 7-10, Risk

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Category 4, structures at the site location. And the  
2 snow loads that are determined are based on the ground  
3 snow load of 21.9 PSF, and we're using the same  
4 criteria, based on ASCE 7-10, Risk Category 4, for  
5 these structures.

6 MEMBER BALLINGER: This is Ron Ballinger.

7 I had a question about the ice load not  
8 having to be considered because the roof is sloped.  
9 I can tell you from personal experience that in  
10 certain temperatures, when it rains, it freezes on the  
11 roof; the ice stays on the roof.

12 MR. SONG: Yes, so we are following the  
13 local, the Code of 7-10, and the criteria based on  
14 that will be followed for the ice. It indicates it's  
15 going to be minimal. So, yes, there will be ice load,  
16 but it will be minimal, based on the Code.

17 MEMBER BALLINGER: My house is not  
18 designed to the Code.

19 MEMBER HALNON: It's also in  
20 Massachusetts.

21 (Laughter.)

22 DR. BLEY: I think that's the big thing,  
23 Ron. I've lived in Upstate New York for a while, and  
24 we had to have heating elements on the roof to prevent  
25 that sort of thing, but maybe not down here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BALLINGER: Yes.

2 DR. BLEY: It's Dennis Bley. I have a  
3 question that I've never quite understood.

4 When you look at snow loads, I think you  
5 always assume you've got a mass of snow and that's the  
6 final load. But almost anywhere, including that part  
7 of the country -- and I've lived there -- after you  
8 get a big snow, it's not uncommon, eventually, to have  
9 some light rain come. And I tell you, that snow gets  
10 a heck of a lot heavier. Do you look at that, the  
11 load of rain following the snow?

12 MR. SONG: Yes, it is considered in the  
13 Code, as mentioned below, as well. So, unbalanced  
14 snow load, snow drifts, and rain on snow, surcharge  
15 loads, are also considered, based on the Code of ASCE  
16 7. So, we will be considering that, yes.

17 DR. BLEY: Okay. I'll have to go look at  
18 that, because I in the past have gotten a different  
19 answer on this from other people. But, based on what  
20 you're doing, it kind of sounds reasonable.

21 A couple of slides back when you were  
22 talking about rain, flooding, you looked at periods  
23 like 1700 years and 25,000 years, or something like  
24 that. And clearly, there's no collected data going  
25 back to those timeframes. Did you use some form of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 paleo data to estimate if these things have happened  
2 in the distant past? How did you come up with those  
3 types of flooding numbers?

4 MR. SONG: Okay. So, I think you're  
5 mentioning the slide 2.4, if that is correct --

6 DR. BLEY: Yes, the slide number is not  
7 important, but --

8 MR. SONG: Got it.

9 DR. BLEY: Yes. There was another one  
10 after this that had a smaller number for a different  
11 kind of hydrological event.

12 But, anyway, yes. So, how do you come up  
13 with those?

14 MR. SONG: I would like to defer that  
15 question to Lori, our consultant.

16 DR. GROSS: Okay. Hi. I'm Lori Gross.

17 So, it's a complicated, sort of bigger  
18 technical response, but, in essence, we do have a  
19 historical record of floods and paleo records of  
20 floods, but, certainly, they aren't that high. The  
21 maximum floods that have been observed are on the  
22 order of, I'll say, 70- to 100-year return period  
23 floods.

24 So, what is done is a statistical -- you  
25 know, the historical data is evaluated statistically.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 There's also some hydrologic models that are used to  
2 project up into these lower-probability, higher-  
3 return-period floods. So, they are estimated through  
4 modeling. Those models are calibrated, I'll say --  
5 I'll use that word "calibrated" -- using historical  
6 records.

7 DR. BLEY: Well, I don't see how you can  
8 do this in convincing way unless you look at some  
9 kinds of paleo information.

10 DR. GROSS: It is. It is. There's a lot  
11 of information, historically, that's been collected.

12 DR. BLEY: Okay.

13 DR. GROSS: And I think that was presented  
14 in some previous slides about all the data within the  
15 Oak Ridge area. TVA has done a lot of data collection  
16 modeling for their designs and, you know, all the work  
17 that they do.

18 DR. BLEY: Okay. As long as you did that,  
19 I'm much more comfortable with it. The idea of  
20 statistically extrapolating 100 years' worth of data  
21 doesn't make any sense to me, but looking at  
22 indications in the earth and the surroundings of  
23 what's happened in the past certainly does give a  
24 basis for it.

25 But thank you.

1 DR. GROSS: Sure.

2 MEMBER HALNON: This is Greg Halnon.

3 One more piece of operating experience on  
4 your flooding aspect and the ice is ice on the roof,  
5 followed by rain, melts faster than ice on yard drains  
6 that sit in the shade. So, if you're going to credit  
7 any yard drains to help get that precipitation off,  
8 keep the timing of that in mind relative to a  
9 freeze/thaw event.

10 DR. SCHULTZ: This is Steve Schultz.

11 Just to comment, to follow up on Dennis'  
12 note, where you well could have snow following by  
13 rain. Given that you're using the maximum event  
14 associated with snow, 28 inches, and then, have rain  
15 on top of that, the 22 pounds per square foot really  
16 does seem low in that calculation. It should be a  
17 higher value for that.

18 MR. SONG: Yes. So, the value of the  
19 ground snow is there, but, yes, based on the Code, we  
20 will evaluate the correct value.

21 DR. SCHULTZ: Good. Thank you.

22 MEMBER KIRCHNER: Brian or Lori, following  
23 up on Dennis' question, do you have to look at  
24 upstream dam failures and the TVA watershed there?

25 DR. GROSS: That is a requirement.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Brian, I'm assuming you want me to answer  
2 that?

3 MR. SONG: Yes. Yes, please do.

4 DR. GROSS: Okay. Sorry.

5 Yes, this is Lori again.

6 That is a requirement and that was  
7 presented in the -- there was some of that work done  
8 in those historical studies that Brian cited that are  
9 in the PSAR. And I'm saying, yes, that is considered.  
10 It was not factored into the design basis flood, but  
11 it is part of the evaluation.

12 MEMBER KIRCHNER: I think, if I remember  
13 correctly, when we reviewed the Clinch River early  
14 site permit application, I think that was also  
15 considered in their assessment for their site, which  
16 isn't too far away from you.

17 DR. GROSS: Yes.

18 MEMBER KIRCHNER: Okay. Thank you.

19 DR. GROSS: Okay. Is that sufficient  
20 then?

21 Yes, I agree with you that is a big --  
22 that is a standard requirement, to look at flooding  
23 hazards due to precipitation and, separately,  
24 hypothetical, I'll say, simulated dam failures.

25 MEMBER DIMITRIJEVIC: This is Vesna

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Dimitrijevic.

2 I just have one comment just to let you  
3 know that -- are you saying that this will be  
4 addressed in the OL, the rain on the snow and snow  
5 movement after construction is finished and the slopes  
6 of the roofs?

7 I just want to make something for good  
8 keeping. They didn't make it to say it is one of the  
9 OL expectations. So, it's critically missing. So, it  
10 would be nice to audit. Okay?

11 MR. SONG: Sounds good.

12 All right. So, I'll continue.

13 Next slide, please. All right. So, the  
14 safety-related portion of the reactor building  
15 considers load from both external and internal  
16 flooding events.

17 For the external flooding event, there's  
18 no pose of hydraulic load because the grade elevation  
19 is above the design basis flood elevation determined  
20 in PSAR Section 2.4.

21 And the internal postulated events  
22 consider the water resources within the safety-related  
23 portion of the reactor building.

24 So, it will be discussed in Section 3.5,  
25 but the safety-related SSCs are protected from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 internal flooding. For instance, the safety-related  
2 SSC that are vulnerable to flooding are elevated or  
3 shielded, or otherwise protected from spray. And this  
4 includes the flibe-bearing components.

5 Design features direct water flow and  
6 prevent it from entering enclosures containing safety-  
7 related SSCs. And the volume of the water in the  
8 safety-related portion of the reactor building is  
9 limited by the design. And the water systems that  
10 cross the base isolation mode automatic or manual  
11 termination of flow will be specified in the operating  
12 license application.

13 So, I think that ends my slides.

14 CHAIR PETTI: Okay. Oh, go ahead.

15 MEMBER BIER: Yes, I have a question going  
16 back to Chapter 2. I don't think we need to put the  
17 slides back up.

18 But, in Chairman Rempe's absence, she  
19 encouraged me to take a look at the population  
20 projections. And it looks like, based on demographic  
21 data for the counties, you folks are predicting a  
22 decline in population, which seems to be accurate.  
23 The 2020 Census has a smaller population than 2010,  
24 and, you know, not unexpected in a sort of rural area.

25 But, within the five-mile radius, there

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 are a number of new facilities going in -- airport,  
2 Clinch River pharmaceutical company, et cetera. So,  
3 the daytime population in those areas may actually be  
4 going up quite a bit.

5 And I understand the reasons for wanting  
6 to rely on kind of official published demographic  
7 data, rather than doing your own estimates, but, in  
8 this case, it may not be too realistic to do that, you  
9 know, within the five-mile boundary. So, I just  
10 wanted to raise that as a household issue.

11 MR. BRYAN: Yes, this is Marty Bryan.

12 Yes, that's a good point. We will look at  
13 that in the operating license application to see if  
14 there's an update.

15 MEMBER BIER: Okay. Thank you.

16 CHAIR PETTI: Okay. I don't see any other  
17 hands up.

18 So, staff.

19 MR. HELVENSTON: Our presenters for this  
20 section are virtual. So, I believe you're going,  
21 first, Amit. So, I'll turn it over to you.

22 MR. GHOSH: Yes. Thanks, Ed.

23 Good morning, everybody.

24 My name is Amit Ghosh, and I will start  
25 the presentation of the staff review of PSAR Sections

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 2.1 through 2.4 and 3.2 and 3.3.

2 I am from the Division of Engineering and  
3 External Hazards of the Office of Nuclear Reactor  
4 Regulation.

5 Next slide, please. I will be presenting,  
6 first, to the 2.1, "Geography and Demography," and  
7 2.2, "Nearby Industrial Transportation and Military  
8 Facilities." And I will come back at the end to  
9 present 3.2 and 3.3 on behalf of my colleague who did  
10 the actual review, Bryce Lehman. I'll just present it  
11 because, unfortunately, he is not able to make it in  
12 the morning. He'll be there in the afternoon.

13 Next slide, please. So, first, I have  
14 listed the regulatory vessels which we have used in  
15 this review, 50.34(a), 50.35, 50.40, and 100.10, and  
16 we used the Standard Review Plan and NUREG-1537.

17 For Section 2.1 only, we also used  
18 10 CFR 100.11(a) for determination of exclusion area,  
19 low population zone, and distance to nearby population  
20 centers. We also used Reg Guide 2.6, Rev. 2, and  
21 ANSI/ANS 15.16, "Emergency Planning for Research  
22 Reactors."

23 For Section 2.2, we used Reg Guide 1.21 to  
24 evaluate the determination of explosions postulated to  
25 occur at nearby facilities or a transportation route.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1           Next slide, please. So you have in the  
2 morning, a few minutes back, Kairos' presentation,  
3 very nice pictures of the site location. It is the  
4 old K-31 and K-33 facility of the Oak Ridge  
5 Reservation Gas Diffusion Plant which was used to  
6 enrich uranium at one time.

7           The site near the reactor is relatively  
8 flat. We reviewed the exclusion area boundary, low  
9 population zone, emergency planning zone, and we found  
10 they are reasonably done.

11           We also looked into the nearby population  
12 center. And based on 2020 Census, the city of Oak  
13 Ridge is the one within -- because the definition of  
14 population center more than 25,000 residents. So, the  
15 city of Oak Ridge has 31,402 residents at Census. And  
16 it turns out this site also is within the city limits,  
17 but, as we discussed, the nearby resident is about .7  
18 miles away.

19           There is very low population close to the  
20 facility. Most of the people live at the northeast  
21 corner of the map which was shown before. So, we  
22 measured the distance and we found the site also  
23 passes the NRC criterion, 1 and one-third of the EPZ  
24 for the nearest population center.

25           And we checked the population projection

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 which Kairos used from the Boyd Center for Business  
2 and Economic Research of Tennessee, which is a  
3 reliable organization.

4 Next slide, please. Is there any question  
5 on 2.1? Because that's all I have to present.  
6 Otherwise, I will go to 2.2.

7 CHAIR PETTI: Keep going.

8 MR. GHOSH: Okay. Kairos has used the  
9 Site Safety Analysis Report, SSAR, of the Clinch River  
10 Nuclear Site ESP application. They used their  
11 analysis because very similar things are here.

12 And as Marty discussed a few minutes back,  
13 there is a new airport proposed to be constructed very  
14 close to this site. That's called -- the name is Oak  
15 Ridge Airport. It is supposed to be -- construction  
16 is supposed to start next year, 2024.

17 And if you look into this map, you can see  
18 the Clinch River and the Kairos Hermes site. There is  
19 a highway, Tennessee 58. The runway will be parallel  
20 to that. So, it is about less than a mile from the  
21 reactor site.

22 And what we understand is that this new  
23 airport, it will be a general aviation airport, mostly  
24 for the business jets, people coming to Oak Ridge, and  
25 doing their business, and going back. Ninety-seven

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 percent of the flights are estimated to be general  
2 aviation aircraft. Only about 3 percent will be  
3 helicopters, which may be local, and very few, and  
4 used for spraying or medical purposes. So, for design  
5 purposes, this general aviation airport will be a  
6 light one. And I'll talk a little bit more about that  
7 in the next slide.

8 Next slide, please. So Kairos has looked  
9 into the possible or potential detonation of high  
10 explosives, the explosion of chemical vapor clouds,  
11 release of toxic chemicals, and fires while being  
12 transported nearby to highways, railways, waterways,  
13 or carried in pipelines, or when they are stored at  
14 the nearby facilities.

15 They assessed the potential hazard area  
16 and checked each of them, whether the distance is  
17 enough not to be a credible hazard; whether the  
18 quantity of hazardous material released is so small  
19 that it doesn't a big difference, any much of a  
20 difference, or the potential consequences are  
21 tolerable.

22 Based on their analysis -- and we have  
23 gone through those analyses and agreed that -- the  
24 potential release of chlorine and anhydrous ammonia,  
25 when being transported very close to this Highway 58,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Tennessee 58, could be a problem to the main control  
2 room. So, they will be equipping the ventilation  
3 system at the main control room with chlorine and  
4 ammonia detectors.

5 We also looked into -- I mean they also  
6 looked into the potential annual frequency of aircraft  
7 crashes while landing or taking off from this future  
8 Oak Ridge Airport. We checked the FAA database and  
9 they are listing it as a new airport coming in soon.

10 The FAA -- or DOE environmental  
11 assessment, as Marty has talked a few minutes back,  
12 and they have identified which craft, 500 aircraft is  
13 the typical one which they considered in designing the  
14 runway, and, also, my guess is that would be a very  
15 nice and appropriate aircraft to use in our design  
16 process of the structure.

17 As Kairos has already said, the site  
18 doesn't pass the initial screening criterion. So,  
19 they will be designing the safety-related portion of  
20 the reactor building to withstand a crash. So, in the  
21 OL application, we'll be looking at the loads taken  
22 and other details.

23 So, these are my findings and that is also  
24 the regulatory findings, that we found the information  
25 present in PSAR Section 2.2.1 and 2.2 is sufficient

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 and meets the applicable guidance and regulatory  
2 requirements to issue a construction permit, in  
3 accordance with 10 CFR 50.35.

4 MEMBER HALNON: Amit, this is Greg Halnon.

5 In the aircraft crash into the reactor  
6 building, if that's going to be in the design basis,  
7 the ensuing fire is still, in my mind, part of that.  
8 And previously, we didn't ask -- we didn't require  
9 that requirement because 10 CFR 50.155, or something  
10 up in that range, was not required for that facility.

11 As you get to the operating license, I  
12 would encourage you to ask the question, or at least  
13 internally, whether or not the ensuing fire is a  
14 concern and to make sure that that site will be able  
15 to withstand that.

16 MR. GHOSH: Yes. And I give a very good  
17 example of 9/11, the twin towers. Yes, they got hit,  
18 physically damaged by the crashing aircraft, but the  
19 whole structure collapsed because of the actual fire,  
20 the heat, the thermal part of it, based on the  
21 analysis done by NIST after that.

22 So, when the time comes, we'll be asking  
23 all those questions and look at it. And I have to,  
24 obviously, rely on my structure colleagues, thermal  
25 areas, on that one.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: And the fire protection.

2 MR. GHOSH: Yes, fire protection.

3 MEMBER HALNON: Thank you.

4 MR. GHOSH: Thank you.

5 MEMBER BIER: I have another question.

6 This is Vicki Bier.

7 With regard to the chlorine and ammonia  
8 detectors -- again, this is kind of more of a question  
9 probably for the operating license phase -- but is it  
10 anticipated that control room operators could evacuate  
11 and leave the facility in a safe condition? Or do we  
12 need a system that can somehow isolate the control  
13 room for a period of time, so they can remain there?  
14 Do you know what's anticipated for operation under  
15 those conditions?

16 MR. GHOSH: Yes, very good question. At  
17 this moment, with the kind of details we have, I  
18 cannot answer this question. All we know, like this  
19 facility, the main control room may be affected if  
20 there is a chlorine and ammonia spill very closeby.  
21 So, once the time comes, we are going to look into  
22 that, the design of it and how -- all the details.

23 MEMBER BIER: Sure. Is that something  
24 that Kairos wants to comment on at this moment?

25 MR. PEEBLES: We don't have any comment at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 this time.

2 MEMBER BIER: Yes.

3 MR. PEEBLES: We'll provide more details  
4 at the OLA phase.

5 MEMBER BIER: Okay. Thank you.

6 MR. PEEBLES: Sorry. That was Drew  
7 Peebles, Senior Licensing Manager.

8 MR. GHOSH: Is there any other question  
9 for me?

10 Then, I will hand it over to the next  
11 presenter on Section 2.3, "Meteorology."

12 MR. WHITE: Thanks, Amit. Good morning.  
13 My name is Jason White. I'm a Meteorologist in the  
14 External Hazards Branch here at the NRC.

15 Today, I will be discussing Section 2.3 of  
16 the application which focuses on the site  
17 characteristics related to meteorology.

18 The regulatory basis for the review of  
19 this section was mentioned previously in the  
20 presentation. In addition, the staff used the  
21 guidance of NUREG-1537, Part 2, Section 2.3, which is  
22 the section focusing on meteorology.

23 The Applicant provided information related  
24 to the original climatology and local meteorology of  
25 the proposed site. Information in these sections

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 included the site characteristics related to wind,  
2 temperature, precipitation, atmosphere stability, and  
3 various extreme weather conditions.

4 The NRC staff reviewed a description of  
5 the general climate of the region and the  
6 meteorological conditions relevant to the design and  
7 operation of the facility. This included the staff  
8 reviewing the various data resources and the  
9 analytical approaches used by the Applicant to prepare  
10 the information.

11 Based on this review, the NRC staff  
12 concludes that the site characteristics associated  
13 with the regional climatology and local meteorology  
14 are representative of the region at the proposed site,  
15 and therefore, acceptable for use in evaluating the  
16 conditions at the site.

17 Next slide.

18 MEMBER HALNON: Hey, Jason, this is Greg  
19 Halnon.

20 Did you, in your review, compare what the  
21 ESP was with Clinch River, since it's so close? I  
22 mean, did they use all the appropriate HMRS and  
23 whatever analytical models were out there to make sure  
24 they're at least within the ballpark of the facilities  
25 there nearby?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MR. WHITE: What was the first part of  
2 your question? I missed it. I'm sorry.

3 MEMBER HALNON: I mean, clearly, there had  
4 to be some met data from the ESP at Clinch River,  
5 which isn't too far away. And I realize that, from a  
6 flooding perspective, it's closer to a river, and  
7 whatnot. But, for the intense, you know, the  
8 precipitation models and storms and transpositions,  
9 and all that stuff, was that compared to what the  
10 Clinch River ESP had done?

11 MR. WHITE: I didn't necessarily compare  
12 it to the Clinch River data, but we did look at the  
13 representative data from the National Weather Service  
14 and other local data sources within the region. I'm  
15 sure it's probably similar to the data that they  
16 actually pulled from Clinch River.

17 MEMBER HALNON: Okay. So, if we compare  
18 the two, we shouldn't see anything that's way out  
19 different from a precipitation, intense precipitation,  
20 or storm transposition aspect?

21 MR. WHITE: Correct. I think that it  
22 should be similar. I'm not sure exactly in terms of  
23 the distance between the two, if there are any  
24 topographical effects that would change what we would  
25 expect to see, but, overall, for the site, since

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 they're in the same general area, I would expect to  
2 see similar results.

3 MEMBER HALNON: You know, I think it was  
4 only three-plus miles, 3 and a half miles away. So,  
5 okay. I'll take a look. It's more of a curiosity.

6 MR. WHITE: Okay.

7 MEMBER HALNON: Because there would be a  
8 lot of work that had already been done on the ESP that  
9 should be applicable here. Thanks.

10 MR. WHITE: Yes. So, on this slide, the  
11 Applicant also provided information related to the  
12 meteorological monitoring program and atmospheric  
13 dispersion modeling at the proposed site.

14 Information in these sections included a  
15 description of the location and measurements taken at  
16 the network of meteorological towers, as well as the  
17 methodology used for the atmospheric dispersion  
18 modeling.

19 The NRC staff reviewed the information  
20 describing the network of meteorological towers and  
21 their measurement capabilities. The staff reviewed  
22 the data taken from the towers to support the  
23 dispersion analysis at the proposed site and the  
24 methodology, inputs, assumptions used in the short-  
25 term atmospheric dispersion analysis.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           For the long-term atmospheric dispersion  
2 analysis, Kairos states in the PSAR that modeling for  
3 the routine releases will be provided in the operating  
4 license application.

5           Based on this review and its confirmatory  
6 analysis of the atmospheric dispersion factors, the  
7 NRC staff concludes that Kairos' meteorological  
8 monitoring program is acceptable; that the  
9 meteorological dataset provided is representative of  
10 the proposed site, and sufficient to support  
11 dispersion analysis, and that Kairos' short-term  
12 atmospheric dispersion analysis and calculated  
13 dispersion factors for the EAB and outer boundary of  
14 the LPZ are also acceptable.

15           Next slide. The NRC staff concludes,  
16 based on a review of the information provided in the  
17 application, subsequent RAI responses and the staff's  
18 technical evaluation, that the information related to  
19 meteorology in the Hermes PSAR Section 2.3 is  
20 sufficient and meets the applicable guidance and  
21 regulatory requirements for the issuance of a  
22 construction permit, in accordance with 10 CFR 50.35.

23           Further information on meteorology,  
24 namely, the details regarding the long-term dispersion  
25 modeling for routine releases, can reasonably be left

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 for later consideration in the operating license  
2 application.

3 So, that concludes the presentation on  
4 meteorology. Are there any further questions before  
5 I turn it over to Yuan?

6 CHAIR PETTI: Keep going.

7 MR. CHENG: This is Yuan Cheng. I'm a  
8 hydrologist of the NRC. I am a hydrologist and  
9 responsible to evaluate the Hermes site safety  
10 evaluations related to the PSAR Section 2.4,  
11 "Hydrology."

12 The Applicant provided information on the  
13 following. The staff evaluated the hydrologic  
14 descriptions and historical flood records. The staff  
15 finds the design basis floods is the result of the  
16 flood hazards analysis, based on the industry-accepted  
17 methods.

18 The staff evaluated hypothetical dam  
19 failures in the upstreams. The staff finds such an  
20 event is highly unlikely for the four years  
21 operational life of the Hermes reactor. This finding  
22 is based on TVA providing the dam inspections and  
23 performing dam maintenance for TVA dams.

24 The staff evaluated the groundwater and  
25 finds the groundwater is protected, based on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 following: the groundwater levels, in general, it's  
2 about 10 feet below the grade of the Hermes site.  
3 There is no groundwater extraction and injection to  
4 operate the Hermes reactor.

5 The (audio interference) of the reactor  
6 coolant is confined in the plant building. The  
7 fission products, such as tritium, are monitored and  
8 confined in the plant.

9 And environmental monitoring program will  
10 be implemented to detect any radiological releases  
11 beyond normal operational release.

12 Next slide, please. The staff finds the  
13 Hermes site elevations provides approximately 5-foot  
14 safety margins above the design basis for elevation  
15 for the stream and river floods. The design basis  
16 flood elevation for the stream and river floods is  
17 higher than FEMA's 5 feet of flood elevation by  
18 approximately 10 feet.

19 The site presents no significant risk to  
20 the Hermes facility due to the postulated flood  
21 events.

22 The facility's design basis includes  
23 mitigation and prevention of uncontrolled leakage or  
24 loss of the reactor coolant to groundwater and Service  
25 water.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   Based on the above findings, the site  
2 hydrology demonstrates that the Hermes site is an  
3 adequate site to support facility design basis and  
4 satisfies the applicable acceptance criterias of  
5 NUREG-1537, Part 2, Section 2.4.

6                   Next slide, please.

7                   MEMBER HALNON: Yuan, this is Greg Halnon  
8 again. Are all those conclusions going to be  
9 confirmed with site characterization? Or has that  
10 already been done?

11                  MR. CHENG: It's already done.

12                  MEMBER HALNON: Okay. So, we know for a  
13 fact that the 10 feet --

14                  MR. CHENG: Yes.

15                  MEMBER HALNON: -- below the grade --

16                  MR. CHENG: Yes.

17                  MEMBER HALNON: And when you say, "below  
18 the grade," is that below the lowest point of the  
19 buildings from a (audio interference) perspective or -  
20 -

21                  MR. CHENG: The site is flat. I believe  
22 that the floor elevation maybe has a couple of inches  
23 above the current grade, because they will have  
24 constructions, like a concrete slab. In general, in  
25 the construction, they may have 9 or 6 -- 6 inches to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 9 inches is the floor thickness. So, they will be  
2 above the grade by that, the levels. So, in general,  
3 the 10 feet above the 500-year flood is correct.

4 MEMBER HALNON: That's a generalization --

5 MR. CHENG: Yes. Yes, it may be plus or  
6 minus .5 feet.

7 MEMBER HALNON: Okay. Thank you.

8 MR. CHENG: The staff findings, there is  
9 reasonable assurance that the preliminary information  
10 conforms with 10 CFR 110 and supports 10 CFR 50.34 by  
11 providing flood hazards analysis and site evaluation  
12 factors.

13 The staff concludes the information of  
14 hydrology in Hermes PSAR Section 2.4 is sufficient and  
15 meets the applicable guidance and the regulatory  
16 requirements identified in these sections for the  
17 issuance of a construction permit, in accordance with  
18 10 CFR 50.35. And additional information on hydrology  
19 can reasonably be left for later consideration in the  
20 operating license application.

21 This is the end of my presentation. Do  
22 you have any other questions?

23 I will pass the next presentation to my  
24 colleague, Amit.

25 MR. GHOSH: Hi. Thank you, Yuan

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           This is Amit Ghosh again. I'll be talking  
2           on behalf of the reviewer, Bryce Lehman, on PSAR  
3           Sections 3.2 and 3.3, "Meteorological and Water Damage  
4           Review."

5           As we heard a few minutes back, all the  
6           safety-related structures are designed to withstand  
7           meteorological loads and the water loads, including  
8           internal and external floods.

9           Next slide, please. So, there are three  
10          regulatory bases which we used in this review:  
11          50.34(a), 50.35, 50.40, and there is an approved  
12          design Topical Report, Technical Report, Primary  
13          Design Criteria 3 -- sorry -- 2, Design Vessels for  
14          Protection against Natural Phenomena in the Approved  
15          Report KP-TR-003-NP, the (audio interference) version.

16          And we used the relevant guide NUREG-1537,  
17          Section 2.2, "Meteorological Damage," and Section 2.3,  
18          "Water Damage."

19          Next slide, please. We have verified that  
20          the structural loads are approved for rain, snow, and  
21          wind using the ASCE guidance 7-10 with the Risk  
22          Category Structure 4, the highest risk category. The  
23          tornado wind loads and the associated missiles come  
24          from our Reg Guide 1.76 for Region I. For hurricane  
25          load, the Reg Guide 1.221 gives the appropriate wind

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 speed and, also, the missile characteristics. So,  
2 those have been taken into account in designing that.

3 And we also find in our review what are  
4 the flooding-related loads. They are appropriately  
5 propagated from Chapter 2 review. The reactor  
6 building, the safety-related portions were designed in  
7 accordance with National Standard or American Concrete  
8 Institute 349 and American Institute of Steel  
9 Construction ANSI/AISC N690 -- very, very widely used  
10 that. And we also considered it to meet the Primary  
11 Design Criteria 2.

12 Next slide, please. As Yuan and Kairos  
13 just presented, the extended flood level will be below  
14 the grade of this structure. All the SSCs important  
15 to safety will not be below that. And there will be  
16 grading which will try to take the water away from the  
17 reactor, which, generally, everybody uses -- like  
18 don't want the water to be near the basement.

19 So, we'll be reviewing the site features  
20 and the design, how that thing will be carried out.  
21 And there will be limited water available to minimize  
22 the potential for internal flooding. The SSCs in the  
23 building will be (audio interference). There is not  
24 much of flooding issues. And there will be,  
25 obviously, drains to minimize that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           We will be reviewing the specific details  
2 of the layout and the amount of water that may have  
3 the potential to be released during the OL review  
4 phase.

5           Next slide, please. So in conclusion, the  
6 safety-related portions of the reactor building are  
7 designed for good, appropriate codes and standards.  
8 Meteorological data has been appropriately provided  
9 from Chapter 2 to design this facility, and the  
10 meteorological and the hydrological, both water and  
11 the weather-related.

12           The specific design details will be  
13 reviewed during the OL phase.

14           Next slide, please. So we found, with  
15 reasonable assurance, that the preliminary information  
16 provided in the PSAR, these two sections, conforms  
17 with 10 CFR 50.34(a)(iii), by providing information  
18 related to the materials of construction, general  
19 arrangement, approximate dimension, which is  
20 sufficient to provide reasonable assurance that the  
21 final design will conform to the design basis.

22           The staff concludes the information  
23 presented in these two sections, 3.2 and 3.3, is  
24 sufficient and meets the applicable guidance and  
25 regulatory requirements identified in the issuance of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the -- ready and can issue the construction permit, in  
2 accordance with 10 CFR 50.35, and that information can  
3 reasonably be left for the OL application for us to  
4 review.

5 With this, I conclude my presentation on  
6 behalf of my colleague. And whatever questions you  
7 have, I will try my best to answer them.

8 CHAIR PETTI: Any questions, Members?

9 MEMBER KIRCHNER: Amit, this is Walt.

10 MR. GHOSH: Yes?

11 MEMBER KIRCHNER: This is more for Kairos.  
12 I meant to ask this earlier. I think this is the  
13 case, but I'll ask it specifically. Is the decay heat  
14 removal system enveloped by the safety-related portion  
15 of the reactor building? And it's a leading question  
16 because, in other advanced designs, the decay heat  
17 removal systems that were also thermal siphon designs  
18 had vulnerabilities to external hazards, like wind-  
19 driven missiles and aircraft.

20 MR. PEEBLES: This is Drew Peebles with  
21 Kairos.

22 Yes, the safety-related portions of DHRS  
23 are in the safety-related portion of the reactor  
24 building.

25 MEMBER BROWN: What about the water tank?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER KIRCHNER: Yes, that was the  
2 question.

3 MEMBER BROWN: That feeds the DHRS.

4 MR. SONG: Yes, that is also included in  
5 the safety-related portion.

6 This is Brian Song.

7 MEMBER BROWN: Okay. This is Charlie  
8 Brown following up with Walt. Sorry. Sorry to  
9 interrupt you, Walt.

10 MEMBER KIRCHNER: Yes. Excellent. Okay.  
11 Thank you.

12 CHAIR PETTI: Okay. Then, hearing no more  
13 questions, we're only three minutes behind. It's time  
14 for lunch. So, we will again recess, and we will be  
15 back at 12:45 Eastern to start with Section 2.5, 3.4,  
16 and 3.5. And then, we'll do Chapters 2 and 3 memos,  
17 and then, get into Chapter 4. Thank you all.

18 (Whereupon, the above-entitled matter went  
19 off the record at 11:49 a.m. and resumed at 12:49  
20 p.m.)

21 CHAIR PETTI: Let's get going. Kairos,  
22 you're up.

23 MR. SONG: All right, thank you.

24 This is Brian Song again, from Kairos  
25 Power. I'm a senior manager civil structures. I hope

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 you guys all enjoyed your lunch. Let me continue with  
2 Chapter 2.5, 3.4 and 3.5

3 Next slide, please. So, yeah, as Marty  
4 mentioned, Chapter 2 and Chapter 3 are kind of  
5 related. And Chapter 2 defines the design basis and  
6 parameters.

7 And Chapter 3 defines the methods of  
8 transferring it to the design mode. And that all goes  
9 to Chapter -- sorry, Section 3.5 which will define how  
10 these goals are being protected, how the SSCs are  
11 being protected by, by the design modes.

12 Next slide, please. So Section 2.5 talks  
13 about geology, seismology, and geotechnical  
14 engineering. They characterize the geologic,  
15 geophysical effects and, again, geotechnical aspects  
16 of the region and seis -- to develop a seismic design  
17 basis for the facility.

18 Hermes PSAR relies on existing information  
19 from the Clinch River Early Site Permit application  
20 for the regional and local geologic description, with  
21 supplement information as needed. And that covers 200  
22 miles around the site.

23 Also, the Clinch River nuclear site is  
24 very close to the Hermes site, which is about 3.5  
25 miles. So, we share the same regional geology.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The Hermes probabilistic sites and hazard  
2 analysis is also adapted for the -- from the Clinch  
3 River Early Site Permit application, PSHA supplemented  
4 with consideration of the current site and the  
5 publications for the site and regional area are  
6 considered.

7           The PSHA methodology is an enhancement  
8 over the guidance of NUREG-1537. And also the Clinch  
9 River nuclear site PH -- PSHA meets ANS 2.29 criteria.

10           Okay, next slide, please. Talking about  
11 the site geology, the Clinch River nuclear site's  
12 geology information does -- are applicable to our site  
13 since it's in close proximity. But a subsurface  
14 stratigraphy is -- was also developed for Hermes site  
15 from geotechnical boring that we performed.

16           And the placing at the facility on the  
17 site was also informed by the geotechnical information  
18 that we gathered.

19           Next slide, please. For the vibratory  
20 ground motion, the Clinch River PSHA, we used it, we  
21 used the Clinch River PSHA to develop the site and the  
22 design response spectra. And the analysis relies on  
23 the information from, also from the Clinch River Early  
24 Site Permit, Early Site Permit application, with  
25 supplements.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The use of the Clinch River Early Site  
2 Permit application on PSHA is both appropriate and  
3 reasonable give that we are pretty close to between  
4 Clinch River and the Hermes site.

5           The seismic source transition is based on  
6 the Central and Eastern United States seismic source  
7 characterization report. And the design response  
8 spectra meets ASCE 43.19 and uses Seismic Design  
9 Category 3 for the safety-related SSCs, which is  
10 appropriate for a non-power reactor application.

11           Okay. And you can see the graph on the  
12 right side. And the performance goal we are aiming is  
13 1E to the minus 4, which is SDC-3.

14           Next slide, please. For the subsurface  
15 deformation, this information also relies, we will  
16 also rely on the Clinch River Early Site Permit  
17 application, supplemented by the site-specific  
18 assessments, with potential -- with a potential of  
19 sinkholes, faults, or soil liquefaction.

20           Given the conditions that we discussed  
21 over the foundation interface plans along with fill  
22 placement, there is, there is no potential for  
23 liquefaction at the site. Only inactive surface  
24 faults have been documented within the site area. And  
25 the foundation rock for Hermes reactor is at depth at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 which no evidence of karst dissolution was encountered  
2 -- is encountered.

3 Okay. Next slide, please. For the  
4 foundation interface, as you can see on the right  
5 side, the foundation layout has been established based  
6 on what we know, has been -- based on the knowledge of  
7 the site surface conditions gathered from historical  
8 documents, and also Clinch River Early Site Permit  
9 application, and also the subsurface boring  
10 exploration that we did.

11 The bearing system for the safety-related  
12 structure is a foundation mat resting on concrete fill  
13 over the bedrock that you see on the right side.

14 Okay.

15 MEMBER HALNON: This is Greg.

16 On the comparison to the Clinch River, is  
17 the soil subsurface the same in the -- I thought the  
18 Clinch River site was right on the river, and this is  
19 quite a ways away. Does that make any difference? Or  
20 is that comparable?

21 MR. SONG: Thanks. Thank you for that  
22 question.

23 I'll rely on one of my consultants.  
24 Antonio, if you can.

25 MR. FERNANDEZ: Sure. Sure.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1                   Hi. This is Antonio Fernandez. And I  
2 help Brian with geotechnical and seismic issues.

3                   Yes, that's a good question. Well, in  
4 terms of specifically what's beneath the site itself,  
5 of course they are different locations and the soil  
6 contents are going to be different. So, what we  
7 didn't, we didn't rely on the RN on Clinch River for  
8 the specific soil beneath Hermes.

9                   So, there's a due diligence investigation  
10 and boring investigation to define the soil profile  
11 here. So, yeah, in this specific case, this specific  
12 picture it's standalone. It's not relying on Clinch  
13 River.

14                   MEMBER HALNON: Okay. So, Clinch River  
15 informed the --

16                   MR. FERNANDEZ: Right.

17                   Other, other aspects, like, Brian  
18 mentioned, like the regional geology, which is kind of  
19 a more, much more wider area where there's probably  
20 six sites in the analysis, that is, that is reliant on  
21 Clinch River. But this is very specific to Hermes.

22                   MEMBER HALNON: Okay, thank you.

23                   MR. FERNANDEZ: Uh-huh.

24                   MR. SONG: All right, thank you.

25                   Any other questions? Or I can proceed to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 3.4.

2 MEMBER HALNON: Go on.

3 MR. SONG: Okay, right.

4 So, Chapter 3.4 discusses about the  
5 seismic. And we are using the graded performance  
6 based approach from ASCE-43.19 in our design to use  
7 the design to protection for the safety-related SSCs  
8 from the design basis earthquakes.

9 The safety-related SSCs are designed to  
10 SDC-3. Some safety-related SSCs are designed to the  
11 local building code, which is consistent with the  
12 NUREG-1537 and IAEA TECHDOCS. That is mentioned here.

13 The return period associated with the  
14 design basis ground motion corresponding to SDC-3 is  
15 similar to the maximum earthquake specified in  
16 building codes with a 2 percent probability of  
17 exceedance in 50 years. And this is consistent with  
18 the NRC approvals for other non-power reactors.

19 And it has also additional margin exists  
20 due to the short period of operation time that we have  
21 for Hermes.

22 Seismic performance criteria --

23 CHAIR PETTI: But just a question.

24 MR. SONG: Yes. Go ahead.

25 CHAIR PETTI: That 2 percent, that's 4

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 times to the minus 4. In your earlier sites you had  
2 10 to the minus four as a SDC-3 performance goal. Am  
3 I mixing up numbers?

4 MR. SONG: Correct.

5 DR. KOSBAB: Brian, would you like me to  
6 speak to that?

7 MR. SONG: Yes.

8 DR. KOSBAB: Okay. Hi. I'm Ben Kosbab,  
9 seismic and structural consultant helping Brian and  
10 others at Kairos.

11 What you saw on the previous slide about  
12 10 to the minus 4 was the structural performance  
13 target attached to reliability of the structure and  
14 the return period of the earthquake, or the annual  
15 exceedance rate to the earthquake.

16 Here, the 2 percent probability of the  
17 exceedance in 50 years is referring to the earthquake  
18 return period.

19 CHAIR PETTI: Okay.

20 MR. SONG: Okay. All right, so, I'll  
21 continue.

22 The seismic performance criteria are  
23 consistent with ANS 15.7, which is reactor, research  
24 reactor site evaluation.

25 The 5 percent damped horizontal and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 vertical design response spectra are developed  
2 consistent with ANS 2.29, using the design response  
3 spectra as defined in Section 2.5.

4 The structural design of non-safety  
5 related SSCs is performed in accordance with the 2012  
6 International Building Code and the Tennessee Building  
7 Code.

8 Okay. Next slide, please. The analysis  
9 models, we will be developing a 3-D fine element model  
10 for safety-related structures that will be used for  
11 seismic analysis. And that is consistent with ASCE  
12 4.16.

13 Cracking analysis applies based on ASCE  
14 4.16, Table 3-2.

15 Structural damping applies based on ASCE  
16 4.16, Table 3-1.

17 The structural mass captures self-weight  
18 of structural elements as well as portion of the  
19 design live loads and the design of uniform snow load.

20 The model uses three component seismic  
21 inputs to develop the structural forces and end  
22 structure of the response spectra. This is used for  
23 SDC 3 structural and equipment qualifications as well.

24 The seismic response analysis meets ASCE  
25 4.16, Chapter 4, using deterministic linear analysis.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The soil structure analysis will be  
2 consistent with ASCE 4.16, Chapter 5.

3           Okay. Next slide, please. For seismic  
4 instrumentation, seismic instrumentations will be  
5 installed for monitoring seismic events. And triaxial  
6 time history accelerometers will be located in the  
7 pre-field and in the safety-related portion of the  
8 reactor building.

9           Okay. Next slide, please. So, okay, so  
10 to explain a little bit about the reactor building  
11 here. Currently in the PSAR it is 200 feet long and  
12 100 feet wide.

13           The roof is not shown here, but it is, it  
14 will be a sloped roof.

15           And the safety-related portion of the  
16 building uses base isolation, which is a spring,  
17 spring-backed element type isolators.

18           And as you see here, the right side is the  
19 reactor cell, which includes vessel, applied  
20 inventory, and heat reduction regulator, PSAR. And  
21 the fuel cell includes the PHSS, which is the pebble  
22 handling and storage system. And spent fuel storage  
23 will be on the fuel cell side.

24           And these will be base isolated.

25           The other buildings, including the building that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 is, that houses the main control room, are non-safety  
2 related, so.

3 Next slide, please. All right. The  
4 safety functions of the safety-related portion of the  
5 reactor building does protect, does protection of  
6 safety-related SSCs from design base natural phenomena  
7 and external hazards.

8 The structural support for the safety-  
9 related SSCs is located on the safety-related portion  
10 of the -- are located in the safety-related portion of  
11 the reactor building.

12 Protection of the adverse effects of non-  
13 safety related SSCs relies on the ability of safety-  
14 related SSCs to perform their safety functions and  
15 prevent interactions between reactor coolant and the  
16 water contained in concrete in the safety-related  
17 portion of the reactor building.

18 No part of the reactor building is  
19 credited to meet the functional containment safety  
20 function.

21 All right. Next slide. It describes the  
22 design using prevention standard and in accordance  
23 with the applicable quality assurance program based on  
24 ASCE 710, SDC 2. Describes protect safety-related  
25 SSCs from the effects of design basis meteorology,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 cold, flooding, and seismic events.

2 SDC 3 describes design minimize -- design  
3 minimizes probability and the effort of fire and  
4 explosions. These have low combustible materials  
5 operating in the fire protection program.

6 SDC 75 describes to design protects the  
7 geometry of the decay heat removal system from related  
8 natural phenomena events. And the DHRS is located in  
9 the safety-related portion of the reactor building.

10 SDC 76 describes design permits, periodic  
11 inspections, and survey events of safety-related  
12 structure areas. And this is to be determined in the  
13 final safety analysis report.

14 Okay. Next slide, please. All right.  
15 Just a little bit of explanation of SDC 2, seismic  
16 events. The safety-related portion of the reactor  
17 building is reinforced concrete structure, design  
18 based on ACI 349-2013. And the internal steel  
19 structures are designed to meet AISC N690.

20 By meeting ASCE 43.19, the safety-related  
21 portion of the building provides protection to safety-  
22 related SSCs from the design basis earthquakes.

23 The seismic assessment is checked for both  
24 strength and displacement base criteria, and limit  
25 states are set based on the target performance goal.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The safety-related portion of the reactor  
2 building uses a spring-backed seismic isolation system  
3 which lowers seismic demands on the safety-related  
4 reactor building and safety-related SSCs in both  
5 horizontal and vertical directions.

6           The moat is sized to accommodate the  
7 displacement consistent with the isolation system,  
8 meeting the performance goal of 1E minus 4 per year.

9           And design features a combination, a  
10 potential differential displacement for SSCs that  
11 cross the moat.

12           I think that concludes my presentation.  
13 If there's any questions?

14           MEMBER KIRCHNER: This is Walt Kirchner.  
15 Just a simple question.

16           For those components that are non-safety  
17 related within the reactor, the safety-related portion  
18 of the reactor building, do you use the same analysis  
19 tools?

20           MR. SONG: So, wanted to make sure I  
21 understood the question.

22           Is it do you mean the non-safety related  
23 equipment inside the safety-related portion of the  
24 reactor building?

25           MEMBER KIRCHNER: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MR. SONG: Is that what you are --

2 MEMBER KIRCHNER: Yeah.

3 MR. SONG: Yeah.

4 MEMBER KIRCHNER: It could be just simple  
5 yes or no. I, I would expect you would use the same  
6 tools.

7 MR. SONG: Correct, yes. We will use the  
8 same tools to --

9 MEMBER KIRCHNER: Excellent.

10 Okay, thank you.

11 MR. SONG: Uh-huh.

12 CHAIR PETTI: Okay. Seeing no more, let's  
13 go to the staff.

14 MR. HELVENSTON: I believe Jenise Thompson  
15 will be starting out virtually for the staff on the  
16 next presentation.

17 MS. THOMPSON: Good afternoon. My name is  
18 Jenise Thompson. I'm a geologist in the Division of  
19 Engineering and External Hazards in the Office of  
20 Nuclear Reactor Regulation.

21 So, I'll be presenting the staff's review  
22 of PSAR Section 2.5, and then handing off this  
23 presentation to my colleagues to overview the staff's  
24 review of 3.4 and 3.5.

25 Next slide, please. In Section 2.5 we'll

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 cover the geology, seismology, and geotechnical  
2 engineering. And 3.4 we'll address seismic damage.  
3 And 3.5 we'll address the reactor building structure.

4 Next slide, please. The overview of the  
5 staff's review is as follows. The applicant applied  
6 for a construction permit and has not specifically  
7 requested approval for detailed design information.

8 The applicant also provided a preliminary  
9 design description and a discussion of the relevant  
10 design bases, for example, the principal design  
11 criteria, or SDC.

12 The staff were asked to assess whether the  
13 preliminary design information, including the  
14 identification of relevant design bases, was  
15 sufficient to allow the staff to determine that the  
16 information meets the applicable regulations for the  
17 issuance of a construction permit and, also, the  
18 detailed design information can be left to the  
19 operating license application.

20 Next slide, please. The regulatory bases  
21 for these sections, there's a fair amount of overlap  
22 for all sections: 10 CFR 50.34(a), 50.35, and 50.40  
23 apply.

24 The staff also followed the relevant  
25 guidance in NUREG-1537, which is the standard review

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 plan and acceptance criteria for non-power reactors.

2 For Section 2.5 only, the regulatory  
3 requirements in 10 CFR 100.10 are also applicable.  
4 And applicable to just Section 3.5 are the principal  
5 design criteria that were just discussed of PDCs 1, 2,  
6 3, 75, and 76.

7 Next slide, please. PSAR Section 2.5.1  
8 and 2.5.2 address the regional and site geology. The  
9 regional geology was incorporated by reference from  
10 the Clinch River Early Site Permit location, which is  
11 3.5 miles away from the proposed Kairos location.

12 The Kairos site is underlain by the Mascot  
13 dolomite, the Murfreesboro limestone, and the Pond  
14 Springs Formation, all of which occur within the  
15 Appalachian Valley and Ridge physiographic province.

16 And as two of the three names suggest,  
17 each of these units is to some degree calcareous and,  
18 therefore, these foundation rock units are susceptible  
19 to karst.

20 The applicant noted that although there  
21 was no surface indication of sinkholes at the site,  
22 there was evidence of karstic activity encountered in  
23 the borings performed for the location.

24 Next slide, please. The staff determined  
25 that the characterization of the local and regional

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 geology is adequate. We also noted that the potential  
2 for surface faulting is something that can be deferred  
3 to the operating license.

4 We also included the geologic mapping  
5 permit conditions which, combined with the removal of  
6 the overburden soil and weathered rock at the site  
7 location, will ensure no evidence of karstic  
8 dissolution at the foundation level.

9 We've included the full text of these  
10 geologic mapping permit conditions here, essentially  
11 requiring detailed geologic mapping and examination of  
12 any encountered geologic features. And then  
13 notification to the Director of NRR once those  
14 excavations are open for examination by the NRC staff.

15 And we included the exact permit  
16 conditions in the Clinch River ESP as well.

17 DR. BLEY: I'd like to ask a question.  
18 This is Dennis Bley.

19 I thought when the applicant was talking  
20 they said they didn't find any karst. But you said,  
21 but they did, you're saying.

22 Were there indications of, are there big  
23 voids underground or is this just small areas?

24 MS. THOMPSON: In our smaller voids that  
25 were encountered in the borings that were performed at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the site there was no evidence of large scale sinkhole  
2 activity.

3 But the borings are essentially a thin  
4 hole picture of what's going on in the subsurface,  
5 which is why we include the geologic mapping permit  
6 conditions to ensure that there are no large karst  
7 features encountered at the foundation level once that  
8 excavation is complete.

9 DR. BLEY: Makes sense. But these were  
10 fairly small it sounds like, and no surface, well,  
11 several times no surface vents. Okay, thank you.

12 MS. THOMPSON: You're welcome.

13 Next slide, please. Moving into PSAR  
14 Section 2.5.3 addressing vibratory ground motion at  
15 the site, the applicant adopted the Clinch River site  
16 ground motion hazard curves for the site-specific  
17 design response spectra, which you saw in the  
18 applicant's slides.

19 Again, this is a site that's 3.5 miles  
20 from the Clinch River site. They are both rock sites  
21 with similar geology.

22 This is all based on the NRC's approved  
23 seismic source model, which can be found in NUREG-  
24 2115, and also the previously NRC-approved Central and  
25 Eastern U.S. Ground Motion Model in EPRI 2013.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           In this case, the applicant increased the  
2 Clinch River hazard curves by scale factors of 1.5 to  
3 1.7. And this is to account for use of the older  
4 ground motion model and the potential impact of site-  
5 specific site response analysis.

6           Next slide, please. The staff's  
7 evaluation determined that the applicant's use of the  
8 Clinch River hazard curves for the site-specific DRS  
9 for the Hermes test reactor is appropriate at the  
10 construction permit stage.

11           The staff also notes that for the  
12 operating license Kairos will need to update its site-  
13 specific DRS to incorporate new NRC-approved Central  
14 and Eastern U.S. Ground Motion Model NGA East, and the  
15 site amplification factors determined from the result  
16 of site response analysis.

17           And before that, the staff also plans to  
18 perform a confirmatory evaluation using the NGA East  
19 model and local site amplification.

20           Next slide, please. And, finally, in 2.5  
21 we also address the geotechnical engineering in PSAR  
22 Section 2.5.4. The applicant determined the  
23 subsurface stratigraphy and material properties from  
24 a series of blinds and trenches at the site.

25           The applicant determined that liquefaction

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 was not a concern for safety-related structure, and  
2 that bearing capacity of the foundation rock is  
3 expected to be adequate.

4 With respect to settlement for safety-  
5 related structures, that's expected to be negligible.  
6 And that the settlement for non-safety related  
7 structures is something that can be controlled through  
8 the use of an engineered backfill.

9 Next slide, please. The staff's  
10 conclusions are that liquefaction is not a concern for  
11 rock units encountered at the site, and that the  
12 liquefaction potential for non-safety related  
13 structures, those that are founded on engineered fill,  
14 can be deferred to the operating license.

15 The staff also notes or concludes that the  
16 over excavation to a foundation depth where no  
17 evidence of karst dissolution is encountered and,  
18 again, not something that would be confirmed by the  
19 geologic mapping permit condition.

20 And, finally, that additional  
21 characterization of foundation bedrock can be  
22 addressed in the operating license application.

23 Next slide, please. Overall the Section  
24 2.5 regulatory findings are that the NRC staff  
25 concludes that based on the information provided,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 responses, and our own technical evaluation, that the  
2 geology, seismology, and geotechnical engineering  
3 characteristics provided for the Hermes site in PSAR  
4 Section 2.5 is sufficient and meets the applicable  
5 guidance and regulatory requirements for the issuance  
6 of a construction permit.

7 And that further information on geology,  
8 seismology, and geotechnical engineering can  
9 reasonably be left for later consideration at the  
10 construction permit application stage -- or, sorry, at  
11 the operating license stage because it's not necessary  
12 to be provided as part of the construction permit  
13 application.

14 I'll pause for questions and then,  
15 Chairman, I'll then pass the presentation over to my  
16 colleagues for their discussion of 3.4 and 3.5.

17 MEMBER KIRCHNER: Jenise, this is Walt  
18 Kirchner. I have a couple of questions for you.

19 MS. THOMPSON: Uh-huh.

20 MEMBER KIRCHNER: Since there is extensive  
21 cross-reference to the Clinch River Early Site Permit  
22 activity, just for my own information, did they use  
23 the CEUS -- the, I forget the acronym you used, NGA  
24 East or whatever, for that Early Site Permitting  
25 activity?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MS. THOMPSON: No. The NGA East was not  
2 used for the Clinch River site.

3 MEMBER KIRCHNER: Okay. So, that's more  
4 recent.

5 And does that account, then, for the  
6 scaling factor of 1.5 to 1.7?

7 MS. THOMPSON: I'm actually going to refer  
8 that question to Cliff Munson.

9 MEMBER KIRCHNER: Uh-huh.

10 MS. THOMPSON: Cliff, do you want to  
11 respond to that?

12 MR. MUNSON: Sure. I'm Cliff Munson, a  
13 senior level advisor for siting in NRR DEX.

14 So, the factors of 1.5 to 1.7 are intended  
15 to account for the potential increase in amplitudes,  
16 ground motion amplitudes due to NGA East, and  
17 potentially a slight increase due to the site response  
18 analysis, the site amplification factors.

19 So, they increased, they used those  
20 factors to account for both of those items.

21 MEMBER KIRCHNER: Okay, thank you.

22 And then a last question. Now, looking at  
23 the information in the PSAR and then contrasting that  
24 with the Clinch River site, what I remember of the  
25 Clinch River site is pretty much sitting on this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 dolomitic rock at the old Clinch River breeder reactor  
2 foundations, essentially.

3 Here it seems like it's on soil on rock.

4 So, I guess that's -- so, you're  
5 permitting condition then is to get a better map of  
6 what's underneath so that you can, let me see, ensure  
7 that the foundation and et cetera is, is -- I'm  
8 searching for the right words -- but could you just  
9 explain a little bit more about that permitting  
10 condition?

11 What does that entail in terms of  
12 activities: is that more borings and such to answer  
13 Dennis' question about karst and such?

14 MS. THOMPSON: So, I'll give, I'll start  
15 with the response and then I'll ask our geotechnical  
16 engineer Amit to tag in as well.

17 The purpose of the geologic mapping permit  
18 condition is to look at the clean surface that's  
19 already been excavated. So, this would be the actual  
20 foundation surface as it's exposed during the  
21 excavation process.

22 And we can go back a couple slides if we  
23 want. But the, the intent is to see the removal of  
24 the soil and weathered rock in its entirety to expose  
25 a clean, hard rock surface.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   And I'll ask Amit if he has anything to  
2 add on that?

3                   MR. GHOSH: Yes. This is Amit Ghosh.

4                   And I reviewed this part. And what we are  
5 looking for is was they are supposed to put it on the  
6 hard rock, as Dennis said right now. And there will  
7 be a concrete pedestal on which the reactor is  
8 sitting.

9                   So, the reactor is specifically sitting on  
10 hard rock surfaces. But we want to ensure that there  
11 is no karst feature inside. And as Dennis said, like  
12 the bore holes gives you a very 1-D information on  
13 what is below the surface.

14                   I would prefer, I'd like to see, and it's  
15 up to the applicant how to come up with that, some  
16 kind of a T.V. picture of the ground, like geophysical  
17 technique ground penetration radar or something to  
18 show that there is no large void. All we need is  
19 small void which can affect.

20                   The reactor is sitting on Murfreesboro  
21 limestone, which is -- has fractures, rock joints,  
22 dipping quite high in the level 60 degree. And those  
23 joints, some of them are clefting.

24                   Clearly, some places, you know, if it gets  
25 wet it swells. So, that may open up the joints and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 all, so the stability and the bearing capacity are the  
2 concerns here. So, that's why you want to have a very  
3 good characterization of what is below the surface so  
4 that we have a good confidence that the design will  
5 work.

6 MEMBER KIRCHNER: Okay. So, the  
7 expectation, though, is it will basically -- I'll say  
8 this because I'm not a geologic engineer -- you're  
9 going to sit the foundation mat on hard rock  
10 essentially, is what you're looking at?

11 MR. GHOSH: Right. Right.

12 MEMBER KIRCHNER: Okay. And --

13 MR. GHOSH: Hard rock with sufficient  
14 strength.

15 MEMBER KIRCHNER: Bearing capacity. Okay.

16 MR. GHOSH: Yes.

17 MEMBER KIRCHNER: Okay. All right. Thank  
18 you very much.

19 MR. GHOSH: Thank you, sir.

20 MS. THOMPSON: And if there were no other  
21 questions for 2.5, I can pass the presentation to  
22 Bryce Lehman who will be presenting 3.4 and 3.5.

23 Thank you.

24 DR. SCHULTZ: Before we do that, I have a  
25 question.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           On the design response spectrum where the  
2           applicant has done their evaluation and you've asked  
3           for an update to that, whether it's the U.S. ground  
4           motion model that has now been recently updated by the  
5           NRC, that's something that they need to do before they  
6           do the design for construction?

7           And you'll review that evaluation before  
8           that happens?

9           Is that the sequence of events? I'm  
10          looking at slide 51.

11          MS. THOMPSON: So, my understanding is that  
12          the expectation is that the construction, or the  
13          construction permit application does not need to  
14          address NGA East. But the operating license  
15          application would need to include an updated DRS  
16          incorporating or using NGA East.

17          But I'll defer to Cliff if he wants to add  
18          more to that.

19          MR. MUNSON: That's my understanding as  
20          well, that they will proceed with the design based on  
21          their construction permit design response spectrum,  
22          and that they will verify that prior to OL -- as part  
23          of their OL application we will see that.

24          MEMBER KIRCHNER: Cliff, this is Walt  
25          Kirchner again.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           Let me just pull the thread on this a  
2 little bit more. Doesn't that put them at risk a  
3 little bit?

4           I mean, we've had problems with other  
5 construction projects where you update the seismic  
6 curves that, you know, the spectrum curves and such,  
7 and then you, you're in a position of backbiting or  
8 making major design changes.

9           DR. SCHULTZ: Thank you, Walt. This is  
10 Steve again.

11           That's what I was looking for in  
12 understanding the sequence of events here. I'd hate  
13 to see something move forward on the construction  
14 design side and wind up at the operating license time  
15 that more work needs to be done.

16           MR. MUNSON: So, from my understanding --  
17 this is Cliff again -- they are proceeding a little  
18 bit at risk. That is why they did their scale factors  
19 of 1.5 to 1.7 to potentially account for that.

20           We don't expect the spectra, the design  
21 spectra to be that different.

22           One thing to note, they are siting the  
23 Hermes reactor on hard rock, so the amplification is  
24 expected to be flat, basically 1. So, we don't expect  
25 amplifications due to the upcoming seismic waves since

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 these are very hard rock structures.

2 So, we believe that we concluded that  
3 there is not going to be much difference, if any,  
4 between the CT design response spectrum and the OL  
5 design response spectrum.

6 DR. SCHULTZ: So, the factors that they've  
7 applied should account for what is anticipated in the  
8 reevaluation?

9 MR. MUNSON: Exactly.

10 DR. SCHULTZ: Good. Thank you for  
11 clarifying that.

12 MS. THOMPSON: And I guess if there aren't  
13 any more questions we'll go to Bryce.

14 MR. LEHMAN: All right. Thanks, Jenise.

15 Good afternoon, everybody. My name's  
16 Bryce Lehman. I'm a structural reviewer in NRR,  
17 Division of Engineering and External Hazards.

18 I'm going to go through Section 3.4 and  
19 3.5.

20 So, PSAR Section 3.4 comprises design  
21 overview, pretty similar to what the applicant just  
22 discussed. Obviously addresses the SSC required to  
23 remain functional after an earthquake, and associated  
24 with ASCE 43-19, Seismic Design Category 3.

25 It uses the graded approach. And the DRS

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 is based on Seismic Design Category 3 and site hazard  
2 from PSAR Section 3.5.

3 Seismic response analysis as well as  
4 structure interaction will be performed in accordance  
5 with AC -- ASCE 4-16.

6 Next slide, please. The staff evaluation  
7 really focused on verifying the appropriate seismic  
8 hazard standards to be used, and that there would be  
9 -- the reactor building would be designed to the  
10 overview in ASCE 43-19 and ASCE 4-16.

11 Verify that the DRS is properly developed  
12 based on site data from Chapter 2.

13 And then a lot of information on the  
14 specific design details, including seismic and other  
15 things will be reviewed during the operating license.  
16 But they've been properly identified at this stage.

17 Within a reasonable level of detail and  
18 information provided to the issuance of the  
19 construction permit with, again, it's been very  
20 clearly identified what staff will expect to see in  
21 the operating license review.

22 So, moving on to Section 3.5, this  
23 describes the principal structural elements and design  
24 of the reactor building. And it summarizes how the  
25 reactor building is PDCs 1, 2, 3, 75 and 76. And it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 really supports or repeats information that's  
2 contained in earlier PSAR sections, especially 3.2,  
3 3.3, and 3.4.

4 Sort of the unique part of this section,  
5 I think, is the discussion of the seismic isolation  
6 system. So, we put a little bit of focus on that for  
7 this section.

8 Next slide, please. I'll move through  
9 these pretty quickly because, one, the applicant has  
10 covered them and, two, like I said, they're kind of  
11 referring back to other sections in this.

12 But SDC-1, the SSC importance of safety  
13 shall be designed to quality standards. The staff  
14 verified the safety-related SSCs will be designed and  
15 constructed in accordance with ACI 349 and AISC N690.

16 For PVC-2, SSCs important to safety shall  
17 be designed to withstand natural phenomena. Again,  
18 the structure will be designed to withstand the  
19 appropriate natural loads. And there's more  
20 discussion about it in earlier sections.

21 And in PVC-1, structure of the design in  
22 accordance with the appropriate nuclear codes, ACI 349  
23 and AISC N690.

24 DR. SCHULTZ: Bryce, am I missing  
25 something. I thought we determined this morning that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 we are using safety-related and non-safety related.  
2 And here we have components important to safety.

3 MR. LEHMAN: Yeah, I apologize. If you  
4 guys had that discussion this morning, I imprecisely  
5 said it. I would say unless they've got something to  
6 add, if you guys agreed on something this morning,  
7 assume that advisement.

8 DR. SCHULTZ: Yes.

9 MR. LEHMAN: Okay. All right. Okay.

10 DR. SCHULTZ: Thank you, Bryce.

11 MR. LEHMAN: Yeah, thank you.

12 All right, thanks for that comment.

13 For PVC-3, the SSCs shall be designed and  
14 located to minimize the effects of fire. The reactor  
15 building uses low combustible materials and physically  
16 separates SSCs. And then, also, there's a fire  
17 protection program provided.

18 And that's discussed in more detail in  
19 Section 9.4.

20 PVC-75, the reactor building shall be  
21 protected down to the decay heat removal system  
22 located inside the safety-related portion of the  
23 reactor building, which provides assurance that it  
24 will be protected from the natural phenomena.

25 And then, finally, PVC-76, reactor

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 building shall be designed to permit periodic  
2 inspection. That is the plan of the design, including  
3 the seismic isolation system that will be designed to  
4 allow access and permit inspection.

5 So, for the seismic isolation, as the  
6 applicant went over the safety-related portion of the  
7 reactor building will be seismically isolated, at this  
8 point minimal information was provided on the design  
9 of that other than kind of noting that it's going to,  
10 going to be there.

11 They did explain that there would be a  
12 moat, as they highlighted during their presentation,  
13 which separates the seismic isolated portion from the  
14 rest of the plant.

15 And the system will be accessible and  
16 inspected throughout the life of the plant.

17 So, really here the staff I think have  
18 verified that the system will be designed in  
19 accordance with the appropriate guidance, which is  
20 Chapter 9 of ASCE 43-19. And really highlighted that,  
21 obviously, they're going to need a lot more details of  
22 the system and the analysis, which will be provided  
23 for the operating license application.

24 Next slide. The conclusions. Safety-  
25 related portions of the reactor building will be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 designed to appropriate codes to support those PVCs.

2 The seismic isolation system will be  
3 designed to the appropriate guidance in ASCE 43-19.

4 And specific design details that will be  
5 reviewed during the operating license have been  
6 properly identified.

7 For the regulatory findings for Section  
8 3.4 and 3.5, the staff finds that there is reasonable  
9 assurance that the preliminary information is  
10 consistent with the applicable criteria in NUREG--  
11 1537, and the relevant PVC, and conforms with 10 CFR  
12 50.34(a)(4), thereby providing preliminary analysis  
13 and evaluation of the design performance of SSCs.

14 Staff also concludes that the information  
15 in the Hermes PSAR Section 3.4 and 3.5 is sufficient  
16 and meets the applicable guidance and regulatory  
17 requirements in accordance with 10 CFR 50.35, and that  
18 further information can reasonably be left for the  
19 operating license application.

20 And that's my last slide and I think the  
21 last slide of this, this section of the presentation.

22 Obviously, if there's any questions.

23 MEMBER HALNON: Bryce, this is Greg.

24 On these ASCIs, and I think that's the  
25 right thing, it's these seismic codes, are those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 similar or the same as we were using for large light-  
2 water reactor post-Fukushima? Or are these specific  
3 just for reactors, these non-power reactors?

4 MR. LEHMAN: Yeah, I'll go ahead and try.  
5 And then, Cliff, if you want to jump onboard and add  
6 to it.

7 I think it is the same as sort of the new,  
8 the new --

9 MEMBER HALNON: We're not using then --

10 MR. LEHMAN: -- revolution of it.

11 MEMBER HALNON: -- all that we learned  
12 after post-Fukushima, and we're using the same, the  
13 same methodologies I guess?

14 MR. LEHMAN: Yes.

15 MEMBER HALNON: So, when we're reviewing  
16 the operating license we should expect to see a level  
17 of detail similar to what we saw for post-Fukushima?  
18 Or is it going to be a little bit less or --

19 MR. LEHMAN: I think, --

20 MEMBER HALNON: -- a lot less, or?

21 MR. LEHMAN: -- obviously, a lot more than  
22 what we've seen here today. About the same as what we  
23 would expect for a power reactor. Right?

24 As far as that level of detail, maybe, Ed,  
25 you can support a little bit.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 I think, obviously, the staff is going to  
2 try, so where that's going to be I'm unsure, but --

3 MEMBER HALNON: But just curiosity.

4 MR. LEHMAN: Yeah.

5 MEMBER HALNON: I mean, I'm just trying to  
6 prepare myself.

7 MEMBER KIRCHNER: Greg.

8 MEMBER HALNON: Yes?

9 MEMBER KIRCHNER: Greg, this is Walt.

10 That suite of codes that were just cited  
11 on this last few vugraphs are the same codes that  
12 NuScale used to design their reactor building systems.

13 MR. LEHMAN: Oh, I didn't know that.

14 MEMBER HALNON: Okay.

15 CHAIR PETTI: And this is new in terms of  
16 regulations compared to, say, 20, 30 years ago. So,  
17 it's an evolution. It's going to be positive, I  
18 think, as you'll see in the design.

19 MEMBER HALNON: Yeah. The reason I was  
20 asking, you know, my depth of knowledge goes just  
21 post-Fukushima large light-water reactor. And I was  
22 just curious how, how much harder it is to get to this  
23 point, or is going to be the same thing that I'm used  
24 to seeing relative to codes?

25 I describe it as a sharper --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: Sharper. From the light-  
2 water reactor?

3 CHAIR PETTI: Yes. Because these response  
4 spectra allow you to propagate things differently than  
5 in the old days because we just didn't have the  
6 knowledge and the capability of the codes to protect  
7 that. Then you put the seismic isolator.

8 MEMBER BALLINGER: These, the ASCE, the  
9 concrete code has been around since --

10 MEMBER HALNON: Before you were born?

11 MEMBER BALLINGER: No. They just keep  
12 evolving. And the same for these, these folks.

13 And I actually went and got these codes  
14 and ran their numbers. They check out. And they're  
15 the same way you would do it for any light-water  
16 reactor.

17 MEMBER HALNON: Okay. All right.

18 MEMBER BALLINGER: They don't make a  
19 distinction, at least --

20 MEMBER HALNON: Well, that was the, that  
21 was what I needed to hear, that it's going to be these  
22 similar to what I'm used to seeing.

23 MEMBER BALLINGER: The reg guides that call  
24 out those things are the key; right?

25 MEMBER HALNON: Well, and this was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 completely after the reg guide, so just all going to  
2 codes. So that's why I was trying to -- I think I got  
3 what I was asking.

4 MR. LEHMAN: Any other questions?

5 DR. SCHULTZ: This is Steve Schultz. Just  
6 one, Bryce.

7 It's hard not to miss that the Kairos  
8 presentation had within it that the control room is  
9 non-safety related. And so, the buildings where that  
10 is located is non-safety related, as well as these  
11 other buildings onsite.

12 So, those buildings are just built to the  
13 international building codes and the Tennessee  
14 Building Code?

15 MR. LEHMAN: That's correct, yes.

16 DR. SCHULTZ: All right. Thank you.

17 MEMBER BALLINGER: I mean, they're relying  
18 on the fact that safety, it's passively cooled, so  
19 there's nothing that can happen. So, the control room  
20 could disappear.

21 DR. SCHULTZ: Yeah. I understand that.  
22 It's just different.

23 MR. LEHMAN: Yeah, yeah. Exactly right.

24 DR. SCHULTZ: And good to see. Thank you.

25 MR. LEHMAN: All right, thanks a lot. I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 guess, I don't know if you have any other comments.  
2 Other than that, I think we're done now.

3 CHAIR PETTI: Okay. I think then we can  
4 turn to the memos.

5 Oh, there's a hand up? Yes, Kairos,  
6 please.

7 MR. PEEBLES: We had a couple of  
8 corrections to make, so I'm going to hand it over to  
9 Brian Song again.

10 MR. SONG: Yes. It's Brian Song.

11 So, I think the first item is about the  
12 karst. In our slides we indicated no karst  
13 information. However, we did an investigation  
14 throughout the whole site, and we did discover that  
15 the karst information is north of where we located the  
16 Hermes site.

17 So, that is kind of what we tried to  
18 indicate in the slides. So, hopefully that clarifies  
19 that.

20 The second item is the question about the  
21 tools being the same of the safety-related and non-  
22 safety related structure that where it's located.  
23 Based on PSAR, we are, for the non-safety related  
24 items we are using ASCE 7 and building codes to, to  
25 analyze those items.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           So, the tools may or may not be the same.  
2           So, I just wanted to clarify that as well.

3           DR. SCHULTZ: Thank you.

4           MEMBER BROWN: Dave, this is Charlie. One  
5           question not explicitly related, but sort of.

6           Main control building is separate, it's  
7           non-safety related.

8           There are some things that I'll bring up  
9           in Chapter 6 as well as 7, in that there's some manual  
10          controls associated with actuating or ensuring things  
11          have actuated in the DHRS and the reactor trip type  
12          functions. So, if they're separated and it's non-  
13          safety, it would be interesting to at least address  
14          how we maintain those remote on backup shutdown  
15          capabilities for those two safety-related issues.

16          That's all. Just put that in the hopper  
17          to talk about whenever we get to them.

18          CHAIR PETTI: Yeah. And I had the same  
19          thought with DHRS actively engaging.

20          MEMBER BROWN: Yeah, there are a couple of  
21          things that are -- we'll talk about some of those  
22          tomorrow when we talk about Chapter 6, so.

23          CHAIR PETTI: Okay.

24          MEMBER BROWN: DHRS is obviously the one.  
25          But there's also a water source for the water tanks

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 and things like that that are -- feed the tanks, even  
2 though it's in a safety-related area it's got sources.  
3 And how do you control that source?

4 Just another point that we didn't talk  
5 about.

6 CHAIR PETTI: Yeah. I think that's best  
7 talked about tomorrow.

8 MEMBER BROWN: Pardon?

9 CHAIR PETTI: We'll talk about that  
10 tomorrow.

11 MEMBER BROWN: Yeah, yeah. I just wanted  
12 t make sure we had, because it was remote and it's  
13 non-safety, therefore, and there are controls, and  
14 it's not like everything else, so I just wanted to get  
15 it on the table so people have it in their brain, in  
16 case I forget.

17 That's it. Thank you.

18 CHAIR PETTI: Kairos again? No? Or do we  
19 take a break?

20 MR. PEEBLES: Yeah. I was just going to  
21 preview. So, we will discuss that more in Chapter 6  
22 and Chapter 7. But the backup shutdown functions are  
23 not safety-related.

24 So, the primary shutdown functions in the  
25 reactor protection system are what's safety-related.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 But we can talk more about that in the Chapter 6 and  
2 Chapter 7 discussion.

3 CHAIR PETTI: Okay. So, let's, we have  
4 Chapter 3. Should we do Chapter 2 first? Either way?

5 (Whereupon, the above-entitled matter went  
6 off the record at 1:39 p.m. and resumed at 2:01 p.m.)

7 CHAIR PETTI: Kairos, you're up.

8 MR. LATTA: Hello, my name is Ryan Latta.  
9 I'm a principal engineer here at Kairos Power, in the  
10 fuels and materials area.

11 I've been at Kairos for five years now.  
12 I previously presented the fuel qualification  
13 methodology topical report, that was reviewed and  
14 approved just this month.

15 And now today I'll be speaking about the  
16 Hermes PSAR, Section 4.2.1, on reactor fuel.

17 Next slide, please. So this figure here  
18 just talks to the fuel form. I believe it's made it's  
19 rounds and been seen at this point.

20 We use the TRISO fuel particle that's  
21 within a pebble fuel form. The TRISO fuel particle is  
22 based on the AGR, DOE AGR program.

23 The TRISO particle has the kernel and  
24 multiple layers, that are part of our functional  
25 containment.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The particles lie within the fuel form,  
2           which is a pebble.    The pebble has fuel, three  
3           regions.    An inner density, or inner, inner core  
4           that's of a low density to low buoyancy of the pebble.

5           The fuel region that contains the TRISO  
6           particles, and the outer fuel free shell that  
7           separates the TRISO particles from mechanical, or  
8           chemical interaction with materials outside of the  
9           pebble.

10          The carbon matrix is the same material  
11          throughout the fuel pebble.

12          In the core, besides the fuel pebble there  
13          are also moderator pebbles.    These are homogenous  
14          pebbles made up of the same carbon matrix material,  
15          with the same diameter.    They do not contain fuel.

16          And the purpose of the moderator pebbles,  
17          is to get the right carbon to heavy metal ratio, so  
18          that you have optimum moderation within the Hermes  
19          reactor.

20          Okay, next slide, please.    Okay, this just  
21          further talks to a description of the fuel.    The main  
22          kind of parameters of the fuel particle are shown on  
23          the left, with nominal values.    These values are  
24          consistent with AGR-2 and AGR 5/6/7 fuel  
25          specifications.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The description of the pebble on the  
2 right, shows the dimensions and overall densities,  
3 which are the same for either the fuel pebble, or the  
4 moderator pebble. And then of course for the fuel  
5 pebble, the loading information.

6           Next slide. Okay, this slide talks to our  
7 fuel qualification program. And so as I said  
8 previously, we had reviewed, had reviewed the fuel  
9 qualification methodology topical report, and I'll  
10 give a kind of quick outline of what that entails.  
11 It's described in the fuel summary.

12           So, the foundation of our fuel  
13 qualification is the DOE AGR program. We used an  
14 equivalent fuel specification for our fuel particle,  
15 that we use in Hermes.

16           And we rely on the EPRI topical report,  
17 that demonstrated AGR-2 irradiation safety performance  
18 that showed good performance of the fuel to low  
19 failure fractions for that fuel.

20           And, we're leveraging that irradiation  
21 safety testing experience, along with that design in  
22 Hermes.

23           And in addition to that, we performed a  
24 PERT exercise looking at fuel particle and pebble  
25 phenomenon, in our application with a figure of merit.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           And through that, we identified high  
2 priority phenomenon that we would investigate further,  
3 as part of the fuel qualification program.

4           This ended up centering on the development  
5 of a pebble laboratory test program, where the purpose  
6 was to demonstrate that the fuel pebble would meet the  
7 functional requirements in the reactor.

8           Part of that includes all the non-  
9 irradiated testing in a laboratory, such as mechanical  
10 testing to demonstrate pebble structural integrity,  
11 geology to look at where within different environments  
12 of its, in its Service life.

13           Molten salt filtration to investigate  
14 buoyancy of the pebble, and then material  
15 compatibility in the environment that the pebble would  
16 see in it's Service life.

17           And looking at interaction between the  
18 pebble and the environment where there's salt, or air  
19 environment.

20           Okay, next slide here is the fuel  
21 qualification envelope. So we base our, I said before  
22 we base the qualification of the TRISO particle on the  
23 EPRI topical, and that looks at AGR to irradiation and  
24 safety performance.

25           So, we used that information to create our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 fuel qualification envelope. Here we identify four  
2 specific parameters of temperature, burn up, power,  
3 and fluence.

4 And then defined values for those for  
5 normal operations, or accident conditions. And then  
6 for the design of Hermes, we operate within that  
7 envelope as part of our qualification.

8 Okay, next slide. So with the operation  
9 of Hermes, there is a fuel surveillance program, and  
10 this includes a couple parts.

11 The first part is monitoring the coolant  
12 and pepper gas, for radioactivity. In this instance,  
13 we would be looking at trends and increases in  
14 activity that could be associated with fuel particle  
15 failures, to indicate that the, the operations and  
16 kind of health of the fuel.

17 Furthermore, then there's the second part,  
18 which is inspection of fuel pebbles, and the pebble  
19 handling system after pebbles exit the core.

20 So the pebbles go through the core  
21 multiple times, as you know, and once they exit the  
22 core each time, they would be examined for gross  
23 damage, and, and burn up, to demonstrate that the  
24 pebbles are still within the operating envelope for  
25 burn up.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1           If pebbles exceeded the operating  
2 envelope, or exceeded the burn up limit, sorry, or  
3 exhibited damage, then they would be removed from  
4 Service and placed in storage versus being  
5 recirculated through the core.

6           This speaks to the design bases. There  
7 are two PDCs addressed in the PSAR. PDC 10, related  
8 to direct core design, and PDC 16, related to the  
9 functional containment for PDC 10 as a sub-core.

10           We're relying on the AGR particle design,  
11 and the every topical design or qualification envelope  
12 for our fuel, that then the Hermes reactor must  
13 operate within.

14           Speaking to functional containment or PDC  
15 16, the TRISO particle makes up a large portion of the  
16 functional containment.

17           There are four barriers within the TRISO  
18 particle. The kernel, and brief coating layers that  
19 prevent the release of radio nuclides.

20           Further protections are provided by the  
21 pebble inspection system, that examines the burn up  
22 and the physical condition of the pebble, and the  
23 effort to remove pebbles that are damaged, or exceed  
24 burn up limits.

25           And then for the pebble form itself, we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 have a pebble laboratory qualification program, where  
2 we through this series of mechanical and other  
3 chemical tests, to demonstrate that the pebble meets  
4 it's functional requirements, and protects the TRISO  
5 particles from damage.

6 CHAIR PETTI: Ryan, I had a question on a  
7 number. You assume, I guess it's going to be a  
8 limiting condition for operation, on failure of 2.310  
9 to minus 3.

10 The table says it's a SiC failure, but  
11 I'm, want to understand from the model from the source  
12 term.

13 Do you assume the OPIC has also failed  
14 when you look at that number?

15 MR. LATTA: Yes. So those are a  
16 combination of manufacturing defects, and in-Service  
17 failure fractions.

18 Those SiC failures are most related IPIC  
19 failure that's occurring at a higher fraction.

20 CHAIR PETTI: Right.

21 MR. LATTA: Yes.

22 CHAIR PETTI: Yes, because of the lower  
23 temperature.

24 MR. LATTA: Yes, primarily, yes. So  
25 there's a high failure fraction of IPIC, due to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 lower temperatures that we see in the models.

2 And, that SiC failure fraction is driven  
3 by those IPIC failures.

4 CHAIR PETTI: I just want to make sure as  
5 I capture it properly, when I talk about function  
6 containment.

7 MR. LATTA: That's correct.

8 CHAIR PETTI: Great, okay. Thank you.

9 Other question. Have you looked at all  
10 about systems to inspect the pebble, as it's rolling  
11 in the handling system?

12 Have you looked at cameras and the like,  
13 and the doses? I just say talk to the guys in Idaho  
14 because they've done a lot in the, in-cell.

15 Pictures are amazing, but they burned out  
16 a lot of cameras because of the dose.

17 MR. LATTA: Yes.

18 CHAIR PETTI: So there's a trade off there.  
19 So if you want you know, really good resolution,  
20 you've got to get closer and there's that trade off.

21 There's a lot out there compared to say 20  
22 years ago.

23 MR. LATTA: Yes, I appreciate the comment  
24 and we're definitely prototyping systems to, to you  
25 know, develop a full system for Hermes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BALLINGER: Yes I mean the  
2 inspection techniques should be, this is consistent  
3 with the expected fraction of failure.

4 If you got an inspection system that can  
5 see 10 to the minus eighth, that cost, cost \$100  
6 million, that's not going to do you any good if all  
7 you need is 10 to the minus four.

8 CHAIR PETTI: No, I'm more worried about  
9 physically, I mean they're going to look for damage.  
10 So you know, what's the best, how much can you see?  
11 What's the resolution?

12 MEMBER BALLINGER: Yes, but there's no  
13 reason to be able to see such detail when it has  
14 nothing to do with the site.

15 CHAIR PETTI: If it, yes.

16 Go ahead, Ryan, keep going.

17 MR. LATTA: That concluded the  
18 presentation.

19 CHAIR PETTI: Oh, that's right, 4.2 is  
20 it's.

21 MR. LATTA: 4.2.2 is a separate section.

22 CHAIR PETTI: Oh. No, it's discussed now,  
23 just a different person.

24 DR. DORON: Are we ready? Yes, okay.

25 CHAIR PETTI: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 DR. DORON: Hi, this is Oded Doron, the  
2 senior director of reactor system design, and I'll be  
3 talking today about the 4.2.2, the reactivity control,  
4 and the shutdown system. Or as we call it, the RCSS.

5 Next slide. RCSS is composed of two  
6 systems. The reactivity shutdown system, the RSS, and  
7 the reactivity control system, the RCS.

8 The RSS is credited for reactor trip and  
9 shutdown. There's three safety related shutdown  
10 elements, that insert directly into the pebble bed.

11 The reactivity control system or RCS, is  
12 inserted on reactor trip, but not credited. There's  
13 four non-safety related control elements that are  
14 inserted into the reflector.

15 The release mechanism is a safety related  
16 electromagnetic clutch. The drive mechanism is a non-  
17 safety related motor driven sheave, to position  
18 elements. This provides for position indication.

19 Testing and inspection. The RCSS is  
20 periodically inspected for wear. The reactor coolant  
21 is periodically sampled for an increase in boron  
22 concentration, that could indicate shutdown element  
23 cladding failure.

24 The RCSS elements can be replaced, if  
25 necessary.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           On the right there, a simple diagram  
2 showing the four RCS elements inserting, or where  
3 their locations would be in the graphite structure,  
4 the reflector structure. And, the three cruciform RSS  
5 elements in the bed.

6           Next slide. So the shutdown elements are  
7 cruciform design. The inner cladding contains the  
8 absorber, B4C. There's an argon fill. The cladding  
9 is stainless steel 316H.

10           And on the right there, you can see a  
11 simple diagram again of the design. And unless  
12 there's comments, I'll just go on.

13           The control elements are segmented annular  
14 design. You can see the diagram on the right there.

15           There is individual capsules. Again argon  
16 filled, the absorbers B4C, and the cladding is  
17 stainless steel 316H.

18           CHAIR PETTI: So just a question. Are  
19 there any concerns on temperature limits? You know,  
20 they're going into some pretty hot locations, and  
21 usually metals in the high regions, you might get  
22 close to limits.

23           DR. DORON: I missed the beginning, the  
24 start of your question.

25           CHAIR PETTI: Just the, no, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 temperatures being experienced by the control  
2 elements, and even the shutdown elements --

3 (Simultaneous speaking.)

4 DR. DORON: Yes.

5 CHAIR PETTI: -- relative to the ASME  
6 allowables on the --

7 DR. DORON: Yes, they, well yes, that's  
8 being considered. And, they are going to stay within  
9 the allowable.

10 CHAIR PETTI: Have you done the  
11 calculations to know that? But you just?

12 I've just, I've been involved in a number  
13 of designs. This is an area that we just have to look  
14 at carefully.

15 DR. DORON: Yes. The details --

16 (Simultaneous speaking.)

17 CHAIR PETTI: I mean with Flibe, you may  
18 get a very big different temperature distribution,  
19 than in gasses.

20 DR. DORON: Yes, uh huh. Yes, I mean the  
21 detailed analysis is going to come in OLA, but that is  
22 a requirement.

23 MEMBER BALLINGER: This, I didn't read  
24 about this, but this is Ron Ballinger. Do these, does  
25 this plant operate with all rods out?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 DR. DORON: Yes.

2 MEMBER BALLINGER: Okay. So it's not in,  
3 the rods are not in the hot --

4 (Simultaneous speaking.)

5 DR. DORON: No.

6 MEMBER BALLINGER: -- section unless it's  
7 really --

8 CHAIR PETTI: The shutdown rods are out  
9 obviously, but the shutdown --

10 (Simultaneous speaking.)

11 DR. DORON: The controller -- I'm sorry.

12 CHAIR PETTI: Go ahead, go ahead, please.

13 DR. DORON: The shutdown elements are fully  
14 withdrawn during operation.

15 MEMBER BALLINGER: But the control  
16 elements?

17 DR. DORON: They may be inserted depending,  
18 but during steady state, they'll be almost completely  
19 withdrawn.

20 CHAIR PETTI: But this reactor will never  
21 really get to steady state. It won't get to  
22 equilibrium in four years, most likely, at the  
23 capacity factors.

24 Just something we're going to have to  
25 watch.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MEMBER BALLINGER: Anyway, the thermal load  
2 is not likely to be as if everything was in. You  
3 know, if they were in the hot section all the time.

4 CHAIR PETTI: All the time, but they'll be  
5 in for some fraction of time.

6 DR. DORON: I'm sorry, it's difficult for  
7 me to hear the second gentleman that was talking. I  
8 couldn't hear if there was a question there.

9 MEMBER REMPE: Ron, you need to turn on  
10 your mic.

11 CHAIR PETTI: Yes, Ron, turn on your mic.

12 MEMBER BALLINGER: No, no, just me  
13 rambling.

14 (Laughter.)

15 DR. DORON: That works, too.

16 Okay, all right, there's a lot of words  
17 here, I'm just going to read through them. Stop me if  
18 I bore you.

19 The safety related RSS is capable of  
20 operating during an earthquake. The insertion  
21 capability is confirmed via testing and maximum  
22 deflection of insertion path, due to an earthquake.  
23 This satisfies PDC 2.

24 The RSS is compatible with environmental  
25 conditions, and confirmed by qualification testing.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Analysis demonstrates internal gas pressure due to  
2 irradiation, does not exceed safety related RSS  
3 element stress limits. This satisfies PDC 4.

4 RSS is designed to fail in a safe state  
5 when the plant trips, or upon loss of normal power.  
6 The energy holding relay is closed, to remove power  
7 supply holding shutdown elements in place.

8 And, the loss of power allows shutdown  
9 elements to drop via gravity. This satisfies PDC 23.

10 The RCS, remember this is the RCSS, which  
11 is the RCS and the RSS together, meet PDC 26. This is  
12 discussed in Section 4.5, the PSAR nuclear design.

13 The RCSS is designed to limit the amount  
14 and rate, of reactivity insertion by controlling the  
15 maximum withdrawal speed of control and shutdown  
16 elements. This satisfies PDC 28.

17 The design of the RSS trip function, in  
18 conjunction with the reactor protection system,  
19 assures an extremely high probability of accomplishing  
20 its safety related function.

21 Both the RSS and the RCS, provide  
22 significant negative reactivity insertions of the core  
23 via gravity and motor driven means, upon a reactor  
24 trip. This satisfies PDC 29.

25 CHAIR PETTI: I have a question sort of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           topicologically. The motors and the clutch, you know,  
2           the top of the reactor there's going to be some shine  
3           off the top because there's not a, you know, an upper  
4           reflector.

5                        And in some designs I'm aware of in the  
6           past, the motors, the radiation damage issue and  
7           combined with the temperature, means you can't use  
8           like a light water reactor design option.

9                        Have you guys looked at that? Is there  
10          going to have to be some testing, or are they far  
11          enough away that they're protected?

12                       DR. DORON: It's a combination of things.  
13          The details will come in OLA, but what I can tell you  
14          is both temperature and radiation effects are taken  
15          into consideration, indeed.

16                       MEMBER KIRCHNER: Can I follow on, Dave?  
17          This is Walt Kirchner.

18                       DR. DORON: I wanted to add one, just a bit  
19          of a clarification.

20                       While the thickest part of the reflector  
21          is certainly on the side, there is still graphite  
22          above the core. There is fuel in the fueling chute,  
23          but there is still graphite above the core.

24                       And, so there is some radiation protection  
25          that is provided by the graphite, and also our head.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 While the dimensions have not been provided, I will  
2 say is relatively thick and provides some radiation  
3 protection, as well.

4 All that to say again, thermal and  
5 irradiation effects are considered in this design.

6 MEMBER KIRCHNER: May I ask a question?  
7 The shutdown system, that's going to go in by force of  
8 gravity, right?

9 DR. DORON: Correct.

10 MEMBER KIRCHNER: Yes, so do you have a  
11 scale test or something in mind to demonstrate that  
12 that cruciform rod will penetrate the pebbles, and is,  
13 has a sufficient weight such that will overcome the up  
14 flow that exists in the core?

15 DR. DORON: Yes, so we've done significant  
16 testing already, but we have --

17 (Simultaneous speaking.)

18 MEMBER KIRCHNER: Okay.

19 DR. DORON: -- committed to a test for the  
20 PSAR specifically, to demonstrate that.

21 MEMBER KIRCHNER: Excellent, okay.

22 And, then it wasn't clear from the design  
23 details that were available in Chapter 4. Is there a  
24 positive way to drive those rods in?

25 DR. DORON: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER KIRCHNER: It seems like it's a  
2 cable clutch arrangement, but I didn't understand or  
3 maybe I just didn't, I missed the detail.

4 DR. DORON: There is not --

5 (Simultaneous speaking.)

6 MEMBER KIRCHNER: Is there a way to do a  
7 positive insertion?

8 DR. DORON: There is not a safety related  
9 design to do forced insertion besides gravity, for the  
10 shutdown elements.

11 MEMBER KIRCHNER: Okay.

12 MEMBER KIRCHNER: But are they capable of  
13 running up?

14 DR. DORON: Yes, it's capable. It's  
15 capable, yes. But we're not committing to it.

16 MEMBER KIRCHNER: And, could you just  
17 briefly describe how that's accomplished? Because it  
18 wasn't clear from PSAR.

19 I mean you've got a hoist-like system.

20 DR. DORON: Yes.

21 MEMBER KIRCHNER: It wasn't clear to me  
22 how you got positive insertion.

23 DR. DORON: Yes, but through the hoist  
24 system, I mean that's why I'm saying it. I would not  
25 commit to saying that we would shove in a sense, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 elements in with it.

2 But we have a means of moving the element  
3 up and down, if absolutely necessary. But there's no  
4 commitment to it.

5 MEMBER KIRCHNER: Okay and again, but that  
6 would just be gravity as the, as the element --

7 (Simultaneous speaking.)

8 DR. DORON: Correct.

9 MEMBER KIRCHNER: -- was, the winch went  
10 in the opposite direction?

11 DR. DORON: Correct.

12 The idea here with the shutdown elements  
13 especially, is extreme simplicity. What we want is  
14 gravity insertion.

15 MEMBER KIRCHNER: Yes.

16 DR. DORON: And we want almost nothing else  
17 to be able to stand in the way of that gravity  
18 insertion.

19 MEMBER BALLINGER: Yes, this is Ron  
20 Ballinger. There's quite a difference between a dry  
21 bed, which is what the German pebble bed was, and a  
22 wet bed, which is what this is.

23 In other words, there's molten salt in  
24 there. So, it's not a dry bed where the rods have to  
25 jam down through there.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           It's kind of a well, let me get my way  
2 through this kind of thing with a lubricated bed.

3           DR. DORON: Yes.

4           MEMBER KIRCHNER: Yes, so my, one of the  
5 concerns I would have is just I'm sure you've looked  
6 at this.

7           As you described, there is an upper  
8 reflector. And as I understand it, that whole space  
9 is filled with Flibe.

10          During normal operations, the shutdown  
11 rods would be retracted into that space and up into  
12 the enclosure attached above the upper vessel head.

13          At some point, where does the Flibe stop,  
14 and do you have to worry about freezing of the Flibe  
15 preventing a gravity drop of the cruciform rod?

16          DR. DORON: That's a very good observation.  
17 The elements when I say quote, fully withdrawn,  
18 they're sitting in the reflector region just above the  
19 core, not above the hot well.

20          The tips are sitting below the hot well.  
21 So they're sitting right above the core region.  
22 Therefore, Flibe freezing wouldn't affect our  
23 insertion.

24          Does that make sense what I just said?

25          MEMBER KIRCHNER: Yes, as long as you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 didn't get cold spots or something, you know, as a  
2 result of tight clearance and tolerances.

3 DR. DORON: I mean, yes, but I guess that  
4 would need to be considered, but I don't see a  
5 physical way for that to happen in the transient time  
6 that we have.

7 MEMBER KIRCHNER: Thank you.

8 DR. DORON: Yes.

9 CHAIR PETTI: And just to confirm, as I  
10 recall reading the piece, there was no need for really  
11 rapid shutdown.

12 DR. DORON: That's correct.

13 CHAIR PETTI: These are like all gas  
14 reactors. They can take, it would be slower as long  
15 as they take their own time.

16 DR. DORON: Yes, you're correct.

17 CHAIR PETTI: Yes.

18 DR. DORON: This was my last slide.

19 CHAIR PETTI: Okay.

20 DR. DORON: I appreciate y'all's time, thank  
21 you.

22 MEMBER KIRCHNER: Dave, this is Walt.

23 CHAIR PETTI: Yes.

24 MEMBER KIRCHNER: Sorry to be so pesky  
25 today. I have another question.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1           It's a simple one, but I'm curious how  
2 competent you will be about your fueling system, and  
3 when you put the moderator pebbles into the reactor,  
4 how do you know where they are distributed vis-a-vis,  
5 the fueled pellets?

6           I assume that they'll, each type pellet or  
7 pebble, sorry, will have the same mass. But what's  
8 the, do you have any uncertainties as to where those  
9 moderator pellets are, pebbles are, such that you  
10 might get hot spots?

11           Or is it just statistically --

12           (Simultaneous speaking.)

13           DR. DORON: Yes.

14           MEMBER KIRCHNER: -- pretty random?

15           DR. DORON: I don't want to punt the  
16 question per se, but what I'd ask is coming up next is  
17 some nuclear design.

18           Our nuclear design manager is going to be  
19 talking. He'll be touching a little bit on the start  
20 up sequence.

21           MEMBER KIRCHNER: Yes.

22           DR. DORON: Then there will be a  
23 presentation I believe on the force on our pebble  
24 handling system, as well. Is that correct? Tomorrow,  
25 okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 I would ask maybe let's go through those  
2 presentations.

3 MEMBER KIRCHNER: Okay.

4 DR. DORON: And then let's revisit --

5 (Simultaneous speaking.)

6 MEMBER KIRCHNER: Yes, that's fair enough.

7 DR. DORON: Yes, and let's revisit that  
8 question after that. I think it will be better than  
9 me trying to talk at a blank screen right now.

10 MEMBER KIRCHNER: Okay, thank you.

11 DR. DORON: Okay, thank you.

12 CHAIR PETTI: So, let's then try to get the  
13 staff in before the break.

14 (Pause.)

15 MR. SCHMIDT: Hi, I'm Jeff Schmidt, Reactor  
16 Systems and Advance Reactor Division. I did the 4.2.1  
17 fuels review. And with me is Ben Adams. He did the  
18 4.2.2 and 4.2.3 reviews.

19 Go ahead, next slide. So this just  
20 described what I just said. So the 4.2.1 is the fuel,  
21 4.2.2 is the reactivity control systems that Kairos  
22 just went through, and 4.2.3 is the neutron source.

23 Go ahead, next slide. So 4.2.1, Kairos  
24 went through this as well, I'm going to go through it  
25 fast. Obviously, the TRISO particle, use of a larger

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 AGR-2 fuel kernel as I described.

2           Nominal AGR coating thicknesses, arranged  
3 in an annulus as they described. Smaller size than  
4 typical HTGR pebble size.

5           And then this also, this section also  
6 covers the moderator pebbles, the non-fueled pebbles  
7 as I described, and covers the fuel performance  
8 monitoring they also described.

9           Next slide. The regulatory basis  
10 preliminary safety analysis report, issuance of a  
11 construction permit, and common standards. We've seen  
12 that in multiple slides here.

13           The guidance we used was NUREG-1537 again.  
14 Principal design criteria. Sure, the principal design  
15 criteria for 1016 34 and 35 considered.

16           Next slide. And this just lets out that  
17 topical report, some of which we described already.  
18 Principal design criteria, we've described.

19           They also described the EPRI topical  
20 report, which is now the foundation for the TRISO  
21 particle that they're using.

22           Fuel qualification, we also discussed this  
23 morning. This deals primarily with the pebble  
24 protecting the TRISO particle, and the various tests  
25 they're going to do.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           And then one we didn't mention but we  
2 talked about previously, was their fuel performance  
3 methodology, which is going to use KP-BISON as their  
4 fuel performance code.

5           Next slide. Particles will be within the  
6 UCO particle parameters that they have in their  
7 topical report, table 5-5, EGR irradiated conditions  
8 found the Hermes expected normal operating conditions.

9           Expected possibly at an event the  
10 temperatures are below the 1600 C; the lowest AGR  
11 program safety testing temperature.

12           An AGR test program did not include  
13 overpower transient test and we'll describe that, or  
14 discuss that in the following slides.

15           Pebbles, the fuel pebbles. The actual  
16 pebble material, the outer matrix is not credited as  
17 a fission production retention.

18           The topical report, the fuel qualification  
19 topical report, addressed pebble testing. Specific  
20 correlations if necessary, will be derived from the  
21 test data and applied in the Hermes FSAR.

22           So things like pebble oxidation rates,  
23 their testing. They may use different ones in the  
24 final design, based on their testing relative to what  
25 they used in the PSAR.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Moderator pebbles contained no fuel, and  
2 is a non-safety related component. Same material as  
3 the fuel pebble matrix.

4 Testing for buoyancy, wear, strength,  
5 salt, ingress will be the same as the fuel pebble  
6 described in the fuel qualification topical report.  
7 The PHS will inspect the fuel pebbles, and also the  
8 moderator pebbles.

9 The staff, the staff's review for the  
10 moderator pebbles focused at least from a fuel  
11 standpoint, focused mostly on the impact of any  
12 potential debris generated that could impact safety  
13 functions, like the fluidic device. And, the natural  
14 circulation flow paths.

15 So it was almost focused on, at least from  
16 this aspect, debris generation and any impact because  
17 it's a non-safety related component.

18 MEMBER KIRCHNER: Jeff, this is Walt.

19 MR. SCHMIDT: Yes.

20 MEMBER KIRCHNER: Sorry to interrupt again.

21 MR. SCHMIDT: Sure.

22 MEMBER KIRCHNER: Could you elaborate on  
23 that last sub-bullet, because why wouldn't that also  
24 be an issue for the fuel topical?

25 MR. SCHMIDT: It is for the fuel but you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 know, they have, as outlined in the fuel qualification  
2 topical report, they have extensive testing to make  
3 sure that that does not happen, right?

4 MEMBER KIRCHNER: Okay.

5 MR. SCHMIDT: What wasn't described in the  
6 fuel qualification topical report is, what are you  
7 doing for the moderator pebbles.

8 So, the staff wanted to make sure that the  
9 moderator pebbles and its effect on the safety  
10 functions, were also addressed.

11 And that's why the PSAR brings that  
12 specific issue to light.

13 MEMBER KIRCHNER: Okay, thank you.

14 MR. SCHMIDT: So the AGR test program  
15 performed relatively slow heat ups, like those  
16 experienced for a loss of flow type events.

17 It does not really cover the Hermes  
18 overpower transient heat up rates, which are  
19 significantly faster than the AGR tests.

20 Overpower events can potentially lead to  
21 fuel melt, or non-melt mechanical failures. Limiting  
22 overpower transients are generally rod injection, and  
23 rapid element withdrawals.

24 Rod injection is precluded by design, and  
25 this event is a low differential pressure that was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 discussed earlier today.

2 Staff evaluated the maximum control  
3 element withdrawal, presented in Figure A1-2 for the  
4 postulated event analysis methodology, the technical  
5 report KP-TR-018.

6 So that was, we're using that information  
7 to inform our review of whether overpower transient  
8 would be necessary, overpower transient testing would  
9 be necessary for the Hermes testing.

10 It gives us an idea of what type of rapid  
11 positive reactivity we could be having.

12 Next slide, please. So here are some  
13 specific numbers. The maximum control element  
14 withdrawal temperature is 1080 C.

15 This is well below the unirradiated UC  
16 temperatures 1.96 and 1.86 of 1800 C, and 2350 C. And  
17 I just point out that the AGR program, they really  
18 only identified UO2 UC and the UC 18.

19 So the 2350 is the, probably the most  
20 appropriate temperature out of those. I just listed  
21 the other ones as the lower bound.

22 When I did literature searches, the 1.96,  
23 UC 1.96, had something down to 1820, but it was not  
24 identified in the AGR program.

25 The energy deposition for this transient,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 for their transient, is a complete control element  
2 withdrawal, was significantly below the 1400 Jules per  
3 gram for UO<sub>2</sub>, for the failures identified, and for  
4 fresh UO<sub>2</sub> testing that has, was done in Japan.

5 Overpower event non-melt failures are also  
6 expected to be negligible. The time to reactor trip  
7 is approximately 10 seconds, so the event from, from  
8 withdrawal to trip is 10 seconds.

9 The fuel thermal time constant is between  
10 30 and 300 milliseconds. And over that time period,  
11 basically the energy has time to escape the particle  
12 and get into the environment.

13 NC wouldn't expect melt or even non-melt  
14 failure modes to occur.

15 Let's go to the next slide, please. And  
16 this is the graph of that. So basically the delta t  
17 across the particle versus the energy deposition  
18 duration, for a range of Jules per gram.

19 And you can see, you know, we're talking  
20 like a 10 second evolution. You can see there's  
21 almost no delta t across the particle that would be  
22 driving potential failure modes.

23 And that's really an important aspect of  
24 how the staff got to the conclusion that overpower  
25 transient testing is not necessary for, for, excuse

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 me, for the Hermes design.

2 I'm dry today. Any questions on this  
3 slide before I go on?

4 No? The vertical line for the dash is  
5 (audio interference). Negligible incremental failure  
6 is predicted by the KP-BISON.

7 So, in addition to that graph I just  
8 showed you, you know, we also brought in other aspects  
9 to determine you know, if overpower transient testing  
10 was necessary for the Hermes design.

11 And these are some of the other  
12 considerations that the staff used, in reaching its  
13 determination.

14 You know, we just looked at the KP-BISON  
15 results. The KP-BISON is not validated but it is  
16 informative. It's not necessarily wrong at this  
17 point, so we used that as kind of a means of  
18 supporting our argument.

19 And, that predicted Service incremental  
20 failures. There was no difference between the in-  
21 Service normal, and the transient induced failures.

22 If you look at those failure fractions,  
23 they're identical. So while we'll look at that again  
24 at the OL after they've done the VNP, but right now,  
25 you know, we're not seeing any significant incremental

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 failures.

2 And, that's not surprising based on the  
3 testing that has been done in the AGR programs is you  
4 know, I know there's slower transients, but you didn't  
5 really see any type of significant jump in incremental  
6 fails till you got pretty high temperatures from 1800  
7 C, so.

8 Based on the low predicted maximum TRISO  
9 temperatures of this design, the corresponding margin  
10 to melt, the low stress caused by the small  
11 differential coating temperatures, and the review of  
12 the preliminary BISON results, the staff finds that  
13 incremental failures are not expected during the worst  
14 case overpower transient events.

15 And you know, transient, overpower  
16 transient testing is not necessary to support the  
17 Hermes application.

18 Next slide. So this is on fuel  
19 performance monitoring. That was also discussed by  
20 Ryan. Three non-destructive means are available to  
21 monitor fuel performance.

22 Cover for gas, reactor coolant, technical  
23 specification reactive coolant as given in PSAR  
24 Chapter 14, but specific values will be provided as a  
25 part of the OL.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Fuel pellets will be examined for damage  
2 and burn up, by the pebble handling system. Pebbles  
3 which show abnormal wear, cracking, or surfaces will  
4 be removed from Service.

5 Pellets will be discharged to prevent  
6 exceeding the burn up. And that was all discussed  
7 prior during our fuel qual topical report review.

8 Next slide. Destructive testing of the  
9 Hermes fuel will be formally stated in the section  
10 3.9.3, of the fuel qualification topical report, KP-  
11 TR-011.

12 Destructive testing will determine failed  
13 fuel fractions, pebble wear, and in the extent if any,  
14 of Flibe ingress.

15 Destructive testing can provide additional  
16 fuel performance code validation, and provide input  
17 to, to revise any future KP-FHR or fuel FIRT, if  
18 necessary.

19 Next slide. Technical evaluation  
20 conclusions. Pressure particles are expected to  
21 operate within the bounds defined by AGR-2 test data.

22 Incremental failures are expected to be  
23 negligible based on all the events, including the  
24 worst overpower transient.

25 Fuel moderator pebble testing programs are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 sufficient to develop relevant acceptance criteria  
2 correlations, to ensure pebble safety.

3 Safety functions are satisfied, and the  
4 fuel monitoring is adequate to determine unexpected  
5 fuel failures to determine those.

6 I guess I'm just going to pause there  
7 before we go on to the 4.2.2 section, to see if  
8 there's any questions from the 4.2.1.

9 That covers a lot of information here.

10 MEMBER KIRCHNER: Jeff, this is Walt again.

11 Just a rhetorical question. What if in  
12 your last bullet on the preceding slide, the activity  
13 detected in the cover gas system turns out to be  
14 higher than expected?

15 Would you then look for destructive  
16 testing of pebbles, to make sure there wasn't  
17 manufacturing induced defects?

18 I mean one of the not open questions, but  
19 certainly one of the changes in this design from the  
20 German pebble, is to go to an annular fuel region with  
21 a higher packing fraction.

22 So substrat you know, the overcoat when  
23 you compress and fire the final fuel form, isn't as  
24 how should I say forgiving, as in, as in the German  
25 pebble bed design.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. SCHMIDT: Yes --

2 (Simultaneous speaking.)

3 MEMBER KIRCHNER: So given that this is a  
4 test reactor, would you then look at the performance,  
5 and then look for the applicant to, or well, it would  
6 be in the operating mode by that point, do destructive  
7 testing?

8 MR. SCHMIDT: Yes, I think initially, you  
9 know, it's going to be governed by some type of tech  
10 specs, right.

11 You start to see activity levels above  
12 what you anticipate, you're going to have to take some  
13 type of action. And, I guess that action will be  
14 defined at the OL as part of the tech spec actions.

15 You know, what you do from there on to  
16 identify what was causing that, I'm not so sure. You  
17 know, I'm not sure I know the answer to that.

18 CHAIR PETTI: That's a needle in a haystack  
19 problem.

20 MR. SCHMIDT: Yes.

21 MEMBER BALLINGER: But would you --

22 (Simultaneous speaking.)

23 CHAIR PETTI: It's a simple game of  
24 spectrocity. You won't be able to tell very easily.

25 MR. SCHMIDT: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR PETTI: And you're not going to  
2 destruct every pebble, you know.

3 MR. SCHMIDT: Yes.

4 MEMBER BALLINGER: Would you be able to  
5 find out in the pebble handling system if you waited  
6 long enough?

7 In other words, you detect that activity  
8 in the bed and it's not, it's not critical in any way,  
9 so you just hang on and wait until you see it.

10 You know that a pebble's got to be failed.

11 CHAIR PETTI: The handling system with  
12 spectrocity is all about burn up.

13 MEMBER BALLINGER: Yes.

14 CHAIR PETTI: So they look at cesium.  
15 Okay, if you fail the particle, cesium's going to get  
16 out. It's going to get into the matrix.

17 But you're not going to see that most  
18 likely, with the spec system, the gamma spec system.  
19 It's just going to look like the cesium, yes, it's  
20 moved a little bit.

21 MEMBER BALLINGER: Could something to be  
22 done to the handling system to, to allow for  
23 additional resolution, if you will?

24 CHAIR PETTI: The only way that I know that  
25 would be a program of SAR failures physically, is in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 destructive examination.

2 You knew you had them in radiation from  
3 gas activity, but then you couldn't say which one it  
4 was until you did something more sophisticated.

5 MR. SCHMIDT: You would have to do  
6 something different. They have not committed to this,  
7 so don't get wrong. This is just my idea of like you  
8 know, they do sipping for a light water fuel.

9 You could arrange some type of off gas  
10 type sipping arrangement, that may identify what  
11 pebbles have significant failures that could go to  
12 destructive testing.

13 But I mean that's just speculation on my  
14 part, nothing more.

15 MEMBER KIRCHNER: Yes, that's what I was  
16 thinking, Jeff, that you would have, you said sipping.  
17 I would say sniffing in this case.

18 MR. SCHMIDT: Okay, okay.

19 MEMBER KIRCHNER: But, yes. Okay, well,  
20 this is the advantage of having a prototype test  
21 reactor. Okay, thank you.

22 MR. SCHMIDT: Yes. Any other questions  
23 before I move on?

24 MR. ADAMS: Good afternoon, I'm Ben Adams.  
25 I will be going through the 4.2.2 section on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Hermes reactivity control and shutdown system.

2 CHAIR PETTI: Either speak louder, or pull  
3 it towards you more.

4 MR. ADAMS: Is this good? Does this sound  
5 better?

6 Okay, I'll start over.

7 Hi, I'm Ben Adams, and I'll be going  
8 through the 4.2.2 section for the Hermes reactivity  
9 control and shutdown system.

10 The regulatory basis is the same as it's  
11 been in the previous presentations. It is 10 CFR  
12 50.34(a), 10 CFR 50.35, and 10 CFR 50.40.

13 The relevant guidance that we used to  
14 conduct the review of the section was also NUREG-1537,  
15 and the findings in this section are related to same.

16 The Hermes design is consistent with the  
17 principal design criteria, which are listed on the  
18 slide here.

19 That's going to be PDC 2 design basis for  
20 protection against natural phenomena.

21 PDC 4 environmental and dynamic effects  
22 design basis.

23 PDC 23, protection system failure modes.

24 PDC 26, reactivity control system.

25 PDC 28, reactivity limits, and PDC 29,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 protection against anticipated operational  
2 occurrences. All but one of the findings in the  
3 section are linked to the PDC.

4 We can go to the next slide. So this is  
5 a bit of an overview slide and Kairos discussed this  
6 just right before we did, but I'll go through some of  
7 it again.

8 The reactivity control and shutdown system  
9 is credited shutdown, the RCSS and sort of safe  
10 shutdown by inserting electronic elements to control  
11 reactivity during normal operation and response to  
12 normal conditions for postulated events.

13 There are four control elements, and three  
14 shutdown elements, and they all use the B4C absorbent  
15 material.

16 In the PSAR, Kairos committed to  
17 periodically inspecting the shutdown limits for wear,  
18 and damage to the cladding that encapsulates the B4C.

19 And they've also committed to monitoring  
20 the Flibe coolant for boron content, which would  
21 provide the location of the B4C cladding failure, and  
22 the control limits and shutdown limits can also be  
23 removed and inspected, or replaced.

24 We are comfortable at the construction  
25 permit stage with this level of information that the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 specific details of the monitoring and performance  
2 monitoring requirements will be handled later at the  
3 OL stage.

4 Dan, the other slide, go back one slide.  
5 Okay.

6 At the control elements, they insert into  
7 the graphite reflector on the periphery of the core,  
8 and they have a range of insertion positions.

9 The shutdown elements insert directly into  
10 the bed, and they should either be fully withdrawn, or  
11 fully inserted.

12 And they are credited with shutting down  
13 the reactor, unlike the control elements.

14 We don't have a picture of them, but  
15 Kairos had one in their presentation, of they had  
16 different designs and different geometries.

17 We won't be looking at the differences and  
18 the exact design of the geometries at the OL stage,  
19 and we'll talk a little why about it in the 4.5  
20 presentation in a little more detail.

21 Next slide. We kind of talked about the  
22 counter-weighted winch system. I won't read through  
23 the bullets to describe exactly how it works.

24 But the PSAR does give a preliminary  
25 design description of the counter-weighted winch

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 system.

2 The release of the clutch is a safety  
3 related mechanism and again, we discussed this a  
4 little more in our PDC 26 writing, and Section 4.5.

5 We don't have the exact specific details  
6 on what this counter-weighted winch system looks like,  
7 like exactly how the rope is supposed to stay in the  
8 sheave, or exactly how the clutch releases the  
9 elements. We will be reviewing those specific details  
10 later at the OL stage.

11 Go to the next slide. So talk about the  
12 findings for the PDC. PDC 22, the design basis and  
13 protection against natural phenomena.

14 Kairos will perform a one-time test before  
15 operation that deflects the shutdown on the chi  
16 structures by a maximum misalignment that would be  
17 caused by a design basis earthquake, in order to  
18 confirm that the element insertion time is counted by  
19 the insertion time that's assumed in the Chapter 13  
20 analysis.

21 Staff finds that this is consistent with  
22 PDC 2, and we will discuss that analysis, I believe  
23 with Chapter 13 on April 18.

24 Okay, for PDC 4, environmental and dynamic  
25 effects design basis. Kairos will perform testing for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 a shutdown element wear during movement, and will also  
2 be expecting analyses for the shutdown element  
3 internal gas release, and B4C swelling and other  
4 stress limits.

5 B4C will be monitored like I discussed  
6 earlier.

7 And the, Kairos will also perform analyses  
8 for the shutdown elements and control elements, to  
9 show that they meet the AMC standards that are  
10 discussed in the PSAR.

11 Staff finds this is consistent with PC 4  
12 and the NUREG-1530 acceptance criteria, that says the  
13 RCSS must be designed to withstand anticipated  
14 stresses, and the chemical and radiation environment.

15 Next slide. For PC 23, protection system  
16 failure modes, the shutdown limits accomplish safe  
17 shutdown via gravity insertion on a reactor trip  
18 signal, or on a loss of normal electrical power.

19 The removal or loss of power, causes the  
20 electromagnetic clutch to open.

21 Staff finds this is consistent with PDC  
22 23, and the NUREG-1537 acceptance criteria.

23 PDC 26, reactivity control systems, that  
24 will be discussed in Section 4.5 later today.

25 For PDC 28, reactivity limits, the NRC

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 staff performed its scoping calculations for the  
2 transients based on the preliminary information given  
3 in the PSAR.

4 We will discuss these calculations in  
5 detail with the Chapter 13 presentation, on April 18.

6 But they did show that TRISO fuel remains  
7 or maintains integrity during a partialated insertion  
8 of excess for activity event, and this was used as a  
9 primary basis to say that the design is consistent  
10 with PDC 28.

11 And rod injection, we talked a little bit  
12 earlier about it, but I think we'll also be talking  
13 about it again in the Chapter 13 presentation.

14 Staff finds this is consistent with PDC  
15 28.

16 PDC 29, Kairos has planned testing for the  
17 shutdown elements, and they have testing for the  
18 shutdown element deflection during an earthquake, and  
19 shutdown element wear, again discussed earlier.

20 Kairos will perform periodic inspections  
21 of the shutdown elements and coolant, to look for  
22 evidence of shutdown element damage and failure, also  
23 like I discussed earlier.

24 And, staff finds this is also consistent  
25 with PDC 29.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           Next slide. 4D includance. The NRC staff  
2 finds that the preliminary design information  
3 provided, is consistent with PDC 2 for 23, 26, 28, 29,  
4 and it's consistent with the relevant acceptance  
5 criteria of NUREG-1537 that's discussed in the safety  
6 evaluation.

7           And the staff has reasonable assurance  
8 that the RCSS will perform its safety functions of  
9 reactivity control and shutdown.

10           I believe that's the end of the  
11 presentation for 4.2.2.

12           MEMBER BROWN: This is Charlie Brown. Can  
13 I ask a question on the control element reactivity  
14 control system?

15           The wire rope and winch. So, the wire  
16 rope, I understand help the drum rotates and the wire  
17 rope pulls them out.

18           But does that mean they can't be driven  
19 in? They have to go in just by gravity when you want  
20 to unwind the winch?

21           So there's no force driving these in if  
22 you wanted them to, such that if you had a seismic  
23 event that jammed the rods, control rods up at the  
24 top, they couldn't be driven in? They would be stuck  
25 out?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. ADAMS: Are you asking about it?

2 MEMBER BROWN: The wire rope that's kind of  
3 flimsy, that's what it seems like. I mean you pull  
4 them out, and then you use their weight to drive them  
5 back in, to let them sink back in if you release them.  
6 As you're controlling them. Incrementally.

7 MEMBER HALNON: Is there any chance of them  
8 binding up and not, gravity not being enough to put  
9 them down in?

10 MEMBER BROWN: No, and you can't drive  
11 these in with, with just the wire rope.

12 MR. SCHMIDT: This is Jeff Schmidt. Yes,  
13 that's right.

14 Their testing though, I think Ben  
15 mentioned that they're testing for the full deflection  
16 to ensure that they will go in under a design basis  
17 seismic event.

18 So, that testing is addressed.

19 MEMBER BROWN: So in other words, the  
20 sleeve that the control element is in, is wide enough  
21 and side-to-side, whatever the dimensions are, that it  
22 would absorb and still maintain, an open window all  
23 the way up and down, the top to the bottom?

24 MR. SCHMIDT: Yes, that's right. I think  
25 the better way to say it is like the maximum

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 deflection that may occur as it goes through the upper  
2 reflector, will be deflected and then ensure you know,  
3 like if you get a rapid trip signal, that it can still  
4 successfully insert.

5 MEMBER BROWN: If all the control elements  
6 stick out, can the shutdown elements still override  
7 and shutdown?

8 MR. SCHMIDT: Yes, so the shutdown margin  
9 we'll talk about in the next section.

10 MEMBER BROWN: Okay.

11 MR. SCHMIDT: Just the in-bed rods are  
12 sufficient to meet shutdown margin. The control  
13 elements, I'm sorry, I said rods, I should say  
14 elements. My old habits.

15 Yes, these are all elements. The control  
16 elements just add a defense in-depth. They're not  
17 necessary for shutdown.

18 MEMBER BROWN: So if they didn't unlatch,  
19 okay, the drums did not disconnect, whatever, and all  
20 four stuck out, or all three stuck out. I've  
21 forgotten which ones are which.

22 Then the shutdown elements going in would  
23 override, and still provide the shutdown margin you  
24 need. I think I'm trying to phrase that the way you  
25 did, or properly.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 Is that correct?

2 MR. SCHMIDT: Yes, I can actually do a  
3 little better, too, because it's there are three  
4 shutdown elements that go into the bed.

5 Only two are necessary for shutdown margin  
6 because you need the 10 minus one.

7 MEMBER BROWN: Yes, those are the inside,  
8 inside elements, right?

9 MR. SCHMIDT: Yes, the inside, in-bed  
10 elements.

11 The control elements are in the  
12 reflective.

13 MEMBER BROWN: Okay.

14 MR. SCHMIDT: They are not credited for  
15 shutdown margin in any way.

16 MEMBER BROWN: Okay, all right.

17 Thank you.

18 MR. ADAMS: Okay, let's go to the 4.2.3,  
19 for the neutron start up source. This is just going  
20 to be one slide.

21 This section was reviewed using NUREG-1537  
22 again.

23 For the overview, PSAR does not specify a  
24 source type, but it does say that they will have one  
25 and that it performs no safety related functions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           This did meet one of the acceptance  
2 criteria in NUREG-1537, that says the neutron start up  
3 source should be capable of performing in its  
4 environment, and removable and replaceable, which is  
5 discussed in the PSAR.

6           We do not know any of Kairos's plans for  
7 inspection or monitoring of the neutron start up  
8 source. Those will be evaluated at the OL stage.

9           We will be looking for specific details at  
10 the OL, such as source type, exactly how it interacts  
11 with the start up plans, and power monitoring, so both  
12 of which will be reviewed at the OL stage.

13           We can go to the next slide. The NRC  
14 staff concludes that the preliminary, or this is 4.2.2  
15 slide. Jeff, did you want me to do this, or?

16           MR. SCHMIDT: Go ahead.

17           MR. ADAMS: Okay. The NRC staff concludes  
18 that the preliminary design provided at PSAR Section  
19 4.2 is consistent with the applicable PDCs and  
20 acceptance criteria in NUREG-1537.

21           The NRC staff finds that the information  
22 in Hermes PSAR Section 4.2, is sufficient for the  
23 issuance of a construction permit in accordance with  
24 10 CFR 50.35 and 50.40.

25           And, further information can be reasonably

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 left for the OL application.

2 CHAIR PETTI: Okay, member questions?

3 DR. SCHULTZ: Yes, just one question to go  
4 back to the shutdown element testing.

5 The two tests that are performed, one is  
6 for demonstration that even in the adverse  
7 positioning, which might occur during an earthquake,  
8 the drop is going to occur. That's one test.

9 And then also for testing to demonstrate  
10 that with wear, the shutdown elements will also  
11 perform their function.

12 Is there periodic testing expected in the  
13 technical specifications, that it will be done as the  
14 reactor operates?

15 MR. ADAMS: We do not have those specific  
16 details yet, and we'll be looking at that at the OL  
17 stage for how that is handled either in tech specs, or  
18 some other commitment.

19 DR. SCHULTZ: When the more detail is  
20 available near the operating license. Good.

21 MR. ADAMS: Right.

22 DR. SCHULTZ: Thank you.

23 MEMBER BROWN: Yes, Charlie Brown again.

24 With the three shutdown elements, if one  
25 of them sticks out do, you still have shutdown margin?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. SCHMIDT: Jeff Schmidt, yes.

2 MEMBER BROWN: Even if all the control  
3 elements are stuck out also?

4 MR. SCHMIDT: Yes.

5 MEMBER BROWN: So you only need two  
6 shutdown elements to go in, regardless of the position  
7 of all the other elements and control rods, and  
8 control elements?

9 MR. SCHMIDT: Yes.

10 MEMBER BROWN: Okay, thank you.

11 CHAIR PETTI: Any other questions, members?

12 It is 3:00 o'clock. So we are ahead of  
13 schedule. We got one more presentation in before the  
14 break. So let's break till 3:20 and we'll wrap up  
15 today with the Section 4.5. Okay.

16 (Whereupon, the above-entitled matter went  
17 off the record at 3:00 p.m. and resumed at 3:20 p.m.)

18 CHAIR PETTI: Okay, sorry, Kairos, let's  
19 go.

20 MR. SATVAT: Good afternoon, everyone. My  
21 name is Nader Satvat, Senior Manager of Nuclear  
22 Design. I will be presenting Section 4.5 of PSAR for  
23 nuclear design.

24 As presented on that image on the right,  
25 which is the neutronic model of the core, the reactor

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 core is a packed bed with spherical pebbles. The fuel  
2 pebbles contain six grams of uranium. They are  
3 enriched up to 20 percent, 20 weight percent uranium  
4 235. Moderator pebbles are used to improve neutron  
5 moderation in the core.

6 The core contains approximately 60 percent  
7 pebbles and 40 percent reactor coolant by volume,  
8 which is basically the packing fraction of the packed  
9 bed. The core is slightly under-moderated, which  
10 means negative temperature of coolant and negative  
11 void feedback of the reactor.

12 The general features of the core is that  
13 it's continuously refueled. The pebbles are inserting  
14 from the bottom of the core. They stay for a period  
15 of time within the core region. They're extracted  
16 from -- with pebble extraction machine. Go through  
17 the inspection and then if decision is made for them  
18 to recirculate, they'll go back to the core, up to  
19 their design burnup.

20 The residence time of the pebbles in the  
21 core is, at -- for each pass, is about 30-50 days.  
22 They're slow -- they're significantly slower compared  
23 to the coolant flow.

24 The reactor core is surrounded by a  
25 graphite reflector. The graphite reflector works as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 -- to increase the neutron economy, provides  
2 moderation and reflection for neutrons. It shields  
3 the reactor structure and maintains the core geometry.

4 Core design methodology is described in  
5 core design and analysis methodology, the Technical  
6 Report 017.

7 This is some of the properties of the  
8 core. The power level of the reactor is 35 megawatt  
9 thermal. The core engines of analysis for nuclear  
10 design is SERPENT-2 continuous energy Monte Carlo code  
11 and STAR-CCM for both disparate element modeling of  
12 pebble dynamics and thermo hydraulics.

13 The coolant is Flibe, enriched in lithium-  
14 7. The shutdown margin is set at .99. I'll talk  
15 about that a little bit later. As pointed out by Dr.  
16 Doron, there are seven total RCSS, three shutdown  
17 elements and four control elements.

18 The irradiation limit -- the irradiation  
19 of the vessel is below .1 dpa, which is set in our  
20 metallic topical report as low level radiation limit.  
21 Inlet temperature is 550 degrees C. The maximum  
22 reactor outlet temperature is 650 C.

23 The core volume is 2 meter cubed.  
24 Enrichment of the fuel, as pointed out, 20 weight  
25 percent uranium 235. The core is a slightly under-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 moderated, which means negative reactivity  
2 coefficient. And also negative reactivity coefficient  
3 for the coolant temperature and void.

4 This seems like a busy slide, though I'll  
5 try to walk through it. There are three boxes here.  
6 One is a green box, an orange box, and a purple box.  
7 The green box is our safety tools, meaning the output  
8 of core design calculations to safety analysis is  
9 derived from the blue box.

10 On the blue box, there are two main  
11 engines, STAR-CCM plus, which provides the pebble  
12 dynamics through the core, and also the temperature  
13 distributions. Using porous media application and  
14 SERPENT-2 is a continuous energy Monte Carlo tool,  
15 which does neutron and gamma transport and provides  
16 the core physics parameters.

17 There are two internally developed  
18 methods, or I like to point, refer to them as  
19 wrappers. They basically, the KPATH is the core  
20 thermo hydraulics, which couples SERPENT to STAR-CCM  
21 to provide temperature distribution. And the feedback  
22 of temperature on power and vice versa.

23 KPACS feeds in pebble flow dynamics from  
24 disparate element modeling of STAR-CCM and simulates  
25 the pseudo steady state operation of a pebble bed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 reactor. It's very similar to how VSOP was modeled  
2 for pebble bed reactors prior to us. The difference  
3 is that KPACS works on the higher fidelity domains of  
4 both SERPENT and STAR-CCM.

5 The purple box is our nuclear data  
6 processing. We do process ace libraries internally.  
7 There is a verification process for them. And we do  
8 use different libraries to make -- to understand the  
9 biases of different libraries that are out there,  
10 including JEFF and ENDF 7, 1, and 8.

11 The support tools, the orange box is  
12 mostly used for design purposes. The KP-AGREE is  
13 spatial kinetics with thermo hydraulics feedback. It  
14 is used for understanding the behavior of the reactor  
15 as we move through different phases of operation.

16 And the MCNP is used for radiation  
17 transport and also for code-to-code benchmark of  
18 SERPENT. There's a tool missing on this box, and  
19 that's the scale. The scale is used internally as for  
20 code-to-code benchmark and a large space of  
21 uncertainty analysis for other neutronics domain is  
22 performed using SKID.

23 The core life cycle of a pebble bed  
24 reactor, it is very common across pebble bed reactors,  
25 there is -- there are four distinct phases or three --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 there is an approach to criticality that we are using,  
2 a very safe approach to criticality for Hermes  
3 reactor, which we go to criticality.

4 Once the tests are performed, we start  
5 ascending to power. There is a phase in ascension to  
6 power which is called low power. We won't go through  
7 low power core compositions. Set of low power testing  
8 will happen. I will talk about it a little bit more  
9 on the next slide.

10 Once everything is done, then the reactor  
11 will start ascending to 100 percent power. Throughout  
12 those power ascension, there are number of other  
13 bullet points, which different tests will be  
14 performed. Not just core physics outside of that,  
15 also test of environment and radiation will be  
16 performed.

17 Once reaching 100 percent power, the  
18 reactor will -- they will stay there. And if Hermes  
19 operates long enough, ultimately the core will reach  
20 an equilibrium state, which largely the radionuclide  
21 inventory is going to stay unchanged in equilibrium.

22 This is the summary of what was presented  
23 in the last -- last slide. For approach to  
24 criticality, a combination of fresh fuel, natural  
25 uranium, and moderate -- moderated pebbles are added

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 to core using a one over M approach.

2 Natural uranium is used as a knob for  
3 managing the effective enrichment of the core and  
4 keeping the core in a desired moderation level with  
5 respect to reactivity coefficients.

6 Once reactor achieves the criticality, the  
7 core composition will change to a low power core  
8 composition. The primary salt pump will follow the  
9 power. And the reactor will start ascending through  
10 different set points to 200 percent power.

11 Power defects, xenon, and burnup is  
12 compensated by control rods and fresh fuel addition.  
13 And as pointed out earlier, once reactor achieves --  
14 goes to 100 percent power and if it operates long  
15 enough at that state, the core will ultimately evolve  
16 into an equilibrium core.

17 And there is a steady state of removal of  
18 this charged pebble, which pebbles that are reached  
19 their design burnup, and fresh pebbles will replace  
20 them at the core. All --

21 CHAIR PETTI: Just a question on the  
22 natural uranium pebbles.

23 MR. SATVAT: Yes.

24 CHAIR PETTI: You said you did it -- it's  
25 for reactivity control? Because you know, gas reactor

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 pebble bits don't start up with natural uranium, they  
2 just start up with graphite pebbles and the regular  
3 fuel.

4 MR. SATVAT: Yes, Dr. Petti, this is  
5 another -- natural uranium pebbles are used -- if we  
6 only rely on graphite pebbles and fuel pebbles in our  
7 reactor, and fill the core with fresh fuel and  
8 graphite pebbles, if you would like to keep excess  
9 reactivity to a desired level, the core will be over-  
10 moderated.

11 So we are using natural uranium pebble as  
12 a mean to keep the effective enrichment and carbon to  
13 -- carbon to heavy metal alloy ratio in a desired  
14 place.

15 CHAIR PETTI: Okay, I got you.

16 MEMBER KIRCHNER: Yeah, Dave, I was going  
17 to ask the same question. So these natural -- natural  
18 uranium pebbles, what's the fuel form?

19 MR. SATVAT: It is -- they're exactly the  
20 form of a TRISO particle as it is in our enriched  
21 fuel.

22 MEMBER KIRCHNER: So you're going to  
23 actually have a TRISO line that uses natural uranium?

24 MR. SATVAT: Yes.

25 MEMBER KIRCHNER: Okay. And this will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 prevent an over-moderated state?

2 MR. SATVAT: Precisely.

3 MEMBER KIRCHNER: Why couldn't -- why  
4 couldn't you -- never mind, okay, thank you.

5 MR. SATVAT: To add to that, the HTRPM,  
6 the Chinese reactor, they're actually using different  
7 enrichment. They're using lower enriched all the way  
8 up to their highest enriched for a startup, and they  
9 continuously remove lower enrichment.

10 That might be something we consider for  
11 future larger reactors, but for Hermes, we found this  
12 to be a desired approach.

13 MEMBER KIRCHNER: Yeah, that was done in  
14 other reactors to change the enrichment level to avoid  
15 the over-moderation problem. Okay, thank you.

16 CHAIR PETTI: And then just a question,  
17 you said you'd check the reactivity coefficients on  
18 startup. But is there any plan, or is it easy to do  
19 it as you approach equilibrium?

20 MR. SATVAT: The isothermal temperature  
21 reactivity coefficient will be tested during low power  
22 regime. Currently the detail of all the physics  
23 testing that will be performed is being completed and  
24 will be provided as part of operating license  
25 application.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           But we believe if we perform the  
2 isothermal throughout the low power, we can rely on  
3 our predicted models not to have to continuously  
4 measure it as we move through different core  
5 compositions.

6           CHAIR PETTI: Okay.

7           DR. SCHULTZ: Nader, this is Steve Schultz.  
8 Can you give an idea what the timberline is for moving  
9 through these various stages approaching criticality  
10 for Hermes, going through the ascension to power, and  
11 the -- how long does it take to get to the equilibrium  
12 core, as you see?

13          MR. SATVAT: That's a very good question.  
14 So the time that it takes to get to equilibrium is  
15 basically the -- where the core will assume an average  
16 burnup distribution --

17          DR. SCHULTZ: Yes.

18          MR. SATVAT: Of the equilibrium core. It  
19 is -- in our calculations, usually it reaches around  
20 1.5 times the residence time of the pebbles. So if we  
21 ascend to power rapidly and stay at 100 percent power,  
22 whatever the residence time is is going to be close to  
23 1.5 times that is the time that it takes to get to  
24 equilibrium.

25          DR. SCHULTZ: And that, you mentioned that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 could be around 40, 50 days, something like that for  
2 the residence time?

3 MR. SATVAT: Thirty, 40 per pass, which  
4 means we're designing to six pass. And again, those  
5 details will be refined for oil. But as of now, there  
6 are six passes. So if there are 50 days, there are  
7 about 300 days of residence time.

8 DR. SCHULTZ: Okay. Okay, thanks, that  
9 helps a lot.

10 MR. SATVAT: Sure. As a last point on  
11 this slide, all core states will operate within  
12 coolant temperature to coolant reactivity coefficients  
13 power for particle limits and excess reactivity  
14 constraints.

15 The design basis. There are two important  
16 PDCs that are met in this slide. The reactor core is  
17 designed so that the power oscillations that could  
18 result in conditions exceeding SARRDLs are not  
19 possible.

20 This is effectively due to the small size  
21 of the core of Hermes and the very long neutron  
22 migration length, which means the core is effectively  
23 neutronically connected. There is no credible way of  
24 having oscillations that -- that are seen in large  
25 LWRs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The reactor core is designed so that the  
2 net effect of prompt in paranuclear feedback tends to  
3 compensate for rapid increases in reactivity.

4           This is PDC-11. The overall reactivity  
5 coefficient is negative. It is provided -- the list  
6 is provided for fresh core and equilibrium core at the  
7 -- at the table below. The fuel Doppler is negative.  
8 The moderator is negative, so is coolant and the void.

9           The reflector temperature coefficient is  
10 positive. The positive reflector temperature  
11 coefficient is due to a spectrum hardening shift,  
12 which shifts flux towards the center of the core. It  
13 is due to reduce leakage. Also because of the locally  
14 over-moderated conditions by the reflector, periphery  
15 of the core.

16           Methodology does not assume any thermal  
17 expansion of reflectors, so it's actually  
18 conservative. It is on the higher end of being  
19 positive, the reflector temperature.

20           The reactivity impact due to the reflector  
21 temperature is delayed compared to fuel and coolant  
22 temperature feedback.

23           But at the last point here again, the  
24 overall feedback coefficient respond to temperature  
25 increase is negative at all conditions in -- in Hermes

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 reactor.

2 The next PDC, PDC 10, a limiting power  
3 distribution for the core design is used to ensure  
4 that the reactor has appropriate margin to SARRDLs.  
5 As pointed out in KP-FHR core design methodology,  
6 SERPENT-2 is used to calculate power distribution.  
7 Flux distributions are verified during startup and low  
8 power using the ex-core detectors.

9 Flux measurements compared to predicted  
10 values will ensure core is operating as designed.  
11 There are no consequence from control rod -- control  
12 and shutdown elements not being core, they're core  
13 symmetric.

14 And I'm putting that picture down there.  
15 As you can see, the yellow RC is the four of them  
16 around the core. They're not fully symmetric, but  
17 that's not causing an issue in a small core such as  
18 Hermes with long neutron diffusion length.

19 There are some example calculations  
20 provided in PSAR for -- in (audio interference) pebble  
21 peaking factor.

22 This is a busy slide, but bear with me.  
23 It's PDC-26. That first condition, shutdown elements  
24 credited to provide means to ensure SARRDLs are not  
25 exceeded and safe shutdown is achieved. This is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 assuming highest worth shutdown element fully  
2 withdrawn. So with only two shutdown element, we  
3 achieve this.

4 Shutdown elements insert reactivity at a  
5 sufficient rate, an amount to ensure the capability to  
6 cool the core is there. The reactor is shut down and  
7 can be maintained in a shutdown condition. It is  
8 again met with the highest worth element fully with  
9 the rod or stuck.

10 The second condition, control elements  
11 provide the capability to control reactivity change  
12 during normal power changes. This ensures SARRDLs are  
13 not exceeded and provide an adequate and separate  
14 means of reactivity control from RSS.

15 Control elements are diverse from shutdown  
16 elements. They have different geometry, different  
17 location, different insertion mechanism.

18 Condition number three, shutdown elements  
19 insert reactivity at a sufficient rate and amount to  
20 ensure the capability to cool the core is maintained.  
21 The reactor is shut down and can be maintained in a  
22 shutdown condition. This is again done with the fully  
23 -- with the highest worth element stuck out.

24 Shutdown elements provide a means of  
25 maintaining the reactor in a shutdown state to allow

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 for fuel loading, inspection, and repair.

2 And this is basically continuation of  
3 previous slide. The shutdown margin calculation  
4 accounts for power defect. The decay of xenon,  
5 operational excess reactivity and margin for  
6 uncertainties are incorporated in the calculations.

7 As pointed out before, the shutdown core  
8 is defined as k-effective of .99. The required worth  
9 for shutdown of the system is 11578 pcm. The total  
10 worth of shutdown elements is 14232 pcm.

11 And again, this is -- this is the required  
12 worth considers highest worth element with the rod.  
13 And as it can be seen, it's the first of a kind  
14 reactor, we recognize that the relying on general  
15 purpose nuclear library might introduce uncertainties.  
16 So we do have the required shutdown is 1000 but we do  
17 have 3652 of margin for shutdown.

18 The interfaces, these are the nuclear  
19 design, nuclear analysis interfaces that the -- is  
20 connected to the methodology. The vessel fluence  
21 supports reactor vessel design. Fluence on vessel  
22 accounts for core pebble insertion. Extraction lines'  
23 fluence is attenuated -- attenuated by the core  
24 barrel, reflector, and the coolant.

25 Preliminary best estimate DPA plus

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 uncertainty is shown to be 30 percent below the low  
2 level irradiation value provided in metallic material  
3 qualification for Kairos power.

4 Nuclear transient analysis, which supports  
5 the safety analysis conservative values used for power  
6 distribution, reactivity coefficient, and shutdown  
7 margin is provided as initial conditions for  
8 postulated reactivity transient events.

9 In -- they're provided in Table 7-1 with  
10 uncertainties and nuclear reliability factors as an  
11 output of the methodology.

12 The core design limits, which supports  
13 technical specifications, core design parameters  
14 during normal operation are shown to be within fuel  
15 qualification envelope for peak fluence, peak  
16 particle power burnup, and peak fuel temperature.  
17 Shutdown margin. Coolant outlet temperature moderated  
18 pebble to fuel pebble ratio.

19 I think that's it.

20 CHAIR PETTI: Members, any questions?

21 MEMBER KIRCHNER: Just one, Dave, from me  
22 again. How do you know where the moderator pebbles  
23 are, or now the uranium pebbles? In the HTGRs like  
24 THGR, the pebbles were dropped in kind of just  
25 randomly kind of built a packed bed core.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           Here, you're going to inject them from the  
2 bottom, I believe. Is the bed packing so tight that  
3 you have a good experimental basis for determining  
4 where the pebbles actually distribute themselves?

5           MR. SATVAT: That's the topic of disparate  
6 element modeling that we have for pebble dynamics in  
7 the core. We do have set up -- set up experiments  
8 internally to validate other models. So far, the  
9 packing fractions for escape tests that we have  
10 performed showed -- showed to give us a packed bed,  
11 close 60 percent.

12           MEMBER KIRCHNER: Yeah.

13           MR. SATVAT: So to answer that question,  
14 yes.

15           MEMBER KIRCHNER: Okay. Okay, thank you.

16           CHAIR PETTI: Just one more question.  
17 Your slide on the codes you're using, maybe it's  
18 because it's just a design. Didn't mention SAM, but  
19 the document did. Is that -- that's a -- I don't  
20 know, system-level code I guess on safety analysis.

21           MR. SATVAT: That's correct. These are  
22 steady state calculations that are -- that the  
23 boundary conditions are transient analysis. You are  
24 correct, Dr. Petti, those are done in our transient  
25 methodology, KP -- using KP-SAM.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR PETTI: Okay, got it, thanks. Any  
2 other questions, members?

3 Okay, then with that, staff.

4 MR. BIELEN: Hello, good afternoon,  
5 everyone. My name is Andy Bielen. I'm a Senior  
6 Neutronics Engineer in the Office of Nuclear  
7 Regulatory Research. I'm going to be presenting here  
8 with Ben Adams a review of PSAR Section 5.4, nuclear  
9 design. So, next slide, please.

10 So basically what we're going to do, I'm  
11 going to first talk about the review of the  
12 methodology technical report that they provided, which  
13 you know, a substantial fraction which is proprietary,  
14 so we'll try to keep this as a high level discussion.  
15 Then I'm going to go through some coping -- scoping  
16 analysis that the staff performed with the scale code  
17 suite.

18 And then I'm going to turn it over to Ben  
19 so he can talk about the PSAR content and our findings  
20 thereof.

21 Okay, so the regulatory basis is very  
22 similar to the other sections, or the other sections  
23 in Chapter Four, so the look through the preliminary  
24 safety analysis report. We have 50.35 that issued the  
25 construction permit, etc., etc.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           We have our non-power reactor SRP and then  
2           for PDC from Kairos's PDC topical report.

3           Okay, speaking of topical reports, so the  
4           PDC topical report is number one. Then there's a  
5           material, or metallic materials qualification topical  
6           report that's specifically applicable to the fluence  
7           limits. And then also this technical report, which is  
8           not a topical report, but is tied to the PSAR itself.

9           Okay, so I think -- I think that Kairos  
10          did a really good job of, you know, describing their  
11          methods. I don't want to get too far into the weeds  
12          on like what they're doing, other than to say within  
13          the methodology, we have two remaining physics codes,  
14          SERPENT-2, which is the transport code, and isotopics,  
15          it's based on the continuous energy Monte Carlo  
16          method.

17          They used Doppler broad and cross-section  
18          data provided up front by their ace library generator  
19          code. Then they'll also use STAR-CCM plus for doing  
20          the DEM solution of -- or DEM predictions pebbles as  
21          they move through the bed. And then also a porous  
22          media approach to calculate temperature and coolant  
23          distributions, or coolant density distributions.

24          And as -- as they said, there's two  
25          analysis sequences. There's KPATH, which is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 iterations between SERPENT and STAR-CCM for comparable  
2 neutronics and thermal fluidics.

3 And then they have KPACS, which is what  
4 they use to do their fuel cycle analysis. So they  
5 evolved the isotopics within the geometry using --  
6 using KPACS based on what the DEM tells them about how  
7 the pebbles move throughout the core.

8 Okay, so in terms of our evaluation of  
9 this methodology, I think the, you know, big picture,  
10 we think that it's a sound methodology. We think that  
11 they've accounted for the things they need to account  
12 for. I think we're not overly -- they're calculating  
13 a lot of different cross-section libraries based on  
14 temperatures, so they're not overly relying on on-the-  
15 fly interpolation.

16 They have adequate treatment of axial and  
17 radial zoning so they can capture spectral effects  
18 appropriately. Also accounting for the isotopics  
19 within different passes, depending on how many times  
20 they've gone through the core.

21 The coupling to the thermal fluidics is --  
22 seems to be reasonable and acceptable. We think that  
23 the models as a whole provide a robust means to  
24 calculate the things that they need to provide a  
25 transient analysis and also provide their shutdown

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 margin and reactivity coefficient, etc., etc.

2           And you know, one -- one point I would say  
3 is that, you know, when they calculate some of these  
4 feedback coefficients, they're doing it in a  
5 conservative way.

6           For example, you know, the specific  
7 composition of the Flibe as they're calculating the  
8 coolant temperature feedback would result in a -- in  
9 a conservative evaluation of that specific feedback  
10 coefficient. So yeah, I think the big picture, we  
11 think they're on the right track.

12           There are some, you know, remaining  
13 methodology items that I think that we need to close  
14 before we get to OL stage. As I've mentioned, or  
15 maybe didn't mention explicitly, but a lot of the PSAR  
16 analysis is -- is focused on kind of a nominal  
17 average, if you will, core performance. But as you  
18 know, these are stochastic machines.

19           So there's a -- some kind of uncertainty  
20 elements that need to be accounted for, both in the  
21 underlying physics, but also in, you know, the way  
22 that it would be operated in the different limiting,  
23 you know, configurations of particles that might  
24 randomly spawn themselves as they're -- as they're  
25 reloading this thing, you know, from the bottom.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1           So one element that they have to do some  
2 more work here is, you know, establishing the  
3 neutronics uncertainties. You know, as a starting  
4 point they've got a list of what they feel based on  
5 engineering judgment are conservative uncertainties  
6 and their key, you know, neutronics figures of merit,  
7 which feed into the safety analysis.

8           So you know, they need to -- they have  
9 additional work planned to verify the conservatism in  
10 those, you know, the assumed uncertainty in those  
11 different parameters. We expect to see, you know,  
12 some more details of that work at the OLA stage.

13           And another big, you know, missing item  
14 from the staff's perspective, and I know they've done  
15 some work internally on this thus far, but we have not  
16 yet seen anything specific on assessment or  
17 validation. Though there's descriptions of the  
18 validation plans within the -- within the technical  
19 report. And we want to -- we want to make sure that  
20 we get a chance to see that before we get to OL stage.

21           And then there are some kind of nitty, you  
22 know, during the review and during the, you know, the  
23 audit period, there were some of kind of nitpicky  
24 things that we were, you know, asking them questions  
25 about on specifics of various modeling approaches and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 just verifying that those modeling approaches were  
2 robust.

3 So you know, I think that those are things  
4 that they're on -- they'll be able to close, they're  
5 on track to close. But just kind of some things that  
6 we want to make sure that are accounted for before we  
7 get to -- get to the OL.

8 So you know, as such, I think we just want  
9 to be clear that right now, Kairos's neutronic design  
10 approach is not, quote unquote, reviewed and approved.  
11 But given closing these items, we think that they're  
12 well on their way to get there I guess, so.

13 So before I get into the scope and  
14 calculations, do you have any questions that I can  
15 just get or answer?

16 MEMBER HALNON: Just real quick, this is  
17 Greg. This alphabet soup of codes and stuff, it all  
18 seemed reasonable when you played it out? And did you  
19 guys diagram it out as well and make sure that there's  
20 no big hole in there from the standpoint of one code's  
21 beating another and that sort?

22 MR. BIELEN: Yeah, I think that like the  
23 way that the codes communicate within each other needs  
24 to be part of that validation and verification  
25 assessment --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER HALNON:    That's what you'll be  
2                   looking -- and I figure that we're not sending goofy  
3                   data to one place and coming up with a good result and  
4                   saying everything's good.

5                   MR. BIELEN:    That's right.    I mean, and  
6                   you know, when it comes to coupling codes or sending  
7                   -- doing data exchanges between codes, when you make  
8                   a mistake, it's usually obvious.    But it's -- that's  
9                   not guaranteed, obviously.    So you have to -- you have  
10                  to go through your QA process and make sure that  
11                  you're doing that appropriately.

12                  MEMBER HALNON:    Excellent, thank you.

13                  MR. BIELEN:    Okay.    Well, I'm just going  
14                  to walk through real quick here some scoping  
15                  calculations that we were able to do to support the CP  
16                  review.

17                  So hopefully the members are remembering  
18                  that over the last several years, the Office of  
19                  Research and the agency in general have been, you  
20                  know, kind of tasked with getting our codes and  
21                  methods analysis procedures prepared for non-LWR  
22                  licensing.

23                  So since 2018, 2019, 2020, we have, you  
24                  know, several different areas of applicability and  
25                  then different codes within those areas of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 applicability that we need to make sure that we can do  
2 non-LWR confirmatory and licensing support analysis  
3 with.

4 So part of this non-LWR vision and  
5 strategy, we have several different volumes. Volume  
6 3 specifically covers severe accidents in source term,  
7 which -- of which we have several demonstration plants  
8 depending on different technologies.

9 We happened to perform analysis on the  
10 publicly available UC Berkeley Mark 1 design, we  
11 represented a Kairos-like pebble -- TRISO pebbles with  
12 molten salt cool -- coolant. We used the SCALE code  
13 suite for decay heat and radioisotopic inventory and  
14 then reactor physics data performed by Oak Ridge  
15 National Laboratory.

16 And then our MELCOR code was used to  
17 simulate -- different accident progressions using the  
18 data that SCALE provided for it. And that was  
19 performed at Sandia.

20 So we did a demonstration workshop about  
21 a year and a half ago fully documenting this specific  
22 application.

23 And the good news is because we did that  
24 work ahead of time, we were able to rapidly, at NRR's  
25 request, adjust our models to be more Hermes-specific

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 and be able to perform an analysis like fairly quickly  
2 that I think really helped them form their engineering  
3 judgment and feel more comfortable and confident in  
4 the -- in the results they were seeing from the  
5 applicant. So, go to the next slide, please.

6 So one thing I want to kind of cover here,  
7 cover off the bat is this is, we're calling this  
8 scoping rather than confirmatory. First of all, given  
9 the licensing timelines we have for this reactor, we  
10 wanted to be able to do this within a rapid turnaround  
11 period.

12 So in fact, the initial discussion started  
13 in December of 2021. We started doing work in January  
14 of 2022. And the first briefing to NRR staff, you  
15 know, was by the end of -- the end of March of 2022.  
16 So we were able to do this within three months, which  
17 I think is, you know, fairly notable.

18 We want to, you know, we wanted to  
19 basically not go through the RAI process in case there  
20 were data that we -- data that we needed to have. So  
21 basically we did the best we could with what was  
22 available publicly in the Hermes PSAR.

23 Plus, you know, wherever there were gaps,  
24 you know, engineering judgment or applicable data from  
25 the -- from the UC Berkeley designed, you know, I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 think was able to come up with at least a reasonable  
2 surrogate for this model without -- while we all  
3 understand that, yes, there's going to be some  
4 differences. And those are probably reasons for some  
5 of those differences.

6 Now, I'll just point you to this -- this  
7 report from Oak Ridge on the overall SCALE FHR  
8 workflow. It's very similar to our work flow for the  
9 pebble bed gas reactors.

10 But basically, we're justifying a multi-  
11 group rather than continuous energy treatment. Then  
12 we described the process of generating an equilibrium  
13 isotopic inventory using 2D models that we then can  
14 feed into a full 3D core model and then do reactor  
15 physics stuff with that.

16 And you know, before I go too much  
17 further, I just want to make sure that I acknowledge  
18 Rike Bostelmann at Oak Ridge National Laboratory. She  
19 really led this work there. And you know, provided  
20 most of this analysis and explanation, and hopefully  
21 I don't butcher what she did too badly.

22 But the point is that we have this model  
23 of the FHR system that is a -- as close to Hermes as  
24 we can get based on what is out there in the public.  
25 We're using multi-group Monte Carlo transport using

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 KINO-6 for isotopics and you know, evaluating as how  
2 the isotopics evolve with operation.

3 So in the real system obviously it's a  
4 random packed bed. You know, given our current  
5 capabilities, like we have to make some assumptions  
6 and approximations in order to have a tenable run time  
7 for our model. So we're approximating these with a  
8 regular lattice.

9 As I mentioned, we use this 2D slice model  
10 with SCALE/TRITON to produce the TRITON sequence out  
11 of the SCALE code to produce equilibrium of isotopics.  
12 So these are -- so what you're seeing in this model is  
13 basically the isotopics vary axially from bottom to  
14 top.

15 Like each level of pebbles, even though,  
16 you know, we know that their -- different passes of  
17 pebbles will have different isotopics depending on  
18 what their specific history is. We're kind of  
19 smearing all that out into, you know, an axial average  
20 isotopics at each level basically.

21 So you know, it's nearly as high fidelity  
22 as I would say the SERPENT model that the applicant is  
23 using is. But you know, big picture, I think that  
24 it's adequate to get us the sort of information that  
25 we're interested in seeing.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           And another, you know, item of note here,  
2 we don't currently have the shutdown in bed elements  
3 within this model, which is obviously something that  
4 we are working on, but we haven't gotten that complete  
5 for -- in time for this presentation.

6           But you do see the -- we have those  
7 channels outside the core that would represent where  
8 the control elements go.

9           MEMBER HALNON: I'm getting confused a  
10 little bit, but weren't there three types of pebbles  
11 now? Fuel pebble, the natural uranium pebble, and a  
12 moderator pebble? Is there any distinction there?

13          MR. BIELEN: So I think the natural  
14 uranium pebbles were only in the startup core. So  
15 we're basically, we're performing an -- like the way  
16 that we generate these is to go directly to  
17 equilibrium.

18          MEMBER HALNON: Okay.

19          MR. BIELEN: So yeah. That's why we  
20 wouldn't -- we could do that if we wanted to. But I  
21 think, you know, from a limiting, you know, state  
22 point before an accident scenario from a decay heat,  
23 you know, radio inventory, radioisotopics point of  
24 view, the equilibrium is like a limiting --

25                   (Simultaneous speaking.)



1                   MEMBER HALNON: And that's the equilibrium  
2                   that we asked earlier about, which was 300,  
3                   potentially 300 days?

4                   MR. BIELEN: Something like that.

5                   MEMBER HALNON: So in the interim, you say  
6                   everything is bounded by that 300-day equilibrium?

7                   MR. BIELEN: I think that that's true in  
8                   general. There may be some specific things that  
9                   aren't, but you know, I --

10                  CHAIR PETTI: Inventory-wise, I agree with  
11                  you. But there may be events during startup that  
12                  challenge the systems in unique and different ways  
13                  than they would during --

14                  (Simultaneous speaking.)

15                  MEMBER HALNON: That's what I was thinking  
16                  about too, especially with the unknowns.

17                  CHAIR PETTI: Well, and you know, the  
18                  decay heat removal system has a certain capacity,  
19                  right. And then you're generating energy. At steady  
20                  state, everything looks good.

21                  But now, you know, you're at 7 megawatts  
22                  thermal or 10 megawatts, you know. Can you make sure  
23                  you don't remove too much heat to freeze? Those are  
24                  the sorts of things that I think are more interesting  
25                  to look at analytically.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER HALNON: That's noted, we can try  
2                   to adjust that going forward, so. Okay, so you know,  
3                   just to kind of walk through some of our results here  
4                   --

5                   MEMBER BROWN: This is Charlie Brown, can  
6                   I ask you a question?

7                   MR. BIELEN: Sure.

8                   MEMBER BROWN: I don't know whether -- I  
9                   don't know whether Dave and Walt and the others, I'm  
10                  not a fuels guy. But how in the world in this thing  
11                  with three or four or whatever it is types of pebbles  
12                  do you get any types of predictability on a uniform  
13                  distribution with these things moving up through the  
14                  core?

15                  You said you'd get an equilibrium, but I,  
16                  it's just hard to envision all these different pebbles  
17                  being fed in and then achieving any type of uniform  
18                  distribution throughout the core region. How do you  
19                  deal with that?

20                  MR. BIELEN: Yeah, I mean, so the way that  
21                  Kairos specifically deals with it I think we're going  
22                  to have to, you know, I'm going to defer to them to  
23                  discuss with you whatever proprietary details that  
24                  they want to share in this environment.

25                  But I will say that in general, you know,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 you have so many pebbles that it does become a very --  
2 it's a very kind of law of large numbers statistical  
3 process I guess.

4 Like, and that's the best way I can, you  
5 know, kind of describe it off the top of my head.  
6 Like I think that -- I think that in general you can  
7 represent the average behavior of the core and -- and  
8 the pebbles, you know, using -- using kind of  
9 averaging or stochastic methods.

10 And then for those special cases where  
11 hey, well, what happens if like there's some bunch of  
12 fresh pebbles get by chance randomly, you know, loaded  
13 next to each other or something like that.

14 In that case, then you would want to do  
15 like a special calculation or like a detailed  
16 calculation of that specific scenario to prove to  
17 yourself that you're, you know, meeting your thermal  
18 margins.

19 CHAIR PETTI: So Charlie, this is a  
20 question that's been around for a while. And a  
21 tremendous amount of work has been --

22 MEMBER BROWN: That's why I asked.

23 CHAIR PETTI: Has been done in the gas  
24 reactor realm. The concern at the time was all about  
25 the fuel, okay. They didn't know what the peak

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 temperature limits were for some of the fuel. And UO2  
2 TRISO had more restrictive limits.

3 And so knowing all these distributions  
4 well was more important. My personal view is with UCO  
5 TRISO, the temperature, a lot of these questions go  
6 away because, okay, we may -- you don't think you know  
7 it. But there have been tons of studies, tons of  
8 codes, international benchmarks on all of this stuff  
9 to show you do get to this, quote, equilibrium.

10 And what that means is just on average,  
11 okay, on average at a location in the core, that  
12 condition stays at that condition all the time. If  
13 there are seven pebbles in that volume, they can had  
14 different burnups. But on average you get the same --  
15 the same number.

16 MEMBER BROWN: So you don't have to -- you  
17 don't have to worry about a non-equilibrium  
18 temperature distribution that's too far out of whack.

19 CHAIR PETTI: Correct. If your fuel had  
20 really tight limits and you were close to fuel limits,  
21 then it's a big issue. But I really think that a lot  
22 of those types of questions don't matter with the  
23 TRISO fuel today. Which is really good, because it  
24 adds a lot of questions.

25 MEMBER KIRCHNER: Yeah, Dave, you're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 right, you've got a lot of margin. The other thing is  
2 that there's so many pebbles, Charlie, that it's, you  
3 know, it's almost like a random number generator.

4 And then the other thing that was pointed  
5 out earlier is that the core's, at least for this size  
6 and for this power, is very well coupled. So that the  
7 local spatial -- the local heterogeneity of the  
8 pebbles isn't as critical as when you start pushing a  
9 system in a larger core configuration.

10 MEMBER BROWN: Is there a larger core --

11 MEMBER KIRCHNER: Because the neutron  
12 diffusion life is quite long. So it's a well-coupled  
13 core, even though it's heterogeneous pebbles.

14 MEMBER BROWN: Okay, all right. I'm  
15 obviously not fuels, it's just, I just had to ask that  
16 question at some point as we went through this, that's  
17 all. I've listened, I will be quiet.

18 MR. BIELEN: Yeah, so I think just kind of  
19 going over some of the results in comparison with  
20 what's in the PSAR. So I think we do very well with  
21 the axial power distribution. The radial and peak  
22 pebbles, there are some differences.

23 And I can tell you that I think the radial  
24 difference is due to a difference in the way that Oak  
25 Ridge defined the radial peaking factor versus the way

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 that Kairos did. But unfortunately Kairos's  
2 definition was behind the proprietary wall. So you  
3 know, if that ever gets lifted then we can -- we can  
4 update that accordingly.

5 And then, you know, there's also, you  
6 know, we don't know exactly what the peak, or the  
7 radial reflector looks like. We don't know where the,  
8 you know, how much Flibe is in the reflector.

9 It may change the neutronic  
10 characteristics on the edge of the core where the  
11 peaking really is. So, you know, that may feed into,  
12 you know, the difference in peak pebble peaking.

13 But you know, given all the uncertainties  
14 we have in this and the, you know, the limitations and  
15 constraints we were working under, we thought these  
16 were, you know, reasonable comparisons that could be,  
17 you know, further understood or resolved, given  
18 additional information.

19 Okay, and then, you know, the big thing  
20 for transient analysis is reactivity -- reactivity  
21 feedback coefficients. And I think that, you know,  
22 this slide shows despite all these differences in  
23 modeling and in energy treatment and in geometry and  
24 isotopics, etc., etc., we are still like getting  
25 remarkably good agreement in most of our transient

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 coefficients.

2 So you know, I think that that kind of  
3 gives us a lot of comfort that, you know, the analysis  
4 that we're seeing from the Applicant is at least on  
5 some level, you know, consistent with other sources of  
6 information. So I think that that really helps --  
7 helps us, you know, justify and defend our acceptance  
8 of their -- of what they're presenting, so.

9 MEMBER HALNON: Did you do any sensitivity  
10 analysis on that to see how if changing might change  
11 your results to where they become not remarkable  
12 anymore?

13 MR. BIELEN: I would say most of our  
14 sensitivity analysis -- so this, full disclosure, this  
15 isn't the complete set of comparisons that we formed.  
16 We, you know, are showing the ones that we think are  
17 most important for this context. But like there are  
18 certain areas where we have results that aren't as  
19 good as we would like.

20 And I think we spent most of our, you  
21 know, whatever limited budget we had left to do  
22 sensitivity analysis after this was done, we spent  
23 more time kind of focusing on those things. Like you  
24 know, okay, is it important to capture, you know, the  
25 difference in differential speed between pebbles going

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 up the middle versus pebbles going up, you know,  
2 adjacent to the -- to the reflector.

3 And you know, okay, well, what about the  
4 composition in the reflector for the pebble peaking on  
5 the periphery and all those sorts of things. So I  
6 think that that's a great point.

7 You know, this is, okay, you could accuse  
8 us of confirmation bias to some degree because we saw  
9 what we liked and we said oh, okay, this is great.  
10 But you know, I think this wasn't all that we saw and  
11 some of what we saw we didn't like. So, you know, we  
12 did explore some of those things a lot deeper.

13 MEMBER HALNON: Thanks.

14 DR. SCHULTZ: Andrew, the -- this is Steve  
15 Schultz -- the uncertainties you showed is noted as  
16 the Monte Carlo uncertainty. Other bases of  
17 uncertainty that you would explore in order to  
18 determine the goodness of the comparison that you show  
19 here?

20 MR. BIELEN: Yeah, I mean, we would have  
21 to basically go through and do like a nuclear data  
22 based on certainty or manufacturing, you know,  
23 tolerances based on certainty. And really, like we  
24 have tools in SCALE to do that stuff but we just, you  
25 know, haven't gotten to that point yet.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1           So given the degree by which, you know,  
2           Rike was able to converge these, like the neutronics  
3           solutions within these models and then propagate that  
4           uncertainty into -- into the uncertainties in  
5           reactivity coefficients, like that was pretty much  
6           where we were able to end.

7           So and we expect during, you know,  
8           Kairos's assessment of their uncertainties in their  
9           parameters, that that would be something that they  
10          would -- that they would be looking at, you know.

11          DR. SCHULTZ: Sure.

12          MR. BIELEN: Physics-based uncertainties  
13          on these -- on these parameters.

14          DR. SCHULTZ: Well, this gives a real good  
15          feel for how the models work and you've done it  
16          independently, and that's excellent demonstration.  
17          And it's good to present it in public forum, that's  
18          excellent.

19          CHAIR PETTI: And that you know, for other  
20          members, there are benchmarks in the IAEA on pebble  
21          bed reactors. So there's a lot of codes out there, a  
22          lot of countries that participated. You know, it's a  
23          lot different than, say, 20 years ago.

24          MR. BIELEN: Ben, your turn, buddy.

25          MR. ADAMS: This is Ben Adams again.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The way the PSAR and SE are laid out is it  
2 goes through topics like power distribution, the  
3 shutdown margins. So we're going to start with power  
4 distribution and go from there.

5           The codes, like we talked about earlier,  
6 SERPENT-2 is used to calculate the core power  
7 distribution and STAR-CCM+ is used to calculate the  
8 material temperature distributions, and those two  
9 codes are coupled together.

10          The core power distribution is  
11 characterized by the axial peaking factor, the radial  
12 peaking factor, and the total peaking factor. Those  
13 are calculated using SERPENT-2. We just show a bit of  
14 our comparison for that.

15          That scoping calculation showed reasonable  
16 agreement with Kairos's preliminary calculations of  
17 power distribution and total pebble peaking factors.  
18 The core power distributions are an input to the fuel  
19 performance calculations, and the staff finds that  
20 this is consistent with PDC-10.

21          Okay, the shutdown margin criteria is  
22 defined as k-effective less than 0.99 as defined  
23 relative to the margin to Flibe freezing.

24          The control element worth is calculated  
25 from changes to k-effective resulting from determining

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the element axial positions to SERPENT-2 with the  
2 single most reactive element assumed to be fully  
3 withdrawn from the core. It's a pretty standard  
4 method from what we can talk about in the public  
5 forum.

6 Kairos will perform source range control  
7 element worth testing. And the staff finds that this  
8 is consistent with PDC-26.

9 The reactivity coefficients again were  
10 calculated using SERPENT-2. I won't list them off  
11 again. They are all negative during startup and  
12 equilibrium, except for the reflector coefficient,  
13 which is always positive.

14 The reflector coefficient is only slightly  
15 positive, but like I believe Kairos mentioned, thermal  
16 expansion is conservatively forward because that would  
17 be a difference in leakage in that the moderator  
18 temperature reactivity coefficient includes the change  
19 in reactivity due to the change in temperature in the  
20 fuel pebble graphite and in the graphite pebbles.

21 And the coolant temperature reactivity  
22 coefficient accounts for density changes. And the  
23 coolant void reactivity coefficient is the change in  
24 reactivity due to the change in coolant void fraction.

25 Overall, reactivity coefficients are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 negative even though the one reflector coefficient is  
2 positive always. The staff looked at scoping  
3 calculations to show reasonable agreement with  
4 Kairos's preliminary calculations for the reactivity  
5 coefficients, which we also just looked at.

6 Once Hermes achieves criticality and is at  
7 zero power, Kairos will perform isothermal remote  
8 reactivity coefficient testing to confirm those. And  
9 staff finds this is consistent with PDC-11.

10 For the OL, we will be looking for how  
11 five compositions impact the reactivity coefficients  
12 as well as the graphite densities in the reflector.  
13 Our scoping calculations do not account for different  
14 Flibe compositions from what I recall.

15 And we did perform some sensitivity  
16 studies on the graphite density and it did have an  
17 impact. So those are a couple of things that the  
18 staff is interested in looking at during the OL stage.

19 The vessel lifetime was originally slated  
20 to be ten years but was reduced to four years during  
21 the course of the review. The vessel is showed by the  
22 core barrel, the reflector, and the Flibe coolant.  
23 SERPENT-2 is used to calculate the fast neutron  
24 fluence and alpha generation on the vessel received  
25 from the core and pebble insertion and extraction

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 lines.

2           And Kairos's preliminary calculations of  
3 displacement per atoms in the vessel is within the low  
4 level irradiation value discussed in KPTR-013. Kairos  
5 did not give us the full methodology for calculating  
6 vessel fluence, including how uncertainties are  
7 accounted for. So we will be looking through at the  
8 OL stage.

9           We did not do any scoping calculations for  
10 this. And we'll review this in greater detail later  
11 at the OL stage.

12           The nuclear transient perimeters are  
13 outputs from SERPENT-2 and are used as inputs for  
14 transient analyses. They include the neutron  
15 generation time, the delayed neutron fraction groups,  
16 and their decay constants and the prompt neutron  
17 lifetimes.

18           They were given the PSAR for both  
19 equilibrium and startup. These perimeters play into  
20 things like the kinetic responses and the timings of  
21 transients and the shapes of curves related to the  
22 kinetics model.

23           Our scoping calculations did have relevant  
24 agreement with Kairos's preliminary calculations. So  
25 we were comfortable with this level of information

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 that was given in the PSAR. And these scoping  
2 calculations, again, will be discussed with Chapter 13  
3 later on April 18.

4 Kairos notably did not submit an  
5 uncertainty analysis for nuclear transient parameters.  
6 We will be reviewing that later as well.

7 The staff's evaluation of the nuclear core  
8 design limits of the burnup peak fuel temperature,  
9 peak particle power, and peak fluence are discussed in  
10 Section 4.2.1. We talked a little bit about that  
11 earlier today.

12 The neutron flux will be monitored using  
13 four power range ex-core detectors located in  
14 azimuthally symmetric locations outside the reactor  
15 core at mid-core elevation. And four source range ex-  
16 core detectors located in relation to the start of  
17 source for best detectability criticality.

18 During normal operation, these detectors  
19 will be used to monitor core power and the flux rate  
20 trip signal. And the source range detectors will be  
21 used during startup.

22 Gamma spectroscopy will be used to  
23 evaluate the fuel pebble burnup. But we did not make  
24 any findings on the burnup monitoring plan in this  
25 section. I believe that is discussed in Chapter 9.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Kairos will also perform neutron flux distribution  
2 verification tests during startup. And staff finds  
3 that this is consistent with PC-10.

4 For the technical conclusions, we  
5 discussed some of the PC. Preliminary design  
6 information provided is consistent with PDC-10, 11,  
7 12, and 26. And is consistent with some of the  
8 acceptance criteria in NUREG-1537. And the analytical  
9 methods for the nuclear design are acceptable at this  
10 stage of the design.

11 And for the regulatory findings in Section  
12 4.5, NRC staff concludes that the preliminary design  
13 provided in PSAR Section 4.5 is consistent with the  
14 applicable PDCs and acceptance criteria in NUREG-1537.

15 The NRC staff finds that the information  
16 in Hermes' PSAR Section 4.5 is sufficient for the  
17 issuance of a construction permit in accordance with  
18 10 CFR 50.35 and 50.40. And further information can  
19 be reasonably left for the OL application.

20 I believe that is the last slide.

21 DR. SCHULTZ: Ben, the statement that you  
22 didn't make any findings related to the burnup  
23 monitoring plan that Kairos has, is that because more  
24 details are required and they will be available at the  
25 OL stage?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. ADAMS: Yes. Part of it is because I  
2 believe we addressed it in Chapter 9 and not in this  
3 section. And also because the details are -- they're  
4 not very detailed, so we will be reviewing that in  
5 detail at the OL stage, yes.

6 DR. SCHULTZ: More information needed.

7 MR. ADAMS: Correct, yes.

8 DR. SCHULTZ: I appreciate that, thank  
9 you.

10 MR. ADAMS: Thanks.

11 CHAIR PETTI: Members, any other  
12 questions?

13 Okay, with that, I think we're done for  
14 the day, 40 minutes early is good. And -- huh? Oh,  
15 public comments, yeah, we probably should. It's a  
16 good idea.

17 Okay, so anybody out there, a member of  
18 the public that wants to make a comment, please unmute  
19 yourself, your name and your comment. That's coming  
20 from Kairos. Yeah, I'll get him.

21 Okay, not hearing anything from the  
22 public. Kairos?

23 MR. TOMKINS: So can I -- this is Jim  
24 Tomkins, Manager of Licensing. This morning we had a  
25 discussion about the burnup in Hermes. And we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 mentioned that it's around 6 percent FIMA.

2           There were some questions about what that  
3 corresponded to as far as operating plants. So Nader  
4 is the expert we didn't have then. So if you could --  
5 you could talk on that.

6           MR. SATVAT: For Hermes, every percent  
7 FIMA is equivalent to 9.4 gigawatt day per metric ton.  
8 So for Hermes, it's about 50-60 gigawatt day per  
9 metric ton.

10           Our power plant, the full scale -- full  
11 scale plant will go up to 20 percent FIMA, close to 20  
12 percent. So it's about 180-200 gigawatt day per  
13 metric ton.

14           CHAIR PETTI: Thank you.

15           MR. TOMKINS: Sure.

16           CHAIR PETTI: And with that then I guess  
17 we're done for the day and we'll see everyone again  
18 same time, same place tomorrow morning. Thank you,  
19 everyone.

20           MEMBER KIRCHNER: Dave, just quickly,  
21 could you just go over the chapters that are going to  
22 be covered tomorrow?

23           CHAIR PETTI: Sure. So tomorrow we're  
24 going to finish the rest of Chapter 4, so Section 4.3,  
25 4.4, 4.6, and 4.7, as we did 4.2 and 4.5.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           Then all of Chapter -- that's before, all  
2 of them before lunch. Our memo will be the last thing  
3 before lunch. Then after lunch, we'll do Chapter 6  
4 completely. And with our memo, break, then Chapter 9.  
5 Then public comments, and then we still have a closed  
6 session, but I doubt that we'll need it. But it's  
7 there.

8           MEMBER KIRCHNER: Thank you.

9           CHAIR PETTI: Okay.

10          MEMBER DIMITRIJEVIC: It is Chapter 6  
11 completely, Dave, or it's just 6.2 and 6.3

12          CHAIR PETTI: Proprietary? The whole  
13 thing, the whole thing.

14          MEMBER DIMITRIJEVIC: So all Chapter 6.

15          CHAIR PETTI: All of Chapter 6.

16          MEMBER DIMITRIJEVIC: All right.

17          CHAIR PETTI: Okay, everyone, have a good  
18 evening. Thank you.

19                 (Whereupon, the above-entitled matter went  
20 off the record at 4:22 p.m.)

21

22

23

24

25

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
Kairos Power Licensing Subcommittee

Docket Number: (n/a)

Location: teleconference

Date: Friday, March 24, 2023

Work Order No.: NRC-2232

Pages 1-201

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
1716 14th Street, N.W.  
Washington, D.C. 20009  
(202) 234-4433

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

KAIROS POWER LICENSING SUBCOMMITTEE

+ + + + +

FRIDAY

MARCH 24, 2023

+ + + + +

The Subcommittee met via Videoconference,  
at 8:30 a.m. EDT, David A. Petti, Chair, presiding.

COMMITTEE MEMBERS:

- DAVID A. PETTI, Chair
- RONALD G. BALLINGER, Member
- VICKI M. BIER, Member
- CHARLES H. BROWN, JR., Member
- VESNA B. DIMITRIJEVIC, Member
- GREGORY H. HALNON, Member
- WALTER L. KIRCHNER, Member
- JOY L. REMPE, Member

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

ACRS CONSULTANTS :

DENNIS BLEY

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL :

WEIDONG WANG

CONTENTS

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

Page

ACRS Chairman Introductory Remarks . . . . . 4

Hermes Section 4.3 . . . . . 28

Hermes Section 4.4 . . . . . 50

Hermes Section 4.6 . . . . . 58

Hermes Section 4.7 . . . . . 72

Hermes Chapter 4 Memo . . . . . 80

Hermes Chapter 6 . . . . . 83

Hermes Chapter 6 Memo . . . . . 113

Hermes Chapter 9 . . . . . 130

Hermes Chapter 9 Memo . . . . . 145

Public Comments . . . . . 198

Adjourn

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIR PETTI: Okay. I guess we're going to restart. As planned, everyone, we're going to finish up Chapter 4 before lunch and then hit Chapters 6 and 9 after lunch. We should just start with Hermes, I guess, right? You don't -- okay. So, yes, I'm sorry, Kairos, you're up.

DR. DORON: Okay. This is Oded Doron again, Senior Director of Reactor System Design, and I'm going to be presenting on Section 4.3, the Reactor Vessel System.

So the reactor vessel is -- the vessel, the head, the shell, are all made out of 316H stainless steel. The vessel material is qualified for our metallics topical reports. That's KP-TR-013. The reactor vessel top head supports attachment of equipment and components. It's bolted and planned, designed to be leak-tight, but it's not credited for that. The head nozzles and attachments are seismically qualified, and the hold-down structure, that's also 316H, and it provides support against upward buoyant loads from the graphite.

CHAIR PETTI: Question on the hold-down structure. Is that kind of like a cage structure?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 What's it physically look like?

2 DR. DORON: I don't think we went into  
3 detail on the PSAR, per se, but think of it as simple  
4 as possible. Think of it as a rib system that's just  
5 maintaining the upward buoyant loads from the  
6 graphite, and it has pins, as well, but the graphite,  
7 of the top layer of the graphite attaches to, or  
8 engages with rather.

9 CHAIR PETTI: Is there any concern on  
10 temperature limits there? Because that's pretty hot  
11 at the top of the graphite and stainless steel  
12 temperature limit.

13 DR. DORON: We don't believe that we'll be  
14 hitting temperature limits there from the work that  
15 we've done. But, certainly, I mean, it's a  
16 consideration for sure.

17 CHAIR PETTI: Yes. I mean, every high-  
18 temperature reactor I've seen, the metals in the hot  
19 part always can be challenging.

20 DR. DORON: Yes, for sure.

21 MEMBER BALLINGER: This is Ron Ballinger.  
22 You can be assured that, during the OL review, those  
23 temperature limits and history and the like will be of  
24 great interest, at least to me.

25 DR. DORON: Yes. They're of great

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 interest to us, as well. To add a little flavor to  
2 it, they're in the gas space. They're not in contact  
3 with the FLiBe at that level.

4 MEMBER BALLINGER: That doesn't bother me.

5 DR. DORON: Okay.

6 CHAIR PETTI: Yes, that actually could  
7 make it worse. I mean, I'm assuming the FLiBe will  
8 sort of even out any peaking, so it will be  
9 interesting to see what the numbers look like.

10 DR. DORON: Yes, yes, absolutely. I mean,  
11 it's within design considerations right now, and you  
12 will get many, many more details on it. Okay?

13 CHAIR PETTI: Yes.

14 DR. DORON: The reactor vessel shell  
15 maintains the reactor coolant boundary and provides a  
16 geometry for coolant inlet and heat transfer, the heat  
17 transfer surface for the decay heat removal system,  
18 DHRS. The reactor vessel bottom head maintains the  
19 reactor coolant boundary, provides flow geometry for  
20 the low-pressure reactor coolant inlet to the core.

21 I just want to add a note here, and it  
22 will make more sense when I go to the next one that  
23 the lower head, in conjunction with the shell and the  
24 core rail is what creates that inlet path. The gap  
25 that exists between the core rail and the shell and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 then the gap that exists between the core barrel and  
2 the lower head, if you can visualize that, that's  
3 where you have the flow. There's a figure on the  
4 right --

5 MEMBER KIRCHNER: Can we go -- this is  
6 Walt Kirchner. Can you go back to what you precisely  
7 mean by being designed for the top head to be leak-  
8 tight but not credited? Because your argon cover gas  
9 system, if it's not leak-tight, then that would be a  
10 concern.

11 DR. DORON: So we design it, and there's  
12 a seal there, it is designed to be leak-tight. We  
13 don't design it to leak, but we do not credit it as a  
14 safety-related leak-tight boundary.

15 MEMBER KIRCHNER: I have to think about  
16 the implications of that. That means you don't test  
17 for leak-tightness.

18 DR. DORON: Yes.

19 MEMBER BALLINGER: This is Ron Ballinger  
20 again. If it's a Section III weld or B31, regardless  
21 of whether you credit it or not, you're going to have  
22 to weld it in accordance with that procedure, and that  
23 will require a test.

24 MEMBER KIRCHNER: Right. That's where I'm  
25 going, Ron, yes. I mean, it's a Section III vessel.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Are you saying that the top head and flange is not  
2 Section III?

3 DR. DORON: No. The connection of the top  
4 head to the vessel is bolted and flanged.

5 MEMBER KIRCHNER: Well, yes.

6 DR. DORON: Everything is per Section III,  
7 but I do have a seal there. That seal is not credited  
8 as safety-related. So per Section III, everything  
9 still meets, right. And that's why we're saying we're  
10 designing it to, so, per Section III, I will do a  
11 pressure test to ensure that it holds leak-tightness.  
12 That's how I'll be able to certify it or show that I  
13 followed the intent of Section III.

14 MEMBER KIRCHNER: Yes, exactly.

15 DR. DORON: But we're not crediting it for  
16 safety-related seal.

17 CHAIR PETTI: So I think we ran into this  
18 yesterday. At least in my mind, you know, okay, is it  
19 safety-related, is it not. And in my mind, not  
20 safety-related moves you to a different part of the  
21 code; but, in fact, they're still staying inside  
22 Section III, they're just not crediting it. So it's  
23 a nuance that I hadn't appreciated until we explored  
24 it yesterday.

25 MEMBER REMPE: What about operational

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 testing? I mean, do you have to check if it's safety-  
2 related every so many months for maintenance to ensure  
3 it's still leak-tight and, because it's not safety-  
4 related during operation, it doesn't have to have that  
5 type of --

6 CHAIR PETTI: But if it's a Section III --

7 MEMBER REMPE: They still have to do  
8 testing during operation --

9 CHAIR PETTI: They have to follow --

10 MEMBER REMPE: -- throughout its four-year  
11 life --

12 CHAIR PETTI: Tied to Section 11, Section  
13 11.

14 MEMBER REMPE: So for its whole four-year  
15 lifetime, they have to do this. I apologize. I had  
16 to go to other meetings for some of yesterday, so  
17 perhaps you discussed this yesterday, but that would  
18 be my concern.

19 DR. DORON: Let me just make one  
20 statement, that Section III, once you build the  
21 vessel, there are no requirements for further testing.  
22 Once you certify the vessel, there are no more  
23 requirements for further testing.

24 MEMBER BALLINGER: Section 11 doesn't?

25 MEMBER KIRCHNER: Yes, Section 11 applies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 DR. DORON: We haven't committed to  
2 Section 11.

3 MEMBER BALLINGER: Ah.

4 MEMBER REMPE: That's a big difference.

5 MEMBER BALLINGER: That's a big  
6 difference.

7 MEMBER KIRCHNER: Yes, yes. Because that  
8 would be a concern, Ron. I mean, the vessel itself is  
9 credited for safety function, so you would inspect it  
10 accordingly, and that would be Section 11.

11 DR. DORON: Well, we will inspect the  
12 vessel for the vessel itself will not leak. It is  
13 credited, okay. So what we're talking about is above  
14 the fluid level is what we're discussing here. We're  
15 talking about the gas space. But then the fluid  
16 level, we are crediting it and those welds will be  
17 inspected.

18 MEMBER KIRCHNER: This is an interesting  
19 precedent, Ron, from an application to a primary  
20 system. We discussed a lot of this yesterday, but  
21 okay.

22 MEMBER BALLINGER: It will be interesting  
23 to see how that works out in the operating license.

24 DR. BLEY: I have to admit -- this is  
25 Dennis Bley -- this is a bit confusing to get the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 implications of this. But why have you decided to go  
2 this way?

3 DR. DORON: For simplicity. I mean, we  
4 could talk to -- do you want to answer? You want to  
5 talk, Matt? Okay.

6 MR. DENMAN: This is Matthew Denman, the  
7 radiological source term lead. In our transient  
8 analyses, we do not credit the vessel head for  
9 radionuclide retention. So once radionuclides reach  
10 the gas space, likely via evaporation from the FLiBe-  
11 free surface, there is no hold-up in the vessel and  
12 the radionuclides quickly move to or seem to move into  
13 the building and then out to the environment. And  
14 because our safety case, our functional containment  
15 approach, allows us to not credit the vessel head for  
16 radionuclide retention, we are able to do the approach  
17 that Oded just mentioned.

18 MR. GARDNER: So this is Darrell Gardner  
19 from licensing. I just also wanted to add I know  
20 there's a lot of talk about precedent, but, to my  
21 knowledge, we really haven't licensed an advanced  
22 reactor that's not an LWR like this yet. So I would  
23 caution us to be careful about precedent because I'm  
24 not sure that there is. We have to look at this  
25 technology as it's being presented, and, for this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 technology, we do not credit the reactor vessel as a  
2 fission product barrier, and that's an important  
3 distinction from LWR technology, which does credit  
4 reactor vessel and primary piping as a fission product  
5 barrier. That's the distinction that matters here and  
6 why you see things that might seem unusual compared to  
7 LWR technology.

8 MEMBER KIRCHNER: Well, there have been  
9 advanced reactors, like Fermi, that have been  
10 licensed.

11 CHAIR PETTI: Thank you. I was going to  
12 say that.

13 MEMBER BALLINGER: I would caution that we  
14 don't get, in this case, because of all these  
15 precedents, hidebound by the rules and don't use  
16 common sense and Occam's razor for some of these  
17 designs. If that's meant to be cryptic, you're right.

18 CHAIR PETTI: Let's keep going.

19 DR. DORON: Okay. The diagram on the  
20 right highlights the layout of the upper head. I'm  
21 not going to step through every single one of those  
22 unless you want me to. Do you want to pause on it for  
23 a second, or do you want me to walk through those?

24 CHAIR PETTI: Silence means keep going.

25 DR. DORON: Okay. Very good. Let's go to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the next one then.

2 MEMBER REMPE: Just a second. Again, I  
3 keep bringing up the coolant level sensor. Have you  
4 made any progress on what that sensor will be? I  
5 don't think it's documented what you're going to use  
6 in the PSAR, right? Do you want to wait until Chapter  
7 7 to discuss this?

8 DR. DORON: Well, we've made progress, but  
9 the details will come later.

10 MEMBER REMPE: Thank you.

11 DR. DORON: Yes. So the internals are  
12 compromised of the core barrel, which I mentioned  
13 previously. It is also 316H. The downcomer is part  
14 of the normal natural circulation flow paths. Recall  
15 from what I was saying that the downcomer is formed by  
16 the concentricity of the core barrel and the vessel,  
17 the gap between those. The reflector support  
18 structure is 316H. It defines, it helps define the  
19 flow path into the core and supports the reflector  
20 blocks. You can see it on the right diagram there at  
21 the bottom of the vessel indicated as the reflector  
22 support structure.

23 The reflector blocks are ET-10 graphite.  
24 They are going to be qualified per the topical, the  
25 graphite topical KP-TR-014. They form the fueling

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 shoot, flow channels, core, upper plenum, hot well,  
2 bump well, the fueling shoot, and diode pathway.  
3 They're part of the normal circulation flow path. The  
4 diode pathway is in the reflector block and is also  
5 316H. It's within the blocks, and they're part of the  
6 natural circulation flow path, as well.

7 CHAIR PETTI: So question. How is the  
8 core barrel supported.

9 DR. DORON: It is attached at the upper  
10 portion of the vessel.

11 CHAIR PETTI: Okay. At the top. Okay.  
12 Thank you.

13 DR. DORON: Yes, sir. There's a secondary  
14 metallic hold-down structure that precludes damage to  
15 the natural circulation flow path from a postulated  
16 air ingress event.

17 Go back one real quick. So the diagrams  
18 at the right there are from PSAR directly, and they  
19 just highlight all the components there that I was  
20 discussing. There's a section cut through the diode  
21 pathway. You can see that as section cut A. This is  
22 going to be important for when we go into the flow  
23 path discussion here I think on the next slide.

24 MEMBER HALNON: This is Greg. How big are  
25 the clearances are we talking between the graphite

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 reflector and the core barrel?

2 DR. DORON: We did not specify that.

3 MEMBER HALNON: Okay. I guess the concern  
4 would be, if there's any vibration or anything to  
5 that, degradation in the graphite through contact.

6 DR. DORON: Yes, I mean, that's being  
7 considered. I'll say it's relatively tight. There is  
8 FLiBe that takes up any space that's not physically  
9 filled by the graphite.

10 MEMBER HALNON: Okay. So it's  
11 hydraulically buffered in some ways.

12 DR. DORON: Correct.

13 MEMBER HALNON: Yes, okay. All right. Go  
14 on. Thanks.

15 DR. DORON: Yes. So we've got two  
16 diagrams at the right here, one indicated being the  
17 normal flow path and one indicating the natural  
18 circulation flow path, so we'll talk through this one  
19 here. So the natural circulation flow path, or what  
20 we call force flow, essentially what I'm stepping  
21 through here is the process of the arrows. So we have  
22 the cold leg, the downcomer, the reflector support  
23 structure --

24 MEMBER HALNON: I'm sorry. Are you  
25 talking to the one on the left or the right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 DR. DORON: The one on the left first, the  
2 natural circulation path first.

3 MEMBER HALNON: But that says normal  
4 operation coolant flow.

5 DR. DORON: Apologize. It's early here.  
6 Forced flow coolants -- sorry. Normal operation, the  
7 one on the left. Thanks for catching that.

8 So the normal circulation path: the cold  
9 leg downcomer, reflector support structure into the  
10 reflector, the coolant inlet channels, the core, the  
11 coolant outlet channels, PEM, hot well, the pump weld,  
12 primary salt pump, pot leg, and then the heat is  
13 removed by the heat reduction radiator. So what I  
14 stepped through there is the process of the flow going  
15 all the way through the system.

16 Next, I'll discuss the figure on the  
17 right, the natural circulation flow path. This is  
18 during postulated events. I have the cold leg, really  
19 the downcomer, the reflector support structure,  
20 reflector, so the coolant inlet channel, the core,  
21 coolant outlet channel, the PEM, the hot well, the  
22 pump well, the natural circulation pathway to the  
23 fluidic diode, back to the cold leg, the downcomer,  
24 and the heat is removed from the vessel wall by the  
25 DHRS. And I want to pause here to make sure that this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 is absorbed.

2 MEMBER HALNON: So the fluidic diodes,  
3 this flow, is it just the pressure on the normal  
4 operation that keeps it from flowing? Because it  
5 looks like the flow could go in that direction on the  
6 normal operation coolant flow path.

7 DR. DORON: Correct. Yes, there is  
8 bypass, there is some bypass there during normal  
9 operation, and that's part of the temperature  
10 monitoring that we do on the diode.

11 MEMBER HALNON: Okay. But the primary way  
12 of keeping that flow is the pressure on the coolant.

13 DR. DORON: Is the pressure differential  
14 on the diode.

15 MEMBER HALNON: Okay.

16 MEMBER KIRCHNER: Could you further  
17 describe the diode? It looks like a check valve kind  
18 of function. Can you just share a little about the  
19 physical --

20 DR. DORON: We provided very little detail  
21 on the specifics of the diode and the PSAR. It's  
22 active work, and the details will obviously will be  
23 forthcoming in the OLA. I apologize if that's less  
24 than satisfying.

25 MEMBER BROWN: But, conceptually, it looks

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 like the pressure of the incoming flow is going to be  
2 what keeps the flow up through the core from going  
3 back toward the natural circulation path. So whatever  
4 it does, it's going to have something to do with  
5 higher pressure on one side and lower on the other.  
6 Is that a rational assumption?

7 DR. DORON: That's a rational assumption.

8 MEMBER BIER: Hi. I have some questions.  
9 This is Vicki Bier. And these are very high-level  
10 questions coming because I'm a PRA person, I'm used to  
11 everything works because you have a bunch of bumps and  
12 valves, so it's not, you know, a specific challenge to  
13 anything in the design but just to educate me.

14 So first of all, are you kind of relying  
15 on the Hermes demonstration to know that the natural  
16 circulation is going to work, or you are 100-percent  
17 confident before the demonstration that this is going  
18 to work?

19 MEMBER BROWN: That's a long pause.

20 DR. DORON: Well, we will be doing, I  
21 mean, we are doing testing. I can't recall if we've  
22 committed to it or not.

23 MEMBER BIER: Okay.

24 MEMBER KIRCHNER: I think it's in Appendix  
25 A, Oded, isn't it? In the list of, I don't know if

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 you call it R&D, but supporting work for the PSAR.

2 CHAIR PETTI: I think you're right, Walt.

3 MR. PEEBLES: This is Drew Peebles, senior  
4 licensing manager. So we did get an RAI on the  
5 specifics of testing, monitoring, and inspection of  
6 the fluidic diode as that part of the natural  
7 circulation pathway, and we did commit to those items  
8 in that RAI response. I would characterize that a  
9 little differently than finding out if it's going to  
10 work in the demonstration reactor. We will provide  
11 assurance that it is going to be a functional natural  
12 circulation path before operation. It will  
13 demonstrate the function as we're demonstrating the  
14 rest of the technology in the test reactor.

15 MEMBER BIER: Okay.

16 CHAIR PETTI: But on initial start-up, can  
17 you do a test to test that?

18 DR. DORON: I can talk to that a little  
19 bit. So there's monitoring, there's temperature  
20 monitoring, and then there's also -- maybe if we go  
21 back to the top head picture. One more. Yes.  
22 There's four -- where are they here on this one? The  
23 green, there's four green circles there, yes, that are  
24 being highlighted right now. Those are nozzles that  
25 allow for inspection and potential testing of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 diode. We didn't specify details there, but that's  
2 what those nozzle ports are for. So there will be a  
3 way, there will be multiple ways for us to ensure  
4 functionality before we start up.

5 MEMBER BIER: Okay. Another follow-up.  
6 You talked about preventing air ingress from  
7 disrupting the natural circulation. Are there other  
8 things that might challenge that, whether it's some  
9 kind of debris build-up or hot spots that you hadn't  
10 anticipated or whatever? Just, you know, what have  
11 you thought through in that regard?

12 DR. DORON: Yes, that's a good question.  
13 I don't believe that I said that air ingress would  
14 disrupt the flow. If I did, I misspoke. So I'm not  
15 concerned about that. Hot spots, that shouldn't  
16 affect, even pretty dramatic differences shouldn't  
17 affect this process.

18 As far as debris, that will be precluded  
19 through design. And, again, we'll be able to monitor  
20 these, and so we will know if their performance has  
21 been degraded.

22 MEMBER BIER: Okay. Thank you.

23 DR. DORON: Yes.

24 MEMBER KIRCHNER: Oded, are you going to  
25 try and ensure in your design approach that you have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 continuous circulation through the diode? Because  
2 what you don't want is a cold spot or, as Vicki  
3 suggested perhaps, a place that graphite or something  
4 else might accumulate and have a deleterious effect on  
5 that function.

6 DR. DORON: Yes, I can't remember who  
7 mentioned it a few minutes ago, but you correctly  
8 identified that there will be, let's say back flow  
9 during natural circulation and that back flow will  
10 actually be utilized through our advantage through  
11 temperature monitoring.

12 MEMBER KIRCHNER: No. Back flow during  
13 normal circulation.

14 DR. DORON: Sorry. Yes, I keep flipping  
15 it. I apologize. Thank you for catching my mistake.  
16 During normal operation. And that's what we will use  
17 for temperature monitoring, and so that will allow us,  
18 again, to see any degradation in performance, which  
19 would be indicative of the things you just mentioned  
20 there.

21 MEMBER HALNON: But that would also lock  
22 it open in the wrong direction. I mean, so I guess  
23 the design will be important. That's --

24 DR. DORON: The design is important and,  
25 again, you will see that through the temperature

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 monitoring. If you start having excessive flow, you  
2 will know that.

3 MEMBER HALNON: Well, I'm more concerned  
4 with it being locked open and needing natural circ and  
5 it not flowing in the correct direction. Keep in mind  
6 we're thinking check valve, you know, with a flapper,  
7 so it may be different in that respect. Maybe there's  
8 not a mechanical issue. So that's why I'm saying it  
9 will be interested in the --

10 DR. DORON: The detail I can say is it's  
11 not a check valve.

12 MEMBER HALNON: Okay. We'll have to  
13 change our paradigm of thinking how that's going to  
14 work.

15 MEMBER KIRCHNER: Well, Oded, this is Walt  
16 Kirchner again. You know, our job is not to help you  
17 design this, but it would seem to me that one of the  
18 things you would consider is just taking the loss of  
19 having a constant bypass so that you don't have any  
20 concern that it's not going to be functional when the  
21 demand comes. Just an observation because with these  
22 kind of systems, as you know, you're going to go to  
23 extensive effort to prevent freezing and other  
24 plugging kind of issues for a salt-like system. So  
25 you may just take, intentionally take a loss so that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 you can guarantee the safety function is available  
2 when the demand comes.

3 DR. DORON: Yes. So, I mean, you're  
4 bringing up a great point, and I appreciate the help  
5 in the design. So we certainly are, even in this  
6 design, we are planning to utilize that bypass, so we  
7 are using it to our advantage. So, certainly, I mean,  
8 you're 100-percent on the right track with our  
9 thinking.

10 Okay. There are a lot of words coming up  
11 on the next two slides. I will apologize. The reason  
12 is because the vessel is a critical part of the safety  
13 system, and so it does satisfy a lot of PDCs. So  
14 please bear with me.

15 The reactor vessel reflector 316H  
16 structures are designed, fabricated, and tested  
17 consistent with ASME Section III, Division 5 standard.  
18 It satisfies PDC 1.

19 The reactor vessel, the reactor vessel  
20 internals, reactor vessel attachments, are classified  
21 as SDC-3 per ASCE 43-19 to protect against failure  
22 during design basis earthquake. This satisfies PDC 2.

23 The reactor vessel and vessel internals  
24 design accounts for environmental and dynamic effects,  
25 like thermal expansion of the vessel shell and bottom

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 head, mechanical loadings from static weight, and  
2 forces from the pebble bed, coolant and core  
3 components during start-up, normal operation and  
4 postulated events. This satisfies PDC 4.

5 The reflector block design maintain a  
6 geometry in coolant flow path to ensure that SARRDLs  
7 will not be exceeded by supporting coolant flow  
8 through the reflector via gaps and flow channels,  
9 thereby cooling the reflector and maintaining its  
10 structural integrity and the integrity of the coolant  
11 flow path. This satisfies PDC 10.

12 The reactor vessel is fabricated and  
13 tested to have an extremely low probability of  
14 abnormal leakage, rapidly propagating failure, and  
15 gross rupture, and the vessel material is qualified in  
16 accordance with the metallic material qualification  
17 topical report. The vessel is operated within as-  
18 designed operational and transient conditions and  
19 monitored for changes during in-service inspection and  
20 testing. This satisfies PDC 14.

21 The reactor vessel is fabricated and  
22 tested to ASME standards. The reactor vessel design  
23 supports pre- and in-service inspection and catch  
24 basins with sensors are used to detect leakage. This  
25 satisfies PDC 30.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR PETTI: So just a question. When  
2 you refer to the in-service inspection, you're talking  
3 about only the pass to the credit?

4 DR. DORON: Correct.

5 CHAIR PETTI: Thank you.

6 DR. DORON: Think below the fluid level.

7 CHAIR PETTI: Right.

8 DR. DORON: Okay. Onwards and upwards.  
9 The reactor vessel design has margins that withstand  
10 stresses under operating, maintenance, testing, and  
11 postulated events by precluding material fatigue,  
12 thermal, mechanical, and hydraulic stresses that would  
13 degrade the reactor coolant boundary. Stress rupture  
14 factors encompass transient conditions and leak-tight  
15 design of the reactor vessel head to minimize air  
16 ingress. The design prevents fracture of the reactor  
17 coolant boundary. This satisfies PDC 31.

18 Reactor vessel design permits inspection  
19 and monitoring of the structural integrity and leak-  
20 tightness of the reactor coolant boundary using the  
21 material surveillance system, MSS, to confirm  
22 irradiation assistance, stress corrosion/cracking that  
23 is non-existent or manageable. This satisfies PDC 32.

24 The core valve design maintains reactor  
25 coolant inventory in the events of a break in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 primary heat transport system using anti-siphon  
2 cutouts on both sides of the core barrel. This  
3 satisfies PDC 33.

4 The flow path established by the design of  
5 the reactor vessel internals support the removal of  
6 residual heat from the core to ensure SARRDLs are not  
7 exceeded during normal operation and postulated  
8 events. The physical geometry and structure of the  
9 reactor vessel internals provide a pathway for force  
10 flow and continuous natural circulation. This  
11 satisfies PDC 34.

12 The fluidic diode, reflector blocks, and  
13 downcomer are designed to maintain their structural  
14 integrity in order to establish a flow path for  
15 continuous natural circulation during a postulated  
16 event. The passive cooling of the reactor core  
17 prevents damage to the vessel internals due to  
18 overheating and, therefore, ensures the total geometry  
19 of the core is maintained. This satisfies PDC 35.

20 The functional capability of the natural  
21 circulation flow path is confirmed during normal  
22 operation by temperature monitoring. Appropriate  
23 periodic inspections of fluidic diode are performed  
24 via head penetrations. This satisfies PDC 36 and 37.

25 Finally, the reflector is qualified to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 maintain its structural integrity to support residual  
2 heat removal in accordance with the graphite material  
3 qualification topical report. The reactor vessel is  
4 classified as SDC-3 and will maintain its geometry to  
5 support the insertions of shut-down elements. And  
6 this satisfies PDC 74.

7 I believe that's all I got.

8 MEMBER KIRCHNER: Oded, could you give us  
9 a little bit more detail on the cutouts, that was hard  
10 to see in the PSAR, that serve the function of the  
11 breaking, you know, a flow path that would drain the  
12 vessel.

13 DR. DORON: I don't think we added that  
14 detail because that's a pretty specific design detail,  
15 but what I'll tell you is they're in the upper region  
16 of the core barrel and, therefore, as you lose fluid,  
17 you would suck in air and break the siphon.

18 MEMBER KIRCHNER: Okay. All right. Thank  
19 you.

20 DR. DORON: Yes.

21 CHAIR PETTI: That's your last slide,  
22 right?

23 DR. DORON: Yes, sir.

24 CHAIR PETTI: Yes. So let's hear from the  
25 staff.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 DR. DORON: I appreciate your time on  
2 that.

3 MR. CHERESKIN: Good morning. This is  
4 Alex Chereskin from NRC staff, Division of Advanced  
5 Reactors. I'll be -- sorry. This good? All right.  
6 Thanks.

7 So like I was saying, this is Alex  
8 Chereskin from the NRC staff, the Division of Advanced  
9 Reactors, and I'll be presenting the staff's review of  
10 Section 4.3 for the reactor vessel system.

11 Next slide, please. So the staff's  
12 presentation is just going to touch on a very brief  
13 overview of the PSAR. I'll probably try and keep that  
14 detail limited because we just heard from Kairos for  
15 a lot of that. We'll touch on the regulatory basis  
16 and the PDCs included in our review, the reference  
17 topical reports in Section 4.3 of the PSAR, as well as  
18 the staff's technical evaluation, our conclusions, and  
19 then our regulatory findings.

20 Next slide, please. Okay. So as we just  
21 heard from Kairos, the reactor vessel system has a  
22 vessel shell, top and bottom heads, as well as all the  
23 internals which are listed here on the screen. And so  
24 it includes things like the reflector blocks, the  
25 fluidic diodes, the barrel, and the reflector support

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 structure. The purpose of the reactor vessel system  
2 is to contain the core and provide for the circulation  
3 flow path for the reactor coolant pebbles and also to  
4 allow for the insertion of reactivity elements. And  
5 the last thing I note here is that, you know, the  
6 reactor vessel system is a safety-related system.

7 Next slide, please. Okay. So this slide  
8 contains the regulatory basis for the staff's review.  
9 I am not going to go into too much detail here. As  
10 you can see, there are a lot of principal design  
11 criteria listed on the slide, and we have the criteria  
12 from 10 CFR 50 and these are generally related to the  
13 information that needs to be provided for issuance of  
14 a construction permit. And I'll touch on the PDC a  
15 bit more in the subsequent slides, but, in general,  
16 they're aimed towards ensuring that appropriate codes  
17 and standards are used commensurate with the safety  
18 significance of these components, ensuring that the  
19 vessel system is structurally sound and can withstand  
20 the environments in which these components are going  
21 to operate, you know, to ensure the vessel system can  
22 maintain its integrity to support the passive residual  
23 heat removal and insertion of reactivity elements.  
24 And there are PDC that also relate to allowing for  
25 inspection and testing, as appropriate.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1                   Next slide, please. So in Section 4.3 of  
2 the PSAR, Kairos referenced a couple of previously-  
3 approved topical reports from the staff. So the first  
4 topical report that was referenced is the topical  
5 report which describes the principal design criteria  
6 for the Kairos power design, and the second topical  
7 report is for the metallic material qualification,  
8 which covers 316H materials in environments  
9 representative of what would be expected in the design  
10 and also the graphite material qualification report  
11 for the ET-10 graphite that Kairos plans to use. And  
12 on this slide here, I don't have dash A for those  
13 topical reports, although they were recently issued,  
14 I think, within the past couple of weeks, so those are  
15 approved topical reports.

16                   Next slide, please. Okay. So this slide  
17 covers the staff evaluation for Principal Design  
18 Criteria 2, which would require safety-related system  
19 structures and components to withstand effects of  
20 natural phenomenon. And so in the PSAR, Kairos  
21 described the seismic interactions that would be  
22 considered to ensure the vessel system can withstand  
23 a design basis earthquake. The staff has reasonable  
24 assurance this will be met because the vessel, the  
25 internals, and the attachments are classified as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 seismic design Category 3, as per ASCE 43-19, and also  
2 because the design will ensure that safety-related  
3 SSCs would be protected from failure of nearby non-  
4 safety-related SSCs. And this is also consistent with  
5 the criteria in NUREG-1537, which would require the  
6 vessel to be able to withstand all mechanical and  
7 hydraulic forces and stresses to which it could be  
8 subjected to in its lifetime.

9 Next slide, please. So this slide is the  
10 staff's evaluation of PDC 4, which requires protection  
11 against environmental and dynamic effects. And so the  
12 PSAR states that the vessel system can withstand  
13 internal and external static and dynamic loads during  
14 normal operations and postulated events. And, you  
15 know, the staff has reasonable assurance of this  
16 because the vessel system is designed to account for  
17 these loads, which would include static weight,  
18 seismic loads, and forces from the pebble bed, coolant  
19 and core components, you know, pipe whip hazards. We  
20 review that to ensure that those are not a concern  
21 during the operating license stage. And this also  
22 helps meet that NUREG criteria that I mentioned on the  
23 last slide.

24 I would also mention that Kairos has  
25 stated the vessel system would be in accordance with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Section III, Division 5, of the ASME code.

2 Next slide, please. Okay. So this slide  
3 covers the staff evaluation of Principal Design  
4 Criteria 10. And so PDC 10 requires core heat removal  
5 to have appropriate margin, and the role that the  
6 reactor vessel system plays in satisfying this PDC is  
7 mainly to ensure the flow path needed for the adequate  
8 core cooling. This would be accomplished by ensuring  
9 the integrity of the reactor vessel system, so you  
10 have the vessel and the internals that form the flow  
11 paths that Kairos described during their presentation.  
12 And there's reasonable assurance that this will be  
13 achieved because, as noted here, there are the two  
14 material qualification topical reports that will cover  
15 the conditions those materials are expected to  
16 encounter in this design.

17 And, additionally, Kairos will demonstrate  
18 the compliance with Section III, Division 5, you know,  
19 the appropriate sections, Section III, Division 5, for  
20 either stainless steel or graphite components. And  
21 so, you know, that, combined with the vessel and  
22 internals and attachments and being classified as SDC-  
23 3, in order to account for those dynamic behaviors to  
24 make sure that they can operate during a design basis  
25 earthquake, you know, and also combined with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 protecting these safety-related components from the  
2 failure of nearby non-safety-related SCCs.

3 I would also note that, for maintaining  
4 the coolant flow path, that Division 5 design rules  
5 for graphite would require the consideration of  
6 dimensional changes from things like thermal expansion  
7 and radiation damage, which, you know, that would  
8 allow the graphite components to ensure that the flow  
9 path is maintained even, you know, through the  
10 spectrum of thermal and irradiation conditions that  
11 they're expected to experience, and this is consistent  
12 with the NUREG-1537 criterion that graphite components  
13 would have to accommodate radiation damage and thermal  
14 expansion.

15 In addition to that, you know, the  
16 graphite qualification topical report also discusses  
17 the effects of graphite oxidation, and so that would  
18 also be covered to ensure that graphite integrity is  
19 maintained or satisfied as PDC.

20 Next slide, please. So this slide covers  
21 the staff evaluation of PDC 14, which requires safety-  
22 related elements of the coolant boundary to be  
23 designed and fabricated, erected, and tested to have  
24 an extremely low probability of abnormal leakage,  
25 rapidly propagating failure, and gross rupture. And

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 so the staff has reasonable assurance this will be met  
2 because, as stated here, the vessel system is going to  
3 be designed for operational and transient stresses  
4 with an appropriate load methodology.

5 And, additionally, as mentioned before,  
6 the two materials qualification topical reports will  
7 have testing to quantify effects of applicable  
8 degradation mechanisms for 316H components, as well as  
9 the weld filler metal, and as well as the graphite  
10 components, as well. And so, you know, one thing that  
11 the staff will look for at the operating license stage  
12 is the results of these qualification programs to  
13 ensure that these degradation mechanisms aren't too  
14 significant to prevent meeting PDC 14.

15 In addition, the vessel system is designed  
16 to permit appropriate periodic inspections and  
17 contains features such as catch basins to detect any  
18 leakage. And these will also, for the confirmation,  
19 the inspection will help for confirmation of  
20 degradation rates and, you know, ensure potential  
21 corrective actions are taken to ensure that the  
22 safety-related parts of the coolant boundary are  
23 maintained.

24 In addition, at the OL stage, the staff  
25 would review those inspection and monitoring programs,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 and this is all consistent with the NUREG-1537  
2 criterion that the vessel and the coolant have  
3 chemical compatibility. That would be demonstrated  
4 through the metallic material qualification topical  
5 report. And also the Division 5 rules would help to  
6 meet this PDC, as well, to ensure the integrity of the  
7 safety-related components of the boundary.

8           Next slide, please. Okay. So this slide  
9 groups together the evaluation of PDCs 30 and 31. PDC  
10 30, which would require the components that are part  
11 of the coolant boundary to be designed, fabricated,  
12 erected, and tested with quality standards  
13 commensurate with their safety functions, and so  
14 that's satisfied or is consistent with using ASME Code  
15 Section III, Division 5, for design fabrication, those  
16 aspects of the code. And then Principal Design  
17 Criteria Number 31 requires those safety-related  
18 elements of the coolant boundary to have sufficient  
19 margin to ensure that when they're stressed under all  
20 conditions so that the boundary behaves in a non-  
21 brittle manner and the probability of rapidly  
22 propagating fracture is minimized. And so the staff  
23 has reasonable assurance that these will be met  
24 because, as noted, Kairos is going to be using Section  
25 III, Division 5, and that covers effects like high-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 temperature creep and fatigue for the metallic  
2 components in this vessel system. And we noted  
3 previously, there's also the catch basin that can  
4 detect leakage from the safety-related parts of the  
5 coolant boundary. The metallic material qualification  
6 topical report contains testing to extend the weld  
7 filler metal qualification, as noted in the PSAR. And  
8 there is also a proposed safety limit in Chapter 14  
9 for the vessel temperature, and, at the operating  
10 license stage, the NRC staff would look to ensure that  
11 the times and temperatures for metallic components in  
12 the system, safety-related metallic components in the  
13 system are consistent with the NRC staff-endorsed ASME  
14 Code Section III, Division 5.

15 And, additionally, the topical reports  
16 that I mentioned also look at the effects of things  
17 like radiation and coolant composition, you know, for  
18 both the metals and the graphite materials. And so  
19 this would also allow the staff at the operating  
20 license stage to ensure that appropriate coolant  
21 purity limits are included with the operating license  
22 based on material testing that Kairos is going to  
23 perform. And so also at the operating license stage,  
24 we would look at the results of this testing to ensure  
25 that they have the appropriate design margin that's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 discussed mostly in PDC 31.

2 Next slide, please. Okay. So this slide  
3 is the staff evaluation of PDC 32, which will require  
4 those safety-related components that are part of the  
5 coolant boundary to be designed to permit periodic  
6 inspection, monitoring, or functional testing, as well  
7 as an appropriate material surveillance program. As  
8 noted here, the PSAR states that the Hermes design  
9 will have coupons, component monitoring and  
10 inspection, as appropriate. And as I noted before,  
11 the staff is going to review the details of inspection  
12 and monitoring programs at the OL stage, and so the  
13 staff has the reasonable assurance that the vessel  
14 system will be consistent with PDC 32 because they do  
15 have these coupons, as well as the ability to perform  
16 in-service inspection and in-service testing. This is  
17 also consistent with the guidance in NUREG-1537 to  
18 assess the irradiation of vessel materials because  
19 these coupons, as noted in the Kairos presentation,  
20 would be used to look at the effects of irradiation on  
21 corrosion. And so the staff is going to look at the  
22 results of the qualification testing in conjunction  
23 with the surveillance and monitoring at the OL stage,  
24 as well as the modern inspection programs.

25 Next slide, please. Okay. So this slide

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 has the staff evaluation of PDC 33, which is required  
2 to protect against small breaks and maintain FLiBe  
3 inventory. And so most of the evaluation for this PDC  
4 is contained in Chapter 5 of the SE where it discusses  
5 aspects, like the anti-siphon features. And so if we  
6 have any questions on this, I might just ask that we  
7 wait until Chapter 5 of the SE because that's really  
8 where it's contained.

9 Next slide, please. So here's our  
10 evaluation of PDC 34, which requires a system for  
11 residual heat removal. So as stated in the PSAR, the  
12 vessel internal design supports the decay heat  
13 removal, and staff has reasonable assurance that's  
14 going to be consistent with PDC 34. As you can see,  
15 the design maintains the pathway for the coolant, and,  
16 you know, the components in the natural circulation  
17 pathway are qualified in those two previously-  
18 discussed topical reports. And also, as previously  
19 discussed, you know, they'd be designed and fabricated  
20 to ASME Code Section III, Division 5 requirements.  
21 And this combines to give the staff reasonable  
22 assurance that these components can maintain integrity  
23 and form the pathway needed for coolant flow in both  
24 normal operation and natural circulation and  
25 postulated events.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           And then the other aspects of decay heat  
2 removal are evaluated in various sections of the  
3 staff's safety evaluation, as noted here. We have  
4 thermal hydraulics, the decay heat removal system, and  
5 anti-siphon features in different sections.

6           And the next couple of slides are going to  
7 talk about inspection and testing for these  
8 components. So next slide, please.

9           Okay. So these three PDC are pretty  
10 similar, so we just kind of condensed them down to one  
11 slide here. With PDC 35 requirement passive residual  
12 heat removal system to ensure cooling during  
13 postulated accidents, you know, and PDC 36 requiring  
14 the appropriate periodic inspection of important  
15 components and PDC 37 requiring appropriate periodic  
16 functional testing. And so the staff has assurance  
17 that these PDC will be met because, again, as noted,  
18 we have the topical reports that have the  
19 qualification methodologies to bound the expected  
20 conditions that these components are going to see in  
21 the Kairos design environment, as well as the  
22 temperature monitoring that was described in Kairos's  
23 presentation, and as well as the inspection, the  
24 ability to inspect the fluidic diode device that I  
25 think Kairos also went into a little bit of detail in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 their presentation, as well. And this is one of those  
2 things that it's safety-related, it's an important  
3 component, and so the ability to be able to inspect  
4 the diode, I think maybe that also goes to the  
5 conversation we were having earlier about potential  
6 graphite particles, for example, and so the ability to  
7 be able to inspect that gave the staff some reasonable  
8 assurance that, you know, if you were seeing maybe a  
9 build-up of that particles, that you'd be able to take  
10 corrective action if needed.

11 And I would also note that, you know, at  
12 this stage, at the CP stage, we do not have the  
13 details of the inspection and testing programs, but  
14 those will be provided with the operating license.  
15 And so the staff will be able to review them at that  
16 time in conjunction with the overall design to ensure  
17 that, you know, their component integrity plan is able  
18 to ensure that they can inspect and test what they  
19 need to in the reactor vessel system.

20 CHAIR PETTI: So I don't recall seeing  
21 details. The inspection is done after it's shut down.  
22 It's not in situ while the reactor is operating. Of  
23 the diode because it's, you know, it's inside.

24 MR. CHERESKIN: We did not have the  
25 details of exactly, I'll say timing of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 inspections. I'm not sure whether it would be  
2 possible to do while FLiBe is in the system or not.

3 CHAIR PETTI: I mean, you know, good FLiBe  
4 is clear, but as soon as you get impurities it's  
5 cloudy, so that would potentially rule out anything in  
6 in situ.

7 MR. CHERESKIN: Yes. Next slide, please.  
8 Okay. And so this slide details the staff review of  
9 PDC 74, which is discussing the requirements to be  
10 able to maintain that natural circulation flow path,  
11 as well as to allow for the insertion of reactivity  
12 elements. And the staff has reasonable assurance the  
13 vessel system will be able to meet that. Then I'll  
14 bring up those two qualification topical reports to  
15 ensure the materials can withstand the environment  
16 that they're going to be subjected to.

17 In addition, Section 4.3 of the PSAR has  
18 graphite thermocouples, which would also allow the  
19 staff the assurance that the graphite is going to be  
20 within its temperature conditions because the  
21 temperature at which graphite is irradiated obviously  
22 has a great effect on its properties and its ability  
23 to maintain its geometry, which would be important to  
24 allow for the reactivity element insertion.

25 And, in addition, the Division 5 rules for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 both metallics and graphite help to provide the staff  
2 assurance that this is going to be met because it's  
3 going to, especially for the graphite, require  
4 consideration of a lot of these dimensional changes as  
5 the properties change over time and with different  
6 temperatures to ensure that the appropriate allowance  
7 is there for the reactivity elements to be able to be  
8 inserted.

9           And so at the operating license stage, you  
10 know, we look to review the final design of the  
11 graphite components specifically. And this is all  
12 also consistent with the NUREG-1537 requirements that  
13 require graphite components to be compatible with  
14 their chemical, thermal, mechanical, and radiation  
15 environments.

16           CHAIR PETTI: Just a question or comment.  
17 The testing will, you know, give you shrinkage rates  
18 with temperature and fluence. Again, remember, these  
19 are little small-sized tests. There's also this jump  
20 from that to the full component where there's  
21 gradients in temperature, gradients in fluence, so  
22 there's a calculational aspect here, right, that you  
23 get the assurance not just from the testing but it's  
24 through all that analysis in Div 5, right?

25           MR. CHERESKIN: Right. Division 5 is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 obviously very important in that end. The design  
2 portion of Division 5 requires that you would account  
3 for those gradients. It specifically calls out  
4 thermal stresses generated by those temperature  
5 gradients, as well as the radiation damage that can  
6 cause internal stresses to the graphite, and that all  
7 feeds into the probability of failure calculation,  
8 which looks at, you know, the initiation of cracking  
9 essentially. And we'd obviously look at those results  
10 in combination with, like, the concept of damage  
11 tolerance and graphite to determine whether or not the  
12 cracks might occur in an area where it could impact  
13 one of those functions.

14 Next slide, please. So this slide, I  
15 think, is a little bit of a repeat. As the PSAR  
16 doesn't contain the details of the testing and  
17 inspection program to the reactor vessel system, and  
18 so that's going to be something that the staff will  
19 review with the operating license application.

20 DR. SCHULTZ: Alex, I'm glad you got this  
21 page on testing and inspection, but you've mentioned  
22 clearly that this is a very intense evaluation by the  
23 staff at the operating license. Are you confident  
24 that you and Kairos are on the same page with regard  
25 to the programs that they're going to be submitting in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 advance of the operating license? You've had a lot of  
2 interactions with them, not directly on these areas  
3 but certainly discussing that things need to be done  
4 in a certain fashion and so forth. Do you feel you're  
5 comfortable with what will be coming in in advance of  
6 the operating license?

7 MR. CHERESKIN: I would say I think so.  
8 I think that's part of our review for the construction  
9 permit is to have that assurance that we think it can  
10 be done, and so, from that perspective, yes. I would  
11 also note that you're right. I think there's a lot of  
12 work that still needs to be done. We'd still need to  
13 look at the specifics of how some of this stuff can be  
14 done, especially if you're in a new environment with  
15 novel components.

16 And so I think that's an appropriate focus  
17 area, but, you know, there have been a couple of times  
18 where even Kairos has noted that they have ongoing  
19 research and development, and I think we need to see  
20 the outcome of that.

21 DR. SCHULTZ: Very good. Thank you.

22 MEMBER REMPE: So I've heard sometimes  
23 that changes were made in the design because of your  
24 interactions with the folks from Kairos. Were any  
25 changes made because of your interactions with them on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 this topic?

2 MR. CHERESKIN: I think one example, you  
3 know, we issued the RAI on the inspection for the  
4 fluidic diodes, and I think that was part of the  
5 change to have those inspection ports, to be able to  
6 have the ability to inspect those devices, if needed,  
7 as appropriate.

8 MEMBER BALLINGER: This is probably more  
9 of a question that eventually, for the FHRs, will be  
10 important. But with respect to Section 11, are they  
11 using Division 2? Are they going to have a RIM or  
12 whatever, I forget the acronym.

13 MR. CHERESKIN: I don't believe they've  
14 committed to specifics of that. Meg, do you happen to  
15 recall?

16 MS. AUDRAIN: They have not committed to  
17 using a RIM program yet. Meg Audrain, NRC staff.

18 MEMBER BALLINGER: I mean, this is a small  
19 system and everything, but to get engaged between  
20 those two divisions might have implications for the  
21 FHR, the bigger points.

22 CHAIR PETTI: So just another comment, and  
23 I think we'll get back to this in Chapter 5. But as  
24 we're hearing about the downstream implications of  
25 functional containment and the ability to classify

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 what's credited and what's not, given this is first-  
2 of-a-kind, what I haven't heard is, well, you know,  
3 okay, we understand that logic, but this is first-of-  
4 a-kind from defense-in-depth. Wouldn't that be a good  
5 idea? Common sense. So I think we'll be back on this  
6 when they get to Chapter 5. If we were in Part 53 and  
7 Framework A, there's that defense-in-depth look that  
8 you look at everything. And even though the logic  
9 drives you over here, you come back with defense-in-  
10 depth and you go, well, you know, no, we should beef  
11 up this and beef up that. That's not here because of  
12 the strategy, but that's not a bad, that's an  
13 important part of Framework A, I think.

14 MR. CHERESKIN: Thanks. Next slide. Oh,  
15 sorry.

16 MEMBER BIER: A question or a comment to  
17 Dave's comment, which we discussed yesterday, as well,  
18 that it's a challenge doing these separate  
19 construction permanent operating license because  
20 there's certain detail that you might want to see that  
21 a licensee doesn't have to provide at this point. And  
22 I'm just curious, do you have a sense at the level of  
23 detail available was sufficient for you to perform  
24 your review with reasonable assurance, or are there  
25 things that really are kind of nagging doubts because

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 of not having certain things spelled out? Sorry. My  
2 mike was off. I don't know if I should repeat that  
3 all. Okay. Great. Thank you.

4 MR. CHERESKIN: So the staff does have the  
5 reasonable assurance for issuance of a construction  
6 permit, and I think, as we've discussed plenty of  
7 times, there's stuff that we would like to see at the  
8 operating license application. But for a construction  
9 permit, you know, our safety evaluation documents,  
10 that we have what we need.

11 MEMBER BALLINGER: This is not a  
12 reflection on the staff, but, again, this is a first-  
13 of-a-kind system, and is there any thought, we have  
14 this set of rules and we have a tendency to follow the  
15 rules, that's it, and we think that's going to be  
16 fine, but is there any thought to, for lack of a  
17 better word, having what we've termed in the past a  
18 murder board? That is to say, a separate group that  
19 takes a look at what you've done for the overall  
20 package that said, you know, let's look at this and  
21 see if there's some areas where, in spite of the rules  
22 or because of the rules or whatever, that we should  
23 probably take a closer look because this is a new  
24 thing and we're establishing precedent here? Is there  
25 any thought on a high level been given to that kind

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 of, and I guess I'm pointing --

2 MR. SCHMIDT: This is Jeff Schmidt from  
3 the staff. I would have to say, no, we haven't really  
4 thought of that aspect. I mean, it may be more  
5 appropriate for, like, the commercial design --

6 MEMBER BALLINGER: Well, that's what I  
7 mean --

8 MR. SCHMIDT: -- than the test reactor.

9 MEMBER BALLINGER: -- you're establishing  
10 a kind of a precedent here, and the commercial design  
11 is going to be much more -- yes.

12 MR. SCHMIDT: Yes. So, no, we haven't, I  
13 don't think we've really considered that aspect. I  
14 mean, we've tried to do it internally just within the  
15 staff but not another external body beyond --

16 MEMBER BALLINGER: I don't mean external.

17 MR. SCHMIDT: -- the normal process.

18 MEMBER BALLINGER: I mean also within the  
19 --

20 MR. SCHMIDT: Oh, you mean like a separate  
21 staff --

22 MEMBER BALLINGER: Yes.

23 MR. SCHMIDT: -- like an internal review.  
24 No, I don't think we've really considered that.

25 MR. BEASLEY: So this is Ben Beasley of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the staff. And Jeff's correct, we didn't consider  
2 that. It's not a bad idea, but I will admit that  
3 Jeff's examination and Alex's examination and  
4 Michelle's and the entire core team's look was robust,  
5 was thorough. You know, Jeff is very knowledgeable  
6 and did, you know, think through what are all the  
7 things that could go wrong. And so I do have  
8 confidence --

9 MEMBER BALLINGER: Remember, this is not  
10 a criticism.

11 MR. BEASLEY: No, no, I understand.

12 MEMBER BALLINGER: I don't doubt for a  
13 millisecond that it's robust and all the things that  
14 you're saying, but this is a new system.

15 MR. BEASLEY: Yes, so it is a good idea.

16 MEMBER BALLINGER: And so, you know,  
17 sometimes you read the same thing over and over and  
18 over again and you miss the misspelling over and over  
19 again.

20 MR. BEASLEY: Well, and so I guess the  
21 aspect I was thinking is that we were not taking  
22 Kairos's word for this is all that's needed. You  
23 know, we were considering, you know, what is all  
24 that's needed, you know, for our independent review.

25 MEMBER BALLINGER: There is a murder

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 board. It's called the ACRS.

2 MR. BEASLEY: And you guys do a fine job  
3 at that.

4 CHAIR PETTI: Okay. With that, we can  
5 move on. Alex.

6 MR. CHERESKIN: And so just to wrap up  
7 here, you know, the staff has the reasonable assurance  
8 that the preliminary design information, the PSAR, is  
9 consistent with the NUREG-1537 criteria, as well as  
10 the applicable PDC that we just went through, and that  
11 this information, the PSAR, is sufficient for issuance  
12 of a construction permit in accordance with 10 CFR  
13 50.35. And, you know, as noted, a handful of times  
14 here, there's further information that we will look at  
15 during the operating license application.

16 And so that concludes my presentation.  
17 Are there any further questions?

18 CHAIR PETTI: Well, with that, let's move  
19 on then to the bioshield Section 4.4. Kairos.

20 MR. SATVAT: Good morning. Can you hear  
21 me? It's muted.

22 MEMBER HALNON: No, we can hear you fine.

23 MR. SATVAT: Oh, okay. Sorry. Good  
24 morning. This is Nader Satvat, senior manager of  
25 nuclear design. I'll be talking about the biological

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 shield as Section 4.4 of the Preliminary Safety  
2 Analysis Report.

3 The function of biological shield is  
4 protection of public and the work here from release of  
5 radionuclide and the impact of radiation. This meets  
6 the radiation exposure goals in PSAR Chapter 11. The  
7 design of the shield, the primary shield located just  
8 outside of the reactor vessel, there is an image that  
9 I will show on the next slide, a secondary shield  
10 located outside the primary shield and contains the  
11 inventory management and primary heat transfer system.  
12 Both shields are reinforced concrete. Details on  
13 biological shield will be provided as part of the  
14 operating license application.

15 This is pointing out what was described in  
16 a previous slide. The reactor vessel is contained  
17 within the primary biological shield, which is  
18 contained in the secondary biological shield which  
19 holds the reactor cavity, the heat rejection radiator,  
20 and inventory management system.

21 CHAIR PETTI: Can you just give us sort of  
22 rough dimensions on that?

23 MR. SATVAT: The dimensions were not  
24 provided in PSAR, but those details are being worked  
25 out and will be provided as part of operating license

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 application.

2 CHAIR PETTI: Is it bigger than a  
3 breadbox?

4 MEMBER BALLINGER: It just looks like the  
5 same size as the seismic that we qualified building.

6 CHAIR PETTI: No, no, I mean this is a  
7 part of the building. Right.

8 MEMBER BALLINGER: Well, okay.

9 CHAIR PETTI: Yes, all of these are in the  
10 seismic -- the moat is outside of that second gray  
11 box; is that correct?

12 MR. SATVAT: Right. Did you hear me? I  
13 said that's correct.

14 CHAIR PETTI: Yes, yes, I heard. Thank  
15 you.

16 MR. SATVAT: This is the last slide.

17 CHAIR PETTI: And that's just concrete or  
18 -- oops. It's just regular nuclear concrete, so it's  
19 high-density concrete?

20 MR. SATVAT: The details of the material  
21 is being worked on. There is a workstream on  
22 understanding the type of material, the degraded  
23 shielding approach, and the localized shielding which  
24 is missing on this picture. But all of those will be  
25 provided as part of operating license agreement,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 application.

2 CHAIR PETTI: And it's an area in which  
3 personal entry is not anticipated?

4 MR. SATVAT: During operation, there is no  
5 expectation of personnel to be within this shielded  
6 area.

7 CHAIR PETTI: But you may go in when the  
8 reactor is shut down.

9 MR. SATVAT: Yes, that's possible.

10 CHAIR PETTI: Okay. Thank you. Okay.  
11 Staff. Michelle.

12 MS. HART: Yes, good morning. My name is  
13 Michelle Hart. I am from the Division of Advanced  
14 Reactors in the NRC staff, and I'm here to talk to you  
15 about our review of the biological shield. Next  
16 slide, please.

17 So as was just described, it's radiation  
18 shielding for worker protection during operation, as  
19 well as protection of the public from radiation shine.  
20 It's reinforced concrete structures, as Kairos just  
21 described, and it's a safety-related component for  
22 structural support and external event protection but  
23 not safety-related for the radiological protection.

24 I did not perform the review of the  
25 structural design basis. That would be part of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 review in SE Section 3.6.

2 Next slide, please. So for our  
3 evaluation, the staff assessed whether the PSAR  
4 provides an acceptable basis for the development of  
5 the biological shield and determined if the objectives  
6 of the biological shield design basis are sufficient  
7 to protect the public health and safety and the  
8 facility staff and to assess whether there's  
9 reasonable assurance that Kairos will comply with the  
10 regulations of Part 20 during Hermes facility  
11 operation. We did not determine that they need that  
12 at this point because they are in the construction  
13 permit. They are not requesting to have special  
14 nuclear material on site.

15 Next slide, please. So we did ask in  
16 audit if they had some preliminary shielding analysis  
17 because, as you saw, there's not a lot of information  
18 in the preliminary design information. They do  
19 confirm and we did confirm that they had some  
20 preliminary analyses. They did not provide us details  
21 on that, but it is clear that they used isotopic data  
22 based on fuel and FLiBe sources to help them  
23 determine, to help them determine what's going to be  
24 in the biological shield materials and the thicknesses  
25 and the dimensions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The evaluation of its performance to meet  
2 Part 20, including the shielding analysis, will be  
3 reviewed as part of the operating license application.  
4 The overall review of the Hermes facility to meet Part  
5 20 will be part of the Chapter 11 analysis in the OL  
6 application, as well.

7           And that concludes my presentation. Are  
8 there any questions? I mean, I know you have  
9 concerns.

10           MEMBER HALNON: It's not concerns. It's  
11 lots of questions. What just went through my head was  
12 they don't know what the materials are, but they can  
13 confirm that there is analysis to support PSAR, which  
14 means there's some analysis that says this is going to  
15 work which means that there's got to be some idea of  
16 what kind of materials there are going to be. I  
17 almost feel like, when we get to the operating phase  
18 or in a Part 52 type review, we're going to be looking  
19 at everything all over again because we don't have any  
20 detail here.

21           So I don't know. I guess I just vented a  
22 little frustration. It's nothing against you,  
23 Michelle. You guys confirmed that the minimum  
24 requirements have been met, so that's good.

25           CHAIR PETTI: Yes, I would just note that,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 on these smaller systems, there's some leakage,  
2 neutron leakage, more than in large power reactors, so  
3 gamma and neutron will be potentially more important  
4 than other systems. Just something to be aware of.

5 Okay. If no other questions, then --

6 MEMBER REMPE: Again, like what Steve was  
7 saying, do they understand that there's a lot more  
8 risk when you have less detail? I mean, did that come  
9 up in your discussions? I mean, you can build the  
10 thing and then, I mean, that's the trade-off, and they  
11 understand this?

12 MS. HART: Well, certainly, the staff, we  
13 discussed it among ourselves when we were trying to  
14 determine the appropriate amount of information that  
15 would be required for a construction permit, and I  
16 think we did have a few conversations with Kairos  
17 about that point, but we didn't push that point. I  
18 think they're aware. They may be able to speak for  
19 themselves if they would like.

20 MEMBER REMPE: Again, it's not just in the  
21 U.S., again, because we did this thing and the folks  
22 from Finland talked about the issues and how they  
23 actually had additional reviews before they had the  
24 operational license because they kept trying to reduce  
25 the risk because that's their way of doing it, and we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 aren't. And so maybe, as we go forward, we'll learn  
2 from the experiences that are happening.

3 MEMBER KIRCHNER: Joy, just to jump in,  
4 this is Walt. The caution -- doing the shielding,  
5 sharing a little bit of Greg's feelings, I mean, they  
6 can do a good estimate of how much shielding they need  
7 now. I think the staff indicated they looked at that.  
8 As Dave said, for a reactor like this, you know what  
9 the megawatts are. It's a thermal spectrum. You can  
10 pretty much ballpark the amount of shielding that's  
11 needed to get the dose down to acceptable levels.

12 The risk here in the shielding, which is  
13 a more -- how should I say it? Not an exotic item in  
14 the design. Is that should they require more  
15 shielding, that has a ripple effect on the structural  
16 part of the design, particularly the seismic loadings  
17 and the civil structure. So I think Kairos will do  
18 this. They're going to have to lean on the  
19 conservative side towards what materials and weights  
20 and such will be required to achieve the shielding  
21 desired and then do the civil structural design  
22 accordingly so that they can carry that load,  
23 especially with the seismic isolation. So that's the,  
24 that's, I think, the more challenging issue here, not  
25 achieving a sufficient amount of shielding.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BROWN: Hold on a minute. I've got  
2 to mute something. Here I go. I'm in a meeting.

3 MEMBER REMPE: Charlie, I think you didn't  
4 realize -- are you trying to ask a question, or you  
5 just left your mike on?

6 Well, I guess I'm reflecting more, I hear  
7 this same comment a lot about different aspects of the  
8 design and, of course, safety and meeting the  
9 requirements is all we all need to do at this time.  
10 But sometimes the regulator gets blamed for things  
11 later on downstream when something -- there's a lot  
12 less information, and I just hope everybody  
13 understands.

14 DR. SCHULTZ: Well, let's be clear, this  
15 puts the onus on Kairos to come up with a design that  
16 is going to be easily reviewed prior to the operating  
17 license review.

18 MEMBER REMPE: I agree, but then if they  
19 do what they think is adequate and the regulator says,  
20 well, no, then it causes problems later. But, again,  
21 that's not our problem today.

22 DR. SCHULTZ: It could, but it shouldn't.

23 MEMBER REMPE: It shouldn't. We hope.

24 CHAIR PETTI: Okay. With that, let's move  
25 on to Section 4.6. We're a little ahead of schedule,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 so maybe we can get both Kairos and the staff done  
2 before our break. Kairos.

3 MR. SATVAT: This is Nader Satvat, senior  
4 manager of nuclear design, which part of that is the  
5 core design. I'll be talking about thermal hydraulic  
6 design of the internals, which is Section 4.6 of the  
7 PSAR.

8 These two schematics were provided in  
9 Section 4.6. I will not go into great detail there,  
10 but what I will talk about is the thermal hydraulic  
11 design that ensures that the design meets the PDC as  
12 laid out for 4.6.

13 The thermal hydraulic design is a  
14 combination of design features which includes pebbles,  
15 a source of heat, reactor coolant, reactor vessel and  
16 internals, and the primary heat transfer system which  
17 ensures the adequate flow of the coolant through the  
18 vessel and vessel internals. The thermal hydraulic  
19 design uses multiple heat transfer mechanisms between  
20 the reactor materials. The details of those are  
21 presented in the topical report for both core design  
22 analysis and also the transient analysis.

23 Thermal hydraulic design includes coolant  
24 flow path for normal operation and natural  
25 circulation. Natural circulation flow path uses a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 fluid diode which was discussed in Section 4.3 that  
2 minimizes the reverse flow, the bypass.

3 Qualification or functional testing plans  
4 for fluidic diode and the test results to evaluate  
5 performance will be available as part of operating  
6 license application.

7 STAR-CCM and KP-SAM computer codes are  
8 used in thermal hydraulic analysis of the design,  
9 which I'll talk about those in the next slide.

10 STAR-CCM, as described in Section 4.5, is  
11 used to perform thermal hydraulic analysis in the core  
12 design methodology. It is a steady-state for heat  
13 transfer and fluid flow in the form of a 3D porous  
14 media model. It calculates the core material  
15 temperature, which is used as input to neutronics  
16 model. The detail of that methodology is described in  
17 KP-TR-017, Revision 1.

18 CHAIR PETTI: Just a question.

19 MR. SATVAT: Sure.

20 CHAIR PETTI: You know, the whole issue of  
21 validation of the CFD is new, and I know that the  
22 relevant loop inside ASME, thermal hydraulics, has  
23 been working on, I guess, criteria or just some  
24 guidance on how one might validate CFD. Are you guys  
25 aware that you hooked in -- are you ahead of them?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 What's going on there? Have you thought about it at  
2 all?

3 MR. SATVAT: Sure. The part of the STAR-  
4 CCM that is used for this purpose is 3D porous media  
5 approximation. We are developing internal and have  
6 developed internal testing, including different levels  
7 of modeling to ensure the numbers that we're producing  
8 are adequately conservative for figures of merit that  
9 are important for safety.

10 CHAIR PETTI: Okay. I don't know, I  
11 haven't kept track with what ASME is doing, but I know  
12 that they had a working group on it.

13 MR. SATVAT: That's correct.

14 CHAIR PETTI: Yes. Thank you.

15 MEMBER KIRCHNER: Dave, I would also point  
16 out, and I think Kairos might be aware of this, that  
17 porous media kind of techniques have been used for dry  
18 cask storage thermal analysis, so you might look at  
19 what's been done there, as well.

20 MR. SATVAT: Thank you.

21 CHAIR PETTI: Keep going.

22 MR. SATVAT: KP-SAM is a system that  
23 performs transient analysis on postulated event, the  
24 progression of different scenarios, postulated  
25 scenarios for the reactor. It is simplified models to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 represent the major physical components and describes  
2 major physical processes, including fluid flow and  
3 heat transfer. It is used to analyze the progression  
4 of events. As an example, insertion of excess  
5 reactivity, loss of force circulation, and other  
6 relevant accidents. The details of KP-SAM is  
7 presented in KP-TR-018, Revision 2.

8 These are the thermal hydraulic analysis  
9 of the vessel and internal is going to address the  
10 following PDCs. The slide is wordy, but I'll try to  
11 be brief. The design provides adequate transfer of  
12 heat from the fuel to the coolant to ensure SARRDLs  
13 will not be exceeded during normal operation and  
14 postulated events. That's PDC 10.

15 The thermal hydraulic design of the  
16 reactor system ensures that power oscillations that  
17 could result in conditions exceeding SARRDLs are not  
18 possible or can reliably and readily detect it and  
19 suppress. This was discussed again as part of 4.5  
20 that power oscillations in FHRs with the size of  
21 Hermes is not possible.

22 Residual heat is removed during normal  
23 operation and postulated events, such that SARRDLs and  
24 the design conditions of the safety-related elements  
25 of the reactor coolant boundary are not exceeded. The

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 reactor transfers heat from the reactor during  
2 postulated events, such that the fuel and reactor  
3 internal structural damage that could interfere with  
4 continued effective core cooling is prevented.

5 That's my last slide.

6 CHAIR PETTI: Thank you. Questions,  
7 members?

8 MEMBER KIRCHNER: Yes, Dave. This is  
9 pesky Walt again. This is a relatively small reactor,  
10 a small power level. Have you done what I'll call a  
11 static passive calculation like has been done for the  
12 HTGR designs to just assume for whatever reason the  
13 fluidic diode does not function and you have a  
14 stagnant system? Have you looked at a worst-case  
15 scenario such as that and looked at what the pebbles  
16 and the core would see in a decay heat removal passive  
17 cool-down situation as a bounding event?

18 MR. SATVAT: We have not done that  
19 calculation. Our testing and design process,  
20 including start-up, is assessing and continued  
21 monitoring of natural circulation through the diode is  
22 going to ensure that they perform their function when  
23 it's needed for them to perform. So we have not  
24 looked at that analysis. However, internally, we do  
25 have capabilities to look at those scenarios, but we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 have not considered them.

2 CHAIR PETTI: Okay. Then let's turn to  
3 the staff. Ben.

4 MR. ADAMS: Good morning, everyone. This  
5 is Ben Adams from the NRC staff.

6 CHAIR PETTI: Please speak closer or  
7 louder.

8 MR. ADAMS: Good morning. This is Ben  
9 Adams from the NRC staff. I will be presenting on the  
10 NRC's review of PSAR Section 4.6, thermal hydraulic  
11 design. We're going to go over the regulatory basis  
12 and PCs quickly, look at the staff technical  
13 evaluation and conclusions, and the regulatory  
14 findings.

15 The regulations for the regulatory basis  
16 are the same as they've been in the other sections.  
17 It's 50.34(a), 10 CFR 50.34(a), 10 CFR 50.35, and 10  
18 CFR 50.40. We reviewed the principal design criteria  
19 relevant to the section which are listed on this  
20 slide. That would be PDC 10, reactor design; PDC 12,  
21 suppression of reactor power oscillations; PDC 34,  
22 residual heat removal; and PDC 35, passive residual  
23 heat removal. Some of the findings in this section  
24 are related to ensuring the design is consistent with  
25 these PDC and some of the findings are related to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 analytical methods which we thought were important to  
2 capture in this section of the safety evaluation. We  
3 did also use NUREG-1537 as guidance for this section.

4 So for the reference topical reports, we  
5 used KP-TR-003, which is the principal design criteria  
6 topical report, and we also referenced KP-TR-017,  
7 which is the core design and analysis methodology  
8 technical report. And we looked at KP-TR-018, which  
9 is the postulated event analysis methodology.

10 So I'll give a brief overview of the  
11 analytical methods. I know Kairos just discussed this  
12 a little bit. The core design methodology included  
13 SERPENT 2 and STAR-CCM+, which was discussed a little  
14 bit in Chapter 4.5, the presentation yesterday. STAR-  
15 CCM+ is a computational fluid dynamics code or a  
16 safety code.

17 The transient analysis methodology  
18 includes the use of KP-SAM and KP-BISON. KP-SAM is a  
19 modification of the SAM code, which is a transient  
20 code; and KP-BISON is a modification of BISON, which  
21 is a fuel performance code. We will discuss those in  
22 more detail later with the Chapter 13 presentation on  
23 April 18th, but we'd like to make clear that these  
24 codes have not been reviewed for verification and  
25 validation yet, and the NRC has not approved the use

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 of these computer codes.

2 Moving on further to the analytical  
3 methods. The Hermes model accounts for the following  
4 heat transfer modes. It accounts for pebble-to-pebble  
5 convective heat transfer, pebble radiated heat  
6 transfer, pebble-to-pebble heat transfer via a couple  
7 contact conduction, pebble-to-pebble heat transfer via  
8 conduction through the coolant, and conductive,  
9 convective, and radiated heat transfer to the  
10 reflector. So, specifically, the staff reviewed heat  
11 transfer modes to make sure that they were  
12 appropriate, and we reviewed the heat transfer  
13 equations given in the technical reports and the PSAR  
14 to do this staff-performed literature review, which  
15 included checking code manuals, like the SAM and  
16 MELCOR code manuals, SAM being what KP-SAM was based  
17 off of and MELCOR what was we used for our NRC staff's  
18 scoping calculations. We also conducted research. We  
19 also discussed this at length during the audit.

20 Staff reviewed the thermal conductivity  
21 equations and the pebble bed pressure drop equations,  
22 correlations used, and their applicability. We did  
23 not review Kairos's decay heat methodology. I believe  
24 it is named in the updated PSAR revision, but we will  
25 be reviewing that later at the OL stage.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 I would also like to make clear that the  
2 NRC is not approving the use of these equations or  
3 correlations, and the NRC is not approving the  
4 research references in any way used to make these  
5 findings. And, again, the NRC has not approved the  
6 use of the computer codes. We're saying that it's  
7 okay that Kairos is using these for the construction  
8 permit application. We will have to V&V these codes  
9 and confirm the applicability of equations and  
10 correlations later.

11 MEMBER HALNON: Ben, I don't get that. I  
12 don't understand. I mean, that's like building  
13 something to a draft ASME code that's not approved yet  
14 and saying -- did they ask for approval of the codes  
15 and equations, or is this another one of those things  
16 at risk and they're just building moving forward, land  
17 unexplored?

18 MR. ADAMS: I believe it was made clear  
19 that all of these would be reviewed during the code  
20 V&V, which will be done at the OL stage. So we have  
21 not approved anything at this stage.

22 MEMBER HALNON: So that punch list is  
23 growing.

24 DR. SCHULTZ: Ben, this is Steve Schultz.  
25 Is there a schedule for that, for the submittals and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 your review, as well?

2 MR. ADAMS: We have not been given a  
3 specific schedule. We're assuming it's going to come  
4 in with the operating license application, but it  
5 could come in earlier. We don't know.

6 DR. SCHULTZ: In a topical report or  
7 something.

8 MR. ADAMS: It could come in a topical  
9 report, for example, yes.

10 MR. BEASLEY: So, yes, we do not have a  
11 schedule yet. We have talked with Kairos about some  
12 pre-application activities for the OL application, but  
13 we have not started those yet. I say we have talked  
14 with them. They brought it up. I think they are  
15 planning some pre-application activities, but, again,  
16 we have been focusing on this review and haven't  
17 started investing time in that yet.

18 I'm sorry. This is Ben Beasley with the  
19 NRC staff.

20 MEMBER HALNON: So to look back, I am  
21 trying to reconcile in my brain how you build  
22 something with unapproved codes and equations. How do  
23 you guys approve that you can go build this? Is it  
24 because of the hook and the operating license review?  
25 Is that what you're resting on from the standpoint of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 this thing could be built and just left there because  
2 you don't approve it in the future? I mean, is that  
3 essentially the strategy?

4 MR. BEASLEY: This is Ben Beasley with the  
5 staff. Yes, that is essentially the strategy. They  
6 have not asked for specific approval of any design or  
7 of these codes, and so, yes, they are accepting that  
8 risk.

9 MEMBER HALNON: Okay. I'll get off it.  
10 I don't fully understand the business model, but  
11 that's not our purview.

12 MEMBER REMPE: There were historical  
13 precedence years ago when they had the advanced  
14 reactor program and all the various types of designs.  
15 Some of them went all the way, some of them didn't,  
16 right. The PR, what is it called? The power reactor  
17 development program that was done back in the 50s and  
18 60s, right.

19 MEMBER HALNON: That's kind of before I  
20 was in the nuclear business, but I --

21 MEMBER REMPE: It was before I was born.  
22 The history is interesting, though.

23 MR. ADAMS: Okay. I will be moving on to  
24 the NRC staff's technical evaluation conclusions.  
25 We'll go through the list of the PDC first.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1           So for PDC 10, reactor design, the Hermes  
2 thermal hydraulic design is designed to provide  
3 adequate heat removal. The NRC staff did perform  
4 scoping calculations, and the staff predicted that  
5 TRISO fuel does maintain integrity during postulated  
6 events and that there is adequate heat removal. This  
7 also played a role in the findings, and staff finds  
8 this is consistent with PDC 10.

9           For PDC 12, suppression of reactor power  
10 oscillations, we based our findings for the PDC on the  
11 fact that the FLiBe coolant should be experiencing  
12 single-based flow in the core and that the system has  
13 high thermal ownership. We did not have any specific  
14 analyses to review for the construction permit  
15 application, but, as stated in the PSAR, Kairos will  
16 be providing those with the operating license  
17 application for the inherent stability of the reactor.  
18 And the staff did not perform its own scoping  
19 calculations on this topic.

20           For PDC 34, residual heat removal, the  
21 PHTS residual heat removal during normal operations,  
22 which include start-up and shutdown, the downcomer  
23 fluidic diodes, reflector blocks, and THRS remove heat  
24 during postulated events and staff finds this is  
25 consistent with PDC 34. The PHTS DHRS will be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 discussed. I don't know if those are all later today,  
2 but I believe the DHRS is discussed later today. And  
3 the fluidic diode, we discussed that a little bit this  
4 morning.

5 For PDC 35, passive residual heat removal,  
6 again, the same features are relied on for heat  
7 removal during postulated events. All postulated  
8 events, the residual heat is removed via natural  
9 circulation through the downcomer and fluidic diodes  
10 and the reflector blocks and the DHRS. Staff finds  
11 this is consistent with PDC 35.

12 And, again, the scoping analyses performed  
13 by the staff played a role in performing our findings  
14 for all of these PDC. The information provided is  
15 consistent with PDC 10, 12, 34, and 35, and with  
16 acceptance criteria of NUREG-1537, and the analytical  
17 methods for the thermal hydraulic design are  
18 acceptable at this stage of the design.

19 The NRC staff concludes that the  
20 preliminary design provided in PSAR Section 4.6 is  
21 consistent with the applicable PDCs and acceptance  
22 criteria in NUREG-1537, and the NRC staff finds that  
23 the information in Hermes PSAR Section 4.6 is  
24 sufficient for the issuance of a construction permit  
25 in accordance with 10 CFR 50.35 and 50.40, and further

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 information can be reasonable left for the OL  
2 application.

3 I believe that is the last slide.

4 CHAIR PETTI: Members, questions? Let me  
5 just say this on our last discussion that I don't know  
6 that the risk is super high. There's huge margin in  
7 the design, so, you know, knowing what the number is,  
8 let's say, of a temperature, yes, there's uncertainty  
9 in that, but that the codes would be so wrong that  
10 you'd exceed something that would get you into  
11 trouble, I don't think that's the case. You just look  
12 at the power density and the heat removal capability  
13 of FLiBe and the conductivity of graphite. I think  
14 you can easily convince yourself that that's not an  
15 issue.

16 Okay. Then if there's no comments, we can  
17 take our break and, let's see, be back at 10:30.

18 (Whereupon, the above-entitled matter went  
19 off the record at 10:07 a.m. and resumed at 10:29  
20 a.m.)

21 CHAIR PETTI: Kairos, are you ready?

22 DR. DORON: We're on. Okay. This is Oded  
23 Doron again, senior director of reactor system design.  
24 I'm going to be discussing PSAR Section 4.7, the  
25 reactor vessel support system, or what we call RVSS.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           So the purpose of the RVSS, it supports  
2 the weight of the reactor vessel with the fuel,  
3 coolant, internals, and attachments. It provides  
4 thermal management to support the vessel expansion  
5 from ambient to full temp.

6           RVSS is a bottom support that includes a  
7 support tray, a ledge, support columns, support pads,  
8 base plate, vessel connector, and anchoring  
9 connectors. It is made out of 316H stainless steel.  
10 The reactor vessel bottom head sits directly on the  
11 bottom support. It's designed and fabricated using  
12 ASME Section III, Division 5. It's vertically  
13 anchored to the reactor building foundation.

14           RVSS thermal management. It protects the  
15 reactor building cavity concrete from thermal effects.  
16 Thermal break provided by insulation ensures the  
17 reactor building concrete, ensures the integrity of  
18 the reactor building concrete. Reactor building  
19 seismic isolation, it does not use lateral seismic  
20 restraints for the reactor vessel and head-mounted  
21 components the RVSS is designed to keep the reactor  
22 vessel from uplift and shear during seismic events.  
23 Design leverages seismic isolation of the reactor  
24 building to reduce seismic effects on the vessel,  
25 RVSS, and head-mounted components.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 To the right there is a simple schematic  
2 showing where the RVSS will be located. Below that is  
3 some more rather light but still detailed on the  
4 design of the RVSS. I'll pause here for a second.

5 CHAIR PETTI: Yes, so just a question.  
6 The seismic isolator is below the RVSS?

7 DR. DORON: Well, rather, the reactor  
8 building is within, it's seismically isolated, so we  
9 take --

10 CHAIR PETTI: Oh, okay.

11 DR. DORON: Yes, we take credit for the  
12 input spectrum. Okay.

13 Now the PDCs. RVSS is designed to  
14 withstand the effects of natural phenomena and support  
15 the reactor vessel in the event of an earthquake. The  
16 bottom support and connectors meet ASCE 43-19 and  
17 preclude linear buckling of the vessel's forward  
18 columns and provide lateral and uplift support. This  
19 satisfies PDC 2.

20 RVSS is designed for the environmental  
21 conditions, including temperature loading cycles, in  
22 combination with mechanical loading cycles. Catch  
23 basin sensors for leak detectors are used to preclude  
24 damage to the RVSS from primary coolant leaks. It  
25 satisfies PDC 4.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           RVSS design ensures the integrity of the  
2 reactor vessel during postulated events to support the  
3 geometry for passive removal of residual heat from the  
4 core by removing heat from the reactor vessel via the  
5 reactor thermal management system actively during  
6 normal operation and passively during postulated  
7 events. This satisfies PDC 74.

8           RVSS design removes heat from the vessel  
9 and ensures the integrity of the reactor vessel and  
10 the reflector blocks, thereby permitting sufficient  
11 insertion of the control and shutdown elements  
12 providing for reactor shutdown. RVSS design ensures  
13 that ACI 349-13 is met to support maintenance and  
14 inspection of the vessel bottom head and shell weld  
15 and reactor cavity. This satisfies PDC 74.

16           I believe this is my last slide.

17           CHAIR PETTI: Members, questions? Okay.  
18 Hearing none, let's move on to the staff then.

19           MR. LE: Good morning. My name is Tuan  
20 Le. I'm a reactor engineer with Division of Advanced  
21 Reactors and Non-Power Production and Utilization  
22 Facilities. Today, I will go over the staff review on  
23 the PSAR Section 4.7, the reactor vessel support  
24 systems. The agenda for this section I have -- next  
25 slide, please -- I will go over the PSAR Section 4.7,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the reactor vessel support system; the regulatory  
2 basis; and PDCs. References the topical report, staff  
3 technical evaluation, technical conclusion, and  
4 regulatory findings.

5 Next slide, please. For our review of the  
6 reactor vessel support system, the RPD provide the  
7 structure support for the reactor vessel and reactor  
8 internals. Under these supports the full weight of  
9 the vessel, fuel, coolant, vessel internal, and head-  
10 mounted components. RDP is designed to handle the  
11 structures seismic and internal load to calculate the  
12 structures and address the thermal expansion during  
13 the initial heat-up and postulated events.

14 Next slide, please. The regulatory basis  
15 for this review of PSAR Section 4.7, the 10 CFR  
16 50.34(a), the preliminary safety analysis report; 10  
17 CFR 50.35, assurance of construction permits; 10 CFR  
18 50.40, common standards; and the PDC associated with  
19 the review of this Section 4.7 are the following: PDC  
20 2, design basis for protection against natural  
21 phenomena; PDC 4, environmental and dynamic effect  
22 design basis; the PDC 74, reactor vessel and reactor  
23 systems structure design basis. Our staff also used  
24 NUREG-1537, guidelines for repairing and reviewing the  
25 application for the licensing of non-power reactors.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           For PDC 2, the staff evaluation as  
2 follows: PDC 2 is the design basis for protection  
3 against natural phenomena. Table 3 of 4.7-1, the load  
4 recommendation for reactor vessel supports provide a  
5 load recommendation for the RVSS include seismic loads  
6 due to the design basis earthquake. This load  
7 recommendation and the methodology will be used to  
8 demonstrate that the final design will meet the  
9 allowable stress limit specified in the ASME Section  
10 III, Division 5.

11           Based on acceptable loading methodology,  
12 the staff finds that the preliminary information for  
13 the RVSS design is consistent with PDC 2.

14           Next slide, please. For PDC 4, the staff  
15 evaluation as follows: PDC 4 is the environmental and  
16 dynamic effect design basis. The design features  
17 address the environmental and dynamic effect on the  
18 RVSS as following: pipe whip hazard included by design  
19 due to the lack of pressurized piping; discharge fluid  
20 addressed by catch basins with a leak protection  
21 system. The RVSS is designed to address temperature  
22 and mechanical load in order to prevent damage from  
23 creep fatigue to allow the thermal expansion of the  
24 reactor during the start-up and operations.

25           Based on design feature to manage the pipe

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 whip hazard, discharge fluid, and the loading cycle,  
2 the staff find the preliminary information of the RVSS  
3 is consistent with the PDC 4 and the relevant NUREG-  
4 1537 criteria.

5 Next slide, please. For the PDC 74, staff  
6 evaluation as follow: PDC 4, reactor vessel reactor  
7 system structure design basis, RVSS design have to  
8 ensure there is sufficient heat removed from the  
9 vessel while also providing the structure support for  
10 the reactor vessel under static and dynamic load.  
11 This includes seismic loading. Heat is removed by the  
12 reactor thermal management system, the RTMS, actively  
13 during normal operation and passively during the  
14 postulated events.

15 Based on the design for sufficient heat  
16 removal and the structure support, the staff finds the  
17 preliminary information for the RVSS system design  
18 consistent with PDC 74.

19 Next slide, please. So in conclusion, the  
20 staff had the following findings: Regulatory findings,  
21 the staff finds that the preliminary design  
22 information is consistent with PDC 2, 4, and 74, and  
23 applicable criteria in the NUREG-1537. Staff  
24 concluded information in Hermes PSAR Section 4.7 is  
25 sufficient for the issuance of CP in accordance with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 10 CFR 50.35, and further information can be  
2 reasonably left for the application stage.

3 That concludes my presentation for Section  
4 4.3. I'll now open for any question, please.

5 CHAIR PETTI: Members, is there any  
6 questions?

7 MEMBER HALNON: We didn't hear a lot in  
8 your discussion about we'll look at that in the  
9 operating license portion. Previously, presenters  
10 have been very open with saying, hey, we need this but  
11 we'll get it in the operating. Is there anything that  
12 comes to mind that you think is very important? I  
13 know there's a lot that's going to be looked at in the  
14 operating, but what in your mind, are the important  
15 things to be looking at in the operating license when  
16 you review this 4.7?

17 MR. LE: We also identified some  
18 information detailing the design for the RVSS system,  
19 such as the loading cycle and profile for the RVSS  
20 system a detail like that would have to be reviewed to  
21 change the design for the systems. This information  
22 is supported for meeting the requirements, like stress  
23 analysis or support system, which includes testing the  
24 creep fatigue, the fatigue issue and the stress  
25 evaluation of the structures.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: Okay. I know that the  
2 creep and the fatigue and those types of analysis,  
3 with only a four-year operating cycle, it's not  
4 necessarily a big concern, but I can understand that  
5 you'll want to see some of those cycles in the  
6 operating philosophies as we go forward.

7 Okay. Thank you.

8 CHAIR PETTI: Okay. Thank you. At this  
9 point, that concludes Chapter 4, so we can move to the  
10 memo. Thank you.

11 (Whereupon, the above-entitled matter went  
12 off the record at 10:44 a.m. and resumed at 11:00  
13 a.m.)

14 CHAIR PETTI: Okay, since your slides are  
15 up, I assume you're ready, Kairos?

16 MR. PEEBLES: Yes, we're ready. This is  
17 Drew Peebles, senior manager of licensing. Nico  
18 Zweibaum is going to be presenting on the decay heat  
19 removal system, but I'm going to start us off on  
20 functional containment.

21 So, there's been a bit of discussion over  
22 the past two days on functional containment directly,  
23 or indirectly. So, this slide points out that the  
24 functional containment strategy is defined in  
25 commission policy, which is in SECY-18-0096. And

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 that's a barrier, or set of barriers together, that  
2 effectively limit the physical transport of  
3 radioactive material to the environment.

4 There was some discussion on the  
5 reliability of the piping in the PHCS, and how we  
6 differ from LWR technology. So, there are a couple of  
7 parts of the SECY that I'll point out. One is that  
8 the idea of functional containment was born out of the  
9 differences from non-LWR technology from LWRs.

10 The LWR defense in depth strategy was  
11 based on the smaller margins for the zirconium clad  
12 fuel, and water coolant. So, advanced reactors having  
13 a more robust fuel design, a coolant that retains  
14 radionuclides, and operating conditions that don't  
15 allow for energetic releases when we have a break in  
16 the piping mean that we have a lot more margin to the  
17 consequences.

18 So, if I'm looking at Hermes specific  
19 consequences, think of it in terms of we have very  
20 large margins starting at the fuel. When we were  
21 talking about the head being leak tight, all of those  
22 we were kind of thinking of them in terms of physical  
23 barriers, again, beyond the fuel, and the salt. We  
24 don't need that, we don't rely on those, because even  
25 using the very deterministic safety case that we used

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 for Hermes, we only credit the barriers in the fuel,  
2 the TRISO layers, and then the salt.

3 And we allow the radionuclides to  
4 transport to the site boundary, we still end up with  
5 consequences of one rem. So, this is significantly  
6 less than the 25 rem that's needed for a siting  
7 conclusion. But that is with the hyper conservative  
8 safety case where everything is -- we're not taking  
9 credit for it beyond the fuel, and the salt. So, I  
10 wanted to add that context before we moved on. Are  
11 there any thoughts, or questions on that first part?

12 CHAIR PETTI: You said the doses were one  
13 rem, or below one rem?

14 MR. PEEBLES: Below one rem.

15 CHAIR PETTI: Below, that's what I  
16 thought.

17 MR. PEEBLES: So, that's our target site  
18 boundary.

19 CHAIR PETTI: Right. I didn't see any  
20 hands, keep going.

21 MR. PEEBLES: All right, I'm going to hand  
22 it over to Nico for decay heat removal system.

23 MR. ZWEIBAUM: Thank you very much. As  
24 Drew mentioned before, my name is Nico Zweibaum, I'm  
25 the director of solid systems design here at Kairos

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Power. So, as far as Chapter 6, and engineered safety  
2 features, the main system we described is our decay  
3 heat removal system. You see a picture on the left  
4 that kind of describes what that system looks like.  
5 Its purpose is to provide passive decay heat removal  
6 during postulated events when the primary heat  
7 transport system is unavailable.

8 The way this system is run, and works,  
9 it's an ex-vessel system. It continuously operates  
10 when the reactor is operating above the threshold  
11 power, and it removes energy from the vessel wall,  
12 thermal radiation, and conductive heat transfer to  
13 water-based annular thermosiphons, or thimbles. You  
14 can see on the picture, the vessel in the center,  
15 those annular thermosiphons are distributed around the  
16 periphery of the vessel.

17 And it's fed through water storage tanks,  
18 and steam separators. The DHRS, decay heat removal  
19 system, is shut off, and isolated when the reactor  
20 operates at low power levels. In that case the  
21 thermosiphons are dry, the parasitic losses alone are  
22 sufficient for decay heat removal. The DHRS is  
23 activated when the reactor starts operating above a  
24 defined threshold power.

25 And there is no change of state when that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 system is relied upon in response to postulated  
2 events. So, it's an always on type of system once  
3 we've crossed the determined threshold power at which  
4 we activate it. Of note, on the physics of that  
5 system, there's an inherent passive feedback  
6 mechanism, and the heat removal rate is a direct  
7 function of vessel temperature. And that's due to the  
8 physics of thermal radiation heat transfer.

9 So, there's a direct dependency between  
10 the amount of heat that we remove from the vessel  
11 wall, and the temperature difference between the  
12 vessel, and the thermosiphons where boil off is  
13 happening.

14 CHAIR PETTI: Just a question in terms of  
15 the activation of the DHRS, is it going to be  
16 automatic, or is it going to be an operator initiated  
17 action, or do you not know yet?

18 MR. ZWEIBAUM: That's something that we  
19 will clarify with the operating license application.

20 CHAIR PETTI: Okay, it's just you know  
21 that in the context of Part 53, there's these new  
22 definitions of types of facilities, if it's self-  
23 mitigating or not, and that all depends if the  
24 operator has a role in safety functions. So, it's  
25 just a point about the design, if we knew the answer,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 we could say something about it in the letter. That's  
2 fine, thank you.

3 MR. PEEBLES: So, this is Drew Peebles  
4 again, just to be clear, turning on DHRS is not a  
5 safety function. The rest of the mitigating  
6 functions, if there's a transient, would all be  
7 passive. And that is due to the fact that this  
8 activation happens before the system would be relied  
9 upon during a postulated event, right?

10 CHAIR PETTI: Okay, I understand, that  
11 helps, yes.

12 MEMBER BROWN: Can you say that again?  
13 This is Charlie Brown. Once you go into operation, or  
14 startup, and go critical, according to the chapter, it  
15 says it's not on until you pass a threshold, and at  
16 that threshold, you then have an automatic signal  
17 which turns it on, and it operates continuously when  
18 you're above that power threshold.

19 That seems pretty clear, in Chapter 7 it  
20 talks about an activation function which comes out of  
21 the RPS to turn it on, to ensure actuation of the  
22 DHRS. So, your statement that it's on all the time  
23 once you go above a certain power level is listed  
24 inside Chapter 6, which that makes it sound like it's  
25 part of the normal heat removal system.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MR. PEEBLES: I think we'd have to go  
2 back, and look at Chapter 6 again, but I don't think  
3 there's any RPS signal to turn.

4 MEMBER BROWN: Well, on Chapter 7.1,  
5 figure 7.1-1 says there's an activation function that  
6 goes from the RPS down to the DHRS system. And  
7 there's words in the chapter that say although the  
8 DHRS is always operating above a certain threshold of  
9 fission production accumulation level, the decay heat  
10 removal system provides actuation signal. The RPS  
11 provides actuation signal to DHRS to ensure it is  
12 operating when there is an RPS actuation.

13 And that goes on, and on. The actuation  
14 of the DHRS by removing the power to the water tank  
15 isolation valves to ensure passive flow.

16 MR. PEEBLES: Yeah, I'm being told it's  
17 actually a redundant feature. We may turn it on, or  
18 there's a safety signal. The safety signal would be  
19 in case it wasn't operating.

20 MEMBER BROWN: Well, let me back track.  
21 It says any time you go above that threshold power  
22 level of around ten megawatts, I'm sorry, that just  
23 flew out, I apologize, the DHRS is on all the time.

24 MR. PEEBLES: That is right, that is  
25 correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER BROWN: Well, that makes it sound  
2 like it's part of the normal cooling system for the  
3 system, for even normal operation.

4                   MR. PEEBLES: Well, there will be some  
5 heat losses through that system during normal  
6 operations, yes. That's --

7                   MEMBER BROWN: What if it fails during  
8 normal operation as you're at the maximum power?

9                   MR. PEEBLES: So, we'll shut down anytime  
10 there is this type of anomaly. We'll have technical  
11 specifications on a number of metrics within that  
12 system, including water levels, and others, and  
13 integrity of the lead barrier. So, we'll get into  
14 some more details around the design of that system in  
15 a moment, there's a number of technical specifications  
16 that we'll be meeting with that system, and if we're  
17 outside of those bounds, then we would immediately  
18 shutdown the reactor.

19                   MEMBER BROWN: Manually?

20                   MR. PEEBLES: That would be defined in the  
21 tech specs of the operating license application.

22                   MEMBER BROWN: In the Chapter 6 text, it  
23 says for half power operation greater than the  
24 threshold, it is in continuous operation, etcetera,  
25 etcetera. I'm just saying there's an inconsistency,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 in terms of my own mind, regardless, and you've got  
2 various other things like the tanks are capable of  
3 seven days operation, but yet there's other statements  
4 that it operates for 72 hours. I couldn't figure out  
5 the difference between those two times either. I'm  
6 sorry to be picky, it's just --

7 CHAIR PETTI: Let's let him get into that  
8 then, and if they address it, we'll go on.

9 MR. ZWEIBAUM: We can move on, but there  
10 will be mentions of the sizing of those tanks, and  
11 what it's being sized for, and that's the seven days.  
12 Next slide. So, this goes a little bit more into the  
13 various stages of operation, and hopefully sheds light  
14 on the high level statements I made on the previous  
15 slide. So, early on, let's say in the operating life  
16 of the reactor, when we're operating at low, or no  
17 power, you can see there that the isolation valves  
18 that's between those water storage tanks, and the  
19 thermosiphons, or thimbles, is closed.

20 So, the DHRS is deactivated. In that  
21 case, parasitic heat losses through the vessel wall,  
22 and cavity are sufficient to remove decay heat should  
23 a postulated event occur, and so we're not relying on  
24 decay heat removal from the DHRS in that situation to  
25 remove sufficient decay heat from the reactor. Next

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 slide. So, once we operate above a defined threshold  
2 power, that isolation valve that was previously  
3 closed, opens.

4 We also have a feedwater line upstream of  
5 the water storage tank that is open. And so, we have  
6 continuous water flow from the feedwater system  
7 through the water storage tanks down to the thimbles,  
8 and continuous heat removal partly through that  
9 system. So, I think that's part of what Charlie was  
10 referring to before, which is that during normal  
11 operation here, we have some amount of parasitic  
12 losses through that DHRS system, and out through water  
13 boiling, and then steam evacuation through the  
14 atmosphere.

15 As far as the safety function of that  
16 system is really, if we go to the next slide, once the  
17 postulated event occurs, whether that be loss of the  
18 primary heat transport system, loss of electrical  
19 power, or loss of feedwater, in that case we're  
20 relying on the inventory of water that is in the water  
21 storage tank to continuously feedwater to the thimbles  
22 for up to seven days for decay heat removal from the  
23 reactor vessel.

24 MEMBER BROWN: Yes, it still sounds like  
25 it's required for operation for normal operation, put

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1       aside the postulated events. So, in other words your  
2       basic power operation does not remove enough heat to  
3       allow you to operate above a threshold, and DHRS is a  
4       critical system to make sure you cool the core.  
5       That's what it sounds like.

6               MR. ZWEIBAUM: I can take a little bit of  
7       that, I guess. So, the normal decay heat removal  
8       system, and heat removal system from that system  
9       during normal operations is through the primary heat  
10      transport system. So, the primary heat transport  
11      system is sized to extract all the heat from the  
12      reactor core during normal operations.

13             There happens to be some extra parasitic  
14      heat losses through the DHRS, which is by design, so  
15      that there's no change of state once that system is  
16      relied upon during onset of postulated event. But  
17      that is not strictly relied upon for heat removal  
18      during normal operations, if that's the question.

19             MEMBER BROWN: If you go above the  
20      threshold then, and you don't turn on the DHRS, the  
21      plant operates just fine with no problems?

22             MR. ZWEIBAUM: It would, but we will have  
23      technical specifications that would probably --

24             MEMBER BROWN: I'm not worried about the  
25      technical specs, I'm worried about the actual ability

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 to operate now that you're no longer getting rid of  
2 these miscellaneous parasitic heat losses.

3 MR. ZWEIBAUM: It would technically be  
4 able to operate, the issue would be that on the onset  
5 of a postulated event in those conditions, if the DHRS  
6 were not on, that would mean that we were relying on  
7 a change of state, and that's what we're trying to  
8 avoid by design, which is why we turn it on before  
9 it's actually relied upon should a postulated event  
10 occur. But it is never relied upon for normal  
11 operations of the reactor.

12 MEMBER BROWN: So, it's got to be on  
13 already for normal operations in order to protect it  
14 from a postulated event?

15 MR. ZWEIBAUM: Yes.

16 MEMBER BROWN: Above a certain threshold,  
17 is that?

18 MR. ZWEIBAUM: That's right.

19 MEMBER BROWN: So, it's a safety system.

20 MR. ZWEIBAUM: Absolutely, that is our  
21 primary engineered safety feature.

22 MEMBER BROWN: Somebody said it's not a  
23 safety system a few minutes ago in the earlier  
24 conversation.

25 MR. ZWEIBAUM: It is.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BROWN: There's four tanks, the way  
2 I read this, there's four sets of thimbles, four  
3 tanks?

4 MR. ZWEIBAUM: Yes, the answer is yes, but  
5 we'll get into some more details on the design,  
6 there's a few slides remaining, but yes to the  
7 statement you just made.

8 MEMBER BROWN: Why doesn't this then also  
9 require during postulated events, the feedwater is  
10 turned off to the tanks? Why do you do that? The  
11 valve is closed according to your picture. The  
12 previous picture, as well as the words in the text.

13 MR. ZWEIBAUM: So, that's something that  
14 we'll need to clarify for operating license depending  
15 on a number of failure modes analyses, but the main  
16 thing is that we have sufficient inventory in the  
17 tanks themselves so that we're not relying upon water  
18 coming from the feedwater system to feed those  
19 thimbles, and to remove sufficient decay heat over the  
20 seven day period that this is sized for.

21 MEMBER BROWN: What's the 72 hours that's  
22 mentioned in the text referring to them?

23 MR. ZWEIBAUM: I'm not sure which 72 hour  
24 text.

25 MEMBER BROWN: There was 72 hours

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 mentioned that I'm trying to find out. I can't have  
2 both my -- everything on, plus the slides at the same  
3 time.

4 MR. ZWEIBAUM: No, it's fine, I can  
5 elaborate on the timing. So, the seven days is meant  
6 for the storage capacity of the tanks to ensure  
7 there's enough water for the system to operate for  
8 seven days. The 72 hour period is advanced reactor --  
9 excuse me, passive plant policy for safety-related  
10 systems to be able to operate. Beyond that, you can  
11 use non-safety-related systems to mitigate an event.  
12 In the case of the storage tanks, they are sized for  
13 the seven days' time.

14 MEMBER BROWN: Okay, so they're  
15 fundamentally sized for greater than 72 hours then?

16 MR. ZWEIBAUM: Correct.

17 MEMBER BROWN: Okay, so you more than meet  
18 the 72 hour requirement for this system. And the  
19 storage tank capacity does not need to be fed in order  
20 to meet that seven day requirement based on whatever  
21 level you establish in the tank as the normal level  
22 that you would be maintaining during normal operation?

23 MR. ZWEIBAUM: That's correct.

24 MEMBER BROWN: Okay.

25 MR. ZWEIBAUM: And the latest version of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 the PSAR does clearly indicate the seven days, we'll  
2 make sure that this is, that there's no inconsistency  
3 in that document.

4 MEMBER BROWN: I guess my point being is  
5 there's a cycle of operation, it was somewhat  
6 piecemeal in the earlier version, or at least the  
7 version I had of the PSAR, and that's why I asked  
8 those. Also the activation based on the RPS, which is  
9 called out in both documents, the activation plus lock  
10 that's shown in the figure. So, that's not discussed  
11 in the text at all. That's a Chapter 7 thing, but  
12 it's also, I think it's mentioned in the -- the  
13 activation is not mentioned in Chapter 6, but it is  
14 mentioned in Chapter 7.

15 As a safety-related function, activating  
16 the DHRS, figure 7.1-1 shows it, and there's text that  
17 shows it also. I didn't write down the paragraph  
18 number.

19 MR. ZWEIBAUM: Yeah, so there is this  
20 mention in Chapter 7, that there is automatic  
21 activation by the reactor protection system.

22 MEMBER BROWN: So, it ought to be  
23 clarified what circumstances that's needed, because it  
24 wasn't clearly stated, at least I couldn't find it.  
25 All right, I got my points in, that's something to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 think about today, the interaction between Chapter 7  
2 systems, and the DHRS should be further developed,  
3 that would be something I would include in your  
4 letter.

5 DR. BLEY: This is Dennis Bley, following  
6 up on Charlie's comment, if during operation, you do  
7 have some, I think you called it parasitic loss  
8 through the system, after a fair period of operation  
9 do you need to fill up these tanks again, or do they  
10 have enough water to cover that?

11 MR. ZWEIBAUM: So, during normal operation  
12 there is constant feeding of those tanks through the  
13 feedwater lines that you can see towards the right of  
14 this diagram. Yes, the water tanks are instantly  
15 replenished during normal operations. The goal of the  
16 capacity of those storage tanks is so that if a  
17 postulated event resulted in those feeder water lines  
18 not being available to replenish the tanks, then we  
19 have sufficient inventory to feedwater into the  
20 thimbles for up to seven days.

21 MEMBER BROWN: There was not a good  
22 discussion of that Dennis, of the level  
23 instrumentation. It was just noted, that's all. All  
24 right.

25 CHAIR PETTI: Keep going, thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. ZWEIBAUM: So, a little bit more on  
2 kind of the process design for that system. One thing  
3 to note is that the DHRS does not directly interact  
4 with the reactor coolant. It's a system, it's a water  
5 based system, but it's completely outside of the solid  
6 boundary. As mentioned before, there's no change of  
7 state on onset of postulated events. The system is  
8 always on once we operate above set power levels.

9 There are several parallel, and  
10 independent cooling pathways. Four independent  
11 cooling trains, and only three trains are require to  
12 meet the cooling demands. So, I think there was a  
13 question before around there are four tanks, and four  
14 sets of thimbles, so this clarifies with only three be  
15 required for sufficient heat removal from the vessel.

16 MEMBER BROWN: I had another question, you  
17 talked about the parasitic thing is to keep something  
18 from going solid, is that the sodium?

19 MR. ZWEIBAUM: No, the parasitic losses  
20 are inherent to the fact that the system is activated  
21 during normal operations, there's no sodium in that  
22 system.

23 MEMBER BROWN: I know that they're not in  
24 that system, but you said keeping something from going  
25 solid in an earlier statement, and I didn't understand

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 what you were trying to prevent from going solid, and  
2 if the DHRS was responsible for making sure that  
3 didn't happen during a postulated event, or something.  
4 I forgot the context.

5 MR. ZWEIBAUM: Sorry, the change of state  
6 statement might have been confusing. Change of state  
7 not in that it's liquid to solid, change of state in  
8 operating versus not operating.

9 MEMBER BROWN: Okay, not the condition of  
10 the coolant?

11 MR. ZWEIBAUM: No, no, no.

12 MEMBER BROWN: Okay, all right, thank you.

13 MR. ZWEIBAUM: The system is dual walled.  
14 You can see there's a leak barrier that encompasses  
15 all of the subsystems here, all the way up to above  
16 the water level in the water storage tank, and that is  
17 meant for leak prevention, and detection. But of note  
18 is that the system is designed so that we could  
19 continue to remove heat in the presence of a leak.  
20 And you see the isolation valve between the water  
21 storage tank, and the thimbles.

22 That's an active component, a failure  
23 would not introduce failures in heat removal, in that  
24 that valve fails in place. So, if the system  
25 operates, that is the valve is open, a failure would

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 leave that valve open. And similarly, we have a float  
2 valve that regulates level in the separator above the  
3 thimbles, but that float valve stays open.

4 So, any failure of the system is designed  
5 to keep it removing heat from the vessel.

6 MEMBER BROWN: That's for the float valve,  
7 but the isolation valve, if it fails, it can fail  
8 closed.

9 MR. ZWEIBAUM: It fails in place. So, if  
10 it's open, it's all open.

11 MEMBER BROWN: Okay, thank you.

12 MR. ZWEIBAUM: Okay, so just diving down  
13 into a few of the subsystem designs. First the water  
14 storage tanks highlighted in blue on the right. The  
15 sizing, as mentioned a couple of times, is sufficient  
16 for up to seven days of continuous operation to  
17 support heat removal, and mitigate postulated events,  
18 even without replenishing through the feedwater line.  
19 The location of those tanks, four of them, they're  
20 outside of the reactor cavity.

21 That's the darker gray wall that you see  
22 to the left of the storage tanks. They're located at  
23 higher elevation than other DHRS components, and the  
24 flow from the water storage tanks into the thimbles is  
25 gravity driven, to the separator, and the thimbles.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 As far as redundancy, and independence of those  
2 systems, only three out of four tanks are needed for  
3 adequate heat removal, and each tank is independent  
4 from the others in its location, and connection to the  
5 thimbles.

6 So, we have four fully independent trains  
7 of tank, separator, and six thimbles per train.

8 CHAIR PETTI: So, just a question, is this  
9 true even at, say above the threshold value? Because  
10 there's a threshold value, and then there's full  
11 power, that's quite a range of power. Is this all  
12 because the temperature on the outside of the vessel  
13 also scales with the power? So, everything kind of  
14 goes together.

15 MR. ZWEIBAUM: The temperature of the  
16 vessel will be maintained at the same value throughout  
17 the full operating range.

18 CHAIR PETTI: So, basically the radiant  
19 heat flux onto the thimble system is the same  
20 independent of what the power level is in the reactor?

21 MR. ZWEIBAUM: Yeah.

22 CHAIR PETTI: Then this is where I'm kind  
23 of mentally -- then there's a chance to overcool,  
24 because you can extract more heat than is in the core,  
25 because it --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. ZWEIBAUM: Yeah, so -- sorry, I'll let  
2 you finish.

3 MEMBER BROWN: It's turned off below a  
4 threshold.

5 CHAIR PETTI: I'm talking about above  
6 threshold.

7 MR. ZWEIBAUM: Yeah, so the system will be  
8 designed so that there is no over cooling, or freezing  
9 of the coolant inside the reactor vessel for up to 72  
10 hours.

11 CHAIR PETTI: I understand that, I'm still  
12 confused. If you have a certain radiant heat flux,  
13 and that doesn't change, and there's a certain boil  
14 off rate of the coolant propositional to that radiant  
15 heat flux. Now, the power of the reactor could be  
16 above threshold, but the system doesn't know it, or  
17 doesn't feel it, is that?

18 MR. ZWEIBAUM: Yeah, that's correct. So,  
19 you'll see once the trend starts, the temperature  
20 evolution of the reactor vessel will depend on the  
21 initial power at which the postulated event happens.  
22 But the heat flux is constant, since it's just a  
23 dependency on the temperature difference between the  
24 reactor vessel wall, which is set at the onset of the  
25 transient, and the thimble wall temperature, which by

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 virtue of boil off is set at 100 degrees Celsius.

2 CHAIR PETTI: Yeah, okay, so then  
3 temperatures inside the reactor are changing depending  
4 on where you are between threshold power --

5 MR. ZWEIBAUM: Yes.

6 CHAIR PETTI: Yeah, okay, it's clear now,  
7 thank you.

8 MEMBER HALNON: I may have blanked out on  
9 this, inventory for seven days, that's without  
10 feedwater makeup, correct?

11 CHAIR PETTI: Right.

12 MEMBER HALNON: Okay, I for some reason  
13 didn't get that.

14 MR. ZWEIBAUM: Okay, next slide. So,  
15 downstream of those tanks are the steam separators,  
16 and thimbles. The separator is pictured on the upper  
17 right, and also it is one of the figures in the PSAR.  
18 Those separators serve as the interface between the  
19 water storage tanks, and the thimbles. You can see  
20 that the feedwater line from the storage tank comes in  
21 on the upper right here.

22 There is a float valve that's located  
23 there to regulate level in the separator. So, when  
24 the water level exceeds a threshold value, that float  
25 valve blocks the feedwater line, and when the water

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 level is below a threshold value, the float valve  
2 allows for continuous flow. It's a passive operation,  
3 and fail open design as mentioned earlier. If the  
4 valve fails, it fails open.

5 We will flood the separator, but we're  
6 designing, and analyzing the system to show that does  
7 not affect the net heat removal performance of the  
8 thimbles. The thimble itself is an annular  
9 thermosiphon that's located circumferentially around  
10 the outside of the reactor vessel, the four trains of  
11 six. We have a guide tube that's located at the  
12 center of that structure. That's the blue region that  
13 you can see in the picture on the right.

14 So, the water flow goes down through that  
15 guide tube, and then there's an ebb operator tube  
16 that's on the outside of that that forms an annulus  
17 where the boiling of the water happens for each  
18 removal. And yet a third annular region around that  
19 is the leak barrier that was mentioned earlier. So,  
20 we will have a dual well design that allows for the  
21 system to still remove heat, even if there's a breach  
22 in the evaporator tube.

23 And that's a fully passive flow system, so  
24 we're just relying on natural circulation, and boil  
25 off in those thermosiphons for heat removal.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BROWN: So, the blue water comes  
2 out the bottom of the little blue pipe, and comes up  
3 around the outside of it as red, getting heated?

4 MR. ZWEIBAUM: That's correct.

5 MEMBER BROWN: Okay. And that gray area  
6 around it, I take it that's your thimble wall, and  
7 that's what's getting irradiated?

8 MR. ZWEIBAUM: Yes. But that's the leak  
9 barrier, so there is actually some void space in  
10 there, there's just gas in that region, and that acts  
11 as a leak barrier. So, if your red region leaks, you  
12 would still have water contained within that gray  
13 region, and it would not be flooding the reactor  
14 cavity. But we would detect that leak in that sense,  
15 and in the PSAR, and we'll have technical  
16 specifications also on potential shutdown of the  
17 reactor if we detect a leak in that region.

18 MEMBER BROWN: So, that's not a solid,  
19 okay.

20 MR. ZWEIBAUM: There's walls at each  
21 layer, but that gray region, and you can see -- it's  
22 very tiny font, I apologize for that, but it says gas  
23 at the very bottom right. So, that's a gas region  
24 outside of that.

25 MEMBER BROWN: That I don't understand.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 The thimble is -- so, that gray is all gas?

2 MR. ZWEIBAUM: Yes.

3 MEMBER BROWN: Okay. So, you get radiated  
4 heat going into the outside wall thimble, then it's  
5 got a convective through the -- so, it gets through  
6 the gas?

7 MR. ZWEIBAUM: Yeah, you convect and  
8 radiate heat everywhere you have gas in that system  
9 out to the water.

10 MEMBER BROWN: But the gas is not a mobile  
11 type thing, it's a static system?

12 MR. ZWEIBAUM: Yeah.

13 MEMBER BROWN: Okay, thank you.

14 MEMBER KIRCHNER: Just a minor detail from  
15 a design standpoint, four thimbles like that would  
16 have to be either very large to get the surface area  
17 you need, or flattened out like a flat panel radiator.  
18 Have you done that part of the design? Because if you  
19 have localized small thimbles, then you're going to  
20 have local stresses in the vessel.

21 MR. ZWEIBAUM: Yeah, so we have run the  
22 analysis to show that the number of thimbles that we  
23 have around that system is consistent with the power  
24 level of the system. And so, for the 35 megawatt  
25 thermal reactor, the four trains of six thimbles, or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 actually, only three out of four are required, so  
2 technically 18 thimbles would be sufficient to remove  
3 sufficient decay heat during a postulated event to the  
4 maximum reactor power.

5 MEMBER BROWN: What's the diameter of a  
6 thimble? I mean are we talking inches?

7 MR. ZWEIBAUM: Yeah, it's a little under  
8 three inches.

9 MEMBER BROWN: So, you've got a total of  
10 24 three-inch diameter thimbles going around the  
11 vessel?

12 MR. ZWEIBAUM: Yes.

13 MEMBER BROWN: So, is there a big gap  
14 between the thimbles then? I'm addressing Walt's  
15 question. They're not touching each other?

16 MR. ZWEIBAUM: They're not touching each  
17 other. So, I don't have the exact value of the gap  
18 off the top of my head, but they're equally  
19 distributed around the circumference of the vessel,  
20 and there's 24 of them.

21 MEMBER BROWN: And so they're sitting in  
22 air, or whatever --

23 MR. ZWEIBAUM: Yeah, they're sitting in  
24 the reactor cavity. So, the way the geometry goes,  
25 you have the vessel, you have those thimbles, and then

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 outside of that you have the insulation that is  
2 sitting between the thimbles, and the reactor cavity  
3 wall, concrete wall.

4 MEMBER BROWN: Okay. Did that clarify  
5 your question? I had to ask that, Walt.

6 MEMBER KIRCHNER: It was a good question.  
7 Thank you.

8 MR. ZWEIBAUM: Okay, so going to the  
9 design basis for that system. First, the safety-  
10 related portions of the DHRS are designed to ASME 3  
11 Division 5 Class B. ASCE 43-19, and 416 for seismic.  
12 And ACI 349-13 codes, and standards, and that's  
13 consistent with our principle design criteria one.  
14 That system is primarily located in the safety-related  
15 portion of the reactor building.

16 Which is designed to protect safety-  
17 related components from external hazards, and other  
18 non-safety-related DHRS components does not affect the  
19 components of the safety-related SSCs, that's PDC 2.  
20 That system is designed with low combustible  
21 materials, it uses physical separation of the trains  
22 to minimize the probability, and effect of fires, and  
23 explosions, PDC 3.

24 That system is designed with materials  
25 that will withstand the environmental conditions in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the reactor cavity during normal operation,  
2 maintenance, testing, and postulated events. The  
3 components are designed to preclude cascading  
4 failures, and failures that could impact nearby safety  
5 systems, that's PDC 4. That system is capable of  
6 removing an adequate amount of decay heat to ensure  
7 that SARRDLs are not exceeded, and the reactor vessel,  
8 and fuel temperatures remain below their design  
9 limits, PDC 34, and 35.

10 And the system is designed to allow for  
11 periodic inspection, and functional testing to ensure  
12 integrity, operability, and performance of the system,  
13 and that's PDC 36, and 37.

14 CHAIR PETTI: Just another question, in  
15 terms of the temperature limits, in gas systems it's  
16 never the fuel that's the issue with your decay heat  
17 removal, it's always the vessel is closer to its  
18 limit, is that the case here too?

19 MR. ZWEIBAUM: Yes, so that system is  
20 designed to limit the vessel wall temperature to the  
21 maximum temperature level.

22 CHAIR PETTI: Right, okay, thank you.

23 MR. ZWEIBAUM: And its own, which is also  
24 specified in the PSAR. So, the metallic structures of  
25 the DHRS are also limited to that temperature value.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR PETTI: Yeah, right, okay.

2 MEMBER BROWN: Another question, this is  
3 Charlie again. If you're operating at full power,  
4 you're there for a while, long enough to be  
5 equilibrium, and the DHRS is on, and now you go fairly  
6 rapidly back down below the threshold, and yet below  
7 the threshold, the DHRS at least based on what's in  
8 the text, and everything, would turn off.

9 MR. ZWEIBAUM: Not necessarily.

10 MEMBER BROWN: Well, that's the  
11 implication, I'm not saying -- just that was the  
12 implication, because it comes on when you go above the  
13 threshold automatically. That's at least the  
14 implication from reading the text in Chapter 6, and  
15 Chapter 7. And if you go back down below that, and it  
16 goes off, isn't there a greater amount of parasitic,  
17 or whatever other kind of heat you want if you reduce  
18 it fairly rapidly back down?

19 Like you shutdown immediately, and now the  
20 DHRS goes off when you go below the threshold power,  
21 has that been considered?

22 MR. ZWEIBAUM: Yeah, so at that stage the  
23 operations of the DHRS, and turning on, and turning  
24 off will be a function of the power history of the  
25 reactor, and action related fission products, and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 decay heat levels that result from that as opposed to  
2 a straight power level. So, it's more of a power  
3 history dependency at that stage compared to just a  
4 straight on, off depending on power.

5 MEMBER BROWN: Well, you've got to have  
6 some instruments that determine what that is, and then  
7 make sure it stays on if you come back down, and stays  
8 on for a while before you turn it off, wouldn't that  
9 be correct?

10 MR. ZWEIBAUM: Yes. We'll have neutron  
11 flux detectors, and a number of other metrics that  
12 will allow us to determine that.

13 MEMBER BROWN: Well, it's the operation,  
14 the time at power that builds up the decay heat that  
15 you've got to deal with. If you suddenly go down, if  
16 you shutdown, now all of a sudden you've got to deal  
17 with that. And that's higher than what you have from  
18 sitting around for a while as you're going up and go  
19 over the threshold. There's some complications in  
20 there, and something's got to measure it and turn it  
21 on and off. That's all I'm saying.

22 I haven't completed reviewing all of  
23 Chapter 7 yet, so I focused kind of on the decay heat  
24 removal system part of it when we were doing this  
25 review.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MR. ZWEIBAUM: With --

2 MEMBER BROWN: And with the activation --  
3 I'm sorry, I interrupted you, sorry.

4 MR. ZWEIBAUM: We'll clarify all of this  
5 with the operating license application. There will be  
6 a number of different scenarios that we'll have to  
7 consider for this turning on, and turning off that  
8 will be more detailed at that stage. Those points are  
9 all valid.

10 MEMBER BROWN: Will that also be --  
11 because very clearly it looks like the RPS is utilized  
12 right now for the turning on, or the activation,  
13 presumably that would be for deactivation as well, and  
14 that would be the system that would have the  
15 information. It would seem the algorithm is necessary  
16 to determine what the power history is, and what you  
17 might need to do.

18 Nothing says you can't do that with the  
19 computer based systems, and the algorithms you can  
20 use. It's just got to be addressed, that's all.

21 MR. ZWEIBAUM: So, we did bring our  
22 director of instrumentation, and control to sort of  
23 clarify the message earlier about actuation using RPS.

24 DR. CILLIERS: Great, thank you very much,  
25 this is Anthonie Cilliers speaking, director of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 instrumentation, and controls. So, I think we'll  
2 discuss a little bit more during Chapter 7, but the  
3 RPS does have a function in the activation of the DHRS  
4 system. How it works, and it's described in Chapter  
5 7 a little bit more detailed, is that the DHRS  
6 activation, and deactivation is in full manual  
7 control.

8 So, the operators have full control of  
9 that system before that system is required for its  
10 safety function. In other words, before you have  
11 enough accumulated fission products in the system. At  
12 some point, and we will have to clarify that at the  
13 ORA stage, what that exact algorithm would look like.  
14 There will be a determination based on  
15 instrumentation, power level, flux level, temperature.

16 There will be a determination shortly  
17 before the DHRS becomes a safety function where RPS  
18 will activate the DHRS system, and remove manual  
19 controls from the operators. In other words, the  
20 operator will in that case, be unable to deactivate  
21 DHRS because of that. Once an event occurs after  
22 that, and we could include if an event occurs before  
23 DHRS is activated, or after DHRS is activated.

24 The RPS will monitor the system, and that  
25 is completely temperature based. When the temperature

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 has been reduced sufficiently, that there is no risk  
2 to any of the safety functions that the RPS is  
3 protecting, it will hand manual control back to the  
4 operators, so that the operators can choose to  
5 activate DHRS. Because that is not a safety function,  
6 the deactivation. I hope that clarifies it.

7 MEMBER BROWN: Yeah, I was the hand off,  
8 I read the part about the hand off in Chapter 7 so I  
9 would get a little bit of an understanding of how it  
10 interacted with the DHRS. But it wasn't as detailed  
11 as your explanation, so it's just we need to have that  
12 clarified when we get down to the operating level,  
13 operating license time of this, to how all that stuff  
14 interacts.

15 And you only show four channels, but you  
16 don't show any details on what the RPS looks like.  
17 But that's for later, you don't need to do that now,  
18 we just need to know you're going to do it. So, all  
19 right, thank you, that helped, I appreciate it. I  
20 didn't have anything else Dave.

21 CHAIR PETTI: Yeah, anybody else? If not,  
22 we'll turn to the staff.

23 MS. SIWY: Hi everyone, I hope you're all  
24 doing well today. My name is Alex Siwy, and I'm a  
25 technical reviewer in the division of advanced

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 reactors, and non-power production, and utilization  
2 facilities. I will be presenting a staff's review of  
3 Chapter 6 of the PSAR, engineered safety features. As  
4 you will notice, we start with section 6.2, because  
5 section 6.1 is a summary description, and there are no  
6 specific safety findings to be made.

7 Next slide, please. So, here's an outline  
8 of what I will be discussing. First, a very brief  
9 overview of PSAR section 6.2, functional containment.  
10 And I'll provide the regulatory basis, as well as the  
11 staff's technical evaluation, and technical  
12 conclusions, and wrap up with regulatory findings.

13 Next slide, please. So, I think Kairos did a good job  
14 of covering this already.

15 But just to reiterate, the Hermes design  
16 uses a functional containment to limit the potential  
17 release of radioactive material. The functional  
18 containment includes physical barriers, operating  
19 conditions, coolant design, and fuel form. So, for  
20 example the TRISO fuel retains radionuclides, and the  
21 layers of the TRISO particles form barriers. The  
22 pebble itself does provide some physical protection to  
23 the TRISO particles.

24 In addition, Hermes will be operated such  
25 that a large margin to the TRISO fuel design

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 temperature is expected. The FLiBe coolant is  
2 credited for retaining radionuclides that are not  
3 aerosolized, or evaporated during an event. And  
4 Hermes operates at a near atmospheric primary system  
5 pressure, which limits the driving force for  
6 radionuclides to reach the environment in the case of  
7 an event.

8 It's also important to note that PSAR  
9 section 6.2 describes the overall strategy of using a  
10 functional containment, but Chapter 13 is really where  
11 the implementation, and the demonstration of its  
12 acceptability is covered. Next slide, please. This  
13 slide covers regulatory basis. The 10 CFR regulations  
14 are very familiar by now. 50.34A, 50.35, and 50.40.  
15 The one unique aspect for the functional containment  
16 is the SECY paper, SECY 180096, functional containment  
17 performance criteria for non-light water reactors.

18 And it's approval in the associated staff  
19 requirements memorandum. Next slide, please. So, to  
20 give you an overview of how the staff conducted its  
21 review, the staff used relevant parts of NUREG-1537 as  
22 guidance, and in particular the sections included  
23 confinement, and containment, since the high level  
24 objectives are basically the same as a functional  
25 containment.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           We also ensured that the functional  
2           containment approach was consistent with the  
3           functional containment SECY. The one difference we  
4           noted was that the Hermes design uses a maximum  
5           hypothetical accident approach consistent with NUREG-  
6           1537, as opposed to the event category approach that  
7           most power reactors use. Finally, the NRC staff  
8           ensured that the staff was evaluating each individual  
9           component, and feature of the functional containment,  
10          as well as its integral performance.

11          And those PSAR sections, and the  
12          corresponding staff safety evaluations are in section  
13          4.2.1 reactor fuel, 4.3 reactor vessel system, 5.1  
14          primary heat transport system, and 13.1.1, and 13.2.1  
15          which cover the maximum hypothetical accident. Next  
16          slide, please. So, this slide just summarizes the  
17          conclusions that we made relative to NUREG-1537. PSAR  
18          Chapter 13 demonstrates the need for functional  
19          containment as an engineered safety feature because it  
20          is credited to mitigate the Chapter 13 events.

21          The preliminary MHA analysis in Chapter 13  
22          suggests that the radiological consequences are within  
23          the 10 CFR Part 100 criteria, but that's something  
24          that we will be confirming as part of the operating  
25          license application review. In addition, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 functional containment has no adverse impacts to  
2 normal operations, or safe shutdown, as it is an  
3 inherent part of the design.

4           There will be safety-related  
5 instrumentation to monitor the components of the  
6 functional containment. And finally, the technical  
7 specifications will confirm continued operability of  
8 the functional containment, and they are important to  
9 ensure that actual dose consequences will remain  
10 bounded by the MHA analysis. Next slide.

11           CHAIR PETTI: Just a question back on the  
12 instrumentation, you're thinking of like level of  
13 salt, or?

14           MS. SIWY: Yeah, level in the salt,  
15 temperature indications for fuel, things of that  
16 nature.

17           CHAIR PETTI: You can't measure the  
18 temperature of the fuel easily, but salt.

19           MS. SIWY: Yeah, yes. And to summarize  
20 the regulatory findings, the NRC staff finds that the  
21 preliminary design information is consistent with the  
22 applicable criteria in NUREG-1537. The functional  
23 containment approach is consistent with the functional  
24 containment SECY, and staff requirements memorandum,  
25 and the staff concludes that the information in Hermes

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 PSAR section 6.2 is sufficient for the issuance of a  
2 construction permit in accordance with 10 CFR 50.35,  
3 and 50.40.

4 And further information can reasonably be  
5 left for the operating license application.

6 CHAIR PETTI: Just a question, were there  
7 any scoping calculations done of the DHRS, like other  
8 parts of the plant we heard yesterday, that look at  
9 heat removal, and things?

10 MS. SIWY: That was included as part of  
11 some --

12 MR. SCHMIDT: Yeah, this is Jeff Schmidt  
13 of record systems, so you're going to see that in  
14 Chapter 13. Yeah, it was modeled as part of the  
15 MELCOR.

16 CHAIR PETTI: Okay, great, thank you.  
17 Questions members?

18 MEMBER KIRCHNER: Dave, this is Walt.

19 CHAIR PETTI: Yeah.

20 MEMBER KIRCHNER: Functional containment  
21 is not new, I mean the whole TRISO fuel program is --  
22 that's well understood. My question to the staff is  
23 what are you looking for in terms of the credit that's  
24 being taken for the salt retaining radio nuclides in  
25 terms of evaporation, release, unmitigated air

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 interaction with the coolant, etcetera. Is that part  
2 of the Appendix A set of programs that have been  
3 identified?

4 MS. SIWY: So, that's not specifically my  
5 area, I apologize. But I do note that -- or it's my  
6 understanding that there is no credit taken for  
7 anything that aerosolizes, or evaporates out of the  
8 FLiBe, it's only what remains within the FLiBe, I  
9 don't know if that answers your question.

10 MEMBER KIRCHNER: Yeah, that's exactly the  
11 question. So, is there an understanding of the  
12 chemistry of the FLiBe, is that sufficient to lead you  
13 to the conclusion that even if you have a spill, or  
14 the primary system is breached, and it's open to air,  
15 that the FLiBe will retain the radionuclides there in  
16 solution, and carried by the salt?

17 CHAIR PETTI: So, Walt, just if you  
18 recall, in our letter, we reviewed this in the source  
19 term topical, and we actually made a plan about having  
20 some data to back up the assumptions, and the staff  
21 accepted that. And I believe, then, it is in Appendix  
22 A.

23 MEMBER KIRCHNER: Yeah, that was my  
24 understanding Dave, I just wanted to clarify.

25 CHAIR PETTI: Yeah, it's a little

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 different wording, but is that -- it's in Appendix A,  
2 right?

3 MR. SCHMIDT: That's what we were just  
4 discussing. I'm not sure it's in Appendix A, but it's  
5 part of the mechanistic --

6 CHAIR PETTI: So, something about  
7 justification of thermodynamic data, and that's what  
8 I interpreted that to mean. It's in the R&D, I think.

9 MR. SCHMIDT: All right, so I guess the  
10 answer is yes.

11 CHAIR PETTI: Okay, thank you. Okay, so  
12 members, if you'll indulge me, first of all, the  
13 letter was written by Jose, but he's not here, so I  
14 told him I would fill in for him. I don't think the  
15 letter will take that long, we're eight minutes from  
16 -- we have 6.3? Sorry.

17 MEMBER KIRCHNER: Don't we have regulatory  
18 findings on the DHRS?

19 MS. SIWY: We can just keep going.

20 CHAIR PETTI: No, keep going, sorry, keep  
21 going. Okay, I think we can hop a couple slides ahead  
22 Ed. I think we're missing 6.3, it should be -- okay,  
23 there we go. So, I'll also be presenting the staff's  
24 review of the decay heat removal system. Next slide,  
25 please. Same agenda as last time, except decay heat

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 removal system. Next slide. So, a very brief  
2 overview of PSAR section 6.3.

3 Again, the DHRS is a safety grade system  
4 that's credited to remove decay heat when normal heat  
5 removal is not available, such that reactor vessel  
6 temperature will be maintained within the acceptable  
7 limits for 316 stainless steel. The DHRS is designed  
8 to provide passive cooling for up to seven days  
9 following a postulated event without electrical power,  
10 or operator action.

11 Again, the main components are the water  
12 storage tanks, the steam separators, and the annular  
13 thermosiphons. And the mechanism by which it works is  
14 that the heat from the reactor vessel is transferred  
15 via radiation, and convection to water in the annular  
16 thermosiphons where the water boils off. And we  
17 discussed in great length how DHRS is placed in  
18 service of the threshold power, where the passive  
19 radiative cooling alone is not adequate. Next slide,  
20 please.

21 MEMBER HALNON: Alex, on the passive, the  
22 failed in position for the valve is very important,  
23 will you be looking at power supplies, if it's a DC  
24 valve, what a potential short could do to change  
25 state, and that sort of thing? I assume that's not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the detail that we have now. But that failure  
2 mechanism is something we had to deal with in light  
3 water reactors, the smart short issue, those types of  
4 things. Those are all part of the review criteria?

5 MS. SIWY: Yes, we're looking very heavily  
6 at various failure modes.

7 MEMBER HALNON: Okay, thank you.

8 MS. SIWY: Thank you. So, the regulatory  
9 basis for the DHRS is the same 10 CFR Part 50  
10 regulations, and several NRC staff approved PDC from  
11 the Paris power topical report for PDC. They're  
12 listed on the slide, I won't go through them. Next  
13 slide, please. So, to give you a sense of the review  
14 process for this section, we used relevant parts of  
15 NUREG-1537 as guidance.

16 In this case there's nothing quite like a  
17 passive DHRS in there, so we looked at the emergency  
18 core cooling system, and secondary cooling, and kind  
19 of took the bits, and pieces that were applicable from  
20 those systems, as well as the overall guidance on  
21 engineered safety features. We also reviewed the DHRS  
22 against the PDCs that were listed on the previous  
23 slide.

24 As I mentioned just a little bit ago, the  
25 staff reviewed the preliminary system design to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 identify potential system failure modes. We also  
2 audited the Kairos detailed system description, and  
3 the DHRS heat performance calculation that determine  
4 the level of system performance needed to maintain the  
5 vessel temperature below the limit for 316 stainless  
6 steel.

7 And, finally, we performed independent  
8 calculations to ensure that the water tank volumes  
9 would be sufficient for seven days' worth of cooling.  
10 Next slide, please. A couple of aspects of this  
11 review that I wanted to particularly highlight for the  
12 Hermes design is again going back to our focus on  
13 identifying important phenomena and potential failure  
14 modes.

15 We ensured that the Kairos testing plans  
16 address those types of things, and examples include  
17 potential flow, and heat removal, and stability issues  
18 during the transition, and in service phases.  
19 Potential dynamic loads on structure, and components  
20 due to transition phase thermal shock, and in service  
21 evaporative boiling, and the potential for corrosion,  
22 and fouling within the evaporator tube.

23 The other really unique aspect of this  
24 review is that the DHRS needs to be able to both  
25 accommodate the highest heat loads for maintaining

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 vessel integrity, as well as the lowest in service  
2 loads to prevent freezing per a requirement in Chapter  
3 13 of the PSAR. And this is something that we have  
4 noted, we will definitely be looking at how the design  
5 meets these competing design requirements as part of  
6 the OL application review.

7 Next slide, please. And to summarize the  
8 evaluation against the principle design criteria, PDC  
9 1 requires safety significant SSCs to be designed,  
10 fabricated, erected, and tested to appropriate quality  
11 standards, and identification of generally recognized  
12 codes, and standards used. As was mentioned, the DHRS  
13 will be designed to several codes, and standards,  
14 ASME, ASCE, ACI standards.

15 The component design to these standards is  
16 evaluated in Chapters 3 and 4 of the staff safety  
17 evaluation, and the quality assurance program is  
18 evaluated in Chapter 12 of the safety evaluation. PDC  
19 2 requires protection against natural phenomena. And  
20 the way this is addressed with DHRS is that it's  
21 located in the safety-related portion of the reactor  
22 building, except for the steam vent lines, and the  
23 failure of the steam vent lines would not impede the  
24 safety function of the system.

25 And the staff evaluation of seismic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 methodologies are in SCR sections 3.4 and 3.5. Next  
2 slide, please. PDC 3 requires protection against  
3 fires, and the DHRS will be designed with low  
4 combustible materials and physical separation. The  
5 overall fire protection program is evaluated in SER  
6 section 9.4.

7 PDC 4 requires protection against  
8 environmental and dynamic effects, and the DHRS will  
9 be designed to withstand normal operating conditions,  
10 and to protect against dynamic environmental effects.

11 Finally, PDCs 10, 34, and 35 address  
12 adequate heat removal under normal operation and  
13 postulated events. And as was noted, the DHRS is  
14 designed with redundancy to protect against single  
15 failures, both with the redundant train, and there's  
16 actually a redundant thimble in each train. And  
17 preliminary calculations within the PSAR suggest that  
18 the DHRS does remove heat adequately.

19 Finally PDCs 36 and 37 address inspection,  
20 and functional testing of the DHRS. The DHRS is  
21 designed for online monitoring, and access to perform  
22 inspections, and it will be functionally tested during  
23 the startup phase.

24 Next slide, please. So, here are the  
25 conclusions relative to NUREG-1537. PSAR Chapter 13

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 demonstrates the need for DHRS as an engineered safety  
2 feature through it being credited to mitigate events.  
3 The preliminary PSAR analysis suggests that the DHRS  
4 does remove adequate amounts of decay heat, and that  
5 the radiological consequences are within the 10 CFR  
6 Part 100 criteria. And again, staff will confirm this  
7 as part of the operating license application review.

8           The DHRS has no adverse impacts to normal  
9 operations, or safe shutdown. In fact is part of  
10 normal operation above the threshold power level. The  
11 technical specifications, as well as normal operation  
12 itself will help to confirm its continued operability  
13 and availability when needed. And one thing that I  
14 really want to drive home is that the DHR test program  
15 will be key to finalizing the DHRS design.

16           Next slide, please. And to summarize the  
17 regulatory findings, the NRC staff concludes that the  
18 preliminary design is consistent with the associated  
19 PDCs, and acceptance criteria in NUREG-1537. And the  
20 NRC staff finds that the information in Hermes PSAR  
21 Section 6.3 is sufficient for the issuance of a  
22 construction permit in accordance with 10 CFR 50.35  
23 and 50.40, and that further information can reasonably  
24 be left for the operating license application.

25           Are there any other questions?



1           MEMBER REMPE: So, I have a question about  
2 the exchange before you started this part of your  
3 presentation. When Walt asked the question, and the  
4 response was well that was actually something we  
5 brought up in the topical report on the source term,  
6 and we had a recommendation, was that accepted -- that  
7 isn't in Appendix A.

8           How does that get communicated with the  
9 applicant that not only what's in Appendix A, but also  
10 that isn't the only topical report we had  
11 recommendations on where the staff agreed that yes,  
12 something else is needed as I recall. And I'm just  
13 wondering is all of that going to be tracked, and how  
14 easy it for everybody to review it?

15           MS. SIWY: So, as part of the staff's  
16 review of each of the sections that utilized the  
17 methodology, the staff should be checking the  
18 limitations, and conditions, and recommendations  
19 associated with the topical report safety evaluation.

20           MEMBER REMPE: Because, again, hopefully  
21 ACRS will also remember, and the applicant is well  
22 aware that everyone -- there's no confusion.

23           CHAIR PETTI: But everyone mentions the  
24 R&D items, one of the R&D items is justification of  
25 the thermodynamic data, etcetera, etcetera. That's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the response to our concern on the source term.

2 MEMBER REMPE: Okay, because the response  
3 back, the actual recommendation, and unfortunately my  
4 computer is doing weird things, but it was about the  
5 vaporization, and all that. And --

6 CHAIR PETTI: Yes, we asked that they  
7 have, that they get data behind that model.

8 MEMBER REMPE: And that'll be clear to the  
9 applicant and the staff that we're talking about that.  
10 I'm just wondering if it needs some expansion. But if  
11 they checked what's in the topical report reviews,  
12 that's good. But having that appear in Chapter 1, I  
13 kind of sensed there was some disconnect at first,  
14 until Dave mentioned it, and that's why I'm asking the  
15 question. I want to make sure that there won't be a  
16 disconnect two or three years down the road.

17 MR. BEASLEY: Yeah, this is Ben Beasley  
18 with the staff. So, to just re-emphasize what Alex  
19 said, so when we reviewed the PSAR, we reviewed that  
20 in conjunction with the topical reports, and the  
21 conditions that were in there, and we'll do the same  
22 with the operating license application.

23 MEMBER REMPE: The conditions plus the  
24 ACRS response to our letters that you agreed with what  
25 we suggested.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. BEASLEY: Right, well, so if we agreed  
2 with your suggestion, that should have been included  
3 in our safety evaluation, so that will be in the dash  
4 A version of the topical report.

5 MEMBER REMPE: Good, okay, just wanted to  
6 make sure, thank you.

7 MR. BEASLEY: Yes.

8 CHAIR PETTI: Other questions, members?

9 MEMBER KIRCHNER: Dave, may I make an  
10 observation?

11 CHAIR PETTI: Sure.

12 MEMBER KIRCHNER: And it ties back to the  
13 earlier discussions about the core, the reactor  
14 design. I would just suggest this to both the  
15 applicant, and the staff. It would not be that hard  
16 to make a bounding calculation on the thermal  
17 performance of this reactor system with the decay heat  
18 removal system functioning to see what the core center  
19 line peak temperatures are in the TRISO particles in  
20 a decay heat cool down situation without the fluidic  
21 valve functioning.

22 In other words, just assume you have a  
23 static system, ignore convective heat transfer so to  
24 speak, and in the down comer, natural circulation, and  
25 just calculate what the core peak center line

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 temperatures are for the TRISO particles. I would  
2 hazard a guess that these power levels, since you  
3 probably will not get to equilibrium with this core,  
4 and this is speculative on my part, that the decay  
5 heat removal system functioning will keep the core  
6 below the threshold for significant damage in the  
7 TRISO particles.

8 But it would be interesting to see,  
9 because then if you have this calculation as a  
10 function of power, or more correctly, decay heat load,  
11 then you could set a bar for startup testing after the  
12 operating license in terms of proving out the fluidic  
13 diode in particular, and its function. Just an  
14 observation, thank you Dave. And it's not that hard  
15 a calculation to do.

16 You make some conservative assumptions  
17 about the radial conduction in the pebble bed, the  
18 reflector in the down comer, and from the vessel to  
19 the decay heat removal system. My sense is that with  
20 the powers that you'll see, and the radius of this  
21 vessel, that you would keep the peak temperatures of  
22 the TRISO particles well below their limits.

23 CHAIR PETTI: That's my sense, too, having  
24 seen many of these sorts of calculations in the past.

25 Okay, so now we're done. Sorry. So, I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 know we're beyond our time, but it would be nice to be  
2 able to finish this memo, and then break for lunch, I  
3 think. We'll be ahead of schedule. We'll only have  
4 one chapter after lunch, which will be, I think, good.

5 (Whereupon, the above-entitled matter went  
6 off the record at 12:07 p.m. and resumed at 1:14 p.m.)

7 CHAIR PETTI: Are you ready, Kairos?

8 MR. ZWEIBAUM: Yes. Ready and unmuted  
9 now.

10 CHAIR PETTI: Okay. Whenever you want to  
11 start.

12 MR. ZWEIBAUM: Okay. So I'll kick us off  
13 on this chapter. This is Nico Zweibaum, director of  
14 salt systems design. This is Chapter 9 on auxiliary  
15 systems. And there is quite a variety of those  
16 systems, so you'll see a corresponding variety of  
17 presenters throughout.

18 So as I said, I'll kick us off. Next  
19 slide, please. So, as an overview for reactor  
20 auxiliary systems, the reactor coolant auxiliary  
21 systems are a collection of systems that provide  
22 support for the functionality and performance of  
23 FLiBe, our reactor coolant, to remove fission  
24 products, activation products, and other chemical  
25 impurities and particulates from the reactor coolant

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 to maintain the cover gas atmosphere, both in pressure  
2 and composition in the head space above the core, to  
3 provide removal and storage of tritium, to control  
4 inventory, fueling and draining processes for systems  
5 that contain reactor coolant, including transfer of  
6 coolants into the reactor at the beginning of life,  
7 and to provide active and passive thermal managements  
8 to reactor system components.

9 So these various functions are implemented  
10 into the following reactor coolant auxiliary systems.  
11 We have a chemistry control system, inert gas system,  
12 tritium management system, inventory management  
13 system, that's the salt inventory, and reactor thermal  
14 management system.

15 Of note, and this will be a theme  
16 throughout this presentation, but those systems are  
17 not accredited with performing any safety-related  
18 functions.

19 So, starting with the chemistry control  
20 system, or CCS. Again, not created with performing  
21 any safety-related functions, but what the system does  
22 is it monitors primary coolant chemistry for  
23 compliance with FLiBe specifications. The system  
24 extract coolant samples for an offline analysis for  
25 the FLiBe chemistry.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           As far as design basis, due to the  
2 proximity of the CCS to the reactor vessel, it's  
3 designed so that seismic induced failure does not  
4 impact the reactor vessel system, it's consistent with  
5 PDC 2. Again, due to the proximity with the reactor  
6 vessel, that system is designed so that adverse  
7 effects of postulated failures do not impact the  
8 reactor vessel system, consistent with PDC 4.

9           The CCS will monitor the reactor coolant  
10 purity with offline sampling analysis to determine if  
11 the reactor coolant is within specified design  
12 minutes, consistent with PDC 70. And consistent with  
13 10 CFR 20.1406, the CCS is designed, to the extent  
14 practicable, to minimize contamination of the facility  
15 and the environment and facilitate eventual  
16 decommission.

17           MEMBER HALNON: So that last statement is  
18 pretty much a theme throughout this whole chapter.  
19 What does that look like?

20           I mean, are you going to have a process,  
21 some kind of board or some kind of hold point in your  
22 design review that sits back and asks the questions,  
23 the hard questions, whether or not this could be done  
24 a different way?

25           MR. ZWEIBAUM: Well, we'll clarify that by

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the operating license application.

2 MEMBER HALNON: I get that. So you  
3 haven't thought through it yet, is that the case?

4 The reason is, is that that, I mean, that  
5 statement is pretty prominent in this chapter, more  
6 than the others. And if you're just putting it to the  
7 OL, I get that.

8 MR. GARDNER: So this is Darrell Gardner  
9 from licensing. So, I mean, obviously it's a rule we  
10 have to satisfy. There is a number of ways to do  
11 that, depending on the system, terms and materials you  
12 use, maybe layout of things like that.

13 There is, you know, you could look back at  
14 some other design certification FSARs and look at sort  
15 of the programmatic descriptions that they have  
16 included about how they are going to do with the  
17 satisfying 1406. And I would suspect that we would do  
18 something similar.

19 MEMBER HALNON: Okay. Yes, that makes  
20 sense, Darrell. It seems like there would be a system  
21 approach to generically looking at a system and  
22 equipment and either using the same type of sets of  
23 questions or sets of challenges. Having a challenge,  
24 or something to that effect. It just seems like it's  
25 right for a process that might be consistent across

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 the board.

2 MR. GARDNER: Sure is.

3 MEMBER HALNON: All right, thanks.

4 MEMBER BALLINGER: Now this is Ron  
5 Ballinger. You know that the first five bullets are  
6 inconsistent with the last one, in the sense that this  
7 all argues for online monitoring. Now I'm wondering  
8 whether you've thought about that?

9 CHAIR PETTI: Oh, you mean the Part 20  
10 requirement could push you to online monitoring.

11 MEMBER BALLINGER: Well online monitoring  
12 period. Everything.

13 CHAIR PETTI: But that's more complex in  
14 taking a sample.

15 MEMBER BALLINGER: Okay.

16 CHAIR PETTI: In principle.

17 MEMBER BALLINGER: Remember, it's hot  
18 salt.

19 CHAIR PETTI: I know it's hot salt.

20 MEMBER BALLINGER: Okay.

21 CHAIR PETTI: I understand that. Yes.

22 MEMBER BALLINGER: And so, from the  
23 standpoint of physical safety and those kinds of  
24 things, not having to deal with hot salt, radioactive  
25 hot salt complication. Anyway. I mean, what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 parameters are you measuring?

2 MR. ZWEIBAUM: So the system's function is  
3 to make sure that the FLiBe is consistent with the  
4 specifications that were set forth in Topical Report  
5 05, which is our reactor coolant topical report.

6 MEMBER BALLINGER: Right. So, in theory,  
7 if you had a good calibration, all you need to do is  
8 measure the electrical, the chemical potential.

9 MR. ZWEIBAUM: Yes. So how we will do  
10 this will be specified, but this is essentially the  
11 function this is serving. Yes.

12 MEMBER BALLINGER: Okay. I just, you  
13 know, you've got an electrode in there already, right?

14 MR. ZWEIBAUM: Yes. There will be a  
15 number of systems that are part of this chemistry  
16 control system that will be interfacing with our  
17 inventory management system, as I'll mention later, so  
18 we're taking regular representative samples from the  
19 salt and comparing to the tech spec.

20 MEMBER BALLINGER: Okay, thanks. It's  
21 just that the BWR folks have gone, went from grab  
22 samples to online monitoring. And I think the BWR  
23 people did, and so did the Navy people.

24 MR. ZWEIBAUM: We'll clarify that further  
25 by OL. Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           So, separate system. The inert gas  
2 system. Again, that system is not credited with  
3 performing any safety-related function. Its role is  
4 to provide inert argon gas as a purge flow to system  
5 components during normal operation and maintenance.  
6 Part of that system will be removing impurities from  
7 the cover gas. The system will also provide reactor  
8 coolant motive pressure during filling and draining  
9 operations.

10           As far as the design basis, similar to the  
11 previous system, this IGS may be in proximity or  
12 connected to safety-related SSCs and across the  
13 seismic isolation mode. It's designed so that seismic  
14 induced failure will not impact safety-related SSCs  
15 from performing their safety function, consisted with  
16 PDC 2.

17           It is a low pressure system and precludes  
18 pipe whip. Nearby safety-related SSCs will not be  
19 affected by escaping inert argon gas consistent with  
20 PDC 4. That system will monitor radioactive levels in  
21 the gas to support the evaluation of the radioactive  
22 material releases that might occur as a result of a  
23 system or fuel failure, consistent with PDC 64. And  
24 then you got the same statement as before.

25           MEMBER HALNON: Yes. My favorite 20.1406.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Hey, my notes, when I reviewed this, said it also was  
2 meant to operate during postulated events. That's  
3 left off this slide. Was that intentional or is it a  
4 change, or what's the case there?

5 MR. ZWEIBAUM: It's not credited to  
6 performing safety function during postulated events.

7 MEMBER HALNON: Okay. But it is there and  
8 it does --

9 MR. ZWEIBAUM: Yes.

10 MEMBER HALNON: And it does measure, at  
11 least perform as a cover gas. And so there is no  
12 confinement activity, or not activity, but functions  
13 done by this gas then?

14 MR. ZWEIBAUM: No.

15 MEMBER HALNON: No retention and credits  
16 taken. Okay. But my sense is, is that it probably  
17 should be on this slide so we could have had that  
18 discussion. So go on. Thank you.

19 MR. ZWEIBAUM: Yes.

20 MR. DOLAN: All right. So, this is Kieran  
21 Dolan. I'm the responsible engineer for the tritium  
22 management system at Kairos. I'll be presenting this  
23 slide.

24 So tritium is produced by neutron  
25 irradiation of the FLiBe coolant. Tritium management

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 system, or TMS, captures some of that tritium to  
2 prevent environmental release. And it does that with  
3 the tritium capture subsystem integrated into the  
4 inert gas system. And another tritium capture  
5 subsystem integrated into the reactor building HVAC.

6 So the tritium management system is not  
7 credited with performing any safety functions. Like  
8 I said, it separates tritium from argon and the inert  
9 gas system, and from dry air and reactor building  
10 cells.

11 The tritium management system collects and  
12 temporarily stores tritium to facilitate final  
13 disposition in accordance with 10 CFR 71.51. Type A  
14 and Type B packing canisters are used to package and  
15 transport tritium, depending on activity levels.

16 Due to the potential proximity of the TMS  
17 to the reactor vessel, TMS is designed so that seismic  
18 induced failure does not impact the reactor vessel  
19 system, consistent with PDC 2. Tritium monitoring  
20 sensors are selected and provided over an approach  
21 range of tritium activities where the measurements are  
22 needed, consistent with PDC 13.

23 Tritium management system captures tritium  
24 at an overall efficiency to minimize tritium releases  
25 to the plant in accordance with PDC 60. And radiation

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 monitoring is provided in the TMS for the evaluation  
2 of tritium levels in TDS subsystems in support of  
3 evaluation of radioactive material releases that might  
4 occur as a result of system failure consistent with  
5 PDC 64.

6 And we also have the statement here  
7 consistent with 10 CFR 20.1406, the TMS is designed to  
8 the extent practicable to minimize contamination of  
9 the facility and environment and facilitate for  
10 decommission.

11 CHAIR PETTI: Question. What technology  
12 are you going to use to separate the tritium from the  
13 argon in the air?

14 MR. DOLAN: So described in PSAR, we're  
15 using the technology of metallic getters. So  
16 specifically, in the system design description for the  
17 tritium management system we were looking at zirconium  
18 based getters. So zirconium iron, trade name ST-198  
19 from SAES getters. That's the baseline as of the  
20 PSAR.

21 CHAIR PETTI: Thank you. Could you  
22 provide a little more detail on the used, the used  
23 beds, used capture beds being stored or put in  
24 unqualified storage canisters? I may not have phrased  
25 that correctly, but I remember a statement in there

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 saying that they were initially put into unqualified  
2 canisters. Not qualified for storage, for tritium.

3 MR. DOLAN: Right. So the canisters we're  
4 using are shipping canisters, not storage canisters.  
5 So they will be in the plant for a period of time.  
6 But I think the intent of our statement there was to  
7 clarify that the canisters are not for long-term  
8 storage, they're really just transportation canisters  
9 to get the used beds to a low-level waste disposal  
10 service.

11 CHAIR PETTI: Okay, thanks.

12 MEMBER BALLINGER: I have a question,  
13 which I'm sure the answer might be obvious, but with  
14 respect to the Handbook 69 values, or whatever the  
15 release limits are for tritium, how close are you to  
16 being able to dump this stuff up a stack?

17 MR. DENMAN: So this is Matthew Denman.  
18 The radiological source term responsible engineer.  
19 Can I just clarify, your question is on steady state  
20 effluents, right? How close are we to being able to  
21 not hold up any tritium and release the tritium out  
22 the effluents stack?

23 MEMBER BALLINGER: Yes.

24 MR. DENMAN: In our Chapter 11 analysis,  
25 that's effectively what we did. We did not credit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 tritium hold up in the tritium management system. The  
2 entire source, or generation rate for the tritium was  
3 released through the effluent stack as a band founding  
4 calculation. And we were still within the Part 20  
5 limits.

6 MEMBER BALLINGER: Wow, okay. Thanks.

7 CHAIR PETTI: Matthew, since we're there,  
8 I thought we'd probably hit this in 11. You modeled  
9 it as HT, and left the dose calculation converted to  
10 HTL?

11 MR. DENMAN: So we assumed that as soon as  
12 it permeated through the heat rejection radiator it  
13 would immediately oxidize and then transport as HTL.

14 CHAIR PETTI: Okay. And so, I can  
15 understand meeting sort of the offsite dose limit, but  
16 eventually that tritium gets into drinking water. Are  
17 you saying that you meet the drinking water standard  
18 as well?

19 MR. DENMAN: The drinking, so we evaluated  
20 against the Part 20 dose limits. We did not evaluate  
21 against any other regulatory limits.

22 CHAIR PETTI: Yeah. Well, this is always  
23 an issue with tritium, is that that stuff eventually  
24 gets into the groundwater and drinking water. And  
25 that limit is really, really tight. So it might be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1       worth looking at that.

2                   MR. DENMAN:  Yes.

3                   CHAIR PETTI:  Because it's an EPA limit  
4       of, what is it, Part 40 I think.

5                   MR. DENMAN:  Thank you for your comment.

6                   CHAIR PETTI:  20,000 picocuries.  Yes.

7                   MR. DENMAN:  Understand.  And thank you  
8       for your comment.

9                   MR. ZWEIBAUM:  Okay, this is Nico Zweibaum  
10       again, director of salt systems design talking about  
11       the inventory management system.  Again, to clarify,  
12       this is salt inventory.

13                   That system, IMS, is not credited with  
14       performing any safety-related function.  What its  
15       function is, is to maintain primary coolant level in  
16       the reactor vessel during normal operations.  It also  
17       fills and drains the reactor vessel and the primary  
18       heat transport system of salts during startup and  
19       shutdown operations.  And it maintains primary coolant  
20       purity by replacing circulating salt with new salt.

21                   Due to the proximity of the IMS to the  
22       reactor vessel, it's designed so that seismic induced  
23       failure does not impact the reactor vessel system  
24       consistent with PDC 2.  Due to its proximity to the  
25       reactor vessel, it's designed so that adverse effects

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 of postulated failures do not impact the reactor  
2 vessel system, consistent with PDC 4.

3 That system includes design features to  
4 limit the loss of reactor vessel coolant inventory in  
5 the event of breaks in the system, consistent with PDC  
6 33. This system may be used to remove and replace a  
7 sufficient amount of reactor coolants to restore  
8 performance to the FLiBe specific, consistent with PDC  
9 70.

10 And this is where the interface with the  
11 chemistry control system that I mentioned earlier  
12 comes into play. And again, statement around  
13 minimizing contamination of facility and the  
14 environment and facilitate eventual decommissioning.

15 CHAIR PETTI: So is this a batch system or  
16 is it sort of always operating as an extra tank of  
17 FLiBe and somehow automatically you would add as much  
18 as you need?

19 MR. ZWEIBAUM: Yes. So the way that the  
20 system architecture is setup, and you can see that in  
21 the PSAR there is figure, but there will be a pump  
22 mechanism to constantly add salt from the IMS tank to  
23 the reactor vessel, and an overflow line from the  
24 reactor vessel to return exiting FLiBe from the  
25 reactor vessel to the IMS.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR PETTI: So then Ron's earlier  
2 question on doing something, not batching chemistry  
3 system, you've got a lot of plumbing here, you could  
4 do, you could look at that I guess?

5 MR. ZWEIBAUM: Yes.

6 CHAIR PETTI: Okay.

7 MR. ZWEIBAUM: We could.

8 CHAIR PETTI: Thanks.

9 MEMBER HALNON: The system talked about  
10 the three different tanks. RV coolant level, fill and  
11 drain and PHTS fill and drain. And then went on to  
12 say that any one tank could do all three functions.

13 Is it sized for all three functions or is  
14 it just that it could be cross-connected, or, I mean,  
15 piped into the system as necessary? How does that  
16 work?

17 MR. ZWEIBAUM: So as mentioned in the  
18 PSAR, the three tanks that were shown in there are  
19 really intended to clarify three different functions.  
20 Whether these functions are going to be served by a  
21 single, or two or three separate physical tanks, will  
22 be clarified with the operating license --

23 CHAIR PETTI: Okay. Yes. That wasn't  
24 clear in my reading. Thank you.

25 MR. ZWEIBAUM: Okay. The reactor thermal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 management system. That system is not credited with  
2 performing any safety-related functions. Nearby  
3 safety-related SSCs are protected from RTMS failure in  
4 the event of an earthquake consistent with PDC 2.

5 The reactor thermal management system  
6 using water cooling to transfer heat from SSCs to the  
7 ultimate heat sink during normal operation and  
8 maintains the operational temperature limits of  
9 concrete structures during normal operations  
10 consistent with PDC 44. The system is designed to  
11 permit periodic, appropriate inspections and testing  
12 to ensure integrity and capability to cool SSCs and to  
13 ensure adequate interface with other systems,  
14 supporting heat transfer to the ultimate heat sink,  
15 consistent with PDC 45 and 46.

16 So this was on cooling, but on the heating  
17 front, that system is also designed to preheat the  
18 reactor vessel, and to ensure FLiBe in the vessel is  
19 maintained above the minimum operating temperature  
20 consistent with PDC 71. And the system is designed to  
21 the extent practical to minimize contamination of its  
22 sodium environment and facilitate eventual  
23 decommissioning.

24 CHAIR PETTI: So let me just, I want to be  
25 clear, because earlier when we read our memo in on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Chapter 6, Member March-Leuba described it as a  
2 reactor auxiliary heating system. But it really is  
3 the reactor thermal management system that's there to  
4 keep the FLiBe above melting?

5 MR. ZWEIBAUM: Yes, that's --

6 CHAIR PETTI: Okay.

7 MR. ZWEIBAUM: Yes.

8 CHAIR PETTI: So I will change his words  
9 to be consistent. Thank you.

10 MEMBER HALNON: This system, does it  
11 directly support safety-related systems? I mean, the  
12 concrete and other pumps may be or other equipment?

13 MR. ZWEIBAUM: Sorry, could you repeat the  
14 question please?

15 MEMBER HALNON: Yes. I'm sorry, I was  
16 unclear. Does this system directly support safety-  
17 related equipment? Is it a support system?

18 MR. ZWEIBAUM: Can you clarify what you  
19 mean by directly support? Physically or functionally?

20 MEMBER HALNON: Well, I don't know what  
21 the difference between those are. Not physically from  
22 a structural standpoint. Certainly does it remove,  
23 does it provide essential cooling to any safety-  
24 related systems or structures --

25 MR. ZWEIBAUM: No.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: -- or does the concrete  
2 that it's keeping at temperature, that concrete  
3 structure, is it a safety-related structure?

4 MR. ZWEIBAUM: No. The cooling that's  
5 provided here is non safety-related.

6 MEMBER HALNON: Okay. So no safety-  
7 related equipment depends on this system to operate?

8 MR. ZWEIBAUM: Correct.

9 MEMBER HALNON: Okay. So therefore the --  
10 and I guess the point of my question was, would there  
11 be any future tech specs required for a support  
12 system? It sounds like the answer to that is no.

13 MR. ZWEIBAUM: Not expected at the moment.

14 MEMBER HALNON: Okay. Thanks.

15 MR. LINGENFELTER: Hi, everyone. I'm  
16 Andrew Lingenfelter. Lead engineer of engineer and  
17 integration. I'll be walking us through several of  
18 these auxiliary system sections.

19 The first one I'll be talking about here  
20 is reactor building heating, ventilation and air  
21 condition system. And first and foremost, the reactor  
22 building HVAC is not credited to perform and safety-  
23 related functions.

24 Also, the system provides, the function of  
25 the system is providing independent environment

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 control to the reactor building. Um, this system is  
2 not, or excuse me, is designed to ensure occupational  
3 dose does not exceed 10 CFR 20 limits. And consistent  
4 with 10 CFR 20.1406, similar to some of the other  
5 systems we've talked through, reactor building HVAC is  
6 designed to the extent practical to minimize  
7 contamination of the facility and the environment, and  
8 to facilitate eventual decommissioning.

9 Some of the -- was somebody providing a  
10 comment there? Okay.

11 Some of the design basis here. The system  
12 does not adversely affect safety-related SSCs located  
13 nearby in accordance with PDC 2.

14 In accordance with PDC 60, the system is  
15 designed to control the release of radioactive  
16 materials and gaseous effluents during normal  
17 operation.

18 And in accordance with PDC 64, the system  
19 is designed to provide for monitoring the reactor  
20 building effluent discharge bypass for radioactivity  
21 that may be released during operation.

22 MEMBER HALNON: But during postulated  
23 events is it isolated and not released into the  
24 environment?

25 MR. LINGENFELTER: The reactor building

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 HVAC system does not perform a safety-related function  
2 in that regard. Whether that's performed for other  
3 means, we'll be working on that towards the operating  
4 license.

5 MEMBER HALNON: Okay. I was just kind of  
6 reacting to your last bullet there. That may be  
7 released during normal operation. Of course the next  
8 question is, what about, may be released during a  
9 postulated event?

10 MR. LINGENFELTER: Is your question, will  
11 there be releases during postulated events through  
12 that system?

13 MEMBER HALNON: No. Will there be  
14 releases through the HVAC system or the HVAC?

15 MR. DENMAN: So, this is Matthew Denman,  
16 the responsible engineer for radiological source term.  
17 As part of the Chapter 13 analysis we have to exam a  
18 number of postulated events. One of those postulated  
19 events is released of radioactive material from  
20 subsystems or components at any radioactive material  
21 that could be stored within the HVAC system would be  
22 considered in that postulated event.

23 MEMBER HALNON: Okay. So it's, as you get  
24 through all your event analysis, this will pan out one  
25 way or the other? Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MR. DENMAN: Correct.

2 CHAIR PETTI: I have a question. Is this  
3 also the system -- is there going to be something to  
4 monitor beryllium in the facility?

5 MR. LINGENFELTER: There will be.

6 CHAIR PETTI: It will be part of this  
7 system?

8 MR. LINGENFELTER: Those are the details  
9 that we will be working towards for the OLA.

10 CHAIR PETTI: Both the monitoring and if  
11 one needs to trap beryllium particulates. I'm just  
12 worried, you know, if you know what happened at MSRE,  
13 you got dendritic beryllium fluoride at cold spots, so  
14 valve stems like off the pump, and that, it was  
15 dendritic so they went airborne pretty easily. So  
16 we'll have to monitor that because, you know, the  
17 beryllium limits for workers are really tight.

18 MR. LINGENFELTER: Got it. Thank you for  
19 your comment.

20 MR. ZWEIBAUM: Okay. Nico Zweibaum,  
21 director of salt systems design. I'm going to walk  
22 you through our pebble handling and storage system.  
23 This system is responsible for handling of fuel of  
24 Hermes from initial onsite received through in process  
25 circulation until final onsite storage.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           Because of the relative complexity of this  
2 system, we wanted to break it down into major  
3 components here that we'll be walking through. We  
4 have a pebble extraction machine. That's a single  
5 screw mechanism that removes pebbles from the molten  
6 salts in the core.

7           We have a pebble inspection subsection  
8 that performs flaw detection and burn-up measurements  
9 of the removed pebbles. A processing subsystem that  
10 will sort pebbles into appropriate buffer storage  
11 channels based on pebble type. An insertion mechanism  
12 that's a separate wheel feeder mechanism that inserts  
13 pebbles into the reactor through an in-vessel  
14 insertion line.

15           We have storage canisters. Each canister  
16 stores about 2,000 fuel pebbles in a non-critical  
17 configuration. We have a storage cooling area that's  
18 in-building storage for spent fuel canisters that's  
19 capable of passive cooling during loss of power and  
20 other postulated events. And we have a new pebble  
21 introduction subsection that will store fresh fuel and  
22 prepare fuel for circulation with a high temperature  
23 bake out prior to fuel introduction into the salts.

24           Next slide. So this kind of illustrates  
25 with the relevant connections. The architecture of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the system. I won't go into all details of what's on  
2 this slide, but as far as the systems I described  
3 earlier, you see your reactor vessel, simplified  
4 sketch in the bottom right.

5 Sitting at the top of that in the center  
6 is the pebble extraction machine. Pebbles that get  
7 off of that go through an off-head conveyance line to  
8 the buffer storage system where there is inspection  
9 processing and sorting into different bins.

10 You can see that if pebbles are sent to  
11 storage, we have an active storage canister that's  
12 connected to that buffer storage tank. And if pebbles  
13 are meant to be reinserted into the reactor, there is  
14 an assertion machine that also connects, it's shown  
15 here at the top, connects to the buffer storage tank  
16 to push pebbles back through a pebble insertion line  
17 that is shown on the very right of the diagram here.

18 I guess of note, and hopefully by now  
19 people are familiar with this aspect of our design,  
20 but the fuel is buoyant in the salt, which is why we  
21 have mechanisms to push the fuel all the way down to  
22 the bottom of the reactor. And then the fuel  
23 naturally moves up as it gets extracted from the top  
24 in the pebble extraction machine. And then on the  
25 left of this whole diagram you see our fuel cell that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 includes the spent fuel storage pool and spent fuel  
2 storage air-cooled area.

3 On the design basis for the system, the  
4 storage bay, the pool, and the support restraint  
5 structures in the pool are designed as seismic  
6 category SDC-3, to ensure the geometry is maintained  
7 in the event of an earthquake consistent with PDC 2.  
8 By design, this system limits grinding of pebbles and  
9 accumulation of graphite dust to minimize the  
10 potential of fire and explosion consistent with PDC 3.

11 The canister design considers  
12 environmental conditions, such as pressure  
13 accumulation of radionuclides and thermal loads. The  
14 interior of the canister accounts for radiolysis  
15 products. The system design accounts for complete  
16 submergence and internal flooding of the storage  
17 canisters in water as part of our criticality  
18 analysis, consistent with PDC 4.

19 There is an anti-siphon feature on the  
20 pebble insertion line that limits inventory loss to  
21 the primary salt pump elevation. And the pebble  
22 extraction machine is above the coolant free surface,  
23 consistent with PDC 33 to avoid loss of coolant from  
24 the reactor vessel.

25 The TRISO particle confines radioactive

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 material rather than the PHSS. And pebble loads do  
2 not introduce incremental particle failures thereby  
3 ensuring that PHSS does not act to confine or contain  
4 radioactivity consistent with PDC 61. And back to the  
5 functional containment discussion that we had earlier.

6 The design prevents criticality by  
7 controlling pebble removal rate. The system design  
8 precludes moisture intrusion and handling equipment  
9 maintains geometry of the interlocks consistent with  
10 PDC 62.

11 And finally, the inspection and sorting  
12 function ensures that damaged pebbles are removed from  
13 use consistent with PDC 63.

14 CHAIR PETTI: So I had a question here.  
15 I understand graphite pebbles and fuel pebbles, and  
16 burn-up is protected using cesium measurement of the  
17 pebbles. It's the way the Germans did it. I think  
18 the Chinese are doing it. But now that you have  
19 natural uranium pebbles in there, is the cesium signal  
20 from the fission of the small amount of u-235 going to  
21 be enough that you can differentiate between a pure  
22 graphite pebble and a uranium pebble? Natural uranium  
23 pebble.

24 MR. WHATCOTT: Hi, this is Gareth  
25 Whatcott. I'm the responsible engineer for the pebble

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 handling system. You're correct that the cesium  
2 signature early on may be challenging to identify in  
3 uranium pebbles. The method to differentiate between  
4 the natural uranium and fuel pebbles will be detailed  
5 in the OLA.

6 MEMBER HALNON: It wasn't the natural  
7 uranium.

8 CHAIR PETTI: I suppose you could co-  
9 mingle them in your storage, but --

10 MR. WHATCOTT: Yes, okay. Sorry. Sorry  
11 for mis-replying. I think the answer still holds that  
12 the differentiation between those two will be  
13 something that's detailed in the OLA.

14 CHAIR PETTI: But right now, at least for  
15 the pictures, right, I mean, okay, if it's a regular  
16 fuel pebble you've got storage for that, but you're  
17 eventually going to have to get rid of the natural  
18 uranium pebbles. So is there a separate storage  
19 system? How is that all envisioned?

20 MR. WHATCOTT: No, the storage system will  
21 be with the fuel and the natural uranium pebbles will  
22 be stored together in --

23 CHAIR PETTI: Okay.

24 MR. WHATCOTT: -- special storage.

25 CHAIR PETTI: Okay. Thanks.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 DR. SCHULTZ: This is Steve Schultz. I  
2 have a question here on the criticality evaluations.  
3 In the PSAR there is a couple of places where you do  
4 indicate, as shown on the slide here, that the  
5 criticality analysis is performed, assuming both that  
6 the storage bay and canister interiors are flooded and  
7 the evaluation is done that way for conservatism. But  
8 later on when you talk about satisfying PDC 62, you  
9 indicated that the criticality analysis of preliminary  
10 one has been performed with the canister flooded, but  
11 the interior of the canister is not flooded. Is there  
12 a reason for that or are you looking for, I'm looking  
13 for consistency between the assumptions there and I  
14 was surprised to see the inconsistency.

15 MR. ZWEIBAUM: Yes, this was an error that  
16 we caught. This is indeed an inconsistency. The  
17 analysis has been, and will be performed, assuming  
18 that everything is flooded. So this is a typo in the  
19 version --

20 DR. SCHULTZ: Good.

21 MR. ZWEIBAUM: -- of the PSAR that was  
22 shared, and will be corrected.

23 DR. SCHULTZ: Quite satisfactory. Thank  
24 you.

25 MR. LINGENFELTER: Okay, this is Andrew

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1       Lingenfelter again.       Lead engineer of engineer  
2       integration.       I'll be talking about the fire  
3       protection systems and programs.

4               So, first off, the fire protection system  
5       is not credited with performing any safety-related  
6       functions. In accordance with PDC 3, it's designed to  
7       protect and extinguish fires so that a continuing fire  
8       will not prevent safe shutdown.

9               Also in accordance with PDC 3, non-  
10       combustible and fire-resistant materials are usual  
11       never practical. Particularly in locations with SSCs  
12       that are safety-related or required for safe shutdown.

13               Some of the codes that the fire protection  
14       system will conform to are the local building and fire  
15       codes, ANSI-ANS 15.7, fire protection program for  
16       research reactors, NFPA 801, and life safety code NFPA  
17       101. Also in accordance with PDC 2, the system is  
18       designed so that seismic induced study does not impact  
19       nearby safety-related SSCs. Okay.

20               DR. CILLIERS: Thank you. This is Anthony  
21       Cilliers speaking.       I'm the director of  
22       instrumentation and controls. And I'll be talking  
23       about communication.

24               I'd just like to note here that this is  
25       communication technologies that is provided between

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 humans. This is independent of our communication  
2 systems, the data communication throughout the control  
3 systems, as well as the calculation of data. So this  
4 is purely communications between people onsite and  
5 offsite.

6 The communication system is upgraded for  
7 performing any safety-related functions. And we've  
8 identified a coupled of technologies to allow us to  
9 have the appropriate type of communication for  
10 whatever case is required. And these technologies  
11 will do things like plant radio, public address and  
12 general alarm system, communication capability in the  
13 event of loss of normal power, so we can still  
14 communicate in the event of loss of power, distributed  
15 antenna communication and security communications.

16 In addition to this we will be using  
17 diverse commercial communication systems for on and  
18 offsite communication. And that allows just  
19 additional layer of diversity for wireless  
20 communication we needed between staff onsite, as well  
21 as provided information offsite.

22 It's used for normal and emergency  
23 communications to communicate between the key areas of  
24 the facility. And will also be provided phone lines  
25 for offsite communication in case of an emergency.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 This is fairly conventional communication systems as  
2 per normal in nuclear power plants. Thank you.

3 MEMBER BROWN: When you say conventional,  
4 most of this electronic and wireless that you've  
5 listed in here. A phone line varies in what it can  
6 be. It can be the loss of, like, fiber optic phone  
7 lines will die when you lose power. Are you going to  
8 have any, what I would call conventional land lines  
9 available, the old style, such that if you lose power  
10 you can still communicate, or are you going to --

11 DR. CILLIERS: Yes. We will have the  
12 conventional phone lines installed. Just as it is the  
13 easiest system as a backup system. But we'll be  
14 utilizing most of technologically advanced wireless  
15 systems where appropriate because it allows us  
16 additional level of freedom for communications.

17 MEMBER BROWN: Yes, I don't have a problem  
18 --

19 (Simultaneous speaking.)

20 MEMBER BROWN: Yes, I don't have a problem  
21 with that. Okay. I just, hardwired, you know, copper  
22 land lines, a couple of them would be very, very good  
23 to have just in case. And they're easy to put in.

24 If you depend on a fiber optic-type phone  
25 line, well, then you're dependent upon loss of power

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 also and have to have backup power to make sure you  
2 can keep it. Most of those won't last for most of 24  
3 hours, as I can attest in my house.

4 DR. CILLIERS: Yes. Well --

5 MEMBER BROWN: It's just a thought. I  
6 mean, I have no problem with the other stuff you're  
7 doing, it's just that whatever phone lines you have,  
8 if you ought to have some of the old-style copper  
9 phone lines, which go out, which are self-powered.

10 DR. CILLIERS: Yes.

11 MEMBER BROWN: And they'll always be there  
12 for you. I wouldn't use them for the general stuff  
13 around, you're obviously going to do it the other way.  
14 Which is fine.

15 DR. CILLIERS: Yes, thank you. The last  
16 bullet, the intent of that last bullet really is to  
17 cover all of the valves and normal copper phone lines.

18 MEMBER BROWN: Okay, thank you.

19 MS. ELLENSON: Hi, this is Margaret  
20 Ellenson. I am the safeguards and security manager  
21 here at Kairos Power. I'm going to be covering  
22 Section 9.6. There are various materials that we're  
23 aware of that will be on the site at Hermes. We'll  
24 have byproduct material, source term and special  
25 nuclear material.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           So this section covers our expectations  
2 related to how we are going to license the use of  
3 those materials at the site. In particular, we're  
4 going to be applying for the traditional 30, 40, 70  
5 license. That is 10 CFR Part 30, 10 CFR Part 40, and  
6 10 CFR Part 70 for byproduct source of special nuclear  
7 material respectively.

8           We are actively engaged with the staff  
9 about the sequencing of when they need the information  
10 to support those licenses. And our expectation is  
11 that the licenses will be provided as part of the  
12 operating license application. Any questions about  
13 9.6?

14           MEMBER HALNON: Yes. That last bullet  
15 request, will be submitted at a future date. Is that  
16 what you just mentioned is, these will specifically be  
17 part of the operating application?

18           MS. ELLENSON: Yes. And I think the CPA  
19 specifically says, the licenses will be submitted at  
20 a future date. There is some complexities about when  
21 information will be available, depending on when  
22 various program elements are available, right? Those  
23 program elements that are needed to support the Part  
24 30, 40, 70 applications. So we are actively engaged  
25 on like how to get the information to the staff at the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 right time to support the reviews.

2 MEMBER HALNON: Okay. Yes, there is a lot  
3 of admin in here.

4 MS. ELLENSON: Yes.

5 MEMBER HALNON: Yesterday we had a  
6 discussion about the short operating license,  
7 decommissioning windows and whatnot. And in Chapter,  
8 I think 17, you mentioned there is no intent to get a  
9 material or possession only license later on.

10 I know that that this, it just may not be  
11 in this section, but it just talks about, it's a  
12 material license, basically, or a special nuclear  
13 material license. Just kind of keep that in mind. I  
14 think that's important to assess whether or not you  
15 will need a possession only license after the four-  
16 year period.

17 MS. ELLENSON: That's a good point. Thank  
18 you.

19 MR. LINGENFELTER: Okay. This is Andrew  
20 Lingenfelter again and I'll be talking about the  
21 auxiliary systems in 9.7 here and 9.8.

22 So the first one is a plant water systems.  
23 The water systems are not credited with performing any  
24 safety-related function. The first of those systems  
25 is a service water system. And this is the system

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 that facilitates moving the main supply of water that  
2 we received and providing that water to the treated  
3 water system. Along with other areas.

4 The treated water system provides  
5 chemistry control of the service water and provides  
6 water to the component cooling water system, chilled  
7 water and decay heat removal systems. In accordance  
8 with PDC 2, the system is designed to protect against  
9 design basis earthquakes, nearby safety-relates SSCs.

10 Also in accordance with PDC 4, nearby  
11 safety-related SSCs are protected from the effects of  
12 discharging fluid and missiles, and precluded from  
13 pipe whip hazards by design.

14 The component cooling water system, this  
15 provides water cooling for the reactor building HVAC  
16 systems, the equipment instructional cooling system,  
17 plant chilled cooling system, and the inert gas system  
18 coolers and compressors. And also in accordance with  
19 PDC 2, this one will protect against design basis  
20 earthquakes for nearby particular SSCs. And then also  
21 it will follow the guidelines of PDC 4, or nearby  
22 safety-related SSCs that are protected from effects of  
23 discharging fluid and missiles, and precluded from  
24 pipe whip hazards by design.

25 Also, the system is designed with a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 capability to isolate leaks, permit appropriate  
2 periodic inspection and testing, to ensure the  
3 integrity and capability of the system to cool SSCs  
4 and to adequately transfer heat to the ultimate heat  
5 sink, in accordance with PDCs 44, 45 and 46.

6 The chilled water system provides cooling  
7 water for nonessential heat loads. And consistent  
8 with 10 CFR 20.1406, the plant water systems that  
9 directly interface with systems that contain  
10 radioactive material are designed, to the extent  
11 practicable, to minimize contamination of the facility  
12 and the environment and to facilitate eventual  
13 decommissioning.

14 The next one I'll be talking about here is  
15 the remote maintenance and inspection system. This  
16 one is not crediting with performing any safety-  
17 related functions. And the system can remotely handle  
18 components in the reactor systems PHTS and PHSS. The  
19 system supports the following maintenance activities.  
20 And I'll actually let you read those. I don't  
21 necessary have to go through each of those.

22 And consistent with 10 CFR 20.1406, as  
23 we've been discussing in a lot of these slides, that  
24 the system is designed, to the extent practical, to  
25 minimize contamination of the facility and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 environment and facilitate potential decommissioning.  
2 The capabilities of this system will limit personnel  
3 occupational exposures to below 10 CFR 20 limits.

4 Okay. The next one, spent fuel cooling  
5 system. This one is not accredited with performing  
6 any safety-related functions. What the functions it  
7 does provide is the forced air cooling for spent fuel  
8 storage canisters in the storage bay of the PHSS, and  
9 recirculates water in the spent fuel pool. And this  
10 consists of fans and pipings that remove heat during  
11 normal operation. And maintains desired operation  
12 temperatures in the storage bay.

13 And if power, normal power is not  
14 available, the system is capable of passively cooling  
15 the spent fuel storage canisters. And some of the  
16 design bases here, in accordance with PDC 2, the  
17 system is designed to ensure nearby safety-related  
18 SSCs that are protected from seismic induced failure.  
19 And in accordance with PDC 4, nearby safety-related  
20 SSCs are protected from dynamic effects, such as  
21 missiles by design.

22 And a similar statement is, previous to  
23 10, it's consistent with 10 CFR 20.1406, system to the  
24 extent practical, will minimize contamination of the  
25 facility and the environment and facilitate eventual

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 decommissioning.

2           Okay. Next one, compressed air system.  
3 This system is not accredited with performing any  
4 safety-related functions. What the system does, is  
5 providing and distributing compressed air for  
6 maintenance and use for in-valve operation. And the  
7 system is designed so that a failure of that system  
8 does not interfere or preclude the ability of a  
9 safety-related system to perform its safety function.  
10 And this system does not directly interface with  
11 systems that contain or have potential to contain  
12 radioactive materials.

13           Okay. Next one is cranes and rigging. So  
14 again, this is not accredited with performing any  
15 safety-related functions. What this system does is it  
16 will be lifting and moving equipment within the  
17 reactor building, facilitate receiving and shipping  
18 and supporting maintenance activities.

19           And in accordance with PDC 2, the system  
20 will ensure nearby SSCs, are safety-related SSCs that  
21 are protected from seismic induced failure. And in  
22 accordance with PDC 4, nearby safety-related SSCs are  
23 protected from dynamic effects by design, such as  
24 administrative controls and interlocks. And this will  
25 implement codes and standards from ASME B30.2.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           Okay.     Next one is auxiliary site  
2 services. This is not accredited with performing any  
3 safety-related functions. The following services are  
4 provided, you can read there by the system, but I  
5 won't go through each of those.

6           In accordance with PDC 2, the system is  
7 designed to ensure nearby safety-related SSCs are  
8 protected from seismic induced failure. And the  
9 capabilities of the system will limit personnel  
10 occupational exposures to below 10 CFR 20 limits.

11           In services that involve handling the  
12 radioactive material may include remote manipulation  
13 capabilities, as appropriate, to facilitate limiting  
14 personnel occupational exposures to believe 10 CFR 21.

15           I think that's the end of our slides.

16           CHAIR PETTI:   Members, any questions?  
17 Okay, then let's turn to the Staff.

18           MEMBER DIMITRIJEVIC: That, Dave, can you  
19 hear me?

20           CHAIR PETTI:   Oh yes.   Yes.   You had a  
21 question?

22           MEMBER DIMITRIJEVIC: I'm sorry, I have a  
23 really bad technical setup here so I couldn't unmute  
24 myself for a second.

25           I had a general question about this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 auxiliary systems and, and Greg asked in one moment,  
2 do they support any safety questions. So this is my  
3 general question. When we say that those systems are  
4 not accredited in performing any safety function,  
5 which is always the full sentence in presentation,  
6 does that mean they are not supporting any safety  
7 functions, too, and that they're failure would not  
8 impact any safety function?

9 So does this first sentence implies, where  
10 they say not accredited to performing safety function,  
11 does it also imply they're not supporting any safety  
12 function and their failure would not impact any safety  
13 function? That's my general question.

14 (Simultaneous speaking.)

15 MEMBER DIMITRIJEVIC: But second question  
16 is, was there any something like ASME, you know,  
17 failure mode and effect analysis performed on this  
18 systems where you analyzed for type of the failure  
19 modes they can be and how they affect the plants? Was  
20 that a part of, like, for example, analyzing  
21 postulated accident?

22 That's my second question. And my -- and  
23 I noticed, actually, that often we talk about dynamic  
24 -- for subsystems, we talk about those dynamic effects  
25 on the safety SSCs. But that's not -- like, for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 example, I know from the fire analysis in the Section  
2 3 that we actually left for the operating license to  
3 see how can that water source be ethylated (phonetic)  
4 so it will not effecte that.

5 Is there any more detailed documentation  
6 on the type of this secondary or the economic effects  
7 on these systems? Actually, everything is connected  
8 that was -- how and when those systems analyze for  
9 their failure and impact.

10 MR. LINGENFELTER: Okay, well, I can --  
11 this is Andrew Lingenfelter. Thanks for those  
12 questions and comments there. I'll go ahead and field  
13 the first one, and then I'll have our director of  
14 reliability handle the second one.

15 So the first one, I believe your question  
16 was, by saying that it does not perform any safety-  
17 related function, does that also mean it does not  
18 support any safety-related functions, if I'm not  
19 mistaken. And the answer to that question is, yes.

20 MEMBER DIMITRIJEVIC: Well, how then this  
21 -- because we have argued yesterday the FLiBe and foil  
22 are the safety components. And obviously some of  
23 those systems support that, you know, like temperature  
24 control, the FLiBe and things like. Why would you say  
25 they don't support the safety functions then?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. HAGAMAN: So this is Jordan Haganam  
2 and I'm the director of reliability engineering. When  
3 we talk about whether a function is safety-related we  
4 are specifically talking about the performance of the  
5 SSC during postulated accident conditions.

6 So the cooling functions that happen  
7 during steady state, there are cooling functions for  
8 safety-related systems, but the way we provide  
9 assurance of the operability of those SSCs is through  
10 a limiting condition of operation that will be in the  
11 tech spec. Where temperature is important for the  
12 operability of a system, we'll be monitoring the  
13 temperature as part of our limiting condition of  
14 operation.

15 So the actual cooling function is provided  
16 in steady state, it's not a safety-related function.  
17 We rely on the tech spec to ensure that the SSC is  
18 operable. And then the cooling function is not  
19 required during the postulated event mission, mission  
20 time.

21 MEMBER DIMITRIJEVIC: Okay. But that is  
22 -- also part of my suspicion was, does that mean the  
23 system failure would not interfere?

24 See, that is bad thing because if you, the  
25 system failure will not interfere with performing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 safety function.

2 MR. HAGAMAN: Yes. So that is something  
3 that we also check against to ensure that the system  
4 cannot fail in a way that impedes a safety function.

5 MR. GARDNER: Okay, this is Darrell  
6 Gardner. This is why we have the PDC 2 and the PDC 4  
7 specifically mentioned for most of these systems. So  
8 for example, if you have one of these non-safety  
9 systems routed closely or in proximity to something  
10 that was safety-related, then we're going to restrain  
11 it appropriately. Or put up a barrier, or ensure the  
12 distance is sufficiently far enough away that it can't  
13 have an adverse interaction.

14 But until we do specific layout and  
15 routing of those systems, we can't tell you which  
16 ones, or which portions of those systems might  
17 possibly have a failure mechanism such as, again,  
18 failure due to seismic or failure due to pipe breakage  
19 for PDC 4.

20 MEMBER DIMITRIJEVIC: Okay. And I have a  
21 really, I mean, we're going to think a little more  
22 about all of this in Section 13. And how about  
23 failure mode and effects analyses, do perform that for  
24 any of those systems?

25 MR. LINGENFELTER: We regularly perform

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 failure modes and effects analysis in conjunction with  
2 the level of design detail available at any stage.  
3 And we regularly update those failure modes and  
4 effects analyses as the design progresses.

5 So we can expect that as we get final  
6 design to support the operating license we'll have a  
7 final more static version of the failure modes and  
8 effects analysis that confirm the safety functions,  
9 and in particular, that the non-safety systems don't,  
10 cannot impede any safety functions.

11 MEMBER DIMITRIJEVIC: And was that a part  
12 of the review?

13 MR. LINGENFELTER: It was available for  
14 review. I'd have to go into my notes to see how much  
15 we actually looked at it with the staff.

16 MEMBER DIMITRIJEVIC: Okay, thanks.

17 MEMBER REMPE: Maybe the Staff should  
18 answer that question.

19 MR. LINGENFELTER: Yes.

20 MEMBER REMPE: Did you look at some of  
21 their FMEAs as part of your review? And could you  
22 talk a little bit about the details since they said it  
23 was commensurate with the detail of the design?

24 MR. BEASLEY: So this is Ben Beasley with  
25 the Staff. I reviewed just the reactor build in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 HVAC, I did not look at a modes and effects analysis.  
2 I don't know if there were four other reviewers in  
3 Chapter 9.

4 MEMBER REMPE: So you don't remember  
5 seeing --

6 MR. BEASLEY: I don't remember if any of  
7 them pursued that or not. I don't remember  
8 specifically.

9 MEMBER REMPE: Do you remember even seeing  
10 if they were submitted?

11 MR. BEASLEY: Well they wouldn't have been  
12 submitted --

13 MEMBER REMPE: Oh.

14 MR. BEASLEY: -- we would have done it  
15 through audit.

16 MEMBER REMPE: Audit, yes.

17 MR. BEASLEY: Yes.

18 MEMBER REMPE: That they were available to  
19 you, you used the audit.

20 MR. BEASLEY: Yes. If we had wanted to  
21 see it, it would have been put on --

22 MEMBER REMPE: You didn't recall seeing  
23 any?

24 MR. BEASLEY: I do not recall seeing any.  
25 No, ma'am.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MR. CHERESKIN: So this is Alex Chereskin  
2 from the NRC Staff. I, again, don't recall about the,  
3 you know, specifically reviewing failure modes and  
4 effects analysis, but just as an example, with the  
5 inert gas system we did ask about the consequence of,  
6 you know, what happens if air gets in here. Because  
7 obviously it's connected to the handling system, you  
8 can have oxidation. So we did have those discussions.

9 And the resolution ends up that it's  
10 bounded by Chapter 13 analysis. So, you know, at  
11 least when I looked at it up there, just as an  
12 example, it wasn't explicitly an FMEA, but we were  
13 considering what happened is if you have a failure and  
14 what's the data, the effects of that.

15 MEMBER REMPE: So they thought about it  
16 but didn't see documented analysis. Okay, thank you.

17 CHAIR PETTI: So, it just, it seems to me  
18 that, I think of the system in other technologies the  
19 supporting system is playing an important role in  
20 ensuring the safety functions. But here at least the  
21 critical safety function of functional containment is  
22 inherent in TRISO, assuming you don't get above really  
23 high temperatures, which they have huge margins, and  
24 FLiBe, it's inherent in the nature of FLiBe that the  
25 fission products have attained whether it's spilled,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 whether it be in a tank. And so, I think because of  
2 that there is a lot less coupling of the support  
3 systems from the systems that do accomplish the safety  
4 functions.

5 It's, again, I think it's another one of  
6 these things where the functional containment evolves  
7 in the design in a different way of other technology.  
8 Any other questions, members? If not we'll move, go  
9 on to the staff.

10 MR. BEASLEY: Thank you. Again, this is  
11 Ben Beasley, I'm with the NRC Staff. And I do want to  
12 introduce the other presenters for Chapter 9. Alex  
13 Chereskin will talk about a couple of the auxiliary  
14 systems that he reviewed. And Jason Schaperow is  
15 joining us virtually. He'll talk about the systems  
16 that he reviewed.

17 And I would like to do a quick mic check  
18 for Jason. Are you present, and can you check your  
19 mic?

20 MR. SCHAPEROW: Yes, I am.

21 MR. BEASLEY: Very good. Thank you. So,  
22 it's already gone to the second slide. This lists the  
23 content of the safety evaluation and the PSAR.  
24 Nothing in the auxiliary systems of Chapter 9 is  
25 safety-related, as you have already noted.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           We're going to focus on the systems that  
2           are novel and that have more relevance, yes, relevance  
3           to safe operation. Those systems are primarily in 9.1  
4           and 9.3. If you have any questions on other systems,  
5           HVAC, fire protection, communication, use of nuclear  
6           material or other miscellaneous systems, those  
7           reviewers are here and would be able to answer your,  
8           or I'll try to answer your questions.

9           So the next slide.

10          MEMBER HALNON: Ben, you mentioned that --

11          MR. BEASLEY: Yes.

12          MEMBER HALNON: -- nothing is safety-  
13          related. I understand there is no safety-related  
14          functions, but the pump handling the storage system,  
15          I mean, that's got FLiBe in it and pebbles. Is that  
16          not designed as a safety-related, I mean, piping and  
17          pressure boundaries and stuff like that?

18          MR. BEASLEY: So Jason is going to present  
19          on the PHSS in a few minutes.

20          MEMBER HALNON: All right. So I'll just  
21          queue up that question.

22          MR. BEASLEY: Yes.

23          MEMBER HALNON: Thank you.

24          MR. BEASLEY: But Jason will be ready to  
25          answer.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. SCHAPEROW: Yes. Yes. I'll pull up  
2 my notes because I actually talked to the Kairos about  
3 that during an audit meeting.

4 MEMBER HALNON: I'll wait. Thanks, Jason.

5 MR. BEASLEY: So, Kairos did not request  
6 approval of any specific auxiliary system designs in  
7 their construction permit application. The  
8 application contained a description of the preliminary  
9 design and identified the design bases.

10 In general, the evaluation criteria  
11 required, NUREG-1537 required that auxiliary systems  
12 should not result in reactor accidents or uncontrolled  
13 release of radioactivity and that no function or  
14 malfunction of the auxiliary systems should interfere  
15 with or prevent safe shutdown of the reactor. The  
16 Staff review determined that the preliminary designs  
17 of the auxiliary systems are consistent with the  
18 objectives of the identified PDCs and NUREG-1537, thus  
19 the information on auxiliary systems meets the  
20 requirements of 10 CFR 50.34 for a construction  
21 permit. Further information needed to complete the  
22 safety analysis can reasonably be left with the  
23 operating license application.

24 I will turn it over now to Alex, who will  
25 start talking about the chemistry control system.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. CHERESKIN: Sure. This is Alex  
2 Chereskin, the NRC Staff. I'll be covering sections  
3 9.1.1 for the chemistry control system and 9.1.2 for  
4 the inert gas system.

5 So starting with the chemistry control  
6 system, just a brief overview. It's used during  
7 normal operations to monitor coolant chemistry, ensure  
8 the FLiBe meets appropriate specifications. It would  
9 also be able to remove or replace the coolant to  
10 restore performance specifications via the connections  
11 to the inventory management system that Kairos  
12 described earlier in their presentation. And has been  
13 just noted here, this is a non-safety-related system.

14 Next slide, please. So this slide  
15 contains the Staff evaluation of the chemistry control  
16 system. And so, I'll start with the PDC 2, requiring  
17 protection against natural phenomena. As you heard  
18 yesterday, that seismic methodologies were talked  
19 about in section, Chapter 3 of the Staff SER. And,  
20 you know, this is also something that we would look at  
21 the operating license stage, as Kairos mentioned, you  
22 know, once the layouts are finalized to make sure that  
23 failure cannot impact the safety-related SSC.

24 And I think it's pretty similar for PDC 4.  
25 It's the similar thought protecting against

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 environmental and dynamic effects. Once we can see  
2 that final layout, I think that's something that could  
3 be verified.

4 In addition, PDC 70 requires that a  
5 chemistry control system requires a system to monitor  
6 and correct the reactor coolant chemistry. And PDC 70  
7 basis that on factors such chemical attack, fouling  
8 and plugging, radionuclide concentration and the  
9 potential for air and moisture ingress. So there is  
10 reasonable assurance that the chemistry control system  
11 will be able to measure purity and correct the  
12 chemistry via the IMA if needed.

13 As Kairos talked about in their  
14 presentation, if the samples are found to be out of  
15 specification, what would be replaced in order to  
16 restore performance of the specifications. And at the  
17 operating license application stage, the Staff would  
18 review the, you know, where the samples are taken in  
19 the CCS to ensure that you have a well-mixed  
20 representative sample of the coolant.

21 And we would also review the other methods  
22 used to analyze the coolant. I think that's something  
23 that some of the members were talking a little bit  
24 about before. As well as the frequencies. And, you  
25 know, if there are any corrective actions required if

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 you go add a specification.

2 And so, you know, the CCS is also  
3 consistent with some of the proposed limits that were  
4 found in the proposed limits in Chapter 14 of the PSAR  
5 talking about things like maintaining the correct  
6 lithium fluoride to beryllium fluoride ratio, as well  
7 as maintaining appropriate circulating activity  
8 limits.

9 And one other criteria that I wanted to  
10 mention here, there is a NUREG-1537 guidance about  
11 ensuring that whole cleanup systems don't cause an  
12 excessive loss of coolant in the other CCSs downstream  
13 of the anti-siphon features in the vessel. And so, it  
14 would seem unlikely that the CCS could cause that  
15 excessive loss of coolant.

16 Next slide, please. So now we'll cover  
17 the Staff's review of the inert gas system. And per  
18 the PSAR Section 9.1.2, the IGS has several design  
19 functions. That includes maintaining an inert  
20 environment, providing purge flow and removing  
21 impurities, as well as transporting tritium downstream  
22 to the tritium management system. And also providing  
23 the reactor coolant motive force. It also needs to be  
24 able to assess the purity and process the gases, as  
25 well as ensuring control and protection of leaks from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the IGS.

2 The Staff has reasonable assurance that  
3 criteria in NUREG-1537 can be met as the IGS will use  
4 an inert argon gas that's supplied to the components  
5 with individually regulated temperatures, pressures  
6 and flows. It will contain storage tanks, as well as  
7 equipment to be able to measure and remove oxygen and  
8 moisture. And it will also, it also can be monitored  
9 for leaks. And it will contain radiation monitors, as  
10 shown on the P&ID in the PSAR.

11 Next slide, please. And so here, again,  
12 we have PDCs 2 and 4. And so, I think similar to some  
13 of the previous discussions we've had, once the, you  
14 know, the final plant layouts are determined, we would  
15 be able to verify that failures of these systems, you  
16 know, from like seismic or dynamic effects wouldn't  
17 impact safety-related systems.

18 In addition, PDC 64 would require the  
19 monitoring of radioactive releases. And as I noted on  
20 the last slide, the IGS does have radiation monitors  
21 and can be inspected to detect leaks. And so that  
22 would help to meet PDC 64. As well as the proposed  
23 technical specification on circulating activity.

24 And additionally, PSAR Section 9.1.2 talks  
25 about assessing argon volume purity, which is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 consistent with the NUREG-1537 guidance that the gas  
2 purity should be assessed.

3 And the other thing, it's not on the  
4 slide, but because we're talking about the potentials  
5 for how these support systems may impact other things  
6 and whether we've looked at, you know, some of the  
7 things that we discussed during the audit, in addition  
8 to the one I mentioned before was that, you know, the  
9 IGS was also used to ensure that FLiBe doesn't freeze  
10 in certain areas. And, you know, we talked about that  
11 in being able to provide kind of like a sweep gas.  
12 When you move any like FLiBe aerosols along to help  
13 try and mitigate that.

14 And we talked about the air ingress  
15 potential just a little bit before. And then one of  
16 the other things that was discussed during our audit  
17 discussions were, you know, whether or not like a high  
18 initial pressure in the IGS could have impacts on the  
19 natural circulation flow, but given that the FLiBe  
20 level would be, the natural circulation would take  
21 place below the FLiBe free surface, you know, it would  
22 seem unlikely that the IGS would be able to impact  
23 that.

24 So, you know, just based on the previous  
25 discussion I wanted to give at least a couple of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 examples of areas where we did consider that, even  
2 though these systems were classified as non-safety-  
3 related. And I think that's the last slide I have on  
4 the IGS.

5 MEMBER HALNON: Yes. And, Alex, thank you  
6 for going through some of the behind the scene  
7 questions. That helps give us confidence in that your  
8 review is pretty comprehensive, so I appreciate that.

9 MR. CHERESKIN: And so, if there are no  
10 further questions I'll turn it over to Jason because  
11 I believe he has the next session. Section.

12 MR. SCHAPEROW: Yes. I'm Jason Schaperow  
13 with the NRC Staff. Today I will be presenting the  
14 Staff's review of some of the reactor coolant  
15 auxiliary systems. As well as the Staff's review of  
16 the fuel handling and storage system.

17 So as noted on this slide, the three-  
18 reactor coolant auxiliary systems that I reviewed were  
19 the tritium mitigation system, the inventory  
20 management system and the reactor thermal management  
21 system.

22 So these are kind of unique systems. And  
23 as such, when I looked at the review guidance for test  
24 reactors there is not a specific section for tritium  
25 mitigation. That's not one of the sections.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           What they do have is, they have a section,  
2           Section 9.7, called other auxiliary systems. And this  
3           gives review criteria and guidance for these types of  
4           systems, which are other auxiliary systems, which are  
5           not safety-related.

6           I tried to summarize here in just three  
7           short bullets. These systems should be such that they  
8           do not result in reactor accidents. They do not  
9           prevent safe shutdown. And they do not result in  
10          unacceptable releases or exposures.

11          Next slide, please. So regarding our  
12          review, what we did was we asked lots of questions at  
13          audits to enhance our understanding of what the texts  
14          that's in the PSAR. We checked the PDCs that are  
15          listed in the PSAR, which actually Kairos showed in  
16          their slides. We checked those to make sure those are  
17          appropriate to meet the review criteria.

18          And finally, for these facility unique  
19          systems we had checked to make sure the PDCs listed  
20          are appropriate for the specific system. There is a  
21          specific PDC for the thermal management system. For  
22          example, it's called PDC 71, reactor coolant heating  
23          systems.

24          Next slide. Regarding fuel handling and  
25          storage, there are review criteria given for this.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Actually, this section number is not listed here,  
2 sorry. The title of NUREG-1537 is not handling and  
3 storage it's spent fuel. But there should be a  
4 section listed.

5 But anyway. So Kairos calls their system,  
6 they gave it a special name, it's called the pebble  
7 handling and storage system. This is their handling  
8 and storage of spent fuel. So there are a number of  
9 review criteria for NRC Staff when reviewing test  
10 reactors.

11 Six is listed here. The first one is that  
12 all spent, all special nuclear material must be  
13 accounted for. Fuel meets procurement specs.  
14 Criticality is prevented. Fuel handling tools and  
15 procedures need to be appropriate designed. Methods  
16 to assess fuel radioactivity and potential exposure  
17 rates need to be adequate to avoid personnel exposure.  
18 And finally, they have to deal with their occupational  
19 exposure limits in the ALARA.

20 Next slide, please. Again, with regard to  
21 the NRC Staff review, we had meetings with them. We  
22 had audit meetings with them to enhance our  
23 understandings. And again, we checked the PDCs that  
24 Kairos listed in the PSAR to make sure they were the  
25 appropriate ones.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           With regard to the Members question about  
2 what part of the system is considered safety-related,  
3 so we did, actually, another reviewer identified that.  
4 Ed Helvenston. He noted, hey, Jason, you know, it  
5 says here that there is some stuff related, you know,  
6 are you sure you understand exactly what is. We did  
7 discuss this with Kairos, and they clarified what is  
8 safety-related in the system.

9           And what is, is the concrete structures.  
10 I guess I should probably read the text here just to  
11 make sure I don't goof this up because it's been a  
12 long time since I looked at this. Yes, Kairos is  
13 responsible with the concrete structures associated  
14 with the storage bay for the canisters, the spent fuel  
15 pool and the support restraints in the pool. Those  
16 are safety-related structures.

17           And the reason they are is to ensure that  
18 the geometry is maintained to preclude inadvertent  
19 criticality during an earthquake. They also mentioned  
20 that the pebble extraction machine trip is a safety-  
21 related function.

22           The other things that I think are  
23 addressed through Chapter 13 analysis, I recall there  
24 being an analysis in Chapter 13 of a break in the  
25 pebble handling system where pebbles would spill out

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 onto the floor of the room there where the system was  
2 located. And so I think that's how the rest of this  
3 is treated. I hope that answers the question.

4 MEMBER HALNON: Yes, I think it does. I  
5 have to think about it, but I don't see any additional  
6 follow-up I need.

7 MR. SCHAPEROW: Over to you, Ben.

8 MEMBER DIMITRIJEVIC: Sorry, I am again  
9 late. Can you go back, I think it was Slide 67. This  
10 is Vesna Dimitrijevic.

11 That when you define that, when was that,  
12 when they defined that based on the NUREG, what the  
13 three question, not after the reactor shutdown, what,  
14 let me just think.

15 MR. SCHAPEROW: Oh, that's Slide 68 maybe.  
16 68.

17 MEMBER DIMITRIJEVIC: Yes, somewhere  
18 around that. I don't remember exactly what slide.

19 MR. SCHAPEROW: Yes, there is it.

20 MEMBER DIMITRIJEVIC: Okay. So let me  
21 just see it. So not the stopping the reactor  
22 accident, right? That's the question?

23 MR. SCHAPEROW: Correct. That's what's --

24 MEMBER DIMITRIJEVIC: We know here that  
25 also there is no accidents, right? They have a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 postulated events, right?

2 MR. SCHAPEROW: Well, the point, I guess  
3 the point I was trying to distill down here was that  
4 failure of these systems should not result in a  
5 reactor accident. Like if the tritium mitigation  
6 system stops functioning or gets a hole in it or  
7 something, it won't result in core damage.

8 MEMBER DIMITRIJEVIC: Oh, okay. Well the  
9 reactor accident means will not result in the core  
10 damage or will not result in the initiating event?

11 MR. SCHAPEROW: Hm.

12 MEMBER DIMITRIJEVIC: Because, seem what  
13 happening here since they merge, after the accidents  
14 in the coolants and accidents, everything in  
15 postulated event, is there a safety question that's in  
16 failure of this system would not result in a  
17 postulated event. So that's what -- I'd just like a  
18 sort of, you know, the trying to understand how this  
19 all comes to the postulated events. That's why I'm  
20 asking this.

21 MR. SCHAPEROW: Yes, I don't think NUREG-  
22 1537 uses the term postulated events, although I guess  
23 it's --

24 MEMBER DIMITRIJEVIC: I know. But in the  
25 Section 3 you have determined that we're going to use

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 this in this application, so --

2 CHAIR PETTI: Yes, I think the question,  
3 Jason is, NUREG-1537 uses a certain set of terms and  
4 terminology, but things have been redefined in Kairos,  
5 so how did you map what --

6 MR. SCHAPEROW: I --

7 CHAIR PETTI: -- 1537 says in terms of the  
8 language that Kairos uses?

9 MR. SCHAPEROW: Yes, I would say they're  
10 synonymous in reactor accident or postulated events.  
11 I mean, I --

12 MEMBER DIMITRIJEVIC: Well in that case,  
13 if an accident is in the coolant some of those  
14 systems would result in shutdown of the reactor,  
15 right? And that's also postulated event. I'm just  
16 being, you know, interested.

17 MR. SCHAPEROW: Yes. I don't see that any  
18 of these systems, at least the way they're described,  
19 would result in reactor shutdown. Again, if the  
20 tritium mitigation system stopped working, you might  
21 see a little buildup of tritium somewhere in the  
22 plant, but it's not going to initiate a reactor --

23 MEMBER DIMITRIJEVIC: But management,  
24 maybe the fuel handling. You know, that's why I think  
25 the failure mode doesn't affect analysis --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MEMBER KIRCHNER: Well, I would point out

2 --

3 MEMBER DIMITRIJEVIC: -- bring this  
4 reactor accident information offline. I'm okay.

5 CHAIR PETTI: Go ahead, Walt. You had a  
6 question?

7 MEMBER KIRCHNER: No. I was just going to  
8 say, in tech specs of the applicant in Chapter 14, it  
9 identifies classes of limiting conditions of  
10 operations that are mainly maintained by the systems  
11 at particularly 9.2. And if those, if the detected  
12 conditions are outside that envelope than that would  
13 have a, certainly have an impact on reactor  
14 operations. For example, purity of the purity spec  
15 that they need to maintain for the FLiBe.

16 MR. HELVENSTON: This is Ed Helvenston  
17 from the Staff. I'll just, maybe I'll clarify one  
18 thing a little bit in terms of the reactor accidents  
19 and postulated events terminology.

20 I think the term postulated events is  
21 probably a little broader than accidents. I think  
22 accidents may mean something that's actually occurring  
23 that has some potential failure or consequence for the  
24 reactor.

25 We do look at a wide range of postulated

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 events in Chapter 13. For example, I think a  
2 malfunction of equipment is a possible postulated  
3 event, but, you know, we have an analysis in Chapter  
4 13 that demonstrates why that won't result in any  
5 unacceptable consequences for the reactor.

6 So I think there is a little bit of a  
7 nuance between those terms. I just, hopefully that  
8 clarification is helpful.

9 MR. SCHMIDT: Yes, this is Jeff Schmidt  
10 from the Staff also. So, like things like, let's just  
11 say a cooling water system and an interaction with  
12 FLiBe is prevented by design. So like you could have  
13 a leak of water somewhere, right, and that could be  
14 "an initiating event," but it's interaction, it's  
15 negative interaction would be precluded by design. So  
16 I guess you could call that an initiating event, but  
17 it doesn't lead to anything.

18 I would also agree with Dr. Kirchner that  
19 most of these systems set the initial conditions for  
20 the postulated events, right? These mostly go into  
21 tech specs that set the allowed range of initial  
22 conditions, and then the accident, or event, I'm  
23 sorry, the event progresses, right? And that sets the  
24 initial condition for these systems. It's not used to  
25 mitigate the event but sets the initial conditions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER DIMITRIJEVIC: But, okay. But my,  
2 I'm just, you know, in terms of the NUREG-1537 you're  
3 not -- you're integrating this first thing, is not  
4 result in postulated accident. Postulate event,  
5 sorry. I mean, you know, is that, because here we  
6 have this little issue with the implementation of the  
7 postulated events, so.

8                   MR. SCHAPEROW: Yes. That's how we're  
9 interpreting that, not to result in postulated events.

10                  MEMBER DIMITRIJEVIC: It was obviously  
11 just agreeing that that would result in several  
12 postulated events, right? And the shutdown is a  
13 postulated event.

14                  MR. BEASLEY: So this is Ben Beasley with  
15 the Staff. Jason, I'm going to amend your answer  
16 there a little bit. I think that we were using this  
17 term because that's the terminology used in the  
18 criteria in NUREG-1537. So that's why it's showing up  
19 in our slides because that's the criteria we were  
20 measuring against.

21                  And as Ed pointed out, there is a nuance  
22 between what you would consider a postulated event and  
23 what we would consider an accident. And so, you know,  
24 so weren't examining these systems to assure that they  
25 wouldn't create a postulated event, but that they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 wouldn't create an accident that could have  
2 radiological consequences.

3 And again, this is a very preliminary  
4 design and so we couldn't dig into detail. That is  
5 what we will do on the next round with the operating  
6 license application.

7 MEMBER DIMITRIJEVIC: Well, maybe even  
8 need to, you need to add additional definition here in  
9 using this, you know, so there no confusion here.

10 MR. BEASLEY: Thank you for the comment.  
11 And we'll certainly consider that as we move forward  
12 with the OL application review. Ed, could you go on  
13 to Slide 72.

14 So unless, you know, I don't want to cut  
15 off questions, but we just have one more slide and  
16 would be glad to take any of your questions. So the  
17 Staff found that the auxiliary system designs, and  
18 this is kind of why I wanted to get to this point, we  
19 were reviewing against the criteria in 1537, and so  
20 the Staff found that auxiliary system design should  
21 not result in reactor accidents, or uncontrolled  
22 release of radioactivity, and that no function or  
23 malfunction of the auxiliary systems should interfere  
24 with, or prevent, safe shutdown of the reactor.

25 And mere design of the auxiliary systems

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 is sufficient and meets the applicable regulatory  
2 requirements and guidance for the issuance of a  
3 construction permit in accordance with 50.35. Further  
4 technical or design information required to complete  
5 the safety analysis can be left for later  
6 consideration in the FSAR. So that concludes our  
7 presentation.

8 CHAIR PETTI: Members, any additional  
9 questions? Okay, then let's move to the memo. Greg.

10 MEMBER HALNON: Okay. Since there was  
11 such a broad topic of space here, the background just  
12 basically summarizes the heat system in a principal  
13 function of the system. And that was to keep some  
14 context of where we were.

15 If you go to the SCR summary. So, it just  
16 reiterates that we agree with the conclusion that  
17 there are sufficient details there to provide  
18 competence in the evaluation, and we really do  
19 appreciate the extra context that you guys have put  
20 behind some of the questions you asked.

21 And we acknowledge the fact that there is  
22 a lot to do in the operating license. So, you know,  
23 we talked a little bit about how much there is and  
24 schedules and that stuff. It's going to be a  
25 tremendous, a tremendous effort to schedule that out

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 and get it done as well.

2 On the discussion, I call out the fact  
3 that the Part 20 stuff still has to get done. The  
4 items to highlight I'll just kind of step through.  
5 I'm not sure, I think you got the same numbers I have.  
6 Yes.

7 The numbers, or the systems described,  
8 they have no safety-related functions, as we talked  
9 about. But we did find out that there is some safety-  
10 related aspects in the construction and equipment.  
11 But there is no mitigation functions. And I did come  
12 off the pebble handling and storage system, as we  
13 mentioned, that there are some parts in there that  
14 aren't constructive to safety-related functions.

15 The PHAs pebble handling storage system,  
16 the assumptions I called out, found out that that was  
17 an error in the assumptions and criticality analysis.  
18 I'll go back, Dave, and revise the memo to make that  
19 clear that it was an error and that it will be fixed.  
20 But probably a lot of the verbiage will stay there,  
21 just so it makes things in context.

22 I call out the fact that pretty well they  
23 have described the fact that non-safety systems at  
24 interface are in a general proximity will be designed  
25 accordingly with the proper seismic and other designs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           Again, Part 20 requirements needed to be  
2           looked at. This anti-siphoning function of the PHTS  
3           was, in my mind, is really important for inventory.  
4           And when I tried to go through the string of go, talk  
5           about it here, go to Chapter 4, then go to Chapter 5,  
6           each time it was handed off I expected to see a little  
7           bit more detail on what that looked like. And I  
8           realized that anti-siphoning is fairly intuitive but  
9           I didn't get much details.

10           So I'll be looking forward to getting that  
11           detail a lot to see how that configuration is and how  
12           it interfaces. Because that truly is an interface  
13           with a safety-related system and the inventory  
14           management system. So it's sort of indirect, but it  
15           certainly isn't a factor.

16           CHAIR PETTI: You know, I mentioned it is  
17           one of the "novel features" of Chapter 1, so to see it  
18           again in another memo is perfect.

19           MEMBER HALNON: Okay. I did mention that  
20           there were, I'm on Number 7 if you're not there yet,  
21           there is three tanks. Or at least the picture showed  
22           three tanks I believe on the IMS. Inventory  
23           management system.

24           I understand from, and I'll revise this  
25           one as well with the comments that we had here that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 whether it be three tanks or one tank that can do any  
2 of the functions, make sure that's clear in here too  
3 because I thought that was a clarifying, a good  
4 clarifying comment by Kairos.

5 The low pressure water systems that  
6 received water to the plant for cooling, maintenance,  
7 potable water, some of them will interface with  
8 radioactive systems potentially. The water systems do  
9 have that potential so the interconnected system  
10 leakage would be a problem. We've seen that in the  
11 existing nuclear plants for non-safety, non-  
12 contaminated systems that contaminated quite easily  
13 with one failure, so we had to make sure that those  
14 are recognized.

15 And then I just mentioned, that there is,  
16 in my mind, as the design hold out there could be  
17 potentially some technical specification parameters  
18 that are necessary to maintain, to put into tech specs  
19 for some of these support functions. Maybe not, but  
20 again, we don't have the details so let's keep that in  
21 mind. The only recommendation was to correct that  
22 error in the criticality in the auxiliary, criticality  
23 analysis. And that summarizes that pretty quickly.

24 CHAIR PETTI: What about this tritium  
25 drinking water, should we put a sentence in? Or we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 can put it in on 11 when we get to 11 next April. So  
2 they haven't, all they've done is a classic dose  
3 calculation, but the tritium drinking water standard  
4 may be the more limiting condition that needs to be  
5 looked at.

6 MEMBER HALNON: Okay. Let me think about  
7 that because we're dealing with another tritium issue  
8 right now that --

9 CHAIR PETTI: Yes.

10 MEMBER HALNON: Yes, I'll take to the  
11 other, I may draft up a sentence or two and make sure  
12 it's consistent so we don't send it in different  
13 directions. Any other comments, questions? Steve,  
14 thank you for your help on this. Okay, Dave, back to  
15 you.

16 CHAIR PETTI: Okay. I guess we can, once  
17 again, go out for public comments. Any member of the  
18 public that has a comment, please unmute yourself,  
19 state your name, affiliation if applicable, and your  
20 comment. Okay, not hearing anything I think we're  
21 done.

22 This is good. We completed in advance of  
23 the agenda. And it gives us confidence in terms of  
24 the rest of the reviews and now have a sense of a  
25 cadence in terms of how much time it's going to take

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 to get through the remaining chapters. So with that  
2 we'll recess --

3 MR. HASTINGS: Mr. Chairman?

4 CHAIR PETTI: Yes.

5 MR. HASTINGS: Hi, this is Peter Hastings.  
6 I wanted to make just some brief closing remarks on  
7 behalf of Kairos.

8 CHAIR PETTI: Sure.

9 MR. HASTINGS: So, this is Peter Hastings.  
10 I'm the vice president of regulatory affairs for  
11 Kairos Power. And I want to thank the ACRS Members  
12 and Staff, and the NRC Staff, for their engagement and  
13 your detailed review and your comments.

14 I do want to make a couple of comments  
15 myself with respect to some ongoing discussion, both  
16 yesterday and today, on the regulatory pathway that  
17 we're following. In various comments some members  
18 have wondered why there is not more detail than what's  
19 available in the PSAR, and have reiterated that Kairos  
20 is "proceeding at risk" without regulator assurance  
21 over the details of our design.

22 As you know, we are pursuing a  
23 construction permit application under 10 CFR Part 50.  
24 And our application was prepared in accordance with  
25 the regulation. Primarily 10 CFR 50.34(a). And as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 further informed by the NRC approved topical report  
2 that addresses the differences in regulatory  
3 applicability between light water reactors and advance  
4 reactors, and also pursuant to the guidance in NUREG-  
5 1537, as has been discussed numerous times.

6 And has also been noted, generally  
7 speaking we did not request a finding on safety  
8 functions of SSCs for the facility. This is obviously  
9 all completely consistent with the regulation. And  
10 with the conversations that we've held with the Staff  
11 for several years now.

12 I want to make two things clear. First,  
13 to avoid any ambiguity in messaging, the risk of  
14 moving forward in a way that the NRC Staff will not  
15 find acceptable is solely a commercial programmatic  
16 risk, not a safety risk. I'm 100 percent confident  
17 that the Members recognize this, but I wanted to make  
18 it clear on the record for any outside observers.

19 Second, as an applicant, Kairos Power  
20 appreciates and accepts the programmatic risk of the  
21 two-step process under Part 50. We specifically  
22 selected this pathway, in part because of the lack of  
23 land mines that some of us discovered firsthand on the  
24 Part 52 path for first of a kind designs.

25 We recognized the commercial risk of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 moving forward on the details of our design. At the  
2 same time I'll observe we've conducted the most  
3 comprehensive pre-application engagement of any  
4 advance reactor applicant to date. And just recently  
5 approved, received approval of the last of our 11  
6 topical reports that apply to, both to our commercial  
7 design and to the Hermes Reactor.

8 And as Chairman Petti remarked earlier, we  
9 have significant margins that make it exceedingly  
10 unlikely we're painting ourselves into a corner at the  
11 construction permit stage. And so for those reasons  
12 the commercial risk of moving forward in a way that  
13 somehow gets us cross-wise with a regulation and with  
14 the Staff is not something that keeps me awake at  
15 night. We fully intend and expect to be able to  
16 demonstrate all of the regulatory requirements at the  
17 OL stage. So thank you again for a productive  
18 engagement, and we look forward to the next steps.

19 CHAIR PETTI: Thank you.

20 MEMBER DIMITRIJEVIC: Thank you.

21 CHAIR PETTI: With that we will adjourn  
22 the meeting and we will see everyone again April 4th.

23 (Whereupon, the above-entitled matter went  
24 off the record at 2:51 p.m.)

25

March 15, 2023

Docket No. 50-7513

US Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

**Subject:** Kairos Power LLC  
Presentation Materials for Kairos Power Briefing to the Advisory Committee on Reactor Safeguards, Kairos Power Subcommittee on Hermes Preliminary Safety Analysis Report Chapters 1, 2, 3, 4, 6, and 9

**References:** Letter, Kairos Power LLC to Document Control Desk, "Submittal of the Preliminary Safety Analysis Report for the Kairos Power Fluoride Salt-Cooled, High Temperature Non-Power Reactor (Hermes), Revision 2," February 24, 2023 (ML 23055A673)

This letter transmits the presentation slides for the March 23-24, 2023 briefings for the Advisory Committee for Reactor Safeguards (ACRS), Kairos Power Subcommittee. During the March 23 meeting, participants will discuss Hermes Preliminary Safety Analysis Report (PSAR) Chapters 1, 2, 3, and 4. During the March 24 meeting, participants will discuss PSAR Chapters 4, 6, and 9.

Enclosures 1 and 2 provide the non-proprietary slides for the March 23 and 24 briefings, respectively. Kairos Power authorizes the Nuclear Regulatory Commission to reproduce and distribute the submitted content, as necessary, to support the conduct of their regulatory responsibilities.

If you have any questions or need additional information, please contact Drew Peebles at [peebles@kairospower.com](mailto:peebles@kairospower.com) or (704) 275-5388, or Darrell Gardner at [gardner@kairospower.com](mailto:gardner@kairospower.com) or (704) 769-1226.

Sincerely,



Peter Hastings, PE  
Vice President, Regulatory Affairs and Quality

**Kairos Power LLC**  
[www.kairospower.com](http://www.kairospower.com)

Enclosures:

- 1) Presentation Slides for the March 23, 2023 ACRS Kairos Power Subcommittee Meeting (Non-Proprietary)
- 2) Presentation Slides for the March 24, 2023 ACRS Kairos Power Subcommittee Meeting (Non-Proprietary)

xc (w/enclosure):

William Jessup, Chief, NRR Advanced Reactor Licensing Branch

Benjamin Beasley, Project Manager, NRR Advanced Reactor Licensing Branch

Edward Helvenston, Project Manager, NRR Advanced Reactor and Licensing Branch

Samuel Cuadrado de Jesus, Project Manager, NRR Advanced Reactor Licensing Branch

Matthew Hiser, Project Manager, NRR Advanced Reactor Licensing Branch

Weidong Wang, Senior Staff Engineer, Advisory Committee for Reactor Safeguards

**Enclosure 1**  
**Presentation Slides for the March 23, 2023**  
**ACRS Kairos Power Subcommittee Meeting**  
**(Non-Proprietary)**




## Introduction and Hermes PSAR Chapter 1

---

DREW PEEBLES – SENIOR LICENSING MANAGER  
ACRS KAIROS POWER SUBCOMMITTEE MEETING  
MARCH 23, 2023





Kairos Power's mission is to enable the world's transition to clean energy, with the ultimate goal of dramatically improving people's quality of life while protecting the environment.

# Overview of Kairos Power

- Nuclear energy engineering, design and manufacturing company *singularly focused* on the commercialization of the fluoride salt-cooled high-temperature reactor (FHR)
  - Founded in 2016
  - Current Staffing:
    - Over 300 Employees (*and growing*)
    - ~90% Engineering Staff
- Private funding commitment to engineering design and licensing program and physical demonstration through nuclear and non-nuclear technology development program
- Schedule driven by the goal for U.S. commercial demonstration by 2031 (or earlier) to enable rapid deployment in 2030s
- Cost targets set to be competitive with natural gas in the U.S. electricity market

Kairos Power Headquarters



Kairos Power Team



# Hermes PSAR Overview

---

- 10 CFR 50 Licensing Pathway
  - Construction Permit Application – Submitted Fall 2021
    - Environmental Report
    - Preliminary Safety Analysis Report (PSAR)
  - Next Licensing Step: Operating License Application
    - Final Safety Analysis Report (FSAR)
- Hermes PSAR Application Format and Content
  - Developed using guidance in NUREG 1537
  - Presents preliminary design and preliminary safety analysis consistent with 10 CFR 50.34(a)
  - PSAR does not request commission approval of the safety of any design feature or specification
    - *10 CFR 50.35(b) A construction permit will constitute an authorization to the applicant to proceed with construction but will not constitute Commission approval of the safety of any design feature or specification unless the applicant specifically requests such approval and such approval is incorporated in the permit.*

# Hermes PSAR Format

---

- Chapter 1 – The Facility
- Chapter 2 – Site Characteristics
- Chapter 3 – Design of Structures, Systems, and Components
- Chapter 4 – Reactor Description
- Chapter 5 – Heat Transport System
- Chapter 6 – Engineered Safety Features
- Chapter 7 – Instrumentation and Control Systems
- Chapter 8 – Electric Power Systems
- Chapter 9 – Auxiliary Systems
- Chapter 10 – Experimental Facilities and Utilization\*
- Chapter 11 – Radiation Protection Program and Waste Management
- Chapter 12 – Conduct of Operations\*\*
- Chapter 13 – Accident Analysis
- Chapter 14 – Technical Specifications\*\*
- Chapter 15 – Financial Qualifications\*\*
- Chapter 16 – Other License Considerations\*
- Chapter 17 – Decommissioning and Possession-only License Amendments\*
- Chapter 18 – Highly Enriched to Low Enriched Uranium Conversion\*

# Kairos Power Reports Referenced in PSAR

---

- Topical Reports
  - KP-TR-003 – Principal Design Criteria
  - KP-TR-004 – Regulatory Analysis
  - KP-TR-005 – Reactor Coolant
  - KP-TR-007 – Quality Assurance Plan
  - KP-TR-010 – Fuel Performance Methodology
  - KP-TR-011 – Fuel Qualification Methodology
  - KP-TR-012 – Mechanistic Source Term Methodology
  - KP-TR-013 – Metallics Qualification Methodology
  - KP-TR-014 – Graphite Qualification Methodology
- Technical Reports
  - KP-TR-017 – Core Design Methodology
  - KP-TR-018 – Postulated Event Methodology

# Hermes PSAR Chapter 1 – The Facility

---

- The purpose of Hermes is to test and demonstrate the key technologies, design features, and safety functions for KP-FHR technology
  - 35 MWth non-power reactor facility, 4 year licensed lifetime
  - Located in Oak Ridge, Tennessee at the East Tennessee Technology Park (Former site of Oak Ridge Gaseous Diffusion Plant)
- Principal Design Criteria based on NRC-approved topical report, KP-TR-003-NP-A "Principal Design Criteria"
- Low consequences due to inherent safety features
  - TRISO fuel
  - Flibe coolant
- Engineered safety features are provided to contain fission products and passively remove decay heat
- Instrumentation and control system provides monitors and controls plant operations. Electrical System provides the normal and backup power to the facility
- Auxiliary systems include a chemistry control system, inert gas system, tritium management system, fire protection system, heating and cooling systems, etc.

# Hermes PSAR Chapter 1 – The Facility

---

- Nuclear Safety Classifications: Safety-Related or Non-Safety Related
- Potential events are evaluated using a deterministic safety analysis with a Maximum Hypothetical Accident
- Radioactive waste management controls wastes produced by plant operations and radiation protection program protects health and safety of workers
- Experimental capabilities include testing of fuel irradiation, materials corrosion and irradiation, and transient and power maneuvering
  - Capability to perform these activities is included in normal system design described in PSAR
  - No additional facilities or capabilities required
- Research and development programs to resolve safety questions will be resolved before the completion of construction
- Hermes is a single unit reactor that does not share any systems or equipment to perform safety functions



# Kairos Power

Hermes PSAR 3.1 Introduction and 3.6 Systems and Components

---

DREW PEEBLES – SENIOR LICENSING MANAGER  
ACRS KAIROS POWER SUBCOMMITTEE MEETING  
MARCH 23, 2023



# 3.1 Applicable Regulations and Guidance

---

- Kairos Power is pursuing a construction permit for the Hermes reactor under 10 CFR 50
- The NRC regulations in Title 10 to the CFR were evaluated for applicability and documented in “Regulatory Analysis for the Kairos Power Fluoride Salt-Cooled, High Temperature Reactor” topical report (KP-TR-004-NP-A)
- PSAR Table 3.1-1 identifies the design-related regulations that are applicable to the Hermes Test Reactor
  - No specific exemptions from regulations were identified
  - Regulations related to combustible gas control were concluded to be not technically relevant
- Kairos Power evaluated NRC regulatory guides for applicability to the Hermes Test Reactor
  - NRC Division 1 regulatory guides are not applicable to research and test reactors
  - Divisions 2, 4, and 8 apply and were considered for the Hermes Test Reactor, as shown in Section 3.1

# 3.1 Principal Design Criteria

---

- Kairos Power has developed a set of Principal Design Criteria (PDC) for KP-FHR technology
- The design criteria were approved in a Topical Report titled "Principal Design Criteria for the Kairos Power Fluoride Salt-Cooled High Temperature Reactor" (TR-003-NP-A)
- These PDCs have been applied to the design of the Hermes Test Reactor, with the following exceptions:
  - PDC 5, Sharing of structures, systems, and components (SSCs) - Satisfied because there is only one reactor and no SSCs are shared with another reactor
  - PDC 73, Reactor coolant system interfaces - Not Applicable to the Hermes Test Reactor because there is no secondary coolant fluid
- The terms “safety-significant,” “anticipated operational occurrences,” and “accidents” used in the PDCs are not applicable to the Hermes reactor and are not used in the PSAR
  - These terms are relevant to power reactors which use frequency to bin postulated events
  - The Hermes safety analysis utilizes a deterministic Maximum Hypothetical Accident (MHA)

## 3.6 Fundamental Safety Functions

---

- Prevent uncontrolled release of radionuclides
  - Functional containment (TRISO fuel and Flibe coolant) retains fission products and limits release during normal and postulated events
  - Safety-related fluid systems that may contain circulating radiological activity are designed to ASME Section III
  - Non-safety-related fluid systems that may contain circulating radiological activity are designed to ASME Section VIII, B31.1/B31.3, or applicable API standards
- Remove decay heat in the event of a postulated event
  - Natural circulation and the passive decay heat removal system reject residual heat from the reactor core to the atmosphere
- Control reactivity in the reactor core
  - Reactivity control and shutdown system provides reactivity control during normal and postulated events

## 3.6 SSC Safety Classification

---

- SSCs are classified as safety-related or non-safety related
- The 10 CFR 50.2 definition of safety-related for light water reactors is modified for the Hermes Test Reactor as follows:
  - **Safety-related** structures, systems, and components means those structures, systems, and components that are relied upon to remain functional during and following design basis events to ensure:
    - The integrity of the **portions of the** reactor coolant ~~pressure~~-boundary **relied upon to maintain coolant level above the active core**;
    - The capability to shut down the reactor and maintain it in a safe shutdown condition; or
    - The capability to prevent or mitigate the consequences of accidents that could result in potential offsite exposures comparable to the applicable guideline exposures set forth in 10 CFR 50.34(a)(1) or 10 CFR 100.11
- This departure from 10 CFR 50.2 is necessary because the near atmospheric pressure design and the reactor coolant boundary does not provide a similar pressure-related or fission product retention function as light-water reactors for which these definitions were based
- The classification of SSCs is shown in PSAR Table 3.6-1

# 3.6 Seismic and Quality Classifications

---

- Seismic Classification
  - Safety-related SSCs are classified as SDC-3 in accordance with ASCE 43-19
  - Safety-related SSCs are located in the safety-related portion of the reactor building
  - Non-safety-related SSCs are designed to local building codes (ASCE/SEI 7-10)
- Quality Classification
  - Safety-related SSCs are classified as quality-related
  - Non-safety-related SSCs are classified as not quality-related
  - Quality-related SSCs conform to the requirements of the quality assurance program for the Hermes Test Reactor, which is based on ANSI/ANS 15.8
- The seismic and quality classification of SSCs is shown in PSAR Table 3.6-1



## Hermes PSAR Chapters 2.1-2.4, 3.2, and 3.3

---

MARTY BRYAN – SENIOR MANAGER, SITE LICENSING



BRIAN SONG – SENIOR MANAGER, CIVIL STRUCTURES

ACRS KAIROS POWER SUBCOMMITTEE MEETING

MARCH 23, 2023

# 2.1 Geography and Demography: Hermes Site Location

- The site is located in Oak Ridge, Tennessee in Roane County within the East Tennessee Technology Park (ETTP)
- The Hermes test reactor will be located on former Department of Energy gaseous diffusion plant (K-33) building site
- The site boundary encompasses approximately 185 acres
  - About 30 acres would be permanently disturbed for operations of the facility




# 2.1 Geography and Demography: Hermes Site Location

---

- The original K-33 Building was constructed in 1954
- The uranium enrichment facility ceased operations in 1985
- DOE began reindustrialization of the ETTP in 1996
- The site was released for industrial use in 2011

View from West to East




View from North to South





# 2.1 Geography and Demography: Boundary and Zone Area Maps

- The site boundary is defined by the area owned, leased, or controlled (10 CFR 20.1003)
- The exclusion area boundary is defined as the area within the site boundary where the reactor site management has direct authority over all activities (10 CFR 100.3 and ANSI/ANS-15.16-2015)
- The low population zone is conservatively set at 800 meters from the reactor
  - The nearest resident is 0.7 mi NW from the site boundary
  - The PSAR includes population data 5 miles from the reactor
- The emergency planning zone is coincident to the site boundary (10 CFR 50, Appendix E.1.3)



## 2.2 Nearby Industrial, Transportation, and Military Installations

---


- An investigation of industrial, transportation, and military facilities within 5 miles (8 km) of the site was performed to identify potential external hazards (explosions, flammable vapor clouds [delayed ignition], toxic chemicals, and fires)
- The effects from potential external hazards within 5 miles of the site were determined to not warrant further analysis with the exception of:
  - The distance from the Hermes site to TN-58 was less than the safe distance calculated for shipments of chlorine or anhydrous ammonia. Therefore, the main control room will be designed with detectors for these chemicals.
- There are no existing commercial airports located within 10 miles of the site, however a general aviation airport is proposed to be located less than 1 mile SE of the site
  - The annual probability of an aircraft crashing into the facility was evaluated using the methodology outlined in DOE Standard DOE-STD-3014-2006
    - The total crash frequency for small, non-military aircraft from general aviation or helicopter operations is above the screening acceptance frequency threshold
  - The safety-related portion of the Reactor Building structure will be designed to withstand the impact of a small non-military general aviation aircraft

# Chapter 2 and 3 Relationships

Step 1: Define design basis parameter input envelope

Step 2: Define methods to translate inputs into design loads

Step 3: Define protections for safety-related SSCs using design loads



## 2.3 Meteorology

---

- The Hermes site is located on a prior U.S. Department of Energy (DOE) nuclear facility site within the DOE-managed Oak Ridge Reservation (ORR)
  - The ORR includes an extensive network of meteorological towers
  - Historical meteorological studies from 1953 and 2011 indicate that basic flow patterns have been in place during the recorded weather history of the ORR area
- Topography influences the weather and climate of the region around the site due to its location between the Cumberland Mountains to the northwest and the Great Smoky Mountains to the southeast.
- Prevailing winds in the region reflect the channeling of airflow from southwest to northeast caused by the orientation of the valleys and ridges


## 2.3 Meteorology (continued)

---

- Extreme Winds
  - Estimated extreme winds are based on climatological data from Oak Ridge and Knoxville, Tennessee, and hourly observations from meteorological Tower J (1.1 km southeast of the site) and Tower L (1.6 km southeast of the site)
    - For a 100-year return period, the maximum wind speed is 90 mph
  - Hurricane winds are mainly a concern for coastal locations as shown by the wind speed contours presented in Regulatory Guide 1.221
  - The probability of a tornado occurring at the site is low based on records from the NWS Morristown Tornado Database
- Extreme Precipitation
  - Historical precipitation data for the site were obtained from several surrounding National Weather Service (NWS) and Tennessee Valley Authority (TVA) sites
  - Storms with ice greater than or equal to 1 inch of ice occurred five times in 50 years and storms with ice greater than or equal to 2 inches of ice occurred two times in 50 years
  - The historical maximum snowfall event for a 48-hour period was determined to be 28 inches recorded in Westbourne, Tennessee, from February 19, 1960 to February 21, 1960

## 2.4 Hydrology: Description

- The site is located near the confluence between Clinch River and Poplar Creek
  - TVA manages water levels year-round for dam safety and flood control
  - Both Clinch River and Poplar Creek are considered as potential flooding sources
- The grade level for the site is 765 feet above mean sea level (feet msl)
  - The normal water surface elevation for Poplar Creek near the site is 744 feet msl (21 feet lower than site grade)



## 2.4 Hydrology Characterization: Previous Flood Studies

---

- There are two previous flood studies with estimated flooding elevations in the vicinity of the ETTP Hermes site:
  - FEMA Flood Insurance Study for Roane County, TN
    - Includes 10-, 50-, 100-, and 500-year return periods
    - All flood elevations from this study are below the Hermes site grade of 765 feet above mean sea level (feet msl)
  - Flood Hazard Evaluation for UCOR dated April 2015
    - A large range of return period floods (25 year to 100,000 year) were modeled and estimated
    - Results were assessed and used to identify a preliminary design-basis flood

## 2.4 Hydrology: Credible Hydrology Events and Design Basis

---

- The credible hydrological event for the Hermes site is selected as a 25,000-year return period (exceedance probability of  $4E-5$ ), consistent with Flooding Design Category 4 (FDC-4)
  - This results in a design basis flooding level for the site at 759.9 feet msl, based on previous studies
    - 5.1 feet below plant grade of 765.0 feet msl
- The Hermes site layout and grading plan takes advantage of the existing site topography so that storm water runoff naturally drains to the east, south, and west with flow directed to Poplar Creek



## 3.2 Meteorological Damage

---

- The design of SSCs considers the potential for meteorological damage, including rain, snow, wind, tornado, and tornado and wind-borne missiles for the site
- The safety-related portion of the reactor building structure provides protection to safety-related systems and components from meteorological damage
  - No credit is taken for the non-safety-related portions of the reactor building (exterior shell)
- Design basis meteorological parameters applicable to the design of the safety-related portion of the reactor building structure are established for: normal wind loads, high wind loads (tornados and hurricanes), and precipitation loads
- Normal wind load design basis:
  - Local building codes cite ASCE/SEI 7-10, “Minimum Design Loads for Buildings and Other Structures”. This standard defines risk categories for structures and includes design basis normal wind velocities for each risk category.
  - Risk Category IV (for hazardous substances) is the most stringent and selected as the design basis for the safety-related portions of the Reactor Building
  - Risk Category IV results in a design basis wind velocity of 120 miles per hour (mph)
    - This wind velocity bounds the site characterization meteorological data
    - This is based on a 1700-year mean recurrence interval, which is more conservative than the 100-year return period
  - The applied normal wind loads are determined using ASCE/SEI 7-10 Risk Category IV and exposure category C

## 3.2 Meteorological Damage (continued)

---

- High wind load design basis:
  - Guidance from Regulatory Guide (RG) 1.76, Revision 1, “Design-Basis Tornado and Tornado Missiles for Nuclear Power Plants,” was used to determine characteristics of the design-basis tornado
    - The applied tornado wind loads are determined using the methods in ASCE/SEI 7-10 and the wind speeds from RG 1.76 for Region I
    - The loads from tornado-generated missile impacts are transformed into an effective or equivalent static load consistent with NUREG-0800, Section 3.5.3, Subsection II using the missile spectrum and maximum horizontal speeds provided in Table 2 of RG 1.76 for Region I
  - Guidance from RG 1.221, Revision 0, “Design-Basis Hurricane and Hurricane Missiles for Nuclear Power Plants,” was used to determine applicable design parameters for hurricane loads
    - The applied hurricane wind loads are determined using the methods in ASCE/SEI 7-10 with a maximum wind speed of 130 mph and velocity pressure based on the guidance in RG 1.221 for the site location
    - The loads from hurricane-generated missile impacts are transformed into an effective or equivalent static load consistent with NUREG-0800, Section 3.5.3, Subsection II using the missile spectrum from RG 1.221

## 3.2 Meteorological Damage (continued)

---

- Precipitation load design basis:
  - The grading and drainage design for the site will preclude loads from precipitation accumulation on the ground affecting the safety-related portion of the Reactor Building
  - The non-safety related exterior shell of the Reactor Building has a sloped roof, therefore, loads due to rain accumulation are not considered as a structural load in the structural design.
  - Similarly, as a result of the lack of rain accumulation, load due to ice is anticipated to be minimal and is therefore enveloped by the snow load
  - The snow load design parameters are based on Chapters 1 and 7 of ASCE/SEI 7-10 for Risk Category IV structures and site location
  - The applied structural snow loads are determined based on the ground snow load of 21.9 psf and using the methods in ASCE/SEI 7-10 for Risk Category IV structures
    - Load considerations include balanced snow loads, unbalanced snow loads, snow drift loads, and rain on snow surcharge loads

## 3.3 Water Damage

---

- The design of the safety-related portions of the reactor building considers the loads from both external and internal flooding events
- External flooding postulated events do not pose a hydrologic load because the grade elevation is above the design basis flood elevation determined in PSAR Section 2.4
- Internal flooding postulated events consider the water sources within the safety-related portions of the reactor building
  - As discussed in Section 3.5, safety-related SSCs are protected from internal flooding:
    - Safety-related SSCs vulnerable to flooding are elevated, shielded or otherwise protected from spray. This includes Flibe-bearing components.
    - Design features direct water flow and prevent it from entering enclosures containing safety-related SSCs.
    - The volume of water in the safety-related portions of the reactor building is limited by design. For water systems that cross the base isolation moat, automatic or manual termination of flow will be specified in the operating license application.



# Kairos Power

Hermes PSAR 2.5, 3.4, and 3.5

Geology, Seismic Design, and Reactor Building Structures

---

BRIAN SONG – SENIOR MANAGER, CIVIL STRUCTURES

ACRS KAIROS POWER SUBCOMMITTEE MEETING

MARCH 23, 2023

# Chapter 2 and 3 Relationships

Step 1: Define design basis parameter input envelope

Step 2: Define methods to translate inputs into design loads

Step 3: Define protections for safety-related SSCs using design loads

Meteorology  
Section 2.3

- Section 3.2

Hydrology  
Section 2.4

- Section 3.3

Seismic  
Section 2.5

- Section 3.4

Section 3.5

## 2.5 Geology, Seismology, and Geotechnical Engineering

---

- Section 2.5 characterizes the geologic, geophysical, seismic and geotechnical aspects of the region and site to develop a seismic design basis for the facility
- The Hermes PSAR relies on existing information from the Clinch River Early Site Permit Application (CR-ESPA) for the regional and local geologic description, with supplemental information as needed
  - Covers 200 miles around the site
  - The CRNS site is close (3.5 miles) to the Hermes site and shares the same regional geology
- The Hermes Probabilistic Seismic Hazard Analysis (PSHA) is adapted from the CR-ESPA PSHA supplemented with consideration of current seismic hazard publications for the site and regional area
  - The PSHA methodology is an enhancement over the guidance in NUREG 1537
  - The CRNS PSHA meets ANSI/ANS 2.29 "Probabilistic Seismic Hazard Analysis"

## 2.5 Geology, Seismology, and Geotechnical Engineering: Site Geology


---

- CRN site geology information is directly applicable to the Hermes site
- A subsurface stratigraphy was developed for the Hermes site from a geotechnical boring program
- The placement of the facility on the site was informed by the geotechnical information



# 2.5 Geology, Seismology, and Geotechnical Engineering: Vibratory Ground Motion Analysis

- Uses CRN PSHA to develop the Seismic Design Response Spectra (DRS)
- Analysis relies on information from the CR-ESPA, with supplements
  - Use of the CR-ESPA, PSHA is both appropriate and reasonable given the proximity between both sites
- The Seismic Source Characterization is based on the CEUS (Central and Eastern United States) Seismic Source Characterization report
- The DRS meets ASCE 43-19 and uses Seismic Design Category 3 for safety-related SSCs which is appropriate for a non-power reactor application



SDC-3 Performance Goal: 1E-4


## 2.5 Geology, Seismology, and Geotechnical Engineering: Subsurface Deformation

---

- Relies on information from the CR-ESPA, supplemented by site-specific assessments to assess the potential for sinkholes, faults, and/or soil liquefaction
  - Given the subsurface conditions, and foundation interface plans along with fill placement, there is no potential for liquefaction at the site
  - Only inactive surface faults have been documented within the site area
  - The foundation rock for the Hermes reactor is at depths at which no evidence of karstic dissolution is encountered

# 2.5 Geology, Seismology, and Geotechnical Engineering: Foundation Interface

- The foundation layout has been established based on knowledge of the site subsurface conditions gathered from both historical documentation, including the CR-ESPA, and the subsurface boring exploration campaign
- The bearing system for the safety-related structure is a foundation mat resting on concrete fill over the Murfreesboro rock



## 3.4 Seismic Damage

---

- The graded performance-based approach from ASCE 43-19 is used to design the protections for safety-related SSCs from design basis earthquakes
  - Safety-related SSCs are designed to SDC-3, non-safety related SSCs are designed to local building code, which is consistent with NUREG-1537, IAEA-TECHDOC-403, and IAEA-TECHDOC-1347
  - The return period associated with the design basis ground motion corresponding to SDC-3 is similar to the maximum earthquake specified in building codes with a 2% probability of exceedance in 50 years
    - Consistent with NRC approvals for other non-power reactors
    - Additional margin exists due to the short operating lifetime of Hermes
- Seismic performance criteria are consistent with ANSI/ANS 15.7, Research Reactor Site Evaluation
- The 5% damped horizontal and vertical design response spectra are developed consistent with ANS 2.29, using the DRS defined in Section 2.5
- Structural design of non-safety related SSCs is performed in accordance with the 2012 International Building Code and the Tennessee Building Code

## 3.4 Seismic Damage: Analysis Models

---

- A 3-D finite element model of safety-related structures will be used for seismic analysis consistent with ASCE 4-16
  - Cracking analysis applies ASCE 4-16 Table 3-2
  - Structural damping applies ASCE 4-16 Table 3-1
  - Structural mass captures self-weight of structural elements as well as portions of design live loads and design uniform snow load
- Models use 3-component seismic input to develop structural forces and in-structure response spectra. Used for SDC-3 structural and equipment qualification.
- Seismic response analysis meets ASCE 4-16, Chapter 4, using deterministic, linear analysis
- Soil-structure analysis will be consistent with ASCE 4-16, Chapter 5


## 3.4 Seismic Damage: Seismic Instrumentation

---

- Seismic instrumentation will be installed for monitoring seismic events
- Tri-axial time-history accelerometers will be located in the free field and in the safety-related portion of the reactor building

# 3.5 Plant Structures: Reactor Building

- ~200' long, 100' wide
- Sloped roof
- The safety-related portion of the building uses base isolation using spring/dashpot elements
  - Reactor Cell: vessel, Flibe inventory, and HRR
  - Fuel Cell: PHSS, spent fuel storage
- No other building on the site performs a safety function, including the building that houses the main control room



## 3.5 Plant Structures: Reactor Building (continued)

---

The safety functions of the safety-related portion of the Reactor Building are:

- Protection of safety-related SSCs from design basis natural phenomena and external hazards
- Structural support for safety-related SSCs located on the safety-related portion of the Reactor Building
- Protection from adverse effects of non-safety related SSCs failures on the ability of safety-related SSCs to perform their safety functions
- Prevent interactions between reactor coolant (Flibe) and water contained in concrete in the safety-related portion of the reactor building

*Note: No part of the reactor building is credited to meet the functional containment safety function*



## 3.5 Plant Structures: Reactor Building Design Criteria

PDC	Description
1	Designed using consensus standards and in accordance with the applicable quality assurance program (ASCE/SEI 7-10).
2	Protects safety-related SSCs from the effects of design basis meteorological, flooding, and seismic events (see Slide 14 for seismic events).
3	Design minimizes the probability and the effect of fires and explosions. (Use of low-combustible materials, separation, fire protection program.)
75	Design protects the geometry of the decay heat removal system from postulated natural phenomena events. (DHRS is located in the safety-related portion of the Reactor Building.)
76	Design permits periodic inspection and surveillance of safety-related structural areas (to be demonstrated in the final safety analysis report).

# PDC 2: Seismic Events

---

- The safety-related portion of the reactor building is a reinforced concrete structure designed to meet ACI 349-2013, "Code Requirements for Nuclear Safety-Related Concrete Structures and Commentary." Internal steel structures are designed to meet AISC N690-18, "Specification for Safety-Related Steel Structures for Nuclear Facilities."
- By meeting ASCE 43-19, the safety-related portion of the building provides protection to safety-related SSCs from design basis earthquakes
  - Seismic acceptance is checked for both strength- and displacement-based criteria
  - Limit states are set based on the target performance goals
- Safety-related portion of the Reactor Building uses a spring/dashpot seismic isolation system, which lowers seismic demands on safety-related reactor building and safety-related SSCs in both horizontal and vertical directions
  - The moat is sized to accommodate a displacement consistent with the isolation system meeting the performance goal of 1E-4 per year
  - Design features accommodate potential differential displacements for SSCs that cross the moat



## Hermes PSAR 4.2 Reactor Core

---

RYAN LATTA – PRINCIPAL ENGINEER, FUELS AND MATERIAL

ODED DORON – SENIOR DIRECTOR, REACTOR SYSTEMS DESIGN

ACRS KAIROS POWER SUBCOMMITTEE MEETING

MARCH 23, 2023


# 4.2.1 Reactor Fuel

---

RYAN LATTA – PRINCIPAL ENGINEER, FUELS AND MATERIAL

## 4.2.1 Reactor Fuel: Fuel Description

- Hermes Test Reactor uses tri-structural isotropic (TRISO) fuel particles in a pebble-based fuel form
- TRISO particle fuel specification is equivalent to the DOE Advanced Gas Reactor (AGR) program
- The kernel and multiple layers of the TRISO fuel particle constitute a primary portion of the functional containment
- Hermes fuel pebble design consists of three regions:
  - Low-density carbon matrix inner core
  - Fuel annulus with TRISO-coated fuel particles embedded in a carbon matrix
  - Fuel-free carbon matrix outer shell
- Moderator pebbles are homogeneous carbon matrix pebbles that do not contain fuel
  - The mixture (ratio) of fuel and moderator pebbles is designed for optimal moderation in Hermes



4.0-cm diameter, annular fuel pebble is about the same size as a golf ball

## 4.2.1 Reactor Fuel: Fuel Description

---

### Fuel Particle Description

Property	Nominal Value
Kernel diameter ( $\mu\text{m}$ )	425
Buffer thickness ( $\mu\text{m}$ )	100
PyC thickness ( $\mu\text{m}$ )	40
SiC thickness ( $\mu\text{m}$ )	35
Kernel density ( $\text{g}/\text{cm}^3$ )	$\geq 10.4$
Buffer density ( $\text{g}/\text{cm}^3$ )	1.05
PyC density ( $\text{g}/\text{cm}^3$ )	1.90
SiC density ( $\text{g}/\text{cm}^3$ )	$\geq 3.19$

### Fuel Pebble Description

Property	Nominal Value
Pebble radius (cm)	2.0
Overall density ( $\text{g}/\text{cm}^3$ )	1.74
TRISO particles packing fraction	$\sim 37\%$
Pebble uranium loading (g)	6.0
Number of particles per pebble	$\sim 16,000$

## 4.2.1 Reactor Fuel: Fuel Qualification

---

- The Hermes fuel qualification approach is described in topical report KP-TR-011-P “Fuel Qualification Methodology for the Kairos Power Fluoride Salt-Cooled High Temperature Reactor”
- The Hermes TRISO particle fuel specification is equivalent to the DOE AGR fuel specification
  - The EPRI TRISO topical report (EPRI-AR1(NP)-A) demonstrated that the AGR-2 irradiation test resulted in low failure fractions in particles manufactured and inspected to meet the fuel specification
- A PIRT was conducted to evaluate fuel particle and pebble phenomena against a figure of merit
  - The results of the PIRT informs the fuel qualification program
- Pebble laboratory testing in the fuel qualification program demonstrates reasonable assurance the annular pebble will meet functional requirements
  - Mechanical tests – structural integrity
  - Tribology in molten salt and inert gas environments – wear
  - Molten salt infiltration tests – buoyancy
  - Material compatibility tests in salt and air environments – material interaction

## 4.2.1 Reactor Fuel: Fuel Qualification Envelope

---

- The Hermes fuel operating envelope is bounded by the fuel qualification envelope established in the fuel qualification methodology topical report
  - The fuel qualification envelope is based on the DOE AGR-2 irradiation and safety tests

Parameter	TRISO Particle Qualification Envelope
Peak SiC Layer Temperature – Normal Operation (°C)	1360
Peak SiC Layer Temperature - Transient (°C)	1600
Burnup (%FIMA)	13.2
Peak Particle Power (mW)	155
Peak Fluence ( $\times 10^{25} \text{n/m}^2$ , $E > 0.1 \text{MeV}$ )	3.8



## 4.2.1 Reactor Fuel: Fuel Surveillance

---

- The inert cover gas and Flibe coolant activity levels are monitored to detect an increase in fuel particle failure
- Fuel pebbles are examined in the pebble handling and storage system (PHSS) after exiting the core
  - Pebbles are examined for gross damage – wear, cracking, missing surfaces
  - Burnup is measured to confirm it is less than the qualification envelope, allowing pebble recirculation
- Pebbles near the design burnup limit and those exhibiting indications of damage are removed from service and placed in storage

## 4.2.1 Reactor Fuel: Fuel Design Bases

---

- The fuel is designed with appropriate margin to ensure that specified acceptable system radionuclide release design limits (SARRDLs) are not exceeded (PDC 10)
  - The annular fuel pebble design improves heat transfer by locating TRISO particles near the coolant allowing high operating powers while remaining within temperature limits
  - The TRISO fuel particle design has an equivalent fuel manufacturing specification as the AGR program
  - Fuel particles operate within the qualification envelope that is based on the AGR-2 irradiation and safety tests
- The fuel particle is designed with multiple barriers to constitute the primary portion of the functional containment which controls the release of radioactivity to the environment (PDC 16)
  - The TRISO fuel particle contains four barriers to the release of radionuclides
  - Pebble inspection in the PHSS ensures pebbles operate within the qualification envelope and are not damaged
  - Pebble laboratory testing confirmations that pebbles meet functional requirements, protecting the TRISO particles from damage


# 4.2.2 Reactivity Control and Shutdown System

---

ODED DORON – SENIOR DIRECTOR, REACTOR SYSTEMS DESIGN

## 4.2.2 Reactivity Control and Shutdown System

- Reactivity Shutdown System (RSS)
  - Credited for reactor trip and shutdown
  - 3 safety-related shutdown elements that insert directly into pebble bed
- Reactivity Control System (RCS)
  - Inserted on reactor trip, but not credited
  - 4 non-safety-related control elements that insert into reflector
- Release Mechanism
  - Safety-related electromagnetic clutch
- Drive Mechanism
  - Non-safety-related motor-driven sheave to position element
  - Provides for position indication
- Testing and Inspection
  - RCSS periodically inspected for wear
  - Reactor coolant periodically sampled for an increase in boron concentration that could indicate shutdown element cladding failure
  - RCSS elements can be replaced if necessary




### Hermes Core Layout

3 in-bed shutdown elements

4 ex-core control elements


# 4.2.2 Reactivity Control and Shutdown System: Shutdown Elements

- Shutdown Element
  - Cruciform Design
  - Inner Cladding contains absorber
  - Argon fill
  - Absorber:  $B_4C$
  - Cladding: SS-316H



# 4.2.2 Reactivity Control and Shutdown System: Control Elements

- Control Element
  - Segmented Annular Design
  - Individual Capsules
  - Argon fill
  - Absorber:  $B_4C$
  - Cladding: SS-316H



## 4.2.2 Reactivity Control and Shutdown System: Design Bases

---

- Safety-related RSS is capable of operating during an earthquake. Insertion capability confirmed via testing with maximum deflection of insertion path due to an earthquake. (PDC 2)
- RSS is compatible with environmental conditions and confirmed by qualification testing. Analysis demonstrates internal gas pressure due to irradiation does not exceed safety-related RSS element clad stress limits. (PDC 4)
- RSS is designed to fail in a safe state when the plant trips or upon loss of normal power. The energy holding relays close to remove power supply holding shutdown elements in place and a loss of power allows shutdown elements to drop via gravity. (PDC 23)
- The RCSS (RCS and RSS) meets PDC 26 (discussed in Section 4.5, Nuclear Design)
- RCSS (RCS and RSS) is designed to limit the amount and rate of reactivity insertion by controlling the maximum withdrawal speed of control and shutdown elements (PDC 28)
- The design of the RSS trip function in conjunction with the reactor protection system assures an extremely high probability of accomplishing its safety-related function. Both the RSS and the RCS provide significant negative reactivity insertion into the core via gravity and motor driven means upon a reactor trip. (PDC 29)



# Kairos Power

## Hermes PSAR 4.5 Nuclear Design

---

NADER SATVAT – SENIOR MANAGER, REACTOR CORE DESIGN


ACRS KAIROS POWER SUBCOMMITTEE MEETING

MARCH 23, 2023



# 4.5 Nuclear Design

- Reactor core is a packed bed with spherical pebbles
  - Fuel pebbles contain ~6 grams of uranium
  - Fuel pebbles have enrichment up to 20 wt% U-235
  - Moderator pebbles used to improve neutron moderation
  - Core contains approximately 60% pebbles (fuel and moderator) and 40% reactor coolant by volume
  - Core is under-moderated (negative temperature and void feedback)
- Reactor core is continuously refueled
  - Both fuel and moderator pebbles are introduced into the core from the bottom by the pebble handling and storage system (PHSS) and slowly move to the top in ~30-50 days and removed from the core by the PHSS
  - Pebbles inspected for physical damage and burnup
  - Pebbles discharged as they approach their design burnup
- Reactor core is surrounded by a graphite reflector
  - Increases neutron economy, provides moderation/reflection, shields the reactor structures, and maintains the core geometry
- Core design methodology described in “KP-FHR Core Design and Analysis Methodology” (KP-TR-017)




# 4.5 Nuclear Design

---


<b>Power</b>	35 MW <sub>th</sub>
<b>Method for Calculation</b>	Serpent 2 (neutronics); STAR-CCM+ (DEM and T/H)
<b>Coolant</b>	Flibe
<b>Shutdown margin</b>	$k_{\text{eff}} < 0.99$
<b>Reactivity Control Elements</b>	7 total; 3 shutdown elements, 4 control elements
<b>Vessel Irradiation</b>	< 0.1 dpa
<b>Reactor Inlet Temperature</b>	550°C
<b>Max Core Outlet Temperature</b>	650°C
<b>Core Volume</b>	2.0 m <sup>3</sup>
<b>Enrichment</b>	< 20 wt% U-235
<b>Reactivity Coefficients</b>	Net negative reactivity coefficient; under-moderated

# 4.5 Nuclear Design: Analytical Methods



# 4.5 Nuclear Design: Core Life Cycle

- Four cycles of life of the core:
  - Startup and approach to criticality
  - Power ascension
  - Transition to equilibrium (initial power plateau)
  - Equilibrium



# 4.5 Nuclear Design: Core Operational Regimes

---

- Approach to criticality
  - A combination of fresh fuel, natural uranium, and moderator pebbles are added into the core using 1/M approach
- Low power through ascension to power
  - Primary salt pump follows the power. Power defect, xenon, and burnup is compensated by control rods and fresh fuel addition
- Approach to equilibrium core
  - During the transition to full power, core composition will evolve: fresh fuel pebbles are added, and depleted pebbles are removed via the pebble handling and storage system (PHSS)
- All core states will operation within coolant reactivity coefficients, power per particle limits, and excess reactivity constrains

# 4.5 Nuclear Design: Design Basis


- The reactor core is designed so that the power oscillations that could result in conditions exceeding SARRDLs are not possible (PDC 12)
  - Due to the small core and the long neutron diffusion length (neutronically connected)
- The reactor core is designed so that the net effect of prompt inherent nuclear feedback tends to compensate for rapid increases in reactivity. The overall reactivity coefficient is negative. (PDC 11)
  - Large negative fuel doppler feedback
  - Positive reflector temperature coefficient due to spectrum hardening shifts flux toward core (reduces leakage) plus locally over-moderated conditions
  - Methodology used does not assume any thermal expansion of reflector (could counter-act positive feedback effect)
  - Reactivity impact due to the reflector temperature is delayed compared to fuel and coolant temperature feedback

Reactivity Coefficient	Startup	Equilibrium
Fuel Doppler (pcm/°C)	-6.2	-4.1
Moderator (pcm/°C)	-1.5	-0.4
Coolant (pcm/°C)	-2.3	-1.6
Void (pcm/%void), @3% void	-34	-53
Reflector (pcm/°C)	+2.6	+2.0

# 4.5 Nuclear Design: Design Basis (cont.)

- A limiting power distribution for the core design is used to ensure that the reactor core has appropriate margin to SARRDLs (PDC 10)
  - Serpent 2 used to calculate power distribution using methodology described in "KP-FHR Core Design and Analysis Methodology" (KP-TR-017-P)
  - Flux distributions are verified during startup using ex-core detectors. Flux measurements compared to predicted calculations to ensure core is operating as designed.
  - There are no consequence from control and shutdown elements not being quarter core symmetric due to the small core size and long neutron diffusion length

Power Distribution	Equilibrium
Axial Peak ( $F_z$ )	1.2
Radial Peak ( $F_R$ )	1.2
Total Pebble Peaking ( $F_Q$ )	1.8



## 4.5 Nuclear Design: Design Basis (cont.)

---

- Shutdown elements credited to provide means to ensure SARRDLs are not exceeded, and safe shutdown is achieved; met assuming highest worth shutdown element fully withdrawn. Shutdown elements insert reactivity at a sufficient rate and amount to ensure the capability to cool the core is maintained, the reactor is shut down and can be maintained in a shutdown condition; met assuming highest worth shutdown element fully withdrawn (PDC 26, Condition 1)
- Control elements provide the capability to control reactivity changes during normal power changes, ensure SARRDLs are not exceeded and provide an independent and separate means of reactivity control from RSS. Control elements are diverse from shutdown elements (different geometry, different locations, different insertion mechanisms) (PDC 26, Condition 2)
- Shutdown elements insert reactivity at a sufficient rate and amount to ensure the capability to cool the core is maintained, the reactor is shut down and can be maintained in a shutdown condition; met assuming highest worth shutdown element fully withdrawn (PDC 26, Condition 3)
- Shutdown elements provide a means of maintaining the reactor in a shutdown state to allow for fuel loading, inspection, and repair. (PDC 26, Condition 4)



## 4.5 Nuclear Design: Design Basis (cont.)

---

- The shutdown margin calculation accounts for:
  - Power defect
  - Xenon decay
  - Operational excess reactivity
  - Margin for uncertainties

Parameter	Value at Equilibrium
Required Shutdown Margin	1,000
Actual Shutdown Margin (pcm)	3,654
Required Worth for Shutdown (pcm) <sup>1</sup>	11,578
Worth of Shutdown Elements (pcm)	14,232

1. Required worth considers highest worth shutdown element withdrawn (which is 6,266 pcm)

# 4.5 Nuclear Design: Interfaces

---

- The output from nuclear design is used in interfaces with other calculations
- Vessel Fluence – Supports reactor vessel design
  - Fluence on vessel accounts for core, pebble insertion and extraction lines. Fluence is attenuated by the core barrel, reflector and coolant
  - Preliminary best estimate dpa + uncertainty is within 30% of the low-level irradiation value provided in "Metallic Materials Qualification for the Kairos Power Fluoride Salt-Cooled High-Temperature Reactor" (KP-TR-013-P)
- Nuclear Transient Analyses – Supports safety analysis
  - Conservative values used for power distribution, reactivity coefficients and shutdown margin provided as initial conditions for postulated reactivity transient events
- Core Design Limits – Supports technical specifications
  - Core design parameters during normal operation are within the fuel qualification envelope for peak fluence, peak particle power, burnup and peak fuel temperature
  - Shutdown margin
  - Coolant outlet temperature
  - Moderator pebble to fuel pebble ratio

**Enclosure 2**  
**Presentation Slides for the March 24, 2023**  
**ACRS Kairos Power Subcommittee Meeting**  
**(Non-Proprietary)**



## Hermes PSAR 4.3 Reactor Vessel System

---


ODED DORON – SENIOR DIRECTOR, REACTOR SYSTEM DESIGN

ACRS KAIROS POWER SUBCOMMITTEE MEETING

MARCH 24, 2023



# 4.3 Reactor Vessel System

- 316H stainless steel reactor vessel bottom head, shell and top head
- Vessel material qualified per topical report "Metallic Materials Qualification for the Kairos Power Fluoride Salt-Cooled High-Temperature Reactor" (KP-TR-013)
- Reactor Vessel Top Head
  - Supports attachment of equipment and components
  - Bolted and flanged
  - Designed to be leak tight (not credited)
  - The head, nozzles, and attachments are seismically qualified
  - 316H SS hold-down provides structural support against upward buoyant loads
- Reactor Vessel Shell
  - Maintains reactor coolant boundary
  - Provides the geometry for coolant inlet and heat transfer surface for Decay Heat Removal System (DHRS)
- Reactor Vessel Bottom Head
  - Maintains the reactor coolant boundary
  - Provides flow geometry for low pressure reactor coolant inlet to the core



# 4.3 Reactor Vessel System: Reactor Vessel Internals


- Core Barrel
  - 316H Stainless Steel
  - Downcomer is part of the normal and natural circulation flow pathways
- Reflector Support Structure
  - 316H Stainless Steel
  - Defines the flow path into the core
  - Supports the reflector blocks
- Reflector Blocks
  - ET-10 Graphite
  - Qualified per topical report "Graphite Material Qualification for the Kairos Power Fluoride Salt-Cooled High Temperature Reactor" (KP-TR-014)
  - Forms the fueling chute, flow channels, core, upper plenum, hot well, pump well, defueling chute, and diode pathway
  - Part of the normal circulation flow pathway
  - Diode pathway in the reflector block and 316H SS fluidic diode within the reflector block are part of the natural circulation flow path
  - Secondary metallic hold-down structure precludes damage to the natural circulation flow path from a postulated air ingress event




Section A-A

# 4.3 Reactor Vessel System: Flow Path

- Normal Circulation Flow Path (forced flow)
  - Cold leg (downcomer)
  - Reflector support structure
  - Reflector
    - Coolant inlet channels
    - Core
    - Coolant outlet channels and PEM
    - Hot well, pump well
  - Primary salt pump
  - Hot leg
  - Heat is removed by the heat rejection radiator
- Natural Circulation Flow Path (during postulated events)
  - Cold leg (downcomer)
  - Reflector support structure
  - Reflector
    - Coolant inlet channels
    - Core
    - Coolant outlet channels and PEM
    - Hot well, pump well
    - Natural circulation pathway
  - Fluidic diode
  - Cold leg (downcomer)
  - Heat is removed from the vessel wall by DHRS



**(a) Normal Operation  
Coolant Flow Path**



**(b) Natural Circulation  
Coolant Flow Path**

## 4.3 Reactor Vessel System: Design Basis

---

- Reactor vessel, reflector and 316H SS structures are designed, fabricated and tested consistent with ASME Section III, Division 5 standard (PDC 1)
- Reactor vessel, reactor vessel internals and vessel attachments are classified as SDC-3 per ASCE 43-19 to protect against failure during a design basis earthquake (PDC 2)
- Reactor vessel and vessel internals design accounts for environmental and dynamic effects like thermal expansion of vessel shell and bottom head, mechanical loadings from static weight and forces from the pebble bed, coolant and core components during start-up, normal operation and postulated events (PDC 4)
- The reflector block design maintain a geometry and coolant flow path to ensure the SARRDLs will not be exceeded by supporting coolant flow through the reflector via gaps and flow channels, thereby cooling the reflector and maintaining its structural integrity and the integrity of the coolant flow path (PDC 10)
- The reactor vessel is fabricated and tested to have an extremely low probability of abnormal leakage, rapidly propagating failure and gross rupture and the vessel material is qualified in accordance with the metallic materials qualification topical report. The vessel is operated within as-designed operational and transient conditions and monitored for changes during in-service inspection and testing (PDC 14)
- The reactor vessel is fabricated, and tested to ASME standards, the reactor vessel design supports pre- and in-service inspections, and catch basins with sensors are used to detect leakage (PDC 30)



## 4.3 Reactor Vessel System: Design Basis

---

- The reactor vessel design has margin to withstand stresses under operating maintenance, testing, and postulated events by precluding material creep, fatigue, thermal, mechanical and hydraulic stresses that would degrade the reactor coolant boundary. Stress rupture factors encompass transient conditions and leak tight design of reactor vessel head minimizes air ingress. The design prevents fracture of the reactor coolant boundary. (PDC 31)
- The reactor vessel design permits inspection and monitoring of the structural integrity and leak-tightness of the reactor coolant boundary using the material surveillance system (MSS) to confirm irradiation assisted stress corrosion cracking is non-existent or manageable (PDC 32)
- The core barrel design maintains reactor coolant inventory in the event of a break in the primary heat transport system using anti-siphon cutouts on both sides of the core barrel. (PDC 33)
- The flow path established by the design of the reactor vessel internals support the removal of residual heat from the core to ensure SARRDLs are not exceeded during normal operation and postulated events. The physical geometry and structure of the reactor vessel internals provide a pathway for forced flow and continuous natural circulation. (PDC 34)
- The fluidic diode, reflector blocks and downcomer are designed to maintain their structural integrity in order to establish a flow path for continuous natural circulation during a postulate event. The passive cooling of the reactor core prevents damage to the vessel internals due to overheating and therefore ensures the coolable geometry of the core is maintained. (PDC 35)
- The functional capability of the natural circulation flow path is confirmed during normal operation by temperature monitoring. Appropriate periodic inspections of the fluidic diode are performed via head penetrations. (PDC 36, PDC 37)
- The reflector is qualified to maintain its structural integrity to support residual heat removal in accordance with the graphite material qualification topical report. The reactor vessel is classified as SDC-3 and will maintain its geometry to support the insertions of shutdown elements. (PDC 74)



# Kairos Power

## Hermes PSAR 4.4 Biological Shield

---

NADER SATVAT – SENIOR MANAGER, REACTOR CORE DESIGN

ACRS KAIROS POWER SUBCOMMITTEE MEETING


MARCH 24, 2023

## 4.4 Biological Shield

---

- Protects workers and the public from radiation per 10 CFR 20
- Meets radiation exposure goals in PSAR Chapter 11
- Shield Design
  - Primary shield located just outside the reactor vessel
  - Secondary shield located outside the primary shield and contains the inventory management and primary heat transfer systems
  - Both shields are concrete
- Details on biological shield will be provided as part of the operating license application

## 4.4 Biological Shield





## Hermes PSAR 4.6 Thermal Hydraulic Design

---


NADER SATVAT – SENIOR MANAGER, REACTOR CORE DESIGN

ACRS KAIROS POWER SUBCOMMITTEE MEETING

MARCH 24, 2023

# 4.6 Thermal Hydraulic Design: Design Description

- The thermal hydraulic design is a combination of design features:
  - Pebble
  - Reactor coolant
  - Reactor vessel and internals
  - Primary heat transport system
- Thermal hydraulic design uses multiple heat transfer mechanisms between the reactor materials
- Thermal hydraulic design includes coolant flow path for normal operation and natural circulation
  - Natural circulation flow path uses a fluidic diode which minimizes reverse flow
  - Qualification or functional testing plans for fluidic diode and test results to validate performance will be available with the operating license
- STAR-CCM+ and KP-SAM computer codes are used in thermal hydraulic analysis of the design



## 4.6 Thermal Hydraulic Design: Computer Codes and Models

---

- STAR-CCM+ is used to perform the thermal hydraulic analysis in the core design methodology
  - Steady state solver for heat transfer and fluid flow in the form of a 3-D porous media model
  - Calculates the core material temperatures used as input into the neutronics model
  - Discussed in KP-TR-017-P “KP-FHR Core Design and Analysis Methodology”, Revision 1
- KP-SAM is used to perform the thermal hydraulic analysis in the postulated event methodology
  - Simplifies models to represent the major physical components and describe major physical processes (i.e., fluid flow, heat transfer)
  - Used to analyze the progression of postulated events (i.e., insertion of excess reactivity, loss of forced circulation)
  - Discussed in KP-TR-018-P “Postulated Event Methodology”, Revision 2

## 4.6 Thermal Hydraulic Design: Design Basis

---

- The design provides adequate transfer of heat from the fuel to the coolant to ensure SARRDLs will not be exceeded during normal operation and postulated events (PDC 10)
- The thermal hydraulic design of the reactor system ensures that power oscillations that could result in conditions exceeding SARRDLs are not possible or can reliably and readily detected and suppressed (PDC 12)
- Residual heat is removed during normal operation and postulated events, such that SARRDLs and the design conditions of the safety-related elements of the reactor coolant boundary are not exceeded (PDC 34)
- The reactor transfers heat from the reactor core during postulated events such that fuel and reactor internal structural damage that could interfere with continued effective core cooling is prevented (PDC 35)





Hermes PSAR 4.7 Reactor Vessel Support System

---



ODED DORON – SENIOR DIRECTOR, REACTOR SYSTEM DESIGN

ACRS KAIROS POWER SUBCOMMITTEE MEETING

MARCH 24, 2023

# 4.7 Reactor Vessel Support System

- Reactor vessel support system (RVSS) purpose:
  - Supports the weight of the reactor vessel with fuel, coolant, internals and attachments
  - Provides thermal management to support vessel expansion
- RVSS Bottom Support:
  - Includes a support tray, ledge, support columns, support pads, base plate, vessel connector, and anchoring connector
  - 316H stainless steel
  - Reactor vessel bottom head sits directly on the bottom support
  - Designed and fabricated using ASME Section III, Division 5
  - Vertically anchored to the reactor building foundation
- RVSS Thermal Management
  - Protects the reactor building cavity concrete from thermal effects
  - Thermal break provided by insulation ensures reactor building concrete integrity
- Reactor Building Seismic Isolation
  - Does not use lateral seismic restraints for the reactor vessel and head-mounted components. RVSS designed to keep reactor vessel from uplift and shear during seismic event.
  - Design leverages seismic isolation of the reactor building to reduce seismic effects on the vessel, RVSS, and head-mounted components



## 4.7 Reactor Vessel Support System: Design Basis

---

- RVSS is designed to withstand the effects of natural phenomena and support the reactor vessel in the event of an earthquake. The bottom support and connectors meet ASCE 43-19 and preclude linear buckling in the vessel support columns and provide lateral and uplift support. (PDC 2)
- RVSS is designed for the environmental conditions including temperature loading cycles in combination with mechanical loading cycles. Catch basins with sensors for leak detectors are used to preclude damage to the RVSS from primary coolant leaks. (PDC 4)
- The RVSS design ensures the integrity of the reactor vessel during postulated events to support the geometry for passive removal of residual heat from the core by removing heat from the reactor vessel via the reactor thermal management system, actively during normal operation and passively during postulated events. (PDC 74)
- The RVSS design removes heat from the vessel and ensures the integrity of the reactor vessel and reflector blocks, thereby permitting sufficient insertion of the control and shutdown elements providing for reactor shutdown. RVSS design ensures that ACI 349-13 is met to support maintenance and inspection of the vessel bottom head and shell weld and reactor cavity. (PDC 74)



# Kairos Power

## Hermes PSAR Chapter 6 Engineered Safety Features

---

NICOLAS ZWEIBAUM – DIRECTOR, SALT SYSTEMS DESIGN

ACRS KAIROS POWER SUBCOMMITTEE MEETING


MARCH 24, 2023

## 6.2 Functional Containment

---

- Functional containment is defined by the NRC in SECY-18-0096 as “a barrier, or set of barriers taken together, that effectively limits the physical transport of radioactive material to the environment”
- The functional containment for Hermes is made up of physical barriers, operating conditions, coolant design, and fuel form that limit the potential release of radioactive material
- Majority of radioactive material at risk for release is held within the design of TRISO fuel
  - Further discussion of TRISO fuel in PSAR Section 4.2
- Retention properties of Flibe act as an additional barrier for release of radionuclides for submerged fuel
  - Further discussion of the radionuclide retention capabilities of Flibe in PSAR Section 5.1
- Specified acceptable system radionuclide release design limits (SARRDLs) are met by controlling the reactor conditions (e.g., temperature and flux) that result in limiting allowable fuel conditions. Safety limits discussed in Chapter 14 will ensure SARRDLs are not exceeded, and potential dose consequences remain below dose targets.
  - SARRDLs and technical specifications will be described in the application for an operating license


## 6.3 Decay Heat Removal System: Overview



- Purpose: Passive decay heat removal during postulated events when the primary heat transport system is unavailable
- Operation: DHRS is an ex-vessel system that continuously operates when the reactor is operating above a threshold power by removing energy from the vessel wall via thermal radiation and convective heat transfer to water-based annular thermosyphons (thimbles)
  - DHRS is shut off and isolated when reactor operates at low power levels (parasitic losses alone are sufficient for decay heat removal)
  - DHRS is activated when reactor starts operating above threshold power
  - No change of state when relied upon in response to postulated event
- Passive Feedback Mechanism
  - Heat removal rate is a direct function of vessel temperature due to physics of thermal radiation heat transfer


# 6.3 DHRS: Operation

Normal Operation  
(DHRS deactivated)



# 6.3 DHRS: Operation


## Normal Operation






# 6.3 DHRS: Operation

Postulated Event  
(e.g., loss of PHTS,  
loss of electrical power,  
loss of feedwater)




## 6.3 DHRS: Process Flow Diagram



- DHRS does not directly interact with reactor coolant
- No change of state on onset of postulated events
  - Always-on operation above set power levels
- Parallel and independent cooling pathways
  - Four independent cooling trains
  - Only three trains required to meet cooling demand
- Dual-walled for leak prevention and detection
  - Continued heat removal in the presence of a leak
- Active component (isolation valve) failures do not introduce failures in heat removal
  - Isolation valve fails in place (an operating system continues to operate)
  - Float valve fails open


## 6.3 DHRS: Water Storage Tank

- Sizing
  - Sufficient inventory for up to 7 days of continuous operation to support heat removal to mitigate postulated events
- Location
  - Outside of reactor cavity
  - Higher elevation than other DHRS components
  - Gravity-driven flow of water to separator and thimbles
- Redundancy / Independence
  - 3 out of 4 tanks needed for adequate heat removal
  - Each tank is independent in its location and connection to thimbles



# 6.3 DHRS: Separator and Thimble

- Separator
  - Interface between water storage tank and thimbles
  - Float valve
    - When water level exceeds threshold value, the float valve blocks the feedwater line
    - When water level is below threshold value, the float valve allows for continuous flow
  - Passive operation and fail-open design
    - Floods separator
    - Does not affect the net heat removal performance of the thimbles
- Thimble
  - Annular thermosyphons located circumferentially around the outside of the reactor vessel
  - Guide tube located within evaporator tube
  - Leak barrier
    - Dual wall design – still can remove heat
  - Passive flow



## 6.3 Decay Heat Removal System: Design Basis

---

- Safety-related portions of DHRS are designed to ASME III Div. 5 Class B, ASCE 43-19, ASCE 4-16, and ACI 349-13 codes and standards (PDC 1)
- DHRS is primarily located in the safety-related portion of the reactor building, which is designed to protect safety-related components from external hazards. Failure of non-safety related DHRS components does not affect the performance of safety-related SSCs (PDC 2)
- DHRS is designed with low combustible materials and uses physical separation of the trains to minimize the probability and effect of fires and explosions (PDC 3)
- DHRS is designed with materials that will withstand the environmental conditions in the reactor cavity during normal operation, maintenance, testing, and postulated events. DHRS components are designed to preclude cascading failures and failures that could impact nearby safety systems (PDC 4)
- DHRS is capable of removing an adequate amount of decay heat to ensure that SARRDLs are not exceeded, and reactor vessel and fuel temperatures remain below their design limits (PDC 34 and 35)
- DHRS is designed to allow for periodic inspection and functional testing to ensure integrity, operability, and performance of the system (PDC 36 and 37)



# Kairos Power

## Hermes PSAR Chapter 9 Auxiliary Systems

ACRS KAIROS POWER SUBCOMMITTEE MEETING

MARCH 24, 2023

---

NICO ZWEIBAUM – DIRECTOR, SALT SYSTEMS DESIGN

KIERAN DOLAN – SENIOR ENGINEER, FUELS AND MATERIALS

ANDREW LINGENFELTER – SENIOR ENGINEER, ENGINEERING DESIGN

ANTHONIE CILLIERS – DIRECTOR, INSTRUMENTATION AND CONTROLS

MARGARET ELLENSON – MANAGER, NUCLEAR FACILITIES AND SAFEGUARDS AND SECURITY

# 9.1 Reactor Auxiliary Systems Overview

---

- The reactor coolant auxiliary systems are a collection of systems that provide support for the functionality and performance of Flibe:
  - Remove fission products, activation products, and other chemical impurities and particulates from the reactor coolant
  - Maintain the cover gas atmosphere (pressure and composition) in the head space above the core
  - Provide removal and storage of tritium
  - Control inventory, filling, and draining processes for systems containing reactor coolant, including transfer of coolant into the reactor
  - Provide active and passive thermal management to reactor system components
- These functions are implemented into the following reactor coolant auxiliary systems:
  - Chemistry control system
  - Inert gas system
  - Tritium management system
  - Inventory management system
  - Reactor thermal management system
- These systems are not credited with performing any safety-related functions

## 9.1.1 Chemistry Control System

---

- The CCS is not credited with performing any safety-related functions
- The CCS monitors primary coolant chemistry for compliance with Flibe specifications
- The CCS extracts coolant samples for an offline analysis of the Flibe chemistry
- Due to the proximity of the CCS to the reactor vessel, the CCS is designed so that seismic induced failure does not impact the reactor vessel system (PDC 2)
- Due to the proximity of the CCS to the reactor vessel, the CCS is designed so that adverse effects of postulated CCS failures do not impact the reactor vessel system (PDC 4)
- The CCS monitors the reactor coolant purity with offline sampling analysis to determine if the reactor coolant is within specified design limits (PDC 70)
- Consistent with 10 CFR 20.1406, the CCS is designed, to the extent practicable, to minimize contamination of the facility and the environment, and facilitate eventual decommissioning



## 9.1.2 Inert Gas System

---

- The IGS is not credited with performing any safety-related functions
- Provides inert argon gas as a purging flow to system components during normal operation and maintenance
- Removes impurities from the cover gas
- Provides reactor coolant motive pressure during filling and draining operations
- The IGS may be in proximity or connected to safety-related SSCs and may cross the seismic isolation moat. The IGS is designed so that seismic induced failure does not impact safety-related SSCs from performing their safety function (PDC 2)
- The IGS is a low-pressure system and precludes pipe whip. Nearby safety-related SSCs will not be affected by escaping inert argon gas (PDC 4)
- The IGS monitors radioactivity levels in the gas to support the evaluation of the radioactive material releases that might occur as a result of a system or fuel failure (PDC 64)
- Consistent with 10 CFR 20.1406, the IGS is designed, to the extent practicable, to minimize contamination of the facility and the environment, and facilitate eventual decommissioning

## 9.1.3 Tritium Management System

---

- The TMS is not credited with performing any safety-related functions
- TMS separates tritium from argon in the inert gas system and from dry air in the Reactor Building cells
- TMS collects and temporarily stores tritium for final disposition
  - In accordance with 10 CFR 71.51, Type A and Type B packaging canisters are used
- Due to the potential proximity of the TMS to the reactor vessel, the TMS is designed so that seismic-induced failure does not impact the reactor vessel system (PDC 2)
- Tritium monitoring sensors are selected to provide measurements over a range of anticipated tritium activities where measurements are needed (PDC 13)
- The TMS maintains a minimum level of overall tritium capture capacity in order to minimize tritium releases from the plant (PDC 60)
- Radiation monitoring is provided in the TMS for the evaluation of tritium levels in TMS subsystems in support of evaluation of radioactive material releases that might occur as a result of a system failure (PDC 64)
- Consistent with 10 CFR 20.1406, the TMS is designed, to the extent practicable, to minimize contamination of the facility and the environment, and facilitate eventual decommissioning

## 9.1.4 Inventory Management System

---

- The IMS is not credited with performing any safety-related functions
- The IMS maintains primary coolant level in the reactor vessel during normal operations
- The IMS fills and drains the reactor vessel and the primary heat transport system during start-up and shutdown operations
- The IMS maintains primary coolant purity by replacing circulating salt with new salt
- Due to the proximity of the IMS to the reactor vessel, the IMS is designed so that seismic-induced failure does not impact the reactor vessel system (PDC 2)
- Due to the proximity of the IMS to the reactor vessel, the IMS is designed so that adverse effects of postulated IMS failures do not impact the reactor vessel system (PDC 4)
- The IMS includes design features to limit the loss of reactor vessel coolant inventory in the event of breaks in the system (PDC 33)
- The IMS may be used to remove and replace a sufficient amount of reactor coolant to restore conformance to the Flibe specification (PDC 70)
- Consistent with 10 CFR 20.1406, the IMS is designed, to the extent practicable, to minimize contamination of the facility and the environment, and facilitate eventual decommissioning

## 9.1.5 Reactor Thermal Management System

---

- The RTMS is not credited with performing any safety-related functions
- Nearby safety-related SSCs are protected from RTMS failure in the event of an earthquake (PDC 2)
- The RTMS uses water cooling to transfer heat from SSCs to the ultimate heat sink during normal operation and maintains the operational temperature limits of concrete structures during normal operations (PDC 44)
- The system is designed to permit periodic appropriate inspections and testing to ensure integrity and capability to cool SSCs and to ensure adequate interface with other systems supporting heat transfer to the ultimate heat sink (PDC 45, PDC 46)
- RTMS is designed to pre-heat the reactor vessel and to ensure Flibe in the vessel is maintained above a minimum operating temperature (PDC 71)
- Consistent with 10 CFR 20.1406, the RTMS is designed, to the extent practicable, to minimize contamination of the facility and the environment, and facilitate eventual decommissioning

## 9.2 Reactor Building Heating, Ventilation, and Air Conditioning System

---


- The RBHVAC is not credited to perform any safety-related functions
- Reactor building heating, ventilation, and air conditioning system provides independent environmental control to the reactor building
  - The system is designed to ensure occupational dose does not exceed 10 CFR 20 limits
- Consistent with 10 CFR 20.1406, the RBHVAC is designed, to the extent practicable, to minimize contamination of the facility and the environment, and facilitate eventual decommissioning
- RBHVAC does not adversely affect safety-related SSCs located nearby (PDC 2)
- RBHVAC is designed to control the release of radioactive materials in gaseous effluents during normal operation (PDC 60)
- RBHVAC is designed to provide for monitoring of the RB effluent discharge paths for radioactivity that may be release during normal operation (PDC 64)

## 9.3 Pebble Handling and Storage System

---

- Responsible for handling of fuel in Hermes, from initial on-site receipt, in-process circulation, and final on-site storage
- Major components of the system:
  - Pebble Extraction Machine (PEM): Single screw mechanism removes pebbles from molten salt
  - Pebble Inspection: Performs flaw detection and burn-up measurement of removed pebbles
  - Processing: Sorts pebbles into appropriate buffer storage channel based on pebble type
  - Insertion: Stepper wheel feeder mechanism inserts pebbles into the reactor via an in-vessel insertion line
  - Storage Canister: Stores ~2,000 fuel pebbles in a non-critical configuration
  - Storage Cooling Area: In-building storage area for spent fuel canisters, capable of passive cooling during loss of power and other postulated events
  - New Pebble Introduction: Stores fresh fuel and prepares fuel for circulation via a high-temperature bakeout

# 9.3 Pebble Handling and Storage System



## 9.3 Pebble Handling and Storage System: Design Basis

---

- Storage bay, pool and support restraint structures in the pool are designed as seismic category SDC-3 to ensure geometry is maintained in the event of an earthquake (PDC 2)
- System limits grinding of pebbles and the accumulation of graphite dust to minimize the potential of fire and explosion (PDC 3)
- The canister design considers environmental conditions such as pressure accumulation of radionuclides and thermal loads; the canister interior accounts for radiolysis products. The system design accounts for complete submergence and internal flooding of the storage canisters in water. (PDC 4)
- An anti-siphon feature on the pebble insertion line limits inventory loss to primary salt pump elevation, the PEM is above the coolant free surface (PDC 33)
- The TRISO particle confines radioactive material rather than the PHSS and pebble loads do not introduce incremental particle failures thereby ensuring the PHSS does not act to confine or contain radioactivity (PDC 61)
- The design prevents criticality by controlling pebble removal rate. The system design precludes moisture intrusion and handling equipment maintains geometry via interlocks. (PDC 62)
- The inspection and sorting function ensures damaged pebbles are removed from use (PDC 63)



## 9.4 Fire Protection Systems and Programs

---

- The fire protection system is not credited with performing any safety-related functions
- Designed to detect and extinguish fires so that a continuing fire will not prevent safe shutdown (PDC 3)
- Noncombustible and fire-resistant materials are used whenever practical, particularly in locations with SSCs that are safety-related or required for safe shutdown (PDC 3)
- The fire protection system will conform to local building and fire codes, ANSI/ANS 15.17 “Fire Protection Program for Research Reactors,” NFPA 801, and Life Safety Code NFPA 101
- The system is designed so that seismic induced failure does not impact nearby safety-related SSCs (PDC 2)

# 9.5 Communication

---

- The communication system is not credited with performing any safety-related functions
- Composed of diverse and independent subsystems:
  - Plant radio
  - Public address and general alarm
  - Communication capability in the event of a loss of normal power
  - Distributed antenna
  - Security communication
  - In addition, diverse commercial communication systems will be utilized for on- and off-site communication
- Used for normal and emergency conditions to communicate between key areas of the facility
- Phone lines area available for off-site communication in the case of an emergency

## 9.6 Possession and Use of Byproduct, Source, and Special Nuclear Material

---

- Byproduct material is managed by compliance with 10 CFR Part 30 , by use of spent fuel canisters, by the tritium management system, and by the radioactive waste management program
- Source material is managed by compliance with 10 CFR Part 40, by use of fresh and spent fuel canisters, and by the nature of the pebble design, in which the source material is encapsulated in a graphite substrate
- Special nuclear material (SNM) is managed by compliance with 10 CFR Part 70, by the use of fresh and spent fuel canisters, by the pebble handling and storage system, which includes shielding, by the reactor vessel, and by the nature of the pebble design, in which the SNM is encapsulated in a graphite substrate
- Requests for materials licenses will be submitted at a future date

# 9.7 Plant Water Systems

---

- The water systems are not credited with performing any safety-related functions
- Service water system is the facilities main supply of water and provides water to the treated water system
- Treated Water System provides chemistry control of the service water and provides water to the component cooling water, chilled water, and decay heat removal systems
  - Treated water is designed to protect against design basis earthquake for nearby safety-related SSCs (PDC 2)
  - Nearby safety-related SSCs are protected from the effects of discharging fluid and missiles and precluded from pipe whip hazards by design (PDC 4)
- Component cooling water system provides water cooling for reactor building HVAC systems, the equipment and structural cooling system, spent fuel cooling system, and the inert gas system coolers and compressors
  - The system is designed to protect against design basis earthquake for nearby safety-related SSCs (PDC 2)
  - Nearby safety-related SSCs are protected from the effects of discharging fluid and missiles and precluded from pipe whip hazards by design (PDC 4)
  - The system is designed with the capability to isolate leaks, permit appropriate periodic inspection and testing to ensure the integrity and capability of the system to cool SSCs, and to adequately transfer heat to the ultimate heat sink (PDC 44, 45, and 46)
- Chilled water system provides cooling water for nonessential heat loads
- Consistent with 10 CFR 20.1406, the plant water systems that directly interface with the systems that contain radioactive material are designed, to the extent practicable, to minimize contamination of the facility and the environment, and facilitate eventual decommissioning

# 9.8.1 Remote Maintenance and Inspection System

---

- The remote maintenance and inspection system (RMIS) is not credited with performing any safety-related functions
- The RMIS can remotely handle components in the reactor system, PHTS, and PHSS
- RMIS supports the following maintenance activities:
  - Disassemble flanges and subassemblies
  - Remove subassemblies
  - Clear fuel and residual coolant before removal of SSCs for maintenance
  - Transport of equipment to hot maintenance cells (via use of shielded casks)
  - Activities performed in standalone hot cells
  - Use of through-wall electro-mechanical manipulators for hot cells
  - Use of cranes for hot cell and post-irradiation examination facilities
- Consistent with 10 CFR 20.1406, the RMIS is designed, to the extent practicable, to minimize contamination of the facility and the environment, and facilitate eventual decommissioning
- The capabilities of RMIS will limit the personnel occupational exposures to below 10 CFR Part 20 limits

## 9.8.2 Spent Fuel Cooling System

---

- The spent fuel cooling system (SFCS) is not credited with performing any safety-related functions
- The SFCS provides forced air cooling for spent fuel storage canisters in the storage bay of the PHSS and recirculates water in the spent fuel pool
  - Consists of fans and piping that remove heat during normal operation
  - Maintains desired operational temperatures in the storage bay
- In the event normal power is not available, the SFCS is capable of passively cooling spent fuel storage canisters
- The system is designed to ensure nearby safety-related SSCs are protected from seismic-induced failure (PDC 2)
- Nearby safety-related SSCs are protected from dynamic effects such as missiles by design (PDC 4)
- Consistent with 10 CFR 20.1406, the SFCS is designed, to the extent practicable, to minimize contamination of the facility and the environment, and facilitate eventual decommissioning

## 9.8.3 Compressed Air System

---

- The compressed air system is not credited with performing any safety-related functions
- The compressed air system provides and distributes compressed air for maintenance and use in valve operation
- The system is designed so that a failure of the system does not interfere or preclude the ability of a safety-related system to perform its safety function
- The system does not directly interface with systems that contain or have the potential to contain radioactive materials

## 9.8.4 Cranes and Rigging

---

- The crane and rigging is not credited with performing any safety-related functions
- A crane and rigging are provided to lift and move equipment within the reactor building, facilitate receiving and shipping, and support maintenance activities
- The system is designed to ensure nearby safety-related SSCs are protected from seismic induced failure (PDC 2)
- Nearby safety-related SSCs are protected from dynamic effects by design, such as administrative controls and interlocks (PDC 4)
- Implements codes and standards from ASME B30.2-2016



## 9.8.5 Auxiliary Site Services

---

- Auxiliary site services is not credited with performing any safety-related functions
- The following services provide additional functions necessary to maintain and operate the plant:
  - Machine shop(s), which include radioactive and non-radioactive machining capabilities
  - Chemistry laboratory
  - Post-irradiation examination laboratory
  - Materials testing laboratory
  - Vents and drains for non-potentially contaminated facility compartments
  - Warehouse(s) for storage of spare equipment
  - Storage of contaminated equipment
  - Facility lighting, including emergency lighting
  - Non-hazardous waste management services
  - Firewater storage systems
  - Storm and sanitary sewers
  - Groundwater monitoring wells
- The system is designed to ensure nearby safety-related SSCs are protected from seismic induced failure (PDC 2)
- The capabilities of the Auxiliary Site Services will limit the personnel occupational exposures to below 10 CFR Part 20 limits
- Services that involve handling of radioactive material may include remote manipulation capabilities, as appropriate, to facilitate limiting personnel occupational exposures to below 10 CFR Part 20 limits



# **NRC Staff Review for PSAR Chapter 1 The Facility**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**Thursday, March 23, 2023**

By the Division of Advanced Reactors and Non-Power Production and  
Utilization Facilities,  
Office of Nuclear Reactor Regulation

# Agenda

---

- Introduction
- Regulatory Requirements
- CP Application Review Overview
- Summary of Chapter 1 Review

# Introduction

- Kairos Power LLC has requested a construction permit for a 35 MWth\* non-power reactor facility known as Hermes
  - **Purpose:** test and demonstrate key technologies, design features, and safety functions for the commercial Kairos Power fluoride salt-cooled, high temperature reactor (KP-FHR) structures, systems, and components (SSCs)
  - **Location:** East Tennessee Technology Park near Oak Ridge
- Hermes would be licensed as a non-power reactor under Title 10 of the *Code of Federal Regulations* (10 CFR) Part 50
  - Class 104 license per 10 CFR 50.21(c) for testing research and development

\*MWth = megawatts of thermal power

# Regulatory Requirements

- The staff's evaluation of Hermes' preliminary design and analysis was based primarily upon the following 10 CFR requirements:
  - 10 CFR 50.2, "Definitions."
  - 10 CFR 50.21, "Class 104 licenses; for medical therapy and research and development facilities," paragraph (c).
  - 10 CFR 50.33, "Contents of applications; general information," paragraph (f).
  - 10 CFR 50.34, "Contents of applications; technical information," paragraph (a), "Preliminary safety analysis report."
  - 10 CFR 50.35, "Issuance of construction permits."
  - 10 CFR 50.40, "Common standards."
  - 10 CFR 50.41, "Additional standards for class 104 licenses."
  - 10 CFR 50.50, "Issuance of licenses and construction permits."
  - 10 CFR 50.55, "Conditions of construction permits, early site permits, combined licenses, and manufacturing licenses."
  - 10 CFR 50.58, "Hearings and report of the Advisory Committee on Reactor Safeguards."
  - 10 CFR Part 50, Appendix C, "A Guide for the Financial Data and Related Information Required to Establish Financial Qualifications for Construction Permits and Combined Licenses."
  - 10 CFR Part 50, Appendix E, "Emergency Planning and Preparedness for Production and Utilization Facilities."

# CP Application Review Overview

- Preliminary Safety Analysis Report, Revision 2, dated February 24, 2023 (ADAMS Accession No. ML23055A672)
- Construction Permit
  - Allows licensee to proceed with construction based on preliminary design information
  - Does not approve of the safety of any design feature or specification unless specifically requested by the applicant
- Regulatory Guidance and Acceptance Criteria
  - NUREG 1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors”
  - Other guidance (e.g., regulatory guides and ANSI/ANS standards) and engineering judgment used, as appropriate, to make construction permit findings

# Summary of Chapter 1 Review

- PSAR Section 1.1, “Introduction”
- PSAR Section 1.2, “Summary and Conclusions on Principal Safety Considerations”
  - Applicable standards and requirements of the Atomic Energy Act and NRC regulations have been met.
- PSAR Section 1.3, “General Description”
- PSAR Section 1.4, “Shared Facilities and Equipment”
  - No existing facilities or equipment will be shared by Hermes, and any site infrastructure that may be shared is not needed to perform a safety function.

# Summary of Chapter 1 Review

- PSAR Section 1.6, “Summary of Operations”
  - Kairos’ preliminary information on proposed Hermes operation is consistent with relevant assumptions and analyses later in the PSAR in which any safety implications of the proposed operations are evaluated.
- PSAR Section 1.7, “Compliance with the Nuclear Waste Policy Act of 1982”
  - Kairos is in compliance with the NWPA for the CP stage based on its documentation of communication with the Department of Energy to enter into a contract for the disposition of high-level waste.
- PSAR Section 1.8, “Facility Modifications and History”
  - There are no existing facilities or modifications with respect to the Hermes facility.



# Ongoing Research and Development (PSAR Section 1.3.9)

- 10 CFR 50.34(a)(8) requires identification of SSCs requiring R&D
- PSAR Section 1.3.9 identifies the following R&D activities:
  - Confirm fuel pebble behavior (PSAR Section 4.2.1).
  - Material surveillance sampling program for the reactor vessel and internals (PSAR Section 4.3.4).
  - Testing of high temperature material to qualify Alloy 316H and ER16-8-2 (PSAR Section 4.3).
  - Analysis of potential graphite oxidation in certain postulated (PSAR Section 4.3).
  - Validation of computer codes for core design and analysis methodology (PSAR Section 4.5).
  - Development and qualification testing of a fluidic diode device (PSAR Section 4.6).
  - Justification of thermodynamic data and associated vapor pressure correlations of representative species (PSAR Section 5.1.3).
  - Develop process sensor technology for key reactor process variables (PSAR Section 7.5.3).
  - Develop the reactor coolant chemical monitoring instrumentation (PSAR Section 9.1.1).
- Activities will be completed before the completion of construction, which is expected by December 2026
- The staff is tracking these activities and will verify their resolution prior to the completion of construction

# PSAR Section 1.5, “Comparison with Similar Facilities”

- Key Similar Facilities
  - Molten Salt Reactor Experiment (MSRE) – molten fluoride salt coolant (with liquid fuel)
  - Pebble Bed Reactors (PBRs) - use of pebbles with TRISO fuel particles.
  - High temperature gas reactors (HTGRs) at Peach Bottom 1 and Ft. St. Vrain - TRISO particle fuel in non-pebble form
  - Advanced Gas Reactor (AGR) in the United Kingdom - use of graphite as a neutron moderator
- The staff finds:
  - Kairos has compared the design bases and safety considerations of Hermes with similar facilities.
  - Aspects of the Hermes design that are similar to features in other facilities should be expected to perform in a similar manner to these comparable features in other facilities.
  - Kairos is using test data and operational experience from facilities with similar components and design features in designing Hermes components, as practicable.

Questions?



# **NRC Staff Review for PSAR Sections 3.1 and 3.6**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**March 23, 2023**

By the Division of Advanced Reactors and Non-Power Production and  
Utilization Facilities,  
Office of Nuclear Reactor Regulation

# Agenda

---

- PSAR Section 3.1, “Design Criteria”
  - Overview and Regulatory Basis
  - Staff Technical Evaluation and Conclusions
  - Regulatory Findings
- PSAR Section 3.6, “Systems and Components”
  - Overview and Regulatory Basis
  - Staff Technical Evaluation and Conclusions
  - Regulatory Findings

# Overview of PSAR Section 3.1

---

- The principal design criteria (PDC) for the Hermes reactor are based on the approved topical report KP-TR-003-NP, “Principal Design Criteria for the Kairos Power Fluoride Salt-Cooled High Temperature Reactor.”
- In this section Kairos identifies the relevant regulations and PDCs for the Hermes reactor, as well as the NRC guidance considered in the design

# Regulatory Basis

---

- 10 CFR Section 50.34(a), “Preliminary safety analysis report”
- 10 CFR 50.35, “Issuance of construction permits”
- 10 CFR 50.40, “Common standards”

# Staff Technical Evaluation: Review Process

---

- The NRC staff used the following guidance in its evaluation of the Hermes design criteria:
  - Relevant parts of NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors”
  - Regulatory Guide (RG) 1.232, “Guidance for Developing Principal Design Criteria for Non-Light Water Reactors,” Revision 0
- The staff review included consideration of the limitations and conditions from the staff SE for KP-TR-003-NP.



## Section 3.1 Staff Technical Evaluation

---

- Limitations and conditions from the staff SE for KP-TR-003-NP:
  1. Key design features of Hermes are consistent with those in KP-TR-003-NP
  2. Manufacturing license scope – not applicable to Hermes
  3. NRC-approved guidance to endorse NEI 18-04, “Risk-Informed Performance-Based Technology-Inclusive Guidance for Non-Light Water Reactor Licensing Basis Development,” Revision 1
    - Not applicable because Hermes follows the guidance of NUREG-1537 instead of NEI 18-04
  4. Use of the term “safety-related”
    - Hermes uses “safety-related” consistent with 10 CFR 50.2
- Terminology
  - “Safety-related” used instead of “safety significant”
  - “Postulated events” used consistent with NUREG-1537

## Section 3.1 Regulatory Findings

---

- The NRC staff finds the design information is consistent with the guidance in RG 1.232 and the applicable criteria in NUREG-1537.
- The staff concludes that the information in Hermes PSAR Section 3.1 is sufficient for the issuance of a construction permit in accordance with 10 CFR 50.35 and 50.40, and further information can be reasonably left for the OL application.

# Overview of PSAR Section 3.6

---

- PSAR Section 3.6, “Systems and Components,” describes the design bases for the systems and components required to function for safe reactor operation and shutdown.
- PSAR Section 3.6.1 “General Design Basis Information,” describes the safety functions performed by safety-related SSCs:
  - preventing uncontrolled releases of radionuclides,
  - removal of decay heat following a successful reactor trip and
  - control of reactivity
- PSAR Section 3.6.2 “Classification of Structures, Systems, and Components,” describes how SSCs are classified.

# Staff Technical Evaluation: Review Process

---

- The NRC staff used the following guidance in its evaluation of the Hermes design criteria:
  - Relevant parts of NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors”
  - RG 1.29, “Seismic Design Classification for Nuclear Power Plants,” Revision 6, ML21155A003
  - RG 1.143, “Design Guidance for Radioactive Waste Management Systems, Structures, and Components Installed in Light-Water-Cooled Nuclear Power Plants,” Revision 2, ML013100305
  - RG 1.87, “Acceptability of ASME Section III, Division 5, High Temperature Reactors,” Revision 2, ML22101A263
- The staff review covered the design bases and safety, seismic, and quality classifications.

# Staff Technical Evaluation – Design Basis

---

- Design and construction codes and standards for fluid systems are consistent with RG 1.143 and acceptable.
- High-level safety functions are met by Hermes design because:
  - Reactor vessel and internals support a coolable core geometry and natural circulation for heat transfer to DHRS
  - DHRS operates to remove heat from the core for at least 72 hours following a postulated event where normal cooling systems are unavailable.
  - TRISO fuel pebbles and the Flibe coolant contain fission products.
  - Reactivity control and shutdown system shuts down the reactor and maintains reactor shutdown after an earthquake event
  - Safety-related portion of the Reactor Building protects the reactor vessel and other safety-related SSCs from natural phenomena

# Staff Technical Evaluation – Safety and Seismic

---

- Safety Classification
  - The safety-related classifications of SSCs in Table 3.6-1 meet the definition requirements of 10 CFR 50.2 with one exception:
    - “integrity of the portions of the reactor coolant boundary relied upon to maintain coolant level above the active core.”
- Seismic Classification
  - The NRC staff finds that the safety and seismic classification conforms with the guidance in RG 1.29, because safety related SSCs are assigned correctly to the seismic classification, SDC-3, in accordance with ASCE 43-19.
  - The seismic qualification by analysis and testing will be performed in accordance with Section 8.2 and 8.3 of ASCE 43-19.

# Staff Technical Evaluation – Quality

---

- All safety related SSCs are assigned to a quality-related classification.
  - This conforms to RG 1.29 guidance and is acceptable to NRC staff
- ASME Code, Section III, Division 5, will be used for design and fabrication of safety-related mechanical components
  - ANSI/ANS 15.8-1995 (R2005) quality assurance program used rather than NQA-1
- The methodology of load combinations conforms to RG 1.143 Table 3 “Design Load Combinations.”
  - Design transients loading and the number of cycles will be included with the OL application.
- The staff finds that non-condensable gases in the reactor coolant system would not cause a loss of function and present no undue risk, because the design already includes an inert gas blanket above the Flibe coolant.

## Section 3.6 Regulatory Findings

---

- The NRC staff finds the preliminary design information is consistent with the applicable criteria in NUREG-1537.
- The staff concludes that the information in Hermes PSAR Section 3.6 is sufficient for the issuance of a construction permit in accordance with 10 CFR 50.35 and 50.40, and further information can be reasonably left for the OL application.



Questions?



# **NRC Staff Review for PSAR Sections 2.1 – 2.4, 3.2, and 3.3**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**March 23, 2023**

By the Division of Engineering and External Hazards,  
Office of Nuclear Reactor Regulation

# Sections 2.1 – 2.4, 3.2, and 3.3

---

- Format
  - 2.1: Geography and Demography
  - 2.2: Nearby Industrial, Transportation, and Military Facilities
  - 2.3: Meteorology
  - 2.4: Hydrology
  - 3.2: Meteorological Damage
  - 3.3: Water Damage

# Overview of staff review

---

- Kairos applied for a CP and has not specifically requested approval of detailed design information
- Kairos provided a preliminary design description and a discussion of the relevant design bases (e.g., PDCs)
- NRC staff assessed whether the preliminary design information, including identification of relevant design bases, is sufficient to allow the staff to determine that
  - The information meets the relevant regulations for the issuance of a CP
  - The detailed design information can be left to the OL application

# Section 2.1 -2.4 Regulatory Basis

---

- Common to Sections 2.1 to 2.4
  - 10 CFR 50.34(a), “Preliminary safety analysis report.”
  - 10 CFR 50.35, “Issuance of construction permits.”
  - 10 CFR 50.40, “Common standards.”
  - 10 CFR 100.10, “Factors to be considered when evaluating sites.”
  - **Relevant guidance:** NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors,” Part 2, “Standard Review Plan and Acceptance Criteria.”
- Section 2.1 only:
  - 10 CFR 100.11(a), “Determination of exclusion area, low population zone, and population center distance”
  - NRC Regulatory Guide (RG) 2.6, “Emergency Planning for Research and Test Reactors,” Revision 2.
  - American National Standards Institute/American Nuclear Society (ANSI/ANS)-15.16-2015, “Emergency Planning for Research Reactors.”
- Section 2.2 only:
  - NRC RG 1.91, “Evaluations of Explosions Postulated to Occur at Nearby Facilities and on Transportation Routes Near Nuclear Power Plants,” Revision 2.

# PSAR Section 2.1: Geography and Demography

- Site located on previous K-31 and K-33 (Oak Ridge Reservation Gas Diffusion Plant to enrich uranium)
- Site within 0.5 mi is flat
- Exclusion Area Boundary (EAB) coincides with site boundary
- Low Population Zone (LPZ) 0.5 mi
- Emergency Planning Zone (EPZ) boundary set to coincide with site boundary
- Nearest population center is the City of Oak Ridge (2020 Census: 31,402)
- Population projection till 2031 based on Boyd Center for Business and Economic Research, Tennessee

# PSAR Section 2.2: Nearby Industrial, Transportation, and Military Installations

- Used Site Safety Analysis Report (SSAR) of the Early Site Permit (ESP) application of the Clinch River Nuclear Site
  - Except for flight operations at Future Oak Ridge Airport
- Audit: Total 5 questions



# Sections 2.1 and 2.2 Findings

- Sources of potential hazards (detonation, flammable vapor clouds, toxic chemicals, and fires) from nearby pipelines, highways, railways, waterways, and facilities assessed (PSAR Section 2.2)
  - Distance from the site/facility
  - Quantity of hazardous materials released
  - Potential consequences
- Main Control Room equipped with Chlorine and Ammonia detectors
- Potential aircraft crashes from Oak Ridge Airport significantly high
  - Safety-related portion of Reactor Building will be designed for a crashing small General Aviation aircraft
- Information in PSAR Section 2.1 (Geography and Demography) and 2.2 (Nearby Industrial, Military, and Transportation Facilities) is sufficient and meets the applicable guidance and regulatory requirements to issue construction permit in accordance with 10 CFR 50.35



# Section 2.3 Meteorology

---

## Regional Climatology and Local Meteorology

The review of these sections included:

- Thunderstorms, Hail, Lightening
- Extreme Weather Conditions
- Hurricanes, Tornadoes, Winter Precipitation Events
- Wind, Temperature, Precipitation, Atmospheric Stability

NRC staff reviewed:

- The description of the general climate of the region and meteorological conditions relevant to the design and operation of the facility
- The data resources and analytical approaches used by the applicant to prepare the information

NRC staff concludes that the site characteristics associated with the regional climatology and local meteorology are representative of the region of the proposed site and therefore acceptable for use in evaluating the conditions at the proposed site.

## Section 2.3 Meteorology

---

### **Meteorological Monitoring Program and Atmospheric Dispersion Modeling**

The review of these sections included:

- The description of the location and measurements taken at the network of meteorological towers
- The methodology used for atmospheric dispersion modeling

NRC staff reviewed:

- The information describing the network of meteorological towers and their measurement capabilities
- The data taken from the towers to support dispersion analyses at the proposed site.
- The methodology, inputs, and assumptions used in the short term atmospheric dispersion analysis.
- (Kairos states that modeling for routine releases will be provided in the OL application)

NRC staff concludes that:

- Kairos' meteorological monitoring program is acceptable
- The meteorological data set provided is representative of the proposed site and sufficient to support dispersion analyses
- Kairos' short term atmospheric dispersion analysis and calculated dispersion factors for the EAB and LPZ boundary are acceptable

## Section 2.3 Regulatory Findings

---

- NRC staff concludes, based on the review of the information provided in the application, subsequent RAI responses, and the staff's technical evaluation, that the information on meteorology in Hermes PSAR Section 2.3 is sufficient and meets the applicable guidance and regulatory requirements for the issuance of a construction permit in accordance with 10 CFR 50.35.
- Further information on meteorology, namely the details regarding long-term dispersion modeling, can reasonably be left for later consideration in the OL application.

# Staff Evaluation of Hydrology

- The applicant provided information on the following topics:
  - Hydrological Description and Flood Record (Hydrologic Setting)
  - Design-Basis Flood Elevation Based on Industry Accepted Methods
  - Hypothetical Dam Failures Scenarios Using Information from TVA
  - Groundwater Levels and Mitigating Measures Based on the Following:
    - The groundwater levels are about 10 feet below grade.
    - There is no groundwater extraction and injection to operate Hermes.
    - The leak of reactor coolant is solidified and confined in the plant building.
    - The fission products, such as tritium, are monitored and confined in the plant.
    - An environmental monitoring program will be implemented to detect any radiological releases beyond normal operational releases.

# Hydrology Technical Evaluation Conclusions

- The staff finds:
  - The Hermes site elevation provides approximately 5 feet safety margin above the design-basis flood elevation for the stream and river flood.
  - The design-basis flood elevation for the stream and river flood is higher than FEMA's 500-year flood elevation by approximately 10 feet.
  - The site presents no significant risk to the Hermes facilities due to the postulated flood events.
  - The facility design bases include mitigation and prevention of uncontrolled leakage or loss of reactor coolant to groundwater and surface water.
- Based on above findings, the site hydrology demonstrates that the Hermes site is an adequate site to support facility design bases and satisfies the applicable acceptance criteria of NUREG-1537, Part 2, Section 2.4.

# Regulatory Findings on Hydrology

- The staff finds there is reasonable assurance that the preliminary information conforms with 10 CFR 100.10 (c)(3) and supports 10 CFR 50.34(a)(1)(i) by
  - providing flood hazard analyses and site evaluation factors with the objective of assessing the risk to public health and safety resulting from operation of the facility and including determination of the safety margins for design-basis flood elevation for the site.
- The staff concludes that the information on hydrology in Hermes PSAR Section 2.4 is sufficient and meets the applicable guidance and regulatory requirements identified in this section for the issuance of a construction permit in accordance with 10 CFR 50.35, and additional information on hydrology can reasonably be left for later consideration in the OL application.

# PSAR Sections 3.2 and 3.3 Meteorological and Water Damage Overview

- Addresses safety-related structures designed to cope with meteorological damage and water damage, including internal and external floods
- Meteorological loading determined in accordance with ASCE/SEI 7-10
- External flood levels based on reviewed data in Chapter 2

# Section 3.2 and 3.3 Regulatory Basis

- 10 CFR 50.34(a), “Preliminary safety analysis report”
- 10 CFR 50.35 “Issuance of construction permits”
- 10 CFR 50.40, “Common standards”
  
- PDC 2 – “Design bases for protection against natural phenomena” which has been approved by the staff (KP-TR-003-NP-A)
  
- **Relevant Guidance:** NUREG-1537, Part 2, Section 3.2, “Meteorological Damage” and Section 3.3, “Water Damage”



# Staff Evaluation - Meteorological

- Appropriate structural loads will be determined in accordance with ASCE/SEI 7-10
  - Tornado and Hurricane wind loads are determined in accordance with RG 1.76 and RG 1.221, respectively
- Design criteria properly align with approved data and predictions in Chapter 2
- Safety-related portion of reactor building designed in accordance with ACI 349 and AISC N690
- Credited to meet PDC 2

# Staff Evaluation - Water

- External flood level below structure
- Drainage and grading will be designed to preclude loads from precipitation
  - Staff will review site features during the operating license review
- Internal flooding will be controlled via SSC layout, limiting water volumes, and curbs and drains
  - Staff will review specific details of layout and water volumes during the operating license review
- Credited to meet PDC 2

# Technical Evaluation Conclusions

- Safety-related portions of the Reactor Building are designed to appropriate codes and standards
- Meteorological data is appropriately referenced from Chapter 2
- Specific design details that will be reviewed during the operating license have been properly identified

# Section 3.2 and 3.3 Regulatory Findings

- The staff finds PSAR Section 3.2 and 3.3 meets the staff guidance provided in NUREG-1537, Part 2, Sections 3.2 and Section 3.3
- The staff finds there is reasonable assurance that the preliminary information conforms with 10 CFR 50.34(a)(3)(iii) by providing information relative to the materials of construction, general arrangement and approximate dimensions, sufficient to provide reasonable assurance that the final design will conform to the design basis
- The staff concludes the information in Hermes PSAR Section 3.2 and 3.3 is sufficient and meets the applicable guidance and regulatory requirements identified in this section for the issuance of a construction permit in accordance with 10 CFR 50.35 and further information can be reasonably left for the OL application



# **NRC Staff Review for PSAR Sections 2.5, 3.4, and 3.5**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**March 23, 2023**

By the Division of Engineering and External Hazards,  
Office of Nuclear Reactor Regulation

# Sections 2.5, 3.4 and 3.5

---

- Format
  - 2.5: Geology, Seismology, and Geotechnical Engineering
  - 3.4: Seismic Damage
  - 3.5: Reactor Building Structure

# Overview of staff review

---

- Kairos applied for a CP and has not specifically requested approval of detailed design information
- Kairos provided a preliminary design description and a discussion of the relevant design bases (e.g., PDCs)
- NRC staff assessed whether the preliminary design information, including identification of relevant design bases, is sufficient to allow the staff to determine that
  - The information meets the relevant regulations for the issuance of a CP
  - The detailed design information can be left to the OL application

# Regulatory Basis

---

- 10 CFR 50.34(a), “Preliminary safety analysis report.”
- 10 CFR 50.35, “Issuance of construction permits.”
- 10 CFR 50.40, “Common standards.”
- Relevant guidance: NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors,” Part 2, “Standard Review Plan and Acceptance Criteria.”
- **Section 2.5 only**: 10 CFR 100.10, “Factors to be considered when evaluating sites,”
  - paragraph (c), which requires that in considering the acceptability of a site for a test reactor, physical characteristics of the site, including seismology and geology, should be considered by the NRC.
- **Section 3.5 only** – principal design criteria (PDC):
  - PDC 1 – “Quality standards and records”
  - PDC 2 – “Design bases for protection against natural phenomena”
  - PDC 3 – “Fire protection”
  - PDC 75 – “Reactor building design basis”
  - PDC 76 – “Provisions for periodic reactor building inspection”



# PSAR 2.5.1 and 2.5.2 Regional and Site Geology

- Regional geology incorporated by reference from Clinch River ESP 3.5 miles away
- Site underlain by Mascot Dolomite, Murfreesboro Limestone, and Pond Springs Formation within the Appalachian Valley and Ridge Physiographic province
- Foundation rock units are susceptible to karst
  - No surface indications of sinkholes
  - Evidence of karstic activity in borings

# Staff Evaluation - Geology

- Characterization of the local and regional geology is adequate
- Potential for surface faulting deferred to operating license.
- **Permit condition:** Removal of overburden soils and weathered rock and geologic mapping will ensure no evidence of karstic dissolution
  - Kairos shall perform detailed geologic mapping of excavations for safety-related engineered structures; examine and evaluate geologic features discovered in those excavations; and notify the Director of the Office of Nuclear Reactor Regulation, or the Director's designee, as specified in 10 CFR 50.4, once excavations for safety-related structures are open for examination by NRC staff.

# PSAR Section 2.5.3 Vibratory Ground Motion

- Adopted Clinch River site ground motion hazard curves for site-specific Design Response Spectrum (DRS)
  - 3.5 miles between the two sites
  - Rock site with similar geology
  - Based on NRC-approved seismic source model (NUREG-2115)
  - Based on previously NRC-approved CEUS ground motion model EPRI (2013)
  - Increased Clinch River hazard curves by scale factors of 1.5 to 1.7 to account for use of older ground motion model and potential impact of site-specific site response analysis

# Staff Evaluation – Vibratory Ground Motion

- Kairos' use of the Clinch River hazard curves for the site-specific DRS for the Hermes test reactor is appropriate at the CP stage
- For OL Kairos will update its site-specific DRS to incorporate new NRC-approved CEUS ground motion model NGA-East and site amplification factors determined from the results of site response analysis
  - Staff will perform confirmatory evaluation using NGA-East model and local site amplifications

# PSAR Section 2.5.4 – Geotechnical Engineering

- Subsurface stratigraphy and material properties determined from boreholes and trenches
- Liquefaction not a concern for safety-related structures
- Bearing capacity of foundation rock expected to be adequate
- Settlement for safety-related structures is negligible – settlement of non-safety related structures controlled through engineered backfill

# Staff Evaluation – Geotechnical Engineering

- Liquefaction not a concern for rock units encountered at the site - liquefaction potential for non-safety related structures on engineered fill deferred to OL
- Over-excavation to foundation depth where no evidence of karstic dissolution encountered.
- Additional characterization of foundation bedrock will be addressed in OL

# Section 2.5 Regulatory Findings

- NRC staff concludes, based on the review of the information provided in the application, subsequent RAI responses, and the staff's technical evaluation, that the information on geology, seismology, and geotechnical engineering characteristics of the Hermes site in Hermes PSAR Section 2.5 is sufficient and meets the applicable guidance and regulatory requirements for the issuance of a construction permit in accordance with 10 CFR 50.35.
- Further information on geology, seismology, and geotechnical engineering can reasonably be left for later consideration since this information is not necessary to be provided as part of a CP application.

# PSAR Section 3.4 Seismic Design Overview

- Addresses SSCs required to remain functional after an earthquake (ASCE 43-19 seismic design category 3)
- Uses graded approach from ASCE 43-19
- DRS based on seismic design category 3 and site hazard from PSAR Section 2.5
- Seismic response analysis and Soil Structure Interaction will be performed in accordance with ASCE 4-16



# Staff Evaluation – Seismic Design

- Safety-related portions of the Reactor Building will be designed to appropriate seismic codes and standards (ASCE 43-19, ASCE 4-16)
- DRS is properly developed based on site data from Chapter 2
- Specific design details (seismic model, etc.) that will be reviewed during the operating license have been properly identified
- Reasonable level of detail and information provided for issuance of a CP

# PSAR Section 3.5 Plant Structures Overview

- Describes principal structural elements and design of the reactor building (RB)
- Summarizes how reactor building meets PDCs 1, 2, 3, 75 and 76
  - Supports or repeats information contained in PSAR Sections 3.2, 3.3, and 3.4
- Discusses Seismic Isolation System

# Staff Evaluation – PDC 1 and 2

- PDC 1 –SSCs important to safety shall be designed to quality standards
  - Safety-related SSCs will be designed and constructed in accordance with ACI 349 and AISC N690
- PDC 2 – SSCs important to safety shall be designed to withstand natural phenomena
  - Structures will be designed to withstand appropriate natural loads (see SE Sections 3.2, 3.3, and 3.4)
  - Structures designed in accordance with appropriate nuclear codes (ACI 349 and AISC N690)

# Staff Evaluation – PDC 3, 75 and 76

- PDC 3 – SSCs important to safety shall be designed and located to minimize effects of fires
  - RB uses low combustible materials and physically separates SSCs
  - Fire protection program provided (SE Section 9.4)
- PDC 75 – RB shall protect the geometry of the decay heat removal system (DHRS) from natural phenomena
  - DHRS is located inside safety-related portion of RB, which provides assurance the DHRS will be protected
- PDC 76 – RB shall be designed to permit periodic inspection
  - The RB, including the seismic isolation system, is designed to allow access and permit inspection

# Staff Evaluation – Seismic Isolation

- Safety-related portion of RB will be seismically isolated
  - Minimal information provided on design
- ‘Moat’ separates seismically isolated portion from rest of plant
- System will be accessible and inspectable throughout life of plant
- Staff verified system will be designed in accordance with Chapter 9 of ASCE 43-19 and details of system and analysis will be provided in the Operating License application

# Technical Evaluation Conclusions

- Safety-related portions of the RB will be designed to appropriate nuclear codes and support PDCs 1, 2, 3, 75 & 76
- The seismic isolation system will be designed to the appropriate guidance in ASCE 43-19
- Specific design details that will be reviewed during the operating license have been properly identified

# Sections 3.4 and 3.5 Regulatory Findings

- The staff finds there is reasonable assurance that the preliminary information is consistent with the applicable criteria in NUREG-1537 and the relevant PDC and conforms with 10 CFR 50.34(a)(4) by providing a preliminary analysis and evaluation of the design and performance of SSCs
- The staff concludes the information in Hermes PSAR Sections 3.4 and 3.5 is sufficient and meets the applicable guidance and regulatory requirements identified in this section for the issuance of a construction permit in accordance with 10 CFR 50.35 and further information can be reasonably left for the OL application



# **NRC Staff Review for PSAR Section 4.2 Reactor Core**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**March 23, 2023**

By the Division of Advanced Reactors and Non-Power Production and  
Utilization Facilities,  
Office of Nuclear Reactor Regulation



# Agenda

---

- PSAR Section 4.2.1, “Reactor Fuel”
  - Overview and Regulatory Basis
  - Staff Technical Evaluation, Conclusions, and Findings
- PSAR Section 4.2.2, “Reactivity Control and Shutdown System”
  - Overview and Regulatory Basis
  - Staff Technical Evaluation, Conclusions, and Findings
- PSAR Section 4.2.3, “Neutron Startup Source”
  - Overview and Regulatory Basis
  - Staff Technical Evaluation, Conclusions, and Findings

# Overview of PSAR Section 4.2.1

---

- The TRISO particle is the primary fission product barrier
- Uses the larger AGR-2 fuel kernel
- Uses nominal AGR program coating thicknesses
- The TRISO particles are arranged in an annulus near the pebble outer edge
- Smaller than typical HTGR pebble size
- Covers unfueled moderator pebbles
- Covers fuel performance monitoring

## Section 4.2.1 Regulatory Basis

---

- 10 CFR 50.34(a), “Preliminary safety analysis report.”
- 10 CFR 50.35, “Issuance of construction permits.”
- 10 CFR 50.40, “Common standards.”
- **Relevant guidance:** NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors,” Part 2, “Standard Review Plan and Acceptance Criteria.”
- Principal design criteria (PDC):
  - PDC 10 – “Reactor design”
  - PDC 16 – “Containment Design”
  - PDC 34 – “Residual heat removal”
  - PDC 35 – “Passive residual heat removal”

# Referenced Topical Reports

- KP-TR-003-NP-A, Revision 1, “Principal Design Criteria for the Kairos Power Fluoride Salt-Cooled, High Temperature Reactor”
- EPRI-AR-1-NP-A, “Uranium Oxycarbide (UCO) Tristructural Isotropic (TRISO) Coated Particle Fuel Performance”
  - Used to evaluate TRISO particle parameters and performance envelope
- KP-TR-011, Revision 2, “Fuel Qualification Methodology for the Kairos Power Fluoride Salt-Cooled High Temperature Reactor (KP-FHR)”
  - Used to evaluate expected pebble behavior
- KP-TR-010-NP-A, Revision 3, “KP-FHR Fuel Performance Methodology”
  - Illustrative examples for postulated event fuel failure fractions and incremental failure probability to support reasonable assurance finding
  - The KP-BISON code has not been approved by the staff

# Staff Evaluation – TRISO Particles

- Particles will be within the measured UCO particle parameters of EPRI-AR-1, Table 5-5
- AGR-2 irradiated conditions bound the Hermes expected normal operation
- Expected postulated event peak particle temperatures are below 1600 °C, the lowest AGR program safety testing temperature
- AGR test program did not include overpower transient tests (discussed on a following slide)

# Staff Evaluation – Pebbles

- Fuel Pebble
  - Not credited for fission product retention
  - The fuel qualification topical report, KP-TR-018, addresses pebble testing to ensure protection of the TRISO particles and buoyance function
  - Specific correlations, if necessary, will be derived from the test data and applied in the Hermes FSAR
- Moderator Pebbles
  - Contains no fuel and is a nonsafety-related component
  - Same material as the fuel pebble matrix
  - Testing for buoyancy, wear, strength, and salt ingress will be same as the fuel pebble
  - Will be inspected by the PHSS like fuel pebbles
  - Staff review focused on the potential impact to safety-related functions like decay heat removal

# Staff Evaluation – Overpower Transient


- AGR safety test program consisted of relative slow heats like those experienced in loss of flow heat-up events
  - Hermes overpower transient heat-up rates are significantly faster
- Overpower events can potentially lead to fuel melt or non-melt mechanical failures
- Limiting overpower transients are generally rod ejection and rapid element withdrawals
  - Rod ejection is precluded by design due to the low differential pressure
- Staff evaluated the maximum control element withdrawal presented in Figure A1-2 of Postulated Events Analysis Methodology technical report KP-TR-018

# Staff Evaluation – Overpower Transient

- The maximum control element withdrawal kernel temperature is approximately 1,080 °C
  - Below the unirradiated UC<sub>1.96</sub> and UC<sub>1.86</sub> melt temperature (1,820 °C and 2,350 °C, respectively)
    - UO<sub>2</sub>, UC and UC<sub>1.86</sub> were the reported AGR phases
  - The energy deposition is low compared to the 1,400 J/g-UO<sub>2</sub> failure threshold
- Overpower event non-melt failures are also expected to be negligible
  - The time to reactor trip is approximately 10 seconds
  - The fuel thermal time constant is between 30 to 300 milliseconds
  - For events lasting on the order of greater than 1 second the maximum fuel particle differential temperature is near zero and is independent of the energy deposition



# Staff Evaluation – Overpower Transient



# Staff Evaluation – Overpower Transient

- Negligible incremental failures predicted by the KP-BISON code for the maximum control element withdrawal analysis in KP-TR-018
  - The KP-BISON code has not been approved but provides insights to the expected in-service incremental failure fraction
  - The predicted in-service incremental failure fraction using a verified KP-BISON code will be performed as part of the OL application review
- Based on the predicted low, maximum TRISO kernel temperature and the corresponding margin to melt, the low stress caused by the small differential coating temperatures, and review of the preliminary KP-BISON results, the staff finds that incremental failures are not expected during the worst case overpower postulated event.

# Staff Evaluation – Fuel Performance Monitoring

- Three non-destructive means are available to monitor fuel performance:
  - Cover gas and reactor coolant monitoring will be performed, which provides an indication of particle failures
    - A technical specification (TS) on coolant activity is given in PSAR Chapter 14 but specific values will be provided as part of the OL
  - Fuel pebbles will be examined for damage and burnup by the pebble handling system
    - Pebbles which show abnormal wear, cracking or missing surfaces will be removed from service
    - Pebbles will be discharged to prevent exceeding the burnup limit

# Staff Evaluation – Fuel Performance Monitoring

- Destructive testing of the Hermes fuel will be performed as stated in Section 3.9.3 of KP-TR-011
  - The destructive testing will determine failed fuel fractions, pebble wear and the extent, if any, of Flibe ingress
- The destructive testing can provide additional fuel performance code validation data and provide input to revise any future KP-FHR fuel PIRT

## 4.2.1 Technical Evaluation Conclusions

- The TRISO particles are expected to operate within the bounds as defined by the AGR-2 test data
- Incremental failures are expected to be negligible based on assessing the worst overpower postulated event and the AGR program safety testing which addresses the slower heat-up events
- Fuel and moderator pebble testing programs are sufficient to develop the relevant acceptance criteria or correlations to ensure the pebble safety functions are satisfied
- Fuel monitoring is adequate to determine unexpected fuel failures

## Section 4.2.2 Regulatory Basis

---

- 10 CFR 50.34(a), “Preliminary safety analysis report.”
- 10 CFR 50.35, “Issuance of construction permits.”
- 10 CFR 50.40, “Common standards.”
- **Relevant guidance:** NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors,” Part 2, “Standard Review Plan and Acceptance Criteria.”
- Principal design criteria (PDC):
  - PDC 2 – “Design bases for protection against natural phenomena”
  - PDC 4 – “Environmental and dynamic effects design bases”
  - PDC 23 – “Protection system failure modes”
  - PDC 26 – “Reactivity control systems”
  - PDC 28 – “Reactivity limits”
  - PDC 29 – “Protection against anticipated operational occurrences”

# Section 4.2.2 Reactivity Control and Shutdown System Overview

- The reactivity control and shutdown system (RCSS) is credited with shutdown
  - The RCSS ensures safe shutdown by inserting and withdrawing elements to control reactivity during normal operation and in response to abnormal conditions (or postulated events)
- 4 control and 3 shutdown elements use boron carbide ( $B_4C$ ) absorber material
- Control elements (CEs)
  - Insert into the graphite reflector
  - Range of insertion positions
- Shutdown elements (SEs)
  - Insert directly into the pebble bed
  - Either fully withdrawn or fully inserted
  - Credited with shutting down the reactor during postulated events

# Section 4.2.2 Reactivity Control and Shutdown System Overview

- Control and shutdown elements are controlled using counter-weighted winch systems
  - A wire-rope is connected to the element and travels up around the winch drum (also known as a sheave) and down to a counter-weight
  - The winch drum is rotated by an electric motor
- There is an electric clutch between the winch drum and the electric motor to control the element movement
  - During a reactor trip, the electric clutch opens, allowing the winch drum to rotate freely, and the elements are released from their drives, allowing them to drop as a result of gravity.
  - The release of the clutch for the shutdown elements is the primary safety-related reactor trip mechanism



# Staff Evaluation – PDCs 2 and 4

- PDC 2, "Design bases for protection against natural phenomena"
  - Kairos will perform a one-time test before operation that deflects SE guide structures by a maximum misalignment that would be caused by a design basis (DB) earthquake to confirm that element insertion time is bounded by the insertion time assumed in the Ch. 13 analysis
- PDC 4, "Environmental and dynamic effects design bases"
  - Kairos will perform testing prior to operation for SE wear during movement
  - Kairos will perform analyses for SE internal gas release and swelling of B4C and for SE stress
  - Kairos will perform analyses for SEs and CEs to show they meet American Society of Mechanical Engineers standards

# Staff Evaluation – PDCs 23, 26, 28, and 29

- PDC 23, "Protection system failure modes"
  - SEs accomplish safe shutdown via gravity insertion on a reactor trip signal or on a loss of normal electrical power
  - Removal or loss of power causes electromagnetic clutch to open
- PDC 26, "Reactivity control systems"
  - PDC 26 is discussed in Section 4.5
- PDC 28, "Reactivity limits"
  - NRC scoping calculations predicted that TRISO fuel maintains integrity during postulated insertion of excess reactivity events
  - Rod ejection is discussed in Chapter 13
- PDC 29, "Protection against anticipated operational occurrences"
  - Kairos will perform testing (as discussed in PDCs 2 and 4)
  - Kairos will perform periodic inspection of SEs and coolant to look for evidence of SE damage or failure

## 4.2.2 Technical Evaluation Conclusions

- The NRC staff finds the preliminary design information provided is consistent with PDC 2, 4, 23, 26, 28, and 29 and is consistent with the relevant acceptance criteria of NUREG-1537.
- Staff has reasonable assurance that the RCSS will perform its safety functions of reactivity control and shutdown.

## 4.2.3 Neutron Source Overview, Staff Evaluation, and Conclusions

- **Relevant guidance:** NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors,” Part 2, “Standard Review Plan and Acceptance Criteria.”
- Overview
  - PSAR does not specify source type
  - Neutron startup source is placed in a metal sheath and located in reflector
- The staff finds this meets applicable NUREG-1537 acceptance criteria because it should be capable of performing in its environment and is removable and replaceable.

## Section 4.2 Regulatory Findings

- The NRC staff concludes that the preliminary design provided in PSAR Section 4.2 is consistent with the applicable PDCs and acceptance criteria in NUREG-1537.
- The NRC staff finds that the information in Hermes PSAR Section 4.2 is sufficient for the issuance of a construction permit in accordance with 10 CFR 50.35 and 50.40, and further information can be reasonably left for the OL application



# **NRC Staff Review for PSAR Section 4.5 Nuclear Design**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**March 23, 2023**

By the Division of Advanced Reactors and Non-Power Production and  
Utilization Facilities,  
Office of Nuclear Reactor Regulation

# Agenda

---

- Overview of PSAR Section 4.5, “Nuclear Design”
- Regulatory basis and PDCs
- Referenced topical reports
- Staff technical evaluation
- Technical conclusions
- Regulatory Findings

# Regulatory Basis

---

- 10 CFR 50.34(a), “Preliminary safety analysis report.”
- 10 CFR 50.35, “Issuance of construction permits.”
- 10 CFR 50.40, “Common standards.”
- **Relevant guidance:** NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors,” Part 2, “Standard Review Plan and Acceptance Criteria.”
- Principal design criteria (PDC):
  - PDC 10 – “Reactor design”
  - PDC 11 – “Reactor inherent protection”
  - PDC 12 – “Suppression of reactor power oscillations”
  - PDC 26 – “Reactivity control systems”



# Referenced Topical Reports

- KP-TR-003-NP-A, Revision 1, “Principal Design Criteria for the Kairos Power Fluoride Salt-Cooled, High Temperature Reactor”
- KP-TR-013-NP, Revision 4, “Metallic Materials Qualification for the Kairos Power Testing Program”
  - Used to evaluate vessel irradiation
- KP-TR-017-P, Revision 1, “KP-FHR Core Design and Analysis Methodology” (technical report)

# Nuclear Design Methodology

- Two main physics codes:
  - Serpent 2 for neutron/gamma transport and isotopics
    - Continuous energy (CE) Monte Carlo method
    - Doppler-broadened cross section data provided a priori by KACEGEN
  - STAR-CCM+ for pebble tracking and thermal-fluidics (T/F)
    - Discrete element method (DEM) for pebble flow
    - Porous media approach for fluid and structure temperatures
- Used within two analysis sequences:
  - KPATH (coupled transport/T-F) – iterations between Serpent and STAR-CCM+ to update temperature fields based on power distribution and vice versa
  - KPACS (fuel cycle analysis) – updates isotopics within geometry as core operates based on DEM-calculated pebble flow fields

# Staff Evaluation – Methodology

- Basic methodologies appear sound
  - Temperature-dependent CE cross section libraries generated across wide range, fine grid
  - KPACS accounts for radial and axial zoning, local effects on neutron spectrum, differential pebble depletion per pass in core
  - KPATH provides for thermal feedback in the neutronics solution
  - Models provide robust means to calculate safety parameters (shutdown margin, reactivity coefficients, delayed neutron and decay heat data)
  - Coolant temperature feedback calculated assuming limiting isotopic composition

# Remaining Methodology Items for Operating License

- PSAR analysis mainly focuses on *nominal* core performance
- Neutronics uncertainties have not been formally established
  - Additional work is planned to establish conservatism in the presently assumed uncertainties in key figures of merit
  - Submittal expected to support operating license (OL)
- No validation or assessment has been submitted for review
  - KP-TR-017-P includes brief description of validation framework for relevant STAR-CCM+ and Serpent models to support OL
- Additional details on certain modeling approaches (e.g., shutdown control elements when inserted in bed, reactor vessel fluence, operation with control elements partially inserted) are expected
- These codes and methods are not considered "reviewed and approved" at this stage

# Staff Scoping Analysis of Hermes


- NRC developed several ‘representative’ non-LWR systems models since 2020
  - Part of “Non-LWR Vision and Strategy, Volume 3” covering severe accidents/source term
  - Included UC Berkeley Mark 1 design, representing TRISO pebble fueled/molten salt cooled FHR
  - SCALE code suite used for inventory and reactor physics data generation (ORNL)
  - MELCOR used for accident progression using SCALE-produced data (Sandia)
  - FHR demonstration public workshop 9/2021 (ML21256A231)
- These models/workflow were rapidly adapted to support Hermes scoping-level analysis (early 2022)

# SCALE Analysis Approach

- This is a scoping rather than a confirmatory analysis
  - Rapid turnaround to support review timeline (initiated in January, presented to NRR staff in March 2022)
  - Exclusive reliance on non-proprietary data from Hermes PSAR
  - Inform review staff's engineering judgement
- SCALE FHR workflow described in ML22152A163
  - Justification of multigroup energy treatment
  - Generation of equilibrium isotopic inventory using 2D slice models of reactor
  - 3D full core calculations for reactor physics data
    - Eigenvalue
    - Power distribution
    - Feedback coefficients
    - Kinetics parameters

# SCALE Model Description


- Multigroup Monte Carlo transport using KENO-VI, isotopics calculated with ORIGEN
- Random pebble geometry approximated by regular lattice
- Equilibrium isotopics generated iteratively via 2D slice models with SCALE/TRITON
- Axially-dependent fuel isotopics inserted into 3D core model for reactivity and power shape evaluations
- Does not currently include shutdown (in-bed) elements – on list for further development



# SCALE Results: Power Distribution

Relative Power	Kairos PSAR	SCALE
Axial (-)	1.2	1.19
Radial (-)	1.2	1.76
Peak Pebble (-)	1.8	2.09

- Excellent agreement axially
- Not as good radially or at peak pebble
  - Inconsistencies in peaking definitions
  - Inconsistencies in reflector model
  - Differences in pebble treatment – averaged vs. pass/location dependent isotopics
- *Reasonable*, given uncertainties – could be resolved with additional information





# SCALE Results: Reactivity Coefficients

Parameter	Kairos PSAR	SCALE*
Fuel Doppler (pcm/K) <sup>†</sup>	-4.1	-4.30 ± 0.27
Moderator (pcm/K) <sup>†</sup>	-0.4	-0.47 ± 0.13
Coolant (pcm/K) <sup>†</sup>	-1.6	-1.62 ± 0.02
Void (pcm/% void, @3% void)	-53	-46.6 ± 4.0
Reflector (pcm/K) <sup>†</sup>	+2.0	+1.92 ± 0.23
$\beta_{eff}$ (pcm)	605	576 ± 10

\* - includes Monte Carlo uncertainty

† - calculated assuming temperature distributions provided by MELCOR

# Staff Evaluation – Power Distribution

- Codes
  - Serpent 2 is used to calculate core power distribution
  - STAR-CCM+ is used to calculate material temperature distributions
  - Serpent 2 and STAR-CCM+ are coupled and output the distributions
- The core power distribution is characterized by axial peaking factor, radial peaking factor, and total peaking factor
  - Peaking factors are calculated using Serpent 2 by tallying fission power in each pebble and dividing by the average power per pebble in the core
- Staff scoping calculations showed reasonable agreement with Kairos' preliminary calculations of power distribution and total pebble peaking factors
  - The core power distributions are an input to the fuel performance calculations. The staff finds that this is consistent with PDC 10.

# Staff Evaluation – Shutdown Margin

- Shutdown margin (SDM) design criteria is  $k_{\text{eff}} < 0.99$ 
  - SDM is defined relative to the margin to Flibe freezing temperature in the core
  - SDM is maintained at all core states
- Control element worth is calculated from changes in  $k_{\text{eff}}$  resulting from perturbing element axial positions in Serpent 2.
  - The single most reactive element is assumed to be fully withdrawn from the core.
- Kairos will perform source range control element worth testing
- Staff finds this is consistent with PDC 26

# Staff Evaluation – Reactivity Coefficients

- Reactivity coefficients were calculated using Serpent 2
- Reactivity coefficients include
  - Fuel temperature (-)
  - Moderator temperature (-)
  - Coolant temperature (-)
  - Coolant void (-)
  - Reflector temperature (+)
- Reflector temperature reactivity coefficient is slightly positive, but thermal expansion in the reflector, which is a negative feedback, was conservatively ignored
- Moderator temperature reactivity coefficient includes change in reactivity due to change in temperature in fuel pebble graphite and in graphite pebbles
- Coolant temperature reactivity coefficient accounts for density changes. Coolant void reactivity coefficient is change in reactivity due to change in coolant void fraction.

# Staff Evaluation – Reactivity Coefficients

- Overall reactivity coefficient is negative
- Staff scoping calculations showed reasonable agreement with Kairos' preliminary calculations for reactivity coefficients
- Once Hermes achieves criticality and is at zero power, Kairos will perform isothermal reactivity coefficient testing
- Staff finds this is consistent with PDC 11

# Staff Evaluation – Vessel Irradiation

- Vessel lifetime is 4 years
- Vessel is shielded by the core barrel, the reflector, and the Flibe coolant
- Serpent 2 is used to calculate fast neutron fluence and alpha generation on the vessel received from the core and pebble insertion and extraction lines
- Kairos' preliminary calculation of displacements per atoms (dpa) in the vessel is within the low-level irradiation value discussed in KP-TR-013-NP

# Staff Evaluation – Nuclear Transient Parameters

- Nuclear transient parameters are outputs from Serpent 2 and are used as inputs for transient analyses
- Nuclear parameters include
  - Neutron generation time
  - Delayed neutron fraction groups and their decay constants
  - Prompt neutron lifetime
- Staff's evaluation of nuclear core design limits (i.e., Burnup, peak fuel temperature, peak particle power, and peak fluence) are discussed in SE Section 4.2.1, "Reactor Fuel"

# Staff Evaluation – Monitoring

- Neutron flux will be monitored using
  - 4 power range ex-core detectors located in azimuthally symmetric locations outside the reactor vessel at mid-core elevation
  - 4 source range ex-core detectors located in relation to the startup source for best detectability of criticality
- During normal operation, these detectors will be used to monitor core power and the flux rate trip signal
- Source range detectors used during startup
- Gamma spectrometry used to evaluate fuel pebble burnup
  - Staff did not make any findings on Kairos' burnup monitoring plan
- Kairos will perform neutron flux distribution verification tests during startup
- Staff finds this is consistent with PDC 10



# Technical Evaluation Conclusions

- Kairos PDC 10, “Reactor design”
- Kairos PDC 11, “Reactor inherent protection”
- Kairos PDC 12, “Suppression of reactor power oscillations”
- Kairos PDC 26, “Reactivity control systems”
  
- Preliminary design information provided is consistent with PDC 10, 11, 12, and 26 and is consistent with acceptance criteria of NUREG-1537
- Analytical methods for nuclear design are acceptable at this stage of the design

# Section 4.5 Regulatory Findings

- The NRC staff concludes that the preliminary design provided in PSAR Section 4.5 is consistent with the applicable PDCs and acceptance criteria in NUREG-1537.
- The NRC staff finds that the information in Hermes PSAR Section 4.5 is sufficient for the issuance of a construction permit in accordance with 10 CFR 50.35 and 50.40, and further information can be reasonably left for the OL application

# Questions?



# **NRC Staff Review for PSAR Section 4.3 Reactor Vessel System**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**March 24, 2023**

By the Division of Advanced Reactors and Non-Power Production and  
Utilization Facilities,  
Office of Nuclear Reactor Regulation

# Agenda

---

- Overview of PSAR Section 4.3 “Reactor Vessel System”
- Regulatory basis and PDCs
- Referenced topical reports
- Staff technical evaluation
- Technical conclusions
- Regulatory Findings

# PSAR Section 4.3 Reactor Vessel System

---

- Comprised of vessel shell, top head, bottom head, and vessel internals
  - Internals include reflector blocks, fluidic diodes, core barrel, and reflector support structure
- Contains the core, provides for circulation of the reactor coolant and pebbles, and insertion of RCSS elements
- Safety related system

# Regulatory Basis

---

- 10 CFR 50.34(a) “Preliminary safety analysis report”
- 10 CFR 50.35 “Issuance of construction permits”
- 10 CFR 50.40, “Common standards”
- The following NRC staff approved PDC (KP-TR-003-NP-A):
  - PDC 1 – “Quality standards and records”
  - PDC 2 – “Design bases for protection against natural phenomena”
  - PDC 4 – “Environmental and dynamic effects design bases”
  - PDC 10 – “Reactor design”
  - PDC 14 – “Reactor coolant boundary”
  - PDC 30 – “Quality of reactor coolant boundary”
  - PDC 31 – “Fracture prevention of reactor coolant boundary”
  - PDC 32 – “Inspection of reactor coolant boundary”
  - PDC 33 – “Reactor coolant inventory maintenance”
  - PDC 34 – “Residual heat removal”
  - PDC 35 – “Passive residual heat removal”
  - PDC 36 – “Inspection of the passive residual heat removal system”
  - PDC 37 – “Testing of the passive residual heat removal system”
  - PDC 74 – “Reactor vessel and reactor system structural design basis”

# Referenced Topical Reports

---

- KP-TR-003-NP-A, Revision 1, “Principal Design Criteria for the Kairos Power Fluoride Salt-Cooled, High Temperature Reactor”
- KP-TR-013-NP, Revision 4, “Metallic Materials Qualification for the Kairos Power Fluoride Salt-Cooled High-Temperature Reactor,”
- KP-TR-014-NP, Revision 4, “Graphite Material Qualification for the Kairos Power Fluoride Salt-Cooled High-Temperature Reactor”



# Staff Evaluation – PDC 2

---

- The reactor vessel, vessel internals, and vessel attachments are classified as Seismic Design Category (SDC)-3 per ASCE 43-19 “Seismic Design Criteria for Structures, Systems, and Components in Nuclear Facilities”.
- The safety related SSCs will be protected from the failure of nearby non-safety related SSCs during a design basis earthquake.

# Staff Evaluation – PDC 4

---

- The reactor vessel is designed to account for internal and external static and dynamic loads, including static weight, seismic loads, and forces from the pebble bed, coolant, and core components.
- Pipe whip hazards are not a concern because there are no pressurized piping systems near the reactor vessel.

# Staff Evaluation – PDC 10

---

- PSAR states that the vessel and internals needed to define coolant flow path
  - Integrity of SS and graphite components
- The NRC staff has reasonable assurance that the design will be consistent with PDC 10
  - Graphite qualified as per KP-TR-014-NP and designed to Section III Division 5
  - 316H SS qualified as per KP-TR-013-NP and designed to Section III Division 5
  - The reactor vessel, vessel internals, and vessel attachments are classified as SDC-3 per ASCE 43-19 to account for dynamic behaviors to ensure continued functionality during and after a design basis earthquake event.
  - The reactor vessel system is protected from the failure of nearby non-safety related SSCs impacting safety significant SSCs.

# Staff Evaluation – PDC 14

---

- PSAR states
  - Vessel material and weld metal will be qualified consistent with Section III Division 5 and KP-TR-013-NP
  - Designed to accommodate operational and transient stresses
- NRC staff has reasonable assurance the reactor vessel system can be designed consistent with PDC 14
  - Qualification testing of 316H SS and weld filler will demonstrate compatibility between vessel and weld metals with the reactor coolant
  - Catch basins for leak monitoring
  - Inspection and monitoring programs to be reviewed at OL stage
  - Vessel will be monitored and is designed for in-service inspection
  - The load combination methodology conforms to Table 3, “Design Load Combinations,” of RG 1.143.

# Staff Evaluation – PDCs 30 and 31

---

- PSAR states reactor vessel will be fabricated, erected, and tested consistent with Section III Division 5
- NRC staff has reasonable assurance that the design will be consistent with PDCs 30 and 31
  - Temperatures up to 750°C and proposed Safety Limit on vessel temperature
  - KP-TR-013-NP contains additional testing to account for material degradation
  - TR includes extension of weld filler metal qualifications
  - Consistency with NRC-endorsed standards
  - Leakage detection
  - Minimization of air ingress and coolant purity limits

# Staff Evaluation – PDC 32

---

- PSAR states coupons, component monitoring, and inspection will assess structural integrity and leak-tightness of reactor coolant boundary
- NRC staff has reasonable assurance the reactor vessel system can be designed consistent with PDC 32
  - Preliminary information is consistent with guidance in NUREG-1537 to assess irradiation of vessel materials
  - Staff will evaluate final design to confirm
    - Results of qualification testing in conjunction with final design and associated surveillance, inspection, and performance monitoring programs to determine need for fracture toughness coupons
    - Monitoring and inspection programs will be performed to assure vessel integrity

## Staff Evaluation – PDC 33

---

- The PSAR states that the core barrel is designed to include anti-siphon features to limit reactor coolant inventory loss
- Staff evaluation of PDC 33 and NUREG-1537 guidance is in Chapter 5 of the SE

# Staff Evaluation – PDC 34

---

- PSAR states that vessel internals design supports decay heat removal
- NRC staff has reasonable assurance the reactor vessel system can be designed consistent with PDC 34
  - Design maintains pathway for coolant
    - In conjunction with Primary Heat Transfer System for forced flow in normal operation
    - Via fluidic diodes for natural circ in postulated events
- Many other sections of the SE describe aspects of this PDC
  - Ch 4.6 (thermal hydraulics), Ch 6.3/13 (PHTS), Ch 5 (anti-siphon)



## Staff Evaluation – PDCs 35, 36, and 37

- PSAR states that fluidic diode and reactor design maintain a flow path to allow for natural circulation of coolant
- NRC staff has reasonable assurance the reactor vessel system can be designed consistent with PDCs 35, 36, and 37
  - KP-TR-013-NP, Rev 4 testing will bound the design temperature and fluence of diode
  - Normal flow path – temperature monitoring at exit of reactor vessel
  - Postulated accident flow path - inspection of fluidic diode and temperature monitoring fluidic diode pathway

# Staff Evaluation – PDC 74

---

- PSAR states that reflector will be designed to meet Division 5 requirements
- NRC staff has reasonable assurance the reactor vessel system can be designed consistent with PDC 74
  - Preliminary info consistent with NUREG-1537 requirements
    - Design limits - KP-TR-014-NP, Rev 4 includes testing on effects needs to design the reflector (irradiation, thermal, etc.)
    - Surveillance - thermal mapping of reflector
  - RVSS is designed to provide the structural support for the reactor vessel under static and dynamic loadings (e.g., seismic).

# Testing and Inspection

---

- PSAR states design of vessel/internals allows for monitoring, inspection and maintenance
- PSAR states testing and inspection of reactor vessel and internals will be submitted with the OL application
  - Staff will review these programs at that time

# Conclusion

---

- NRC staff finds the preliminary design information is consistent with the applicable criteria in NUREG-1537 and the applicable PDC
- The staff concludes information in Hermes PSAR Section 4.3 is sufficient for the issuance of a CP in accordance with 10 CFR 50.35 and further information can be reasonably left for the OL application

# Questions?



# **NRC Staff Review for PSAR Section 4.4 Biological Shield**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**March 24, 2023**

By the Division of Advanced Reactors and  
Non-Power Production and Utilization Facilities,  
Office of Nuclear Reactor Regulation

# Overview of PSAR 4.4 “Biological Shield”

---

- Radiation shielding for worker protection during operation
- Reinforced concrete structures
- Safety related component for structural support and external event protection
  - Not safety related for radiation protection function

# Staff Evaluation – Biological Shield

---

- Assess whether the PSAR provides an acceptable basis for the development of the biological shield
- Determine if the objectives of the biological shield design basis are sufficient to protect the health and safety of the public and facility staff
- Assess whether there is reasonable assurance that Kairos will comply with the regulations in 10 CFR Part 20 during Hermes facility operation



# Staff Evaluation - Biological Shield Radiation Protection Design Basis

---

- Audit confirmed that Kairos performed preliminary shielding analysis to support PSAR
  - Isotopic data based on fuel and Flibe sources
- Evaluation of performance to meet Part 20, including shielding analyses, to be provided in OL application



# **NRC Staff Review for PSAR Section 4.6 Thermal-Hydraulic Design**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**March 24, 2023**

By the Division of Advanced Reactors and Non-Power Production and  
Utilization Facilities,  
Office of Nuclear Reactor Regulation

# Agenda

---

- Regulatory basis and PDCs
- Referenced topical reports
- Staff technical evaluation
- Technical conclusions
- Regulatory Findings

# Regulatory Basis

---

- 10 CFR 50.34(a), “Preliminary safety analysis report.”
- 10 CFR 50.35, “Issuance of construction permits.”
- 10 CFR 50.40, “Common standards.”
- Principal design criteria (PDC):
  - PDC 10 – “Reactor design”
  - PDC 12 – “Suppression of reactor power oscillations”
  - PDC 34 – “Residual heat removal”
  - PDC 35 – “Passive residual heat removal”
- **Guidance:** NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors,” Part 2, “Standard Review Plan and Acceptance Criteria.”

# Referenced Topical Reports

- KP-TR-003-NP-A, Revision 1, “Principal Design Criteria for the Kairos Power Fluoride Salt-Cooled, High Temperature Reactor”
- KP-TR-017-P, Revision 1, “KP-FHR Core Design and Analysis Methodology” (technical report)
- KP-TR-018-P, Revision 1, “Postulated Event Analysis Methodology” (technical report)

# Staff Evaluation – Analytical Methods

- Core design methodology includes Serpent 2 and STAR-CCM+ (discussed in Ch. 4.5)
  - Serpent 2 is a 3D Monte Carlo code that models neutrons and photons
  - STAR-CCM+ is a computational fluid dynamics (CFD) code
- Transient analysis methodology includes KP-SAM and KP-BISON codes (discussed in Ch. 13.1.2)
  - KP-SAM is a modification of SAM. KP-SAM is an accident analysis code
  - KP-BISON is a modification of BISON. KP-BISON is a fuel performance code
- Codes have not been reviewed for verification and validation (V&V)
- The NRC is not approving the use of these computer codes

# Staff Evaluation – Analytical Methods

- Hermes models account for the following heat transfer modes:
  - Pebble-to-pebble convective heat transfer
  - Pebble radiative heat transfer
  - Pebble-to-pebble heat transfer via pebble contact conduction
  - Pebble-to-pebble heat transfer via conduction through the coolant
  - Conductive, convective, and radiative heat transfer to reflector
- Staff reviewed thermal conductivity equations for pebble-to-pebble and pebble-to-coolant heat transfer
- Hermes models use the same pebble bed pressure drop correlation
  - Staff reviewed the pebble bed pressure drop correlation
- The NRC is not approving the use of these equations and correlations
- The NRC is not approving the references used to make the findings

# Technical Evaluation Conclusions

- PDC 10, "Reactor design"
  - Hermes thermal-hydraulic design provides adequate heat removal
- PDC 12, "Suppression of reactor power oscillations"
  - Supporting analyses for power oscillations will be provided later
- PDC 34, "Residual heat removal"
  - PHTS removes heat during normal operation
  - Downcomer and fluidic diodes and DHRS enable heat removal during postulated events
- PDC 35, "Passive residual heat removal"
  - Downcomer and fluidic diodes and DHRS enable heat removal during postulated events
- Information provided is consistent with PDC 10, 12, 34, and 35 and with acceptance criteria of NUREG-1537
- Analytical methods for thermal-hydraulic design are acceptable at this stage of the design



# T-H Design Regulatory Findings

- The NRC staff concludes that the preliminary design provided in PSAR Section 4.6 is consistent with the applicable PDCs and acceptance criteria in NUREG-1537.
- The NRC staff finds that the information in Hermes PSAR Section 4.6 is sufficient for the issuance of a construction permit in accordance with 10 CFR 50.35 and 50.40, and further information can be reasonably left for the OL application

Questions?



# **NRC Staff Review for PSAR Section 4.7 Reactor Vessel Support System**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**March 24, 2023**

By the Division of Advanced Reactors and Non-Power Production and  
Utilization Facilities,  
Office of Nuclear Reactor Regulation

# Agenda

---

- Overview of PSAR Section 4.7 “Reactor Vessel Support System”
- Regulatory basis and PDCs
- Referenced topical reports
- Staff technical evaluation
- Technical conclusions
- Regulatory Findings

# Overview of 4.7 Reactor Vessel Support System

---

- The RVSS provides the structural support for the reactor vessel and the vessel internals.
- The RVSS supports the full weight of the vessel, fuel, coolant, vessel internals, and the head-mounted components.
- The RVSS is designed to transmit pressure, seismic, and thermal loads to the cavity structures and address thermal expansion during initial heat-up and postulated events.

# Regulatory Basis

---

- 10 CFR 50.34(a) “Preliminary safety analysis report”
- 10 CFR 50.35 “Issuance of construction permits”
- 10 CFR 50.40, “Common standards”
- The following PDC (KP-TR-003-NP-A):
  - PDC 2 – “Design bases for protection against natural phenomena”
  - PDC 4 – “Environmental and dynamic effects design bases”
  - PDC 74 – “Reactor vessel and reactor system structural design basis”
- **Guidance:** NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors”

# Staff Evaluation – PDC 2

---

PDC 2, “Design bases for protection against natural phenomena.”

- PSAR Table 4.7-1, “Load Combinations for the Reactor Vessel Support System,” provides the load combinations for the RVSS, including seismic loads due to design basis earthquake events
  - Will be used to demonstrate that the final design will meet the allowable stress limits specified in ASME BPVC Section III, Division 5
- Based on the acceptable load combination methodology, the staff finds that the preliminary information on the RVSS design is consistent with PDC 2

# Staff Evaluation – PDC 4

---

## PDC 4, “Environmental and dynamic effects design bases.”

- Design features to address environmental and dynamic effects on the RVSS:
  - Pipe whip hazards are precluded by design due to a lack of pressurized piping.
  - Discharging fluids are addressed by catch basins with a leak detection system.
  - RVSS is designed to address temperature and mechanical loading cycles in order to prevent damage from creep-fatigue and to allow for thermal expansion of the reactor during startup and operation.
- Based on the design features to manage pipe whip hazards, discharging fluids, and loading cycles, the staff finds that the preliminary information on the RVSS is consistent with PDC 4 and the relevant NUREG-1537 criteria.



# Staff Evaluation – PDC 74

---

- PDC 74 – “Reactor vessel and reactor system structural design basis”
- RVSS design helps ensure sufficient heat removal from the reactor vessel, while also providing structural support for the reactor vessel under static and dynamic loadings (e.g., seismic).
- The heat is removed via the reactor thermal management system (RTMS), actively during normal operation and passively during postulated events.
- Based on the design for sufficient heat removal and structural support, the staff finds that the preliminary information on the RVSS design is consistent with PDC 74.

## Section 4.7 Regulatory Findings

---

- The NRC staff finds the preliminary design information is consistent with PDC 2, 4, and 74 and the applicable criteria in NUREG-1537.
- The staff concludes information in Hermes PSAR Section 4.7 is sufficient for the issuance of a CP in accordance with 10 CFR 50.35 and further information can be reasonably left for the OL application

Questions?



# **NRC Staff Review for PSAR Section 6.2 Functional Containment**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**March 24, 2023**

By the Division of Advanced Reactors and Non-Power Production and  
Utilization Facilities,  
Office of Nuclear Reactor Regulation

# Agenda

---

- Overview of PSAR Section 6.2, “Functional Containment”
- Regulatory Basis
- Staff Technical Evaluation
- Technical Conclusions
- Regulatory Findings

# Overview of PSAR Section 6.2

---

- Kairos Hermes uses a functional containment to limit potential release of radioactive material
- Functional containment includes physical barriers, operating conditions, coolant design, and fuel form
  - TRISO fuel retains radionuclides, layers form barriers, pebble provides physical protection
  - Large margin to TRISO fuel design temperature expected
  - Flibe credited for retaining radionuclides
  - Near-atmospheric primary system pressure
- PSAR Section 6.2 describes the strategy of using a functional containment; Chapter 13 intends to demonstrate its acceptability

# Regulatory Basis

---

- 10 CFR Section 50.34(a), “Preliminary safety analysis report”
- 10 CFR 50.35, “Issuance of construction permits”
- 10 CFR 50.40, “Common standards”
- SECY-18-0096, “Functional Containment Performance Criteria for Non-Light-Water-Reactors” (ML18114A546) and its approval in SRM-SECY-18-0096, “Staff Requirements – SECY-18-0096 - Functional Containment Performance Criteria for Non-Light-Water-Reactors” (ML18338A502)

# Staff Technical Evaluation: Review Process

---

- The NRC staff used relevant parts of NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors,” as guidance
- The NRC staff ensured the functional containment approach was consistent with SECY-18-0096
  - One difference: Maximum hypothetical accident (MHA), per NUREG-1537, instead of event categories
- The NRC staff ensured that the staff evaluated each individual component/feature of the functional containment as well as its integral performance
  - PSAR Section 4.2.1, “Reactor Fuel”
  - PSAR Section 4.3, “Reactor Vessel System”
  - PSAR Section 5.1, “Primary Heat Transport System”
  - PSAR Sections 13.1.1 and 13.2.1, both titled “Maximum Hypothetical Accident”



# Staff Technical Evaluation: Conclusions

---

- PSAR Chapter 13 demonstrates the need for functional containment as an engineered safety feature
- Preliminary MHA analysis suggests radiological consequences are within 10 CFR Part 100 criteria; staff will confirm as part of operating license (OL) application
- Functional containment has no adverse impacts to normal operations or safe shutdown
- Safety related instrumentation to monitor functional containment components
- Technical specifications will confirm continued operability and are important to ensure that actual dose consequences are bounded by the MHA analysis

# Regulatory Findings

---

- The NRC staff finds:
  - the preliminary design information is consistent with the applicable criteria in NUREG-1537
  - The functional containment approach is consistent with SECY-18-0096 and SRM-SECY-18-0096
- The staff concludes that the information in Hermes PSAR Section 6.2 is sufficient for the issuance of a construction permit in accordance with 10 CFR 50.35 and 50.40, and further information can be reasonably left for the OL application.

# Questions?



# **NRC Staff Review for PSAR Section 6.3 Decay Heat Removal System**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**March 24, 2023**

By the Division of Advanced Reactors and Non-Power Production and  
Utilization Facilities,  
Office of Nuclear Reactor Regulation

# Agenda

---

- Overview of PSAR Section 6.3, “Decay Heat Removal System”
- Regulatory Basis
- Staff Technical Evaluation
- Technical Conclusions
- Regulatory Findings

# Overview of PSAR Section 6.3

---

- The decay heat removal system (DHRS) is the safety-grade system credited to maintain the reactor vessel temperature within acceptable limits for SS-316
- DHRS is designed to provide passive cooling for up to seven days following a postulated event without electrical power or operator action
- Main components: water storage tanks, steam separators, annular thermosyphons
- Heat from the reactor vessel is transferred via radiation and convection to water in the annular thermosyphons, where water boils off
- DHRS is placed in service at a “threshold power” where passive radiative cooling alone is not adequate
  - During this transition phase, water is introduced to the guide tube and evaporator

# Regulatory Basis

---

- 10 CFR Section 50.34(a), “Preliminary safety analysis report”
- 10 CFR 50.35, “Issuance of construction permits”
- 10 CFR 50.40, “Common standards”
- The following NRC staff-approved PDC from KP-TR-003-NP-A, “Principal Design Criteria for the Kairos Power Fluoride Salt-Cooled, High Temperature Reactor”:
  - PDC 1, “Quality standards and records”
  - PDC 2, “Design bases for protection against natural phenomena”
  - PDC 3, “Fire protection”
  - PDC 4, “Environmental and dynamic effects design bases”
  - PDC 10, “Reactor design”
  - PDC 34, “Residual Heat Removal”
  - PDC 35, “Passive residual heat removal”
  - PDC 36, “Inspection of the passive residual heat removal system”
  - PDC 37, “Testing of the passive residual heat removal system”

# Staff Technical Evaluation: Review Process

---

- The NRC staff used relevant parts of NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors,” as guidance
- The NRC staff reviewed the DHRS against the relevant PDCs
- The NRC staff reviewed the preliminary system design to identify potential system failure modes
- The NRC staff audited the Kairos detailed system description and DHRS heat performance calculation that determined the level of system performance necessary to maintain the vessel below the SS-316 limit
- The NRC staff performed independent calculations to ensure water tank volumes are sufficient for 7 days of cooling



# Staff Technical Evaluation: Design-Specific Aspects

---

- The NRC staff ensured Kairos testing plans address several potential phenomena and failure modes, such as:
  - Potential flow and heat removal instability issues during the transition and in-service phases
  - Potential dynamic loads on the structure and components due to transition phase thermal shock and in-service evaporator boiling
  - Potential for corrosion and fouling in the evaporator tube
- The NRC staff noted that the DHRS design must accommodate the highest heat loads for vessel integrity and the lowest in-service heat loads to prevent freezing
  - Final determination on the adequacy of the DHRS to meet these competing design requirements will be made based on the final design presented in the OL application

# Staff Technical Evaluation: PDCs

---

- PDC 1 requires safety-significant SSCs to be designed, fabricated, erected, and tested to appropriate quality standards and identification of generally recognized codes and standards used
  - DHRS will be designed to American Society of Mechanical Engineers, American Society of Civil Engineers, and American Concrete Institute standards
  - Component design to these standards is evaluated in Chapters 3 and 4 of the NRC staff safety evaluation report (SER)
  - Quality assurance program is evaluated in Chapter 12 of the NRC staff SER
- PDC 2 requires protection against natural phenomena
  - DHRS located in safety related portion of reactor building except for steam vent lines
  - Failure of steam vent lines will not impede safety function
  - Seismic methodologies are evaluated in Sections 3.4 and 3.5 of the NRC staff SER

# Staff Technical Evaluation: PDCs

---

- PDC 3 requires protection against fires
  - DHRS designed with low combustible materials and physical separation
  - Fire protection program is evaluated in Section 9.4 of the NRC staff SER
- PDC 4 requires protection against environmental and dynamic effects
  - DHRS will be designed to withstand normal operating conditions and to protect against dynamic environmental effects
- PDCs 10, 34, and 35 address adequate heat removal under normal operation and postulated events
  - DHRS is designed with redundancy to protect against single failures
  - Preliminary calculations in PSAR suggest that DHRS removes heat adequately
- PDCs 36 and 37 address inspection and functional testing of the DHRS
  - DHRS is designed for online monitoring and access to perform inspections
  - DHRS will be functionally tested during startup phase

# Staff Technical Evaluation: Conclusions

---

- PSAR Chapter 13 demonstrates the need for DHRS as an engineered safety feature
- Preliminary PSAR analyses suggest that DHRS removes adequate amounts of decay heat and that radiological consequences are within 10 CFR Part 100 criteria; staff will confirm as part of OL application review
- DHRS has no adverse impacts to normal operations or safe shutdown
- Technical specifications and normal operation will confirm continued operability
- The Kairos DHRS test program will be key to finalizing the DHRS design

# Regulatory Findings

---

- The NRC staff concludes that the preliminary design is consistent with the associated PDCs and acceptance criteria in NUREG-1537
- The NRC staff finds that the information in Hermes PSAR Section 6.3 is sufficient for the issuance of a construction permit in accordance with 10 CFR 50.35 and 50.40, and further information can be reasonably left for the OL application

# Questions?



# **NRC Staff Review for PSAR Chapter 9 Auxiliary Systems**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**March 24, 2023**

By the Division of Advanced Reactors and  
Non-Power Production and Utilization Facilities,  
Office of Nuclear Reactor Regulation

# Chapter 9, “Auxiliary Systems”

---

- Format
  - 9.1: Reactor coolant auxiliary systems (chemistry control, inert gas, tritium management, inventory management, thermal management)
  - 9.2: Heating, ventilation, and air conditioning
  - 9.3: Pebble handling and storage
  - 9.4: Fire protection
  - 9.5: Communication
  - 9.6: Possession and use of byproduct, source, and special nuclear material
  - 9.7: Plant water (service water, treated water, component cooling water, chilled water)
  - 9.8: Other (remote maintenance and inspection, spent fuel cooling, compressed air, cranes and rigging, auxiliary site services)



# Overview of staff review

---

- Kairos applied for a CP and has not specifically requested approval of detailed design information
- Kairos provided a preliminary design description and a discussion of the relevant design bases (e.g., PDCs)
- NRC staff assessed whether the preliminary design information, including identification of relevant design bases, is sufficient to allow the staff to determine that
  - The information meets the relevant regulations for the issuance of a CP
  - The detailed design information can be left to the OL application

## 9.1.1 Chemistry Control System

---

- Used during normal operations to monitor coolant chemistry
- Ensures Flibe meets appropriate specifications
- Able to remove and replace reactor coolant to restore conformance to Flibe specifications
- Non-safety related system

# Staff Evaluation of CCS

---

- PDC 2 requires protection against natural phenomena
  - Seismic methodologies are evaluated in Sections 3.4 and 3.5 of the NRC staff SER
- PDC 4 requires protection against environmental and dynamic effects
  - CCS will be designed to protect against dynamic environmental effects
- PDC 70 requires the CCS to monitor and correct reactor coolant chemistry
  - The CCS will measure coolant purity and can correct chemistry via the IMS if needed
  - Sampling locations, methods, frequencies and required actions will be available for staff review as part of OL application
- Proposed limits for reactor coolant chemistry are supported by CCS functions.
  - LiF to BeF<sub>2</sub> ratio, circulating activity

## 9.1.2 Inert Gas System - Staff Evaluation

---

- PSAR Section 9.1.2 states the IGS is designed to:
  - Maintain inert environment, purge flow, remove impurities, tritium transport, and reactor coolant motive force
  - Assess purity, and process and store gases to ensure reactor and personnel safety
  - Ensure control and detection of leaks
- NRC staff has reasonable assurance criteria in NUREG-1537 can be met because:
  - IGS uses inert argon gas that is supplied to components with individually regulated temperatures, pressures, and flows
  - IGS contains storage tanks, equipment to measure and remove oxygen and moisture
  - IGS can be monitored for leaks and contains radiation monitors

## Staff Evaluation of IGS (Cont'd)

---

- PDC 2 requires protection against natural phenomena
  - seismic methodologies are evaluated in Sections 3.4 and 3.5 of the NRC staff SER
- PDC 4 requires protection against environmental and dynamic effects
  - IGS will be designed to prevent pipe whip and argon gas is inert
- PDC 64 requires the IGS to monitor radioactive releases
  - IGS has radiation monitors and can be inspected to detect leaks
  - Proposed TS on circulating activity
- Proposed TS for argon volume and purity consistent with NUREG-1537 guidance that gas purity should be assessed.

# Reactor coolant auxiliary systems

---

- Non-safety-related systems
  - Tritium mitigation – monitor and remove tritium in vapor spaces
  - Inventory management – add and remove salt coolant
  - Reactor thermal management – preheat reactor, cool cavity
- Review criteria – NUREG-1537, Section 9.7, “Other Auxiliary Systems”
  - Not result in reactor accidents
  - Not prevent safe shutdown of the reactor
  - Not result in unacceptable radioactive releases or exposure

# Reactor coolant auxiliary systems

---

- NRC staff review
  - Asked audit questions to enhance staff’s understanding of PSAR
  - Checked to ensure PDCs listed in PSAR are appropriate to meet the review criteria
  - Checked to ensure PDCs listed in PSAR are appropriate for each facility-unique system
    - E.g., Thermal management system lists PDC 71, “Reactor Coolant Heating Systems”

# Fuel handling and storage

---

- Pebble handling and storage system – circulate pebbles through core, load spent fuel in storage canister, transfer canister to pool
- Review criteria – NUREG-1537, “Handling and storage of spent fuel”
  - All special nuclear material accounted for
  - Fuel meets procurement specifications
  - Criticality prevented
  - Fuel-handling tools and procedures designed to avoid damaging fuel
  - Methods to assess fuel radioactivity and potential exposure rates adequate to avoid personnel overexposure
  - Shielding methods ensure doses below occupational exposure limits and ALARA



# Fuel handling and storage

---

- NRC staff review
  - Asked audit questions to enhance staff’s understanding of PSAR
  - Checked to ensure PDCs listed in PSAR are appropriate to meet the review criteria
    - E.g., PDC 62, “Prevention of criticality in fuel storage and handling”

# Staff conclusions

---

- The preliminary design of the auxiliary systems is sufficient and meets the applicable regulatory requirements and guidance for the issuance of a construction permit in accordance with 10 CFR 50.35.
- Further technical or design information required to complete the safety analysis can be left for later consideration in the FSAR.