



Post Office Box 2000, Decatur, Alabama 35609-2000

November 16, 2023

10 CFR 21.21

ATTN: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001

Browns Ferry Nuclear Plant, Units 1, 2, and 3  
Renewed Facility Operating License Nos. DPR-33, DPR-52, and DPR-68  
NRC Docket Nos. 50-259, 50-260, and 50-296

Subject: **Interim Report of a Deviation or Failure to Comply Associated with Check Valve 0-CKV-023-0565 for D1 Residual Heat Removal Service Water Pump**

Reference: Letter from TVA to NRC, "Interim Report of a Deviation or Failure to Comply Associated with Check Valve 0-CKV-023-0565 for D1 Residual Heat Removal Service Water Pump," dated October 6, 2023 (ML23282A002)

In accordance with the requirements of Title 10 of the Code of Federal Regulations (10 CFR) 21.21(a)(2), the Tennessee Valley Authority is submitting this interim report for Browns Ferry Nuclear Plant (BFN).

On August 10, 2023, following completion of maintenance on the D1 Residual Heat Removal Service Water (RHRSW) Pump and its check valve 0-CKV-023-0565, the clearance was removed. During the removal, header pressure dropped to 20 psig bringing in the "RHRSW Header Pressure Low" alarm and Unit 1 operators started the D2 RHRSW Pump to restore pressure. Initial thought was an air pocket caused the pressure drop. Following completion of the tagout, the D2 RHRSW Pump was secured and pressure dropped to 20 psig again. Unit 1 operations personnel restarted the D2 RHRSW Pump again to restore header pressure. An Assistant Unit Operator (AUO) was dispatched to walkdown the D1 RHRSW Pump alignment and found the pump rotating backwards. The AUO closed the D1 RHRSW Pump discharge valve as directed by the Senior Reactor Operator (SRO) and rotation stopped. Then the AUO slowly re-opened the discharge valve of the D1 RHRSW Pump and the backwards rotation began immediately. BFN completed its 10 CFR Part 21 discovery process and determined the need to perform a 10 CFR Part 21 Evaluation. The vendor for testing (Watts Water) was contacted and will assume responsibility for performing the Part 21 Evaluation for the check valve. This Part 21 Evaluation is being tracked by TVA under Condition Report 1873788.

U.S. Nuclear Regulatory Commission

Page 2

November 16, 2023

The check valves were returned to Watts Water for evaluation. The scheduled work to replace the remaining check valves was postponed until the evaluation can be completed. The vendor had expressed that they are tracking the Part 21 evaluation under tracking number 452830, and that the evaluation would be completed by November 1, 2023. Because the vendor evaluation was not completed by the previously reported due date, TVA requests an extension until January 15, 2024 to submit the Part 21 Report.

There are no new regulatory commitments contained in this letter. Should you have any questions concerning this submittal, please contact David Renn, Site Licensing Manager, at (256) 729-2636.

Respectfully,



M. Sivaraman  
Site Vice President

cc (w/ Enclosures):

NRC Regional Administrator - Region II  
NRC Senior Resident Inspector - Browns Ferry Nuclear Plant  
NRC Project Manager - Browns Ferry Nuclear Plant