


Reactor Oversight Process (ROP)


Internal Use Only

INTERNAL UNTIL PUBLIC POSTING

Fort Calhoun 4Q/2013 Performance Summary

Fort Calhoun was shut down in April 2011 and subsequently commenced power operation in December 2013. Mitigating Systems Performance Index (MSPI) performance indicators (PIs) are heavily influenced by the operational status of the reactor, NRC staff has evaluated the validity of these PIs. The MSPI values can become skewed because of the low number of critical hours during the assessment period (3 years) of the PI. For these reasons, the staff has determined that these PIs currently do not provide valid indications of performance. The low critical hours are also causing other indicators at this site to be invalid, in accordance with NEI 99-02.






Performance Indicators

Unplanned Scrams (N)	Safety System Functional Failures (W)	Reactor Coolant System Activity (G)	Drill/Exercise Performance (G)	Occupational Exposure Control Effectiveness (G)	RETS/DDCM Radiological Effluent (G)	Protected Area Equipment (G)
Unplanned Power Changes (N)	Emergency AC Power System (N)	Reactor Coolant System Leakage (G)	ERO Drill Participation (G)			
Unplanned Scrams with Complications (G)	High Pressure Injection System (N)		Alert and Notification System (G)			
	Heat Removal System (N)					
	Residual Heat Removal System (N)					
	Cooling Water Systems (N)					

Last Modified: January 22, 2014

Legend: R=Red W=White GTG=Greater Than Green I=Insufficient Data to Calculate PI U=Unique Design
 Y=Yellow G=Green T=Thresholds under development N=Not Applicable D=Discrepant



Most Significant Inspection Findings

4Q/2013	No findings this quarter	No findings this quarter	No findings this quarter	G	No findings this quarter	No findings this quarter	No findings this quarter
3Q/2013	No findings this quarter						
2Q/2013	G	G	G	G	G	No findings this quarter	G
1Q/2013	R (1)	G	No findings this quarter	G			

Miscellaneous findings

Additional Inspection & Assessment Information

◆ **Assessment Reports/Inspection Plans:**

- 4Q/2013
- 3Q/2013
- 2Q/2013
- 1Q/2013

◆ **Cross Reference Of Assessment Reports**

◆ **List of Inspection Reports (IR)**

- ◆ List of Security IR Cover Letters
- ◆ List of Assessment Letters/Inspection Plans
- ◆ Baseline Inspection Completion Information

Last Modified: February 24, 2014