


Hatch 1

3Q/2014 Performance Indicators

The solid trend line represents the current reporting period.

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
Unplanned scrams	0	1.0	0	0	0	0	0	0
Critical hours	2209.0	1790.9	2184.0	2208.0	2129.3	1465.9	2184.0	2208.0
Indicator value	0	0.8	0.8	0.8	0.8	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
Unplanned power changes	0	2.0	0	0	1.0	0	1.0	0
Critical hours	2209.0	1790.9	2184.0	2208.0	2129.3	1465.9	2184.0	2208.0
Indicator value	0.9	2.5	1.7	1.7	2.5	0.9	1.8	1.8

Licensee Comments: none

Unplanned Scrams with Complications




Thresholds: White > 1.0

Notes

Unplanned Scrams with Complications	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
Scrams with complications	0	0	0	0	0	0	0	0
Indicator value	0.0							

Licensee Comments: none

Safety System Functional Failures (BWR)



Thresholds: White > 6.0


Notes

Safety System Functional Failures (BWR)	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
Safety System Functional Failures	0	0	0	0	0	0	1	0
Indicator value	0	0	0	0	0	0	1	1

Licensee Comments:

2Q/14: LER 2014-002, HPCI Steam Leak Results in Water in the Turbine Making HPCI Inoperable.

Mitigating Systems Performance Index, Emergency AC Power System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, Emergency AC Power System	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
UAI (Δ CDF)	1.68E-07	1.69E-07	9.72E-08	8.68E-08	1.25E-07	5.34E-08	1.22E-07	7.52E-08
URI (Δ CDF)	2.98E-07	3.19E-07	1.34E-07	1.46E-07	-3.00E-08	-1.08E-07	-1.01E-07	-9.38E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	4.70E-07	4.90E-07	2.30E-07	2.30E-07	9.40E-08	-5.50E-08	2.10E-08	-1.90E-08

Licensee Comments:

2Q/14: Changed PRA Parameter(s).

1Q/14: Changed PRA Parameter(s). The Hatch baseline PRA models were revised October 12, 2013 to revision 4.1 per calculations PRA-CN-H-13-003 and PRA-CN-H-13-002. In accordance with NEI 99-02, Revision 7, the Hatch MSPI basis document was revised to incorporate the following changes: - Success criteria for each MSPSI Function was expanded to include details such as flow rates and response times as contained in the PRA model documentation success criteria. This did not change any CDE data, but clarifies what an MSPI failure is. - The Hatch MSPI base CDF numbers were revised. This affects all MSPI calculations. - Planned unavailability values (UABLP) were revised to match the planned maintenance numbers in the current PRA models. This updates the MSPI information to match the current maintenance philosophy. - Six circuit breakers and two valves were added to the MSPI scope on each unit, based on Birnbaum values. - The FVUAP and FVURC coefficients for every monitored component changed due to changes in the PRA model logic. - The tables containing the above coefficients in section 2.0 of the MSPI basis document were re-formatted to more closely match the CDE data input screen. - The MSPI margin for HPCI Failure to Start was reduced from five (5) to two (2). - All MSPI functions still remain in green.

Mitigating Systems Performance Index, High Pressure Injection System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, High Pressure Injection System	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
UAI (Δ CDF)	4.40E-08	1.01E-08	-1.75E-08	-2.24E-08	-2.11E-08	-7.73E-08	-7.44E-08	-7.44E-08
URI (Δ CDF)	-4.07E-08	-3.55E-08	-3.14E-08	-3.15E-08	-3.29E-08	-1.16E-07	3.25E-07	3.25E-07
PLE	NO							
Indicator value	3.30E-09	-2.50E-08	-4.90E-08	-5.40E-08	-5.40E-08	-1.90E-07	2.50E-07	2.50E-07

Licensee Comments:

1Q/14: Changed PRA Parameter(s). The Hatch baseline PRA models were revised October 12, 2013 to revision 4.1 per calculations PRA-CN-H-13-003 and PRA-CN-H-13-002. In accordance with NEI 99-02, Revision 7, the Hatch MSPI basis document was revised to incorporate the following changes: - Success criteria for each MSPSI Function was expanded to include details such as flow rates and response times as contained in the PRA model documentation success criteria. This did not change any CDE data, but clarifies what an MSPI failure is. - The Hatch MSPI base CDF numbers were revised. This affects all MSPI calculations. - Planned unavailability values (UABLP) were revised to match the planned maintenance numbers in the current PRA models. This updates the MSPI information to match the current maintenance philosophy. - Six circuit breakers and two valves were added to the MSPI scope on each unit, based on Birnbaum values. - The FVUAP and FVURC coefficients for every

monitored component changed due to changes in the PRA model logic. - The tables containing the above coefficients in section 2.0 of the MSPI basis document were re-formatted to more closely match the CDE data input screen. - The MSPI margin for HPCI Failure to Start was reduced from five (5) to two (2). - All MSPI functions still remain in green.

Mitigating Systems Performance Index, Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes

Mitigating Systems Performance Index, Heat Removal System	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
UAI (Δ CDF)	2.52E-08	2.41E-08	1.04E-08	1.03E-08	9.96E-09	4.27E-09	4.21E-09	1.21E-08
URI (Δ CDF)	1.35E-08	1.51E-08	1.62E-08	1.63E-08	1.62E-08	1.58E-08	1.57E-08	1.46E-08
PLE	NO							
Indicator value	3.90E-08	3.90E-08	2.70E-08	2.70E-08	2.60E-08	2.00E-08	2.00E-08	2.70E-08


Licensee Comments:

1Q/14: The Hatch baseline PRA models were revised October 12, 2013 to revision 4.1 per calculations PRA-CN-H-13-003 and PRA-CN-H-13-002. In accordance with NEI 99-02, Revision 7, the Hatch MSPI basis document was revised to incorporate the following changes: - Success criteria for each MPSI Function was expanded to include details such as flow rates and response times as contained in the PRA model documentation success criteria. This did not change any CDE data, but clarifies what an MSPI failure is. - The Hatch MSPI base CDF

numbers were revised. This affects all MSPI calculations. - Planned unavailability values (UABLP) were revised to match the planned maintenance numbers in the current PRA models. This updates the MSPI information to match the current maintenance philosophy. - Six circuit breakers and two valves were added to the MSPI scope on each unit, based on Birnbaum values. - The FVUAP and FVURC coefficients for every monitored component changed due to changes in the PRA model logic. - The tables containing the above coefficients in section 2.0 of the MSPI basis document were re-formatted to more closely match the CDE data input screen. - The MSPI margin for HPCI Failure to Start was reduced from five (5) to two (2). - All MSPI functions still remain in green.

1Q/14: Changed PRA Parameter(s). The Hatch baseline PRA models were revised October 12, 2013 to revision 4.1 per calculations PRA-CN-H-13-003 and PRA-CN-H-13-002. In accordance with NEI 99-02, Revision 7, the Hatch MSPI basis document was revised to incorporate the following changes: - Success criteria for each MSPI Function was expanded to include details such as flow rates and response times as contained in the PRA model documentation success criteria. This did not change any CDE data, but clarifies what an MSPI failure is. - The Hatch MSPI base CDF numbers were revised. This affects all MSPI calculations. - Planned unavailability values (UABLP) were revised to match the planned maintenance numbers in the current PRA models. This updates the MSPI information to match the current maintenance philosophy. - Six circuit breakers and two valves were added to the MSPI scope on each unit, based on Birnbaum values. - The FVUAP and FVURC coefficients for every monitored component changed due to changes in the PRA model logic. - The tables containing the above coefficients in section 2.0 of the MSPI basis document were re-formatted to more closely match the CDE data input screen. - The MSPI margin for HPCI Failure to Start was reduced from five (5) to two (2). - All MSPI functions still remain in green.

Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, Residual Heat Removal System	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
UAI (Δ CDF)	-1.02E-08	-1.10E-08	-1.88E-08	-4.08E-09	-4.52E-09	1.39E-08	1.38E-08	-1.20E-08
URI (Δ CDF)	-1.26E-07	-1.23E-07	-1.20E-07	-1.23E-07	-1.27E-07	-1.32E-07	-1.34E-07	-1.33E-07
PLE	NO							
Indicator value	-1.40E-07	-1.30E-07	-1.40E-07	-1.30E-07	-1.30E-07	-1.20E-07	-1.20E-07	-1.50E-07

Licensee Comments:

2Q/14: Changed PRA Parameter(s).

1Q/14: Changed PRA Parameter(s). The Hatch baseline PRA models were revised October 12, 2013 to revision 4.1 per calculations PRA-CN-H-13-003 and PRA-CN-H-13-002. In accordance with NEI 99-02, Revision 7, the Hatch MSPI basis document was revised to incorporate the following changes: - Success criteria for each MPSI Function was expanded to include details such as flow rates and response times as contained in the PRA model documentation success criteria. This did not change any CDE data, but clarifies what an MSPI failure is. - The Hatch MSPI base CDF numbers were revised. This affects all MSPI calculations. - Planned unavailability values (UABLP) were revised to match the planned maintenance numbers in the current PRA models. This updates the MSPI information to match the current maintenance philosophy. - Six circuit breakers and two valves were added to the MSPI scope on each unit, based on Birnbaum values. - The FVUAP and FVURC coefficients for every monitored component changed due to changes in the PRA model logic. - The tables containing the above coefficients in section 2.0 of the MSPI basis document were re-formatted to more closely match the CDE data input screen. - The MSPI margin for HPCI Failure to Start was reduced from five (5) to two (2). - All MSPI functions still remain in green.

Mitigating Systems Performance Index, Cooling Water Systems



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

Notes


Mitigating Systems Performance Index, Cooling Water Systems	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
UAI (Δ CDF)	1.13E-07	1.05E-07	1.05E-07	8.50E-08	4.20E-08	1.47E-10	1.50E-10	4.48E-09
URI (Δ CDF)	-8.03E-08	-8.00E-08	-8.08E-08	-8.22E-08	-8.56E-08	-7.94E-08	-8.28E-08	-8.45E-08
PLE	NO							
Indicator value	3.30E-08	2.50E-08	2.40E-08	2.70E-09	-4.40E-08	-7.90E-08	-8.30E-08	-8.00E-08

Licensee Comments:

2Q/14: Changed PRA Parameter(s).

1Q/14: Changed PRA Parameter(s). The Hatch baseline PRA models were revised October 12, 2013 to revision 4.1 per calculations PRA-CN-H-13-003 and PRA-CN-H-13-002. In accordance with NEI 99-02, Revision 7, the Hatch MSPI basis document was revised to incorporate the following changes: - Success criteria for each MSPSI Function was expanded to include details such as flow rates and response times as contained in the PRA model documentation success criteria. This did not change any CDE data, but clarifies what an MSPI failure is. - The Hatch MSPI base CDF numbers were revised. This affects all MSPI calculations. - Planned unavailability values (UABLP) were revised to match the planned maintenance numbers in the current PRA models. This updates the MSPI information to match the current maintenance philosophy. - Six circuit breakers and two valves were added to the MSPI scope on each unit, based on Birnbaum values. - The FVUAP and FVURC coefficients for every monitored component changed due to changes in the PRA model logic. - The tables containing the above coefficients in section 2.0 of the MSPI basis document were re-formatted to more closely match the CDE data input screen. - The MSPI margin for HPCI Failure to Start was reduced from five (5) to two (2). - All MSPI functions still remain in green.

Reactor Coolant System Activity



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Activity	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13	7/13	8/13	9/13
Maximum activity	0.000003	0.000003	0.000003	0.000006	0.000002	0.000004	0.000005	0.000006	0.000008	0.000010	0.000020	0.000010
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	10/13	11/13	12/13	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14
Maximum activity	0.000948	0.000019	0.000023	0.000011	0.000012	0.000188	0.000003	0.000002	0.000012	0.000003	0.000005	0.000004
Technical specification limit	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Indicator												

value	0.5	0	0	0	0	0.1	0	0	0	0	0	0
-------	-----	---	---	---	---	-----	---	---	---	---	---	---

Licensee Comments: none

Reactor Coolant System Leakage



Thresholds: White > 50.0 Yellow > 100.0


Notes

Reactor Coolant System Leakage	10/12	11/12	12/12	1/13	2/13	3/13	4/13	5/13	6/13	7/13	8/13	9/13
Maximum leakage	1.660	1.650	1.660	1.890	1.910	1.880	1.810	1.800	1.730	1.740	1.910	1.850
Technical specification limit	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Indicator value	5.5	5.5	5.5	6.3	6.4	6.3	6.0	6.0	5.8	5.8	6.4	6.2

Reactor Coolant System Leakage	10/13	11/13	12/13	1/14	2/14	3/14	4/14	5/14	6/14	7/14	8/14	9/14
Maximum leakage	2.110	2.140	1.970	1.850	1.980	2.240	2.100	2.210	2.430	2.550	2.420	2.290
Technical specification limit	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Indicator value	7.0	7.1	6.6	6.2	6.6	7.5	7.0	7.4	8.1	8.5	8.1	7.6

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
Successful opportunities	14.0	40.0	51.0	38.0	48.0	32.0	64.0	78.0
Total opportunities	14.0	40.0	54.0	38.0	50.0	32.0	65.0	78.0
Indicator value	96.4%	96.8%	96.7%	96.8%	96.8%	97.0%	97.2%	98.4%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
Participating Key personnel	130.0	110.0	112.0	110.0	111.0	110.0	106.0	107.0
Total Key personnel	130.0	110.0	112.0	110.0	111.0	110.0	106.0	107.0
Indicator value	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System



Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
Successful siren-tests							1040	1117
Total sirens-tests							1040	1119
Indicator value								

Licensee Comments:

1Q/14: Plant Hatch does not use sirens as an emergency notification system.

4Q/13: Plant Hatch does not use sirens as an emergency notification system.


3Q/13: Plant Hatch does not use sirens as an emergency notification system.

2Q/13: Plant Hatch does not use sirens as an emergency notification system.

1Q/13: Plant Hatch does not use sirens as an emergency notification system.

4Q/12: Plant Hatch does not use sirens as an emergency notification system.

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0							

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/12	1Q/13	2Q/13	3Q/13	4Q/13	1Q/14	2Q/14	3Q/14
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0							

Licensee Comments: none

Although the Security Cornerstone is included in the Reactor Oversight Process assessment program, the Commission has decided that specific information related to findings and performance indicators pertaining to the Security Cornerstone will not be publicly available to ensure that security information is not provided to a possible adversary. Other than the fact that a finding or performance indicator is Green or Greater-Than-Green, security related information will not be displayed on the public web page.

 [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: November 3, 2014