

December 28, 1999

Mr. Douglas R. Gipson
Senior Vice President
Nuclear Generation
Detroit Edison Company
6400 North Dixie Highway
Newport, MI 48166

SUBJECT: FERMI 2 - RELIEF REQUESTS FOR IMPLEMENTATION OF SUBSECTIONS
IWE AND IWL OF ASME CODE, SECTION XI, FOR CONTAINMENT
INSPECTION (TAC NO. MA6736)

Dear Mr. Gipson:

By letter dated September 17, 1999, as supplemented November 10, 1999, the Detroit Edison Company (the licensee) requested relief from certain containment inspection requirements of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI, for the Fermi 2 plant. The November 10, 1999, letter provided additional information regarding two of the relief requests and withdrew Relief Request CISI-005.

The NRC staff has completed its review of the seven remaining relief requests. Based on the information provided in the relief requests, the staff concludes that for Relief Requests CISI-003 and 008, the licensee's proposed alternatives will provide an acceptable level of quality and safety. Therefore, the proposed alternatives are authorized pursuant to 10 CFR 50.55a(a)(3)(i). For Relief Requests CISI-001, 002, 004, 006, and 007, the staff concludes that compliance with the code requirements would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety, and that the licensee's proposed alternatives will provide reasonable assurance of containment pressure integrity. Therefore, these proposed alternatives are authorized pursuant to 10 CFR 50.55a(a)(3)(ii). A copy of the staff's safety evaluation is enclosed.

Sincerely,

(original signed by)

Claudia M. Craig, Chief, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-341

Enclosure: Safety Evaluation

cc w/encl: See next page

DF01/11

NRC FILE CENTER COPY

DISTRIBUTION:
PDIII-1 Reading
ACRS

RScholl(e-mail SE)
TCheng

PUBLIC
OGC
GHill (2)

WBeckner
AVegel, RIII

TO RECEIVE A COPY OF THIS DOCUMENT, INDICATE "C" IN THE BOX

*NO SIGNIFICANT CHANGES TO S.E. INPUT
**SEE PREVIOUS CONCURRENCE

OFFICE	PDIII-1/PM	C	PDIII-1/LA	C	EMEB/SC*	OGC**	PDIII-1/SC	C
NAME	AKugler: <i>AK</i>		RBouling: <i>RB</i>		DTeruo	RBachmann	CCraig: <i>CC</i>	
DATE	12/22/99		12/23/99		11/23/99	12/17/99	12/28/99	

DOCUMENT NAME: G:\PDIII-1\FERMI\Rifa6736.wpd

OFFICIAL RECORD COPY

December 28, 1999

Mr. Douglas R. Gipson
Senior Vice President
Nuclear Generation
Detroit Edison Company
6400 North Dixie Highway
Newport, MI 48166

**SUBJECT: FERMI 2 - RELIEF REQUESTS FOR IMPLEMENTATION OF SUBSECTIONS
IWE AND IWL OF ASME CODE, SECTION XI, FOR CONTAINMENT
INSPECTION (TAC NO. MA6736)**

Dear Mr. Gipson:

By letter dated September 17, 1999, as supplemented November 10, 1999, the Detroit Edison Company (the licensee) requested relief from certain containment inspection requirements of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI, for the Fermi 2 plant. The November 10, 1999, letter provided additional information regarding two of the relief requests and withdrew Relief Request CISI-005.

The NRC staff has completed its review of the seven remaining relief requests. Based on the information provided in the relief requests, the staff concludes that for Relief Requests CISI-003 and 008, the licensee's proposed alternatives will provide an acceptable level of quality and safety. Therefore, the proposed alternatives are authorized pursuant to 10 CFR 50.55a(a)(3)(i). For Relief Requests CISI-001, 002, 004, 006, and 007, the staff concludes that compliance with the code requirements would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety, and that the licensee's proposed alternatives will provide reasonable assurance of containment pressure integrity. Therefore, these proposed alternatives are authorized pursuant to 10 CFR 50.55a(a)(3)(ii). A copy of the staff's safety evaluation is enclosed.

Sincerely,
(original signed by)
Claudia M. Craig, Chief, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-341

Enclosure: Safety Evaluation

cc w/encl: See next page

DISTRIBUTION:	File Center	PUBLIC	WBeckner
PDIII-1 Reading	RScholl(e-mail SE)	OGC	AVegel, RIII
ACRS	TCheng	GHill (2)	

TO RECEIVE A COPY OF THIS DOCUMENT, INDICATE "C" IN THE BOX

*NO SIGNIFICANT CHANGES TO S.E. INPUT
**SEE PREVIOUS CONCURRENCE

OFFICE	PDIII-1/PM	C	PDIII-1/LA	C	EMEB/SC*	OGC**	PDIII-1/SC	C
NAME	AKugler: <i>AK</i>		RBouling: <i>RB</i>		DTerao	RBachmann	CCraig: <i>CC</i>	
DATE	12/22/99		12/23/99		11/23/99	12/17/99	12/28/99	

DOCUMENT NAME: G:\PDIII-1\FERMI\RifA6736.wpd

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 28, 1999

Mr. Douglas R. Gipson
Senior Vice President
Nuclear Generation
Detroit Edison Company
6400 North Dixie Highway
Newport, MI 48166

SUBJECT: FERMI 2 - RELIEF REQUESTS FOR IMPLEMENTATION OF SUBSECTIONS
IWE AND IWL OF ASME CODE, SECTION XI, FOR CONTAINMENT
INSPECTION (TAC NO. MA6736)

Dear Mr. Gipson:

By letter dated September 17, 1999, as supplemented November 10, 1999, the Detroit Edison Company (the licensee) requested relief from certain containment inspection requirements of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI, for the Fermi 2 plant. The November 10, 1999, letter provided additional information regarding two of the relief requests and withdrew Relief Request CISI-005.

The NRC staff has completed its review of the seven remaining relief requests. Based on the information provided in the relief requests, the staff concludes that for Relief Requests CISI-003 and 008, the licensee's proposed alternatives will provide an acceptable level of quality and safety. Therefore, the proposed alternatives are authorized pursuant to 10 CFR 50.55a(a)(3)(i). For Relief Requests CISI-001, 002, 004, 006, and 007, the staff concludes that compliance with the code requirements would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety, and that the licensee's proposed alternatives will provide reasonable assurance of containment pressure integrity. Therefore, these proposed alternatives are authorized pursuant to 10 CFR 50.55a(a)(3)(ii). A copy of the staff's safety evaluation is enclosed.

Sincerely,

A handwritten signature in cursive script that reads "Claudia M. Craig".

Claudia M. Craig, Chief, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-341

Enclosure: Safety Evaluation

cc w/encl: See next page

Fermi 2

cc:

John Flynn, Esquire
Senior Attorney
Detroit Edison Company
2000 Second Avenue
Detroit, MI 48226

Drinking Water and Radiological
Protection Division
Michigan Department of
Environmental Quality
3423 N. Martin Luther King Jr Blvd
P. O. Box 30630 CPH Mailroom
Lansing, MI 48909-8130

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
6450 W. Dixie Highway
Newport, MI 48166

Monroe County Emergency Management
Division
963 South Raisinville
Monroe, MI 48161

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Norman K. Peterson
Director, Nuclear Licensing
Detroit Edison Company
Fermi 2 - 280 TAC
6400 North Dixie Highway
Newport, MI 48166

November 1999