



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

December 29, 1999

Mr. Harold W. Keiser  
Chief Nuclear Officer & President -  
Nuclear Business Unit  
Public Service Electric & Gas  
Company  
Post Office Box 236  
Hancocks Bridge, NJ 08038

SUBJECT: RESPONSE TO GENERIC LETTER 96-05, SALEM NUCLEAR GENERATING  
STATION, UNIT NOS. 1 AND 2 (TAC NOS. M97095 AND M97096)

Dear Mr. Keiser:

On September 18, 1996, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 96-05, "Periodic Verification of Design-Basis Capability of Safety-Related Motor-Operated Valves," requesting that each nuclear power plant licensee establish a program, or ensure the effectiveness of its current program, to verify that safety-related motor-operated valves (MOVs) continue to be capable of performing their safety functions within the current licensing bases of the facility.

On November 18, 1996, Public Service Electric and Gas Company (PSE&G) submitted its 60-day response to GL 96-05 to notify the NRC that it would implement the requested MOV periodic verification program at the Salem Nuclear Generating Station, Unit Nos. 1 and 2 (Salem). On March 13, 1997, PSE&G submitted its 180-day response to GL 96-05 providing a summary description of the MOV periodic verification program planned to be implemented at Salem. In a letter dated June 4, 1998, PSE&G updated its commitment to GL 96-05. On May 27, 1999, PSE&G provided a response to a request for additional information from the NRC staff dated March 23, 1999.

The NRC staff has reviewed PSE&G's submittals and the applicable NRC inspection reports for the MOV program at Salem. The staff finds that PSE&G has established an acceptable program to periodically verify the design-basis capability of the safety-related MOVs at Salem through its commitment to all three phases of the Joint Owners Group (JOG) Program on MOV Periodic Verification and the additional actions described in its submittals. As discussed in the attached safety evaluation (SE), the NRC staff concludes that PSE&G is adequately addressing the actions requested in GL 96-05. The NRC staff may conduct inspections at Salem to verify the implementation of the MOV periodic verification program is in accordance with the licensee's commitments, this SE, the NRC's SE dated October 30, 1997, on the JOG Program on MOV Periodic Verification, and the NRC's SE dated April 14, 1998, on the Westinghouse Owners Group methodology for ranking MOVs by their safety significance.

NRC FILE CENTER COPY

PDR Adock


DFOI

H. Keiser

- 2 -

This completes the staff's efforts on TAC Nos. M97095 and M97096. Please contact me at 301-415-1479 if you have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "W. C. Gleaves". The signature is written in a cursive style with a large initial "W" and a long, sweeping underline.

William C. Gleaves, Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-272 and 50-311

Enclosure: Safety Evaluation

cc w/encl: See next page

Salem Nuclear Generating Station,  
Units 1 and 2

cc:

Jeffrie J. Keenan, Esquire  
Nuclear Business Unit - N21  
P.O. Box 236  
Hancocks Bridge, NJ 08038

General Manager - Salem Operations  
Salem Nuclear Generating Station  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Mr. Louis Storz  
Sr. Vice President - Nuclear Operations  
Nuclear Department  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Senior Resident Inspector  
Salem Nuclear Generating Station  
U.S. Nuclear Regulatory Commission  
Drawer 0509  
Hancocks Bridge, NJ 08038

Dr. Jill Lipoti, Asst. Director  
Radiation Protection Programs  
NJ Department of Environmental  
Protection and Energy  
CN 415  
Trenton, NJ 08625-0415

Maryland Office of People's Counsel  
6 St. Paul Street, 21st Floor  
Suite 2102  
Baltimore, MD 21202

Ms. R. A. Kankus  
Joint Owner Affairs  
PECO Energy Company  
965 Chesterbrook Blvd., 63C-5  
Wayne, PA 19087

Mr. Elbert Simpson  
Senior Vice President-  
Nuclear Engineering  
Nuclear Department  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Richard Hartung  
Electric Service Evaluation  
Board of Regulatory Commissioners  
2 Gateway Center, Tenth Floor  
Newark, NJ 07102

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Lower Alloways Creek Township  
c/o Mary O. Henderson, Clerk  
Municipal Building, P.O. Box 157  
Hancocks Bridge, NJ 08038

Director - Licensing Regulation & Fuels  
Nuclear Business Unit - N21  
P.O. Box 236  
Hancocks Bridge, NJ 08038

Mr. David Wersan  
Assistant Consumer Advocate  
Office of Consumer Advocate  
1425 Strawberry Square  
Harrisburg, PA 17120

Manager - Joint Generation  
Atlantic Energy  
6801 Black Horse Pike  
Egg Harbor Twp., NJ 08234-4130

Carl D. Schaefer  
External Operations - Nuclear  
Delmarva Power & Light Company  
P.O. Box 231  
Wilmington, DE 19899

Public Service Commission of Maryland  
Engineering Division  
Chief Engineer  
6 St. Paul Centre  
Baltimore, MD 21202-6806