

DOCKETED
USNRC

'00 JAN -7 P3:47

January 4, 2000

OFFICE OF SECRETARY
REGULATORY AND
ADJUDICATIONS STATE

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

Before the Atomic Safety and Licensing Board

In the Matter of)

CAROLINA POWER & LIGHT)
COMPANY)

(Shearon Harris Nuclear Power Plant))

Docket No. 50-400-LA

ASLBP No. 99-762-02-LA

**SUMMARY OF FACTS, DATA, AND ARGUMENTS
ON WHICH APPLICANT PROPOSES TO RELY
AT THE SUBPART K ORAL ARGUMENT**

Of Counsel:
Steven Carr
Legal Department
CAROLINA POWER & LIGHT
COMPANY
411 Fayetteville Street Mall
Post Office Box 1551
Raleigh, North Carolina 27602-1551
(919) 546-4161

John H. O'Neill, Jr.
William R. Hollaway
SHAW PITTMAN
2300 N Street, N.W.
Washington, D.C. 20037-1128
(202) 663-8148
Counsel for CAROLINA POWER &
LIGHT COMPANY

TABLE OF CONTENTS

I.	INTRODUCTION	1
II.	LEGISLATIVE AND REGULATORY PURPOSE REQUIRING THE STRICT THRESHOLD FOR AN ADJUDICATORY HEARING IN A SUBPART K PROCEEDING	10
III.	SUMMARY STATEMENT OF THE RESULT OF THE APPLICATION OF THE STRICT THRESHOLD TO TECHNICAL CONTENTIONS 2 AND 3	16
A.	Technical Contention 2 – Criticality Control.....	16
1.	Basis 1 – Legal Interpretation of General Design Criterion (“GDC”) 62	16
2.	Basis 2 – Fuel Assembly Misplacement Analysis	16
B.	Technical Contention 3 – Spent Fuel Pool Cooling and Cleanup System Embedded Piping.....	17
1.	10 C.F.R. § 50.55a Alternative Plan to demonstrate adequate quality and safety of the embedded piping as constructed.....	17
2.	Adequacy of the inspections and tests as part of the Equipment Commissioning Plan to demonstrate the embedded piping has not been subject to significant corrosion or other deterioration and to demonstrate adequate quality and safety of the embedded piping “as is”	17
IV.	TECHNICAL CONTENTION 2	18
A.	Admitted Contention 2 and Other Issues Raised during Discovery	18
1.	Basis 1 of Contention 2.....	19
a.	Admitted Basis 1 – GDC 62 Prohibits Administrative Measures	19
b.	Other Issues Raised by BCOC during Discovery Regarding GDC 62	20

2.	Basis 2 of Contention 2.....	24
a.	Admitted Basis 2 – Single Fuel Assembly Misplacement.....	24
b.	Other Issues Raised by BCOC during Discovery Regarding Criticality Analysis	25
B.	Summary of Legal Argument Supporting the NRC Staff's Interpretation of GDC 62 as Allowing Administrative Measures to Enforce Fuel Enrichment and Burnup Limits for Criticality Control (Contention 2, Basis 1)	29
1.	Undisputed Relevant Facts that Inform and Support the Conclusions of Law	30
2.	As a Practical Matter, Every Method Available for Spent Fuel Pool Criticality Control is a Physical System or Process that is Implemented by some Administrative Measure.....	31
3.	The Regulatory History of GDC 62 Reveals That Administrative Measures Were Always Understood to be Included in GDC 62	35
4.	The Commission's 10 C.F.R. § 50.68 Rulemaking Affirms that the Commission Permits Administrative Measures, Fuel Enrichment Limits, and Fuel Burnup Limits for Criticality Control	44
5.	NRC Staff's Determination that Fuel Enrichment and Burnup Limits Comply with GDC 62 Should Be Accorded Considerable Weight.....	49
6.	Summary of Undisputed Material Facts and Conclusions of Law Sustaining the NRC Staff's Interpretation of GDC 62 Permitting Fuel Enrichment and Burnup Limits for Criticality Control and the Administrative Measures Required to Implement Such Limits.....	52
7.	New Position Raised by BCOC Cannot be Considered by the Board Except as an Implicit Admission that its Position in Contention 2, Basis 1, is Untenable	54

C.	Summary of Facts, Data and Arguments which Demonstrate that a Single Fuel Assembly Misplacement Could Not Cause Criticality in Harris Spent Fuel Pools C or D (Contention 2, Basis 2)	55
1.	Admitted Basis 2 – Single Fuel Assembly Misplacement.....	56
2.	Other Issues Raised by BCOC during Discovery Regarding Criticality Analysis.....	61
a.	BCOC’s First New Issue.....	62
b.	BCOC’s Second New Issue	66
c.	BCOC’s Third New Issue	69
D.	Intervenor BCOC Cannot Meet its Burden of Demonstrating an Adjudicatory Hearing Must Be Held to Dispose of Contention 2	70
1.	Basis 1 is a Question of Law for which an Adjudicatory Hearing is Not Appropriate.....	70
2.	Basis 2 presents no Genuine and Substantial Dispute of Fact for an Adjudicatory Hearing	71
V.	TECHNICAL CONTENTION 3	74
A.	Clarification of the Scope of Contention 3 during Discovery	74
B.	Summary of Facts, Data and Arguments which Demonstrate that CP&L’s 10 C.F.R. § 50.55a Alternative Plan Provides an Acceptable Level of Quality and Safety in the Spent Fuel Pool Cooling and Cleanup System for Harris Nuclear Plant Spent Fuel Pools C and D as Constructed	77
C.	Summary of Facts, Data and Arguments which Demonstrate that the SFPCCS Stainless Steel Piping and Welds Have not Significantly Deteriorated Due to Corrosion or Otherwise During the Period of Time Between Original Construction and Today, Are Suitable for Their Intended Purpose, and Provide an Adequate Level of Quality and Safety	89

D. Intervenor BCOC Cannot Meet its Burden of
Demonstrating an Adjudicatory Hearing Must Be Held to
Dispose of Contention 3.....105

VI. ACTIONS REQUESTED OF THE BOARD.....108

Exhibit Table of Contents

Exhibit No.	Exhibit Title	Attachment No.	Attachment Title
1.	Affidavit of S. Edwards	A	CP&L License Amendment Application (9 enclosures w/ supporting information)
		B	CP&L 4/30/99 (HNP-99-069), Response to RAI 1 (with enclosures 1, 3, 4, 7, 13, 14, 16, 17)
		C	CP&L 6/14/99 (HNP-99-094), Response to RAI 2 (with enclosure 1)
		D	CP&L 9/3/99 (HNP-99-129), Response to RAI 4 (with enclosure 1)
		E	CP&L 10/29/99 (HNP-99-172), Response to RAI 5 (with enclosures 1, 2, 3)
		F	CP&L 10/15/99 (HNP-99-156), Supplementary Response to Previous RAIs (with enclosure 1)
		G	Spent Fuel Pool Cooling and Cleanup System Description (SD-116) from the Harris Plant Operating Manual (Vol. 6 Part 2)
		H	Spent Fuel Pool Cooling and Cleanup System Schematic
		I	Harris Operating Procedure PLP-616, Fuel Handling Operations
		J	Harris Operating Procedure FHP-014, Fuel and Insert Shuffle Sequence
		K	Harris Operating Procedure FHP-020, Refueling Operations
		L	Harris Operating Procedure FHP-024, HNP Spent Fuel Handling Operations
		M	CP&L Nuclear Fuels Procedure NFP-NGGC-0021, Corporate Special Nuclear Material Accountability Plan

Exhibit No.	Exhibit Title	Attachment No.	Attachment Title
		N	CP&L Nuclear Fuels Procedure NFP-NGGC-0003, Procedure for Selection of Irradiated Fuel for Shipment in the IF-300 Spent Fuel Cask
		O	Harris Operating Procedure PLP-629, Reactivity Management Program, Attachment 6, Reactivity Management Controls, Spent Fuel Pool Activities
		P	Harris Operating Procedure CRC-001, SHNPP Environmental and Chemistry Sampling and Analysis Program (Chemistry Procedure for Control of Boron in Pool Water)
		Q	Engineering Service Request ("ESR") 99-00266, Evaluation of Units 2 and 3 Spent Fuel Pool Cooling Embedded Piping
		R	Special Plant Procedure ("SPP")-0312T, Temporary Procedure for Remote Visual Examination of Interior Welds and Surfaces of Embedded Unit 2 Spent Fuel Pool Cooling Piping for "C" and "D" Pools
		S	Hydrotest Report for a segment of the SFPCCS embedded piping that included field weld 2-SF-159-FW-518
		T	Hydrotest Report for a segment of the SFPCCS embedded piping that included field weld 2-SF-159-FW-519
2.	Affidavit of S. Turner	A	Resume
		B	10 C.F.R. Part 50 General Design Criterion ("GDC") 62, Prevention of criticality in fuel storage and handling
		C	10 C.F.R. § 50.68, Criticality accident requirements
		D	Reg. Guide 1.13, draft Revision 2, spent fuel storage facility design basis
		E	1978 Fuel Storage Guidance, Letter from Brian K. Grimes, NRC
		F	ANSI N 16.1-1975, Nuclear criticality safety in operations with fissionable materials outside reactors

Exhibit No.	Exhibit Title	Attachment No.	Attachment Title
		G	ANSI/ANS-8.1-1983 (revision to ANSI N 16.1-1975), Nuclear criticality safety in operations with fissionable materials outside reactors
		H	1998 Criticality Guidance, Memorandum from Laurance I. Kopp of the NRC Staff's Reactor System Branch
3.	Affidavit of E. Redmond II	A	Resume
		B	Harris Misplacement Analysis (PROPRIETARY)
		C	NRC Staff's Misplacement Analysis
4.	Affidavit of M. DeVoe	A	Resume
		B	Owner Review Comment Sheets for Harris Misplacement Analysis
5.	Affidavit of C. Griffin	A	QCI-19.1, Preparation & Submittal of Weld Data Report, Repair Weld Data Report, Tank Fabrication Weld Record & Seismic I Weld Data Report (Rev. 1)
		B	Weld Data Report ("WDR") for field weld FW-5
		C	Repair WDR for field weld FW-408 (included with the Deficiency and Disposition Report package No. 829)
6.	Affidavit of D. Shockley	A	CP&L ASME Quality Assurance Manual
		B	Hydrotest Report for a segment of the SFPCCs embedded piping that included field welds 2-SF-143-FW-512, -513, and -514
		C	Hydrotest Report for a segment of the SFPCCS embedded piping that included field welds 2-SF-1-FW-1, -2, -4, and -5

Exhibit No.	Exhibit Title	Attachment No.	Attachment Title
		D	Hydrotest Report for a segment of the SFPCCS embedded piping that included field welds 2-SF-144-FW-515, -516, and -517
		E	Deficiency and Disposition Report package No. 794
7.	Affidavit of W. T. Gilbert	A	Construction Procedure WP-115, Pressure Testing of Pressure Piping (Nuclear Safety Related)
		B	Hydrotest Report for a segment of the SFPCCS embedded piping that included field weld 2-SF-149-FW-408
		C	Hydrotest Report for a segment of the SFPCCS embedded piping that included field welds 2-SF-144-FW-515, -516, and -517
		D	Hydrotest Report for a segment of the SFPCCS embedded piping that included field welds 2-SF-143-FW-512, -513, and -514
		E	Concrete Placement Report for the internal wall of the spent fuel unloading building at elevation 281
8.	Affidavit of A. Moccari	A	Curriculum Vitae (includes Resume and List of Publications)
		B	5/12/99 Technical Report 99-90, Harris Nuclear Plant – Bacteria Detection in Water from the C&D Spent Fuel Pool Cooling Lines
		C	12/16/99 Technical Report 99-179, Harris Nuclear Plant – Bacteria Detection in a Deposit Sample and Chemical Analysis of Reddish-Brown Material from the C&D Spent Fuel Pool Cooling Lines
9.	Affidavit of G. Licina	A	Resume
		B	List of Publications
		C	Report No. SIR-99-127 Rev. 2, Evaluation of Embedded Welds in Spent Fuel Piping at Harris Nuclear Plant

Exhibit No.	Exhibit Title	Attachment No.	Attachment Title
10.	Deposition of D. Lochbaum, with errata sheets		
11.	Deposition of G. Thompson, with errata sheets		
12.	Deposition of L. Kopp, with errata sheets		
13.	Letter from John J. Kearney, Senior Vice President, Edison Electric Institute, to Secretary of the Commission, dated February 17, 1984		
14.	NRC Inspection Report No. 50-400/99-12, dated December 28, 1999		
15.	<p>NRC Correspondence on the GDC 62 Rulemaking:</p> <ul style="list-style-type: none"> A. Press Release from the AEC on proposed GDC rulemaking (11/65) B. Comparison of drafts 10/20/66 and 02/06/67 C. Memorandum from ACRS providing comments on GDC rulemaking (02/67) D. AEC-R 2/57 – Note by the Secretary regarding proposed GDC (06/67) E. Letter from AEC to ACRS regarding review of proposed GDC (07/69) F. SECY-R 143 – Note by the Secretary regarding amendment to GDC (01/71) 		
16.	<p>Statements of Consideration for GDC 62:</p> <ul style="list-style-type: none"> A. Proposed Rule (1967) B. Final Rule (1971) 		
17.	<p>Public Comments on GDC 62:</p> <ul style="list-style-type: none"> A. Letter from Oak Ridge National Laboratory, Sept. 6, 1967 B. Letter from Atomics International, Sept. 25, 1967 		
18.	<p>NRC Correspondence on the 10 C.F.R. § 50.68 Rulemaking:</p> <ul style="list-style-type: none"> A. SECY B. SRM and Commission Voting Records 		

Exhibit No.	Exhibit Title	Attachment No.	Attachment Title
19.	Statements of Consideration and Public Comments for 10 C.F.R. § 50.68: A. Direct Final Rule B. Proposed Rule C. Public Comments on 10 C.F.R. § 50.68 Rulemaking (Letter from Northern States Power Co., Jan. 2, 1998) D. Withdrawal of Direct Final Rule E. Final Rule		
20.	NRC Correspondence on Reg. Guide 1.13 A. NRC Memorandum, Aug. 1979 – response to regulatory guide review request B. NRC Memorandum, Aug. 1981 – draft 1 of Reg. Guide 1.13 Revision 2 C. NRC Memorandum, Sept. 1981 – draft 1 of Reg. Guide 1.13 Revision 2		

TABLE OF AUTHORITIES

CASES

<u>Carolina Power & Light Co.</u> (Shearon Harris Nuclear Power Plant), LBP-99-25, 50 NRC 25 (1999).....	<i>passim</i>
<u>Consumers Power Co.</u> (Big Rock Point Nuclear Plant), ALAB-725, 17 NRC 562 (1983).....	52
<u>Northern States Power Co. v. Department of Energy</u> , 128 F.3d 754 (D.C. Cir. 1997).....	10
<u>Petition for Emergency and Remedial Action</u> , CLI-78-6, 7 NRC 400 (1978).....	52
<u>Public Service Co. of New Hampshire</u> (Seabrook Station , Units 1 and 2), ALAB-899, 28 NRC 93 (1988)	23
<u>Vermont Yankee Nuclear Power Corp.</u> (Vermont Yankee Nuclear Power Station), LBP-88-25, 28 NRC 394 (1988)	23, 24, 28

STATUTES AND REGULATIONS

10 C.F.R. § 2.1113(a) (1997).....	1
10 C.F.R. § 2.1115(a)(2) (1997)	13
10 C.F.R. § 2.1115(b) (1997).....	12
10 C.F.R. § 2.714(a) (1997).....	55
10 C.F.R. § 2.714(e) (1997).....	14, 71
10 C.F.R. § 2.749 (1997)	15
10 C.F.R. § 2.749(d) (1997).....	15
10 C.F.R. § 50.68 (1997)	<i>passim</i>
10 C.F.R. §50.55a (a)(3)(i) (1997).....	<i>passim</i>
10 C.F.R. Part 2, Subpart K (1997).....	<i>passim</i>
10 C.F.R. Part 50, Appendix A (1997)	<i>passim</i>
10 C.F.R. Part 50, Appendix B (1997)	<i>passim</i>
42 U.S.C. § 10101 <i>et seq.</i> (1997).....	10
42 U.S.C. § 10151(b)(1) (1988).....	11
42 U.S.C. § 10151(a)(1) (1988).....	11

42 U.S.C. § 10152 (1988).....	11
42 U.S.C. § 10154 (1988).....	11
42 U.S.C. § 10154(a) (1988).....	11
42 U.S.C. § 10154(b) (1988)	12
48 Fed. Reg. 54,499 (1983)	13
50 Fed. Reg. 41,662 (1985)	12, 13
58 Fed. Reg. 28,050 (1993)	50
59 Fed. Reg. 27,049 (1994)	50
61 Fed. Reg. 7,542 (1996)	50
63 Fed. Reg. 40,551 (1998)	50

MISCELLANEOUS

128 Cong. Rec. S15,644 (daily ed. Dec. 20, 1982) (statement of Sen. Mitchell).....	12
128 Cong. Rec. S4,155 (daily ed. April 28, 1982) (statement of Sen. McClure)	12
H.R. Rep. No. 97-785, pt. 1 (1982).....	10, 11, 12
Viability Assessment of a Repository at Yucca Mountain, DOE/RW-0508 (December 1998)	10

January 4, 2000

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**
Before the Atomic Safety and Licensing Board

In the Matter of)	
)	
CAROLINA POWER & LIGHT)	Docket No. 50-400-LA
COMPANY)	
(Shearon Harris Nuclear Power Plant))	ASLBP No. 99-762-02-LA

**SUMMARY OF FACTS, DATA, AND ARGUMENTS ON WHICH APPLICANT
PROPOSES TO RELY AT THE SUBPART K ORAL ARGUMENT**

I. INTRODUCTION

Pursuant to the Board's Memorandum and Order (Granting Request to Invoke 10 C.F.R. Part 2, Subpart K Procedures and Establishing Schedule) dated July 29, 1999, as amended by the Board's Memorandum and Order (Extending Time for Written Summaries and Oral Argument) dated December 13, 1999, Applicant Carolina Power & Light Company ("CP&L") submits its "Summary of Facts, Data, and Arguments on which Applicant Proposes to Rely at the Subpart K Oral Argument" ("Applicant's Summary"). As required by 10 C.F.R. § 2.1113(a), attached as exhibits to Applicant's Summary are supporting facts and data in the form of sworn written affidavits.

This proceeding relates to CP&L's December 23, 1998 application for a license amendment to place spent fuel pools C and D in service at CP&L's Harris Nuclear Plant

("Harris Plant," "HNP," or "Harris"). The Harris Plant was originally planned as a four nuclear unit site (Harris 1, 2, 3 and 4). In order to accommodate four units, the Harris Fuel Handling Building was designed and constructed with four separate pools capable of storing spent fuel. Spent fuel pools A and B were originally intended to support Harris 1 and 4. Spent fuel pools C and D were originally intended to support Harris 2 and 3.

Harris 3 and 4 were canceled in late 1981. Harris 2 was canceled in late 1983. Spent fuel pools A, B, C and D and the spent fuel pool cooling and cleanup system ("SFPCS") for spent fuel pools A and B were completed as part of the Fuel Handling Building, are described in the HNP Final Safety Analysis Report, and are licensed as part of the HNP. Construction on the SFPCS for spent fuel pools C and D was discontinued after Harris 2 was canceled. By that time, all four spent fuel pools had been constructed, concrete had been poured, and the SFPCS piping was installed, welded in place and embedded in reinforced concrete.

Harris 1 began commercial operations in 1987. In addition, HNP was licensed to accept spent fuel for storage from CP&L's other nuclear plants, H. B. Robinson Unit 2, and Brunswick Units 1 and 2. Beginning in 1989, spent fuel assemblies from Robinson and Brunswick have been regularly shipped to the Harris Plant and are stored in spent fuel pools A and B.

The December 23, 1998 license amendment request and the need to expand spent fuel storage at HNP result from the failure of the U.S. Department of Energy ("DOE") to begin taking delivery of spent fuel in 1998, as required by the contract between DOE and

CP&L and by the Nuclear Waste Policy Act of 1982, as amended. CP&L requested that the license amendment to allow placement of spent fuel in spent fuel pools C and D be issued no later than December 31, 1999. CP&L plans to begin loading spent fuel in pool C beginning in 2000. Delays would adversely impact CP&L's ability to maintain adequate spent fuel storage capacity and, with the loss of full core discharge capability at one or more of CP&L's nuclear plants, could lead to a forced shutdown condition.

Applicant invoked the Subpart K Procedures after the Board admitted Technical Contentions 2 and 3 proffered by intervenor Board of Commissioners of Orange County ("BCOC") in its Memorandum and Order (Ruling on Standing and Contentions) dated July 12, 1999. The Commission adopted 10 C.F.R. Part 2, Subpart K to implement a Congressional mandate for expedited licensing procedures designed to encourage utilities to expand spent fuel storage capacity at reactor sites.

Part II of Applicant's Summary describes the legislative and regulatory purpose requiring the strict threshold for an adjudicatory hearing in a Subpart K proceeding.

Part III summarizes Applicant's position on the application to the strict threshold to Technical Contentions 2 and 3.

Part IV addresses Technical Contention 2. First, we discuss Contention 2 as admitted and the new issues BCOC has raised that are outside the scope of the contention. Second, we brief the legal arguments which support the NRC Staff's consistent interpretation of General Design Criterion 62 since it was adopted in 1971 as

allowing burnup credit for criticality control in spent fuel pools. Third, we summarize facts, data and arguments which demonstrate that a single fuel assembly misplacement could not cause criticality in Harris spent fuel pools C and D. Fourth, we summarize our arguments why BCOC cannot meet its burden of demonstrating an adjudicatory hearing must be held to dispose of Contention 2.

Part V addresses Technical Contention 3. First, we point out the clarification and narrowing of Contention 3 during discovery. Second, we summarize facts, data and arguments which demonstrate that CP&L's 10 C.F.R. § 50.55a Alternative Plan provides an acceptable level of quality and safety in the as constructed SFPCCS for spent fuel pools C and D. Third, we summarize facts, data and arguments which demonstrate that the SFPCCS embedded piping and field welds have not deteriorated due to corrosion or otherwise during the period between construction and today, are suitable for their intended purpose, and provide an adequate level of quality and safety. Fourth, we summarize our arguments why BCOC cannot meet its burden of demonstrating an adjudicatory hearing must be held to dispose of Contention 3.

Part VI states the actions requested of the Board by Applicant at the conclusion of oral argument.

Applicant's Summary is supported by nine sworn statements in the form of affidavits. In the remainder of this Introduction, we introduce each affidavit and its purpose.

· Exhibit 1 is the Affidavit of R. Steven Edwards ("Edwards Affidavit"). Mr. Edwards has been employed by CP&L since 1982. He is presently the Supervisor, Spent Fuel Pool Project, and is responsible for commissioning and placing into service spent fuel pools C and D at the Harris Plant. Mr. Edwards first summarizes the background of the license amendment request and the information submitted in support of the application. He describes Harris Plant procedures, controls, physical conditions, physical constraints, and calculations that establish a single fuel assembly misplacement in HNP spent fuel pools C and D, involving a fuel element of the wrong burnup or enrichment, cannot cause criticality in the fuel pool. Next, he describes the basis for the 10 C.F.R. §50.55a Alternative Plan that provides assurance of acceptable quality and safety of the stainless steel piping that is part of the SFPCS for spent fuel pools C and D -- notwithstanding the destruction of the weld data reports for the field welds in that piping. He then describes the measures set forth in the Equipment Commissioning Plan for spent fuel pools C and D to ensure that there has not been significant degradation of the components and piping in the SFPCS that would affect their suitability for service. Mr. Edwards provides the results of additional inspections and tests to confirm the acceptable condition of the SFPCS piping embedded in concrete. Finally, he discusses the insignificant impact on Harris Plant operations and safety in the highly improbable event of a failure of a weld in the embedded piping, and describes the counter-balancing hardship and unusual difficulty that would result if CP&L were required to commission spent fuel pools C and D without approval of the 50.55a Alternative Plan.

Exhibit 2 is the Affidavit of Dr. Stanley E. Turner, PE ("Turner Affidavit"). Dr. Turner is Senior Vice President and Chief Nuclear Scientist of Holtec International. Dr. Turner has four decades' experience in criticality safety analysis for nuclear power plants and has personally performed criticality analyses, and authored the related reports to support approximately 60 to 70 license amendment requests for spent fuel pool storage. In his affidavit Dr. Turner explains the physical systems or processes available as criticality control methods for spent fuel storage, and the administrative measures used to implement each method. He also discusses the NRC's regulations governing criticality control for spent fuel pools, including General Design Criterion 62 and 10 C.F.R. § 50.68. He addresses specific aspects of the NRC Staff's regulatory guidance concerning spent fuel pool criticality control, including the Double Contingency Principle and the implementation of burnup credit. He also provides information concerning the prevalence of the use of burnup credit for spent fuel pool criticality control at numerous sites across the country. Finally, he provides his review of the nuclear criticality analysis performed by the NRC Staff for this proceeding.

Exhibit 3 is the Affidavit of Dr. Everett L. Redmond II ("Redmond Affidavit"). Dr. Redmond is a nuclear engineer with Holtec International and one of Holtec's principal engineers responsible for performing nuclear criticality analyses for spent fuel storage systems. Dr. Redmond describes the misplacement analysis that he performed for Harris spent fuel pools C and D and summarizes its principal conclusions. He also provides his review of the nuclear criticality analysis performed by the NRC Staff for this proceeding.

Exhibit 4 is the Affidavit of Michael J. DeVoe ("DeVoe Affidavit"). Mr. DeVoe is a nuclear engineer, employed since 1984 by CP&L, who presently works in the Nuclear Fuel Services Unit of CP&L's Nuclear Fuels Management & Safety Analysis Section. He is responsible for performing the Owner's Review of the nuclear criticality analyses for Harris Nuclear Plant spent fuel pools C and D. His affidavit describes the CP&L review and confirmation of information in the fuel assembly misplacement analysis prepared by Dr. Redmond.

Exhibit 5 is the Affidavit of Charles H. Griffin ("Griffin Affidavit"). Mr. Griffin is a materials engineer employed by CP&L in its Corporate Nuclear Engineering Department. Mr. Griffin worked at the Harris Nuclear Plant as a Welding Engineer from 1978 through 1986, and was responsible for welding activities on piping during Harris Plant construction. Mr. Griffin attests to the quality of the welding program during the construction of the Harris Plant, specifically during the welding of the SFPCS piping now embedded in concrete. In addition, he reviewed the videotapes pertaining to the visual inspection of the interior of the SFPCS piping and welds, and reports on his evaluation of the condition and suitability for service of the welds that he reviewed in those tapes.

Exhibit 6 is the Affidavit of David L. Shockley ("Shockley Affidavit"). Mr. Shockley began work at the Harris Nuclear Plant in 1979 as a quality assurance ("QA") inspector, and continued in various QA-related activities at HNP through construction of Harris. He is now the Supervisor of Configuration Management at the Harris Nuclear

Plant. The purpose of his affidavit is first to describe briefly CP&L's QA Program and the implementation of the ASME N-Stamp Program during Harris construction, particularly as it applied to the installation of ASME Section III, Class 3 stainless steel piping. Mr. Shockley also confirms from personal knowledge the acceptability of certain field welds on the SFPCCS piping installed for spent fuel pools C and D.

Exhibit 7 is the Affidavit of William T. Gilbert ("Gilbert Affidavit"). Mr. Gilbert also began work at the Harris Plant as a QA inspector and has worked for CP&L at HNP since 1979. He has twenty years of experience in QA activities and presently is a Lead Auditor in the Procurement, Dedication & Vendor/Equipment Services Unit at HNP. Based on his extensive first-hand knowledge, Mr. Gilbert describes aspects of CP&L's QA Program and the implementation of the ASME N-Stamp program during Harris Plant construction, particularly as it applied to the installation of ASME Section III, Class 3 stainless steel piping. He also confirms from personal knowledge the acceptability of certain field welds on the SFPCCS piping installed for spent fuel pools C and D.

Exhibit 8 is the Affidavit of Dr. Ahmad A. Moccari ("Moccari Affidavit"). Dr. Moccari is a scientist specializing in corrosion. His Ph.D. in metallurgical engineering was awarded by Ohio State University. Dr. Moccari has been employed as a senior engineer by CP&L since 1982 at the Harris Energy and Environmental Center. In his affidavit, Dr. Moccari reports (1) the results of tests that he performed in May 1999 to determine whether nuisance bacteria were present in the water samples from the SFPCCS piping; (2) his observations and conclusions regarding the condition of the SFPCCS

pipng, based on his review of videotapes from a video camera inspection of the internals of the SFPCCS piping embedded in the concrete walls and floor of spent fuel pools C and D; and (3) the results of the tests he conducted to characterize the microbiological nature of the localized, reddish-brown deposits on field weld 2-SF-144-FW-517 in the SFPCCS piping.

Exhibit 9 is the Affidavit of George J. Licina ("Licina Affidavit"). Mr. Licina is a metallurgical engineer and is the leading expert on corrosion at Structural Integrity Associates, Inc. Mr. Licina has over 25 years' experience in evaluating environmental degradation of materials in power plant and other industrial environments, including all forms of corrosion and stress-corrosion cracking in aqueous environments, irradiation embrittlement, and Microbiologically Influenced Corrosion. CP&L asked Mr. Licina to provide a third-party independent review of the structural integrity and suitability for service of stainless steel piping in the SFPCCS for spent fuel pools C and D at the Harris Nuclear Plant. Mr. Licina's affidavit introduces his independent expert report which concludes that the information available today allows no reasonable doubt that the SFPCCS piping was properly installed, has suffered no significant degradation since installation that would shorten its expected service life, and can be expected to operate under its expected service conditions for its design service life without significant degradation.

Exhibit 10 is the transcript of the sworn deposition of BCOC's expert Mr. David Lochbaum.

Exhibit 11 is the transcript of the sworn deposition of BCOC's expert Dr. Gordon Thompson.

Exhibit 12 is the transcript of the sworn deposition of the NRC Staff's expert on criticality analyses Dr. Laurence Kopp.

Exhibits 13 through 20 are regulatory documents, described in the table of contents, and provided as exhibits for the convenience of the Board.

II. LEGISLATIVE AND REGULATORY PURPOSE REQUIRING THE STRICT THRESHOLD FOR AN ADJUDICATORY HEARING IN A SUBPART K PROCEEDING

Congress passed the Nuclear Waste Policy Act of 1982, 42 U.S.C. § 10101 et seq., in order to establish a federal program for funding and development of a permanent disposal repository for spent nuclear fuel and other high-level nuclear waste. See H.R. Rep. No. 97-785, pt. 1, at 32 (1982). Congress recognized that it would be many years before the permanent repository was ready to accept spent fuel. The Act therefore made provisions for interim storage of the spent fuel.¹ Congress determined that the operators of civilian nuclear power reactors have "primary responsibility" for interim storage of spent fuel, and that they should do so "by maximizing, to the extent practical, the

¹ Congress correctly anticipated the need to encourage interim storage of spent fuel. The Department of Energy ("DOE") has defaulted on its statutory obligation to complete the repository and begin accepting spent fuel by January 1998. Northern States Power Co. v. Department of Energy, 128 F.3d 754 (D.C. Cir. 1997). DOE has stated that it will not be ready to begin accepting spent fuel until 2010, at the earliest. Viability Assessment of a Repository at Yucca Mountain, DOE/RW-0508, 3 (December 1998). Thus, the need for expanded interim storage capacity at reactor sites is growing ever more acute.

effective use of existing storage facilities at the site of each civilian nuclear power reactor, and by adding new onsite storage capacity in a timely manner where practical.” 42 U.S.C. § 10151(a)(1). Congress further declared that the purpose of the Act was to promote “the addition of new spent nuclear fuel storage capacity” at civilian reactor sites. Id. § 10151(b)(1). To that end, all federal agencies were directed “to encourage and expedite the effective use of available storage, and necessary additional storage” at reactor sites. Id. § 10152. Congress specifically recognized that several methods could be used for effectively expanding storage capacity, including “the use of high-density fuel storage racks” and “the transshipment of spent nuclear fuel to another civilian nuclear power reactor within the same utility system.” Id. § 10154.

The Act also provided special expedited licensing procedures designed “to encourage utilities to expand storage capacity at reactor sites.” H. R. Rep. No. 97-785, at 39. The new procedures require written submissions and sworn testimony on any contentions, along with oral argument on the issues. 42 U.S.C. § 10154(a). Following the oral argument, the Licensing Board must determine whether any of the contentions merits an adjudicatory hearing:

(b) ADJUDICATORY HEARING. (1) At the conclusion of any oral argument ..., the Commission shall designate any disputed question of fact, together with any remaining questions of law, for resolution in an adjudicatory hearing only if it determines that —

(A) there is a genuine and substantial dispute of fact which can only be resolved with sufficient accuracy by the introduction of evidence in an adjudicatory hearing; and

(B) the decision of the Commission is likely to depend in whole or in part on the resolution of such dispute.

Id. § 10154(b). Congress reasoned that by “scoping” the issues in this manner, the time and expense of adjudicatory hearings could be avoided unless the issues were truly significant and capable of accurate resolution only through full-blown adjudicatory proceedings. H.R. Rep. No. 97-785, at 39, 82. It was recognized that the standards for an adjudicatory hearing were “extremely narrow.” 128 Cong. Rec. S15,644 (daily ed. Dec. 20, 1982) (statement of Sen. Mitchell). Nevertheless, the narrow standards were judged necessary for a “streamlined regulatory process” that would “insure predictable and timely measures necessary to keep America’s nuclear power plants in full operation without any threat of reduced operations or shutdown because of a failure by the Federal Government to provide for interim spent fuel management.” 128 Cong. Rec. S4155 (daily ed. April 28, 1982) (statement of Sen. McClure).

The Commission implemented the Act’s new procedures via a 1985 rulemaking that added Subpart K to the Commission’s regulations. 50 Fed. Reg. 41,662 (1985). The regulations track the statutory language. Thus, an issue may be designated for an adjudicatory hearing *only* if (1) there is a genuine and substantial dispute of fact; *and* (2) the dispute can be resolved with sufficient accuracy only through introduction of evidence at an adjudicatory hearing; *and* (3) the Commission’s ultimate decision is likely to depend in whole or in part on the resolution of the dispute. 10 C.F.R. § 2.1115(b).

Any issues not meeting this test are to be disposed of by the Licensing Board promptly after the oral argument. Id. § 2.1115(a)(2).²

In adopting the regulations, the Commission made it clear that the threshold for an adjudicatory hearing is strict:

The Commission continues to believe that the statutory criteria are sufficient. As the Commission pointed out in connection with the proposed rules, the statutory criteria are *quite strict* and are designed to ensure that the hearing is focused exclusively on *real issues*. They are similar to the standards under the Commission's existing rule for determining whether summary disposition is warranted. *They go further, however, in requiring a finding that adjudication is necessary to resolution of the dispute and in placing the burden of demonstrating the existence of a genuine and substantial dispute of material fact on the party requesting adjudication.*

50 Fed. Reg. at 41,667 (emphasis added).

Accordingly, BCOC here bears the burden of demonstrating that it is entitled to an adjudicatory hearing. And the rules must be strictly applied to limit such hearings to real issues that can be decided only through formal adjudicatory procedures. *First*, there must be a dispute of fact. Pure questions of law obviously do not require an adjudicatory

² The proposed rule would have required the Licensing Board to "decide" all issues not designated for an adjudicatory hearing. 48 Fed. Reg. 54,499, 54,505 (1983). The Edison Electric Institute and a group of interested utilities submitted comments challenging the proposed language requiring the Board to "decide" all issues, when in fact "dismiss" may be the more appropriate way to resolve certain issues. See Letter from John J. Kearney, Senior Vice President, Edison Electric Institute, to Secretary of the Commission (February 17, 1984) (attached as Exhibit 13). The NRC accommodated this comment in

Footnote continued on next page

hearing and can be resolved by the Licensing Board on the briefs.³ The only exceptions might be legal issues so interrelated with factual issues designated for a full hearing that they cannot be decided independent of the factual determination. Legal issues standing alone could never justify an adjudicatory hearing.

Second, the factual dispute must be genuine and substantial. If the dispute is genuine but peripheral or of secondary importance, then no hearing is warranted and the Licensing Board can resolve the issue on the basis of the sworn testimony and written submissions filed by the parties.

Third, even if the factual dispute is genuine and substantial, a hearing is still unwarranted unless it is the type of dispute that can be accurately resolved only with the traditional adjudicatory procedures, such as oral testimony from live witnesses subject to cross-examination. This might be the case, for example, if the issue turned primarily on the credibility of a particular witness. Most factual disputes, however, depend on technical or scientific issues that can be accurately decided on written submissions. Such issues are typically decided on the basis of plant records, scientific reports and other written materials that the Licensing Board itself can evaluate, drawing upon its own

Footnote continued from previous page

the final rule by using the term "dispose," which can include both "decide" and "dismiss."

³ See 10 C.F.R. § 2.714(e) ("If the Commission or the presiding officer determines that any of the admitted contentions constitute pure issues of law, those contentions must be decided on the basis of briefs or oral argument according to a schedule determined by the Commission or presiding officer.")

technical expertise. The accuracy of the decision-making process would not be enhanced by cross-examination of live witnesses. In this sense, the Subpart K rules go beyond the usual summary disposition procedures, as the Commission pointed out. Under the usual summary disposition procedures, any genuine issue of material fact requires a hearing. 10 C.F.R. § 2.749. Under Subpart K, by contrast, Licensing Boards must dispose of genuine factual issues without a hearing if they are able to do so with sufficient accuracy.

Fourth, the resolution of the factual issue must be central to the ultimate decision in the case. The summary disposition rules simply require the factual issue to be “material.” Id. § 2.749(d). The Subpart K rules could have used the same phrase but did not. Instead, they provide that a hearing may be held only if the Commission’s decision “is likely to depend in whole or in part” on the resolution of the factual dispute. This is a stricter threshold than simple materiality. It implies that the factual issue must play a central role in the ultimate outcome of the case as a whole. Failing that, no adjudicatory hearing may be held.

This proceeding will be the first time the strict standards of Subpart K will actually be applied to a license amendment proceeding. Thus, we do not have the benefit of precedent in interpreting the Subpart K standards. However, applying these standards to the case at hand will not require careful line drawing. As will become abundantly evident, BCOC cannot meet its burden of showing that an adjudicatory hearing is warranted. To hold such a hearing in this case would surely thwart the congressional

purpose of encouraging and expediting applications to expand spent fuel storage capacity at reactor sites.

III. SUMMARY STATEMENT OF THE RESULT OF THE APPLICATION OF THE STRICT THRESHOLD TO TECHNICAL CONTENTIONS 2 AND 3

For the reasons outlined in the remainder of the Applicant's Summary, the Board should dispose of Technical Contentions 2 and 3 as follows:

A. Technical Contention 2 – Criticality Control

1. Basis 1 – Legal Interpretation of General Design Criterion (“GDC”) 62

The Board should decide BCOC's legal challenge to the NRC Staff's interpretation of GDC 62 based on the arguments made by the parties. A purely legal issue cannot require an adjudicatory hearing. For the reasons set forth in Section IV. B. infra, the NRC Staff's interpretation of GDC 62 should be affirmed.

2. Basis 2 – Fuel Assembly Misplacement Analysis

There is no genuine dispute of fact regarding whether a single fuel assembly misplacement could cause criticality. The Applicant has performed a supplemental criticality analysis that answers this question. Indeed, the NRC Staff has performed an analysis – one that is not required by NRC regulations and goes beyond the allegation in Contention 2 - which demonstrates the spent fuel storage racks for Harris spent fuel pools C and D will remain subcritical, even if *every* location in the spent fuel storage rack is assumed to be concurrently loaded with a misplaced fresh fuel assembly of the maximum possible reactivity. The contention is moot. The Board should dismiss it.

B. Technical Contention 3 – Spent Fuel Pool Cooling and Cleanup System Embedded Piping

1. 10 C.F.R. § 50.55a Alternative Plan to demonstrate adequate quality and safety of the embedded piping as constructed

Contention 3 has been narrowed during discovery to address only the piping and welds embedded in concrete, as part of the spent fuel pool cooling and cleanup system for spent fuel pools C and D. There is no genuine dispute of fact regarding whether American Society of Mechanical Engineers (“ASME”) Code approved welding procedures, nondestructive examinations, hydrostatic testing, and quality assurance inspections were followed in the installation of the embedded piping during construction of the Harris Plant. BCOC has not challenged any aspect of the Piping Pedigree Plan, as part of the 50.55a Alternate Plan, to demonstrate adequate quality and safety of the embedded piping as constructed. The Board should dismiss this aspect of Contention 3.

2. Adequacy of the inspections and tests as part of the Equipment Commissioning Plan to demonstrate the embedded piping has not been subject to significant corrosion or other deterioration and to demonstrate adequate quality and safety of the embedded piping “as is”

BCOC no longer questions the adequacy of inspections and tests to determine the condition of the equipment and components of the spent fuel pool cooling and cleanup system for spent fuel pools C and D, other than the piping embedded in concrete. CP&L expanded its inspections and tests to include remote video camera inspection of all 15 embedded field welds and associated piping. This renders BCOC’s original contention regarding the scope of the remote camera inspection moot. BCOC’s continuing issues regarding the inspections and tests of the embedded piping and welds are not substantial,

are not central to the decision of the NRC on the license amendment application, and do not require an adjudicatory hearing for disposition. There is no health or safety consequence or significant environmental impact that could result from a hypothesized leak in the embedded piping in any event. The record before the Board is more than sufficient to allow the Board to decide this aspect of Contention 3 without an adjudicatory hearing.

IV. TECHNICAL CONTENTION 2

A. Admitted Contention 2 and Other Issues Raised during Discovery

Contention 2, as admitted by the Board, alleges the following⁴:

CONTENTION: Storage of pressurized water reactor ("PWR") spent fuel in pools C and D at the Harris plant, in the manner proposed in CP&L's license amendment application, would violate Criterion 62 of the General Design Criteria ("GDC") set forth in Part 50, Appendix A. GDC 62 requires that: "Criticality in the spent fuel storage and handling system shall be prevented by physical systems or processes, preferably by use of geometrically safe configurations." In violation of GDC 62, CP&L proposes to prevent criticality of PWR fuel in pools C and D by employing administrative measures which limit the combination of burnup and enrichment for PWR fuel assemblies that are placed in those pools. This proposed reliance on administrative measures rather than physical systems or processes is inconsistent with GDC 62.

The two Bases of Contention 2 that were admitted by the Board are discussed separately below.

⁴ Carolina Power & Light Co. (Shearon Harris Nuclear Power Plant), LBP-99-25, 50 NRC 25, 35 (1999) (Board's Ruling on Standing and Contentions).

Applicant also addresses below other issues that BCOC has attempted to raise during the course of discovery, which are beyond the scope of the admitted contention.

1. Basis 1 of Contention 2

a. Admitted Basis 1 – GDC 62 Prohibits Administrative Measures

Basis 1, as admitted by the Board, alleges the following⁵:

CP&L's proposed use of credit for burnup to prevent criticality in pools C and D is unlawful because GDC 62 prohibits the use of administrative measures, and the use of credit for burnup is an administrative measure.

The Board specifically defined the litigable issue in Basis 1 as follows⁶:

Does GDC 62 permit an applicant to take credit in criticality calculations for enrichment and burnup limits in fuel, limits that will ultimately be enforced by administrative controls?

Basis 1 presents a question of law regarding the legal interpretation of GDC 62.⁷ To this end, the Board agreed to entertain legal arguments on this issue.⁸

The Board's definition of Basis 1 is unambiguous and does not require any clarification. In response to Basis 1, the Applicant demonstrates herein that GDC 62 permits the use of administrative measures to enforce criticality control methods, and

⁵ Id. at 35.

⁶ Id. at 35.

⁷ Id. at 35-36.

⁸ Id. at 36.

thus fuel enrichment and burnup limits, which are ultimately enforced by administrative controls, are permissible under GDC 62.

b. Other Issues Raised by BCOC during Discovery Regarding GDC 62

During the course of discovery, BCOC has changed its position on Basis 1. Basis 1, as admitted, unambiguously maintains that "GDC 62 *prohibits* the use of *administrative measures*."⁹ In fact, BCOC's stated position was "*thou shalt not use administrative measures* in showing compliance with this general design criterion."¹⁰ In contrast, BCOC now admits that administrative measures *are permitted* under GDC 62. BCOC's new position is that there are *two classes* of administrative measures: those that are made over a finite time and those that are required on an ongoing basis. BCOC now maintains that GDC 62 permits administrative measures of the first type and prohibits administrative measures of the second type.

BCOC's new position has been stated during the sworn deposition of Dr. Gordon Thompson, the sole expert proffered by BCOC on Contention 2, in BCOC's Responses to Interrogatories, and in recent statements by Dr. Thompson to another licensing board. In his deposition, Dr. Thompson admitted under oath that no method of criticality control is purely physical and that every one requires some administrative measures to

⁹ This accurately reflects BCOC's proposed contention, which states that "GDC 62 is quite clear that any measures relied on must be physical rather than administrative. There is no room in the criterion for flexibility or exception." Orange County's Supplemental Petition to Intervene at 12 (April 5, 1999).

¹⁰ Harris Pre-Hearing Conf. Tr. at 96 (emphasis added).

implement.¹¹ BCOC thereafter admitted in its interrogatory responses that administrative measures are required for every criticality control method, including those methods BCOC admits are in compliance with GDC 62.¹² Dr. Thompson reiterated and clarified

¹¹ After he had identified every available measure for criticality control in spent fuel storage pools, Dr. Thompson responded to the Applicant's deposition question as follows:

Q. Can you tell me which of the measures you've identified are purely physical and require absolutely no administrative measures to implement?

A. None of them are purely physical.

For instance, take spacing. Spacing achieves criticality control, provided the spacing is maintained correctly. If a rack were poorly designed and constructed so that it were physically weak and some event within the design basis, such as an earthquake or other action compressed the assemblies, then the physical provision would not have achieved its desired objective.

The distinction that I drew between, on the one hand, spacing and solid panels, and, on the other hand, boron credit and burn-up enrichment and enrichment credit is that in the first category, the physical provision is embodied in a - - an engineering construction that has no moving parts and does not rely upon the action of operators or machinery or the supporting services, such as electricity or - - or any other supporting requirement. The physical - - the physical principle is embodied in a - - a construction - - a construction that, once - - once constructed according to specifications, requires no further intervention or action to achieve its function.

The second category - namely, boron in the water or the burn-up and enrichment credit - does require ongoing actions in order to serve its required function of criticality control.

Thompson Deposition Transcript of October 21, 1999 ("Thompson Dep. Tr.") (Exhibit 11 at 53-55). Dr. Thompson thereafter described some of the administrative measures used to implement fixed-geometry storage racks. *Id.* at 55-56.

¹² BCOC answered Applicant's Interrogatory No. 2-12 as follows:

INTERROGATORY NO. 2-12: Do you admit that every criticality control measure requires some type of administrative controls for implementation? If not, explain in detail why each such criticality control measure does not require some type of administrative controls for implementation.

Footnote continued on next page

this new position in his recent statements to the Licensing Board in the Millstone licensing proceeding.¹³

Footnote continued from previous page

RESPONSE TO INTERROGATORY NO. 2-12: The construction and installation of fixed-geometry fuel racks, with or without attached solid neutron-absorbing material, requires that certain human actions are performed correctly. After the racks are installed, no ongoing human action is required to prevent criticality when fuel is placed in the racks. By contrast, taking credit for soluble boron or fuel burnup as a means of criticality control involves ongoing human actions, and therefore does not satisfy GDC 62.

Orange County's Response to Applicant's Second Set of Discovery Requests at 6 (Oct. 27, 1999) ("BCOC's Interrogatory Responses"). BCOC's position throughout this proceeding has been that the use of fixed-geometry storage racks or solid neutron absorbers is in compliance with GDC 62. See, e.g., id. at 5-6 (Response to Interrogatory No. 2-10).

¹³ See Millstone Pre-Hearing Conference Transcript at 138-42 (Dec. 13, 1999) (this document is available from the NRC's Public Document Room). In response to Judge Kelber's question that he was puzzled by the intervenor's interpretation that administrative measures are excluded by GDC 62, Dr. Thompson clarified his position as follows:

DR. THOMPSON: We'd say there are two classes of administrative measures: those that are made over a finite time and after having been made are no longer necessary; and in the second class, administrative measures that are required on an ongoing basis. The design and construction of a rack with fixed spacing between fuel assemblies requires actions of an administrative type to perform correctly. Once the rack is installed, no further ongoing administrative action of any kind is required to exploit the physical phenomena of separation of fuel assemblies. Similarly, the placement of boral plates around the cells in the rack requires administrative and quality control measures, up to the point when the rack is completed and installed. No further ongoing action is required.

In distinction to this category of administrative actions are those that are required on an ongoing basis. Taking credit for burn up and enrichment, the soluble boron and for decay time, all require ongoing administrative measures. Our research of the development of GDC 62 under the Atomic Energy Commission shows that - - very clearly that in the early versions of this criterion, there was a possibility for ongoing administrative actions and that this possibility was removed as the criterion involved and came to its present form. . . . this criterion in[] its present form . . . excludes administrative measures of[f] an ongoing type.

Footnote continued on next page

It is well established that “the scope of a contention is determined by the ‘literal terms’ of the contention, coupled with its stated bases.”¹⁴ BCOC’s new position, however, is not encompassed in the wording of Contention 2. It could potentially have been raised as the subject of a contention, but BCOC did not do so. The contention, both as proffered and as admitted, charged that no administrative measures were permitted under GDC 62. Nowhere in either the proposed contention, the prehearing conference, or the admitted contention is it stated that GDC 62 permits certain administrative measures and prohibits others.¹⁵ The Applicant has never had an opportunity to challenge the admissibility of such a contention. Because this new position is not within the “‘literal terms’ of the admitted contention, coupled with its stated bases,” any attempt by BCOC

Footnote continued from previous page

Millstone Pre-Hearing Conf. Tr. at 139-40. Requesting clarification, Judge Kelber asked:

JUDGE KELBER: Now, when I design [the fuel storage racks], that’s one type of administrative control. Are you telling me now that that changes to a different type of administrative control after the rack is built?

Id. at 141. In response, Dr. Thompson first described the administrative controls required for storage racks, and then stated:

DR. THOMPSON: These are quite different in nature from the types of administrative actions that are needed to keep track of the burn up, enrichment combination that is used to take credit for burn up.

Id. at 141-42.

¹⁴ Vermont Yankee Nuclear Power Corp. (Vermont Yankee Nuclear Power Station), LBP-88-25, 28 NRC 394, 396 (1988) (citing Public Service Co. of New Hampshire (Seabrook Station, Units 1 and 2), ALAB-899, 28 NRC 93, 97 (1988)).

¹⁵ In fact, BCOC admits that if it had the opportunity to rewrite Contention 2, it would change some things, including providing a discussion of “the role of administrative measures in association with physical provisions for criticality.” Thompson Dep. Tr. (Exhibit 11 at 113, 121).

to raise this new position should be rejected by the Board as going beyond the scope of the admitted contention.¹⁶ The Applicant will demonstrate herein, however, that this new position is equally without support and would be decided in the Applicant's favor, if it had been raised in an admitted contention.

2. Basis 2 of Contention 2

a. Admitted Basis 2 – Single Fuel Assembly Misplacement

Basis 2, as admitted by the Board, alleges the following¹⁷:

The use of credit for burnup is proscribed because Regulatory Guide 1.13 requires that criticality not occur without two independent failures, and one failure, misplacement of a fuel assembly, could cause criticality if credit for burnup is used.

The Board specifically defined the litigable issue in Basis 2 as follows¹⁸:

Will a *single fuel assembly misplacement*, involving a fuel element of the wrong burnup or enrichment, cause criticality in the fuel pool, or would more than one such misplacement or a misplacement coupled with some other error be needed to cause such criticality?

The Basis was admitted based on the fact that the NRC Staff had recently sought further information regarding CP&L's position that "when account is taken for the boron present in the fuel pool water, a *single misplacement* cannot lead to criticality."¹⁹ The Board

¹⁶ Vermont Yankee, LBP-88-25, supra, 28 NRC at 396.

¹⁷ Harris, LBP-99-25, supra, 50 NRC at 36.

¹⁸ Id. at 36 (emphasis added).

¹⁹ Id. (emphasis added).

admitted this basis to permit further inquiry into whether the “required *single failure criterion* is met.”²⁰ Basis 2 raises a question of fact regarding whether a single fuel assembly misplacement will cause criticality in the spent fuel pool.²¹

The Board’s definition of Basis 2 is unambiguous and does not require any clarification. In response to Basis 2, the Applicant demonstrates herein, through a supplemental analysis performed in response to admission of this contention, that a single fuel assembly misplacement, with a fresh fuel assembly of the maximum permissible reactivity at Harris, will *not* cause criticality in spent fuel pools C and D.

b. Other Issues Raised by BCOC during Discovery Regarding Criticality Analysis

BCOC has raised additional issues during the course of discovery that go beyond the scope of the admitted Basis 2. Basis 2, as admitted, unambiguously maintains that “one failure, misplacement of a fuel assembly, could cause criticality if credit for burnup

²⁰ Id. (emphasis added).

²¹ Id. BCOC’s own statements prior to admission of the contention, both in the proposed contention and the Pre-Hearing Conference, clearly demonstrate the this contention addressed a *single* fuel assembly misplacement. For example, in its proposed Contention 2, BCOC charged that the Applicant would not meet Reg. Guide 1.13 “because only *one failure* or violation, namely placement in the racks of PWR fuel not within the ‘acceptable range’ of burnup, could cause criticality.” Orange County’s Supplemental Petition to Intervene at 13 (emphasis added). BCOC specifically cited Reg. Guide 1.13’s requirement to analyze “misplacement of a spent fuel assembly.” Id. In the Pre-Hearing Conference, BCOC discusses Basis 2 as misplacement of a single fuel assembly. See, e.g., Harris Pre-Hearing Conf. Tr. at 91 (“misplacing a fuel assembly”), 92 (“A low burn up. A fuel assembly into the pool.”), 93 (“if a low burnup assembly is mistakenly placed in the pool”).

is used.”²² BCOC has acknowledged that this is the subject of Basis 2, as admitted by the Board.²³ BCOC apparently questions, however, the Board’s authority to define the contentions it admits.²⁴ During discovery, BCOC conceded that the issue in Basis 2, as admitted in LBP-99-25, has been satisfactorily addressed, but then proceeded to identify new issues it would instead prefer to litigate in this proceeding. While it is unclear whether BCOC will raise any of these new issues in its filing, we summarize briefly here the facts, data and arguments upon which Applicant will rely if BCOC continues to press these new issues.

BCOC raised three additional issues during the course of discovery that exceed the scope of the admitted Basis 2. These three new issues have been stated in the deposition of BCOC’s expert Dr. Gordon Thompson and in BCOC’s Interrogatory Responses. First, BCOC asserts that the Applicant should also have evaluated the loss of all soluble boron in the pool water concurrent with the misplacement of a fuel

²² Harris, LBP-99-25, supra, 50 NRC at 36.

²³ Dr. Thompson admitted that the Board’s Order admitting Basis 2 “could be construed as a statement by the Board that it wishes to be considered only one failure; namely, misplacement of the single fresh fuel assembly.” Thompson Dep. Tr. (Exhibit 11 at 138).

²⁴ After again concurring that Basis 2, as admitted by the Board, involves a “single fuel assembly misplacement,” Dr. Thompson charged that the Board’s Order “wrongly excludes the possibility of a single failure leading to multiple misplacements.” Id. at 191. “I believe that the Board has - - has not covered the universe of - - of errors and failures that it should have done.” Id. Frustrated with the difference between the admitted contention and the new issues he would prefer to litigate, Dr. Thompson exclaimed “the extent to which the intervenor can challenge the Board on this sort of interpretation is beyond my competence.” Id.

assembly.²⁵ Second, BCOC asserts that the Applicant should have evaluated the concurrent misplacement of multiple fuel assemblies, over and above the misplacement of a single fuel assembly.²⁶ Third, BCOC asserts that the Applicant should have analyzed the universe of scenarios involving two or more unlikely, independent, and concurrent postulated accidents that could result in criticality.²⁷

²⁵ Dr. Thompson asserted that the Applicant should have considered “fuel misplacements followed by boron dilution events or preceded by boron dilution events.” Id. at 163. Dr. Thompson readily admitted that “misplacement of a single assembly and an insufficiency of boron would be two separate errors.” Id. at 133. However, as will be shown later, BCOC also acknowledged that, even if it were shown to be legally required, this issue has already been satisfactorily addressed by the Applicant’s supplemental criticality analysis. See id. at 186, 189.

²⁶ Dr. Thompson urged in his deposition that Applicant should have considered the “misplacement of multiple out-of-compliance assemblies.” Thompson Dep. Tr. at 161-62. He charged that the Board wrongfully excluded multiple fuel assembly misplacements from Basis 2. Id. at 191. BCOC confirmed this new position in its responses to interrogatories, claiming that “the County would take the position that a single failure or violation could lead to misplacement of more than one fuel assembly.” BCOC’s Interrogatory Responses at 3-4 (Response to Interrogatory 2-4); see also id. at 5 (Response to Interrogatory 2-8 emphasis added; “one or more PWR fuel assemblies”). Dr. Thompson conceded that the misplacement of an entire pool full of fuel assemblies is not credible, and that he would only require that the number of fresh fuel assemblies normally present in the pool be considered. Thompson Dep. Tr. (Exhibit 11 at 164-65).

²⁷ BCOC’s broadest new claim is that the Applicant is required to evaluate the “universe of possible unlikely, independent, concurring failures,” including all scenarios involving two or more unlikely, independent, concurring failures. Id. at 133; see id. at 123-24, 127, 138, 188, 191-92, 195-96. Dr. Thompson charged that the admitted Basis 2 “has not covered the universe of - - of errors and failures that it should have done,” id. at 191, and recommended that NRC require “a PRA type analysis of the criticality problem.” Id. at 124. BCOC confirmed this new position in its responses to interrogatories, asserting that the Applicant should have addressed “the full set of potential events that could cause criticality in pools C and D at Harris.” BCOC’s Interrogatory Responses at 4 (Responses to Interrogatories 2-4 and 2-6). However, BCOC has narrowed its claim for this particular case, admitting that “the remaining universe of failures all involves misplacement of more than one assembly.” Thompson Dep. Tr. (Exhibit 11 at 192).

All three of these new issues are outside “the scope of a contention [as] determined by the ‘literal terms’ of the contention, coupled with its stated bases.”²⁸ These new issues are beyond the scope of Basis 2 because they attempt to raise new scenarios beyond a single fuel assembly misplacement. Basis 2 addresses the scenario of “one failure, misplacement of a fuel assembly.”²⁹ Nowhere does Basis 2 address scenarios of “loss of soluble boron concurrent with misplacement of a fuel assembly” or “misplacement of multiple fuel assemblies.” It is also clear that Basis 2 does not address the “universe” of scenarios involving two or more unlikely, independent, concurrent failures. These new issues are not encompassed in the wording of Contention 2, as admitted. They could potentially have been raised as the subject of a late-filed contention, but BCOC did not do so. The Applicant has never had an opportunity to challenge the admissibility of such a contention.

Because none of these three new issues are within the “‘literal terms’ of the contention, coupled with its stated bases,” any attempt by BCOC to raise these issues should be rejected by the Board as beyond the scope of the admitted contention.³⁰ The Applicant will demonstrate in Section IV.C. infra, however, that all three of these new issues are, in any event, either moot, or would be decided in Applicant’s favor if raised in an admitted contention.

²⁸ Vermont Yankee, LBP-88-25, supra, 28 NRC at 396.

²⁹ Harris, LBP-99-25, supra, 50 NRC at 36.

³⁰ Vermont Yankee, LBP-88-25, supra, 28 NRC at 396.

B. Summary of Legal Argument Supporting the NRC Staff's Interpretation of GDC 62 as Allowing Administrative Measures to Enforce Fuel Enrichment and Burnup Limits for Criticality Control (Contention 2, Basis 1)

Contention 2, Basis 1 raises a question of law: Does GDC 62 permit an applicant to take credit in criticality calculations for enrichment and burnup limits in fuel, limits that will ultimately be enforced by administrative controls?³¹ Basis 1 is founded on BCOC's adamant assertion that GDC 62 prohibits the use of any administrative measures.³²

Criterion 62 of the General Design Criteria set forth in 10 C.F.R. Part 50, Appendix A, requires that: "Criticality in the fuel storage and handling system shall be prevented by physical systems or processes, preferably by use of geometrically safe configurations."

The NRC Staff has consistently interpreted GDC 62 to permit taking into account enrichment limits and burnup limits in fuel in criticality calculations, which necessarily require administrative controls. This interpretation of GDC 62 must be sustained for a number of reasons. First, as a practical matter, every method available for spent fuel pool criticality control is a physical system or process that is implemented by some administrative measure. BCOC's interpretation of GDC 62 would render the criterion a

³¹ Harris, LBP-99-25, supra, 50 NRC at 35.

³² During the Pre-Hearing Conference, BCOC paraphrased GDC 62 as "thou shalt not use administrative measures in showing compliance with this general design criterion." Harris Pre-Hearing Conf. Tr. at 96.

nullity. Second, the regulatory history of GDC 62 shows that administrative measures have always been understood to be part of the physical systems or processes for criticality control. Third, the Commission's adoption of 10 C.F.R. § 50.68 (criticality accident requirements for spent fuel storage) explicitly contemplates and permits administrative measures, fuel enrichment limits and fuel burnup limits for criticality control. Fourth, the NRC Staff's consistent interpretation of GDC 62 over two decades, in its guidance documents and license amendment approvals, should be accorded considerable weight. Finally, BCOC's new and revised interpretation of GDC 62 – some administrative measures are permitted and some are not – simply highlights the absurdity and naivete of its original position, but is not before this Board.

1. Undisputed Relevant Facts that Inform and Support the Conclusions of Law

There are three relevant facts that inform the understanding of the Commission's regulations relevant to resolving this question of law. These facts provide the underpinnings for the NRC Staff's and Applicant's legal interpretation of GDC 62:

1. All methods of criticality control for spent fuel pools, including fuel enrichment and burnup limits, are physical systems or processes.
2. All methods of criticality control for spent fuel pools, including fuel enrichment and burnup limits, are implemented through the use of some administrative measures.
3. Fuel assembly reactivity includes the effects of fuel burnup.

Applicant establishes these three relevant facts through the positions of the NRC Staff, the Affidavit of Dr. Stanley E. Turner (Exhibit 2),³³ and BCOC's own admissions. They are not disputed.

2. As a Practical Matter, Every Method Available for Spent Fuel Pool Criticality Control is a Physical System or Process that is Implemented by some Administrative Measure

Every criticality control method involves, by necessity, a physical system or process.³⁴ This is because criticality control can only be achieved through physical measures that affect neutron multiplication.³⁵ Neutrons will not recognize, much less obey, procedures and other administrative measures alone.³⁶ Some physical measure is required to achieve criticality control.³⁷

In practice, there are four methods available for criticality control in spent fuel storage pools: (1) geometric separation; (2) solid neutron absorbers; (3) soluble neutron absorbers; and (4) fuel reactivity.³⁸ Fuel reactivity is determined by three factors: (1) fuel assembly structure; (2) initial (or "fresh") fuel enrichment; and (3) fuel depletion (or

³³ Dr. Turner has been evaluating criticality control systems since 1957, and employing GDC 62 since it was first promulgated, almost 30 years ago. Turner Affidavit (Exhibit 2, ¶¶ 6, 7, 27, Attachment A).

³⁴ Id. ¶ 9).

³⁵ Id.

³⁶ Id.

³⁷ Id.

³⁸ Id. at ¶ 10.

“burnup”).³⁹ BCOC admits to this same list of available criticality control methods.⁴⁰

Each of these four criticality control methods is a physical system or process that has a physical effect on the neutron multiplication factor (“k-effective”) in the spent fuel pool.⁴¹

- Geometric separation is a physical system or process that physically affects neutron coupling between assemblies in storage.⁴²
- Solid neutron absorbers are a physical system or process that physically affects neutron absorption.⁴³
- Soluble neutron absorbers are a physical system or process that physically affects neutron absorption.⁴⁴
- Fuel enrichment, part of fuel reactivity, is a physical system or process that physically affects neutron production.⁴⁵

³⁹ Id. at ¶ 14.

⁴⁰ Dr. Thompson identified geometric spacing, solid neutron-absorbing material, soluble neutron absorber, and limits on burn-up and enrichment. Thompson Dep. Tr. (Exhibit 11 at 39-41).

⁴¹ Turner Affidavit (Exhibit 2, ¶ 10).

⁴² Id. at ¶11. BCOC admits this is a physical provision. See Thompson Dep. Tr. (Exhibit 11 at 51).

⁴³ Turner Affidavit (Exhibit 2, ¶ 12). BCOC admits this is a physical provision. See Thompson Dep. Tr. (Exhibit 11 at 51).

⁴⁴ Turner Affidavit (Exhibit 2, ¶ 13). BCOC admits this is a physical item. See Thompson Dep. Tr. (Exhibit 11 at 53).

- Fuel burnup, part of fuel reactivity, is a physical system or process that physically affects neutron production.⁴⁶

All of these criticality control methods for spent fuel storage are physical systems or processes, consistent with the requirements of GDC 62.⁴⁷ Specifically, fuel enrichment limits and fuel burnup limits are physical systems or processes consistent with the requirements of GDC 62.⁴⁸ These two criticality methods are aspects of fuel reactivity, which is clearly a physical measure.⁴⁹

As a practical matter, every one of the physical systems or processes for criticality control identified above is implemented using some administrative measures.⁵⁰

- Geometric separation is implemented using administrative measures.⁵¹

Footnote continued from previous page

⁴⁵ Turner Affidavit (Exhibit 2, ¶ 16). BCOC admits this is a physical characteristic, property, or process. See Thompson Dep. Tr. (Exhibit 11 at 53). BCOC's Interrogatory Responses at 6-7 (Response to Interrogatory No. 2-14).

⁴⁶ Turner Affidavit (Exhibit 2, ¶ 17). BCOC admits this is a physical characteristic, property, or process. See Thompson Dep. Tr. (Exhibit 11 at 53). BCOC's Interrogatory Responses at 7 (Response to Interrogatory No. 2-15).

⁴⁷ Turner Affidavit (Exhibit 2, ¶ 28).

⁴⁸ Id. at ¶ 31.

⁴⁹ Id.

⁵⁰ Id. at ¶¶ 18, 29.

⁵¹ Id. at ¶ 19. BCOC admits this fact. See Thompson Dep. Tr. (Exhibit 11 at 53, 55-56). In response to the Applicant's interrogatories, BCOC admitted that "[t]he construction and installation of fixed-geometry fuel racks, with or without attached solid neutron-

Footnote continued on next page

- Solid neutron absorbers are implemented using administrative measures.⁵²
- Soluble neutron absorbers are implemented using administrative measures.⁵³
- Fuel enrichment, part of fuel reactivity, is implemented using administrative measures.⁵⁴
- Fuel burnup, part of fuel reactivity, is implemented using administrative measures.⁵⁵

While the type, degree, and timing of administrative controls vary for each of the physical systems or processes, it is a fact that every one of these physical measures for criticality control is implemented using some administrative measures.⁵⁶ No criticality

Footnote continued from previous page

absorbing material, requires that certain human actions are performed correctly.”
BCOC’s Interrogatory Responses at 6 (Response to Interrogatory No. 2-12).

⁵² Turner Affidavit (Exhibit 2, ¶ 20). BCOB admits this fact. See Thompson Dep. Tr. (Exhibit 11 at 54). BCOB’s Interrogatory Responses at 6 (Response to Interrogatory No. 2-12).

⁵³ Turner Affidavit (Exhibit 2, ¶ 21). BCOB admits this fact. See Thompson Dep. Tr. (Exhibit 11 at 54-55).

⁵⁴ Turner Affidavit (Exhibit 2, ¶ 23). BCOB admits this fact. See Thompson Dep. Tr. (Exhibit 11 at 54-55).

⁵⁵ Turner Affidavit (Exhibit 2, ¶ 24). BCOB admits this fact. See Thompson Dep. Tr. (Exhibit 11 at 54-55).

⁵⁶ Turner Affidavit (Exhibit 2, ¶¶ 25, 30). Note that nothing in GDC 62 differentiates between physical systems or processes for criticality control based on the timing and duration of the administrative measures required to implement them. Id. at ¶ 30.

control methods can be implemented without some degree of administrative control.⁵⁷ In practice, therefore, GDC 62 encompasses criticality control by physical systems or processes that are implemented with the use of some administrative measures.⁵⁸ An interpretation that GDC 62 prohibits administrative measures to implement physical systems or processes for criticality control would render GDC 62 a nullity, because none of the available criticality control methods could comply with such an interpretation.⁵⁹ If this were the interpretation, GDC 62 would prohibit any method of criticality control.⁶⁰ The meaning given to GDC 62 must be consistent with the practical realities of implementing criticality control.

3. The Regulatory History of GDC 62 Reveals That Administrative Measures Were Always Understood to be Included in GDC 62

The regulatory history of GDC 62 reveals that the Commission has always understood that administrative measures were included within the scope of GDC 62.⁶¹

⁵⁷ Id. at ¶ 18. BCOC acknowledges this fact as well. In Dr. Thompson's deposition, the following question and answer took place:

Q. Can you tell me which of the measures you've identified are purely physical and require absolutely no administrative measures to implement?

A. None of them are purely physical.

Thompson Dep. Tr. (Exhibit 11 at 53).

⁵⁸ Turner Affidavit (Exhibit 2, ¶ 29).

⁵⁹ Id.

⁶⁰ Id.

⁶¹ The Applicant has assembled, and provided herein, from the regulatory history:

- Draft versions of GDC 62 prior to rulemaking, including:

Footnote continued on next page

GDC 62 was promulgated by the Atomic Energy Commission ("AEC") through notice and comment rulemaking in the mid-1960's, and enacted as a final rule in 1971. The

Footnote continued from previous page

- AEC Press Release H-252, "AEC Seeking Public Comment on Proposed Design Criteria for Nuclear Power Plant Construction Permits," Nov. 22, 1965 (with attached General Design Criteria for Nuclear Power Plant Construction Permits) ("1965 AEC Draft Criteria") (Exhibit 15A);
- "Comparison of Drafts Dated October 20, 1966, and February 6, 1967 for General Design Criteria for Nuclear Power Plant Construction Permits," Feb. 6, 1967 ("Comparison of 10/66 and 2/67 Draft Criteria") (Exhibit 15B);
- Memorandum from S. Hanauer (ACRS) to H. Etherington re: Review of New Draft General Design Criteria, Feb. 20, 1967 ("February 1967 ACRS Comments on Draft Criteria") (Exhibit 15C);
- Staff Memorandum recommending rulemaking (equivalent to a SECY), "Proposed Amendment to 10 CFR 50: General Design Criteria for Nuclear Power Plant Construction Permits," AEC-R 2/57, June 16, 1967 ("June 1967 Staff Memorandum Proposing Rulemaking") (Exhibit 15D);
- Commission's Proposed Rule with Statements of Consideration, 32 Fed. Reg. 10,213 (July 11, 1967) ("Proposed Rule") (Exhibit 16A);
- Public Comment on GDC 62, including:
 - Letter from W. Cottrell (Oak Ridge National Laboratory) to H. Price (AEC Staff), Sept. 6, 1967 ("ORNL Comment Letter") (Exhibit 17A);
 - Letter from J. Flaherty (Atomics International) to Secretary, AEC, Sept. 25, 1967 ("Atomics International Comment Letter") (Exhibit 17B);
- 1969 Revision to General Design Criteria, Letter from E. Case (AEC Staff) to S. Hanauer (ACRS) with attached "General Design Criteria for Nuclear Power Plants - July 15, 1969," July 23, 1969 ("1969 Revision to Proposed Criteria") (Exhibit 15E);
- Staff SECY Memorandum recommending final rule, "Amendment to 10 CFR 50 - General Design Criteria for Nuclear Power Plants," SECY-R-143, Jan. 28, 1971 ("January 1971 SECY Supporting Final Rule") (Exhibit 15F);
- Commission's Final Rule with Statements of Consideration, 36 Fed. Reg. 3,255 (Feb. 20, 1971) ("Final Rule") (Exhibit 16B).

original framers of GDC 62, as will be seen, understood “physical systems or processes” to encompass administrative measures.⁶² However, the language of early drafts and the final criterion was, by design, cast in broad, general terms.⁶³ The first published version of GDC 62, issued for public comment in 1965, stated only that storage facilities “must be designed to prevent criticality.”⁶⁴ This very broad language by itself indicates nothing about the implementation of criticality control.

By 1966, however, GDC 62 addressed methods for implementing criticality control. The October 1966 version of GDC 62 read:⁶⁵

Possibilities for inadvertent criticality must be prevented by engineered systems or processes to every extent practicable. Such means as geometric safe spacing limits shall be emphasized over procedural controls.

The purpose of the first sentence of GDC 62 is to identify the set of acceptable methods for criticality control. At this time it included “engineered systems or processes to every extent practicable.” The second sentence of GDC 62 prioritizes the different methods for criticality control. At this time “geometric safe spacing limits” were emphasized over “procedural controls.” It is essential to understand the different purposes of the two

⁶² While the number of GDC 62 changed over time (e.g., first GDC 25, then GDC 61, then GDC 66, and finally GDC 62), Applicant herein consistently refers to this criterion as “GDC 62.”

⁶³ The General Design Criteria are, by their very nature, cast in broad, general terms requiring additional interpretation. See Petition for Emergency and Remedial Action, CLI-78-6, 7 NRC 400, 406 (1978).

⁶⁴ 1965 AEC Draft Criteria at 8 (Exhibit 15A). At this time, GDC 62 was “Criterion 25.”

sentences in this version, and subsequent versions, of GDC 62 – the first sentence sets the scope of acceptable methods, the second sentence prioritizes among methods. It is clear that the AEC Staff understood “engineered systems or processes” in GDC 62 to encompass “procedural controls.” Procedural controls are one type of administrative measure.

By February 1967, GDC 62 had evolved to read:⁶⁶

Possibilities for criticality in new and spent fuel storage shall be prevented by physical systems or processes to every extent practicable. Such means as favorable geometries shall be emphasized over procedural controls.

The scope of acceptable measures for criticality control, as defined in the first sentence of GDC 62, had evolved to “physical systems or processes to every extent practicable.” The only change to the second sentence was the terminology for the preferred method, “favorable geometries.”⁶⁷ Since the first sentence defines the scope, it is clear that the AEC Staff understood “physical systems or processes” to encompass “procedural

Footnote continued from previous page

⁶⁵ See Comparison of 10/66 and 2/67 Draft Criteria at 18 (Exhibit 15B). The October 1966 version is obtained by backing out the revisions in the comparison.

⁶⁶ See Comparison of 10/66 and 2/67 Draft Criteria at 18 (Exhibit 15B). The February 1967 version is obtained by accepting the revisions in the comparison. By this time, GDC 62 was “Criterion 61.”

⁶⁷ The wording “favorable geometries” was subsequently changed to “geometrically safe configurations,” as it remains in its final form, in response to a comment from the Advisory Committee on Reactor Safeguards (“ACRS”). February 1967 ACRS Comments on Draft Criteria at 3 (Exhibit 15C).

controls," a type of administrative measure. The prioritization of methods in the second sentence still emphasized "such means as favorable geometries" over procedural controls.

The Staff proposed GDC 62 for Commission rulemaking in June 1967. The Staff recommended the following text for GDC 62 :⁶⁸

Criticality in new and spent fuel storage shall be prevented by physical systems or processes. Such means as geometrically safe configurations shall be emphasized over procedural controls.

The significant change in this revision was to drop the phrase "to every extent practicable" after "physical systems or processes." It is clear from the text, as proposed, that every criticality control method acceptable under GDC 62 must be a "physical system or process." Any methods mentioned in the second sentence, the prioritization sentence, must, of necessity, be encompassed in "physical systems or processes." The retention of "procedural controls" in the second sentence, the prioritization sentence, establishes that the AEC Staff understood "procedural controls," one type of administrative measure, to be encompassed in "physical systems or processes," within the meaning of GDC 62. The prioritization had not changed, geometric spacing was still emphasized over procedural controls.

The Commission adopted the AEC Staff's recommended wording in the proposed rulemaking for GDC 62. The text of GDC 62 in the Commission's proposed rule reads:⁶⁹

⁶⁸ June 1967 Staff Memorandum Proposing Rulemaking at 33 (Exhibit 15D). By this time, GDC 62 was "Criterion 66."

Criticality in new and spent fuel storage shall be prevented by physical systems or processes. Such means as geometrically safe configurations shall be emphasized over procedural controls.

The first sentence is absolute. To meet GDC 62, a criticality control measure must fall within the scope of acceptable methods established in the first sentence. The Commission defined the scope of all acceptable means for criticality control as "physical systems or processes." The inclusion of "procedural controls" in the second sentence establishes that the Commission must have understood "procedural controls" to fall within the scope of "physical systems or processes," as it is defined in GDC 62. Therefore, physical systems or processes must be understood to include administrative measures. The prioritization in the second sentence remained unclear at that time. It was ambiguous as to whether "geometrically safe configurations" are preferred over *all* other methods, or *just* over "procedural controls." The phrase "[s]uch means as" further exacerbates this ambiguity.

The Commission received two public comments addressing GDC 62. The first public comment, from Oak Ridge National Laboratory, took issue with the Commission's acceptance of "procedural controls to prevent accidental criticality in storage facilities of power reactors."⁷⁰ To this end, the commenter requested the Commission to delete "processes" from "physical systems or processes" in the first sentence, and "procedural

Footnote continued from previous page

⁶⁹ Proposed Rule, 32 Fed. Reg. at 10,217 (Exhibit 16A).

⁷⁰ ORNL Comment Letter at 11 (Exhibit 17A).

controls” from the second sentence.⁷¹ The Commission did not accept this comment. The final version of GDC 62 retains the terminology “physical systems or processes,” and therefore, the Commission’s understanding that procedural controls are included within the scope of GDC 62 was not changed.⁷² The commenters’ second change was incorporated as part of clarifying the prioritization in the second sentence of GDC 62, as discussed below.

The second public comment, from Atomics International, addressed the ambiguity in the prioritization established in the second sentence of GDC 62.⁷³ The commenter requested the Commission to revise the second sentence to read “Inherent means should be used where practicable.”⁷⁴ In this way, the second sentence would address only one type of measure, “inherent means,” and would state the Commission’s intent that this is a preference, to be used “where practicable.”⁷⁵ While it did not adopt the specific words offered by the commenter, the Commission did incorporate the commenter’s intent. In the final rule, the Commission revised the prioritization sentence to state simply “preferably by use of geometrically safe configurations.”⁷⁶ By including only one method in the prioritization sentence, the Commission indicated that “geometrically safe

⁷¹ Id.

⁷² See Final Rule, 36 Fed. Reg. at 3,260.

⁷³ Atomics International Comment Letter at 4 (Exhibit 17B).

⁷⁴ Id.

⁷⁵ Id.

⁷⁶ Final Rule, 36 Fed. Reg. at 3,260.

configurations” were preferred over *all* other methods, not *just* over procedural controls.⁷⁷ The Commission also deleted the ambiguous phrase “such terms as” to further clarify its intent in prioritizing criticality control measures.⁷⁸ The prioritization in the second sentence (now second phrase) is still stated in terms of a preference, which does not itself rule any other measures out.

The Staff SECY paper recommending the final rulemaking lends support to the interpretation that the ORNL comment was rejected.⁷⁹ The ORNL comment, requesting that procedural controls no longer be permitted under GDC 62, would have made a very significant substantive change to the meaning and scope of GDC 62. In discussing the changes made between the proposed rule and the final rule, the SECY states that:⁸⁰

Most of the comments received were in the form of suggested improvements in language to facilitate understanding of the intent of the criteria, with few suggestions to change or delete many requirements. The more significant comments and our resolution of them [are discussed below].

The discussion of significant comments in the SECY does not discuss any of the text changes to GDC 62, indicating that the changes made to GDC 62 were not substantive,

⁷⁷ The Commission also made the prioritization sentence, now reduced to just one preferred method, into a second phrase of the first sentence. This is just a change in grammar for brevity and clarity. It does not change the underlying construct of the two sentence (now two phrase) structures: the first sentence (phrase) establishes the set of acceptable measures for achieving criticality control; and the second sentence (phrase) prioritizes among the available measures.

⁷⁸ See Final Rule, 36 Fed. Reg. at 3,260.

⁷⁹ See January 1971 SECY Supporting Final Rule at 2-3 (Exhibit 15F).

but rather just improvements in language to facilitate understanding.⁸¹ Certainly, a change of the magnitude requested by ORNL would have been discussed as a significant change, had it been made. Moreover, the change made to the second sentence, prioritization of the available measures, improved the language and facilitated understanding of the Commission's intent that geometrically safe configurations are to be preferred over all other methods.

In the Commission's final rule, GDC 62 reads:⁸²

Criticality in the fuel storage and handling system shall be prevented by physical systems or processes, preferably by use of geometrically safe configurations.

The phrase "shall be prevented by physical systems or processes" in the first sentence (now first phrase), identifying the set of available criticality control measures under GDC 62, remains unchanged from the proposed rule.⁸³ A review of the regulatory history of the text of GDC 62 reveals that the definition of "physical systems or processes" was never changed from its definition in the proposed rule. It has always included administrative measures.

Footnote continued from previous page

⁸⁰ Id.

⁸¹ See id. at 3-6.

⁸² Final Rule, 36 Fed. Reg. at 3,260. The final wording of GDC 62 had been developed by the AEC Staff by 1969. See 1969 Revision to Proposed Criteria (Exhibit 15E).

⁸³ Compare the Final Rule, 36 Fed. Reg. at 3,260 ("Criticality in the fuel storage and handling system shall be prevented by physical systems or processes," with the Proposed Rule, 32 Fed. Reg. at 10,217 ("Criticality in new and spent fuel storage shall be prevented by physical systems or processes"). The relevant language is identical.

4. The Commission's 10 C.F.R. § 50.68 Rulemaking Affirms that the Commission Permits Administrative Measures, Fuel Enrichment Limits, and Fuel Burnup Limits for Criticality Control

The Commission's promulgation of new regulations for criticality accident requirements for spent fuel storage squarely addresses and resolves the legal issue raised in Basis 1 of Contention 2. The Commission issued 10 C.F.R. § 50.68 in late 1998. The rulemaking history⁸⁴ and the new regulation itself clearly demonstrate that the Commission endorses the use of administrative measures to implement criticality control, and permits fuel enrichment limits and fuel burnup limits as methods of criticality control.

⁸⁴ 10 C.F.R. § 50.68 was promulgated by the Commission through notice and comment rulemaking. For the Board's convenience, we have included as exhibits all the applicable documents for the Commission's 10 C.F.R. § 50.68 rulemaking:

- Staff memorandum SECY-97-155, "Staff's Action Regarding Exemptions from 10 CFR 70.24 for Commercial Nuclear Power Plants," SECY-97-155 (July 21, 1997) ("SECY-97-155") (Exhibit 18A);
- Commission's SRM and voting records approving SECY-97-155, "Staff Requirements – SECY-97-155," (August 19, 1997) and attached Commission Voting Record ("SRM and Voting Sheets") (Exhibit 18B);
- Commission's direct final rule, 62 Fed. Reg. 63,825 (1997) ("50.68 Direct Final Rule") (Exhibit 19A);
- Commission's proposed rule, 62 Fed. Reg. 63,911 (1997) ("50.68 Proposed Rule") (Exhibit 19B);
- Public comment on proposed rule, Letter from M. Voth (Northern States Power) to Secretary of NRC (Jan. 2, 1998) ("NSP Public Comment Letter") (Exhibit 19C);
- Commission's withdrawal of direct final rule, 63 Fed. Reg. 9,402 (1998) ("50.68 Direct Final Rule Withdrawal") (Exhibit 19D);
- Commission's final rule, 63 Fed. Reg. 63,127 (1998) ("50.68 Final Rule") (Exhibit 19E).

The 10 C.F.R. § 50.68 rulemaking identifies criticality control measures the Commission permits in compliance with GDC 62. The Staff memorandum (SECY-97-155) that initiated the rulemaking, specifically addresses GDC 62.⁸⁵ SECY-97-155 was reviewed and approved by the Commission.⁸⁶ The Commission's 50.68 Direct Final Rule explicitly addresses GDC 62:⁸⁷

General Design Criterion (GDC) 62 in Appendix A to 10 CFR Part 50 reinforces the prevention of criticality in fuel storage and handling through physical systems, processes, and safe geometrical configuration. Moreover, fuel handling at power reactor facilities occurs only under strict procedural control.

10 C.F.R. § 50.68 addresses methods for preventing inadvertent criticality events at nuclear [power] plants licensees, which is the same purpose as GDC 62.⁸⁸ It is clear that the Commission understood it was discussing the same criticality control provisions as GDC 62 in its statements on 10 C.F.R. § 50.68.

⁸⁵ SECY-97-155 (Exhibit 18A) at 3.

⁸⁶ SRM and Voting Sheets at 1 (Exhibit 18B).

⁸⁷ 62 Fed. Reg. at 63,826 (Exhibit 19A). The direct final rule was withdrawn pursuant to significant comments received on the proposed rule. See 63 Fed. Reg. at 9,402 (50.68 Direct Final Rule Withdrawal) (Exhibit 19D). The proposed rule was continued subject to standard notice and comment rulemaking provisions. Id. The proposed rule published in the Federal Register referred to the concurrently noticed direct final rule for substance. See 62 Fed. Reg. at 63,911 (50.68 Proposed Rule) (Exhibit 19B).

⁸⁸ 63 Fed. Reg. at 63,129 (50.68 Final Rule) (Exhibit 19E). The Commission stated that when these methods of criticality control are implemented, "the conditions which could lead to a criticality event are so unlikely that the probability of occurrence of an inadvertent criticality is negligible." 62 Fed. Reg. at 63,825 (50.68 Direct Final Rule) (Exhibit 19A). The Commission's safety assessments have concluded that "the

Footnote continued on next page

The 10 C.F.R. § 50.68 rulemaking expressly acknowledges and permits the use of administrative measures to implement criticality control. SECY-97-155 states that “commercial nuclear power plants have *procedures* and design features that prevent inadvertent criticality,” and “[t]he staff considers a fuel-handling accidental criticality at a commercial nuclear power plant to be extremely unlikely due to *administrative* and design controls.”⁸⁹ In the statements of consideration for the Direct Final Rule, the Commission noted that “[n]uclear power plant licensees have *procedures* and the plants have design features *to prevent inadvertent criticality*.”⁹⁰ None of these statements were withdrawn in the final rule.⁹¹ Moreover, the final text of 10 C.F.R. § 50.68 includes “plant procedures” and “administrative controls” for criticality control.⁹² 10 C.F.R. § 50.68, as adopted, acknowledges and permits the use of administrative controls to implement criticality control methods for fuel storage pools.⁹³ A review of the 10 C.F.R.

Footnote continued from previous page

likelihood of criticality [is] negligible.” 63 Fed. Reg. at 63,127 (50.68 Final Rule) (Exhibit 19E).

⁸⁹ SECY-97-155 at 2-3 (Exhibit 18A) (emphasis added). SECY-97-155 also refers to “strict procedural control and supervision” and “administrative and design controls” (several times) as means for criticality control in fuel storage and handling. *Id.* at 3. The SECY was reviewed and approved by the Commission. See SRM and Voting Sheets at 1 (Exhibit 18B).

⁹⁰ 62 Fed. Reg. at 63,825 (50.68 Direct Final Rule) (Exhibit 19A) (emphasis added). On the same page, the Commission discusses GDC 62, immediately followed by statements regarding “strict procedural control” and “administrative controls” to prevent criticality. *Id.* at 63,826. The Commission did not modify these statements in the 50.68 Final Rule.

⁹¹ See 63 Fed. Reg. at 63,127 (50.68 Final Rule) (Exhibit 19E).

⁹² 63 Fed. Reg. at 63,130 (50.68 Final Rule) (Exhibit 19E).

⁹³ Turner Affidavit, ¶ 37 (Exhibit 2).

§ 50.68 rulemaking demonstrates that the Commission understands and permits the use of administrative measures to implement criticality control methods for spent fuel storage and handling.

As adopted, 10 C.F.R. § 50.68 explicitly acknowledges and permits the use of fuel enrichment limits as a criticality control method for fuel storage in pools. 10 C.F.R. § 50.68(b)(7) specifically permits the use of fuel enrichment limits for criticality control.⁹⁴ The Commission determined that a fuel enrichment limit addresses criticality concerns.⁹⁵ Fuel enrichment limits are implemented using administrative measures.

As adopted, 10 C.F.R. § 50.68(b)(4) specifically directs that “spent fuel storage racks loaded with fuel of the maximum fuel assembly reactivity” be considered for criticality control purposes. Spent fuel assembly reactivity, as stated in 10 C.F.R. § 50.68 (b)(4), includes the effects of fuel burnup, and thus implicitly permits the use of fuel burnup limits as a method of criticality control.⁹⁶ The Direct Final Rule, as proposed, would have required that spent fuel storage analyses be evaluated using “the maximum permissible U-235 enrichment.”⁹⁷ The maximum U-235 enrichment represents fresh fuel, before it undergoes any burnup. One public comment specifically addressed this

⁹⁴ See also discussion in Turner Affidavit, ¶¶ 36, 37 (Exhibit 2).

⁹⁵ Id. at 63,128.

⁹⁶ See Turner Affidavit, ¶¶ 35, 37 (Exhibit 2).

⁹⁷ 62 Fed. Reg. at 63,827 (50.68 Direct Final Rule) (Exhibit 19A) (the proposed 10 C.F.R. § 50.68(b)(4)).

issue.⁹⁸ The commenter requested that the phrase “maximum permissible U-235 enrichment” in proposed 10 C.F.R. § 50.68 (b)(4) be replaced by the phrase “maximum fuel assembly reactivity” because, in part, fuel assembly reactivity is comprised of a number of factors, of which enrichment is only one.⁹⁹ The NRC Staff’s fuel storage criticality safety expert, Dr. Laurence I. Kopp, confirmed that fuel reactivity includes the effects of burnup.¹⁰⁰ BCOC’s expert also admitted that fuel reactivity includes the effects of burnup.¹⁰¹ Fuel assembly reactivity does include the effects of fuel burnup.¹⁰² In the Final Rule, the Commission revised 10 C.F.R. § 50.68 (b)(4) to allow licensees to use “maximum fuel assembly reactivity,” which includes the effects of fuel burnup, in place of “maximum permissible U-235 enrichment,” in demonstrating criticality control.¹⁰³ As adopted by the Commission, 10 C.F.R. § 50.68, therefore, acknowledges and permits the use of fuel burnup as a method for criticality control in spent fuel storage,

⁹⁸ NSP Public Comment Letter at 1 (Exhibit 19C).

⁹⁹ Id.

¹⁰⁰ Kopp Deposition Transcript of November 4, 1999 (“Kopp Dep. Tr.”) attached hereto as Exhibit 12 at 40. Dr. Kopp’s deposition transcript is included as Exhibit 12. In Dr. Kopp’s deposition, the following question and answer took place:

Q. Dr. Kopp, in your opinion does the term “reactivity” include the effects of burnup?

A. Certainly burnup determines the reactivity of a fuel assembly.

Kopp Dep. Tr. at 40 (Exhibit 12).

¹⁰¹ Thompson Dep. Tr. at 66 (Exhibit 11).

¹⁰² Turner Affidavit, ¶¶ 14, 17, 35, 37 (Exhibit 2).

¹⁰³ 63 Fed. Reg. at 63,128, 63,130 (50.68 Final Rule) (Exhibit 19E).

and necessarily permits administrative measures to implement such criticality control methods for fuel pool storage.¹⁰⁴

BCOC's legal position regarding GDC 62 is inconsistent with the Commission's pronouncements on criticality control as adopted in 10 C.F.R. § 50.68 in 1998.

5. NRC Staff's Determination that Fuel Enrichment and Burnup Limits Comply with GDC 62 Should Be Accorded Considerable Weight

The NRC Staff has consistently interpreted GDC 62 to encompass the use of fuel enrichment and burnup limits for criticality control. The Staff has also acknowledged that these criticality control methods require some administrative measures to implement. The Staff has implemented fuel enrichment and burnup limits for criticality control through generic guidance and case-by-case implementation in license amendment approvals over a period of almost 20 years.

The NRC Staff's guidance governing spent fuel pool criticality control permits the use of fuel enrichment and burnup limits, and outlines the administrative measures required to implement these methods. The NRC Staff initially permitted fuel enrichment and burnup limits for spent fuel pool criticality control through Reg. Guide 1.13, draft Revision 2 ("Reg. Guide 1.13"), issued in 1981.¹⁰⁵ Appendix A of Reg. Guide 1.13 provides specific guidance on the administrative measures used to implement fuel

¹⁰⁴ Turner Affidavit (Exhibit 2, ¶ 35, 37).

¹⁰⁵ A copy of Reg. Guide 1.13 (Rev. 2) is included as Attachment D to Exhibit 2 (Turner Affidavit). See Turner Affidavit (Exhibit 2, ¶ 49).

enrichment and burnup limits used for criticality control. Although Reg. Guide 1.13 (Rev. 2) was never issued in final form, the NRC Staff's practice of implementing its provisions for two decades demonstrates that it is *de facto* final NRC Staff guidance.

The NRC Staff has implemented its guidance permitting fuel enrichment and burnup limits in approving numerous license amendment requests to expand the capacity of spent fuel pool storage beginning in the early 1980's. BCOG acknowledges the NRC Staff's pattern and practice of approving fuel enrichment and burnup limits for spent fuel pool criticality control.¹⁰⁶ Dr. Turner has identified at least 20 nuclear power plants across the country where the Staff has approved the use of fuel enrichment and burnup limits as a criticality control method for spent fuel pool storage.¹⁰⁷ In approving each of these license amendments approvals, the NRC Staff made a case-by-case determination that fuel enrichment and burnup limits comply with GDC 62.¹⁰⁸ Each of these license

¹⁰⁶ See Thompson Dep. Tr. at 172-75 (Exhibit 11).

¹⁰⁷ Turner Affidavit (Exhibit 2, ¶ 51). For examples of some recent approvals, see, e.g., 58 Fed. Reg. 28,050, 28,069 (1993) (Sequoyah); 59 Fed. Reg. 27,049, 27,703 (1994) (Salem); 61 Fed. Reg. 7,542, 7,566 (1996) (Comanche Peak); 63 Fed. Reg. 40,551, 40,566 (1998) (Waterford).

¹⁰⁸ For example, in approving the license amendment for Waterford, the Staff concluded that "General Design Criterion 62 . . . is met" by "burnup reactivity equivalencing" implemented using "enrichment versus burnup ordered pairs." See Letter from NRC to Entergy Operations and Enclosed Safety Evaluation at 2-3 (July 10, 1998) (Waterford) (PDR Nos. 9807140341, 347).

amendment approvals is founded on an extensive safety analysis by the Staff and a determination of compliance with all applicable NRC regulations, including GDC 62.¹⁰⁹

The NRC Staff has confirmed its interpretation that fuel enrichment and burnup limits comply with GDC 62 in its most recent guidance document. The NRC Staff issued its new guidance memorandum on criticality control in 1998 ("1998 Criticality Guidance").¹¹⁰ This new guidance effectively replaces Reg. Guide 1.13. The 1998 Criticality Guidance is intended to comply with GDC 62.¹¹¹ In addition to approving fuel enrichment and burnup limits, this document outlines the administrative measures required to implement these methods.¹¹²

The NRC Staff has established a long-standing pattern and practice of interpreting GDC 62 to include the use of fuel enrichment and burnup limits for criticality control in spent fuel pool storage. The NRC Staff has done so both through guidance documents and numerous case-by-case license amendment approvals involving detailed safety analyses.

¹⁰⁹ As a condition precedent to approving these license amendments, the Staff is required to determine that all the General Design Criteria have been satisfied. 36 Fed. Reg. 3255, (1971).

¹¹⁰ "Guidance on the Regulatory Requirements for Criticality Analysis of Fuel Storage at Light-Water Reactor Plants" (August 1998) ("1998 Criticality Guidance") (Attachment H to Exhibit 2). See Turner Affidavit, ¶ 50 (Exhibit 2).

¹¹¹ See 1998 Criticality Guidance (Attachment H to Exhibit 2) at 1.

¹¹² See Turner Affidavit, ¶ 50 (Exhibit 1).

The NRC Staff's interpretations of GDC 62 should be accorded "considerable weight."¹¹³ When a General Design Criterion is being interpreted, the Commission has directed that where "there is conformance with regulatory guides, there is likely to be compliance with the GDC."¹¹⁴ Of course, here the Staff's consistent interpretation over two decades has been recently endorsed by the Commission itself in adopting 10 C.F.R. § 50.68.

6. Summary of Undisputed Material Facts and Conclusions of Law Sustaining the NRC Staff's Interpretation of GDC 62 Permitting Fuel Enrichment and Burnup Limits for Criticality Control and the Administrative Measures Required to Implement Such Limits

Applicant's arguments for sustaining the NRC Staff's interpretation of GDC 62 can be summarized as follows:

- All methods of criticality control for spent fuel pools, including fuel enrichment and burnup limits, are physical systems or processes.¹¹⁵
- All methods of criticality control for spent fuel pools, including fuel enrichment and burnup limits, are implemented by using some administrative measures.¹¹⁶

¹¹³ Consumers Power Co. (Big Rock Point Nuclear Plant), ALAB-725, 17 NRC 562, 568 (1983) (finding made for the specific issue of *spent fuel pool criticality control*).

¹¹⁴ Petition for Emergency and Remedial Action, CLI-78-6, 7 NRC 400, 406-07 (1978).

¹¹⁵ See Turner Affidavit, ¶¶ 9, 10, 16, 17 (Exhibit 2); Thompson Dep. Tr. at 51, 53 (Exhibit 11); BCOC's Interrogatory Responses at 6-7 (Responses to Interrogatories No. 2-14, 2-15).

- Fuel assembly reactivity includes the effects of fuel burnup.¹¹⁷
- The regulatory history of GDC 62, together with the Commission's statements of consideration in promulgating 10 C.F.R. § 50.68, establish that GDC 62 permits the use of administrative measures to implement physical systems or processes used for criticality control.
- 10 C.F.R. § 50.68 establishes directly that the Commission permits both fuel enrichment limits and fuel burnup limits to be used for criticality control in spent fuel storage.
- The NRC Staff's consistent interpretation of GDC 62 should be accorded considerable weight, particularly where its interpretation is the only one that could give practical meaning to GDC 62.

Thus, this Board should find as a matter of law:

- ◆ GDC 62 permits the use of administrative measures to implement criticality control methods.
- ◆ GDC 62 permits an applicant to take credit in criticality calculations for enrichment and burnup limits in fuel.

Footnote continued from previous page

¹¹⁶ See Turner Affidavit, ¶¶ 18, 23, 24, 25 (Exhibit 2); Thompson Dep. Tr. at 53-56 (Exhibit 11).

¹¹⁷ See Turner Affidavit, ¶¶ 14, 16, 17 (Exhibit 2); Kopp Dep. Tr. at 40 (Exhibit 12); Thompson Dep. Tr. at 66 (Exhibit 11).

◆ GDC 62 permits the use of administrative measures to implement these limits.

These conclusions of law answer the legal question raised in Contention 2, Basis 1, as admitted. The Board should therefore decide the question of law in the Applicant's favor and rule that an adjudicatory hearing is not necessary for resolution of Contention 2, Basis 1.

7. New Position Raised by BCOC Cannot be Considered by the Board Except as an Implicit Admission that its Position in Contention 2, Basis 1, is Untenable

We turn briefly to the new position raised by BCOC during the course of discovery. This new position is not the subject of an admitted contention, and should be ignored by the Board. Indeed, BCOC's new position undercuts its legal arguments in Contention 2, Basis 1.

During the course of discovery, BCOC effectively abandoned its admitted Contention 2, Basis 1 that "GDC 62 *prohibits* the use of *administrative measures*."¹¹⁸ BCOC has instead staked out a new position that administrative measures are *permitted* under GDC 62, but that only *some* administrative measures are allowed, while others are not.¹¹⁹

¹¹⁸ Harris, LBP-99-25, supra, 50 NRC at 35 (emphasis added).

¹¹⁹ See Section IV.A.1.b., supra.

It is too late for BCOC to “plead in the alternative” at this stage.¹²⁰ It would be inappropriate for the Board to consider BCOC’s new legal position, except to note that it highlights the absurdity of BCOC’s interpretation in the admitted Contention 2, Basis 1.

There is absolutely nothing in the text of GDC 62 drawing a line between different types of administrative measures. Nothing in GDC 62 differentiates between physical systems or processes for criticality control based on the timing and duration of the administrative measures required to implement different physical systems or processes.¹²¹ BCOC’s sole expert on Contention 2, Dr. Thompson, now appears to understand that his original position is untenable. But his new interpretation of GDC 62 has no more support than his first try.¹²² Dr. Thompson’s new interpretation of GDC 62, as articulated during discovery and in another NRC licensing proceeding, would appear on its own to doom BCOC’s admitted Contention 2, Basis 1.

C. Summary of Facts, Data and Arguments which Demonstrate that a Single Fuel Assembly Misplacement Could Not Cause Criticality in Harris Spent Fuel Pools C or D (Contention 2, Basis 2)

¹²⁰ The appropriate procedural mechanism for BCOC to have raised a new question of law would be through a late-filed contention. See 10 C.F.R. § 2.714(a)(1). BCOC has not filed a late-filed contention on this new issue, nor addressed the five late-filed factors in 10 C.F.R. § 2.714(a)(1). Applicant would oppose admission of such a contention.

¹²¹ Turner Affidavit, ¶ 30 (Exhibit 2).

¹²² Dr. Thompson is on a steep learning curve. By his own admission, Dr. Thompson has no training or experience with criticality control systems, no experience with criticality control regulation, nuclear power plant licensing, nuclear power plant operations, or nuclear plants as a general matter. Thompson Dep. Tr. at 25-29, 110 (Exhibit 11). His knowledge in this area is limited to his reading pursuant to this proceeding and a handful of tours of fuel handling buildings, for an hour at a time. *Id.* at 27-28, 33-36.

1. Admitted Basis 2 – Single Fuel Assembly Misplacement

Basis 2 raises a question of fact: will a single fuel assembly misplacement, involving a fuel element of the wrong burnup or enrichment, cause criticality in Harris spent fuel pools C and D? The following material facts are required to dispose of Basis 2:

1. The Applicant has performed a criticality analysis of a single fuel assembly misplacement, involving a fresh fuel assembly with the maximum permissible reactivity at Harris, for the spent fuel storage racks in Harris pools C and D.
2. The criticality analysis demonstrates that a single fuel assembly misplacement, involving a fresh fuel assembly fuel element with the maximum permissible reactivity at Harris, will not cause criticality in Harris pools C and D.

The Board should dispose of Basis 2 in the Applicant's favor if these two material facts are answered in the affirmative.

Following the admission of Basis 2, the Applicant performed a supplemental analysis to evaluate the misplacement of a single fuel assembly in the spent fuel storage racks for Harris pools C and D.¹²³ The results of this analysis are documented in Holtec

¹²³ Redmond Affidavit (Exhibit 3, ¶ 9); DeVoe Affidavit (Exhibit 4, ¶ 4). This analysis was performed even though the question had already been addressed through previous analyses by Holtec International ("Holtec") for another plant with similar spent fuel

Footnote continued on next page

report no. HI-992283, Evaluation of Fresh Fuel Assembly Misload in Harris Pools C and D, Rev. 0, dated September 20, 1999 ("Harris Misplacement Analysis").¹²⁴ The Harris Misplacement Analysis performs a fuel assembly misplacement analysis specifically for the spent fuel storage racks for Harris pools C and D, using the specific fuel assembly characteristics and spent fuel storage rack designs for Harris spent fuel pools C and D.¹²⁵ The Harris Misplacement Analysis also addresses the additional scenario of misplacement of a fresh fuel assembly assuming no soluble boron in the pool water, which exceeds the NRC Staff's misplacement analysis requirements.¹²⁶

The Harris Misplacement Analysis was performed by Dr. Everett L. Redmond II, a nuclear criticality analyst employed by Holtec.¹²⁷ Dr. Redmond had performed the original nuclear criticality analysis ("Harris Base Criticality Analysis") for the spent fuel

Footnote continued from previous page

storage racks and identical fuel to that used in the Harris analysis. Redmond Affidavit (Exhibit 3, ¶ 7); DeVoe Affidavit (Exhibit 4, ¶ 4). This previous analysis was the basis of the Applicant's statement in response to the proposed Basis 2 and its response to the Staff's RAI regarding the misplacement analysis. See Applicant's Answer to Petitioner BCOC's Contentions at 35-36; Redmond Affidavit (Exhibit 3, ¶ 8); Edwards Affidavit (Exhibit 1, ¶ 24). The Applicant's RAI response is included as Attachment C to Exhibit 1.

¹²⁴ The Harris Misplacement Analysis is included at Attachment B to Exhibit 3 (Redmond Affidavit).

¹²⁵ Redmond Affidavit (Exhibit 3, ¶¶ 10, 11, 15, 16); DeVoe Affidavit (Exhibit 4, ¶¶ 8, 9).

¹²⁶ Redmond Affidavit (Exhibit 3, ¶ 12). This additional analysis does, however, provide the analysis to render BCOC's first new issue moot.

¹²⁷ See Redmond Affidavit (Exhibit 3, ¶ 4).

storage racks in Harris pools C and D.¹²⁸ The Harris Misplacement Analysis uses the same analysis methodology, including the assumptions and modeling of the storage rack design and fuel assembly characteristics, as that developed for, and used in, the Harris Base Criticality Analysis.¹²⁹

The Harris Misplacement Analysis evaluates the misplacement of a single fresh fuel assembly, of the maximum permissible enrichment at Harris, into a spent fuel storage rack that is otherwise loaded with fuel of the maximum permissible reactivity allowable under the burnup and enrichment curve.¹³⁰ The maximum reactivity fresh fuel assembly at Harris is a Westinghouse 15x15 Pressurized Water Reactor ("PWR") fuel assembly enriched to 5% (by weight) uranium-235.¹³¹ The Harris Misplacement Analysis considered the presence of 2000 ppm of soluble boron in the pool water, as required by Harris operating procedures.¹³² The analysis also evaluated criticality safety

¹²⁸ Redmond Affidavit (Exhibit 3, ¶ 13). The Harris Base Criticality Analysis is documented in Holtec report no. HI-971760, "Licensing Report for Expanding Storage Capacity in Harris Pools C and D." This analysis did not explicitly analyze a fresh fuel assembly misplacement event. Redmond Affidavit (Exhibit 3, ¶ 6). The Harris Base Criticality Analysis is part of the Harris License Amendment Request, which is included herein as Attachment A to Exhibit 1 (Edwards Affidavit).

¹²⁹ Redmond Affidavit (Exhibit 3, ¶¶ 13, 14, 15, 16, 17). Dr. Thompson could find no fault in the Harris Base Criticality Analysis and described this analysis as "a very carefully written, very presentable document that's in a high professional competence." Thompson Dep. Tr. (Exhibit 11 at 185).

¹³⁰ Redmond Affidavit (Exhibit 3, ¶ 16).

¹³¹ Redmond Affidavit (Exhibit 3, ¶ 16); DeVoe Affidavit (Exhibit 4, ¶¶ 9, 10). This had already been determined in the Harris Base Criticality Analysis.

¹³² Redmond Affidavit (Exhibit 3, ¶¶ 7, 11); DeVoe Affidavit (Exhibit 4, ¶ 10); Edwards Affidavit (Exhibit 1, ¶ 23).

assuming only 400 ppm of soluble boron was present in the pool water, to confirm CP&L's statements in its RAI response to the NRC Staff.¹³³ In addition, to demonstrate the robustness of criticality safety of the spent fuel storage racks for Harris pools C and D, the Harris Misplacement Analysis evaluated the limiting case of no soluble boron in the pool water at all.¹³⁴ While not considered a credible scenario, this analysis was performed to render moot any further discussion of the loss of soluble boron in this proceeding.

The methodology, assumptions, and results of the Harris Misplacement Analysis were reviewed and approved under the quality assurance requirements of both Holtec and CP&L. The analysis was verified and validated through the Holtec quality assurance process, which included an independent review and approval by another competent criticality analyst.¹³⁵ The analysis was also reviewed and approved by CP&L's Owner's Review process pursuant to CP&L's procedures.¹³⁶ These quality assurance reviews of the Harris Misplacement Analysis by qualified nuclear criticality analysts provides reasonable assurance that the results of the analysis are valid.

¹³³ Redmond Affidavit (Exhibit 3, ¶¶ 7, 11); DeVoe Affidavit (Exhibit 4, ¶ 10).

¹³⁴ Redmond Affidavit (Exhibit 3, ¶ 12); DeVoe Affidavit (Exhibit 4, ¶ 10).

¹³⁵ Redmond Affidavit (Exhibit 3, ¶ 8).

¹³⁶ DeVoe Affidavit (Exhibit 4, ¶¶ 4-13). The CP&L Owner's Review determined that the input assumptions accurately reflected Harris fuel characteristics and spent fuel storage racks, and that the results were consistent with CP&L's nuclear criticality analysts' expectations. Id., ¶¶ 6, 8. The CP&L Owner's Review approved the Harris Misplacement Analysis with no adverse comments. Id., ¶¶ 11, 12, 13.

The results of the Harris Misplacement Analysis demonstrate that a single fuel assembly misplacement, involving a fuel element of the wrong burnup or enrichment, will not cause criticality in Harris spent fuel pools C and D.¹³⁷ The analysis demonstrates that the spent fuel storage racks, with the required 2000 ppm of soluble boron in the spent fuel pool water, will remain subcritical following the misplacement of a fresh fuel assembly with the maximum permissible enrichment at Harris, with a k-effective of 0.7783.¹³⁸ This is the analysis required to comply with the NRC Staff's guidance regarding a misplacement event.¹³⁹ The Harris Misplacement Analysis also demonstrates that the spent fuel storage racks will remain subcritical, with a k-effective of 0.9352, following a misplacement event assuming only 400 ppm of soluble boron is present in the spent fuel pool water.¹⁴⁰ This result confirms the response made by CP&L in its June 14, 1999 RAI response to the NRC.¹⁴¹ Finally, the analysis demonstrates that the spent fuel storage racks for Harris pools C and D will remain subcritical following a fresh fuel assembly misplacement event even if no soluble boron (i.e., zero (0) ppm) is present in the spent fuel pool water, with a k-effective of 0.9932.¹⁴²

¹³⁷ Redmond Affidavit (Exhibit 3, ¶ 20); DeVoe Affidavit (Exhibit 4, ¶ 10).

¹³⁸ Redmond Affidavit (Exhibit 3, ¶ 21); DeVoe Affidavit (Exhibit 4, ¶ 10).

¹³⁹ The analysis may take credit for the presence of soluble boron required by procedure to be maintained in the spent fuel pool water. Redmond Affidavit (Exhibit 3, ¶ 11).

¹⁴⁰ Redmond Affidavit (Exhibit 3, ¶ 22); DeVoe Affidavit (Exhibit 4, ¶ 10).

¹⁴¹ Redmond Affidavit (Exhibit 3, ¶ 22). CP&L's June 14, 1999 RAI response is included herein as Attachment C to Exhibit 1 (Edwards Affidavit).

¹⁴² Redmond Affidavit (Exhibit 3, ¶ 23); DeVoe Affidavit (Exhibit 4, ¶ 10); Edwards Affidavit (Exhibit 1, ¶ 26).

The supplemental criticality analysis performed in the Harris Misplacement Analysis, as documented in Attachment B of Exhibit 3, and supported by the sworn affidavits provided herein, provides the answers to the material facts required to dispose of the admitted Basis 2. The Harris Misplacement Analysis demonstrates in the affirmative that:

1. The Applicant has performed a criticality analysis of a single fuel assembly misplacement, involving a fresh fuel assembly with the maximum permissible reactivity at Harris, for the spent fuel storage racks in Harris pools C and D.¹⁴³
2. The criticality analysis demonstrates that a single fuel assembly misplacement, involving a fresh fuel assembly fuel element with the maximum permissible reactivity at Harris, will not cause criticality in Harris pools C and D.¹⁴⁴

Because these two materials facts are answered in the affirmative, and BCOC does not dispute them, the Board should dispose of Basis 2 in Applicant's favor.

2. Other Issues Raised by BCOC during Discovery Regarding Criticality Analysis

¹⁴³ See Redmond Affidavit (Exhibit 3, ¶¶ 7, 9, 10, 11, 15, 16); DeVoe Affidavit (Exhibit 4, ¶¶ 4, 8, 9, 10).

¹⁴⁴ See Redmond Affidavit (Exhibit 3, ¶¶ 20, 21, 22); DeVoe Affidavit (Exhibit 4, ¶ 10).

As discussed above, BCOC raised three additional issues during the course of discovery that exceed the scope of the admitted Basis 2:

1. The Applicant should have evaluated the loss of all soluble boron in the pool water concurrent with the misplacement of a fuel assembly.
2. The Applicant should have evaluated the concurrent misplacement of multiple fuel assemblies, over and above the misplacement of a single fuel assembly.
3. The Applicant should have analyzed the universe of scenarios involving two or more unlikely, independent, and concurrent events.

Each of these issues exceeds the scope of Basis 2, as admitted. In the event that BCOC attempts to raise these new issues, Applicant demonstrates below that each issue would be disposed of in the Applicant's favor, and, in any event, has been rendered moot by the supplemental criticality analyses performed by Dr. Redmond, Dr. Turner and the NRC Staff in this case.

a. BCOC's First New Issue

BCOC's first new issue alleges that the Applicant should evaluate the loss of all soluble boron in the pool water concurrent with the misplacement of a fuel assembly.

This analysis is not required under the Double Contingency Principle.¹⁴⁵ The Double Contingency Principle is sometimes called the Single Failure Criterion.¹⁴⁶ BCOC has admitted that the NRC Staff's definition of the Double Contingency Principle, as stated in Draft Regulatory Guide 1.13 ("Reg. Guide 1.13"), is consistent with the NRC's regulation of criticality control in GDC 62.¹⁴⁷ The Double Contingency Principle is defined in Reg. Guide 1.13 as follows:¹⁴⁸

At all locations in the LWR spent fuel storage facility where spent fuel is handled or stored, the nuclear criticality safety analysis should demonstrate that criticality could not occur without at least two unlikely, independent, and concurrent failures or operating limit violations.

Since the Double Contingency Principle is an NRC Staff development, the most appropriate way to determine its meaning is to inspect NRC Staff guidance.¹⁴⁹ The most

¹⁴⁵ The origin, meaning, and application of the Double Contingency Principle are addressed at length in the Affidavit of Stanley L. Turner, Ph.D., PE. Turner Affidavit (Exhibit 2, ¶¶ 38-45).

¹⁴⁶ Id. at ¶ 38.

¹⁴⁷ When it proposed Contention 2, BCOC addressed the Double Contingency Principle on page 1.13-9 of Reg. Guide 1.13, and then stated that "the language at page 1.13-9 [the Double Contingency Principle] is consistent with GDC 62." Orange County's Supplemental Petition to Intervene at 13.

¹⁴⁸ Turner Affidavit (Exhibit 2, ¶¶ 39, 40). Reg. Guide 1.13 is included herein as Attachment D to Exhibit 2 (Turner Affidavit).

¹⁴⁹ Even though the Double Contingency Principle (or Single Failure Criterion) is an NRC Staff development, in 10 C.F.R. § 50.68 the Commission effectively endorsed the use of the Single Failure Criterion for the evaluation of accident conditions in spent fuel storage pools. Turner Affidavit (Exhibit 2, ¶ 34).

recent published NRC Staff guidance (“1998 Criticality Guidance”) defines the Double Contingency Principle as follows:¹⁵⁰

ABNORMAL CONDITIONS AND THE DOUBLE-CONTINGENCY PRINCIPLE

The criticality safety analysis should consider all credible incidents and postulated accidents. However, by virtue of the double-contingency principle, *two unlikely independent and concurrent incidents or postulated accidents are beyond the scope of the required analysis*. The double-contingency principle means that a realistic condition may be assumed for the criticality analysis in calculating the effects of incidents or postulated accidents. For example, if soluble boron is normally present in the spent fuel pool water, the loss of soluble boron is considered as one accident condition and *a second concurrent accident need not be assumed*. Therefore, credit for the presence of the soluble boron may be assumed in evaluating other accident conditions.

(Emphasis added). The Double Contingency Principle, as defined by the NRC Staff, requires that the Applicant’s criticality analysis consider separately each single unlikely, independent incident or credible accident condition.¹⁵¹ There is no requirement under the Double Contingency Principle to evaluate two or more unlikely, independent, concurrent incidents or postulated accidents; such an analysis is beyond the scope of the required analysis.¹⁵² The Double Contingency Principle has always been interpreted this way.¹⁵³ Applicant’s criticality analysis for Harris, including the supplemental analysis in the

¹⁵⁰ Turner Affidavit (Exhibit 2, ¶ 41). The 1998 Criticality Guidance is included herein as Attachment H to Exhibit 2 (Turner Affidavit).

¹⁵¹ Id. at ¶ 43.

¹⁵² Id. at ¶¶ 43, 45.

Harris Misplacement Analysis, correctly implements the Double Contingency Principle.¹⁵⁴

Loss of soluble boron is a highly unlikely (in fact, not credible) accident condition that is independent from a fuel misplacement event. A boron dilution event resulting in the loss of all soluble boron down to 400 ppm or less is not a credible event for Harris spent fuel pools C and D.¹⁵⁵ Harris operating procedures require that 2000 ppm of soluble boron be maintained in the spent fuel pools at all times.¹⁵⁶ There is no known credible mechanism to dilute the pool water from 2000 ppm of soluble boron down to 400 ppm, or less.¹⁵⁷ A fuel assembly misplacement is a highly unlikely event at Harris.¹⁵⁸ Boron dilution and fuel assembly misplacement are entirely unrelated and independent unlikely events.¹⁵⁹ In fact, BCOC admits that boron dilution and misplacement of a fuel assembly are two separate events.¹⁶⁰ As two separate unlikely independent events, the concurrent analysis of a boron dilution event and a fuel assembly misplacement event is not required

Footnote continued from previous page

¹⁵³ *Id.* at ¶¶ 42, 44.

¹⁵⁴ *Id.* at ¶¶ 46.

¹⁵⁵ Edwards Affidavit (Exhibit 1, ¶¶ 23-25).

¹⁵⁶ *Id.* at ¶ 22. A copy of the Harris operating procedure is included at Attachment P to Exhibit 1 (Edwards Affidavit).

¹⁵⁷ Edwards Affidavit (Exhibit 1, ¶¶ 24, 25); see also Turner Affidavit (Exhibit 2, ¶ 21).

¹⁵⁸ Edwards Affidavit (Exhibit 1, ¶¶ 14-20).

¹⁵⁹ *Id.* at ¶ 23.

¹⁶⁰ Dr. Thompson admits that “[a] misplacement of a single assembly and an insufficiency of boron would be two separate errors.” Thompson Dep. Tr. (Exhibit 11 at 133).

under the Double Contingency Principle. BCOC's first new issue, therefore, requests the Applicant to perform an analysis that is not required. If considered by the Board at all, BCOC's first new issue should be disposed of in Applicant's favor.

Applicant's supplemental Harris Misplacement Analysis renders this discussion moot. Regardless of whether or not the Double Contingency Principle requires it, the Harris Misplacement Analysis evaluated the concurrent misplacement of a fresh fuel assembly combined with the loss of all soluble boron in the Harris spent fuel pools.¹⁶¹ The Harris Misplacement Analysis demonstrates that the spent fuel storage racks in Harris pools C and D will remain subcritical following a fresh fuel assembly misplacement event, even if no soluble boron (i.e., zero (0) ppm) is present in the spent fuel pool water.¹⁶² Thus, BCOC's first new issue, alleging that the Applicant should evaluate the loss of all soluble boron and the concurrent misplacement of a fuel assembly, has been demonstrated to be moot by the Harris Misplacement Analysis.

b. BCOC's Second New Issue

BCOC's second new issue alleges the Applicant should have evaluated the concurrent misplacement of multiple fuel assemblies, over and above the misplacement of a single fuel assembly. As in the first issue, BCOC's requested analysis is not required

¹⁶¹ Redmond Affidavit (Exhibit 3, ¶ 12).

¹⁶² Redmond Affidavit (Exhibit 3, ¶ 23); Edwards Affidavit (Exhibit 1, ¶ 26); Turner Affidavit (Exhibit 2, ¶ 48).

under the Double Contingency Principle. Moreover, as with the first issue, supplemental criticality analysis performed for this proceeding has demonstrated that this issue is moot.

As discussed above, the Double Contingency Principle, as defined by the NRC Staff, requires that the Applicant's criticality analysis consider separately each single unlikely, independent incident or credible accident condition.¹⁶³ There is no requirement under the Double Contingency Principle to evaluate two or more unlikely, independent, concurrent incidents or postulated accidents; such an analysis is beyond the scope of the required analysis.¹⁶⁴ Misplacement of a single fuel assembly at Harris is a highly unlikely event, and, in fact, has never occurred at Harris.¹⁶⁵ Because of procedural and physical limitations, each movement of an individual fuel assembly in the Harris spent fuel pools is a separate, independent event.¹⁶⁶ The concurrent misplacement of multiple fuel assemblies in the Harris spent fuel pools is not credible.¹⁶⁷ Therefore, multiple fuel assembly misplacements would require the occurrence of two or more unlikely, independent, and concurrent incidents or postulated accidents. As two or more separate unlikely independent events, multiple fuel assembly misplacement events are not required to be analyzed under the Double Contingency Principle. BCOC's second new issue, therefore, requests Applicant to perform an analysis that is not required. If

¹⁶³ Id. at ¶ 43.

¹⁶⁴ Id. at ¶¶ 43, 45.

¹⁶⁵ Edwards Affidavit (Exhibit 1, ¶¶ 14-20).

¹⁶⁶ Id. at ¶¶ 12, 13.

¹⁶⁷ Id. at ¶¶ 21, 22.

considered by the Board at all, BCOC's second new issue should be disposed of in Applicant's favor.

Moreover, as with the first new issue, the supplemental Harris Misplacement Analysis performed for this proceeding renders this discussion moot. In response to BCOC's allegations of multiple fuel assembly misplacements, the NRC Staff performed a supplemental criticality analysis for this proceeding ("NRC Staff's Criticality Analysis").¹⁶⁸ Applicant's nuclear criticality experts, Dr. Stanley Turner and Dr. Everett Redmond II, have both reviewed and confirmed the methodology, assumptions, and results of the NRC Staff's Criticality Analysis.¹⁶⁹ The NRC Staff's Criticality Analysis evaluates the concurrent misplacement of an infinite number of fresh fuel assemblies of the maximum permissible reactivity at Harris.¹⁷⁰ Even BCOC admits that this assumption exceeds what needs to be considered.¹⁷¹ The NRC Staff's Criticality Analysis demonstrates that the spent fuel storage racks in Harris pools C and D will

¹⁶⁸ Redmond Affidavit (Exhibit 3, ¶¶ 24-27); Turner Affidavit (Exhibit 2, ¶¶ 52-55). The NRC Staff's Criticality Analysis is included herein as Attachment C to Exhibit 3 (Redmond Affidavit).

¹⁶⁹ Redmond Affidavit (Exhibit 3, ¶¶ 25, 26); Turner Affidavit (Exhibit 2, ¶¶ 53-54). Dr. Turner also performed an independent analysis that confirms the results obtained by the NRC Staff. Turner Affidavit (Exhibit 2, ¶ 54).

¹⁷⁰ Consistent with the Double Contingency Principle, the analysis includes the 2000 ppm of soluble boron required to be in the spent fuel pool water pursuant to Harris operating procedures. Redmond Affidavit (Exhibit 3, ¶ 24); Turner Affidavit (Exhibit 2, ¶ 52).

¹⁷¹ Dr. Thompson admitted that the misplacement of an entire pool full of assemblies has a low enough probability that it need not be considered. Thompson Dep. Tr. (Exhibit 11 at 164-65).

remain subcritical following an infinite number of fresh fuel assembly misplacements.¹⁷² Thus, the Harris spent fuel storage racks will remain subcritical even if every location in the spent fuel storage rack is assumed to be concurrently loaded with a misplaced fresh fuel assembly of the maximum permissible reactivity at Harris.¹⁷³ BCOC's second new issue, alleging that CP&L should evaluate the multiple fuel assembly misplacements, has been demonstrated to be moot by the NRC Staff's Criticality Analysis.

c. BCOC's Third New Issue

BCOC's third new issue alleges that Applicant should have analyzed the universe of scenarios involving two or more unlikely, independent, and concurrent events. As with the first two new issues, BCOC's requested analysis is not required under the Double Contingency Principle. There is no requirement to analyze the universe of two or more unlikely, independent, and concurrent incidents or postulated accidents that, taken all together, could result in criticality.¹⁷⁴ Moreover, in light of the many criticality analyses that Applicant has already performed, BCOC has admitted that the only missing scenario, from its "universe" of scenarios of two or more failures, is multiple fuel assembly misplacements.¹⁷⁵ BCOC's narrowing of the remaining universe of scenarios down to multiple fuel assembly misplacements renders the third new issue, in practical

¹⁷² Redmond Affidavit (Exhibit 3, ¶ 27); Turner Affidavit (Exhibit 2, ¶ 55).

¹⁷³ Id.

¹⁷⁴ Turner Affidavit (Exhibit 2, ¶ 45).

¹⁷⁵ Dr. Thompson admitted that the remaining "universe," for this particular case, includes only the assumption of multiple fuel assembly misplacements. Thompson Dep. Tr. (Exhibit 11 at 195-96).

effect, identical to the second issue. Just like the second issue, then, BCOC's request to analyze the misplacement of multiple fuel assemblies, which comprises two or more unlikely, independent, and concurrent errors, is not required to be analyzed under the Double Contingency Principle. If considered by the Board at all, BCOC's third new issue should be disposed of in Applicant's favor.

Moreover, as with the second new issue, the NRC Staff's Criticality Analysis renders BCOC's third new issue moot.¹⁷⁶ BCOC has admitted that the remaining universe of scenarios, for this particular case, is limited to multiple fuel assembly misplacements.¹⁷⁷ The NRC Staff's Criticality Analysis demonstrates that the spent fuel storage racks for Harris pools C and D will remain subcritical following an infinite number of fresh fuel assembly misplacements.¹⁷⁸ Thus, BCOC's third new issue has also been rendered moot by the NRC Staff's Criticality Analysis.

D. Intervenor BCOC Cannot Meet its Burden of Demonstrating an Adjudicatory Hearing Must Be Held to Dispose of Contention 2

1. Basis 1 is a Question of Law for which an Adjudicatory Hearing is Not Appropriate

The issue presented in Basis 1 is a question of law that does not require an adjudicatory hearing and can be decided on the written and oral legal arguments. The

¹⁷⁶ Redmond Affidavit (Exhibit 3, ¶¶ 24-27); Turner Affidavit (Exhibit 2, ¶¶ 52-55).

¹⁷⁷ Thompson Dep. Tr. (Exhibit 11 at 195-96).

¹⁷⁸ Redmond Affidavit (Exhibit 3, ¶ 27); Turner Affidavit (Exhibit 2, ¶ 55).

Board admitted Basis 1 as "a question of law" to be addressed by "legal arguments."¹⁷⁹ The Commission has determined that issues of law should be decided on the basis of briefs and oral argument.¹⁸⁰ The only quasi-factual issues in Basis 1 are that all available methods of criticality control, including fuel enrichment and burnup limits, are physical systems or processes that are implemented using administrative measure, and that fuel assembly reactivity includes the effects of fuel burnup. However, these facts have been admitted by all parties, and therefore do not present any genuine and substantial dispute of fact. The underlying legal issue can and should be decided by the Board on the basis of the legal arguments in the parties' respective filings and during oral argument.¹⁸¹

2. Basis 2 Presents no Genuine and Substantial Dispute of Fact for an Adjudicatory Hearing

There is no dispute of fact regarding the material facts necessary for the Board to dispose of Basis 2. The only material facts required to dispose of Basis 2, as admitted by the Board, are that Applicant has analyzed criticality for a single fuel assembly fuel assembly misplacement in Harris spent fuel pools C and D, and that the criticality analysis demonstrates the misplacement will not cause criticality. BCOC has admitted that Applicant's supplemental Harris Misplacement Analysis satisfactorily answers these

¹⁷⁹ Harris, LBP-99-25, supra, 50 NRC at 35-36.

¹⁸⁰ See 10 C.F.R. § 2.714(e).

¹⁸¹ These legal arguments are supported by numerous documents and sworn statements submitted with the filing.

questions.¹⁸² Moreover, BCOC has repeatedly stated that it will not challenge the validity of the criticality calculations in the Harris Misplacement Analysis.¹⁸³ In any event, BCOC's sole expert for Basis 2, by his own admission, is not competent to challenge the nuclear criticality analyses.¹⁸⁴ Thus, there is no genuine and substantial dispute of fact regarding Applicant's demonstration that misplacement of a single fuel assembly will not cause criticality in Harris pools C and D. Therefore, Contention 2, Basis 2, should be dismissed.

The technical issues in Basis 2 can be accurately resolved based on the written submissions and attached technical reports, regardless of whether there is any dispute. The question of fact in Basis 2 is one of a technical nature - - will criticality occur in the Harris pools following a fuel assembly misplacement. The Applicant has submitted the

¹⁸² In his sworn deposition, Dr. Thompson admitted that the Harris Misplacement Analysis "does address the question of a single fuel assembly misplacement . . . [a]nd this finding, this Holtec finding mentioned in Exhibit 18, does show . . . that a single misplacement still allows criticality safety without boron." Thompson Dep. Tr. (Exhibit 11 at 189). Dr. Thompson repeats this admission two other times. Id. at 139-40, 196.

¹⁸³ Dr. Thompson repeatedly stated that BCOC will not challenge the validity of the Applicant's criticality calculations. Thompson Dep. Tr. at (Exhibit 11 183-85, 194). Dr. Thompson praised the Applicant's criticality analysis as "a very carefully written, very presentable document that's in a high professional competence." Id. at 185. In its response to interrogatories, BCOC stated that it "does not intend to challenge [Holtec's calculations] in this license amendment proceeding." BCOC's Interrogatory Responses at 4-5 (Responses to Interrogatories 2-6 and 2-7).

¹⁸⁴ Dr. Thompson admitted that he is not competent to assess the criticality analysis that was performed. Thompson Dep. Tr. (Exhibit 11 at 24-25). He admitted that he has never performed any nuclear criticality analyses, has no training, education, or experience with nuclear criticality analysis, and does not anticipate doing so for this proceeding. See id. at 21-23, 25. Dr. Thompson confined his expertise to evaluating only the adequacy of the assumptions used in the analysis. Id. at 24-25.

criticality analysis report answering this question of fact. This criticality analysis, together with the sworn submittals attesting to the validity of its methodology and accuracy of its results, provides all that is required for the Board to dispose of Basis 2 with sufficient accuracy. A hearing on this matter would serve no purpose because BCOC has admitted it will not challenge the results of the criticality analysis, and its sole witness is not competent to do so, by his own admission. There is simply no need for a formal adjudicatory hearing to resolve with sufficient accuracy this technical question of fact in Basis 2.

The three new issues raised by BCOC during the course of discovery also would not warrant an adjudicatory hearing, even if they had been the subjects of an admitted contention. All three of these new issues have been rendered moot by the criticality analyses performed by Applicant and the NRC Staff in this proceeding. BCOC has admitted that Applicant's supplemental Harris Misplacement Analysis answers the first new issue, misplacement of a fuel assembly plus the loss of all soluble boron.¹⁸⁵ The NRC Staff's analysis of an infinite number of fuel assembly misplacements answers the second new issue, misplacement of multiple fuel assemblies. Moreover, BCOC has repeatedly stated that it will not challenge the validity of criticality calculations in this proceeding,¹⁸⁶ nor is it competent to do so.¹⁸⁷ For the third new issue, the "universe" of

¹⁸⁵ Dr. Thompson admitted that the Applicant's analysis demonstrated criticality safety in the event of misplacement of a fuel assembly with no soluble boron in the pool water. See Thompson Dep. Tr. (Exhibit 11 at 186, 189).

¹⁸⁶ See Thompson Dep. Tr. (Exhibit 11 at 183-85, 194); BCOC's Interrogatory Responses at 4-5 (Responses to Interrogatories 2-6 and 2-7).

scenarios of two or more failures, BCOC has admitted that in this particular case the only missing scenario is multiple fuel assembly misplacements.¹⁸⁸ The issue of multiple misplacements is the same as the BCOC's second new issue, which is answered by the NRC Staff's analysis of infinite fuel assembly misplacements. Thus, even if they were the subjects of an admitted contention, these three new issues present no genuine and substantial dispute of fact. Moreover, as with Basis 2, these three new issues could be accurately resolved based on the written submissions and attached technical reports. While these three new issues should be rejected by the Board as beyond the scope of Basis 2, it is clear that there would be no need for a formal adjudicatory hearing to resolve with sufficient accuracy the technical questions presented by these new issues.

V. TECHNICAL CONTENTION 3

A. Clarification of the Scope of Contention 3 During Discovery

Contention 3, as admitted by the Board, alleges the following¹⁸⁹:

CP&L's proposal to provide cooling of pools C & D by relying upon the use of previously completed portions of the Unit 2 Fuel Pool Cooling and Cleanup System and the Unit 2 Component Cooling Water System fails to satisfy the quality assurance criteria of 10 C.F.R. Part 50, Appendix B, specifically Criterion XIII (failure to show that the piping and equipment have been stored and preserved in a manner that prevents damage or deterioration), Criterion XVI (failure to institute measures

Footnote continued from previous page

¹⁸⁷ See Thompson Dep. Tr. (Exhibit 11 at 23-25).

¹⁸⁸ Thompson Dep. Tr. (Exhibit 11 at 195-96).

¹⁸⁹ Harris, LBP-99-25, supra, 50 NRC at 36-37.

to correct any damage or deterioration), and Criterion XVII (failure to maintain necessary records to show that all quality assurance requirements are satisfied).

Moreover, the Alternative Plan submitted by Applicant fails to satisfy the requirements of 10 C.F.R. § 50.55a for an exception to the quality assurance criteria because it does not describe any program for maintaining the idle piping in good condition over the intervening years between construction [and] implementation of the proposed license amendment, nor does it describe a program for identifying and remediating potential corrosion and fouling.

The Alternative Plan submitted by Applicant is also deficient because 15 welds for which certain quality assurance records are missing are embedded in concrete and inspection of the welds to demonstrate weld quality cannot be adequately accomplished with a remote camera.

Finally, the Alternative Plan submitted by Applicant is deficient because not all other welds embedded in concrete will be inspected by the remote camera, and the weld quality cannot be demonstrated adequately by circumstantial evidence.¹⁹⁰

Contention 3 was clarified and narrowed in scope through the discovery process, both during the sworn deposition of Mr. David Lochbaum, the sole expert proffered by BCOC on Contention 3, and in BCOC's Interrogatory Responses. Specifically, Mr. Lochbaum agreed that the scope of the Contention 3 is limited to those components of the Harris SFPCCS for spent fuel pools C and D where an exception is sought by CP&L from the ASME Code requirements and where both an internal and external inspection is

¹⁹⁰ This final alleged deficiency in the Alternative Plan is now moot. CP&L inspected by remote camera inspection all 15 embedded field welds in the SFPCCS piping for spent fuel pools C and D. See Edwards Affidavit (Exhibit 1, ¶ 36). Copies of the videotapes for all remote camera inspections, including a re-inspection of one weld to determine the nature of certain reddish-brown deposits, were provided to counsel for BCOC.

not possible.¹⁹¹ Here, the 50.55a Alternative Plan, submitted as part of CP&L's license amendment request¹⁹², provides an alternative to satisfy the intent of the ASME Code requirements for field welds in SFPCCS piping, for which certain quality documentation had been destroyed.¹⁹³ Mr. Lochbaum conceded that the SFPCCS heat exchangers, pumps, and accessible piping (i.e., the SFPCCS piping not embedded in concrete and thus subject to re-inspection and nondestructive examination) are not at issue in Contention 3.¹⁹⁴ Nor were any issues regarding SFPCCS heat exchangers, pumps, or accessible piping raised in BCOC's Interrogatory Responses.¹⁹⁵ The only issue now before the Board in Contention 3 is the condition of the SFPCCS piping and 15 field welds embedded in concrete.¹⁹⁶ BCOC disputes: (1) the condition of the embedded welds in 1983 when construction of the SFPCCS was abandoned with the cancellation of

¹⁹¹ Lochbaum Deposition Transcript of October 14, 1999 ("Lochbaum Dep. Tr.") at 81-87 (attached hereto as Exhibit 10.)

¹⁹² The license amendment request is Attachment A to Exhibit 1 and the 50.55a Alternative Plan is Enclosure 8 to Attachment A.

¹⁹³ Edwards Affidavit (Exhibit 1, ¶ 27, 30-32).

¹⁹⁴ Lochbaum Dep. Tr. (Exhibit 10 at 83-87).

¹⁹⁵ See BCOC's Interrogatory Responses relating to Contention 3.

¹⁹⁶ "Q. The only thing that this contention addresses, is it not true, is the embedded piping and embedded welds? A. The way it's worded, that's correct." Lochbaum Dep. Tr. (Exhibit 10 at 86-87).

Harris Unit 2¹⁹⁷; and (2) whether there has been corrosion damage or deterioration to the embedded welds or piping between 1983 and 1999.¹⁹⁸

B. Summary of Facts, Data and Arguments which Demonstrate that CP&L's 10 C.F.R. § 50.55a Alternative Plan Provides an Acceptable Level of Quality and Safety in the Spent Fuel Pool Cooling and Cleanup System for Harris Nuclear Plant Spent Fuel Pools C and D as Constructed

There are three subparts to the first paragraph of Contention 3, which alleges CP&L's proposed license amendment request to place the SFPCCS in service to enable storage of spent fuel in spent fuel pools C and D "fails to satisfy the quality assurance criteria of 10 C.F.R. Part 50, Appendix B": (1) specifically Criterion XIII (failure to show that the piping and equipment have been stored and preserved in a manner that prevents damage or deterioration), (2) Criterion XVI (failure to institute measures to correct any damage or deterioration), and (3) Criterion XVII (failure to maintain necessary quality records to show that all quality assurance requirements are satisfied).

It is undisputed that subsequent to cancellation of Harris 2 in December 1983, the piping for the Unit 2 SFPCCS has not been maintained as part of the licensed HNP, and therefore was not subject to the requirements of the plant's 10 C.F.R. Part 50, Appendix B, QA Program. The SFPCCS piping was not stored or placed in lay-up pursuant to Criterion XIII. It was not subject to the HNP Corrective Action Program. A

¹⁹⁷ The condition of the piping with vendor's welds as of 1983 is not at issue because the vendor quality documentation for the piping spools that are embedded in concrete were not destroyed. Edwards Affidavit (Exhibit 1, ¶ 30).

¹⁹⁸ See Lochbaum Dep. Tr. (Exhibit 10 at 89-90).

number of piping isometric packages (including weld data reports ("WDR") for field welds) for field installation of the completed portion of the SFPCCS were discarded and are not available.¹⁹⁹ As a result, quality records required by the ASME Code, Section III, are no longer available for certain large bore welds in the completed SFPCCS piping.²⁰⁰

However, once construction on the Harris Unit 2 SFPCCS is completed and the system and spent fuel pools C and D are commissioned and placed in service, the SFPCCS must meet the requirements of 10 C.F.R. Part 50, Appendix B. The 50.55a Alternative Plan addresses the existing situation where HNP is no longer under construction, CP&L no longer maintains its ASME N-Stamp certification program, and certain quality documentation was discarded concerning field welds. Under the circumstances, 10 C.F.R. §50.55a permits an alternative demonstration of an acceptable level of quality and safety in construction.²⁰¹

¹⁹⁹ Edwards Affidavit (Exhibit 1, ¶ 27), Attachment A, Lic. Amend. App., Encl. 8, at 3.

²⁰⁰ *Id.* at 3, 5. The accessible field welds have been reexamined, including nondestructive examination ("NDE"), and substitute WDRs for the 22 accessible field welds have been created to address the ASME Code requirements on quality documentation. As noted previously, the accessible piping and field welds are not subject to challenge by Contention 3. The 15 embedded field welds cannot be reexamined pursuant to the original ASME Code requirements.

²⁰¹ 10 C.F.R. § 50.55a(e)(1) by its terms does not require CP&L to meet the requirements for Class 3 components in Section III of the ASME Code for the SFPCCS, because the construction permit for the HNP was docketed prior to May 14, 1984. Nevertheless, CP&L had, however, committed to design and construct the spent fuel pools and SFPCCS (Quality Group C Components) to Section III, Class 3 requirements at the time of construction. This commitment was reflected in the Safety Evaluation Report issued by the NRC for the operation of Harris Units 1 and 2. CP&L has not sought to back

Footnote continued on next page

There are two issues addressed in CP&L's 50.55a Alternative Plan: (1) development of Supplemental Quality Assurance ("QA") requirements for the commissioning of the SFPCCS for spent fuel pools C and D to augment CP&L's Corporate QA Program, in order to address construction QA requirements that were part of the Harris ASME Code QA Program during construction at HNP; and (2) the missing QA documentation for the SFPCCS piping field welds.

BCOC has not challenged the adequacy of the Supplemental QA requirements as an alternative to ASME N-Stamp certification. The licensed and operating portion of the HNP, including spent fuel pools A and B and the Unit 1 SFPCCS, was subject to the Harris ASME Code QA Program during construction and has been subject to the CP&L Corporate QA Program during operations. BCOB has not challenged the HNP ASME Code QA Program in effect at the time of construction.²⁰² BCOB does not dispute the efficacy of the present CP&L Corporate QA Program. BCOB does not argue that once

Footnote continued from previous page

away from that commitment in connection with the commissioning of the SFPCCS for spent fuel pools C and D.

²⁰² The only facts presented by BCOB which border on an attack of the HNP Quality Assurance Program are the presentation of four NRC inspections reports from 1981 in the "Declaration of David A. Lochbaum, Nuclear Safety Engineer, Union Of Concerned Scientists, Concerning Technical Issues And Safety Matters Involved In The Harris Nuclear Plant License Amendment For Spent Fuel Storage," dated March 31, 1999, which found minor deficiencies in construction quality control. When questioned during his deposition: "Do you have an opinion on the quality of the QA organization and its effectiveness during the construction at the Shearon Harris plant?" Mr. Lochbaum replied: "You know, in my declaration, there were some inspection reports cited noting some problems of quality assurance, but I wouldn't - that wouldn't lead me to believe that

Footnote continued on next page

the SFPCCS is placed in service, CP&L will be unable to successfully meet the requirements of the CP&L Corporate QA Program and 10 C.F.R. Part 50, Appendix B, including Criteria XIII, XVI, and XVII. CP&L has described in detail the Supplemental QA Requirements that have been imposed on the completion of construction and commissioning of the SFPCCS for spent fuel pools C and D.²⁰³ BCOC has not found fault with the Supplemental QA Requirements.

BCOC's "dispute" regarding the efficacy of the 50.55a Alternative Plan in addressing the missing documentation has never been articulated without reference to concerns regarding subsequent deterioration of the SFPCCS piping between construction and today. The best Mr. Lochbaum could articulate during his deposition was the following:

For the embedded welds, we have an issue that the original quality assurance requirements are not met. The alternative plan is the alternative to meeting the code, and we contend that that's not an adequate – an equal replacement.²⁰⁴

In addition, BCOC's response to a very specific interrogatory does not find specific fault with the 50.55a Alternative Plan:

INTERROGATORY NO. 3-4. Describe in detail why BCOC contends CP&L's Alternative Plan submitted

Footnote continued from previous page

the quality assurance program at Shearon Harris was deficient or had a programmatic breakdown." Lochbaum Dep. Tr. (Exhibit 10 at 129-130).

²⁰³ See Edwards Affidavit (Exhibit 1, ¶¶ 27-29, Attachment B, Enclosure 17).

²⁰⁴ Lochbaum Dep. Tr. (Exhibit 10 at 89).

pursuant to 10 C.F.R. §50.55a does not “provide an acceptable level of quality and safety?”

RESPONSE TO INTERROGATORY NO. 3-4: The aggregate of the responses to these interrogatories, along with the responses to the questions during the deposition of Orange County’s expert witness David Lochbaum on October 14, 1999, describe in detail why Orange County contends that CP&L’s Alternative Plan is deficient. Orange County points out that since this contention was filed, CP&L has taken actions which implicitly demonstrate CP&L’s concurrence, such as locating previously missing weld data records, expanding the scope of remote video examination of embedded welds to include all 15 welds, and analyzing the chemistry of the water in the Unit 2 spent fuel cooling system piping.

The “aggregate of the responses” to the other interrogatories is no more illuminating.²⁰⁵

The acceptability of the embedded welds in 1983, when Harris 2 was canceled and construction of the SFPCCS for spent fuel pools C and D was abandoned, has been demonstrated by the implementation of a “Piping Pedigree Plan.” This Plan is part of the 50.55a Alternative Plan to address the missing weld data reports and includes an exhaustive review of available QA documentation, additional inspections, and interviews with personnel who were involved in installation and quality inspections of the embedded SFPCCS piping and welds. Overwhelming evidence is available to provide reasonable assurance that the field welding of the SFPCCS piping was performed pursuant to the ASME Code approved welding procedures and the welds were inspected and tested to ensure that the welds met Code requirements pursuant to the ASME Code QA Program. The results of these reviews, inspections, and interviews are described in considerable

detail in the Edwards Affidavit (Exhibit 1, ¶¶ 30-32), Shockley Affidavit (Exhibit 6, ¶¶ 4-16), Gilbert Affidavit (Exhibit 7, ¶¶ 4-14), and Griffin Affidavit (Exhibit 5, ¶¶ 4-11). Shockley, Gilbert, and Griffin all speak to the quality of the welding of the SFPCCS piping and the QA inspections from first-hand knowledge. They provide direct sworn statements of the existence of the missing QA documentation at the time of construction.

Stripped to its essence, Contention 3 is not about “inadequate quality assurance.” Rather, BCOC’s discussion surrounding Contention 3 and the Lochbaum Declaration address what they perceive to be deficiencies in the Equipment Commissioning Plan (which is incorporated in the Supplemental QA Requirements). Specifically, BCOC faults the 50.55a Alternative Plan for (1) “failing to describe a program for identifying and remediating potential corrosion and fouling;” (2) attempting to demonstrate weld quality by use of a remote camera; and (3) in any event, not even looking at all of the embedded welds.

We address in the next section each alleged deficiency in CP&L’s Equipment Commissioning Plan in inspecting for any corrosion or other degradation that might have occurred between the time of construction and today. In the remainder of this section, we list material facts, which are not in dispute and which demonstrate that the SFPCCS embedded piping and 15 field welds were installed in accordance with the ASME Code approved welding procedures, NDE examinations, hydrostatic testing, and ASME Code

Footnote continued from previous page

²⁰⁵ See BCOC’s Interrogatory Responses, 3-1 through 3-7.

QA inspections. We rely on these facts to demonstrate reasonable assurance of an “acceptable level of quality and safety” for the SFPCCS embedded piping and field welds, as constructed.²⁰⁶

1. The SFPCCS for spent fuel pools C and D was constructed to the same exacting standards pursuant to the same ASME Code QA Program as was the SFPCCS for spent fuel pools A and B and the rest of Harris Plant.²⁰⁷
2. The installation of piping, welding and concrete placement was accomplished at all four spent fuel pools more or less contemporaneously, using the same pool of construction personnel, welders, supervisors, engineers, and QA inspectors, and ANI inspectors.²⁰⁸
3. Harris Nuclear Plant has operated the SFPCCS for spent fuel pools A and B successfully since startup.²⁰⁹

²⁰⁶ While this test from 10 C.F.R. §50.55a(a)(3)(i) is easily met in this case, CP&L actually need not show more than that required by the alternate test: “compliance with the specified requirements of this section would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety.” 10 C.F.R. § 50.55a(a)(3)(ii); see Edwards Affidavit (Exhibit 1, ¶ 50) regarding the hardship that would be presented by the failure to approve the 50.55a Alternative Plan.

²⁰⁷ See Edwards Affidavit (Exhibit 1, ¶ 31), Shockley Affidavit (Exhibit 6) and CP&L’s ASME Code QA Manual (Attachment A to Exhibit 6).

²⁰⁸ See Edwards Affidavit (Exhibit 1, ¶ 31); Griffin Affidavit (Exhibit 5, ¶ 8); Shockley Affidavit (Exhibit 6, ¶ 15).

²⁰⁹ See Edwards Affidavit (Exhibit 1, ¶ 31).

4. Documentation for field welds joining pipe spools in the SFPCCS was contained on WDRs, which provided a record of all ASME Code required attributes pertinent to a given weld. Data such as joint and piece identification, filler material identification, weld procedure, welder identification and NDE requirements were all specified and documented on the WDR, and generally the WDR constituted the only permanent documentation for this information. Construction procedures required each WDR to be prepared by weld engineering personnel as part of work package preparation, and to be reviewed by both QA inspectors and the ANI prior to its release to the field. Subsequent to weld performance, each completed WDR would be reviewed again by QA inspectors and the ANI to verify that all requirements were met. WDRs were collected as part of piping isometric packages, which were compiled and stored pending system completion for N-Stamp review.²¹⁰
5. Failure to complete the WDRs for the field welds in the embedded piping would have required a complete breakdown of the welding procedures and processes and the QA procedures and processes. As attested to directly by Charles Griffin, David Shockley, and Tommy Gilbert, there was no such

²¹⁰ Id.; Griffin Affidavit (Exhibit 5, ¶¶ 5-6).

breakdown of the ASME Code welding program nor of the ASME Code QA Program at the Harris Plant.²¹¹

6. Available construction era information conclusively supports that the WDRs for the 15 field welds in the SFPCCS did exist at the time of construction and were satisfactorily completed. The most direct QA documentation pertaining to this conclusion is found in the hydrostatic test (“hydrotest”) records for embedded spent fuel pool piping. Procedural requirements for conducting the hydrotest included a review by QA inspectors of all weld documentation associated with the piping being tested. Accordingly, the QA inspector performed a review of the WDR for each field weld within the test boundary, verifying that each WDR was completed, reviewed and approved, including the ANI’s review. In addition, the hydrotest procedure required that each field weld be individually inspected for leakage while at test pressure, providing additional assurance as to the completion and quality of these welds. Hydrotest records are on hand for 13 of the 15 embedded field welds, and

²¹¹ See Griffin Affidavit (Exhibit 5, ¶ 8); Shockley Affidavit (Exhibit 6, ¶ 15); Gilbert Affidavit (Exhibit 7, ¶ 14).

additional QC documents indirectly confirm that the remaining two field welds were also hydrotested.²¹²

7. Several of the QA inspectors actually performing document reviews and hydrotest inspections associated with embedded SFPPCS piping are still employed by CP&L. Two such individuals readily attest that, to the extent indicated by their signature on the hydrotest records, they positively and personally confirm that the WDRs for eleven of the field welds within the test boundary did exist and were satisfactorily completed, and that each such weld was closely inspected as part of the hydrotest effort. They are also confident that the WDRs for the other four welds also were properly prepared and reviewed prior to the hydrotest.²¹³
8. Concrete Placement Reports (commonly referred to as Concrete Pour Cards) have been retrieved for spent fuel pools C and D and those sections of the Fuel Handling Building that includes the embedded SFPPCS piping. As part of the QA review prior to a concrete pour, the QA inspector confirmed that all required QA documentation for piping that would be embedded in concrete was in the QA package and was complete

²¹² See Edwards Affidavit (Exhibit 1, ¶ 31, Attachments S and T); Shockley Affidavit (Exhibit 6, ¶¶ 10-15, Attachments B, C, D and E); Gilbert Affidavit (Exhibit 7, ¶¶ 6-10, Attachments B, C and D).

²¹³ See Shockley Affidavit (Exhibit 6 at ¶¶ 15-16); Gilbert Affidavit (Exhibit 7 at ¶ 10); Edwards Affidavit (Exhibit 1, ¶ 32).

– including vendor records for the piping spools, WDRs for the field welds, NDE records and hydrotest reports. The signatures by the QA inspectors on the Concrete Pour Cards verifies that QA documentation for the SFPCCS piping and field welds, including the missing WDRs, was reviewed and verified for completeness again prior to pouring concrete.²¹⁴

9. A copy of a WDR was found for one of the 15 embedded field welds.²¹⁵ A Repair Weld Data Report was located for another one of the 15 embedded field welds.²¹⁶ The Repair WDR is one indication that the ASME Code QA Program was being implemented properly: deficiencies were identified and corrected to ensure compliance with the Program.
10. The NRC Staff performed a formal special team inspection at the HNP on November 15-19, 1999. The purpose of the inspection, in part, was “to assess the implementation of the construction quality assurance program in construction of the C and D spent fuel pools.” The NRC Staff concluded that CP&L “had a comprehensive program to control, inspect, and document welding at the time of original [plant] construction in accordance with Section III of the ASME Boiler and Pressure Vessel

²¹⁴ See Gilbert Affidavit (Exhibit 7, ¶¶ 11-13, Attachment E); Shockley Affidavit (Exhibit 6, ¶ 9).

²¹⁵ See Griffin Affidavit (Exhibit 5, ¶ 5, Attachment B).

²¹⁶ Id. at ¶ 5, Attachment C.

Code, and NRC requirements.”²¹⁷ Thus, the NRC inspection confirmed CP&L’s own review. The NRC inspectors reviewed NRC Inspection Reports which documented inspection of construction activities at HNP by NRC Region II inspectors between 1978 and 1983. These inspection reports document over 50 separate inspections for this period for items related to the welding program and/or piping installation. The minor violations noted would not be cited under the current NRC reactor inspection program and were typical of what would be expected for oversight of a large construction project.²¹⁸ This review of construction-era inspection reports again confirms the overall quality of the Harris construction ASME Code welding program.

These undisputed facts provide verification that WDRs did exist for each of the embedded field welds, that each WDR was fully completed, reviewed and accepted, and therefore, that these field welds were completed in full compliance with ASME Code construction requirements. The 50.55a Alternative Plan demonstrates that, as constructed, the SFPCCS for spent fuel pools C and D met ASME Code requirements, and, therefore, absent significant deterioration of the SFPCCS since construction, provides an acceptable level of quality and safety.

²¹⁷ NRC Inspection Report No. 50-400/99-12, dated December 28, 1999 (Exhibit 14 at 2).

²¹⁸ Id. at 26.

In the next section, we address the implementation of the Equipment Commissioning Plan, which included inspections and testing to determine the extent, if any, of deterioration of the SFPPCS since construction.

C. Summary of Facts, Data and Arguments which Demonstrate that the SFPPCS Stainless Steel Piping and Welds Have Not Significantly Deteriorated Due to Corrosion or Otherwise During the Period of Time Between Original Construction and Today, Are Suitable for Their Intended Purpose, and Provide an Adequate Level of Quality and Safety

BCOC disputes that the Equipment Commissioning Plan is sufficient to determine the condition of the embedded SFPPCS piping. In response to the interrogatory question -- Does the Equipment Commissioning Plan adequately address BCOC's concerns relating to the failure to store and preserve all the equipment and components of the Spent Fuel Cooling System pursuant to the requirements of 10 C.F.R. Part 50, Appendix B? -- BCOC responded as follows:

No. The Equipment Commissioning Plan fails to provide for inspection of all the equipment and components of the Unit 2 spent fuel cooling system. For example, the original Equipment Commissioning Plan relied on a remote camera inspection of the interior portions for some of the welds in the embedded piping. Orange County's expert witness will be reviewing recent CP&L changes to the original plan which now suggest that all embedded field welds have been inspected. As another example, Orange County contends, as detailed in the responses to Interrogatory Nos. 3-2 all parts, 3-3 all parts, and 3-7 all parts that the remote camera inspection and associated activities did not adequately

determine the interior surface of the embedded piping to be absent of material degradation.²¹⁹

Contention 3, as admitted, objected to the remote camera inspection and the original plan to inspect fewer than all 15 embedded field welds. In response to interrogatories, BCOC also alleged (1) that the remote camera inspection viewed only the field welds and not the piping; (2) CP&L failed to analyze the surface film observed on the inside of the piping and welds; and (3) an inspection, engineering evaluation, or analysis should have been performed regarding the potential for contaminants to affect the external surface of the embedded piping.²²⁰ BCOC contends that an inspection effort, providing more meaningful results than simple remote camera inspection, would include ultrasonic evaluations or other non-destructive examination techniques.²²¹

There are no genuine issues in dispute regarding inspection and testing of equipment and components of the SFPCCS for spent fuel pools C and D, other than the embedded piping and welds. Mr. Lochbaum conceded as much. BCOC has not raised

²¹⁹ BCOC Response to Interrogatories, Interrogatory No. 3-1.

²²⁰ *Id.*, Interrogatory No. 3-2.

²²¹ *Id.*, Interrogatory No. 3-3. On the other hand, BCOC's sole expert on Contention 3, David Lochbaum, stated in his deposition that his concerns would be satisfied by "a complete visual inspection of the interior piping surfaces, all of the welds of the embedded portions, and some evaluation, analysis or inspection of the exterior piping surfaces." Lochbaum Dep. Tr. (Exhibit 10 at 218-219). When pressed on what an "evaluation, analysis or inspection of the exterior piping surfaces" could entail (since the piping is embedded in concrete), Mr. Lochbaum stated "some walkdown of, was there any history of spills or anything that would have gotten into the concrete or around where these pipes came through walls that could have been an external contaminant, an inspection of where it went into the pipe, into the walls and out of, things like that, that

Footnote continued on next page

one specific concern regarding the accessible piping and welds (that have been re-inspected) or other components, such as the heat exchangers, pumps, strainers or skimmers.²²²

The final allegation of Contention 3, as admitted, is moot. BCOC complained that not all of the 15 embedded welds would be inspected by remote camera. CP&L modified its Equipment Commissioning Plan and inspected all 15 embedded welds.²²³

With respect to the remaining concerns raised by BCOC regarding the inspection and testing of the embedded piping, the material facts set forth in the remainder of this section are not in dispute and demonstrate that the condition of the embedded piping and welds are very good. An analysis of each of the indications observed during the remote camera inspection, chemical and microbiological analyses of the water inside the SFPCCS piping, an analysis of the reddish-brown deposit observed on the piping and weld surfaces, an analysis of the structural integrity of the piping, and an analysis of the suitability of the "as is" embedded piping to perform its intended function all confirm that the embedded piping will provide an adequate level of quality and safety and there is

Footnote continued from previous page

would have given me some basis for saying that there was not, or no apparent indications of an external contaminant source." *Id.* at 219-220.

²²² See Section V.A. *supra*; Lochbaum Dep. Tr. (Exhibit 10 at 83-87).

²²³ Edwards Affidavit (Exhibit 1, ¶¶ 36-37, 44-46, Attachment Q). CP&L inspected all fifteen of the embedded welds and associated piping by remote camera and even pressure washed and re-inspected a field weld with observed reddish-brown deposits in order to be in a position to answer every question pertaining to the suitability of the SFPCCS piping for its intended purpose.

reasonable assurance that public health and safety, and the environment will be protected with the operation of spent fuel pools C and D with the SFPCCS.

The implementation of the Equipment Commissioning Plan and the results of the tests and inspections are described in the Edwards Affidavit (Exhibit 1, ¶¶ 33-48 and Attachments B, E, Q, and R); Moccari Affidavit (Exhibit 8 and Attachments B and C); Griffin Affidavit (Exhibit 5, ¶¶ 9-10); and Licina Affidavit (Exhibit 9 and Attachment C). Applicants rely on the sworn facts set forth in these affidavits, including the following material facts that are not in dispute:

1. An Equipment Commissioning Plan was developed as part of the “Supplemental Quality Assurance Requirements for the Design Change Packages Associated with the Completion of the Units 2 & 3 Spent Fuel Pool Cooling System.”²²⁴ The Equipment Commissioning Plan prescribes a set of criteria to ensure that the components and equipment in the SFPCCS will meet the requirements of Appendix B to 10 C.F.R. Part 50 and is capable of performing their intended function in the completed design. The Equipment Commissioning Plan includes physical inspections and testing to verify that the lack of controlled storage conditions and regular maintenance has not caused any condition affecting quality, including damage from personnel, introduction of foreign

²²⁴ Edwards Affidavit (Exhibit 1, Attachment B, Enclosure 16, § 5.2).

material, scavenging of parts, corrosion, fouling, aging, or radiation exposure.²²⁵

2. The tests and inspections included testing of the water in the SFPCCS piping, a complete walk-down and visual inspection of all accessible piping, welds, components and equipment, re-inspection of all accessible welds, testing the weld filler material in the accessible welds, a visual inspection with a high-quality video camera of the segments of the embedded SFPCCS piping with field welds, and taking a sample and testing the composition of a deposit on one of the welds.²²⁶ In addition, records were reviewed and the surface of the spent fuel pool walls and concrete in which the SFPCCS piping is embedded was inspected for any evidence of outside chemical attack to the external surface of the embedded piping.²²⁷
3. The water, which has been in the SFPCCS piping under extended lay-up conditions, was subject to chemical analysis by HNP Chemists and microbiological analysis by Dr. Ahmad Moccari, a scientist specializing in corrosion studies and working for CP&L at its metallurgical laboratories. The chemical analysis revealed that the water in these lines was of high

²²⁵ See Edwards Affidavit (Exhibit 1, ¶ 33).

²²⁶ See Edwards Affidavit (Exhibit 1, ¶ 34).

²²⁷ Id. at 47.

purity (consistent with that in the spent fuel pools themselves). Nuisance bacteria capable of causing microbiologically induced corrosion ("MIC") were not detected. In general, there were low levels of microbiological activity in the water samples for the SFPCCS piping. The results of this testing indicates a highly unlikely potential for chemically or microbiologically induced corrosion to have occurred during extended lay-up.²²⁸

4. All of the fifteen embedded field welds and associated SFPCCS piping runs were inspected using a high-resolution camera fitted to a pipe crawler. The inspection included welds on six of the eight embedded cooling lines connected to spent fuel pools C and D. The remaining two lines have only approximately 6 feet of embedded pipe each, with no embedded field welds. All of the lines inspected were 12" diameter, type 304 stainless steel piping.²²⁹
5. The video camera was able to take high quality pictures of everything on the inside of the SFPCCS piping – longitudinal welds, circumferential welds, and the piping's inside surfaces. The camera work was very professional. The light clearly illuminated the surfaces examined. Areas

²²⁸ See Moccari Affidavit (Exhibit 8, ¶¶ 7-10, 22, Attachments B and C); Edwards Affidavit (Exhibit 1, ¶ 35, Attachment Q, §§ 3.4.3.1 - 3.4.3.2).

²²⁹ See Edwards Affidavit (Exhibit 1, ¶ 36).

of interest were inspected from a number of different angles as the camera moved back and forth over the same surface. The videotapes emphasized the welds in the embedded sections of the piping, both longitudinal (from the original fabrication of the piping) and circumferential (where lengths of piping are connected), but the videotapes also showed the interior surface between circumferential welds as the camera moved through the piping. The images were very clear. Reviewers could even see machine marks left from the time the pipe was manufactured.²³⁰

6. A team of experts from various disciplines reviewed the videotapes from the remote camera inspections. Generally, the inspection results were very good. The welds in question were never subject to volumetric examination by Code requirements, and were sufficiently far from the open end of the pipe at the time of welding that an internal visual examination would not have been performed. Some general discoloration of the welds and portions of the internal surfaces of piping was noted, reddish-brown deposits were observed on welds and the piping, incomplete melting of consumable inserts was noted on two welds, and shallow linear indications were observed on a weld and on the longitudinal

²³⁰ See Moccari Affidavit (Exhibit 8, ¶ 11); Edwards Affidavit (Exhibit 1, ¶ 44).

seam of one of the adjacent pipe spools. Each indication was recorded and evaluated.²³¹

7. Inspection of field weld FW-517 found three locations having a localized deposit of reddish-brown material at the field weld. Samples of this material were removed by fitting the head of the inspection camera with an arm and swab, and using pan and tilt manipulations to collect material directly from the locations of interest. Any remaining deposits were removed with high-pressure water and the surface was re-inspected with the remote camera.²³² After a careful review of the area underneath the deposits, Dr. Moccari could not conclusively identify any surface discontinuities.²³³ Mr. Licina identified what “appeared to be two small pits” underneath the deposits.²³⁴ Both Dr. Moccari and Mr. Licina agreed any such small pits could have no impact on the integrity of the piping.²³⁵
8. Dr. Moccari tested the sample of the reddish-brown deposit to determine whether any bacteria present were aggressive enough to cause MIC.

Three separate tests confirmed that no bacteria capable of causing material

²³¹ See Edwards Affidavit (Exhibit 1, ¶¶ 36-44, Attachment Q); Moccari Affidavit (Exhibit 8, ¶¶ 11-12, 17-22); Licina Affidavit (Exhibit 9, ¶¶ 12, 15, 21-22, 25, 28, Attachment C).

²³² See Edwards Affidavit (Exhibit 1, ¶ 38); Moccari Affidavit (Exhibit 8, ¶ 12).

²³³ Moccari Affidavit (Exhibit 8, ¶ 17, Attachment C at 5).

²³⁴ Licina Affidavit (Exhibit 9, ¶ 21).

degradation due to MIC were present in the deposit sample from the SFPCCS piping weld.²³⁶ An elemental analysis of the deposit material was performed using a scanning electron microscope. This analysis determined that the deposit material is primarily composed of iron oxide. This material is very similar in appearance to the iron oxide which is introduced to the spent fuel pools by way of spent fuel transshipment from CP&L's other nuclear plants. This iron oxide neither results from, contributes to, or is otherwise associated with corrosion or degradation in the SFPCCS piping.²³⁷

9. Some of the reddish-brown film observed on the piping was removed by high-pressure water and the filtered residue was analyzed by Dr. Moccari. Dr. Moccari used a scanning electron microscope with an energy dispersive x-ray spectrometer attachment to determine the elemental composition of the reddish-brown material from the SFPCCS piping. A x-ray diffractometer was then used to identify the chemical compounds present. The scanning electron microscope/energy dispersive spectrometer showed that the reddish-brown material consists primarily of

Footnote continued from previous page

²³⁵ *Id.* at ¶¶ 22-23; Moccari Affidavit (Exhibit 8, ¶ 22).

²³⁶ Moccari Affidavit (Exhibit 8, ¶¶ 12-15).

²³⁷ See Edwards Affidavit (Exhibit 1, ¶ 38, Attachment Q, Attachment 3); Moccari Affidavit (Exhibit 8, ¶ 16).

iron and oxygen (most likely iron oxide) with lesser and varying amounts of silicon, aluminum, carbon, calcium, chromium, nickel, sodium, magnesium, nickel, potassium, zinc, and chlorine. X-ray diffraction analysis of the deposit sample showed this sample to consist primarily of iron oxide (a mixture of hematite ($\alpha\text{-Fe}_2\text{O}_3$) and lepidocrocite (FeOOH)) and possibly graphite. Apart from the iron oxides, however, the deposits appear to be largely particulate in structure, including small fragments of what appears to be stainless steel. The presence of these particulates and small metallic fragments suggests that the deposits do not reflect corrosion of the piping at the welds. Rather, the weld itself appears to have acted as a site at which crud has simply accumulated.²³⁸

10. The typical field weld joint of the SFPCCS piping incorporated a consumable insert, with the ends of the pipe spools being prepped at the vendor facility for use with this configuration. The purpose of a welding consumable insert is to serve as a consumable retainer and filler metal during completion of a weld joint root pass (first welding pass). By design, the root pass of the weld would consume the insert while fusing both ends of the pipe together. A number of welds had locations where small portions of the insert could be discerned, indicating that it was not fully consumed by the root pass. Generally, these incidences of

²³⁸ See Moccari Affidavit (Exhibit 8, ¶ 16).

unconsumed insert were limited to several very small areas where a small portion of the insert could be discerned. Notably, to the extent that could be discerned by closely reviewing multiple camera angles, inspection of these areas of unconsumed insert indicates that these pieces of insert material are completely fused around the edges.²³⁹

11. Unconsumed inserts are typically the result of welder technique with this particular condition limited to the weld root pass. It is not an unusual condition. Unlike some welding flaws, such as hot cracking and piping porosity, which could possibly extend into subsequent weld layers, once the root pass is completed, subsequent weld passes are unaffected by an unconsumed insert condition. Unconsumed insert materials could typically be detected by visual observation of the pipe inside diameter surface (if accessible) or by conducting volumetric NDE examinations like radiography. However, consistent with ASME Code requirements, the final inspection requirements for these ASME Code Class 3 SFPCCS weld joints were a final visual exam and a liquid/dye penetrant examination of the weld joint outside diameter surface. Therefore the final inspections and NDE for these weld joints would not have detected indications such as these regions of unconsumed insert in the root pass, unless the weld inside

²³⁹ See Edwards Affidavit (Exhibit 1, ¶ 39); Griffin Affidavit (Exhibit 5, ¶ 9); Licina Affidavit (Exhibit 9, ¶¶ 12-13).

diameter surface had been accessible for local visual observation during plant construction.²⁴⁰

12. The indications of unconsumed weld insert identified by camera inspection of the embedded field welds were evaluated and determined not to represent a challenge to piping integrity or otherwise affect its suitability for the intended service. The indications were determined to be relatively insignificant imperfections which are to some degree expected on field welds such as FW-516, which was only subject to surface examination and does not lend itself to internal visual examination. ASME Section III, Subsection ND design rules for vessels specifically recognize the potential for imperfections in welds which are not subject to volumetric examination, and provide compensation when necessary by a reduction in joint efficiency based on the type and extent of NDE performed. Although this consideration regarding joint efficiency does not directly apply to the embedded SFPCS piping, it does demonstrate that the ASME acknowledges that minor imperfections will exist in welds of this nature which are not subject to volumetric examination. Based on these considerations and the additional discussion in the Report of Structural Integrity Associates, Inc., pertaining to structural integrity, the

²⁴⁰ See Edwards Affidavit (Exhibit 1, ¶ 40); Griffin Affidavit (Exhibit 5, ¶ 9).

indications of incomplete fusion identified on these embedded field welds were deemed acceptable with no rework / repair.²⁴¹

13. A small linear indication (approximately ½" long) was observed extending out of the seam weld on the pipe spool above field weld FW-515 and into the counter-bored region adjacent to this weld. This indication did not appear to originate in the field weld itself, nor did it have the appearance of being corrosion related. The corrosion mechanisms which could possibly cause cracking in the Type 304 Stainless Steel spent fuel pool cooling lines are very unlikely due to a lack of the aggressive conditions (chemistry and temperature) which might initiate them. Further, the line is not exposed to cyclical loading or thermal variations, which might induce fatigue cracking. Edwards Affidavit (Exhibit 1, ¶ 42, Attachment Q, § 3.4.4); Licina Affidavit (Exhibit 9, ¶¶ 25-26, Attachment C at 5-6 – 5-7).
14. At this point, the specific cause for the linear indication in the seam weld adjacent to field weld FW-515 cannot be conclusively determined. What can be said is that an external visual and liquid penetrant examination was completed of this field weld after its construction, and that the indication of interest would have been identified if it extended to the exterior surface

²⁴¹ See Edwards Affidavit (Exhibit 1, ¶ 41, Attachment Q, §3.4.2 and attachment 2); Griffin Affidavit (Exhibit 5, ¶ 10); Licina Affidavit (Exhibit 9, ¶ 13, Attachment C at 5-1
Footnote continued on next page

of the piping. Subsequently, this field weld was subjected to and successfully completed hydrostatic testing and additional close visual inspection prior to the concrete pour. These examinations and tests provide conclusive evidence that the indication is not a through-wall crack and will not result in leakage. Structural Integrity Associates was asked to provide an expert independent evaluation of the implications of the indication on the structural integrity of the piping. Their conclusion, based on critical flaw size analysis and consideration of the potential mechanisms for crack propagation, is that the indication does not pose any challenge to piping integrity, nor is there any reason to suspect that the indication might propagate beyond its existing condition.²⁴²

15. The overall good condition of the piping is not surprising because it is constructed of high-quality stainless steel, that is otherwise resistant to corrosion and cracking, and it has been maintained in a wet lay-up condition that is very benign. It has not been subject to extreme temperatures, pressure or other stresses. It would have been quite surprising to observe any degradation in the SFPCS piping under these conditions. Structural Integrity Associates ("SIA") evaluated all of the

Footnote continued from previous page

– 5-4).

²⁴² Edwards Affidavit (Exhibit 1, ¶ 43, Attachment Q, § 3.44); Licina Affidavit (Exhibit 9, ¶¶ 25-26, Attachment C at 5-3 – 5-4).

possible causes of degradation in stainless steel piping and found that the conditions necessary for the degradation of such piping were absent from the conditions in the SFPCCS piping. Structural Integrity Associates also noted that the SFPCCS piping was very conservatively designed for its intended operating conditions. The 0.375 inch wall thickness is approximately 30 times the minimum wall thickness required for the actual service pressure; the stainless steel piping has a design rating of 150 psi and will have a maximum service pressure of about 25 psi.²⁴³

16. A significant portion of the SFPCCS piping which connects to the spent fuel pools C and D is accessible, and subject to the same flooded conditions as the embedded piping. Importantly, these accessible portions are also the low points in this piping, and would be where any corrosion problems would be expected to evidence themselves. Since there has been no leakage or degradation identified with regard to this accessible SFPCCS piping, there was no reason to suspect degradation of the embedded SFPCCS piping.²⁴⁴
17. The remote camera inspections show that the SFPCCS piping and welds embedded in concrete are in very good condition, show negligible degradation during the 17 years since construction (approximately 10 of

²⁴³ Edwards Affidavit (Exhibit 1, ¶ 45); Licina Affidavit (Exhibit 9, ¶¶ 9, 17 - 20).

²⁴⁴ Edwards Affidavit (Exhibit 1, ¶ 46).

which were in essentially wet lay-up), and have no credible source of contamination that could adversely affect the outside of the SFPCCS piping embedded in concrete. Furthermore, Structural Integrity Associates found that even if some corrosion or imperfections in welds or cracks in the piping did exist, it would have no effect on the structural integrity of the SFPCCS or on its suitability for service.²⁴⁵

18. Even in the highly improbable event that a weld were to fail or a pinhole leak occurred in the embedded SFPCCS piping, there would be no impact on public health or safety, the environment, or plant operations. The piping is embedded in reinforced concrete; there is no way for a leak to result in a loss of water that even approaches the normal evaporation rate of the pools; there is no leak pathway to the environment; and there is an entirely redundant piping run to provide cooling to each spent fuel pool.²⁴⁶ In the worst case failure of a SFPCCS piping weld (the failure of a weld in the accessible piping outside the concrete), the level in the spent fuel pools cannot fall below the suction and discharge openings in the pools. Thus the spent fuel would remain covered with water.²⁴⁷

²⁴⁵ Edwards Affidavit (Exhibit 1, ¶ 48, Attachment Q, attachment 2): Licina Affidavit (Exhibit 9, ¶ 28, Attachment C at 6-2 - 6-3).

²⁴⁶ Edwards Affidavit (Exhibit 1, ¶ 49).

²⁴⁷ Id.

The implementation of the Equipment Commissioning Plan with regard to the embedded SFPCCS piping has been thorough and provides reasonable assurance that no degradation has occurred to this piping that would affect its structural integrity or render it unsuitable for the intended function. CP&L has demonstrated that the SFPCCS provides an acceptable level of quality and safety in the commissioning of spent fuel pools C and D.

D. Intervenor BCOC Cannot Meet its Burden of Demonstrating an Adjudicatory Hearing Must Be Held to Dispose of Contention 3

The facts and data submitted to the Board on Contention 3 are comprehensive and permit a well-reasoned and supported decision by the Board on the present condition of the embedded SFPCCS piping.

While there may be a genuine issue in dispute regarding the appropriateness of the remote camera inspection, it is not a substantial dispute. Indeed, CP&L has done exactly what BCOC's sole expert on Contention 3 said would be acceptable: "a complete visual inspection of all of the interior piping surfaces, all of the welds of the embedded portions, and some evaluation, analysis or inspection of the exterior piping surfaces."²⁴⁸

A hearing would be particularly inappropriate here because there is no suggestion that BCOC could offer credible testimony adverse to the sworn statements of fact and expert opinions set forth in the affidavits upon which CP&L relies on Contention 3. Mr. Lochbaum was forthright in disclaiming expertise in the disciplines relevant to the

condition of the SFPCCS piping and welds. Mr. Lochbaum admits to no experience as a construction engineer.²⁴⁹ He has never had any responsibility for welding at a nuclear power plant.²⁵⁰ He has never welded materials himself, never had responsibility as a welding engineer, and never performed NDE of welds or supervised NDE examiners.²⁵¹ Mr. Lochbaum has not served on ASME Code committees nor has he been responsible for QA/QC inspectors at a nuclear plant.²⁵² He admitted that he was not an expert in material science, nor an expert in corrosion of materials at a nuclear power plant, nor an expert in stress analysis.²⁵³ Mr. Lochbaum is not a expert in the causes of degradation of stainless steels, nor was he familiar with the kind of stainless steel, its diameter, and thickness of the SFPCCS piping.²⁵⁴ He was not familiar with the weld process used for the SFPCCS field welds.²⁵⁵ Mr. Lochbaum had not initially requested copies of the videotapes of the remote camera inspections of the SFPCCS piping and welds because he

Footnote continued from previous page

²⁴⁸ Lochbaum Dep. Tr. (Exhibit 10 at 218-219).

²⁴⁹ Id. at 38.

²⁵⁰ Id.

²⁵¹ Id. at 40-41.

²⁵² Id. at 41.

²⁵³ Id.

²⁵⁴ Id. at 43.

²⁵⁵ Id. at 44.

was not in a position to testify whether the condition of the piping and welds “was good, bad or indifferent.”²⁵⁶

Notwithstanding BCOC’s allegations to the contrary, both the embedded piping and welds were inspected by the remote camera, the reddish-brown deposit on the piping and weld surfaces was analyzed and an analysis was performed regarding the potential for contaminants to affect the external surface of the embedded piping.

The facts and opinions of CP&L’s affiants have been tested by the NRC Staff inspectors and the results of the NRC’s independent review of documents and interviews are reported in a detailed inspection report.²⁵⁷ The NRC Staff’s independent review corroborates the facts presented by CP&L. The Board can readily decide this issue on the basis of the facts, data, and expert opinions before it.

Importantly here, the resolution of the factual issue regarding the condition of the SFPCCS piping is not central to the ultimate decision on the license amendment request. There is no credible scenario, even assuming a complete failure of a weld in the embedded piping, that significant water covering the spent fuel could be lost from the pool. The suction and discharge openings of the SFPCCS into the spent fuel pool are near the top of the pool. The spent fuel would remain covered under any scenario. Also, there is a redundant piping line for each spent fuel pool, thus the cooling function to the

²⁵⁶ Id. at 111.

²⁵⁷ See NRC Inspection Report No. 50-400/99-12 (Exhibit 14).

spent fuel pool would not be lost.²⁵⁸ A failure of a weld in the embedded SFPCS piping might at worst cause a minor cleanup issue for CP&L. It could in no way be inimical to the common defense and security, or to the health and safety of the public, or have a significant impact on the environment.

Under the circumstances, BCOC has an insurmountable burden to demonstrate a hearing is necessary.

VI. ACTIONS REQUESTED OF THE BOARD

Applicant CP&L respectfully submits that, at the conclusion of oral argument, the Board should:

1. Decide Contention 2, Basis 1, based on the written legal arguments and oral arguments. The NRC Staff's interpretation of GDC 62 and administrative controls, including burnup credit, should be sustained.
2. Dismiss Contention 2, Basis 2, as moot. BCOC has admitted that the Harris Criticality Analysis demonstrates that a single fuel assembly misplacement will not cause criticality in the fuel racks in spent fuel pools C or D. The new issues raised by BCOC should be rejected as outside the scope of Contention 2 as admitted. In any event the criticality analyses performed by Dr. Redmond, Dr. Turner and by the NRC Staff demonstrate

²⁵⁸ See Edwards Affidavit (Exhibit 1, ¶ 49).

that the new issues are moot as well. BCOC has admitted that it is not in a position to challenge the results of criticality analyses.

3. Dismiss Contention 3, as it relates to the "as constructed" condition of the SFPCCS piping for spent fuel pools C and D. BCOC has not to date offered one specific challenge to the efficacy of the ASME approved welding procedures and ASME Code QA program which governed the installation of the SFPCCS piping. There is no credible rejoinder to the abundant direct and indirect evidence that the missing WDRs were prepared and they document that the SFPCCS piping field welds were properly performed, inspected, passed NDE, passed hydrotest, and met ASME Code requirements.
4. Decide Contention 3, as it relates to the "as is" condition of the SFPCCS piping for spent fuel pools C and D. The tests and inspections carried out pursuant to the Equipment Commissioning Plan demonstrate conclusively that there has been no significant corrosion or other deterioration to the SFPCCS piping. To the extent that BCOC continues to raise a genuine issue in dispute, it is not substantial, it is not central to the ultimate decision on the license amendment request, and it certainly can be disposed of with sufficient accuracy without a hearing.

Of Counsel:
Steven Carr
Legal Department
CAROLINA POWER & LIGHT
COMPANY
411 Fayetteville Street Mall
Post Office Box 1551 – CPB 13A2
Raleigh, North Carolina 27602-1551
(919) 546-4161

Dated: January 4, 2000

Respectfully submitted,



John H. O'Neill, Jr.
William R. Hollaway
SHAW PITTMAN
2300 N Street, N.W.
Washington, D.C. 20037-1128
(202) 663-8000
Counsel For CAROLINA POWER &
LIGHT COMPANY

DOCKETED
USNRC

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION '00 JAN -7 P3:47

Before the Atomic Safety and Licensing Board

OFFICE OF SECRETARY
RULEMAKING AND
ADJUDICATIONS

In the Matter of)
)
CAROLINA POWER & LIGHT) Docket No. 50-400-LA
COMPANY)
(Shearon Harris Nuclear Power Plant)) ASLBP No. 99-762-02-LA

CERTIFICATE OF SERVICE

I hereby certify that copies of the foregoing "Summary Of Facts, Data, And Arguments On Which Applicant Proposes To Rely At The Subpart K Oral Argument," dated January 4, 2000, with the Table of Contents, Exhibit Table of Contents, and Table of Authorities was served on the persons listed below by U.S. mail, first class, postage prepaid, and by electronic mail transmission, this 5th day of January, 2000.

G. Paul Bollwerk, III, Esq., Chairman
Administrative Judge
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001
e-mail: gpb@nrc.gov

Frederick J. Shon
Administrative Judge
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001
e-mail: fjs@nrc.gov

Dr. Peter S. Lam
Administrative Judge
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001
e-mail: psl@nrc.gov

Office of the Secretary
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001
Attention: Rulemakings and Adjudications
Staff
e-mail: hearingdocket@nrc.gov
(Original and two copies)

Susan L. Uttal, Esq.
Office of the General Counsel
Mail Stop O-15 B18
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555
e-mail: harris@nrc.gov

Diane Curran, Esq.
Harmon, Curran, Spielberg &
Eisenberg, L.L.P.
1726 M Street, N.W., Suite 600
Washington, D.C. 20036
e-mail: dcurran@harmoncurran.com

* Adjudicatory File
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

James M. Cutchin, V, Esq.
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001
e-mail: jmc3@nrc.gov

* by mail only


William R. Hollaway