

TITLE 10 - ATOMIC ENERGY

CHAPTER 1 - ATOMIC ENERGY COMMISSION

PART 50 - LICENSING OF PRODUCTION AND UTILIZATION FACILITIES

General Design Criteria for Nuclear Power Plants

The Atomic Energy Commission has adopted an amendment to its regulations, 10 CFR Part 50, "Licensing of Production and Utilization Facilities," which adds an Appendix A, "General Design Criteria for Nuclear Power Plants."

Paragraph 50.34(a) of Part 50 requires that each application for a construction permit include the preliminary design of the facility. The following information is specified for inclusion as part of the preliminary design of the facility:

- (i) The principal design criteria for the facility
- (ii) The design bases and the relation of the design bases to the principal design criteria
- (iii) Information relative to materials of construction, general arrangement, and the approximate dimensions, sufficient to provide reasonable assurance that the final design will conform to the design bases with adequate margin for safety.

The "General Design Criteria for Nuclear Power Plants" added as Appendix A to Part 50 establish the minimum requirements for the principal design criteria for water-cooled nuclear power plants

similar in design and location to plants for which construction permits have been issued by the Commission. They also provide guidance in establishing the principal design criteria for other types of nuclear power plants. Principal design criteria established by an applicant and accepted by the Commission will be incorporated by reference in the construction permit. In considering the issuance of an operating license under Part 50, the Commission will require assurance that these criteria have been satisfied in the detailed design and construction of the facility and that any changes in such criteria are justified.

A proposed Appendix A, "General Design Criteria for Nuclear Power Plant Construction Permits" to 10 CFR Part 50 was published in the FEDERAL REGISTER (32 FR 10213) on July 11, 1967. The comments and suggestions received in response to the notice of proposed rule making and subsequent developments in the technology and in the licensing process have been considered in developing the revised criteria which follow.

The revised criteria establish minimum requirements for water-cooled nuclear power plants similar in design and location to plants for which construction permits have been issued by the Commission, whereas the previously proposed criteria would have provided guidance for applicants for construction permits for all types of nuclear power plants. The revised criteria have been reduced to

55 in number, include definitions of important terms, and have been rearranged to increase their usefulness in the licensing process. Additional criteria describing specific requirements on matters covered in more general terms in the previously proposed criteria have been added to the criteria. The Categories A and B used to characterize the amount of information needed in Safety Analysis Reports concerning each criterion have been deleted since additional guidance on the amount and detail of information required to be submitted by applicants for facility licenses at the construction permit stage is now included in § 50.34 of Part 50. The term "engineered safety features" has been eliminated from the revised criteria and the requirements for "engineered safety features" incorporated in the criteria for individual systems.

Further revisions of these General Design Criteria are to be expected. In the course of the development of the revised criteria, important safety considerations were identified, but specific requirements related to some of these considerations have not as yet been sufficiently developed and uniformly applied in the licensing process to warrant their inclusion in the criteria at this time. Their omission does not relieve any applicant from considering these matters in the design of a specific facility and satisfying the necessary safety requirements. These matters include:

- (1) Consideration of the need to design against single failures of passive components in fluid systems important to safety.

- (ii) Consideration of redundancy and diversity requirements for fluid systems important to safety. A "system" could consist of a number of subsystems each of which is separately capable of performing the specified system safety function. The minimum acceptable redundancy and diversity of subsystems and components within a subsystem and the required interconnection and independence of the subsystems have not yet been developed or defined.
- (iii) Consideration of the type, size, and orientation of possible breaks in the components of the reactor coolant pressure boundary in determining design requirements to suitably protect against postulated loss of coolant accidents.
- (iv) Consideration of the possibility of systematic, non-random, concurrent failures of redundant elements in the design of the protection systems and reactivity control systems.

In addition, the Commission is giving consideration to the need for development of criteria relating to protection against industrial sabotage and protection against common mode failures in systems, other than the protection and reactivity control systems, that are important to safety and have extremely high reliability requirements.

It is expected that these criteria will be augmented or changed when specific requirements related to these and other considerations are suitably identified and developed.

Pursuant to the Atomic Energy Act of 1954, as amended, and sections 552 and 553 of Title 5 of the United States Code, the following amendment to 10 CFR Part 50 is published as a document subject to codification to be effective 90 days after publication in the FEDERAL REGISTER. The Commission invites all interested persons who desire to submit written comments or suggestions in connection with the amendment to send them to the Secretary, U. S. Atomic Energy Commission, Washington, D. C., 20545, Attention: Chief, Public Proceedings Branch, within 45 days after publication of this notice in the FEDERAL REGISTER. Such submissions will be given consideration with the view to possible further amendments. Copies of comments may be examined in the Commission's Public Document Room at 1717 H Street, N. W., Washington, D. C.

1. Subdivision 50.34(a)(3)(i) is amended to read as follows:

§ 50.34 Contents of applications; technical information.

(a) Preliminary safety analysis report. Each application for a construction permit shall include a preliminary safety analysis report. The minimum information to be included shall consist of the following:

* * * * *

(3) The preliminary design of the facility including:

(1) The principal design criteria for the facility. Appendix A, General Design Criteria for Nuclear Power Plants, establishes minimum requirements for the principal design criteria for water-cooled nuclear power plants similar in design and location to

plants for which construction permits have previously been issued by the Commission and provides guidance to applicants for construction permits in establishing principal design criteria for other types of nuclear power units:

* * * * *

2. Footnote² to § 50.34 is amended to read as follows:

²General design criteria for chemical processing facilities are being developed.

* * * * *

3. A new Appendix A is added to read as follows:

APPENDIX A

GENERAL DESIGN CRITERIA FOR NUCLEAR POWER PLANTS

Table of Contents

	<u>Number</u>
INTRODUCTION	
DEFINITIONS	
Nuclear Power Unit	
Loss of Coolant Accidents	
Single Failure	
Anticipated Operational Occurrences	
CRITERIA	
I. <u>OVERALL REQUIREMENTS</u>	
Quality Standards and Records	1
Design Bases for Protection Against Natural Phenomena	2
Fire Protection	3
Environmental and Missile Design Bases	4
Sharing of Structures, Systems, and Components	5
II. <u>PROTECTION BY MULTIPLE FISSION PRODUCT BARRIERS</u>	
Reactor Design	10
Reactor Inherent Protection	11
Suppression of Reactor Power Oscillations	12
Instrumentation and Control	13
Reactor Coolant Pressure Boundary	14
Reactor Coolant System Design	15
Containment Design	16
Electrical Power Systems	17
Inspection and Testing of Electrical Power Systems	18
Control Room	19
III. <u>PROTECTION AND REACTIVITY CONTROL SYSTEMS</u>	
Protection System Functions	20

Protection System Reliability and Testability	21
Protection System Independence	22
Protection System Failure Modes	23
Separation of Protection and Control Systems	24
Protection System Requirements for Reactivity Control Malfunctions	25
Reactivity Control System Redundancy and Capability	26
Combined Reactivity Control Systems Capability	27
Reactivity Limits	28
Protection Against Anticipated Operational Occurrences	29
 IV. <u>FLUID SYSTEMS</u>	
Quality of Reactor Coolant Pressure Boundary	30
Fracture Prevention of Reactor Coolant Pressure Boundary	31
Inspection of Reactor Coolant Pressure Boundary	32
Reactor Coolant Makeup	33
Residual Heat Removal	34
Emergency Core Cooling	35
Inspection of Emergency Core Cooling System	36
Testing of Emergency Core Cooling System	37
Containment Heat Removal	38
Inspection of Containment Heat Removal System	39
Testing of Containment Heat Removal System	40
Containment Atmosphere Cleanup	41
Inspection of Containment Atmosphere Cleanup Systems	42
Testing of Containment Atmosphere Cleanup Systems	43
Cooling Water	44
Inspection of Cooling Water System	45
Testing of Cooling Water System	46
 V. <u>REACTOR CONTAINMENT</u>	
Containment Design Basis	50
Fracture Prevention of Containment Pressure Boundary	51
Capability for Containment Leakage Rate Testing	52
Provisions for Containment Inspection and Testing	53
Systems Penetrating Containment	54
Reactor Coolant Pressure Boundary Penetrating Containment	55
Primary Containment Isolation	56
Closed Systems Isolation Valves	57
 VI. <u>FUEL AND RADIOACTIVITY CONTROL</u>	
Control of Releases of Radioactive Materials to the Environment	60

Fuel Storage and Handling and Radioactivity Control	61
Prevention of Criticality in Fuel Storage and Handling	62
Monitoring Fuel and Waste Storage	63
Monitoring Radioactivity Releases	64

INTRODUCTION

Pursuant to the provisions of § 50.34, an application for a construction permit must include the principal design criteria for a proposed facility. The principal design criteria establish the necessary design, fabrication, construction, testing, and performance requirements for structures, systems, and components important to safety; that is, structures, systems, and components that provide reasonable assurance that the facility can be operated without undue risk to the health and safety of the public.

These General Design Criteria establish minimum requirements for the principal design criteria for water-cooled nuclear power plants similar in design and location to plants for which construction permits have been issued by the Commission. The General Design Criteria are also considered to be generally applicable to other types of nuclear power units and are intended to provide guidance in establishing the principal design criteria for such other units.

The development of these General Design Criteria is not yet complete. For example, some of the definitions need further amplification. Also, some of the specific design requirements for structures, systems, and components important to safety have not as yet been suitably defined. Their omission does not relieve any applicant from considering these matters in the design of a specific facility and satisfying the necessary safety requirements. These matters include:

- (1) Consideration of the need to design against single failures of passive components in fluid systems important to safety. (See Definition of Single Failure.)
- (2) Consideration of redundancy and diversity requirements for fluid systems important to safety. A "system" could consist of a number of subsystems each of which is separately capable of performing the specified system safety function. The minimum acceptable redundancy and diversity of subsystems and components within a subsystem, and the required interconnection and independence of the subsystems have not yet been developed or defined. (See Criteria 34, 35, 38, 41, and 44.)
- (3) Consideration of the type, size, and orientation of possible breaks in components of the reactor coolant pressure boundary in determining design requirements to suitably protect against postulated loss-of-coolant accidents. (See Definition of Loss of Coolant Accidents.)
- (4) Consideration of the possibility of systematic, nonrandom, concurrent failures of redundant elements in the design of protection systems and reactivity control systems. (See Criteria 22, 24, 26 and 29.)

It is expected that the criteria will be augmented and changed from time to time as important new requirements for these and other features are developed.

There will be some water-cooled nuclear power plants for which the General Design Criteria are not sufficient and for which additional criteria must be identified and satisfied in the interest of public safety. In particular, it is expected that additional or different criteria will be needed to take into account unusual sites and environmental conditions, and for water-cooled nuclear power units of advanced design. Also, there may be water-cooled nuclear power units for which fulfillment of some of the General Design Criteria may not be necessary or appropriate. For plants such as these, departures from the General Design Criteria must be identified and justified.

DEFINITIONS AND EXPLANATIONS

NUCLEAR POWER UNIT

A nuclear power unit means a nuclear power reactor and associated equipment necessary for electrical power generation and includes those structures, systems, and components required to provide reasonable assurance the facility can be operated without undue risk to the health and safety of the public.

LOSS OF COOLANT ACCIDENTS

Loss of coolant accidents mean those postulated accidents that result from the loss of reactor coolant at a rate in excess of the capability of the reactor coolant makeup system from breaks in the reactor coolant pressure boundary, up to and including a break equivalent in size to the double-ended rupture of the largest pipe

of the reactor coolant system.¹

SINGLE FAILURE

A single failure means an occurrence which results in the loss of capability of a component to perform its intended safety functions. Multiple failures resulting from a single occurrence are considered to be a single failure. Fluid and electrical systems are considered to be designed against an assumed single failure if neither (1) a single failure of any active component (assuming passive components function properly) nor (2) a single failure of a passive component (assuming active components function properly), results in a loss of the capability of the system to perform its safety functions.²

ANTICIPATED OPERATIONAL OCCURRENCES

Anticipated operational occurrences mean those conditions of normal operation which are expected to occur one or more times during the life of the nuclear power unit and include but are not limited

¹ Further details relating to the type, size, and orientation of postulated breaks in specific components of the reactor coolant pressure boundary are under development.

² Single failures of passive components in electrical systems should be assumed in designing against a single failure. The conditions under which a single failure of a passive component in a fluid system should be considered in designing the system against a single failure are under development.

to loss of power to all recirculation pumps, tripping of the turbine generator set, isolation of the main condenser, and loss of all offsite power.

CRITERIA

I. OVERALL REQUIREMENTS

CRITERION 1 - QUALITY STANDARDS AND RECORDS

Structures, systems, and components important to safety shall be designed, fabricated, erected, and tested to quality standards commensurate with the importance of the safety functions to be performed. Where generally recognized codes and standards are used, they shall be identified and evaluated to determine their applicability, adequacy, and sufficiency and shall be supplemented or modified as necessary to assure a quality product in keeping with the required safety function. A quality assurance program shall be established and implemented in order to provide adequate assurance that these structures, systems, and components will satisfactorily perform their safety functions. Appropriate records of the design, fabrication, erection, and testing of structures, systems, and components important to safety shall be maintained by or under the control of the nuclear power unit licensee throughout the life of the unit.

CRITERION 2 - DESIGN BASES FOR PROTECTION AGAINST NATURAL PHENOMENA

Structures, systems, and components important to safety shall be designed to withstand the effects of natural phenomena such as

earthquakes, tornadoes, hurricanes, floods, tsunami, and seiches without loss of capability to perform their safety functions. The design bases for these structures, systems, and components shall reflect: (1) appropriate consideration of the most severe of the natural phenomena that have been historically reported for the site and surrounding area, with sufficient margin for the limited accuracy, quantity, and period of time in which the historical data have been accumulated, (2) appropriate combinations of the effects of normal and accident conditions with the effects of the natural phenomena and (3) the importance of the safety functions to be performed.

CRITERION 3 - FIRE PROTECTION

Structures, systems, and components important to safety shall be designed and located to minimize, consistent with other safety requirements, the probability and effect of fires and explosions. Noncombustible and heat resistant materials shall be used wherever practical throughout the unit, particularly in locations such as the containment and control room. Fire detection and fighting systems of appropriate capacity and capability shall be provided and designed to minimize the adverse effects of fires on structures, systems, and components important to safety. Fire fighting systems shall be designed to assure that their rupture or inadvertent operation does not significantly impair the safety capability of these structures, systems, and components.

CRITERION 4 - ENVIRONMENTAL AND MISSILE DESIGN BASES

Structures, systems, and components important to safety shall be designed to accommodate the effects of and to be compatible with the environmental conditions associated with normal operation, maintenance, testing, and postulated accidents, including loss-of-coolant accidents. These structures, systems, and components shall be appropriately protected against dynamic effects, including the effects of missiles, pipe whipping, and discharging fluids, that may result from equipment failures and from events and conditions outside the nuclear power unit.

CRITERION 5 - SHARING OF STRUCTURES, SYSTEMS, AND COMPONENTS

Structures, systems, and components important to safety shall not be shared between nuclear power units unless it is shown that their ability to perform their safety functions is not significantly impaired by the sharing.

II. PROTECTION BY MULTIPLE FISSION PRODUCT BARRIERS

CRITERION 10 - REACTOR DESIGN

The reactor core and associated coolant, control, and protection systems shall be designed with appropriate margin to assure that specified acceptable fuel design limits are not exceeded during any condition of normal operation, including the effects of anticipated operational occurrences.

CRITERION 11 - REACTOR INHERENT PROTECTION

The reactor core and associated coolant systems shall be designed so that in the power operating range the net effect of the prompt inherent nuclear feedback characteristics tends to compensate for a rapid increase in reactivity.

CRITERION 12 - SUPPRESSION OF REACTOR POWER OSCILLATIONS

The reactor core and associated coolant, control, and protection systems shall be designed to assure that power oscillations which can result in conditions exceeding specified acceptable fuel design limits are not possible or can be reliably and readily detected and suppressed.

CRITERION 13 - INSTRUMENTATION AND CONTROL

Instrumentation and control shall be provided to monitor variables and systems over their anticipated range for normal operation and accident conditions, and to maintain them within prescribed operating ranges, including those variables and systems which can affect the fission process, the integrity of the reactor core, the reactor coolant pressure boundary, and the containment and its associated systems.

CRITERION 14 - REACTOR COOLANT PRESSURE BOUNDARY

The reactor coolant pressure boundary shall be designed, fabricated, erected, and tested so as to have an extremely low probability of abnormal leakage, of rapidly propagating failure, and of gross rupture.

CRITERION 15 - REACTOR COOLANT SYSTEM DESIGN

The reactor coolant system and associated auxiliary, control, and protection systems shall be designed with sufficient margin to assure that the design conditions of the reactor coolant pressure boundary are not exceeded during any condition of normal operation, including anticipated operational occurrences.

CRITERION 16 - CONTAINMENT DESIGN

Reactor containment and associated systems shall be provided to establish an essentially leaktight barrier against the uncontrolled release of radioactivity to the environment and to assure that the containment design conditions important to safety are not exceeded for as long as postulated accident conditions require.

CRITERION 17 - ELECTRICAL POWER SYSTEMS

An onsite electrical power system and an offsite electrical power system shall be provided to permit functioning of structures, systems, and components important to safety. The safety function for each system (assuming the other system is not functioning) shall be to provide sufficient capacity and capability to assure that (1) specified acceptable fuel design limits and design conditions of the reactor coolant pressure boundary are not exceeded as a result of anticipated operational occurrences and (2) the core is cooled and containment integrity and other vital functions are maintained in the event of postulated accidents.

The onsite electrical power sources, including the batteries, and the onsite electrical distribution system, shall have sufficient independence, redundancy, and testability to perform their safety functions assuming a single failure.

Electrical power from the transmission network to the switchyard shall be supplied by two physically independent transmission lines (not necessarily on separate rights of way) designed and located so as to suitably minimize the likelihood of their simultaneous failure under operating and postulated accident and environmental conditions. Two physically independent circuits from the switchyard to the onsite electrical distribution system shall be provided. Each of these circuits shall be designed to be available in sufficient time following a loss of all onsite alternating current power sources and the other offsite electrical power circuit, to assure that specified acceptable fuel design limits and design conditions of the reactor coolant pressure boundary are not exceeded. One of these circuits shall be designed to be available within a few seconds following a loss-of-coolant accident to assure that core cooling, containment integrity, and other vital safety functions are maintained.

Provisions shall be included to minimize the probability of losing electrical power from any of the remaining sources as a result of, or coincident with, the loss of power generated by the nuclear power unit, the loss of power from the transmission network, or the loss of power from the onsite electrical power sources.

CRITERION 18 - INSPECTION AND TESTING OF ELECTRICAL POWER SYSTEMS

Electrical power systems important to safety shall be designed to permit periodic inspection and testing of important areas and features, such as wiring, insulation, connections, and switchboards, to assess the continuity of the systems and the condition of their components. The systems shall be designed with a capability to test periodically (1) the operability and functional performance of the components of the systems, such as onsite power sources, relays, switches, and buses, and (2) the operability of the systems as a whole and, under conditions as close to design as practical, the full operational sequence that brings the systems into operation, including operation of applicable portions of the protection system, and the transfer of power among the nuclear power unit, the offsite power system, and the onsite power system.

CRITERION 19 - CONTROL ROOM

A control room shall be provided from which actions can be taken to operate the nuclear power unit safely under normal conditions and to maintain it in a safe condition under accident conditions, including loss-of-coolant accidents. Adequate radiation protection shall be provided to permit access and occupancy of the control room under accident conditions without personnel receiving radiation exposures in excess of 5 rem whole body, or its equivalent to any part of the body, for the duration of the accident.

Equipment at appropriate locations outside the control room shall be provided (1) with a design capability for prompt hot shutdown of the reactor, including necessary instrumentation and controls to maintain the unit in a safe condition during hot shutdown, and (2) with a potential capability for subsequent cold shutdown of the reactor through the use of suitable procedures.

III. PROTECTION AND REACTIVITY CONTROL SYSTEMS

CRITERION 20 - PROTECTION SYSTEM FUNCTIONS

The protection system shall be designed (1) to initiate automatically the operation of appropriate systems including the reactivity control systems, to assure that specified acceptable fuel design limits are not exceeded as a result of anticipated operational occurrences and (2) to sense accident conditions and to initiate the operation of systems and components important to safety.

CRITERION 21 - PROTECTION SYSTEM RELIABILITY AND TESTABILITY

The protection system shall be designed for high functional reliability and inservice testability commensurate with the safety functions to be performed. Redundancy and independence designed into the protection system shall be sufficient to assure that (1) no single failure results in loss of the protection function and (2) removal from service of any component or channel does not result in loss of the required minimum redundancy unless the acceptable

reliability of operation of the protection system can be otherwise demonstrated. The protection system shall be designed to permit periodic testing of its functioning when the reactor is in operation, including a capability to test channels independently to determine failures and losses of redundancy that may have occurred.

CRITERION 22 - PROTECTION SYSTEM INDEPENDENCE

The protection system shall be designed to assure that the effects of natural phenomena, and of normal operating, maintenance, testing, and postulated accident conditions on redundant channels do not result in loss of the protection function, or shall be demonstrated to be acceptable on some other defined basis. Design techniques, such as functional diversity or diversity in component design and principles of operation, shall be used to the extent practical to prevent loss of the protection function.

CRITERION 23 - PROTECTION SYSTEM FAILURE MODES

The protection system shall be designed to fail into a safe state or into a state demonstrated to be acceptable on some other defined basis if conditions such as disconnection of the system, loss of energy (e.g., electric power, instrument air), or postulated adverse environments (e.g., extreme heat or cold, fire, pressure, steam, water, and radiation) are experienced.

CRITERION 24 - SEPARATION OF PROTECTION AND CONTROL SYSTEMS

The protection system shall be separated from control systems

to the extent that failure of any single control system component or channel, or failure or removal from service of any single protection system component or channel which is common to the control and protection systems leaves intact a system satisfying all reliability, redundancy, and independence requirements of the protection system. Interconnection of the protection and control systems shall be limited so as to assure that safety is not significantly impaired.

CRITERION 25 - PROTECTION SYSTEM REQUIREMENTS FOR REACTIVITY CONTROL MALFUNCTIONS

The protection system shall be designed to assure that specified acceptable fuel design limits are not exceeded for any single malfunction of the reactivity control systems, such as accidental withdrawal (not ejection or dropout) of control rods or unplanned dilution of soluble poison.

CRITERION 26 - REACTIVITY CONTROL SYSTEM REDUNDANCY AND CAPABILITY

Two independent reactivity control systems of different design principles and preferably including a positive mechanical means for inserting control rods, shall be provided. Each system shall have the capability to control the rate of reactivity changes resulting from planned, normal power changes (including xenon burnout) to assure acceptable fuel design limits are not exceeded. One of the systems shall be capable of reliably controlling reactivity changes to assure that under conditions of normal operations,

including anticipated operational occurrences, and with appropriate margin for malfunctions such as stuck rods, specified acceptable fuel design limits are not exceeded. One of the systems shall be capable of holding the reactor core subcritical under cold conditions.

CRITERION 27 - COMBINED REACTIVITY CONTROL SYSTEMS CAPABILITY

The reactivity control systems shall be designed to have a combined capability, in conjunction with poison addition by the emergency core cooling system, of reliably controlling reactivity changes to assure that under postulated accident conditions and with appropriate margin for stuck rods the capability to cool the core is maintained.

CRITERION 28 - REACTIVITY LIMITS

The reactivity control systems shall be designed with appropriate limits on the potential amount and rate of reactivity increase to assure that the effects of postulated reactivity accidents can neither (1) result in damage to the reactor coolant pressure boundary greater than limited local yielding nor (2) sufficiently disturb the core, its support structures or other reactor pressure vessel internals to impair significantly the capability to cool the core. These postulated reactivity accidents shall include consideration of rod ejection (unless prevented by positive means), rod dropout, steam line rupture, changes in reactor coolant temperature and pressure, and cold water addition.

CRITERION 29 - PROTECTION AGAINST ANTICIPATED OPERATIONAL OCCURRENCES

The protection and reactivity control systems shall be designed to assure an extremely high probability of accomplishing their safety functions in the event of anticipated operational occurrences.

IV. FLUID SYSTEMS

CRITERION 30 - QUALITY OF REACTOR COOLANT PRESSURE BOUNDARY

Components which are part of the reactor coolant pressure boundary shall be designed, fabricated, erected, and tested to the highest quality standards practical. Means shall be provided for detecting and, to the extent practical, identifying the location of the source of reactor coolant leakage.

CRITERION 31 - FRACTURE PREVENTION OF REACTOR COOLANT PRESSURE BOUNDARY

The reactor coolant pressure boundary shall be designed with sufficient margin to assure that when stressed under operating, maintenance, testing, and postulated accident conditions (1) the boundary behaves in a nonbrittle manner and (2) the probability of rapidly propagating fracture is minimized. The design shall reflect consideration of service temperatures and other conditions of the boundary material under operating, maintenance, testing, and postulated accident conditions and the uncertainties in determining (1) material properties, (2) the effects of irradiation on material properties, (3) residual, steady-state and transient stresses, and (4) size of flaws.

CRITERION 32 - INSPECTION OF REACTOR COOLANT PRESSURE BOUNDARY

Components which are part of the reactor coolant pressure boundary shall be designed to permit (1) periodic inspection and testing of important areas and features to assess their structural and leaktight integrity, and (2) an appropriate material surveillance program for the reactor pressure vessel.

CRITERION 33 - REACTOR COOLANT MAKEUP

A system to supply reactor coolant makeup for protection against small breaks in the reactor coolant pressure boundary shall be provided. The system safety function shall be to assure that specified acceptable fuel design limits are not exceeded as a result of reactor coolant loss due to leakage from the reactor coolant pressure boundary and rupture of small piping or other small components which are part of the boundary. The system shall be designed to assure that for onsite electrical power system operation (assuming offsite power is not available) and for offsite electrical power system operation (assuming onsite power is not available) the system safety function can be accomplished using the piping, pumps, and valves used to maintain coolant inventory during normal reactor operation.

CRITERION 34 - RESIDUAL HEAT REMOVAL

A system to remove residual heat shall be provided. The system safety function shall be to transfer fission product decay heat and other residual heat from the reactor core at a rate such that

specified acceptable fuel design limits and the design conditions of the reactor coolant pressure boundary are not exceeded.

Suitable redundancy in components and features, and suitable interconnections, leak detection, and isolation capabilities shall be provided to assure that for onsite electrical power system operation (assuming offsite power is not available) and for off-site electrical power system operation (assuming onsite power is not available) the system safety function can be accomplished, assuming a single failure.

CRITERION 35 - EMERGENCY CORE COOLING

A system to provide abundant emergency core cooling shall be provided. The system safety function shall be to transfer heat from the reactor core following any loss of coolant accident at a rate such that (1) fuel and clad damage that could interfere with continued effective core cooling is prevented and (2) clad metal-water reaction is limited to negligible amounts.

Suitable redundancy in components and features, and suitable interconnections, leak detection, isolation, and containment capabilities shall be provided to assure that for onsite electrical power system operation (assuming offsite power is not available) and for offsite electrical power system operation (assuming onsite power is not available) the system safety function can be accomplished, assuming a single failure.

CRITERION 36 - INSPECTION OF EMERGENCY CORE COOLING SYSTEM

The emergency core cooling system shall be designed to permit periodic inspection of important components, such as spray rings in

the reactor pressure vessel, water injection nozzles, and piping, to assure the integrity and capability of the system.

CRITERION 37 - TESTING OF EMERGENCY CORE COOLING SYSTEM

The emergency core cooling system shall be designed to permit appropriate periodic pressure and functional testing to assure (1) the structural and leaktight integrity of its components, (2) the operability and performance of the active components of the system, and (3) the operability of the system as a whole and, under conditions as close to design as practical, the performance of the full operational sequence that brings the system into operation, including operation of applicable portions of the protection system, the transfer between normal and emergency power sources, and the operation of the associated cooling water system.

CRITERION 38 - CONTAINMENT HEAT REMOVAL

A system to remove heat from the reactor containment shall be provided. The system safety function shall be to reduce rapidly, consistent with the functioning of other associated systems, the containment pressure and temperature following any loss-of-coolant accident and maintain them at acceptably low levels.

Suitable redundancy in components and features, and suitable interconnections, leak detection, isolation, and containment capabilities shall be provided to assure that for onsite electrical power system operation (assuming offsite power is not available) and for offsite electrical power system operation (assuming onsite power is not available) the system safety function can be accomplished, assuming a single failure.

CRITERION 39 - INSPECTION OF CONTAINMENT HEAT REMOVAL SYSTEM

The containment heat removal system shall be designed to permit periodic inspection of important components, such as the torus, sumps, spray nozzles, and piping to assure the integrity and capability of the system.

CRITERION 40 - TESTING OF CONTAINMENT HEAT REMOVAL SYSTEM

The containment heat removal system shall be designed to permit appropriate periodic pressure and functional testing to assure (1) the structural and leaktight integrity of its components, (2) the operability and performance of the active components of the system, and (3) the operability of the system as a whole, and, under conditions as close to the design as practical, the performance of the full operational sequence that brings the system into operation, including operation of applicable portions of the protection system, the transfer between normal and emergency power sources, and the operation of the associated cooling water system.

CRITERION 41 - CONTAINMENT ATMOSPHERE CLEANUP

Systems to control fission products, hydrogen, oxygen, and other substances which may be released into the reactor containment shall be provided as necessary to reduce, consistent with the functioning of other associated systems, the concentration and quantity of fission products released to the environment following postulated accidents, and to control the concentration of hydrogen or oxygen and other

substances in the containment atmosphere following postulated accidents to assure that containment integrity is maintained.

Each system shall have suitable redundancy in components and features, and suitable interconnections, leak detection, isolation, and containment capabilities to assure that for onsite electrical power system operation (assuming offsite power is not available) and for offsite electrical power system operation (assuming onsite power is not available) its safety function can be accomplished, assuming a single failure.

CRITERION 42 - INSPECTION OF CONTAINMENT ATMOSPHERE CLEANUP SYSTEMS

The containment atmosphere cleanup systems shall be designed to permit periodic inspection of important components, such as filter frames, ducts, and piping to assure the integrity and capability of the systems.

CRITERION 43 - TESTING OF CONTAINMENT ATMOSPHERE CLEANUP SYSTEMS

The containment atmosphere cleanup systems shall be designed to permit appropriate periodic pressure and functional testing to assure (1) the structural and leaktight integrity of its components, (2) the operability and performance of the active components of the systems such as fans, filters, dampers, pumps, and valves and (3) the operability of the systems as a whole and, under conditions as close to design as practical, the performance of the full operational sequence that brings the systems into operation, including operation of applicable portions of the protection system, the transfer between normal and emergency power sources, and the operation of associated systems.

CRITERION 44 - COOLING WATER

A system to transfer heat from structures, systems, and components important to safety, to an ultimate heat sink shall be provided. The system safety function shall be to transfer the combined heat load of these structures, systems, and components under normal operating and accident conditions.

Suitable redundancy in components and features, and suitable interconnections, leak detection, and isolation capabilities shall be provided to assure that for onsite electrical power system operation (assuming offsite power is not available) and for offsite electrical power system operation (assuming onsite power is not available) the system safety function can be accomplished, assuming a single failure.

CRITERION 45 - INSPECTION OF COOLING WATER SYSTEM

The cooling water system shall be designed to permit periodic inspection of important components, such as heat exchangers and piping, to assure the integrity and capability of the system.

CRITERION 46 - TESTING OF COOLING WATER SYSTEM

The cooling water system shall be designed to permit appropriate periodic pressure and functional testing to assure (1) the structural and leaktight integrity of its components, (2) the operability and the performance of the active components of the system, and (3) the operability of the system as a whole and, under conditions as close to design as practical, the performance of the full operational sequence that brings the system into operation for reactor shutdown and for

loss-of-coolant accidents, including operation of applicable portions of the protection system and the transfer between normal and emergency power sources.

V. REACTOR CONTAINMENT

CRITERION 50 - CONTAINMENT DESIGN BASIS

The reactor containment structure, including access openings, penetrations, and the containment heat removal system shall be designed so that the containment structure and its internal compartments can accommodate, without exceeding the design leakage rate and, with sufficient margin, the calculated pressure and temperature conditions resulting from any loss-of-coolant accident. This margin shall reflect consideration of (1) the effects of potential energy sources which have not been included in the determination of the peak conditions, such as energy in steam generators and energy from metal-water and other chemical reactions that may result from degraded emergency core cooling functioning, (2) the limited experience and experimental data available for defining accident phenomena and containment responses, and (3) the conservatism of the calculational model and input parameters.

CRITERION 51 - FRACTURE PREVENTION OF CONTAINMENT PRESSURE BOUNDARY

The reactor containment boundary shall be designed with sufficient margin to assure that under operating, maintenance, testing, and postulated accident conditions (1) its ferritic materials behave in a nonbrittle manner and (2) the probability of rapidly propagating

fracture is minimized. The design shall reflect consideration of service temperatures and other conditions of the containment boundary material during operation, maintenance, testing, and postulated accident conditions, and the uncertainties in determining (1) material properties, (2) residual, steady-state, and transient stresses, and (3) size of flaws.

CRITERION 52 - CAPABILITY FOR CONTAINMENT LEAKAGE RATE TESTING

The reactor containment and other equipment which may be subjected to containment test conditions shall be designed so that periodic integrated leakage rate testing can be conducted at containment design pressure.

CRITERION 53 - PROVISIONS FOR CONTAINMENT TESTING AND INSPECTION

The reactor containment shall be designed to permit (1) inspection of all important areas, such as penetrations, (2) an appropriate surveillance program, and (3) periodic testing at containment design pressure of the leaktightness of penetrations which have resilient seals and expansion bellows.

CRITERION 54 - PIPING SYSTEMS PENETRATING CONTAINMENT

Piping systems penetrating primary reactor containment shall be provided with leak detection, isolation, and containment capabilities having redundancy, reliability, and performance capabilities which reflect the importance to safety of isolating these piping systems. Such piping systems shall be designed with a capability to test

periodically the operability of the isolation valves and associated apparatus and to determine if valve leakage is within acceptable limits.

CRITERION 55 - REACTOR COOLANT PRESSURE BOUNDARY PENETRATING CONTAINMENT

Each line that is part of the reactor coolant pressure boundary and that penetrates primary reactor containment shall be provided with containment isolation valves as follows, unless it can be demonstrated that the containment isolation provisions for a specific class of lines, such as instrument lines, are acceptable on some other defined basis:

- (1) One locked closed isolation valve inside and one locked closed isolation valve outside containment. or
- (2) One automatic isolation valve inside and one locked closed isolation valve outside containment. or
- (3) One locked closed isolation valve inside and one automatic isolation valve outside containment. A simple check valve may not be used as the automatic isolation valve outside containment. or
- (4) One automatic isolation valve inside and one automatic isolation valve outside containment. A simple check valve may not be used as the automatic isolation valve outside containment.

Isolation valves outside containment shall be located as close to

containment as practical and upon loss of actuating power, automatic isolation valves shall be designed to take the position that provides greater safety.

Other appropriate requirements to minimize the probability or consequences of an accidental rupture of these lines or of lines connected to them shall be provided as necessary to assure adequate safety. Determination of the appropriateness of these requirements, such as higher quality in design, fabrication, and testing, additional provisions for inservice inspection, protection against more severe natural phenomena, and additional isolation valves and containment, shall include consideration of the population density, use characteristics, and physical characteristics of the site environs.

CRITERION 56 - PRIMARY CONTAINMENT ISOLATION

Each line that connects directly to the containment atmosphere and penetrates primary reactor containment shall be provided with containment isolation valves as follows, unless it can be demonstrated that the containment isolation provisions for a specific class of lines, such as instrument lines, are acceptable on some other defined basis:

- (1) One locked closed isolation valve inside and one locked closed isolation valve outside containment. or
- (2) One automatic isolation valve inside and one locked closed isolation valve outside containment. or

- (3) One locked closed isolation valve inside and one automatic isolation valve outside containment. A simple check valve may not be used as the automatic isolation valve outside containment. or
- (4) One automatic isolation valve inside and one automatic isolation valve outside containment. A simple check valve may not be used as the automatic isolation valve outside containment.

Isolation valves outside containment shall be located as close to the containment as practical and upon loss of actuating power, automatic isolation valves shall be designed to take the position that provides greater safety.

CRITERION 57 - CLOSED SYSTEM ISOLATION VALVES

Each line that penetrates primary reactor containment and is neither part of the reactor coolant pressure boundary nor connected directly to the containment atmosphere shall have at least one containment isolation valve which shall be either automatic, or locked closed, or capable of remote manual operation. This valve shall be outside containment and located as close to the containment as practical. A simple check valve may not be used as the automatic isolation valve.

VI. FUEL AND RADIOACTIVITY CONTROL

CRITERION 60 - CONTROL OF RELEASES OF RADIOACTIVE MATERIALS TO THE ENVIRONMENT

The nuclear power unit design shall include means to control suitably the release of radioactive materials in gaseous and liquid effluents and to handle radioactive solid wastes produced during normal reactor operation, including anticipated operational occurrences. Sufficient holdup capacity shall be provided for retention of gaseous and liquid effluents containing radioactive materials, particularly where unfavorable site environmental conditions can be expected to impose unusual operational limitations upon the release of such effluents to the environment.

CRITERION 61 - FUEL STORAGE AND HANDLING AND RADIOACTIVITY CONTROL

The fuel storage and handling, radioactive waste, and other systems which may contain radioactivity shall be designed to assure adequate safety under normal and postulated accident conditions. These systems shall be designed (1) with a capability to permit inspection and testing of components important to safety, (2) with suitable shielding for radiation protection, (3) with appropriate containment, confinement, and filtering systems, (4) with a residual heat removal capability having reliability and testability that reflects the importance to safety of decay heat and other residual

heat removal, and (5) to prevent significant reduction in fuel storage coolant inventory under accident conditions.

CRITERION 62 - PREVENTION OF CRITICALITY IN FUEL STORAGE AND HANDLING

Criticality in the fuel storage and handling system shall be prevented by physical systems or processes, preferably by use of geometrically safe configurations.

CRITERION 63 - MONITORING FUEL AND WASTE STORAGE

Appropriate systems shall be provided in fuel storage and radioactive waste systems and associated handling areas (1) to detect conditions that may result in loss of residual heat removal capability and excessive radiation levels and (2) to initiate appropriate safety actions.


CRITERION 64 - MONITORING RADIOACTIVITY RELEASES

Means shall be provided for monitoring the reactor containment atmosphere, spaces containing components for recirculation of loss-of-coolant accident fluids, effluent discharge paths, and the plant environs for radioactivity that may be released from normal operations, including anticipated operational occurrences, and from postulated accidents.

(Secs. 161, 182, 68 Stat. 948, 953; 42 U.S.C. 2201, 2232.)

Dated at Washington, D. C. this 10th
day of February 1971.

FOR THE ATOMIC ENERGY COMMISSION

A handwritten signature in dark ink, appearing to read 'W. B. McCool', is written over a horizontal line.

W. B. McCool
Secretary of the Commission

AEC PUBLISHES GENERAL DESIGN CRITERIA
FOR NUCLEAR POWER PLANTS

The AEC is publishing a revised set of general design criteria for use in establishing the principal design criteria for nuclear power plants.

In July 1967 AEC published in the Federal Register for public comment "General Design Criteria for Nuclear Power Plant Construction Permits" developed by its regulatory staff. The revision published today reflects extensive comment received from 21 groups or individuals, review within the AEC, and developments that have occurred in the nuclear industry since publication of the criteria in 1967.

The regulatory staff has worked closely with the Commission's Advisory Committee on Reactor Safeguards in developing the revised criteria.

The amendment to Part 50 of the Commission's regulations fixes minimum requirements for the principal design criteria for water-cooled nuclear power units similar in design and location to units previously approved by the Commission for construction. It provides guidance, also, for establishing the principal design criteria for other types of nuclear power plants. Additional or different criteria are expected to be needed for unusual sites and environmental conditions, and for nuclear power plants of advanced design.

ATOMIC ENERGY COMMISSION

/10 CFR PART 50/

LICENSING OF PRODUCTION AND UTILIZATION FACILITIES

General Design Criteria
for Nuclear Power Plant Construction Permits^{1/}

The Atomic Energy Commission has under consideration an amendment to its regulation, 10 CFR Part 50, "Licensing of Production and Utilization Facilities," which would add an Appendix A, "General Design Criteria for Nuclear Power Plant Construction Permits." The purpose of the proposed amendment would be to provide guidance to applicants in developing the principal design criteria to be included in applications for Commission construction permits. These General Design Criteria would not add any new requirements, but are intended to describe more clearly present Commission requirements to assist applicants in preparing applications.

The proposed amendment would complement other proposed amendments to Part 50 which were published for public comment in the FEDERAL REGISTER on August 16, 1966 (31 F.R. 10891).

^{1/} Inasmuch as the Commission has under consideration other amendments to 10 CFR Part 50 (31 F.R. 10891), the amendment proposed herein would be a further revision to Part 50 previously published for comment in the FEDERAL REGISTER.

The proposed amendments to Part 50 reflect a recommendation made by a seven-member Regulatory Review Panel, appointed by the Commission to study: (1) the programs and procedures for the licensing and regulation of reactors and (2) the decision-making process in the Commission's regulatory program. The Panel's report recommended the development, particularly at the construction permit stage of a licensing proceeding, of design criteria for nuclear power plants. Work on the development of such criteria had been in process at the time of the Panel's study.

As a result, preliminary proposed criteria for the design of nuclear power plants were discussed with the Commission's Advisory Committee on Reactor Safeguards and were informally distributed for public comment in Commission Press Release H-252 dated November 22, 1965. In developing the proposed criteria set forth in the proposed amendments to Part 50, the Commission has taken into consideration comments and suggestions from the Advisory Committee on Reactor Safeguards, from members of industry, and from the public.

Section 50.34, paragraph (b), as published for comment in the FEDERAL REGISTER on August 16, 1966, would require that each application for a construction permit include a preliminary safety analysis report. The minimum information to be included in this preliminary safety analysis report is (1) a description and safety assessment of the site, (2) a summary description of the facility, (3) a preliminary design of the facility, (4) a preliminary safety analysis and evaluation of the facility, (5) an identification of subjects expected

to be technical specifications, and (6) a preliminary plan for the organization, training, and operation. The following information is specified for inclusion as part of the preliminary design of the facility:

- " (i) The principal design criteria for the facility;
- (ii) The design bases and the relation of the design bases to the principal design criteria;
- (iii) Information relative to materials of construction, general arrangement and approximate dimensions, sufficient to provide reasonable assurance that the final design will conform to the design bases with adequate margin for safety;"

The "General Design Criteria for Nuclear Power Plant Construction Permits" proposed to be included as Appendix A to this part are intended to aid the applicant in development item (i) above, the principal design criteria. All criteria established by an applicant and accepted by the Commission would be incorporated by reference in the construction permit. In considering the issuance of an operating license under the regulations, the Commission would assure that the criteria had been met in the detailed design and construction of the facility or that changes in such criteria have been justified.

Section 50.34 as published in the FEDERAL REGISTER on August 16, 1966, would be further amended by adding to Part 50 a new Appendix A containing the General Design Criteria applicable to the construction of nuclear power plants and by a specific reference to this Appendix in §50.34, paragraph (b).

The Commission expects that the provisions of the proposed amendments relating to General Design Criteria for Nuclear Power Plant Construction

Permits will be useful as interim guidance until such time as the Commission takes further action on them.

Pursuant to the Atomic Energy Act of 1954, as amended, and the Administrative Procedure Act of 1946, as amended, notice is hereby given that adoption of the following amendments to 10 CFR Part 50 is contemplated. All interested persons who desire to submit written comments or suggestions in connection with the proposed amendments should send them to the Secretary, United States Atomic Energy Commission, Washington, D.C. 20545, within 60 days after publication of this notice in the FEDERAL REGISTER. Comments received after that period will be considered if it is practicable to do so, but assurance of consideration cannot be given except as to comments filed within the period specified. Copies of comments may be examined in the Commission's Public Document Room at 1717 H Street, N.W., Washington, D.C.

1. §50.34(b)(3)(i) of 10 CFR Part 50 is amended to read as follows:

§50.34 Contents^{2/} of applications; technical information safety analysis report.

* * * * *

(b) Each application for a construction permit shall include a preliminary safety analysis report. The report shall cover all pertinent

^{2/} Inasmuch as the Commission has under consideration other amendments to §50.34 (31 F.R. 10891), the amendment proposed herein would be a further revision of §50.34(b)(3)(i) previously published for comment in the FEDERAL REGISTER.

subjects specified in paragraph (a) of this section as fully as available information permits. The minimum information to be included shall consist of the following:

* * * * *

(3) The preliminary design of the facility, including:

(i) The principal design criteria for the facility.

Appendix A, "General Design Criteria for Nuclear Power Plant Construction Permits," provides guidance for establishing the principal design criteria for nuclear power plants.

2. A new Appendix A is added to read as follows:

APPENDIX A

GENERAL DESIGN CRITERIA FOR NUCLEAR POWER PLANT CONSTRUCTION PERMITS^{3/}

Table of Contents

INTRODUCTION

<u>Group</u>	<u>Title</u>	<u>Criterion No.</u>
I.	<u>OVERALL PLANT REQUIREMENTS</u>	
	Quality Standards	1
	Performance Standards	2
	Fire Protection	3
	Sharing of Systems	4
	Records Requirements	5
II.	<u>PROTECTION BY MULTIPLE FISSION PRODUCT BARRIERS</u>	
	Reactor Core Design	6
	Suppression of Power Oscillations	7
	Overall Power Coefficient	8
	Reactor Coolant Pressure Boundary	9
	Containment	10
III.	<u>NUCLEAR AND RADIATION CONTROLS</u>	
	Control Room	11
	Instrumentation and Control Systems	12
	Fission Process Monitors and Controls	13
	Core Protection Systems	14
	Engineered Safety Features Protection Systems	15
	Monitoring Reactor Coolant Pressure Boundary	16
	Monitoring Radioactivity Releases	17
	Monitoring Fuel and Waste Storage	18

^{3/} Inasmuch as the Commission has under consideration other amendments to 10 CFR Part 50 (31 F.R. 10891), the amendment proposed herein would be a further revision to Part 50 previously published for comment in the FEDERAL REGISTER.

<u>Group</u>	<u>Title</u>	<u>Criterion No.</u>
IV.	<u>RELIABILITY AND TESTABILITY OF PROTECTION SYSTEMS</u>	
	Protection Systems Reliability	19
	Protection Systems Redundancy and Independence	20
	Single Failure Definition	21
	Separation of Protection and Control Instru- mentation Systems	22
	Protection Against Multiple Disability for Protection Systems	23
	Emergency Power for Protection Systems	24
	Demonstration of Functional Operability of Protection Systems	25
	Protection Systems Fail-Safe Design	26
V.	<u>REACTIVITY CONTROL</u>	
	Redundancy of Reactivity Control	27
	Reactivity Hot Shutdown Capability	28
	Reactivity Shutdown Capability	29
	Reactivity Holddown Capability	30
	Reactivity Control Systems Malfunction	31
	Maximum Reactivity Worth of Control Rods	32
VI.	<u>REACTOR COOLANT PRESSURE BOUNDARY</u>	
	Reactor Coolant Pressure Boundary Capability	33
	Reactor Coolant Pressure Boundary Rapid Propagation Failure Prevention	34
	Reactor Coolant Pressure Boundary Brittle Fracture Prevention	35
	Reactor Coolant Pressure Boundary Surveillance	36
VII.	<u>ENGINEERED SAFETY FEATURES</u>	
A.	<u>General Requirements for Engineered Safety Features</u>	
	Engineered Safety Features Basis for Design	37
	Reliability and Testability of Engineered Safety Features	38
	Emergency Power for Engineered Safety Features	39
	Missile Protection	40
	Engineered Safety Features Performance Capability	41
	Engineered Safety Features Components Capability	42
	Accident Aggravation Prevention	43

<u>Group</u>	<u>Title</u>	<u>Criterion No.</u>
VII.	<u>ENGINEERED SAFETY FEATURES</u>	
B.	<u>Emergency Core Cooling Systems</u>	
	Emergency Core Cooling Systems Capability	44
	Inspection of Emergency Core Cooling Systems	45
	Testing of Emergency Core Cooling Systems Components	46
	Testing of Emergency Core Cooling Systems	47
	Testing of Operational Sequence of Emergency Core Cooling Systems	48
C.	<u>Containment</u>	
	Containment Design Basis	49
	NDT Requirement for Containment Material	50
	Reactor Coolant Pressure Boundary Outside Containment	51
	Containment Heat Removal Systems	52
	Containment Isolation Valves	53
	Containment Leakage Rate Testing	54
	Containment Periodic Leakage Rate Testing	55
	Provisions for Testing of Penetrations	56
	Provisions for Testing of Isolation Valves	57
D.	<u>Containment Pressure-Reducing Systems</u>	
	Inspection of Containment Pressure-Reducing Systems	58
	Testing of Containment Pressure-Reducing Systems	59
	Testing of Containment Spray Systems	60
	Testing of Operational Sequence of Containment Pressure-Reducing Systems	61
E.	<u>Air Cleanup Systems</u>	
	Inspection of Air Cleanup Systems	62
	Testing of Air Cleanup Systems Components	63
	Testing of Air Cleanup Systems	64
	Testing of Operational Sequence of Air Cleanup Systems	65

<u>Group</u>	<u>Title</u>	<u>Criterion No.</u>
VIII.	<u>FUEL AND WASTE STORAGE SYSTEMS</u>	
	Prevention of Fuel Storage Criticality	66
	Fuel and Waste Storage Decay Heat	67
	Fuel and Waste Storage Radiation Shielding	68
	Protection Against Radioactivity Release from Spent Fuel and Waste Storage	69
IX.	<u>PLANT EFFLUENTS</u>	
	Control of Releases of Radioactivity to the Environment	70

INTRODUCTION

Every applicant for a construction permit is required by the provisions of §50.34 to include the principal design criteria for the proposed facility in the application. These General Design Criteria are intended to be used as guidance in establishing the principal design criteria for a nuclear power plant. The General Design Criteria reflect the predominating experience with water power reactors as designed and located to date, but their applicability is not limited to these reactors. They are considered generally applicable to all power reactors.

Under the Commission's regulations, an applicant must provide assurance that its principal design criteria encompass all those facility design features required in the interest of public health and safety. There may be some power reactor cases for which fulfillment of some of the General Design Criteria may not be necessary or appropriate. There will be other cases in which these criteria are insufficient, and additional criteria must be identified and satisfied by the design in the interest of public safety. It is expected that additional criteria will be needed particularly for unusual sites and environmental conditions, and for new and advanced types of reactors. Within this context, the General Design Criteria should be used as a reference allowing additions or deletions as an individual case may warrant. Departures from the General Design Criteria should be justified.

The criteria are designated as "General Design Criteria for Nuclear Power Plant Construction Permits" to emphasize the key role they assume at this stage of the licensing process. The criteria have been categorized as Category A or Category B. Experience has shown that more definitive information is needed at the construction permit stage for the items listed in Category A than for those in Category B.

I. OVERALL PLANT REQUIREMENTS

CRITERION 1 - QUALITY STANDARDS (Category A)

Those systems and components of reactor facilities which are essential to the prevention of accidents which could affect the public health and safety or to mitigation of their consequences shall be identified and then designed, fabricated, and erected to quality standards that reflect the importance of the safety function to be performed. Where generally recognized codes or standards on design, materials, fabrication, and inspection are used, they shall be identified. Where adherence to such codes or standards does not suffice to assure a quality product in keeping with the safety function, they shall be supplemented or modified as necessary. Quality assurance programs, test procedures, and inspection acceptance levels to be used shall be identified. A showing of sufficiency and applicability of codes, standards, quality assurance programs, test procedures, and inspection acceptance levels used is required.

CRITERION 2 - PERFORMANCE STANDARDS (Category A)

Those systems and components of reactor facilities which are essential to the prevention of accidents which could affect the public health and safety or to mitigation of their consequences shall be designed, fabricated, and erected to performance standards that will enable the facility to withstand, without loss of the capability to protect the public, the additional forces that might be imposed by natural phenomena such as earthquakes, tornadoes, flooding conditions, winds, ice, and other local site effects. The design

bases so established shall reflect: (a) appropriate consideration of the most severe of these natural phenomena that have been recorded for the site and the surrounding area and (b) an appropriate margin for withstanding forces greater than those recorded to reflect uncertainties about the historical data and their suitability as a basis for design.

CRITERION 3 - FIRE PROTECTION (Category A)

The reactor facility shall be designed (1) to minimize the probability of events such as fires and explosions and (2) to minimize the potential effects of such events to safety. Noncombustible and fire resistant materials shall be used whenever practical throughout the facility, particularly in areas containing critical portions of the facility such as containment, control room, and components of engineered safety features.

CRITERION 4 - SHARING OF SYSTEMS (Category A)

Reactor facilities shall not share systems or components unless it is shown safety is not impaired by the sharing.

CRITERION 5 - RECORDS REQUIREMENTS (Category A)

Records of the design, fabrication, and construction of essential components of the plant shall be maintained by the reactor operator or under its control throughout the life of the reactor.

II. PROTECTION BY MULTIPLE FISSION PRODUCT BARRIERS

CRITERION 6 - REACTOR CORE DESIGN (Category A)

The reactor core shall be designed to function throughout its design lifetime, without exceeding acceptable fuel damage limits which have been

stipulated and justified. The core design, together with reliable process and decay heat removal systems, shall provide for this capability under all expected conditions of normal operation with appropriate margins for uncertainties and for transient situations which can be anticipated, including the effects of the loss of power to recirculation pumps, tripping out of a turbine generator set, isolation of the reactor from its primary heat sink, and loss of all off-site power.

CRITERION 7 - SUPPRESSION OF POWER OSCILLATIONS (Category B)

The core design, together with reliable controls, shall ensure that power oscillations which could cause damage in excess of acceptable fuel damage limits are not possible or can be readily suppressed.

CRITERION 8 - OVERALL POWER COEFFICIENT (Category B)

The reactor shall be designed so that the overall power coefficient in the power operating range shall not be positive.

CRITERION 9 - REACTOR COOLANT PRESSURE BOUNDARY (Category A)

The reactor coolant pressure boundary shall be designed and constructed so as to have an exceedingly low probability of gross rupture or significant leakage throughout its design lifetime.

CRITERION 10 - CONTAINMENT (Category A)

Containment shall be provided. The containment structure shall be designed to sustain the initial effects of gross equipment failures, such as a large coolant boundary break, without loss of required integrity and, together with other engineered safety features as may be necessary, to retain for as long as the situation requires the functional capability to protect the public.

III. NUCLEAR AND RADIATION CONTROLS

CRITERION 11 - CONTROL ROOM (Category B)

The facility shall be provided with a control room from which actions to maintain safe operational status of the plant can be controlled. Adequate radiation protection shall be provided to permit access, even under accident conditions, to equipment in the control room or other areas as necessary to shut down and maintain safe control of the facility without radiation exposures of personnel in excess of 10 CFR 20 limits. It shall be possible to shut the reactor down and maintain it in a safe condition if access to the control room is lost due to fire or other cause.

CRITERION 12 - INSTRUMENTATION AND CONTROL SYSTEMS (Category B)

Instrumentation and controls shall be provided as required to monitor and maintain variables within prescribed operating ranges.

CRITERION 13 - FISSION PROCESS MONITORS AND CONTROLS (Category B)

Means shall be provided for monitoring and maintaining control over the fission process throughout core life and for all conditions that can reasonably be anticipated to cause variations in reactivity of the core, such as indication of position of control rods and concentration of soluble reactivity control poisons.

CRITERION 14 - CORE PROTECTION SYSTEMS (Category B)

Core protection systems, together with associated equipment, shall be designed to act automatically to prevent or to suppress conditions that could result in exceeding acceptable fuel damage limits.

CRITERION 15 - ENGINEERED SAFETY FEATURES PROTECTION SYSTEMS (Category B)

Protection systems shall be provided for sensing accident situations and initiating the operation of necessary engineered safety features.

CRITERION 16 - MONITORING REACTOR COOLANT PRESSURE BOUNDARY (Category B)

Means shall be provided for monitoring the reactor coolant pressure boundary to detect leakage.

CRITERION 17 - MONITORING RADIOACTIVITY RELEASES (Category B)

Means shall be provided for monitoring the containment atmosphere, the facility effluent discharge paths, and the facility environs for radioactivity that could be released from normal operations, from anticipated transients, and from accident conditions.

CRITERION 18 - MONITORING FUEL AND WASTE STORAGE (Category B)

Monitoring and alarm instrumentation shall be provided for fuel and waste storage and handling areas for conditions that might contribute to loss of continuity in decay heat removal and to radiation exposures.

IV. RELIABILITY AND TESTABILITY OF PROTECTION SYSTEMS

CRITERION 19 - PROTECTION SYSTEMS RELIABILITY (Category B)

Protection systems shall be designed for high functional reliability and in-service testability commensurate with the safety functions to be performed.

CRITERION 20 - PROTECTION SYSTEMS REDUNDANCY AND INDEPENDENCE (Category B)

Redundancy and independence designed into protection systems shall be sufficient to assure that no single failure or removal from service of any

component or channel of a system will result in loss of the protection function. The redundancy provided shall include, as a minimum, two channels of protection for each protection function to be served. Different principles shall be used where necessary to achieve true independence of redundant instrumentation components.

CRITERION 21 - SINGLE FAILURE DEFINITION (Category B)

Multiple failures resulting from a single event shall be treated as a single failure.

CRITERION 22 - SEPARATION OF PROTECTION AND CONTROL INSTRUMENTATION SYSTEMS (Category B)

Protection systems shall be separated from control instrumentation systems to the extent that failure or removal from service of any control instrumentation system component or channel, or of those common to control instrumentation and protection circuitry, leaves intact a system satisfying all requirements for the protection channels.

CRITERION 23 - PROTECTION AGAINST MULTIPLE DISABILITY FOR PROTECTION SYSTEMS (Category B)

The effects of adverse conditions to which redundant channels or protection systems might be exposed in common, either under normal conditions or those of an accident, shall not result in loss of the protection function.

CRITERION 24 - EMERGENCY POWER FOR PROTECTION SYSTEMS (Category B)

In the event of loss of all offsite power, sufficient alternate sources of power shall be provided to permit the required functioning of the protection systems.

CRITERION 25 - DEMONSTRATION OF FUNCTIONAL OPERABILITY OF PROTECTION SYSTEMS
(Category B)

Means shall be included for testing protection systems while the reactor is in operation to demonstrate that no failure or loss of redundancy has occurred.

CRITERION 26 - PROTECTION SYSTEMS FAIL-SAFE DESIGN (Category B)

The protection systems shall be designed to fail into a safe state or into a state established as tolerable on a defined basis if conditions such as disconnection of the system, loss of energy (e.g., electric power, instrument air), or adverse environments (e.g., extreme heat or cold, fire, steam, or water) are experienced.

V. REACTIVITY CONTROL

CRITERION 27 - REDUNDANCY OF REACTIVITY CONTROL (Category A)

At least two independent reactivity control systems, preferably of different principles, shall be provided.

CRITERION 28 - REACTIVITY HOT SHUTDOWN CAPABILITY (Category A)

At least two of the reactivity control systems provided shall independently be capable of making and holding the core subcritical from any hot standby or hot operating condition, including those resulting from power changes, sufficiently fast to prevent exceeding acceptable fuel damage limits.

CRITERION 29 - REACTIVITY SHUTDOWN CAPABILITY (Category A)

At least one of the reactivity control systems provided shall be capable of making the core subcritical under any condition (including anticipated operational transients) sufficiently fast to prevent exceeding acceptable fuel

damage limits. Shutdown margins greater than the maximum worth of the most effective control rod when fully withdrawn shall be provided.

CRITERION 30 - REACTIVITY HOLDDOWN CAPABILITY (Category B)

At least one of the reactivity control systems provided shall be capable of making and holding the core subcritical under any conditions with appropriate margins for contingencies.

CRITERION 31 - REACTIVITY CONTROL SYSTEMS MALFUNCTION (Category B)

The reactivity control systems shall be capable of sustaining any single malfunction, such as, unplanned continuous withdrawal (not ejection) of a control rod, without causing a reactivity transient which could result in exceeding acceptable fuel damage limits.

CRITERION 32 - MAXIMUM REACTIVITY WORTH OF CONTROL RODS (Category A)

Limits, which include considerable margin, shall be placed on the maximum reactivity worth of control rods or elements and on rates at which reactivity can be increased to ensure that the potential effects of a sudden or large change of reactivity cannot (a) rupture the reactor coolant pressure boundary or (b) disrupt the core, its support structures, or other vessel internals sufficiently to impair the effectiveness of emergency core cooling.

VI. REACTOR COOLANT PRESSURE BOUNDARY

CRITERION 33 - REACTOR COOLANT PRESSURE BOUNDARY CAPABILITY (Category A)

The reactor coolant pressure boundary shall be capable of accommodating without rupture, and with only limited allowance for energy absorption through plastic deformation, the static and dynamic loads imposed on any boundary

component as a result of any inadvertent and sudden release of energy to the coolant. As a design reference, this sudden release shall be taken as that which would result from a sudden reactivity insertion such as rod ejection (unless prevented by positive mechanical means), rod dropout, or cold water addition.

CRITERION 34 - REACTOR COOLANT PRESSURE BOUNDARY RAPID PROPAGATION FAILURE PREVENTION (Category A)

The reactor coolant pressure boundary shall be designed to minimize the probability of rapidly propagating type failures. Consideration shall be given (a) to the notch-toughness properties of materials extending to the upper shelf of the Charpy transition curve, (b) to the state of stress of materials under static and transient loadings, (c) to the quality control specified for materials and component fabrication to limit flaw sizes, and (d) to the provisions for control over service temperature and irradiation effects which may require operational restrictions.

CRITERION 35 - REACTOR COOLANT PRESSURE BOUNDARY BRITTLE FRACTURE PREVENTION (Category A)

Under conditions where reactor coolant pressure boundary system components constructed of ferritic materials may be subjected to potential loadings, such as a reactivity-induced loading, service temperatures shall be at least 120°F above the nil ductility transition (NDT) temperature of the component material if the resulting energy release is expected to be absorbed by plastic deformation or 60°F above the NDT temperature of the component material if the resulting energy release is expected to be absorbed within the elastic strain energy range.

CRITERION 36 - REACTOR COOLANT PRESSURE BOUNDARY SURVEILLANCE (Category A)

Reactor coolant pressure boundary components shall have provisions for inspection, testing, and surveillance by appropriate means to assess the structural and leaktight integrity of the boundary components during their service lifetime. For the reactor vessel, a material surveillance program conforming with ASTM-E-185-66 shall be provided.

VII. ENGINEERED SAFETY FEATURES

CRITERION 37 - ENGINEERED SAFETY FEATURES BASIS FOR DESIGN (Category A)

Engineered safety features shall be provided in the facility to back up the safety provided by the core design, the reactor coolant pressure boundary, and their protection systems. As a minimum, such engineered safety features shall be designed to cope with any size reactor coolant pressure boundary break up to and including the circumferential rupture of any pipe in that boundary assuming unobstructed discharge from both ends.

CRITERION 38 - RELIABILITY AND TESTABILITY OF ENGINEERED SAFETY FEATURES (Category A)

All engineered safety features shall be designed to provide high functional reliability and ready testability. In determining the suitability of a facility for a proposed site, the degree of reliance upon and acceptance of the inherent and engineered safety afforded by the systems, including engineered safety features, will be influenced by the known and the demonstrated performance capability and reliability of the systems, and by the extent to which the operability of such systems can be tested and inspected where appropriate during the life of the plant.

CRITERION 39 - EMERGENCY POWER FOR ENGINEERED SAFETY FEATURES (Category A)

Alternate power systems shall be provided and designed with adequate independency, redundancy, capacity, and testability to permit the functioning required of the engineered safety features. As a minimum, the onsite power system and the offsite power system shall each, independently, provide this capacity assuming a failure of a single active component in each power system.

CRITERION 40 - MISSILE PROTECTION (Category A)

Protection for engineered safety features shall be provided against dynamic effects and missiles that might result from plant equipment failures.

CRITERION 41 - ENGINEERED SAFETY FEATURES PERFORMANCE CAPABILITY (Category A)

Engineered safety features such as emergency core cooling and containment heat removal systems shall provide sufficient performance capability to accommodate partial loss of installed capacity and still fulfill the required safety function. As a minimum, each engineered safety feature shall provide this required safety function assuming a failure of a single active component.

CRITERION 42 - ENGINEERED SAFETY FEATURES COMPONENTS CAPABILITY (Category A)

Engineered safety features shall be designed so that the capability of each component and system to perform its required function is not impaired by the effects of a loss-of-coolant accident.

CRITERION 43 - ACCIDENT AGGRAVATION PREVENTION (Category A)

Engineered safety features shall be designed so that any action of the engineered safety features which might accentuate the adverse after-effects of the loss of normal cooling is avoided.

CRITERION 44 - EMERGENCY CORE COOLING SYSTEMS CAPABILITY (Category A)

At least two emergency core cooling systems, preferably of different design principles, each with a capability for accomplishing abundant emergency core cooling, shall be provided. Each emergency core cooling system and the core shall be designed to prevent fuel and clad damage that would interfere with the emergency core cooling function and to limit the clad metal-water reaction to negligible amounts for all sizes of breaks in the reactor coolant pressure boundary, including the double-ended rupture of the largest pipe. The performance of each emergency core cooling system shall be evaluated conservatively in each area of uncertainty. The systems shall not share active components and shall not share other features or components unless it can be demonstrated that (a) the capability of the shared feature or component to perform its required function can be readily ascertained during reactor operation, (b) failure of the shared feature or component does not initiate a loss-of-coolant accident, and (c) capability of the shared feature or component to perform its required function is not impaired by the effects of a loss-of-coolant accident and is not lost during the entire period this function is required following the accident.

CRITERION 45 - INSPECTION OF EMERGENCY CORE COOLING SYSTEMS (Category A)

Design provisions shall be made to facilitate physical inspection of all critical parts of the emergency core cooling systems, including reactor vessel internals and water injection nozzles.

CRITERION 46 - TESTING OF EMERGENCY CORE COOLING SYSTEMS COMPONENTS (Category A)

Design provisions shall be made so that active components of the emergency core cooling systems, such as pumps and valves, can be tested periodically for operability and required functional performance.

CRITERION 47 - TESTING OF EMERGENCY CORE COOLING SYSTEMS (Category A)

A capability shall be provided to test periodically the delivery capability of the emergency core cooling systems at a location as close to the core as is practical.

CRITERION 48 - TESTING OF OPERATIONAL SEQUENCE OF EMERGENCY CORE COOLING SYSTEMS (Category A)

A capability shall be provided to test under conditions as close to design as practical the full operational sequence that would bring the emergency core cooling systems into action, including the transfer to alternate power sources.

CRITERION 49 - CONTAINMENT DESIGN BASIS (Category A)

The containment structure, including access openings and penetrations, and any necessary containment heat removal systems shall be designed so that the containment structure can accommodate without exceeding the design leakage rate the pressures and temperatures resulting from the largest credible energy release following a loss-of-coolant accident, including a considerable margin for effects from metal-water or other chemical reactions that could occur as a consequence of failure of emergency core cooling systems.

CRITERION 50 - NDT REQUIREMENT FOR CONTAINMENT MATERIAL (Category A)

Principal load carrying components of ferritic materials exposed to the external environment shall be selected so that their temperatures under normal

operating and testing conditions are not less than 30°F above nil ductility transition (NDT) temperature.

CRITERION 51 - REACTOR COOLANT PRESSURE BOUNDARY OUTSIDE CONTAINMENT (Category A)

If part of the reactor coolant pressure boundary is outside the containment, appropriate features as necessary shall be provided to protect the health and safety of the public in case of an accidental rupture in that part. Determination of the appropriateness of features such as isolation valves and additional containment shall include consideration of the environmental and population conditions surrounding the site.

CRITERION 52 - CONTAINMENT HEAT REMOVAL SYSTEMS (Category A)

Where active heat removal systems are needed under accident conditions to prevent exceeding containment design pressure, at least two systems, preferably of different principles, each with full capacity, shall be provided.

CRITERION 53 - CONTAINMENT ISOLATION VALVES (Category A)

Penetrations that require closure for the containment function shall be protected by redundant valving and associated apparatus.

CRITERION 54 - CONTAINMENT LEAKAGE RATE TESTING (Category A)

Containment shall be designed so that an integrated leakage rate testing can be conducted at design pressure after completion and installation of all penetrations and the leakage rate measured over a sufficient period of time to verify its conformance with required performance.

CRITERION 55 - CONTAINMENT PERIODIC LEAKAGE RATE TESTING (Category A)

The containment shall be designed so that integrated leakage rate testing can be done periodically at design pressure during plant lifetime.

CRITERION 56 - PROVISIONS FOR TESTING OF PENETRATIONS (Category A)

Provisions shall be made for testing penetrations which have resilient seals or expansion bellows to permit leaktightness to be demonstrated at design pressure at any time.

CRITERION 57 - PROVISIONS FOR TESTING OF ISOLATION VALVES (Category A)

Capability shall be provided for testing functional operability of valves and associated apparatus essential to the containment function for establishing that no failure has occurred and for determining that valve leakage does not exceed acceptable limits.

CRITERION 58 - INSPECTION OF CONTAINMENT PRESSURE-REDUCING SYSTEMS (Category A)

Design provisions shall be made to facilitate the periodic physical inspection of all important components of the containment pressure-reducing systems, such as, pumps, valves, spray nozzles, torus, and sumps.

CRITERION 59 - TESTING OF CONTAINMENT PRESSURE-REDUCING SYSTEMS COMPONENTS (Category A)

The containment pressure-reducing systems shall be designed so that active components, such as pumps and valves, can be tested periodically for operability and required functional performance.

CRITERION 60 - TESTING OF CONTAINMENT SPRAY SYSTEMS (Category A)

A capability shall be provided to test periodically the delivery capability of the containment spray system at a position as close to the spray

nozzles as is practical.

CRITERION 61 - TESTING OF OPERATIONAL SEQUENCE OF CONTAINMENT PRESSURE-REDUCING SYSTEMS (Category A)

A capability shall be provided to test under conditions as close to the design as practical the full operational sequence that would bring the containment pressure-reducing systems into action, including the transfer to alternate power sources.

CRITERION 62 - INSPECTION OF AIR CLEANUP SYSTEMS (Category A)

Design provisions shall be made to facilitate physical inspection of all critical parts of containment air cleanup systems, such as, ducts, filters, fans, and dampers.

CRITERION 63 - TESTING OF AIR CLEANUP SYSTEMS COMPONENTS (Category A)

Design provisions shall be made so that active components of the air cleanup systems, such as fans and dampers, can be tested periodically for operability and required functional performance.

CRITERION 64 - TESTING OF AIR CLEANUP SYSTEMS (Category A)

A capability shall be provided for in situ periodic testing and surveillance of the air cleanup systems to ensure (a) filter bypass paths have not developed and (b) filter and trapping materials have not deteriorated beyond acceptable limits.

CRITERION 65 - TESTING OF OPERATIONAL SEQUENCE OF AIR CLEANUP SYSTEMS (Category A)

A capability shall be provided to test under conditions as close to design as practical the full operational sequence that would bring the air cleanup

systems into action, including the transfer to alternate power sources and the design air flow delivery capability.

VIII. FUEL AND WASTE STORAGE SYSTEMS

CRITERION 66 - PREVENTION OF FUEL STORAGE CRITICALITY (Category B)

Criticality in new and spent fuel storage shall be prevented by physical systems or processes. Such means as geometrically safe configurations shall be emphasized over procedural controls.

CRITERION 67 - FUEL AND WASTE STORAGE DECAY HEAT (Category B)

Reliable decay heat removal systems shall be designed to prevent damage to the fuel in storage facilities that could result in radioactivity release to plant operating areas or the public environs.

CRITERION 68 - FUEL AND WASTE STORAGE RADIATION SHIELDING (Category B)

Shielding for radiation protection shall be provided in the design of spent fuel and waste storage facilities as required to meet the requirements of 10 CFR 20.

CRITERION 69 - PROTECTION AGAINST RADIOACTIVITY RELEASE FROM SPENT FUEL AND WASTE STORAGE (Category B)

Containment of fuel and waste storage shall be provided if accidents could lead to release of undue amounts of radioactivity to the public environs.

IX. PLANT EFFLUENTS


CRITERION 70 - CONTROL OF RELEASES OF RADIOACTIVITY TO THE ENVIRONMENT (Category B)

The facility design shall include those means necessary to maintain control over the plant radioactive effluents, whether gaseous, liquid, or solid. Appropriate holdup capacity shall be provided for retention of gaseous, liquid, or solid effluents, particularly where unfavorable environmental conditions can be expected to require operational limitations upon the release of radioactive effluents to the environment. In all cases, the design for radioactivity control shall be justified (a) on the basis of 10 CFR 20 requirements for normal operations and for any transient situation that might reasonably be anticipated to occur and (b) on the basis of 10 CFR 100 dosage level guidelines for potential reactor accidents of exceedingly low probability of occurrence except that reduction of the recommended dosage levels may be required where high population densities or very large cities can be affected by the radioactive effluents.

(Sec. 161, 68 Stat. 948; 42 U.S.C. 2201)

Dated at Washington, D. C. this twenty-eighth
day of June, 1967.

For the Atomic Energy Commission.



W. B. McCool
Secretary