

January 21, 2000

Mr. Douglas R. Gipson  
Senior Vice President  
Nuclear Generation  
Detroit Edison Company  
6400 North Dixie Highway  
Newport, MI 48166

SUBJECT: COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 99-02,  
"LABORATORY TESTING OF NUCLEAR-GRADE ACTIVATED CHARCOAL" -  
FERMI 2 (TAC NO. MA5793)

Dear Mr. Gipson:

On June 3, 1999, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 99-02, "Laboratory Testing of Nuclear-Grade Activated Charcoal," to all holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

The purpose of the GL was to:

- (1) Alert addressees that the NRC has determined that testing nuclear-grade activated charcoal to standards other than American Society for Testing and Materials (ASTM) D3803-1989, "Standard Test Method for Nuclear-Grade Activated Carbon," does not provide assurance for complying with the current licensing basis as it relates to the dose limits of General Design Criterion 19 of Appendix A to Part 50 of Title 10 of the *Code of Federal Regulations* (10 CFR) and Subpart A of 10 CFR Part 100.
- (2) Request that all addressees determine whether their Technical Specifications (TS) reference ASTM D3803-1989 for charcoal filter laboratory testing. Addressees whose TS do not reference ASTM D3803-1989 should either amend their TS to reference ASTM D3803-1989 or propose an alternative test protocol and provide the information discussed in the requested actions.
- (3) Alert addressees to the staff's intent to exercise enforcement discretion under certain conditions.
- (4) Request that all addressees send the NRC written responses to this generic letter relating to implementation of the requested actions.

In GL 99-02, the NRC staff established the following four groups of plants:

- (1) plants in compliance with their TS that test in accordance with ASTM D3803-1989
- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

D. R. Gipson

- 2 -

- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided a letter dated October 7, 1999, for Fermi 2. This submittal indicated that yours is a Group 1 plant. The staff has reviewed your response and has concluded that all requested information has been provided; therefore, we consider GL 99-02 to be closed for your facility. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me at (301) 415-2828.

Sincerely,

*/RA/*

Andrew J. Kugler, Project Manager, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-341

cc: See next page

D. R. Gipson

- 2 -

- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided a letter dated October 7, 1999, for Fermi 2. This submittal indicated that yours is a Group 1 plant. The staff has reviewed your response and has concluded that all requested information has been provided; therefore, we consider GL 99-02 to be closed for your facility. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me at (301) 415-2828.

Sincerely,

*/RA/*

Andrew J. Kugler, Project Manager, Section 1  
 Project Directorate III  
 Division of Licensing Project Management  
 Office of Nuclear Reactor Regulation

Docket No. 50-341

cc: See next page

DISTRIBUTION:

File Center  
 PUBLIC  
 PDIII-1 Reading  
 OGC  
 ACRS  
 BMozafari  
 JSegala  
 JHannon  
 AVegel, RIII

TO RECEIVE A COPY OF THIS DOCUMENT, INDICATE "C" IN THE BOX

|        |            |   |            |   |           |  |         |         |            |  |
|--------|------------|---|------------|---|-----------|--|---------|---------|------------|--|
| OFFICE | PDIII-1/PM | C | PDIII-1/LA | C | LPM       |  | SPLB/SC |         | PDIII-1/SC |  |
| NAME   | AKugler    |   | RBouling   |   | BMozafari |  | EWeiss  | CCraig  |            |  |
| DATE   | 12/27/99   |   | 12/23/99   |   | 12/28/99  |  | 1/18/00 | 1/19/00 |            |  |

DOCUMENT NAME: C:\Ltr-A5793.wpd

OFFICIAL RECORD COPY

Fermi 2

cc:

John Flynn, Esquire  
Senior Attorney  
Detroit Edison Company  
2000 Second Avenue  
Detroit, MI 48226

Drinking Water and Radiological  
Protection Division  
Michigan Department of  
Environmental Quality  
3423 N. Martin Luther King Jr Blvd  
P. O. Box 30630 CPH Mailroom  
Lansing, MI 48909-8130

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
6450 W. Dixie Highway  
Newport, MI 48166

Monroe County Emergency Management  
Division  
963 South Raisinville  
Monroe, MI 48161

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, IL 60532-4351

Norman K. Peterson  
Director, Nuclear Licensing  
Detroit Edison Company  
Fermi 2 - 280 TAC  
6400 North Dixie Highway  
Newport, MI 48166

November 1999