

Date Entered: Jan 11, 2000

TO: USNRC/WASHINGTON  
JMCKNIGHT  
Copy Number: 145

TRANSMITTAL NUMBER: 139566

PROCEDURE NUMBER: EI-1

TITLE: EMERGENCY CLASSIFICATION AND ACTIONS

TRANSMITTAL: LISTED BELOW ARE NEW/REVISED PROCEDURES WHICH MUST BE IMMEDIATELY INSERTED INTO OR DISCARDED FROM YOUR PROCEDURE MANUAL.

Action Required	Section or Description
REMOVE AND DESTROY	EI-1, R/32, COVERSHEET AND ATTACHMENT 1, PAGE 2
REPLACE WITH	EI-1, R/32, COVERSHEET AND ATTACHMENT 1, PAGE 2 EDITORIAL

**SIGN, DATE, AND RETURN THE ACKNOWLEDGEMENT FORM WITHIN 10 DAYS TO THE PALISADES PLANT DOCUMENT CONTROL.**

SIGNATURE OR INITIALS

DATE

\_\_\_\_\_

\_\_\_\_\_

A045



**SITE EMERGENCY PLAN CLASSIFICATION**

**COMMUNICATION LOSS**

CLASSIFICATION	EMERGENCY ACTION LEVEL	METHOD OF DETECTION	ACTIONS
Unusual Event	Significant loss of offsite communication capability.  <b>NOTE:</b> For failures of the Palisades Public Warning System, see Palisades Administrative Procedure 4.00, "Operations Organization, Responsibilities and Conduct," Section 5.5.	Loss of the Emergency Notification System (ENS), and all other phones including satellite phones, that could be used to make notifications to Van Buren County, the State of Michigan and the NRC.  <b>NOTE:</b> The availability of one phone is sufficient to inform offsite authorities of plant problems.	Mandatory: 1, 3, 4, 6, 7, 12  Subsequent: 15, 23  If Needed: None