



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

ENTERGY OPERATIONS INC.

DOCKET NO. 50-313

ARKANSAS NUCLEAR ONE, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 203
License No. DPR-51

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Entergy Operations, Inc. (the licensee) dated December 16, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-51 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 203 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Gramm, Chief, Section 1
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: January 13, 2000

ATTACHMENT TO LICENSE AMENDMENT NO. 203

FACILITY OPERATING LICENSE NO. DPR-51

DOCKET NO. 50-313

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Remove

110ml

Insert

110ml

- b. The steam generator shall be determined operable after completing the corresponding actions (plug, reroll, or sleeve all tubes exceeding the plugging limit and all tubes containing non-TEC through-wall cracks) required by Table 4.18-2.

Tube 110/60 in the "A" steam generator contains indications in the upper roll transition that exceed the plugging limit. Tube 110/60 may remain in service with these indications for the duration of cycle 16 without rendering the "A" steam generator inoperable.

4.18.6 Reports

Following each inservice inspection of steam generator tubes, the complete results of the inspection shall be reported to the NRC. This report, to be submitted within 90 days of inspection completion, shall include:

- a. Number and extent of tubes inspected;
- b. Location and percent of wall-thickness penetration for each indication of an imperfection;
- c. Identification of tubes plugged and tubes sleeved;
- d. Number of tubes repaired by rerolling and number of indications detected in the new roll area of the repaired tubes;
- e. Summary of the condition monitoring and operational assessment results when applying TEC alternate repair criteria; and
- f. Summary of the condition monitoring and the operational assessment results (including growth) when applying the upper tubesheet ODIGA alternate repair criteria.

This report shall be in addition to a Special Report (per Specification 6.12.5.d) required for the results of steam generator tube inspections which fall into Category C-3 as denoted in Table 4.18-2. The Commission shall be notified of the results of steam generator tube inspections which fall into Category C-3 prior to resumption of plant operation. The written Special Report shall provide a description of investigations conducted to determine cause of the tube degradation and corrective measures taken to prevent recurrence.