

January 31, 2000

Mr. Ted C. Feigenbaum
Executive Vice President and
Chief Nuclear Officer
North Atlantic Energy Service Corporation
c/o Mr. James M. Peschel
P.O. Box 300
Seabrook, NH 03874

SUBJECT: SEABROOK STATION, UNIT 1, CLOSEOUT OF GENERIC LETTER 97-06,
"DEGRADATION OF STEAM GENERATOR INTERNALS" (TAC NO. MA0944)

Dear Mr. Feigenbaum:

On December 31, 1997, the staff issued Generic Letter (GL) 97-06, "Degradation of Steam Generator Internals." The purpose of GL 97-06 was to obtain information that would enable the staff to verify that the condition of licensees' steam generator internals complies with and conforms to the current licensing bases for their respective facilities. The staff has now completed its review of the GL.

By letter dated March 30, 1998, you responded to GL 97-06. The staff's review of your response to the GL did not identify any new concerns with the condition of the steam generator internals. The staff did not identify any concerns with the inspection practices employed at your facility to detect degradation of steam generator internals. The staff, therefore, concludes that your response to the GL provides reasonable assurance that the condition of your steam generator internals are in compliance with the current licensing bases for your facility.

The detailed technical basis that supports the staff's determination for all facilities will be published in a NUREG report. The expected publication date is January 2000. This completes the staff's effort on TAC No. MA0944.

Sincerely,

/RA/

Robert M. Pulsifer, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-443

cc: See next page

January 31, 2000

Mr. Ted C. Feigenbaum
Executive Vice President and
Chief Nuclear Officer
North Atlantic Energy Service Corporation
c/o Mr. James M. Peschel
P.O. Box 300
Seabrook, NH 03874

SUBJECT: SEABROOK STATION, UNIT 1, CLOSEOUT OF GENERIC LETTER 97-06,
"DEGRADATION OF STEAM GENERATOR INTERNALS" (TAC NO. MA0944)

Dear Mr. Feigenbaum:

On December 31, 1997, the staff issued Generic Letter (GL) 97-06, "Degradation of Steam Generator Internals." The purpose of GL 97-06 was to obtain information that would enable the staff to verify that the condition of licensees' steam generator internals complies with and conforms to the current licensing bases for their respective facilities. The staff has now completed its review of the GL.

By letter dated March 30, 1998, you responded to GL 97-06. The staff's review of your response to the GL did not identify any new concerns with the condition of the steam generator internals. The staff did not identify any concerns with the inspection practices employed at your facility to detect degradation of steam generator internals. The staff, therefore, concludes that your response to the GL provides reasonable assurance that the condition of your steam generator internals are in compliance with the current licensing bases for your facility.

The detailed technical basis that supports the staff's determination for all facilities will be published in a NUREG report. The expected publication date is January 2000. This completes the staff's effort on TAC No. MA0944.

Sincerely,

/RA/

Robert M. Pulsifer, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-443

cc: See next page

DISTRIBUTION:

File Center	PUBLIC	PDI-2 r/f
EAdensam (EGA1)	JClifford	RPulsifer
TClark	OGC	ACRS
CAnderson, RI		

FILENAME:

*Input provided by memo dated 09/16/99 with no significant changes

OFFICE	PDI-2/PM	PDI-2/LA	EMCB*	PDI-2/SC
NAME	RPulsifer/vw	TClark	ESullivan	JClifford
DATE	1/ 24/00	1/2/00	09 /16 /99	1/28/00

OFFICIAL RECORD COPY

PD I-2 DOCUMENT COVER PAGE

NEED DATE: _____
LOG NO.: 2039

DOCUMENT NAME: C:\SMA0944.WPD

SUBJECT: SEABROOK STATION, UNIT 1, CLOSEOUT OF
GENERIC LETTER 97-06, "DEGRADATION OF STEAM
GENERATOR INTERNALS" (TAC NO. MA0944)

ORIGINATOR: R. PULSIFER

SECRETARY: V. WILLIAMS

DATE: February 8, 2000

●●● ROUTING LIST ●●●

	NAME	DATE
1.	<u>RPulsifer</u>	<u>1/24/00</u>
2.	<u>TClark</u>	<u>1/21/00</u>
3.	<u>ESullivan</u>	<u>09/16/99</u>
4.	<u>JClifford</u>	<u>1/28/00</u>
5.	<u> / /00</u>	

Considered others impacted by staff action (2.206 petitions, open allegations, Congressional or public inquiries, significant enforcement actions, inspection activities, Commission policies, staff positions, Owners Group activities): Yes ___ No ___ NA ___ Initial: PM ___ PD ___

Communicated w/identified stakeholder(s): Yes ___ No ___ NA ___ Initial: PM ___ PD ___

Licensee assessment considered: PM ___ / PD ___

Can Document be Deleted after Dispatch? _____