



**Northeast  
Nuclear Energy**

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385-0128  
(860) 447-1791  
Fax (860) 444-4277

The Northeast Utilities System

JAN 13 2000

Docket No. 50-336  
B17968

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555

Millstone Nuclear Power Station, Unit No. 2  
Deviations from the Licensing Basis of the Safety Parameter Display System -  
Updated Information

In a letter dated December 30, 1999,<sup>(1)</sup> Northeast Nuclear Energy Company (NNECO) provided the Staff an update to the remaining unresolved Millstone Nuclear Power Station Unit No. 2 (MP2) current licensing basis deviations with regards to the Safety Parameter Display System (SPDS). However, following this submittal and follow-up discussions with the MP2 Senior Resident Inspector, it was noted that one SPDS related item had not been adequately addressed. Specifically, it was noted that our licensing bases describes the SPDS as having color coded safety function status indicators and that this information had not been appropriately discussed in our response.

Although it was planned to modify the SPDS safety function indication panels to permit color coded safety function status indication, this action had not been formally docketed as a commitment. As a result, this letter is being submitted to serve that purpose. Presently, this activity is scheduled to be completed no later than the end of refueling outage 14.

Attachment 1 contains NNECO's commitment associated with this letter.

---

<sup>(1)</sup> Stephen E. Scace to U.S. Nuclear Regulatory Commission, "Millstone Nuclear Power Station, Unit No. 2 - Deviations From the Licensing Basis of the Safety Parameter Display System," dated December 30, 1999.

A00/

Docket No. 50-336  
B17968

Attachment 1

Millstone Nuclear Power Station, Unit No. 2

List of Regulatory Commitments

January 2000

### List of Regulatory Commitments

The following table identifies action committed to by NNECO in this document.

Number	Commitment	Due
B17968-01	Modify the Safety Parameter Display System to permit color coded safety function status indication.	Prior to the end of Refueling Outage 14

U.S. Nuclear Regulatory Commission  
B17968/Page 2

Should you have any questions regarding this submittal, please contact Mr. Ravi Joshi at (860) 440-2080.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

A handwritten signature in black ink that reads "Stephen E. Scace". The signature is written in a cursive style with a large, sweeping initial "S".

---

Stephen E. Scace  
Director - Nuclear Oversight and  
Regulatory Affairs

Attachment (1)

cc: H. J. Miller, Region I Administrator  
J. I. Zimmerman, NRC Project Manager, Millstone Unit No. 2  
D. P. Beaulieu, Senior Resident Inspector, Millstone Unit No. 2