

February 1, 2000

MEMORANDUM TO: File Center

FROM: Victor Nerses, Senior Project Manager, Section 2 */RA/*  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

SUBJECT: MILLSTONE, UNIT 3 , DRAFT REQUEST FOR ADDITIONAL  
INFORMATION, SPENT FUEL POOL RERACK, (TAC NO. MA5137)

The attached draft request for additional information (RAI) was transmitted by facsimile on February 1, 2000 to Mr. D. Dotson of Northeast Nuclear Energy Company. Review of the RAI would allow the licensee to determine and agree upon a schedule to respond to the RAI. This memorandum and the attachment do not convey a formal request for information or represent an NRC staff position.

Docket No. 50-423

Attachment:

February 1, 2000

MEMORANDUM TO: File Center

FROM: Victor Nerses, Senior Project Manager, Section 2 */RA/*  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

SUBJECT: MILLSTONE, UNIT 3 , DRAFT REQUEST FOR ADDITIONAL  
INFORMATION, SPENT FUEL POOL RERACK, (TAC NO. MA5137)

The attached draft request for additional information (RAI) was transmitted by facsimile on February 1, 2000 to Mr. D. Dotson of Northeast Nuclear Energy Company. Review of the RAI would allow the licensee to determine and agree upon a schedule to respond to the RAI. This memorandum and the attachment do not convey a formal request for information or represent an NRC staff position.

Docket No. 50-423

Attachment:

DISTRIBUTION

Docket File  
PUBLIC  
AHodgon, OGC  
Section Chief  
Project Manager

OFFICE	PDI, S2/PM	SRXB, SC
NAME	VNerses	
DATE	2/1/00	2/1/00

OFFICIAL RECORD COPY  
DOCUMENT NAME:

## **DRAFT**

### **Request for Additional Information for Millstone Unit 3 Spent Fuel Pool Reracking**

1. What are the minimum and maximum boron concentrations in the spent fuel pool specified by chemical procedures?
2. What are the procedures for surveillance of these boron concentrations?
3. Please describe the administrative procedure used to determine that fuel assemblies have attained proper burn-up for storage in the burn-up dependent racks.
4. Is there any procedure for verifying that fuel assemblies in the spent fuel pool are in the correct locations after fuel movements have ceased?
5. Where are these procedures documented?