

January 27, 2000

Mr. John S. Keenan, Vice President
Carolina Power & Light Company
Brunswick Steam Electric Plant
Post Office Box 10429
Southport, North Carolina 28461

SUBJECT: BRUNSWICK 1 AND 2 - COMPLETION OF LICENSING ACTION FOR
GL 99-02, "LABORATORY TESTING OF NUCLEAR-GRADE ACTIVATED
CHARCOAL" (TAC NOS. MA5769 AND MA5770)

Dear Mr. Keenan:

On June 3, 1999, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 99-02, "Laboratory Testing of Nuclear-Grade Activated Charcoal," to all holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

The purpose of the GL was to:

- (1) Alert addressees that the NRC has determined that testing nuclear-grade activated charcoal to standards other than American Society for Testing and Materials (ASTM) D3803-1989, "Standard Test Method for Nuclear-Grade Activated Carbon," does not provide assurance for complying with the current licensing basis as it relates to the dose limits of General Design Criterion (GDC) 19 of Appendix A to Part 50 of Title 10 of the *Code of Federal Regulations* (10 CFR) and Subpart A of 10 CFR Part 100.
- (2) Request that all addressees determine whether their Technical Specifications (TS) reference ASTM D3803-1989 for charcoal filter laboratory testing. Addressees whose TS do not reference ASTM D3803-1989 should either amend their TS to reference ASTM D3803-1989 or propose an alternative test protocol and provide the information discussed in the requested actions.
- (3) Alert addressees to the staff's intent to exercise enforcement discretion under certain conditions.
- (4) Request that all addressees send the NRC written responses on the implementation of the actions requested in this GL.

In GL 99-02, the NRC staff established the following four groups of plants:

- (1) plants in compliance with their TS that test in accordance with ASTM D3803-1989;
- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989;

- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989; and
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989.

In response to GL 99-02, you provided a letter dated November 24, 1999, for the Brunswick Steam Electric Plant. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL. The NRC staff has reviewed your response and has concluded that you have provided the requested information and a TS change request. In addition, you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, GL 99-02 is closed for your facility. The TS change will be reviewed as a separate, plant-specific action under TAC Nos. MA5769 and MA5770. Thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me.

Sincerely,

/RA/

Allen G. Hansen, Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-325 and 50-324

cc: See next page

- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989; and
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989.

In response to GL 99-02, you provided a letter dated November 24, 1999, for the Brunswick Steam Electric Plant. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL. The NRC staff has reviewed your response and has concluded that you have provided the requested information and a TS change request. In addition, you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, GL 99-02 is closed for your facility. The TS change will be reviewed as a separate, plant-specific action under TAC Nos. MA5769 and MA5770. Thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me.

Sincerely,

/RA/

Allen G. Hansen, Project Manager, Section 2
 Project Directorate II
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket Nos. 50-325 and 50-324

cc: See next page

DISTRIBUTION: File Center PUBLIC PDII Rdg. OGC ACRS
 JSegala JHannon BMozafari BBonser, RII

DOCUMENT NAME: G:\PDII-2\Brunswick\BRMA5767gl99-02closeout.wpd

OFFICE	PM:PD22	LA:PD22	LPM	SC: SPLB	SC:PD22
NAME	AHansen	EDunnington	BMozafari	SWest	RCorreia
DATE	1/5/00	1/4/00	1/5/00	1/18/00	1/19/00

OFFICIAL RECORD COPY

Mr. J. S. Keenan
Carolina Power & Light Company

Brunswick Steam Electric Plant
Units 1 and 2

cc:

Mr. William D. Johnson
Vice President and Corporate Secretary
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602

Ms. Karen E. Long
Assistant Attorney General
State of North Carolina
Post Office Box 629
Raleigh, North Carolina 27602

Mr. Jerry W. Jones, Chairman
Brunswick County Board of Commissioners
Post Office Box 249
Bolivia, North Carolina 28422

Mr. Robert P. Gruber
Executive Director
Public Staff - NCUC
Post Office Box 29520
Raleigh, North Carolina 27626-0520

Resident Inspector
U.S. Nuclear Regulatory Commission
8470 River Road
Southport, North Carolina 28461

Director
Site Operations
Brunswick Steam Electric Plant
Post Office Box 10429
Southport, North Carolina 28461

Mr. John H. O'Neill, Jr.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW.
Washington, DC 20037-1128

Mr. William H. Crowe, Mayor
City of Southport
201 East Moore Street
Southport, North Carolina 28461

Mr. Mel Fry, Director
Division of Radiation Protection
N.C. Department of Environment
and Natural Resources
3825 Barrett Dr.
Raleigh, North Carolina 27609-7721

Mr. Dan E. Summers
Emergency Management Coordinator
New Hanover County Department of
Emergency Management
Post Office Box 1525
Wilmington, North Carolina 28402

Mr. J. J. Lyash
Plant Manager
Carolina Power & Light Company
Brunswick Steam Electric Plant
Post Office Box 10429
Southport, North Carolina 28461

Mr. Terry C. Morton
Manager
Performance Evaluation and
Regulatory Affairs CPB 7
Carolina Power & Light Company
Post Office Box 1551
Raleigh, North Carolina 27602-1551

Public Service Commission
State of South Carolina
Post Office Drawer 11649
Columbia, South Carolina 29211

Mr. K. R. Jury
Manager - Regulatory Affairs
Carolina Power & Light Company
Post Office Box 10429
Southport, NC 28461-0429