

**DUKE POWER COMPANY
NUCLEAR GENERATION DEPARTMENT**

**ODCM
OFFSITE DOSE CALCULATION
MANUAL**



January 1, 2000

Subject: Offsite Dose Calculation Manual (ODCM)
Generic Section - Revision 43

The General Office Radiation Protection Staff is transmitting to you this date Revision 43 of the Offsite Dose Calculation Manual's Generic section. As this revision affects the manual's generic section, the approval of each station manager has been obtained. A list of affected pages is given below. Please insert this letter with the attached Justification section in front of the January 1, 1999, Revision 42 letter.

REMOVE THESE PAGES

iii
3-2

INSERT THESE PAGES

iii
3-2

Effective Date: 1/1/00

Effective Date: 1/1/00



L. E. Haynes, Technical Manager
Radiation Protection



R. A. Jones, Manager
Catawba Nuclear Station

Effective Date: 1/1/00

Effective Date: 1/1/00



D. M. Jamil, Manager
McGuire Nuclear Station



J. S. Forbes, Manager
Oconee Nuclear Station

If you have any questions concerning Revision 43, please call Caryl Ingram at (704) 382-4496.



Caryl D. Ingram, Senior Engineer
Radiation Protection
Nuclear Services Division

JUSTIFICATION FOR REVISION 43

(page 1 of 1)

Page iii

Sentence revised to include Technical Specifications as a location for ODCM reporting requirements in addition to the plant Selected Licensee Commitments.

Page 3-2

Definition of variables for the near field dilution equation revised for clarification.

GENERIC INFO

OFFSITE DOSE CALCULATION MANUAL

FOR

DUKE POWER NUCLEAR STATIONS

TABLE OF CONTENTS

<u>SECTION</u>	<u>Page</u>
INTRODUCTION	iii
1.0 <u>RELEASE RATE CALCULATIONS</u>	1-1
1.1 LIQUID EFFLUENTS	1-1
1.2 GASEOUS EFFLUENTS	1-1
1.2.1 <u>Noble Gases</u>	1-2
1.2.2 <u>Radioiodines, Particulates and Others</u>	1-3
2.0 <u>RADIATION MONITORING SETPOINTS</u>	2-1
2.1 LIQUID MONITORS	2-1
2.2 GAS MONITORS	2-1
3.0 <u>DOSE CALCULATIONS</u>	3-1
3.1 DOSE MODELS FOR MAXIMUM EXPOSED INDIVIDUAL	3-1
3.1.1 <u>Liquid Effluents</u>	3-1
3.1.2 <u>Gaseous Effluents</u>	3-2
3.1.2.1 Noble Gases	3-3
3.1.2.2 Radioiodines, Particulates, and Others	3-3
3.1.3 <u>Direct Radiation</u>	3-9
3.1.4 <u>Effluent Apportionment</u>	3-9
3.2 DOSE PROJECTIONS	3-10
3.3 FUEL CYCLE CALCULATIONS	3-10
3.3.1 <u>Milling</u>	3-10
3.3.2 <u>Conversion</u>	3-11
3.3.3 <u>Enrichment</u>	3-11
3.3.4 <u>Fuel Fabrication</u>	3-11
3.3.5 <u>Nuclear Power Production</u>	3-11
3.3.6 <u>Fuel Reprocessing</u>	3-12
Appendix A - Oconee Nuclear Station Site Specific Information	
Appendix B - McGuire Nuclear Station Site Specific Information	
Appendix C - Catawba Nuclear Station Site Specific Information	

LIST OF TABLES

Table 1.2-1	Dose Factors for Noble Gases and Daughters Dose Parameters for Radioiodines and Radioactive Particulate, Gaseous Effluents
Table 1.2-2	
Table 3.1-1	Bioaccumulation Factors to be Used in the Absence of Site Specific Data
Table 3.1-2	Ingestion Dose Factors for Adults
Table 3.1-3	Ingestion Dose Factors for Teenager
Table 3.1-4	Ingestion Dose Factors for Child
Table 3.1-5	Ingestion Dose Factors for Infant
Table 3.1-6	Inhalation Dose Factors for Adults
Table 3.1-7	Inhalation Dose Factors for Teenager
Table 3.1-8	Inhalation Dose Factors for Child
Table 3.1-9	Inhalation Dose Factors for Infant
Table 3.1-10	External Dose Factors for Standing on Contaminated Ground
Table 3.1-11	Stable Element Transfer Data
Table 3.1-12	R_i Values - Ground Pathway - All Ages
Table 3.1-13	R_i Values - Vegetable Pathway - Adult
Table 3.1-14	R_i Values - Vegetable Pathway - Teenager
Table 3.1-15	R_i Values - Vegetable Pathway - Child
Table 3.1-16	R_i Values - Meat Pathway - Adult
Table 3.1-17	R_i Values - Meat Pathway - Teenager
Table 3.1-18	R_i Values - Meat Pathway - Child
Table 3.1-19	R_i Values - Cow Milk Pathway - Adult
Table 3.1-20	R_i Values - Cow Milk Pathway - Teenager
Table 3.1-21	R_i Values - Cow Milk Pathway - Child
Table 3.1-22	R_i Values - Cow Milk Pathway - Infant
Table 3.1-23	R_i Values - Goat Milk Pathway - Adult
Table 3.1-24	R_i Values - Goat Milk Pathway - Teenager
Table 3.1-25	R_i Values - Goat Milk Pathway - Child
Table 3.1-26	R_i Values - Goat Milk Pathway - Infant
Table 3.1-27	R_i Values - Inhalation Pathway - Adult
Table 3.1-28	R_i Values - Inhalation Pathway - Teenager
Table 3.1-29	R_i Values - Inhalation Pathway - Child
Table 3.1-30	R_i Values - Inhalation Pathway - Infant

INTRODUCTION

The Offsite Dose Calculation Manual (ODCM) provides the methodology and parameters to be used in the calculation of offsite doses due to radioactive liquid and gaseous effluents to assure compliance with the dose limitations of the Selected Licensee Commitments. These dose limitations assure that:

- 1) the concentration of radioactive liquid effluents released from the site to the unrestricted area will be limited to 10 times the effluent concentration (EC) levels of 10CFR20, Appendix B, Table 2;
- 2) the exposures to any individual member of the public from radioactive liquid effluents will not result in doses greater than the design objectives of 10CFR50, Appendix I;
- 3) the dose rate at any time at the site boundary from radioactive gaseous effluents will be limited to: for noble gases; less than or equal to 500 mrem/yr to the whole body and less than or equal to 3000 mrem/yr to the skin; and for iodine-131 and 133, for tritium, and for all radioactive materials in particulate form with half-lives greater than 8 days; less than or equal to 1500 mrem/yr to any organ;
- 4) the exposure to any individual member of the public from radioactive gaseous effluents will not result in doses greater than the design objectives of 10CFR50, Appendix I; and
- 5) the dose to any individual member of the public from the nuclear fuel cycle will not exceed the limits of 40CFR190 and 10CFR20.

The methodology used to assure compliance with the dose limitations described above shall also be used to prepare the radioactive liquid and gaseous effluent reports required by the Selected Licensee Commitments and Technical Specifications. To assure compliance with 40CFR190 when twice the design objectives of 10CFR50, Appendix I are exceeded, the methodology and parameters to be used in calculating the offsite dose to any individual resulting from the entire fuel cycle except mining and waste management facilities are provided in the ODCM.

The ODCM also provides the methodology and parameters to be used in the calculation of radioactive liquid and gaseous effluent monitoring instrumentation alarm/trip setpoints to assure compliance with the concentration and dose rate limitations of the Selected Licensee Commitments. Changes to the methodology and parameters used in this ODCM shall be reviewed by a knowledgeable individual(s), and approved by the Station Manager and the General Office Radiation Protection Manager prior to implementation, and shall be audited by the Nuclear Safety Review Board. Changes to the ODCM shall be submitted to the Nuclear Regulatory Commission in accordance with plant Selected Licensee Commitments and Technical Specifications.

Normally RETDAS, a computer code that implements NUREG-0133 methodology, is used for the calculation of offsite doses, but this document also describes a method for the calculation of offsite doses when RETDAS is not available.

The ODCM does not replace any station implementing procedures.

1.0 RELEASE RATE CALCULATIONS

The release rate calculations presented in the following sections are site release limits. Sites containing two or more units shall administratively control releases to assure that the release rate calculations limit releases as stated in the Selected Licensee Commitments. Administrative controls could limit the number of releases occurring at one time and/or apportion the release rate between the units.

1.1 LIQUID EFFLUENTS

To comply with Selected Licensee Commitments and to assure that the concentration of radioactive liquid effluents released from the site to the unrestricted area is limited to 10 times the effluent concentrations (ECs) of 10CFR20, Appendix B, Table 2, Column 2, the following release rate calculation shall be performed:

$$f \leq F \div \left\{ \sigma \sum_{i=1}^n \frac{C_i}{(10 \times EC_i)} \right\}$$

where:

C_i = the concentration of radionuclide, 'i', in the undiluted liquid effluent, in $\mu\text{Ci/ml}$.

EC_i = the concentration of radionuclide, 'i', from 10CFR20, Appendix B, Table 2, Column 2, in $\mu\text{Ci/ml}$.

f = the undiluted effluent flow from the tank, in gpm.

F = the dilution flow from the site discharge structure to unrestricted area receiving waters, in gpm.

σ = recirculation factor at equilibrium; this factor accounts for the fraction of discharged water reused by the station; this factor is one for stations on rivers or lakes where discharged water cannot be reused, and varies for sites where water is recirculated and is specified in the appropriate Appendix.

1.2 GASEOUS EFFLUENTS

In order to comply with the Selected Licensee Commitments and to assure that the dose rate, at any time, in the unrestricted area due to radioactive materials released in gaseous effluents from the site is limited to: ≤ 500 mrem/yr to the total body, and ≤ 3000 mrem/yr to the skin for the noble gases, and is limited to ≤ 1500 mrem/yr to any organ for all radioiodine and for all radioactive materials in particulate form, and radionuclides other than noble gases with half lives greater than 8 days, the following release rate calculations shall be performed. These calculations, when solved for 'f', i.e. flowrate, are the release rates for noble gases and for radioiodines, particulates and other radionuclides with half-lives greater than 8 days. The most conservative release rate calculated shall control the release rate.

1.2.1 Noble Gases

$$\sum_i K_i \times \left\{ \overline{X/Q} \cdot \tilde{Q}_i \right\} < 500 \text{ mrem/yr, and}$$

$$\sum_i (L_i + 1.1 M_i) \cdot \left\{ \overline{X/Q} \cdot \tilde{Q}_i \right\} < 3000 \text{ mrem/yr}$$

where:

K_i = The total body dose factor due to gamma emissions for each identified noble gas radionuclide, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1.

L_i = The skin dose factor due to beta emissions for each identified noble gas radionuclide, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1.

M_i = The air dose factor due to gamma emissions for each identified noble gas radionuclide, in mrad/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1 (unit conversion constant of 1.1 mrem/mrad converts air dose to skin dose; no correction for structural shielding is assumed - GASPARD uses a factor of 0.7 reduction in gamma contributions to the skin dose consistent with Regulatory Guide 1.109, equation B-9).

$\overline{X/Q}$ = The highest calculated annual average dispersion parameter for any area at or beyond the unrestricted area boundary.

\tilde{Q}_i = The release rate of radionuclides, 'i', in gaseous effluent from all release points at the site, in $\mu\text{Ci}/\text{sec}$.

$$\tilde{Q}_i = k_1 C_i f \div k_2 = 4.72\text{E}+02 \cdot C_i f$$

where:

C_i = the concentration of radionuclide, "i", in undiluted gaseous effluent, in $\mu\text{Ci}/\text{ml}$.

f = the undiluted effluent flow, in cfm.

k_1 = conversion factor, $2.83\text{E}+04 \text{ ml}/\text{ft}^3$.

k_2 = conversion factor, $6.0\text{E}+01 \text{ sec}/\text{min}$.

1.2.2 Radioiodines, Particulates, and Others

$$\sum_i P_i \times \{ W \cdot \bar{Q}_i \} < 1500 \text{ mrem/yr}$$

where:

P_i = The dose parameter for radionuclides other than noble gases for the inhalation pathway, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ and for the food and ground plane pathways in ($\text{m}^2 \times (\text{mrem}/\text{yr per } \mu\text{Ci}/\text{sec})$) from Table 1.2-2. The dose factors are based on the critical individual organ and most restrictive age group.

W = The highest calculated annual average dispersion/deposition parameter for estimating the dose to an individual at a controlling location in the unrestricted area.

Q_i = The release rate of radionuclide, 'i', in gaseous effluent from all release points at the site, in $\mu\text{Ci}/\text{sec}$.

$$Q_i = k_1 C_i f + k_2 = 4.72\text{E}+02 \cdot C_i f$$

where:

C_i = the concentration of radionuclide, "i", in undiluted gaseous effluent, in $\mu\text{Ci}/\text{ml}$.

f = the undiluted effluent flow, in cfm.

k_1 = conversion factor, $2.83\text{E}+04 \text{ ml}/\text{ft}^3$.

k_2 = conversion factor, $6.0\text{E}+01 \text{ sec}/\text{min}$.

DOSE FACTORS FOR NOBLE GASES AND DAUGHTERS*

Radionuclide	Total Body Dose Factor K_i^{**} (mrem/yr per $\mu\text{Ci}/\text{m}^3$)	Skin Dose Factor L_i (mrem/yr per $\mu\text{Ci}/\text{m}^3$)	Gamma Air Dose Factor M_i (mrad/yr per $\mu\text{Ci}/\text{m}^3$)	Beta Air Dose Factor N_i (mrad/yr per $\mu\text{Ci}/\text{m}^3$)
Kr-83m	5.29E-02***	---	1.93E+01	2.88E+02
Kr-85m	8.19E+02	1.46E+03	1.23E+03	1.97E+03
Kr-85	1.13E+01	1.34E+03	1.72E+01	1.95E+03
Kr-87	4.14E+03	9.73E+03	6.17E+03	1.03E+04
Kr-88	1.03E+04	2.37E+03	1.52E+04	2.93E+03
Kr-89	1.16E+04	1.01E+04	1.73E+04	1.06E+04
Kr-90	1.09E+04	7.29E+03	1.63E+04	7.83E+03
Xe-131m	6.40E+01	4.76E+02	1.56E+02	1.11E+03
Xe-133m	1.76E+02	9.94E+02	3.27E+02	1.48E+03
Xe-133	2.06E+02	3.06E+02	3.53E+02	1.05E+03
Xe-135m	2.18E+03	7.11E+02	3.36E+03	7.39E+02
Xe-135	1.27E+03	1.86E+03	1.92E+03	2.46E+03
Xe-137	9.94E+02	1.22E+04	1.51E+03	1.27E+04
Xe-138	6.18E+03	4.13E+03	9.21E+03	4.75E+03
Ar-41	6.19E+03	2.69E+03	9.30E+03	3.28E+03

*The listed dose factors obtained from Regulatory Guide 1.109, Table B-1 are for radionuclides that may be detected in gaseous effluents.

**Includes a residential structure shielding attenuation factor of 0.7.

***7.56E-02 = 7.56×10^{-2}

5.29E-02 = 5.29×10^{-2}

Table 1.2-2
(1 of 1)

DOSE PARAMETERS FOR RADIOIODINES AND RADIOACTIVE
PARTICULATE GASEOUS EFFLUENTS*

(P_i Dose Parameters)

Radio- Nuclide	Pathways		Critical Age
	Inhalation (mrem/yr per $\mu\text{Ci}/\text{m}^3$)	Food and Ground (m^2 mrem/yr per $\mu\text{Ci}/\text{sec}$)	
H-3	1.12E+03	7.52E+03**	Child
Cr-51	1.44E+04	1.84E+07	Adult
Mn-54	1.40E+06	2.35E+09	Adult
Fe-55	1.11E+05	1.11E+09	Child
Fe-59	1.02E+06	2.93E+09	Adult
Co-58	9.28E+05	1.28E+09	Adult
Co-60	5.97E+06	2.57E+10	Adult
Zn-65	9.95E+05	5.44E+09	Child
Sr-89	2.16E+06	4.66E+10	Child
Sr-90	1.01E+08	1.57E+12	Child
Zr-95	1.77E+06	2.93E+09	Adult
Sb-124	2.48E+06	3.99E+09	Adult
I-131	1.48E+07	5.79E+11	Infant
I-133	3.55E+06	5.38E+09	Infant
Cs-134	7.03E+05	1.57E+11	Infant
Cs-136	1.34E+05	1.56E+10	Infant
Cs-137	6.12E+05	1.47E+11	Infant
Ba-140	1.74E+06	3.49E+08	Child
Ce-141	6.13E+05	5.75E+08	Teen
Ce-144	1.34E+07	1.31E+10	Teen

* The P_i values were calculated using the GASPARG computer code by making single computer runs for each radionuclide with the X/Q, D/Q, and Q_i values set to 1. The resulting "dose" values given by GASPARG with all other parameters set to 1 yields the P_i values.

The P_i calculations and GASPARG computer runs can be obtained from the General Office Radiation Protection Group.

** The units for the H-3 Food and Ground pathways are the same as the Inhalation pathway.

2.0 RADIATION MONITORING SETPOINTS

Effluent radiation monitor alarm/trip setpoints shall be determined using the calculations presented in the following sections. The calculations define the relationships between the measured effluent activity, the maximum allowable effluent activity, the effluent flowrate, and the dilution available in the restricted area (as defined for effluent releases in the Selected Licensee Commitments) which must be controlled to assure that the instantaneous release rate is not exceeded.

The setpoints shall be determined for those monitors listed in the appropriate tables of the Selected Licensee Commitments.

2.1 LIQUID MONITORS

The following equation shall be used to calculate liquid radiation monitor setpoints:

$$\frac{Cf}{F + f} \leq (10 \times EC)$$

where:

EC = the effluent concentration from 10CFR20, Appendix B, Table 2, Column 2, in $\mu\text{Ci/ml}$.

C = the radioactivity concentration in $\mu\text{Ci/ml}$, in the effluent line prior to dilution and subsequent release, which may be the setpoint and, if so, represents a value which, if exceeded, would result in concentrations exceeding 10 times EC.

f = the flow measured at the radiation monitor location in gpm.

F = the dilution water flow as measured prior to the release point in gpm.

(Note that if no dilution is provided, $C \leq (10 \times EC)$. Also, note that when (F) is large compared to (f), then $F + f \approx F$.)

2.2 GAS MONITORS

The following equation shall be used to calculate noble gas radiation monitor setpoints based on Xe-133:

$$K_1(X/Q)Q_i < 500$$

$$Q_i = 4.72E+2 C f \quad (\text{See Section 1.2.1})$$

where:

C = the gross activity in undiluted effluent, in $\mu\text{Ci/ml}$.

f = the flow from the tank or building and varies for various release sources, in cfm.

K_1 = from Table 1.2-1 for Xe-133, $2.06E+02$ mrem/yr per $\mu\text{Ci}/\text{m}^3$.

$\overline{X/Q}$ = the highest calculated annual average dispersion parameter for any area at or beyond the unrestricted area boundary for long term releases.

3.0 DOSE CALCULATIONS

3.1 DOSE MODELS FOR MAXIMUM EXPOSED INDIVIDUAL

3.1.1 Liquid Effluents

Of the possible exposure pathways in the aquatic environment, only two contribute significantly to the total dose; these pathways are ingestion of potable water and aquatic foods. The dose contribution from these pathways for measured quantities of radioactive materials identified in liquid effluents released to unrestricted areas shall be calculated for the maximum exposed individual in each age group using:

$$D_{ao} = \sum_i [A_{aoi} C_i] \Delta t F_{\eta}$$

where:

D_{ao} = the cumulative dose commitment for an individual of age group, "a", to the total body or any organ, "o", from the liquid effluent for the total time period, Δt , in mrem.

A_{aoi} = the site related ingestion dose commitment factor for an individual of age group, "a", to the total body or any organ, "o", for each identified principal gamma and beta emitter, "i", in mrem/hr per $\mu\text{Ci/ml}$.

$$A_{aoi} = 1.14\text{E}+05 (U_{aw}\sigma_w/D_w + U_{af}\sigma_f BF_i) DF_{aoi}$$

where:

$$1.14\text{E}+05 = 10^6 \text{ pCi}/\mu\text{Ci} \times 10^3 \text{ ml/kg} \div 8760 \text{ hr/yr.}$$

U_{aw} = Water consumption by age group, liters/yr.
(Regulatory Guide 1.109)

- infant	330
- child	510
- teen	510
- adult	730

σ_w, σ_f = recirculation factors at equilibrium for the water and fish pathways respectively; these factors account for the fraction of discharged water reused by the station.

D_w = Dilution factor from the near field area to the potable water intake.

U_{af} = Fish consumption by age group, kg/yr.
(Regulatory Guide 1.109)

- infant --
- child 6.9
- teen 16
- adult 21

BF_i = Bioaccumulation factor for radionuclide, "i", in fish, pCi/kg per pCi/liter, from Table 3.1-1.

DF_{aoi} = Dose conversion factor by age group, "a", in pre-selected organ, "o", for radionuclide, "i", in mrem/pCi, from Tables 3.1-2, 3.1-3, 3.1-4, and 3.1-5, respectively.

Using the above information, A_{aoi} values for the four age groups have been calculated for each site. This information is provided in Tables "X"4.0-3 through "X"4.0-6 where "X" is the appendix for the site in question.

C_i = the average concentration of radionuclide, "i", in undiluted liquid effluent during time period Δt from any liquid release, in $\mu\text{Ci/ml}$.

Δt = the length of time over which C_i and F_η are averaged for all liquid releases, in hours.

F_η = the near field average dilution factor for C_i during period of interest, Δt :

$$F_\eta = f/(F + f)$$

where:

f = average liquid radwaste flow, in gpm, during period of interest, Δt .

F = average dilution flow, in gpm, during period of interest, Δt .

3.1.2 Gaseous Effluents

The dose contributions from measured quantities of radioactive materials identified in gaseous effluent released to unrestricted areas shall be calculated for the maximum gamma and beta air dose from noble gases, and for the maximum exposed individual from radioiodines, particulates, and others using the following equations:

3.1.2.1 Noble Gases

For gamma radiation the air dose, D_γ , in mrad is given as:

$$D_\gamma = 3.17E-08 \cdot \overline{(X/Q)} \sum_i M_i Q_i$$

For beta radiation the air dose, D_β , in mrad is given as:

$$D_\beta = 3.17E-08 \cdot \overline{(X/Q)} \sum_i N_i Q_i$$

where:

$3.17E-08 =$ The inverse of the number of seconds in a year.

$M_i =$ The air dose factor due to gamma emissions for each identified noble gas radionuclide, "i", in mrad/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1.

$N_i =$ The air dose factor due to beta emissions for each identified noble gas radionuclide, "i", in mrad/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1.

$\overline{X/Q} =$ The highest calculated annual average relative concentration for any area at or beyond the site boundary.

$Q_i =$ The release of noble gas radionuclides, "i", in gaseous effluents, in μCi .

3.1.2.2 Radioiodines, Particulates, and Others

These calculations apply to all radioiodines, radioactive materials in particulate form and radionuclides other than noble gases with half-lives greater than 8 days:

$$D_{ao} = 3.17E-08 (W) \cdot \sum_i R_{aoi} Q_i$$

where:

$D_{ao} =$ The cumulative dose commitment for an individual of age group, "a", to the total body or any organ, "o", from the gaseous effluent, in mrem.

$3.17E-08 =$ The inverse of the number of seconds in a year.

$Q_i =$ The release of radioiodines, radioactive materials in particulate form and radionuclides other than noble gases in gaseous effluents, "i", in μCi .

W = The annual average dispersion or deposition parameter for estimating the dose to an individual at the controlling location.

$$W = (\overline{X/Q}) \text{ for the inhalation pathway, in sec/m}^3.$$

$$W = (\overline{D/Q}) \text{ for the food and ground plane pathways, in meters}^{-2}.$$

R_{aoi} = The dose factor for each identified radionuclide, "i", in m² · (mrem/yr) per μCi/sec or mrem/yr per μCi/m³, for each age, organ, and pathway. (Tables 3.1-12 through 3.1-30).

where:

Inhalation Pathway Factor, R^I_{aoi} (used with $\overline{X/Q}$)

$$R^I_{aoi} = K' (BR)_a (DFA_i)_a \quad (\text{mrem/yr per } \mu\text{Ci/m}^3)$$

where:

K' = a constant of unit conversion, 10⁶ pCi/μCi.

(BR)_a = the breathing rate of the receptor of age group (a), in m³/yr.

The breathing rates (BR)_a for the various age groups are tabulated below, as given in Regulatory Guide 1.109.

<u>Age Group (a)</u>	<u>Breathing Rate (m³/yr)</u>
Infant	1400
Child	3700
Teen	8000
Adult	8000

(DFA_i)_a = the maximum organ inhalation dose factor the receptor of age group (a) for the ith radionuclide, in mrem/pCi. The total body is considered as an organ in the selection of (DFA_i)_a. See Tables 3.1-6, 3.1-7, 3.1-8, and 3.1-9. (Taken from Regulatory Guide 1.109)

Ground Plane Pathway Factor, R^G_{aoi} (used with $\overline{D/Q}$)

$$R^G_{aoi} = K'K''(SF)DFG_i [(1 - \exp(-\lambda_i t))/\lambda_i] \quad (\text{m}^2 \cdot \text{mrem/yr per } \mu\text{Ci/sec})$$

where:

K' = a constant of unit conversion, 10^6 pCi/ μ Ci.

K'' = a constant of unit conversion, 8760 hr/year.

λ_i = the decay constant for the i th radionuclide, sec^{-1} .

t = the exposure time, 4.73×10^8 sec (15 years).

DFG_i = the ground plane dose conversion factor for the i th radionuclide (mrem/hr per pCi/ m^2).

SF = the shielding factor (dimensionless), 0.7 (Regulatory Guide 1.109)

Ground plane dose conversion factors, DFG_i , are found in Table 3.1-10.

Grass-Cow-Milk Pathway Factor, R_{aoi}^C (used with $\overline{D/Q}$)

$$R_{aoi}^C = K' E Q_F(U_{ap}) F_m(DFL_i)_a \left\{ \frac{(r)}{(\lambda_i + \lambda_w)} \times \left[\frac{f_p f_s}{Y_p} (1 - \exp(-(\lambda_i + \lambda_w)t_{ep})) \right. \right. \\ \left. \left. + \frac{(1-f_p f_s)}{Y_s} (1 - \exp(-(\lambda_i + \lambda_w)t_{es})) \exp(-\lambda_i t_h) \right] + \frac{B_{iv}}{P\lambda_i} (1 - \exp(-\lambda_i t_b)) \right\} \exp(-\lambda_i t_f)$$

($\text{m}^2 \cdot \text{mrem/yr}$ per $\mu\text{Ci/sec}$)

where:

K' = a constant of unit conversion, 10^6 pCi/ μ Ci.

Q_F = the cow's consumption rate, in kg/day (wet weight), (Regulatory Guide 1.109). (Milk Cow = 50, Beef Cattle = 50, Goats = 6).

U_{ap} = the receptor's milk consumption rate for age (a), in liters/yr.
(Regulatory Guide 1.109)

- Infant 330
- Child 330
- Teen 400
- Adult 310

Y_p = the agricultural productivity by unit area of pasture feed grass, in kg/m^2 , 0.7.

- Y_s = the agricultural productivity by unit area of stored feed, in kg/m^2 , 2.0.
- F_m = the stable element transfer coefficients, in days/liter, Table 3.1-11.
- r = fraction of deposited activity retained on cow's feed grass, $r = 1$ for radioiodine and $r = 0.2$ for particulates (Regulatory Guide 1.109).
- $(DFL_i)_a$ = the maximum organ ingestion dose factor for the i th radionuclide for the receptor in age group "a", in mrem/pCi . See Tables 3.1-2, 3.1-3, 3.1-4, and 3.1-5.
- λ_i = the decay constant for the i th radionuclide, in sec^{-1} .
- λ_w = the decay constant for removal of activity on leaf and plant surfaces by weathering, $5.73 \times 10^{-7} \text{ sec}^{-1}$ (corresponding to a 14 day half-life).
- t_f = the transport time from pasture to cow, to milk, to receptor, in sec, 1.73×10^5 (2 days).
- t_h = the transport time from pasture to harvest, to cow, to milk, to receptor, in sec, 7.78×10^6 (90 days).
- f_p = fraction of the year that the cow is on pasture (dimensionless), 1.0.
- f_s = fraction of the cow feed that is pasture grass while the cow is on pasture (dimensionless), 1.0.
- E = an adjustment fraction which accounts for the fraction of radionuclides in elemental form which contribute dose for this pathway, $E = 0.5$ for radioiodine, $E = 1.0$ for all others.
- t_{ep} = period of pasture grass exposure during growing season, in seconds, 2.59×10^6 (corresponding to 30 days, Regulatory Guide 1.109).
- t_{es} = period of stored feed crop/vegetation exposure during growing season, in seconds, 5.18×10^6 (corresponding to 60 days, Regulatory Guide 1.109).
- B_{iv} = concentration factor for uptake of radionuclide "i" from soil by edible parts of crops, in pCi/Kg (wet weight) per pCi/Kg dry soil (Regulatory Guide 1.109). See Table 3.1-11.
- P = the effective "surface density" for soil, in kg (dry soil)/ m^2 , 240 (Regulatory Guide 1.109).
- t_b = period of long-term buildup for activity in soil, in seconds, 4.73×10^8 (corresponding to 15 years, Regulatory Guide 1.109).

The concentration of tritium in milk is based on the airborne concentration rather than the deposition. Therefore, the R_{aoi}^C is based on $[X/Q]$:

$$R_{aoi}^C = K' K'' F_m Q_F U_{ap} (DFL_i)_a [0.75(0.5/H)] \quad (\text{mrem/yr per } \mu\text{Ci/m}^3)$$

where:

K'' = a constant of unit conversion, 10^3 gm/kg.

H = absolute humidity of the atmosphere, 8 gm/m^3 , (Regulatory Guide 1.109)

0.75 = the fraction of total feed that is water.

0.5 = the ratio of the specific activity of the feed grass water to the atmospheric water.

Grass-Cow-Meat Pathway Factor, R_{aoi}^M (used with $\overline{D/Q}$)

The integrated concentration in meat follows in a similar manner to the development for the milk pathway, therefore:

$$R_{aoi}^M = K' E Q_F (U_{ap}) F_f (DFL_i)_a \left\{ \frac{(r)}{(\lambda_i + \lambda_w)} \times \left[\frac{f_p f_s}{Y_p} (1 - \exp(-(\lambda_i + \lambda_w)t_{ep})) \right] \right. \\ \left. + \frac{(1 - f_p f_s)}{Y_s} (1 - \exp(-(\lambda_i + \lambda_w)t_{es})) \times \exp(-\lambda_i t_h) \right\} + \frac{B_{iv}}{P\lambda_i} (1 - \exp(-\lambda_i t_b)) \} \times \exp(-\lambda_i t_f)$$

($\text{m}^2 \cdot \text{mrem/yr per } \mu\text{Ci/sec}$)

where:

F_f = the stable element transfer coefficients, in days/kg, Table 3.1.11.

U_{ap} = the receptor's meat consumption rate for age (a), in kg/yr.
(Regulatory Guide 1.109)

- Infant	0
- Child	41
- Teen	65
- Adult	110

t_f = the transport time from pasture to cow, to meat, to receptor, in sec, 1.73×10^6 (20 days).

t_h = the transport time from crop field to receptor, in sec, 7.78×10^6 (90 days).

The concentration of tritium in meat is based on its airborne concentration rather than the deposition. Therefore, the R_{aoi}^M is based on $[X/Q]$:

$$R_{aoi}^M = K' K' ' F_f Q_F U_{ap} (DFL_i)_a [0.75(0.5/H)] \quad (\text{mrem/yr per } \mu\text{Ci/m}^3)$$

where all terms are defined above.

Vegetation Pathway Factor, R_{aoi}^V (used with $\overline{D/Q}$)

The integrated concentration in vegetation consumed by man follows the expression developed in the derivation of the milk factor. Man is considered to consume two types of vegetation (fresh and stored) that differs only in the time period between harvest and consumption, therefore:

$$R_{aoi}^V = K' E (DFL_i)_a \left[\frac{(r)}{Y_v(\lambda_i + \lambda_w)} (1 - \exp(-(\lambda_i + \lambda_w)t_e)) + \frac{B_{iv}}{P\lambda_i} (1 - \exp(-\lambda_i t_b)) \right]$$

$$\times [U_a^L f_L \exp(-\lambda_i t_L) + U_a^S f_g \exp(-\lambda_i t_h)] \quad (\text{m}^2 \cdot \text{mrem/yr per } \mu\text{Ci/sec})$$

where:

K' = a constant of unit conversion, 10^6 pCi/ μ Ci.

U_a^L = the consumption rate of fresh leafy vegetation by the receptor in age group (a), in kg/yr. (Regulatory Guide 1.109)

-	Infant	0
-	Child	26
-	Teen	42
-	Adult	64

U_a^S = the consumption rate of stored vegetation by the receptor in age group (a), in kg/yr. (Regulatory Guide 1.109)

-	Infant	0
-	Child	520
-	Teen	630
-	Adult	520

- f_L = the fraction of the annual intake of fresh leafy vegetation grown locally, (1.0).
- f_g = the fraction of the annual intake of stored vegetation grown locally, (0.76).
- t_L = the average time between harvest of leafy vegetation and its consumption, in seconds, 8.6×10^4 (1 day).
- t_h = the average time between harvest of stored vegetation and its consumption, in seconds, 5.18×10^6 (60 days).
- Y_v = the vegetation area density, 2.0 kg/m^2 .

and all other factors are previously defined.

The concentration of tritium in vegetation is based on the airborne concentration rather than the deposition. Therefore, the R_{aoi}^V is based on the $[X/Q]$.

$$R_{aoi}^V = K'K' \text{'' } U_a^L f_L + U_a^S f_g (DFL_i)_a [0.75(0.5/H)] \text{ (mrem/yr per } \mu\text{Ci/m}^3\text{)}.$$

All terms defined previously.

3.1.3 Direct Radiation

Direct radiation is that radiation from confined sources and does not include any external component from radioactive effluents. The point kernel method has been used to calculate offsite dose rates from radioactive materials stored in the refueling water storage tanks, reactor makeup water storage tanks, and temporary onsite radwaste storage tanks. Dose calculations using this method performed for Duke Nuclear Stations indicate direct radiation doses are much less than 0.01 mrem/yr and, therefore, makes a negligible contribution to individual dose. Likewise, direct and air-scatter radiation dose contributions from the onsite Independent Spent Fuel Storage Installation (ISFSI) at Oconee have been calculated. The maximum dose rate to the nearest potential resident from the Oconee ISFSI is < 0.1 mrem/yr. Direct radiation doses will not be calculated routinely.

3.1.4 Effluent Apportionment

For the Oconee Nuclear Station, dose commitments to members of the public are written in terms of the site rather than on a per unit basis, and, therefore, effluent releases and dose commitments are reported for the entire site. For the McGuire and Catawba Nuclear Stations the effluent releases are apportioned equally to each unit for each site as recommended by Section 3.1 of NUREG-0133, because the shared radwaste treatment systems at each site make it impractical to accurately ascribe releases to a specific reactor unit.

3.2 DOSE PROJECTIONS

Station dose projection calculations are periodically performed to determine the stations's status with respect to meeting annual ALARA goals specified in the Selected Licensing Commitment Manual. Such calculations are used to verify that adequate margin remains during a report period to allow normal station and radwaste system operation, including anticipated operational occurrences, for the remainder of the report period without exceeding applicable goals. Station dose projection calculations can be performed by using generic methodology, RETDAS, or by extrapolating from previous months dose calculation results.

3.3 FUEL CYCLE CALCULATIONS

In accordance with the requirements of 40CFR190, the annual dose commitment to any member of the general public shall be calculated to assure that doses are limited to 25 millirems to the total body or any organ with the exception of the thyroid which is limited to 75 millirems. In accordance with the requirements of the Selected Licensee Commitments, the annual dose commitment shall also be calculated any time that one of the quarterly dose limits of the Selected Licensee Commitments is exceeded; these annual dose commitments may not just be calculated for the calendar year.

The "Uranium fuel cycle" is defined in 40CFR Part 190.02(b) as:

"Uranium fuel cycle means the operations of milling or uranium ore, chemical conversion of uranium, isotopic enrichment of uranium, fabrication of uranium fuel, generation of electricity by a light-water-cooled nuclear power plant using uranium fuel, and reprocessing of spent uranium fuel, to the extent that these directly support the production of electrical power for public use utilizing nuclear energy, but excludes mining operations, operations at waste disposal sites, transportation of any radioactive material in support of these operations, and the reuse of recovered non-uranium special nuclear and by-product materials from the cycle."

Based on this definition of the fuel cycle and the information in 10CFR51, Table S-3, and Wash-1248, the radiological impact of the following operations has been assessed for Duke Nuclear Stations:

3.3.1 Milling

No milling operations occur within fifty miles of any Duke Nuclear Station. The increment of dose from milling operations to any individual within fifty miles of any Duke Nuclear Station is negligible.

3.3.2 Conversion

No uranium hexafluoride production occurs within fifty miles of any Duke Nuclear Station. The increment of dose from UF₆ production to any individual within fifty miles of any Duke Nuclear Station is negligible.

3.3.3 Enrichment

No uranium enrichment operations occur within fifty miles of any Duke Nuclear Station. The increment of dose from enrichment operations to any individual within fifty miles of any Duke Nuclear Station is negligible.

3.3.4 Fuel Fabrication

No fuel fabrication operations occur within fifty miles of any Duke Nuclear Station. The increment of dose from fabrication operations to any individual within fifty miles of any Duke Nuclear Station is negligible.

3.3.5 Nuclear Power Production

The production of electricity for public use using light-water-cooled nuclear power stations results in increments of dose to individuals within fifty miles of any station due to liquid and gaseous effluent releases and direct radiation or skyshine. The increments of dose resulting from liquid and gaseous effluent releases will be calculated using the methodology presented in Sections 3.1.1 and 3.1.2 or the RETDAS computer program. The dose from direct radiation, skyshine, and radiation from the station storage facilities has been estimated using conservative assumptions (see Section 3.1.3).

In certain situations more than one nuclear power station site may contribute to the doses to be considered in making fuel cycle dose assessments in accordance with 40CFR190. However, since the McGuire and Catawba nuclear stations are located approximately 30 miles apart and the Oconee nuclear station is located over 100 miles from either McGuire or Catawba, the relative dose contribution from each site to the other is insignificant, and can be ignored in assessing compliance with 40CFR190.

3.3.6 Fuel Reprocessing

No fuel reprocessing operations occur within fifty miles of any Duke Nuclear Station. The increment of dose from reprocessing operations to any individual within fifty miles of any Duke Nuclear Station is negligible.

To summarize, only dose increments from nuclear power production operations (Section 3.3.5) need be considered in calculations to demonstrate compliance with the requirements of 40CFR190.

TABLE 3.1-1*
(1 of 1)

BIOACCUMULATION FACTORS TO BE USED IN THE ABSENCE OF SITE-SPECIFIC DATA
(pCi/kg per pCi/liter)

<u>FRESHWATER</u>		
<u>ELEMENT</u>	<u>FISH</u>	<u>INVERTEBRATE</u>
H	9.0E-01	9.0E-01
Na	1.0E+02	2.0E+02
Cr	2.0E+02	2.0E+03
Mn	4.0E+02	9.0E+04
Fe	1.0E+02	3.2E+03
Co	5.0E+01	2.0E+02
Ni	1.0E+02	1.0E+02
Cu	5.0E+01	4.0E+02
Zn	2.0E+03	1.0E+04
Br	4.2E+02	3.3E+02
Rb	2.0E+03	1.0E+03
Sr	3.0E+01	1.0E+02
Y	2.5E+01	1.0E+03
Zr	3.3E+00	6.7E+00
Nb	3.0E+04	1.0E+02
Mo	1.0E+01	1.0E+01
Tc	1.5E+01	5.0E+00
Ru	1.0E+01	3.0E+02
Rh	1.0E+01	3.0E+02
Te	4.0E+02	6.1E+03
I	1.5E+01	5.0E+00
Cs	2.0E+03	1.0E+03
Ba	4.0E+00	2.0E+02
La	2.5E+01	1.0E+03
Ce	1.0E+00	1.0E+03
Pr	2.5E+01	1.0E+03
Nd	2.5E+01	1.0E+03
W	1.2E+03	1.0E+01
Np	1.0E+01	4.0E+02

* Table taken from Regulatory Guide 1.109 (Revision 1)

TABLE 3.1-2*
(1 OF 3)

INGESTION DOSE FACTORS FOR ADULTS
(mRem per pCi Ingested)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	NO DATA	1.05E-07	1.05E-07	1.05E-07	1.05E-07	1.05E-07	1.05E-07
Na 24	1.70E-06						
Cr 51	NO DATA	NO DATA	2.66E-09	1.59E-09	5.86E-10	3.53E-09	6.69E-07
Mn 54	NO DATA	4.57E-06	8.72E-07	NO DATA	1.36E-06	NO DATA	1.40E-05
Mn 56	NO DATA	1.15E-07	2.04E-08	NO DATA	1.46E-07	NO DATA	3.67E-06
Fe 55	2.75E-06	1.90E-06	4.43E-07	NO DATA	NO DATA	1.06E-06	1.09E-06
Fe 59	4.34E-06	1.02E-05	3.91E-06	NO DATA	NO DATA	2.85E-06	3.40E-05
Co 58	NO DATA	7.45E-07	1.67E-06	NO DATA	NO DATA	NO DATA	1.51E-05
Co 60	NO DATA	2.14E-06	4.72E-06	NO DATA	NO DATA	NO DATA	4.02E-05
Ni 63	1.30E-04	9.01E-06	4.36E-06	NO DATA	NO DATA	NO DATA	1.88E-06
Ni 65	5.28E-07	6.86E-08	3.13E-08	NO DATA	NO DATA	NO DATA	1.74E-06
Cu 64	NO DATA	8.33E-08	3.91E-08	NO DATA	2.10E-07	NO DATA	7.10E-06
Zn 65	4.84E-06	1.54E-05	6.96E-06	NO DATA	1.03E-05	NO DATA	9.70E-06
Zn 69	1.03E-08	1.97E-08	1.37E-09	NO DATA	1.28E-08	NO DATA	2.96E-09
Br 83	NO DATA	NO DATA	4.02E-08	NO DATA	NO DATA	NO DATA	5.79E-08
Br 84	NO DATA	NO DATA	5.21E-08	NO DATA	NO DATA	NO DATA	4.09E-13
Br 85	NO DATA	NO DATA	2.14E-09	NO DATA	NO DATA	NO DATA	LT E-24
Rb 86	NO DATA	2.11E-05	9.83E-06	NO DATA	NO DATA	NO DATA	4.16E-06
Rb 88	NO DATA	6.05E-08	3.21E-08	NO DATA	NO DATA	NO DATA	8.36E-19
Rb 89	NO DATA	4.01E-08	2.82E-08	NO DATA	NO DATA	NO DATA	2.33E-21
Sr 89	3.08E-04	NO DATA	8.84E-06	NO DATA	NO DATA	NO DATA	4.94E-05
Sr 90	7.58E-03	NO DATA	1.86E-03	NO DATA	NO DATA	NO DATA	2.19E-04
Sr 91	5.67E-06	NO DATA	2.29E-07	NO DATA	NO DATA	NO DATA	2.70E-05
Sr 92	2.15E-06	NO DATA	9.30E-08	NO DATA	NO DATA	NO DATA	4.26E-05
Y 90	9.62E-09	NO DATA	2.58E-10	NO DATA	NO DATA	NO DATA	1.02E-04
Y 91M	9.09E-11	NO DATA	3.52E-12	NO DATA	NO DATA	NO DATA	2.67E-10
Y 91	1.41E-07	NO DATA	3.77E-09	NO DATA	NO DATA	NO DATA	7.76E-05
Y 92	8.45E-10	NO DATA	2.47E-11	NO DATA	NO DATA	NO DATA	1.48E-05

* Table taken from Regulatory Guide 1.109 (Revision 1)

TABLE 3.1-2*
(2 OF 3)

INGESTION DOSE FACTORS FOR ADULTS
(mRem per pCi Ingested)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
Y 93	2.68E-09	NO DATA	7.40E-11	NO DATA	NO DATA	NO DATA	8.50E-05
Zr 95	3.04E-08	9.75E-09	6.60E-09	NO DATA	1.53E-08	NO DATA	3.09E-05
Zr 97	1.68E-09	3.39E-10	1.55E-10	NO DATA	5.12E-10	NO DATA	1.05E-04
Nb 95	6.22E-09	3.46E-09	1.86E-09	NO DATA	3.42E-09	NO DATA	2.10E-05
Mo 99	NO DATA	4.31E-06	8.20E-07	NO DATA	9.76E-06	NO DATA	9.99E-06
Tc 99M	2.47E-10	6.98E-10	8.89E-09	NO DATA	1.06E-08	3.42E-10	4.13E-07
Tc 101	2.54E-10	3.66E-10	3.59E-09	NO DATA	6.59E-09	1.87E-10	1.10E-21
Ru 103	1.85E-07	NO DATA	7.97E-08	NO DATA	7.06E-07	NO DATA	2.16E-05
Ru 105	1.54E-08	NO DATA	6.08E-09	NO DATA	1.99E-07	NO DATA	9.42E-06
Ru 106	2.75E-06	NO DATA	3.48E-07	NO DATA	5.31E-06	NO DATA	1.78E-04
Ag 110M	1.60E-07	1.48E-07	8.79E-08	NO DATA	2.91E-07	NO DATA	6.04E-05
Te 125M	2.68E-06	9.71E-07	3.59E-07	8.06E-07	1.09E-05	NO DATA	1.07E-05
Te 127M	6.77E-06	2.42E-06	8.25E-07	1.73E-06	2.75E-05	NO DATA	2.27E-05
Te 127	1.10E-07	3.95E-08	2.38E-08	8.15E-08	4.48E-07	NO DATA	8.68E-06
Te 129M	1.15E-05	4.29E-06	1.82E-06	3.95E-06	4.80E-05	NO DATA	5.79E-05
Te 129	3.14E-08	1.18E-08	7.65E-09	2.41E-08	1.32E-07	NO DATA	2.37E-08
Te 131M	1.73E-06	8.46E-07	7.05E-07	1.34E-06	8.57E-06	NO DATA	8.40E-05
Te 131	1.97E-08	8.23E-09	6.22E-09	1.62E-08	8.63E-08	NO DATA	2.79E-09
Te 132	2.52E-06	1.63E-06	1.53E-06	1.80E-06	1.57E-05	NO DATA	7.71E-05
I 130	7.56E-07	2.23E-06	8.80E-07	1.89E-04	3.48E-06	NO DATA	1.92E-06
I 131	4.16E-06	5.95E-06	3.41E-06	1.95E-03	1.02E-05	NO DATA	1.57E-06
I 132	2.03E-07	5.43E-07	1.90E-07	1.90E-05	8.65E-07	NO DATA	1.02E-07
I 133	1.42E-06	2.47E-06	7.53E-07	3.63E-04	4.31E-06	NO DATA	2.22E-06
I 134	1.06E-07	2.88E-07	1.03E-07	4.99E-06	4.58E-07	NO DATA	2.51E-10
I 135	4.43E-07	1.16E-06	4.28E-07	7.65E-05	1.86E-06	NO DATA	1.31E-06
Cs 134	6.22E-05	1.48E-04	1.21E-04	NO DATA	4.79E-05	1.59E-05	2.59E-06
Cs 136	6.51E-06	2.57E-05	1.85E-05	NO DATA	1.43E-05	1.96E-06	2.92E-06
Cs 137	7.97E-05	1.09E-04	7.14E-05	NO DATA	3.70E-05	1.23E-05	2.11E-06
Cs 138	5.52E-08	1.09E-07	5.40E-08	NO DATA	8.01E-08	7.91E-09	4.65E-13
Ba 139	9.70E-08	6.91E-11	2.84E-09	NO DATA	6.46E-11	3.92E-11	1.72E-07

* Table taken from Regulatory Guide 1.109 (Revision 1)

TABLE 3.1-2*
(3 OF 3)

INGESTION DOSE FACTORS FOR ADULTS
(mRem per pCi Ingested)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
Ba 140	2.03E-05	2.55E-08	1.33E-06	NO DATA	8.67E-09	1.46E-08	4.18E-05
Ba 141	4.71E-08	3.56E-11	1.59E-09	NO DATA	3.31E-11	2.02E-11	2.22E-17
Ba 142	2.13E-08	2.19E-11	1.34E-09	NO DATA	1.85E-11	1.24E-11	3.00E-26
La 140	2.50E-09	1.26E-09	3.33E-10	NO DATA	NO DATA	NO DATA	9.25E-05
La 142	1.28E-10	5.82E-11	1.45E-11	NO DATA	NO DATA	NO DATA	4.25E-07
Ce 141	9.36E-09	6.33E-09	7.18E-10	NO DATA	2.94E-09	NO DATA	2.42E-05
Ce 143	1.65E-09	1.22E-06	1.35E-10	NO DATA	5.37E-10	NO DATA	4.56E-05
Ce 144	4.88E-07	2.04E-07	2.62E-08	NO DATA	1.21E-07	NO DATA	1.65E-04
Pr 143	9.20E-09	3.69E-09	4.56E-10	NO DATA	2.13E-09	NO DATA	4.03E-05
Pr 144	3.01E-11	1.25E-11	1.53E-12	NO DATA	7.05E-12	NO DATA	4.33E-18
Nd 147	6.29E-09	7.27E-09	4.35E-10	NO DATA	4.25E-09	NO DATA	3.49E-05
W 187	1.03E-07	8.61E-08	3.01E-08	NO DATA	NO DATA	NO DATA	2.82E-05
Np 239	1.19E-09	1.17E-10	6.45E-11	NO DATA	3.65E-10	NO DATA	2.40E-05

* Table taken from Regulatory Guide 1.109 (Revision 1)

TABLE 3.1-3*
(1 OF 3)

INGESTION DOSE FACTORS FOR TEENAGER
(mRem per pCi Ingested)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	NO DATA	1.06E-07	1.06E-07	1.06E-07	1.06E-07	1.06E-07	1.06E-07
Na 24	2.30E-06						
Cr 51	NO DATA	NO DATA	3.60E-09	2.00E-09	7.89E-10	5.14E-09	6.05E-07
Mn 54	NO DATA	5.90E-06	1.17E-06	NO DATA	1.76E-06	NO DATA	1.21E-05
Mn 56	NO DATA	1.58E-07	2.81E-08	NO DATA	2.00E-07	NO DATA	1.04E-05
Fe 55	3.78E-06	2.68E-06	6.25E-07	NO DATA	NO DATA	1.70E-06	1.16E-06
Fe 59	5.87E-06	1.37E-05	5.29E-06	NO DATA	NO DATA	4.32E-06	3.24E-05
Co 58	NO DATA	9.72E-07	2.24E-06	NO DATA	NO DATA	NO DATA	1.34E-05
Co 60	NO DATA	2.81E-06	6.33E-06	NO DATA	NO DATA	NO DATA	3.66E-05
Ni 63	1.77E-04	1.25E-05	6.00E-06	NO DATA	NO DATA	NO DATA	1.99E-06
Ni 65	7.49E-07	9.57E-08	4.36E-08	NO DATA	NO DATA	NO DATA	5.19E-06
Cu 64	NO DATA	1.15E-07	5.41E-08	NO DATA	2.91E-07	NO DATA	8.92E-06
Zn 65	5.76E-06	2.00E-05	9.33E-06	NO DATA	1.28E-05	NO DATA	8.47E-06
Zn 69	1.47E-08	2.80E-08	1.96E-09	NO DATA	1.83E-08	NO DATA	5.16E-08
Br 83	NO DATA	NO DATA	5.74E-08	NO DATA	NO DATA	NO DATA	LT E-24
Br 84	NO DATA	NO DATA	7.22E-08	NO DATA	NO DATA	NO DATA	LT E-24
Br 85	NO DATA	NO DATA	3.05E-09	NO DATA	NO DATA	NO DATA	LT E-24
Rb 86	NO DATA	2.98E-05	1.40E-05	NO DATA	NO DATA	NO DATA	4.41E-06
Rb 88	NO DATA	8.52E-08	4.54E-08	NO DATA	NO DATA	NO DATA	7.30E-15
Rb 89	NO DATA	5.50E-08	3.89E-08	NO DATA	NO DATA	NO DATA	8.43E-17
Sr 89	4.40E-04	NO DATA	1.26E-05	NO DATA	NO DATA	NO DATA	5.24E-05
Sr 90	8.30E-03	NO DATA	2.05E-03	NO DATA	NO DATA	NO DATA	2.33E-04
Sr 91	8.07E-06	NO DATA	3.21E-07	NO DATA	NO DATA	NO DATA	3.66E-05
Sr 92	3.05E-06	NO DATA	1.30E-07	NO DATA	NO DATA	NO DATA	7.77E-05
Y 90	1.37E-08	NO DATA	3.69E-10	NO DATA	NO DATA	NO DATA	1.13E-04
Y 91M	1.29E-10	NO DATA	4.93E-12	NO DATA	NO DATA	NO DATA	6.09E-09
Y 91	2.01E-07	NO DATA	5.39E-09	NO DATA	NO DATA	NO DATA	8.24E-05
Y 92	1.21E-09	NO DATA	3.50E-11	NO DATA	NO DATA	NO DATA	3.32E-05

* Table taken from Regulatory Guide 1.109 (Revision 1)

TABLE 3.1-3*
(2 OF 3)

INGESTION DOSE FACTORS FOR TEENAGER
(mRem per pCi Ingested)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
Y 93	3.83E-09	NO DATA	1.05E-10	NO DATA	NO DATA	NO DATA	1.17E-04
Zr 95	4.12E-08	1.30E-08	8.94E-09	NO DATA	1.91E-08	NO DATA	3.00E-05
Zr 97	2.37E-09	4.69E-10	2.16E-10	NO DATA	7.11E-10	NO DATA	1.27E-04
Nb 95	8.22E-09	4.56E-09	2.51E-09	NO DATA	4.42E-09	NO DATA	1.95E-05
Mo 99	NO DATA	6.03E-06	1.15E-06	NO DATA	1.38E-05	NO DATA	1.08E-05
Tc 99M	3.32E-10	9.26E-10	1.20E-08	NO DATA	1.38E-08	5.14E-10	6.08E-07
Tc 101	3.60E-10	5.12E-10	5.03E-09	NO DATA	9.26E-09	3.12E-10	8.75E-18
Ru 103	2.55E-07	NO DATA	1.09E-07	NO DATA	8.99E-07	NO DATA	2.13E-05
Ru 105	2.18E-08	NO DATA	8.46E-09	NO DATA	2.75E-07	NO DATA	1.76E-05
Ru 106	3.92E-06	NO DATA	4.94E-07	NO DATA	7.56E-06	NO DATA	1.88E-04
Ag 110M	2.05E-07	1.94E-07	1.18E-07	NO DATA	3.70E-07	NO DATA	5.45E-05
Te 125M	3.83E-06	1.38E-06	5.12E-07	1.07E-06	NO DATA	NO DATA	1.13E-05
Te 127M	9.67E-06	3.43E-06	1.15E-06	2.30E-06	3.92E-05	NO DATA	2.41E-05
Te 127	1.58E-07	5.60E-08	3.40E-08	1.09E-07	6.40E-07	NO DATA	1.22E-05
Te 129M	1.63E-05	6.05E-06	2.58E-06	5.26E-06	6.82E-05	NO DATA	6.12E-05
Te 129	4.48E-08	1.67E-08	1.09E-08	3.20E-08	1.88E-07	NO DATA	2.45E-07
Te 131M	2.44E-06	1.17E-06	9.76E-07	1.76E-06	1.22E-05	NO DATA	9.39E-05
Te 131	2.79E-08	1.15E-08	8.72E-09	2.15E-08	1.22E-07	NO DATA	2.29E-09
Te 132	3.49E-06	2.21E-06	2.08E-06	2.33E-06	2.12E-05	NO DATA	7.00E-05
I 130	1.03E-06	2.98E-06	1.19E-06	2.43E-04	4.59E-06	NO DATA	2.29E-06
I 131	5.85E-06	8.19E-06	4.40E-06	2.39E-03	1.41E-05	NO DATA	1.62E-06
I 132	2.79E-07	7.30E-07	2.62E-07	2.46E-05	1.15E-06	NO DATA	3.18E-07
I 133	2.01E-06	3.41E-06	1.04E-06	4.76E-04	5.98E-06	NO DATA	2.58E-06
I 134	1.46E-07	3.87E-07	1.39E-07	6.45E-06	6.10E-07	NO DATA	5.10E-09
I 135	6.10E-07	1.57E-06	5.82E-07	1.01E-04	2.48E-06	NO DATA	1.74E-06
Cs 134	8.37E-05	1.97E-04	9.14E-05	NO DATA	6.26E-05	2.39E-05	2.45E-06
Cs 136	8.59E-06	3.38E-05	2.27E-05	NO DATA	1.84E-05	2.90E-06	2.72E-06
Cs 137	1.12E-04	1.49E-04	5.19E-05	NO DATA	5.07E-05	1.97E-05	2.12E-06
Cs 138	7.76E-08	1.49E-07	7.45E-08	NO DATA	1.10E-07	1.28E-08	6.76E-11
Ba 139	1.39E-07	9.78E-11	4.05E-09	NO DATA	9.22E-11	6.74E-11	1.24E-06

* Table taken from Regulatory Guide 1.109 (Revision 1)

TABLE 3.1-3*
(3 OF 3)

INGESTION DOSE FACTORS FOR TEENAGER
(mRem per pCi Ingested)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
Ba 140	2.84E-05	3.48E-08	1.83E-06	NO DATA	1.18E-08	2.34E-08	4.38E-05
Ba 141	6.71E-08	5.01E-11	2.24E-09	NO DATA	4.65E-11	3.43E-11	1.43E-13
Ba 142	2.99E-08	2.99E-11	1.84E-09	NO DATA	2.53E-11	1.99E-11	9.18E-20
La 140	3.48E-09	1.71E-09	4.55E-10	NO DATA	NO DATA	NO DATA	9.82E-05
La 142	1.79E-10	7.95E-11	1.98E-11	NO DATA	NO DATA	NO DATA	2.42E-06
Ce 141	1.33E-08	8.88E-09	1.02E-09	NO DATA	4.18E-09	NO DATA	2.54E-05
Ce 143	2.35E-09	1.71E-06	1.91E-10	NO DATA	7.67E-10	NO DATA	5.14E-05
Ce 144	6.96E-07	2.88E-07	3.74E-08	NO DATA	1.72E-07	NO DATA	1.75E-04
Pr 143	1.31E-08	5.23E-09	6.52E-10	NO DATA	3.04E-09	NO DATA	4.31E-05
Pr 144	4.30E-11	1.76E-11	2.18E-12	NO DATA	1.01E-11	NO DATA	4.74E-14
Nd 147	9.38E-09	1.02E-08	6.11E-10	NO DATA	5.99E-09	NO DATA	3.68E-05
W 187	1.46E-07	1.19E-07	4.17E-08	NO DATA	NO DATA	NO DATA	3.22E-05
Np 239	1.76E-09	1.66E-10	9.22E-11	NO DATA	5.21E-10	NO DATA	2.67E-05

* Table taken from Regulatory Guide 1.109 (Revision 1)

TABLE 3.1-4*
(1 OF 3)

INGESTION DOSE FACTORS FOR CHILD
(mRem per pCi Ingested)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	NO DATA	2.03E-07	2.03E-07	2.03E-07	2.03E-07	2.03E-07	2.03E-07
Na 24	5.80E-06						
Cr 51	NO DATA	NO DATA	8.90E-09	4.94E-09	1.35E-09	9.02E-09	4.72E-07
Mn 54	NO DATA	1.07E-05	2.85E-06	NO DATA	3.00E-06	NO DATA	8.98E-06
Mn 56	NO DATA	3.34E-07	7.54E-08	NO DATA	4.04E-07	NO DATA	4.84E-05
Fe 55	1.15E-05	6.10E-06	1.89E-06	NO DATA	NO DATA	3.45E-06	1.13E-06
Fe 59	1.65E-05	2.67E-05	1.33E-05	NO DATA	NO DATA	7.74E-06	2.78E-05
Co 58	NO DATA	1.80E-06	5.51E-06	NO DATA	NO DATA	NO DATA	1.05E-05
Co 60	NO DATA	5.29E-06	1.56E-06	NO DATA	NO DATA	NO DATA	2.93E-05
Ni 63	5.38E-04	2.88E-05	1.83E-05	NO DATA	NO DATA	NO DATA	1.94E-06
Ni 65	2.22E-06	2.09E-07	1.22E-07	NO DATA	NO DATA	NO DATA	2.56E-05
Cu 64	NO DATA	2.45E-07	1.48E-07	NO DATA	5.92E-07	NO DATA	1.15E-05
Zn 65	1.37E-05	3.65E-05	2.27E-05	NO DATA	2.30E-05	NO DATA	6.41E-06
Zn 69	4.38E-08	6.33E-08	5.85E-09	NO DATA	3.84E-08	NO DATA	3.99E-06
Br 83	NO DATA	NO DATA	1.71E-07	NO DATA	NO DATA	NO DATA	LT E-24
Br 84	NO DATA	NO DATA	1.98E-07	NO DATA	NO DATA	NO DATA	LT E-24
Br 85	NO DATA	NO DATA	9.12E-09	NO DATA	NO DATA	NO DATA	LT E-24
Rb 86	NO DATA	6.70E-05	4.12E-05	NO DATA	NO DATA	NO DATA	4.31E-06
Rb 88	NO DATA	1.90E-07	1.32E-07	NO DATA	NO DATA	NO DATA	9.32E-09
Rb 89	NO DATA	1.17E-07	1.04E-07	NO DATA	NO DATA	NO DATA	1.02E-09
Sr 89	1.32E-03	NO DATA	3.77E-05	NO DATA	NO DATA	NO DATA	5.11E-05
Sr 90	1.70E-02	NO DATA	4.31E-03	NO DATA	NO DATA	NO DATA	2.29E-04
Sr 91	2.40E-05	NO DATA	9.06E-07	NO DATA	NO DATA	NO DATA	5.30E-05
Sr 92	9.03E-06	NO DATA	3.62E-07	NO DATA	NO DATA	NO DATA	1.71E-04
Y 90	4.11E-08	NO DATA	1.10E-09	NO DATA	NO DATA	NO DATA	1.17E-04
Y 91M	3.82E-10	NO DATA	1.39E-11	NO DATA	NO DATA	NO DATA	7.48E-07
Y 91	6.02E-07	NO DATA	1.61E-08	NO DATA	NO DATA	NO DATA	8.02E-05
Y 92	3.60E-09	NO DATA	1.03E-10	NO DATA	NO DATA	NO DATA	1.04E-04

* Table taken from Regulatory Guide 1.109 (Revision 1)

TABLE 3.1-4*
(2 OF 3)

INGESTION DOSE FACTORS FOR CHILD
(mRem per pCi Ingested)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
Y 93	1.14E-08	NO DATA	3.13E-10	NO DATA	NO DATA	NO DATA	1.70E-04
Zr 95	1.16E-07	2.55E-08	2.27E-08	NO DATA	3.65E-08	NO DATA	2.66E-05
Zr 97	6.99E-09	1.01E-09	5.96E-10	NO DATA	1.45E-09	NO DATA	1.53E-04
Nb 95	2.25E-08	8.76E-09	6.26E-09	NO DATA	8.23E-09	NO DATA	1.62E-05
Mo 99	NO DATA	1.33E-05	3.29E-06	NO DATA	2.84E-05	NO DATA	1.10E-05
Tc 99M	9.23E-10	1.81E-09	3.00E-08	NO DATA	2.63E-08	9.19E-10	1.03E-06
Tc 101	1.07E-09	1.12E-09	1.42E-08	NO DATA	1.91E-08	5.92E-10	3.56E-09
Ru 103	7.31E-07	NO DATA	2.81E-07	NO DATA	1.84E-06	NO DATA	1.89E-05
Ru 105	6.45E-08	NO DATA	2.34E-08	NO DATA	5.67E-07	NO DATA	4.21E-05
Ru 106	1.17E-05	NO DATA	1.46E-06	NO DATA	1.58E-05	NO DATA	1.82E-04
Ag 110M	5.39E-07	3.64E-07	2.91E-07	NO DATA	6.78E-07	NO DATA	4.33E-05
Te 125M	1.14E-05	3.09E-06	1.52E-06	3.20E-06	NO DATA	NO DATA	1.10E-05
Te 127M	2.89E-05	7.78E-06	3.43E-06	6.91E-06	8.24E-05	NO DATA	2.34E-05
Te 127	4.71E-07	1.27E-07	1.01E-07	3.26E-07	1.34E-06	NO DATA	1.84E-05
Te 129M	4.87E-05	1.36E-05	7.56E-06	1.57E-05	1.43E-04	NO DATA	5.94E-05
Te 129	1.34E-07	3.74E-08	3.18E-08	9.56E-08	3.92E-07	NO DATA	8.34E-06
Te 131M	7.20E-06	2.49E-06	2.65E-06	5.12E-06	2.41E-05	NO DATA	1.01E-04
Te 131	8.30E-08	2.53E-08	2.47E-08	6.35E-08	2.51E-07	NO DATA	4.36E-07
Te 132	1.01E-05	4.47E-06	5.40E-06	6.51E-06	4.15E-05	NO DATA	4.50E-05
I 130	2.92E-06	5.90E-06	3.04E-06	6.50E-04	8.82E-06	NO DATA	2.76E-06
I 131	1.72E-05	1.73E-05	9.83E-06	5.72E-03	2.84E-05	NO DATA	1.54E-06
I 132	8.00E-07	1.47E-06	6.76E-07	6.82E-05	2.25E-06	NO DATA	1.73E-06
I 133	5.92E-06	7.32E-06	2.77E-06	1.36E-03	1.22E-05	NO DATA	2.95E-06
I 134	4.19E-07	7.78E-07	3.58E-07	1.79E-05	1.19E-06	NO DATA	5.16E-07
I 135	1.75E-06	3.15E-06	1.49E-06	2.79E-04	4.83E-06	NO DATA	2.40E-06
Cs 134	2.34E-04	3.84E-04	8.10E-05	NO DATA	1.19E-04	4.27E-05	2.07E-06
Cs 136	2.35E-05	6.46E-05	4.18E-05	NO DATA	3.44E-05	5.13E-06	2.27E-06
Cs 137	3.27E-04	3.13E-04	4.62E-05	NO DATA	1.02E-04	3.67E-05	1.96E-06
Cs 138	2.28E-07	3.17E-07	2.01E-07	NO DATA	2.23E-07	2.40E-08	1.46E-07
Ba 139	4.14E-07	2.21E-10	1.20E-08	NO DATA	1.93E-10	1.30E-10	2.39E-05

* Table taken from Regulatory Guide 1.109 (Revision 1)

TABLE 3.1-4*
(3 OF 3)

INGESTION DOSE FACTORS FOR CHILD
(mRem per pCi Ingested)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
Ba 140	8.31E-05	7.28E-08	4.85E-06	NO DATA	2.37E-08	4.34E-08	4.21E-05
Ba 141	2.00E-07	1.12E-10	6.51E-09	NO DATA	9.69E-11	6.58E-10	1.14E-07
Ba 142	8.74E-08	6.29E-11	4.88E-09	NO DATA	5.09E-11	3.70E-11	1.14E-09
La 140	1.01E-08	3.53E-09	1.19E-09	NO DATA	NO DATA	NO DATA	9.84E-05
La 142	5.24E-10	1.67E-10	5.23E-11	NO DATA	NO DATA	NO DATA	3.31E-05
Ce 141	3.97E-08	1.98E-08	2.94E-09	NO DATA	8.68E-09	NO DATA	2.47E-05
Ce 143	6.99E-09	3.79E-06	5.49E-10	NO DATA	1.59E-09	NO DATA	5.55E-05
Ce 144	2.08E-06	6.52E-07	1.11E-07	NO DATA	3.61E-07	NO DATA	1.70E-04
Pr 143	3.93E-08	1.18E-08	1.95E-09	NO DATA	6.39E-09	NO DATA	4.24E-05
Pr 144	1.29E-10	3.99E-11	6.49E-12	NO DATA	2.11E-11	NO DATA	8.59E-08
Nd 147	2.79E-08	2.26E-08	1.75E-09	NO DATA	1.24E-08	NO DATA	3.58E-05
W 187	4.29E-07	2.54E-07	1.14E-07	NO DATA	NO DATA	NO DATA	3.57E-05
Np 239	5.25E-09	3.77E-10	2.65E-10	NO DATA	1.09E-09	NO DATA	2.79E-05

* Table taken from Regulatory Guide 1.109 (Revision 1)

TABLE 3.1-5*
(1 OF 3)

INGESTION DOSE FACTORS FOR INFANT
(mRem per pCi Ingested)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	NO DATA	3.08E-07	3.08E-07	3.08E-07	3.08E-07	3.08E-07	3.08E-07
Na 24	1.01E-05						
Cr 51	NO DATA	NO DATA	1.41E-08	9.20E-09	2.01E-09	1.79E-08	4.11E-07
Mn 54	NO DATA	1.99E-05	4.51E-06	NO DATA	4.41E-06	NO DATA	7.31E-06
Mn 56	NO DATA	8.18E-07	1.41E-07	NO DATA	7.03E-07	NO DATA	7.43E-05
Fe 55	1.39E-05	8.98E-06	2.40E-06	NO DATA	NO DATA	4.39E-06	1.14E-06
Fe 59	3.08E-05	5.38E-05	2.12E-05	NO DATA	NO DATA	1.59E-05	2.57E-05
Co 58	NO DATA	3.60E-06	8.98E-06	NO DATA	NO DATA	NO DATA	8.97E-06
Co 60	NO DATA	1.08E-05	2.55E-05	NO DATA	NO DATA	NO DATA	2.57E-05
Ni 63	6.34E-04	3.92E-05	2.20E-05	NO DATA	NO DATA	NO DATA	1.95E-06
Ni 65	4.70E-06	5.32E-07	2.42E-07	NO DATA	NO DATA	NO DATA	4.05E-05
Cu 64	NO DATA	6.09E-07	2.82E-07	NO DATA	1.03E-06	NO DATA	1.25E-05
Zn 65	1.84E-05	6.31E-05	2.91E-05	NO DATA	3.06E-05	NO DATA	5.33E-05
Zn 69	9.33E-08	1.68E-07	1.25E-08	NO DATA	6.98E-08	NO DATA	1.37E-05
Br 83	NO DATA	NO DATA	3.63E-07	NO DATA	NO DATA	NO DATA	LT E-24
Br 84	NO DATA	NO DATA	3.82E-07	NO DATA	NO DATA	NO DATA	LT E-24
Br 85	NO DATA	NO DATA	1.94E-08	NO DATA	NO DATA	NO DATA	LT E-24
Rb 86	NO DATA	1.70E-04	8.40E-05	NO DATA	NO DATA	NO DATA	4.35E-06
Rb 88	NO DATA	4.98E-07	2.73E-07	NO DATA	NO DATA	NO DATA	4.85E-07
Rb 89	NO DATA	2.86E-07	1.97E-07	NO DATA	NO DATA	NO DATA	9.74E-08
Sr 89	2.51E-03	NO DATA	7.20E-05	NO DATA	NO DATA	NO DATA	5.16E-05
Sr 90	1.85E-02	NO DATA	4.71E-03	NO DATA	NO DATA	NO DATA	2.31E-04
Sr 91	5.00E-05	NO DATA	1.81E-06	NO DATA	NO DATA	NO DATA	5.92E-05
Sr 92	1.92E-05	NO DATA	7.13E-07	NO DATA	NO DATA	NO DATA	2.07E-04
Y 90	8.69E-08	NO DATA	2.33E-09	NO DATA	NO DATA	NO DATA	1.20E-04
Y 91M	8.10E-10	NO DATA	2.76E-11	NO DATA	NO DATA	NO DATA	2.70E-06
Y 91	1.13E-06	NO DATA	3.01E-08	NO DATA	NO DATA	NO DATA	8.10E-05
Y 92	7.65E-09	NO DATA	2.15E-10	NO DATA	NO DATA	NO DATA	1.46E-04

* Table taken from Regulatory Guide 1.109 (Revision 1)

TABLE 3.1-5*
(2 OF 3)

INGESTION DOSE FACTORS FOR INFANT
(mRem per pCi Ingested)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-ILLI
Y 93	2.43E-08	NO DATA	6.62E-10	NO DATA	NO DATA	NO DATA	1.92E-04
Zr 95	2.06E-07	5.02E-08	3.56E-08	NO DATA	5.41E-08	NO DATA	2.50E-05
Zr 97	1.48E-08	2.54E-09	1.16E-09	NO DATA	2.56E-09	NO DATA	1.62E-04
Nb 95	4.20E-08	1.73E-08	1.00E-08	NO DATA	1.24E-08	NO DATA	1.46E-05
Mo 99	NO DATA	3.40E-05	6.63E-06	NO DATA	5.08E-05	NO DATA	1.12E-05
Tc 99M	1.92E-09	3.96E-09	5.10E-08	NO DATA	4.26E-08	2.07E-09	1.15E-06
Tc 101	2.27E-09	2.86E-09	2.83E-08	NO DATA	3.40E-08	1.56E-09	4.86E-07
Ru 103	1.48E-06	NO DATA	4.95E-07	NO DATA	3.08E-06	NO DATA	1.80E-05
Ru 105	1.36E-07	NO DATA	4.58E-08	NO DATA	1.00E-06	NO DATA	5.41E-05
Ru 106	2.41E-05	NO DATA	3.01E-06	NO DATA	2.85E-05	NO DATA	1.83E-04
Ag 110M	9.96E-07	7.27E-07	4.81E-07	NO DATA	1.04E-06	NO DATA	3.77E-05
Te 125M	2.33E-05	7.79E-06	3.15E-06	7.84E-06	NO DATA	NO DATA	1.11E-05
Te 127M	5.85E-05	1.94E-05	7.08E-06	1.69E-05	1.44E-04	NO DATA	2.36E-05
Te 127	1.00E-06	3.35E-07	2.15E-07	8.14E-07	2.44E-06	NO DATA	2.10E-05
Te 129M	1.00E-04	3.43E-05	1.54E-05	3.84E-05	2.50E-04	NO DATA	5.97E-05
Te 129	2.84E-07	9.79E-08	6.63E-08	2.38E-07	7.07E-07	NO DATA	2.27E-05
Te 131M	1.52E-05	6.12E-06	5.05E-06	1.24E-05	4.21E-05	NO DATA	1.03E-04
Te 131	1.76E-07	6.50E-08	4.94E-08	1.57E-07	4.50E-07	NO DATA	7.11E-06
Te 132	2.08E-05	1.03E-05	9.61E-06	1.52E-05	6.44E-05	NO DATA	3.81E-05
I 130	6.00E-06	1.32E-05	5.30E-06	1.48E-03	1.45E-05	NO DATA	2.83E-06
I 131	3.59E-05	4.23E-05	1.86E-05	1.39E-02	4.94E-05	NO DATA	1.51E-06
I 132	1.66E-06	3.37E-06	1.20E-06	1.58E-04	3.76E-06	NO DATA	2.73E-06
I 133	1.25E-05	1.82E-05	5.33E-06	3.31E-03	2.14E-05	NO DATA	3.08E-06
I 134	8.69E-07	1.78E-06	6.33E-07	4.15E-05	1.99E-06	NO DATA	1.84E-06
I 135	3.64E-06	7.24E-06	2.64E-06	6.49E-04	8.07E-06	NO DATA	2.62E-06
Cs 134	3.77E-04	7.03E-04	7.10E-05	NO DATA	1.81E-04	7.42E-05	1.91E-06
Cs 136	4.59E-05	1.35E-04	5.04E-05	NO DATA	5.38E-05	1.10E-05	2.05E-06
Cs 137	5.22E-04	6.11E-04	4.33E-05	NO DATA	1.64E-04	6.64E-05	1.91E-06
Cs 138	4.81E-07	7.82E-07	3.79E-07	NO DATA	3.90E-07	6.09E-08	1.25E-06
Ba 139	8.81E-07	5.84E-10	2.55E-08	NO DATA	3.51E-10	3.54E-10	5.58E-05

* Table taken from Regulatory Guide 1.109 (Revision 1)

TABLE 3.1-5*
(3 OF 3)

INGESTION DOSE FACTORS FOR INFANT
(mRem per pCi Ingested)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
Ba 140	1.71E-04	1.71E-07	8.81E-06	NO DATA	4.06E-08	1.05E-07	4.20E-05
Ba 141	4.25E-07	2.91E-10	1.34E-08	NO DATA	1.75E-10	1.77E-10	5.19E-06
Ba 142	1.84E-07	1.53E-10	9.06E-09	NO DATA	8.81E-11	9.26E-11	7.59E-07
La 140	2.11E-08	8.32E-09	2.14E-09	NO DATA	NO DATA	NO DATA	9.77E-05
La 142	1.10E-09	4.04E-10	9.67E-11	NO DATA	NO DATA	NO DATA	6.86E-05
Ce 141	7.87E-08	4.80E-08	5.65E-09	NO DATA	1.48E-08	NO DATA	2.48E-05
Ce 143	1.48E-08	9.82E-06	1.12E-09	NO DATA	2.86E-09	NO DATA	5.73E-05
Ce 144	2.98E-06	1.22E-06	1.67E-07	NO DATA	4.93E-07	NO DATA	1.71E-04
Pr 143	8.13E-08	3.04E-08	4.03E-09	NO DATA	1.13E-08	NO DATA	4.29E-05
Pr 144	2.74E-10	1.06E-10	1.38E-11	NO DATA	3.84E-11	NO DATA	4.93E-06
Nd 147	5.53E-08	5.68E-08	3.48E-09	NO DATA	2.19E-08	NO DATA	3.60E-05
W 187	9.03E-07	6.28E-07	2.17E-07	NO DATA	NO DATA	NO DATA	3.69E-05
Np 239	1.11E-08	9.93E-10	5.61E-10	NO DATA	1.98E-09	NO DATA	2.87E-05

* Table taken from Regulatory Guide 1.109 (Revision 1)

TABLE 3.1-6*
(1 OF 1)

INHALATION DOSE FACTORS FOR ADULTS
(mRem per pCi Inhaled)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	NO DATA	1.58E-07	1.58E-07	1.58E-07	1.58E-07	1.58E-07	1.58E-07
Cr 51	NO DATA	NO DATA	1.25E-08	7.44E-09	2.85E-09	1.80E-06	4.15E-07
Mn 54	NO DATA	4.95E-06	7.87E-07	NO DATA	1.23E-06	1.75E-04	9.67E-06
Fe 55	3.07E-06	2.12E-06	4.93E-07	NO DATA	NO DATA	9.01E-06	7.54E-07
Fe 59	1.47E-06	3.47E-06	1.32E-06	NO DATA	NO DATA	1.27E-04	2.35E-05
Co 58	NO DATA	1.98E-07	2.59E-07	NO DATA	NO DATA	1.16E-04	1.33E-05
Co 60	NO DATA	1.44E-06	1.85E-06	NO DATA	NO DATA	7.46E-04	3.56E-05
Zn 65	4.05E-06	1.29E-05	5.82E-06	NO DATA	8.62E-06	1.08E-04	6.68E-06
Sr 89	8.30E-05	NO DATA	1.09E-06	NO DATA	NO DATA	1.75E-04	4.37E-05
Sr 90	1.24E-02	NO DATA	7.62E-04	NO DATA	NO DATA	1.20E-03	9.02E-05
Zr 95	1.34E-05	4.30E-06	2.91E-06	NO DATA	6.77E-06	2.21E-04	7.88E-05
Mo 99	NO DATA	1.51E-08	2.87E-09	NO DATA	3.64E-08	1.14E-05	3.10E-05
Sb 124	3.90E-06	7.36E-08	1.55E-06	9.44E-09	NO DATA	3.10E-04	5.08E-05
I 131	3.15E-06	4.47E-06	2.56E-06	1.49E-03	7.66E-06	NO DATA	7.85E-07
I 133	1.08E-06	1.85E-06	5.65E-07	2.69E-04	3.23E-06	NO DATA	1.11E-06
Cs 134	4.66E-05	1.06E-04	9.10E-05	NO DATA	3.59E-05	1.22E-05	1.30E-06
Cs 136	4.88E-06	1.83E-05	1.38E-05	NO DATA	1.07E-05	1.50E-06	1.46E-06
Cs 137	5.98E-05	7.76E-05	5.35E-05	NO DATA	2.78E-05	9.40E-06	1.05E-06
Ba 140	4.88E-06	6.13E-09	3.21E-07	NO DATA	2.09E-09	1.59E-04	2.73E-05
Ce 141	2.49E-06	1.69E-06	1.91E-07	NO DATA	7.83E-07	4.52E-05	1.50E-05
Ce 144	4.29E-04	1.79E-04	2.30E-05	NO DATA	1.06E-04	9.72E-04	1.02E-04

* Table taken from NUREG-0597

TABLE 3.1-7*
(1 OF 1)

INHALATION DOSE FACTORS FOR TEENAGER
(mRem per pCi Inhaled)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	NO DATA	1.59E-07	1.59E-07	1.59E-07	1.59E-07	1.59E-07	1.59E-07
Cr 51	NO DATA	NO DATA	1.69E-08	9.37E-09	3.84E-09	2.62E-06	3.75E-07
Mn 54	NO DATA	6.39E-06	1.05E-06	NO DATA	1.59E-06	2.48E-04	8.35E-06
Fe 55	4.18E-06	2.98E-06	6.93E-07	NO DATA	NO DATA	1.55E-06	7.99E-07
Fe 59	1.99E-06	4.62E-06	1.79E-06	NO DATA	NO DATA	1.91E-04	2.23E-05
Co 58	NO DATA	2.59E-07	3.47E-07	NO DATA	NO DATA	1.68E-04	1.19E-05
Co 60	NO DATA	1.89E-06	2.48E-06	NO DATA	NO DATA	1.09E-03	3.24E-05
Zn 65	4.82E-06	1.67E-05	7.80E-06	NO DATA	1.08E-05	1.55E-04	5.83E-06
Sr 89	5.43E-05	NO DATA	1.56E-06	NO DATA	NO DATA	3.02E-04	4.64E-05
Sr 90	1.34E-02	NO DATA	8.35E-04	NO DATA	NO DATA	2.06E-03	9.56E-05
Zr 95	1.82E-05	5.73E-06	3.94E-06	NO DATA	8.42E-06	3.36E-04	1.86E-05
Mo 99	NO DATA	2.11E-08	4.03E-09	NO DATA	5.14E-08	1.92E-05	3.36E-05
Sb 124	5.38E-06	9.92E-08	2.10E-06	1.22E-08	NO DATA	4.81E-04	4.98E-05
I 131	4.43E-06	6.14E-06	3.30E-06	1.83E-03	1.05E-05	NO DATA	8.11E-07
I 133	1.52E-06	2.56E-06	7.78E-07	3.65E-04	4.49E-06	NO DATA	1.29E-06
Cs 134	6.28E-05	1.41E-04	6.86E-05	NO DATA	4.69E-05	1.83E-05	1.22E-06
Cs 136	6.44E-06	2.42E-05	1.71E-05	NO DATA	1.38E-05	2.22E-06	1.36E-06
Cs 137	8.38E-05	1.06E-04	3.89E-05	NO DATA	3.80E-05	1.51E-05	1.06E-06
Ba 140	6.84E-06	8.38E-09	4.40E-07	NO DATA	2.85E-09	2.54E-04	2.86E-05
Ce 141	3.55E-06	2.37E-06	2.71E-07	NO DATA	1.11E-06	7.67E-05	1.58E-05
Ce 144	6.11E-04	2.53E-04	3.28E-05	NO DATA	1.51E-04	1.67E-03	1.08E-04

* Table taken from NUREG-0597

TABLE 3.1-8*
(1 OF 1)

INHALATION DOSE FACTORS FOR CHILD
(mRem per pCi Inhaled)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	NO DATA	3.04E-07	3.04E-07	3.04E-07	3.04E-07	3.04E-07	3.04E-07
Cr 51	NO DATA	NO DATA	4.17E-08	2.31E-08	6.57E-09	4.59E-06	2.93E-07
Mn 54	NO DATA	1.16E-05	2.57E-06	NO DATA	2.71E-06	4.26E-04	6.19E-06
Fe 55	1.28E-05	6.80E-06	2.10E-06	NO DATA	NO DATA	3.00E-05	7.75E-07
Fe 59	5.59E-06	9.04E-06	4.51E-06	NO DATA	NO DATA	3.43E-04	1.91E-05
Co 58	NO DATA	4.79E-07	8.55E-07	NO DATA	NO DATA	2.99E-04	9.29E-06
Co 60	NO DATA	3.55E-06	6.12E-06	NO DATA	NO DATA	1.91E-03	2.60E-05
Zn 65	1.15E-05	3.06E-05	1.90E-05	NO DATA	1.93E-05	2.69E-04	4.41E-06
Sr 89	1.69E-04	NO DATA	4.66E-06	NO DATA	NO DATA	5.83E-04	4.52E-05
Sr 90	2.73E-02	NO DATA	1.74E-03	NO DATA	NO DATA	3.99E-03	9.28E-05
Zr 95	5.13E-05	1.13E-05	1.00E-05	NO DATA	1.16E-05	6.03E-04	1.65E-05
Mo 99	NO DATA	4.66E-08	1.15E-08	NO DATA	1.06E-07	3.66E-05	3.42E-05
Sb 124	1.55E-05	2.00E-07	5.41E-06	3.41E-08	NO DATA	8.76E-04	4.43E-05
I 131	1.30E-05	1.30E-05	7.37E-06	4.39E-03	2.13E-05	NO DATA	7.68E-07
I 133	4.48E-06	5.49E-06	2.08E-06	1.04E-03	9.13E-06	NO DATA	1.48E-06
Cs 134	1.76E-04	2.74E-04	6.07E-05	NO DATA	8.93E-05	3.27E-05	1.04E-06
Cs 136	1.76E-05	4.62E-05	3.14E-05	NO DATA	2.58E-05	3.93E-06	1.13E-06
Cs 137	2.45E-04	2.23E-04	3.47E-05	NO DATA	7.63E-05	2.81E-05	9.78E-07
Ba 140	2.00E-05	1.75E-08	1.17E-06	NO DATA	5.71E-09	4.71E-04	2.75E-05
Ce 141	1.06E-05	5.28E-06	7.83E-07	NO DATA	2.31E-06	1.47E-04	1.53E-05
Ce 144	1.83E-03	5.72E-04	9.77E-05	NO DATA	3.17E-04	3.23E-03	1.05E-04

* Table taken from NUREG-0597

TABLE 3.1-9*
(1 OF 1)

INHALATION DOSE FACTORS FOR INFANT
(mRem per pCi Inhaled)

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	NO DATA	4.62E-07	4.62E-07	4.62E-07	4.62E-07	4.62E-07	4.62E-07
Cr 51	NO DATA	NO DATA	6.39E-08	4.11E-08	9.45E-09	9.17E-06	2.55E-07
Mn 54	NO DATA	1.81E-05	3.56E-06	NO DATA	3.56E-06	7.14E-04	5.04E-06
Fe 55	1.41E-05	8.39E-06	2.38E-06	NO DATA	NO DATA	6.21E-05	7.82E-07
Fe 59	9.69E-06	1.68E-05	6.77E-06	NO DATA	NO DATA	7.25E-04	1.77E-05
Co 58	NO DATA	8.71E-07	1.30E-06	NO DATA	NO DATA	5.55E-04	7.95E-06
Co 60	NO DATA	5.73E-06	8.41E-06	NO DATA	NO DATA	3.22E-03	2.28E-05
Zn 65	1.38E-05	4.47E-05	2.22E-05	NO DATA	2.32E-05	4.62E-04	3.67E-05
Sr 89	2.84E-04	NO DATA	8.15E-06	NO DATA	NO DATA	1.45E-03	4.57E-05
Sr 90	2.92E-02	NO DATA	1.85E-03	NO DATA	NO DATA	8.03E-03	9.36E-05
Zr 95	8.24E-05	1.99E-05	1.45E-05	NO DATA	2.22E-05	1.25E-03	1.55E-05
Mo 99	NO DATA	1.18E-07	2.31E-08	NO DATA	1.89E-07	9.63E-05	3.48E-05
Sb 124	2.71E-05	3.97E-07	8.56E-06	7.18E-08	NO DATA	1.89E-03	4.22E-05
I 131	2.71E-05	3.17E-05	1.40E-05	1.06E-02	3.70E-05	NO DATA	7.56E-07
I 133	9.46E-06	1.37E-05	4.00E-06	2.54E-03	1.60E-05	NO DATA	1.54E-06
Cs 134	2.83E-04	5.02E-04	5.32E-05	NO DATA	1.36E-04	5.69E-05	9.53E-07
Cs 136	3.45E-05	9.61E-05	3.78E-05	NO DATA	4.03E-05	8.40E-06	1.02E-06
Cs 137	3.92E-04	4.37E-04	3.25E-05	NO DATA	1.23E-04	5.09E-05	9.53E-07
Ba 140	4.00E-05	4.00E-08	2.07E-06	NO DATA	9.59E-09	1.14E-03	2.74E-05
Ce 141	1.98E-05	1.19E-05	1.42E-06	NO DATA	3.75E-06	3.69E-04	1.54E-05
Ce 144	2.28E-03	8.65E-04	1.26E-04	NO DATA	3.84E-04	7.03E-03	1.06E-04

* Table taken from NUREG-0597

TABLE 3.1-10*
(1 of 2)
EXTERNAL DOSE FACTORS FOR STANDING ON CONTAMINATED GROUND

(mrem/hr per pCi/m²)

<u>Element</u>	<u>Total Body</u>	<u>Skin</u>
H-3	0.0	0.0
Na-24	2.50E-08	2.90E-08
Cr-51	2.20E-10	2.60E-10
Mn-54	5.80E-09	6.80E-09
Mn-56	1.10E-08	1.30E-08
Fe-55	0.0	0.0
Fe-59	8.00E-09	9.40E-09
Co-58	7.00E-09	8.20E-09
Co-60	1.70E-08	2.00E-08
Ni-63	0.0	0.0
Ni-65	3.70E-09	4.30E-09
Cu-64	1.50E-09	1.70E-09
Zn-65	4.00E-09	4.60E-09
Zn-69	0.0	0.0
Br-83	6.40E-11	9.30E-11
Br-84	1.20E-08	1.40E-08
Br-85	0.0	0.0
Rb-86	6.30E-10	7.20E-10
Rb-88	3.50E-09	4.00E-09
Rb-89	1.50E-08	1.80E-08
Sr-89	5.60E-13	6.50E-13
Sr-91	7.10E-09	8.30E-09
Sr-92	9.00E-09	1.00E-08
Y-90	2.20E-12	2.60E-12
Y-91M	3.80E-09	4.40E-09
Y-91	2.40E-11	2.70E-11
Y-92	1.60E-09	1.90E-09
Y-93	5.70E-10	7.80E-10
Zr-95	5.00E-09	5.80E-09
Zr-97	5.50E-09	6.40E-09
Nb-95	5.10E-09	6.00E-09
Mo-99	1.90E-09	2.20E-09
Tc-99M	9.60E-10	1.10E-09
Tc-101	2.70E-09	3.00E-09
Ru-103	3.60E-09	4.20E-09
Ru-105	4.50E-09	5.10E-09
Ru-106	1.50E-09	1.80E-09
Ag-110M	1.80E-08	2.10E-08
Te-125M	3.50E-11	4.80E-11
Te-127M	1.10E-12	1.30E-12
Te-127	1.00E-11	1.10E-11
Te-129M	7.70E-10	9.00E-10
Te-129	7.10E-10	8.40E-10

*Taken from Regulatory Guide 1.109 (Rev. 1)

TABLE 3.1-10
(1 of 2)

TABLE 3.1-10 (cont'd)
(2 of 2)

EXTERNAL DOSE FACTORS FOR STANDING ON CONTAMINATED GROUND

(mrem/hr per pCi/m²)

<u>Element</u>	<u>Total Body</u>	<u>Skin</u>
Te-131M	8.40E-09	9.90E-09
Te-131	2.20E-09	2.60E-06
Te-132	1.70E-09	2.00E-09
I-130	1.40E-08	1.70E-08
I-131	2.80E-09	3.40E-09
I-132	1.70E-08	2.00E-08
I-133	3.70E-09	4.50E-09
I-134	1.60E-08	1.90E-08
I-135	1.20E-08	1.40E-08
Cs-134	1.20E-08	1.40E-08
Cs-136	1.50E-08	1.70E-08
Cs-137	4.20E-09	4.90E-09
Cs-138	2.10E-08	2.40E-08
Ba-139	2.40E-09	2.70E-09
Ba-140	2.10E-09	2.40E-09
Ba-141	4.30E-09	4.90E-09
Ba-142	7.90E-09	9.00E-09
La-140	1.50E-08	1.70E-08
La-142	1.50E-08	1.80E-08
Ce-141	5.50E-10	6.20E-10
Ce-143	2.20E-09	2.50E-09
Ce-144	3.20E-10	3.70E-10
Pr-143	0.0	0.0
Pr-144	2.00E-10	2.30E-10
Nd-147	1.00E-09	1.20E-09
W-187	3.10E-09	3.60E-09
Np-239	9.50E-10	1.10E-09

TABLE 3.1-10
(2 of 2)

TABLE 3.1-11*
(1 of 1)
STABLE ELEMENT TRANSFER DATA

<u>Element</u>	B_{iv} <u>Veg/Soil</u>	F_m (Cow) <u>Milk (d/l)</u>	F_f <u>Meat (d/kg)</u>
H	4.8E+00	1.0E-02**	1.2E-02
Na	5.2E-02	4.0E-02	3.0E-02
Cr	2.5E-04	2.2E-03	2.4E-03
Mn	2.9E-02	2.5E-04	8.0E-04
Fe	6.6E-04	1.2E-03**	4.0E-02
Co	9.4E-03	1.0E-03	1.3E-02
Ni	1.9E-02	6.7E-03	5.3E-02
Cu	1.2E-01	1.4E-02**	8.0E-03
Zn	4.0E-01	3.9E-02	3.0E-02
Rb	1.3E-01	3.0E-02	3.1E-02
Sr	1.7E-02	8.0E-04**	6.0E-04
Y	2.6E-03	1.0E-05	4.6E-03
Zr	1.7E-04	5.0E-06	3.4E-02
Nb	9.4E-03	2.5E-03	2.8E-01
Mo	1.2E-01	7.5E-03	8.0E-03
Tc	2.5E-01	2.5E-02	4.0E-01
Ru	5.0E-02	1.0E-06	4.0E-01
Rh	1.3E+01	1.0E-02	1.5E-03
Ag	1.5E-01	5.0E-02	1.7E-02
Te	1.3E+00	1.0E-03	7.7E-02
I	2.0E-02	6.0E-03**	2.9E-03
Cs	1.0E-02	1.2E-02**	4.0E-03
Ba	5.0E-03	4.0E-04	3.2E-03
La	2.5E-03	5.0E-06	2.0E-04
Ce	2.5E-03	1.0E-04	1.2E-03
Pr	2.5E-03	5.0E-06	4.7E-03
Nd	2.4E-03	5.0E-06	3.3E-03
W	1.8E-02	5.0E-04	1.3E-03
Np	2.5E-03	5.0E-06	2.0E-04

*Taken from Regulatory Guide 1.109 (Rev. 1)

**Nuclide Transfer parameters for Goat's milk

<u>Element</u>	F_m (d/l)
H	0.17
Fe	1.30E-04
Cu	0.013
Sr	0.014
I	0.06
Cs	0.30

TABLE 3.1-12
 (1 of 1)
 R_i VALUES - GROUND PATHWAY - ALL AGES

<u>NUCLIDE</u>	<u>T. BODY</u>	<u>SKIN</u>
H 3	NO DATA	NO DATA
CR 51	4.65E+06	5.49E+06
MN 54	1.38E+09	1.62E+09
FE 55	NO DATA	NO DATA
FE 59	2.72E+08	3.20E+08
CO 58	3.79E+08	4.44E+08
CO 60	2.15E+10	2.53E+10
ZN 65	7.44E+08	8.56E+08
SR 89	2.16E+04	2.50E+04
SR 90	NO DATA	NO DATA
ZR 95	2.51E+08	2.91E+08
MO 99	4.63E+06	4.00E+06
SB 124	5.98E+08	6.91E+08
I 131	8.59E+06	1.04E+07
I 133	1.22E+06	1.49E+06
CS 134	6.82E+09	7.96E+09
CS 136	1.50E+08	1.70E+08
CS 137	1.03E+10	1.20E+10
BA 140	2.05E+07	2.34E+07
CE 141	1.36E+07	1.54E+07
CE 144	6.92E+07	8.01E+07

TABLE 3.1-13
 (1 of 1)
 R_i VALUES - VEGETABLE PATHWAY - ADULT

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	2.28E+03	2.28E+03	2.28E+03	2.28E+03	2.28E+03	2.28E+03
CR 51	0.0	0.0	4.58E+04	2.74E+04	1.01E+04	6.07E+04	1.15E+07
MN 54	0.0	3.07E+08	5.86E+07	0.0	9.14E+07	0.0	9.41E+08
FE 55	1.99E+08	1.38E+08	3.21E+07	0.0	0.0	7.68E+07	7.90E+07
FE 59	1.23E+08	2.90E+08	1.11E+08	0.0	0.0	8.09E+07	9.66E+08
CO 58	0.0	2.99E+07	6.71E+07	0.0	0.0	0.0	6.07E+08
CO 60	0.0	1.66E+08	3.67E+08	0.0	0.0	0.0	3.12E+09
ZN 65	4.00E+08	1.27E+09	5.76E+08	0.0	8.52E+08	0.0	8.02E+08
SR 89	9.75E+09	0.0	2.80E+08	0.0	0.0	0.0	1.56E+09
SR 90	6.70E+11	0.0	1.64E+11	0.0	0.0	0.0	1.94E+10
ZR 95	1.16E+06	3.73E+05	2.52E+05	0.0	5.85E+05	0.0	1.18E+09
MO 99	0.0	6.20E+06	1.18E+06	0.0	1.40E+07	0.0	1.44E+07
SB 124	1.01E+08	1.91E+06	4.01E+07	2.45E+05	0.0	7.88E+07	2.87E+09
I 131	4.03E+07	5.76E+07	3.30E+07	1.89E+10	9.88E+07	0.0	1.52E+07
I 133	1.04E+06	1.80E+06	5.50E+05	2.65E+08	3.15E+06	0.0	1.62E+06
CS 134	4.54E+09	1.08E+10	8.83E+09	0.0	3.49E+09	1.16E+09	1.89E+08
CS 136	4.23E+07	1.67E+08	1.20E+08	0.0	9.30E+07	1.27E+07	1.90E+07
CS 137	6.63E+09	9.07E+09	5.94E+09	0.0	3.08E+09	1.02E+09	1.76E+08
BA 140	1.28E+08	1.61E+05	8.40E+06	0.0	5.47E+04	9.22E+04	2.64E+08
CE 141	1.94E+05	1.31E+05	1.49E+04	0.0	6.09E+04	0.0	5.02E+08
CE 144	3.15E+07	1.31E+07	1.69E+06	0.0	7.80E+06	0.0	1.06E+10

TABLE 3.1-14
 (1 of 1)
 R_i VALUES - VEGETABLE PATHWAY - TEENAGER

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	2.61E+03	2.61E+03	2.61E+03	2.61E+03	2.61E+03	2.61E+03
CR 51	0.0	0.0	6.08E+04	3.38E+04	1.33E+04	8.68E+04	1.02E+07
MN 54	0.0	4.46E+08	8.85E+07	0.0	1.33E+08	0.0	9.15E+08
FE 55	3.10E+08	2.20E+08	5.13E+07	0.0	0.0	1.39E+08	9.51E+07
FE 59	1.75E+08	4.09E+08	1.58E+08	0.0	0.0	1.29E+08	9.68E+08
CO 58	0.0	4.25E+07	9.79E+07	0.0	0.0	0.0	5.86E+08
CO 60	0.0	2.47E+08	5.57E+08	0.0	0.0	0.0	3.22E+09
ZN 65	5.35E+08	1.86E+09	8.66E+08	0.0	1.19E+09	0.0	7.86E+08
SR 89	1.48E+10	0.0	4.24E+08	0.0	0.0	0.0	1.76E+09
SR 90	8.32E+11	0.0	2.05E+11	0.0	0.0	0.0	2.34E+10
ZR 95	1.70E+06	5.38E+05	3.70E+05	0.0	7.90E+05	0.0	1.24E+09
MO 99	0.0	5.69E+06	1.09E+06	0.0	1.30E+07	0.0	1.02E+07
SB 124	1.51E+08	2.78E+06	5.88E+07	3.42E+05	0.0	1.32E+08	3.04E+09
I 131	3.83E+07	5.37E+07	2.88E+07	1.57E+10	9.24E+07	0.0	1.06E+07
I 133	9.63E+05	1.63E+06	4.98E+05	2.28E+08	2.87E+06	0.0	1.24E+06
CS 134	6.90E+09	1.62E+10	7.54E+09	0.0	5.16E+09	1.97E+09	2.02E+08
CS 136	4.33E+07	1.71E+08	1.15E+08	0.0	9.28E+07	1.46E+07	1.37E+07
CS 137	1.06E+10	1.41E+10	4.90E+09	0.0	4.78E+09	1.86E+09	2.00E+08
BA 140	1.38E+08	1.69E+05	8.88E+06	0.0	5.72E+04	1.14E+05	2.12E+08
CE 141	2.78E+05	1.86E+05	2.13E+04	0.0	8.75E+04	0.0	5.32E+08
CE 144	5.04E+07	2.09E+07	2.71E+06	0.0	1.25E+07	0.0	1.27E+10

TABLE 3.1-15
 (1 of 1)
 R_i VALUES - VEGETABLE PATHWAY - CHILD

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	4.04E+03	4.04E+03	4.04E+03	4.04E+03	4.04E+03	4.04E+03
CR 51	0.0	0.0	1.15E+05	6.40E+04	1.75E+04	1.17E+05	6.12E+06
MN 54	0.0	6.53E+08	1.74E+08	0.0	1.83E+08	0.0	5.48E+08
FE 55	7.62E+08	4.04E+08	1.25E+08	0.0	0.0	2.29E+08	7.49E+07
FE 59	3.88E+08	6.29E+08	3.13E+08	0.0	0.0	1.82E+08	6.54E+08
CO 58	0.0	6.27E+07	1.92E+08	0.0	0.0	0.0	3.66E+08
CO 60	0.0	3.76E+08	1.11E+09	0.0	0.0	0.0	2.08E+09
ZN 65	1.02E+09	2.73E+09	1.70E+09	0.0	1.72E+09	0.0	4.80E+08
SR 89	3.52E+10	0.0	1.00E+09	0.0	0.0	0.0	1.36E+09
SR 90	1.38E+12	0.0	3.49E+11	0.0	0.0	0.0	1.86E+10
ZR 95	3.82E+06	8.40E+05	7.48E+05	0.0	1.20E+06	0.0	8.77E+08
MO 99	0.0	7.77E+06	1.92E+06	0.0	1.66E+07	0.0	6.43E+06
SB 124	3.44E+08	4.46E+06	1.20E+08	7.59E+05	0.0	1.91E+08	2.15E+09
I 131	7.13E+07	7.17E+07	4.08E+07	2.37E+10	1.18E+08	0.0	6.39E+06
I 133	1.76E+06	2.17E+06	8.22E+05	4.03E+08	3.62E+06	0.0	8.75E+05
CS 134	1.56E+10	2.56E+10	5.40E+09	0.0	7.93E+09	2.85E+09	1.38E+08
CS 136	8.16E+07	2.24E+08	1.45E+08	0.0	1.19E+08	1.78E+07	7.88E+06
CS 137	2.49E+10	2.39E+10	3.52E+09	0.0	7.78E+09	2.80E+09	1.50E+08
BA 140	2.76E+08	2.42E+05	1.61E+07	0.0	7.87E+04	1.44E+05	1.40E+08
CE 141	6.45E+05	3.22E+05	4.78E+04	0.0	1.41E+05	0.0	4.02E+08
CE 144	1.22E+08	3.81E+07	6.48E+06	0.0	2.11E+07	0.0	9.93E+09

TABLE 3.1-16
 (1 of 1)
 R_i VALUES - MEAT PATHWAY - ADULT

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	3.27E+02	3.27E+02	3.27E+02	3.27E+02	3.27E+02	3.27E+02
CR 51	0.0	0.0	5.86E+03	3.50E+03	1.29E+03	7.77E+03	1.47E+06
MN 54	0.0	6.83E+06	1.30E+06	0.0	2.03E+06	0.0	2.09E+07
FE 55	2.13E+08	1.47E+08	3.43E+07	0.0	0.0	8.20E+07	8.44E+07
FE 59	2.12E+08	4.99E+08	1.91E+08	0.0	0.0	1.39E+08	1.66E+09
CO 58	0.0	1.41E+07	3.17E+07	0.0	0.0	0.0	2.87E+08
CO 60	0.0	5.56E+07	1.23E+08	0.0	0.0	0.0	1.04E+09
ZN 65	3.01E+08	9.57E+08	4.32E+08	0.0	6.40E+08	0.0	6.03E+08
SR 89	2.39E+08	0.0	6.86E+06	0.0	0.0	0.0	3.83E+07
SR 90	9.67E+09	0.0	2.37E+09	0.0	0.0	0.0	2.79E+08
ZR 95	1.47E+06	4.72E+05	3.20E+05	0.0	7.41E+05	0.0	1.50E+09
MO 99	0.0	9.38E+04	1.78E+04	0.0	2.12E+05	0.0	2.17E+05
SB 124	1.55E+07	2.93E+05	6.15E+06	3.76E+04	0.0	1.21E+07	4.40E+08
I 131	4.92E+06	7.03E+06	4.03E+06	2.30E+09	1.21E+07	0.0	1.86E+06
I 133	1.69E-01	2.94E-01	8.97E-02	4.32E+01	5.14E-01	0.0	2.65E-01
CS 134	4.83E+08	1.15E+09	9.39E+08	0.0	3.72E+08	1.23E+08	2.01E+07
CS 136	1.06E+07	4.20E+07	3.03E+07	0.0	2.34E+07	3.21E+06	4.78E+06
CS 137	6.58E+08	9.00E+08	5.89E+08	0.0	3.05E+08	1.02E+08	1.74E+07
BA 140	2.56E+07	3.22E+04	1.68E+06	0.0	1.09E+04	1.84E+04	5.27E+07
CE 141	1.15E+04	7.79E+03	8.84E+02	0.0	3.62E+03	0.0	2.98E+07
CE 144	1.07E+06	4.49E+05	5.76E+04	0.0	2.66E+05	0.0	3.63E+08

TABLE 3.1-17
 (1 of 1)
 R_i VALUES - MEAT PATHWAY - TEENAGER

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	1.95E+02	1.95E+02	1.95E+02	1.95E+02	1.95E+02	1.95E+02
CR 51	0.0	0.0	4.68E+03	2.60E+03	1.03E+03	6.69E+03	7.87E+05
MN 54	0.0	5.21E+06	1.03E+06	0.0	1.55E+06	0.0	1.07E+07
FE 55	1.73E+08	1.23E+08	2.86E+07	0.0	0.0	7.78E+07	5.31E+07
FE 59	1.70E+08	3.96E+08	1.53E+08	0.0	0.0	1.25E+08	9.36E+08
CO 58	0.0	1.09E+07	2.51E+07	0.0	0.0	0.0	1.50E+08
CO 60	0.0	4.31E+07	9.72E+07	0.0	0.0	0.0	5.62E+08
ZN 65	2.11E+08	7.34E+08	3.43E+08	0.0	4.70E+08	0.0	3.11E+08
SR 89	2.02E+08	0.0	5.78E+06	0.0	0.0	0.0	2.40E+07
SR 90	6.26E+09	0.0	1.55E+09	0.0	0.0	0.0	1.76E+08
ZR 95	1.18E+06	3.72E+05	2.56E+05	0.0	5.47E+05	0.0	8.58E+08
MO 99	0.0	7.75E+04	1.48E+04	0.0	1.77E+05	0.0	1.39E+05
SB 124	1.27E+07	2.33E+05	4.94E+06	2.87E+04	0.0	1.11E+07	2.55E+08
I 131	4.09E+06	5.72E+06	3.07E+06	1.67E+09	9.85E+06	0.0	1.13E+06
I 133	1.42E-01	2.40E-01	7.32E-02	3.35E+01	4.21E-01	0.0	1.82E-01
CS 134	3.84E+08	9.04E+08	4.19E+08	0.0	2.87E+08	1.10E+08	1.12E+07
CS 136	8.30E+06	3.27E+07	2.19E+07	0.0	1.78E+07	2.80E+06	2.63E+06
CS 137	5.46E+08	7.27E+08	2.53E+08	0.0	2.47E+08	9.61E+07	1.03E+07
BA 140	2.12E+07	2.59E+04	1.36E+06	0.0	8.79E+03	1.74E+04	3.26E+07
CE 141	9.67E+03	6.46E+03	7.42E+02	0.0	3.04E+03	0.0	1.85E+07
CE 144	9.04E+05	3.74E+05	4.86E+04	0.0	2.24E+05	0.0	2.27E+08

TABLE 3.1-18
(1 of 1)
R_i VALUES - MEAT PATHWAY - CHILD

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	2.36E+02	2.36E+02	2.36E+02	2.36E+02	2.36E+02	2.36E+02
CR 51	0.0	0.0	7.31E+03	4.06E+03	1.11E+03	7.40E+03	3.87E+05
MN 54	0.0	5.96E+06	1.59E+06	0.0	1.67E+06	0.0	5.00E+06
FE 55	3.32E+08	1.76E+08	5.45E+07	0.0	0.0	9.95E+07	3.26E+07
FE 59	3.01E+08	4.86E+08	2.42E+08	0.0	0.0	1.41E+08	5.06E+08
CO 58	0.0	1.27E+07	3.90E+07	0.0	0.0	0.0	7.43E+07
CO 60	0.0	5.12E+07	1.51E+08	0.0	0.0	0.0	2.84E+08
ZN 65	3.17E+08	8.45E+08	5.26E+08	0.0	5.33E+08	0.0	1.48E+08
SR 89	3.82E+08	0.0	1.09E+07	0.0	0.0	0.0	1.48E+07
SR 90	8.08E+09	0.0	2.05E+09	0.0	0.0	0.0	1.09E+08
ZR 95	2.09E+06	4.60E+05	4.10E+05	0.0	6.59E+05	0.0	4.80E+08
MO 99	0.0	1.08E+05	2.67E+04	0.0	2.30E+05	0.0	8.92E+04
SB 124	2.29E+07	2.97E+05	8.03E+06	5.06E+04	0.0	1.27E+07	1.43E+08
I 131	7.58E+06	7.62E+06	4.33E+06	2.52E+09	1.25E+07	0.0	6.78E+05
I 133	2.63E-01	3.25E-01	1.23E-01	6.04E+01	5.42E-01	0.0	1.31E-01
CS 134	6.77E+08	1.11E+09	2.34E+08	0.0	3.44E+08	1.24E+08	5.99E+06
CS 136	1.43E+07	3.94E+07	2.55E+07	0.0	2.10E+07	3.13E+06	1.38E+06
CS 137	1.01E+09	9.63E+08	1.42E+08	0.0	3.14E+08	1.13E+08	6.03E+06
BA 140	3.91E+07	3.42E+04	2.28E+06	0.0	1.11E+04	2.04E+04	1.98E+07
CE 141	1.82E+04	9.08E+03	1.35E+03	0.0	3.98E+03	0.0	1.13E+07
CE 144	1.70E+06	5.34E+05	9.10E+04	0.0	2.96E+05	0.0	1.39E+08

TABLE 3.1-19
 (1 of 1)
 R_i VALUES - COW MILK PATHWAY - ADULT

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	7.69E+02	7.69E+02	7.69E+02	7.69E+02	7.69E+02	7.69E+02
CR 51	0.0	0.0	2.38E+04	1.42E+04	5.24E+03	3.15E+04	5.98E+06
MN 54	0.0	6.26E+06	1.19E+06	0.0	1.86E+06	0.0	1.92E+07
FE 55	1.82E+07	1.26E+07	2.94E+06	0.0	0.0	7.03E+06	7.22E+06
FE 59	2.37E+07	5.58E+07	2.14E+07	0.0	0.0	1.56E+07	1.86E+08
CO 58	0.0	3.66E+06	8.19E+06	0.0	0.0	0.0	7.41E+07
CO 60	0.0	1.21E+07	2.68E+07	0.0	0.0	0.0	2.28E+08
ZN 65	1.16E+09	3.69E+09	1.67E+09	0.0	2.47E+09	0.0	2.32E+09
SR 89	1.15E+09	0.0	3.30E+07	0.0	0.0	0.0	1.84E+08
SR 90	3.64E+10	0.0	8.93E+09	0.0	0.0	0.0	1.05E+09
ZR 95	7.38E+02	2.37E+02	1.60E+02	0.0	3.71E+02	0.0	7.50E+05
MO 99	0.0	2.32E+07	4.42E+06	0.0	5.25E+07	0.0	5.38E+07
SB 124	2.02E+07	3.81E+05	7.99E+06	4.89E+04	0.0	1.57E+07	5.72E+08
I 131	1.36E+08	1.94E+08	1.11E+08	6.36E+10	3.32E+08	0.0	5.12E+07
I 133	1.80E+06	3.13E+06	9.55E+05	4.61E+08	5.47E+06	0.0	2.82E+06
CS 134	4.15E+09	9.88E+09	8.08E+09	0.0	3.20E+09	1.06E+09	1.73E+08
CS 136	2.33E+08	9.22E+08	6.63E+08	0.0	5.13E+08	7.03E+07	1.05E+08
CS 137	5.57E+09	7.62E+09	4.99E+09	0.0	2.59E+09	8.59E+08	1.47E+08
BA 140	2.39E+07	3.01E+04	1.57E+06	0.0	1.02E+04	1.72E+04	4.93E+07
CE 141	3.99E+03	2.70E+03	3.06E+02	0.0	1.25E+03	0.0	1.03E+07
CE 144	2.64E+05	1.10E+05	1.42E+04	0.0	6.55E+04	0.0	8.93E+07

TABLE 3.1-19
 (1 of 1)

TABLE 3.1-20
(1 of 1)
R_i VALUES - COW MILK PATHWAY - TEENAGER

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	1.00E+03	1.00E+03	1.00E+03	1.00E+03	1.00E+03	1.00E+03
CR 51	0.0	0.0	4.15E+04	2.31E+04	9.10E+03	5.93E+04	6.98E+06
MN 54	0.0	1.04E+07	2.07E+06	0.0	3.11E+06	0.0	2.14E+07
FE 55	3.23E+07	2.29E+07	5.34E+06	0.0	0.0	1.45E+07	9.92E+06
FE 59	4.14E+07	9.67E+07	3.73E+07	0.0	0.0	3.05E+07	2.29E+08
CO 58	0.0	6.15E+06	1.42E+07	0.0	0.0	0.0	8.48E+07
CO 60	0.0	2.06E+07	4.63E+07	0.0	0.0	0.0	2.68E+08
ZN 65	1.78E+09	6.18E+09	2.88E+09	0.0	3.96E+09	0.0	2.62E+09
SR 89	2.12E+09	0.0	6.07E+07	0.0	0.0	0.0	2.53E+08
SR 90	5.14E+10	0.0	1.27E+10	0.0	0.0	0.0	1.44E+09
ZR 95	1.29E+03	4.07E+02	2.80E+02	0.0	5.98E+02	0.0	9.39E+05
MO 99	0.0	4.19E+07	7.99E+06	0.0	9.59E+07	0.0	7.50E+07
SB 124	3.60E+07	6.62E+05	1.40E+07	8.16E+04	0.0	3.14E+07	7.25E+08
I 131	2.46E+08	3.44E+08	1.85E+08	1.01E+11	5.93E+08	0.0	6.81E+07
I 133	3.29E+06	5.58E+06	1.70E+06	7.79E+08	9.79E+06	0.0	4.22E+06
CS 134	7.21E+09	1.70E+10	7.87E+09	0.0	5.39E+09	2.06E+09	2.11E+08
CS 136	3.97E+08	1.56E+09	1.05E+09	0.0	8.51E+08	1.34E+08	1.26E+08
CS 137	1.01E+10	1.34E+10	4.68E+09	0.0	4.57E+09	1.78E+09	1.91E+08
BA 140	4.32E+07	5.30E+04	2.78E+06	0.0	1.80E+04	3.56E+04	6.67E+07
CE 141	7.31E+03	4.88E+03	5.61E+02	0.0	2.30E+03	0.0	1.40E+07
CE 144	4.86E+05	2.01E+05	2.61E+04	0.0	1.20E+05	0.0	1.22E+08

TABLE 3.1-20
(1 of 1)

TABLE 3.1-21
 (1 of 1)
 R_i VALUES - COW MILK PATHWAY - CHILD

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	1.58E+03	1.58E+03	1.58E+03	1.58E+03	1.58E+03	1.58E+03
CR 51	0.0	0.0	8.47E+04	4.70E+04	1.28E+04	8.58E+04	4.49E+06
MN 54	0.0	1.56E+07	4.16E+06	0.0	4.38E+06	0.0	1.31E+07
FE 55	8.11E+07	4.30E+07	1.33E+07	0.0	0.0	2.43E+07	7.97E+06
FE 59	9.61E+07	1.55E+08	7.74E+07	0.0	0.0	4.51E+07	1.62E+08
CO 58	0.0	9.40E+06	2.88E+07	0.0	0.0	0.0	5.48E+07
CO 60	0.0	3.19E+07	9.41E+07	0.0	0.0	0.0	1.77E+08
ZN 65	3.49E+09	9.31E+09	5.79E+09	0.0	5.87E+09	0.0	1.63E+09
SR 89	5.25E+09	0.0	1.50E+08	0.0	0.0	0.0	2.03E+08
SR 90	8.69E+10	0.0	2.20E+10	0.0	0.0	0.0	1.17E+09
ZR 95	3.00E+03	6.59E+02	5.86E+02	0.0	9.43E+02	0.0	6.87E+05
MO 99	0.0	7.62E+07	1.89E+07	0.0	1.63E+08	0.0	6.30E+07
SB 124	8.51E+07	1.10E+06	2.98E+07	1.88E+05	0.0	4.72E+07	5.32E+08
I 131	5.97E+08	6.00E+08	3.41E+08	1.98E+11	9.85E+08	0.0	5.34E+07
I 133	8.00E+06	9.89E+06	3.74E+06	1.84E+09	1.65E+07	0.0	3.98E+06
CS 134	1.66E+10	2.73E+10	5.75E+09	0.0	8.45E+09	3.03E+09	1.47E+08
CS 136	8.97E+08	2.47E+09	1.60E+09	0.0	1.31E+09	1.96E+08	8.67E+07
CS 137	2.43E+10	2.33E+10	3.44E+09	0.0	7.59E+09	2.73E+09	1.46E+08
BA 140	1.04E+08	9.14E+04	6.09E+06	0.0	2.98E+04	5.45E+04	5.29E+07
CE 141	1.80E+04	8.98E+03	1.33E+03	0.0	3.94E+03	0.0	1.12E+07
CE 144	1.20E+06	3.76E+05	6.40E+04	0.0	2.08E+05	0.0	9.80E+07

TABLE 3.1-21
 (1 of 1)

TABLE 3.1-22
 (1 of 1)
 R_i VALUES - COW MILK PATHWAY - INFANT

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	2.40E+03	2.40E+03	2.40E+03	2.40E+03	2.40E+03	2.40E+03
CR 51	0.0	0.0	1.34E+05	8.75E+04	1.91E+04	1.70E+05	3.91E+06
MN 54	0.0	2.90E+07	6.58E+06	0.0	6.43E+06	0.0	1.07E+07
FE 55	9.81E+07	6.34E+07	1.69E+07	0.0	0.0	3.10E+07	8.04E+06
FE 59	1.79E+08	3.13E+08	1.23E+08	0.0	0.0	9.26E+07	1.50E+08
CO 58	0.0	1.88E+07	4.69E+07	0.0	0.0	0.0	4.69E+07
CO 60	0.0	6.52E+07	1.54E+08	0.0	0.0	0.0	1.55E+08
ZN 65	4.69E+09	1.61E+10	7.42E+09	0.0	7.80E+09	0.0	1.36E+10
SR 89	9.98E+09	0.0	2.86E+08	0.0	0.0	0.0	2.05E+08
SR 90	9.45E+10	0.0	2.41E+10	0.0	0.0	0.0	1.18E+09
ZR 95	5.32E+03	1.30E+03	9.20E+02	0.0	1.40E+03	0.0	6.46E+05
MO 99	0.0	1.95E+08	2.08E+07	0.0	2.91E+08	0.0	6.42E+07
SB 124	1.64E+08	2.41E+06	5.08E+07	4.35E+05	0.0	1.03E+08	5.06E+08
I 131	1.25E+09	1.47E+09	6.45E+08	4.82E+11	1.71E+09	0.0	5.24E+07
I 133	1.69E+07	2.46E+07	7.20E+06	4.47E+09	2.89E+07	0.0	4.16E+06
CS 134	2.68E+10	4.99E+10	5.04E+09	0.0	1.29E+10	5.27E+09	1.36E+08
CS 136	1.75E+09	5.15E+09	1.92E+09	0.0	2.05E+09	4.20E+08	7.83E+07
CS 137	3.88E+10	4.54E+10	3.22E+09	0.0	1.22E+10	4.94E+09	1.42E+08
BA 140	2.15E+08	2.15E+05	1.11E+07	0.0	5.10E+04	1.32E+05	5.27E+07
CE 141	3.57E+04	2.18E+04	2.56E+03	0.0	6.71E+03	0.0	1.12E+07
CE 144	1.72E+06	7.03E+05	9.62E+04	0.0	2.84E+05	0.0	9.85E+07

TABLE 3.1-22
 (1 of 1)

TABLE 3.1-23
 (1 of 1)
 R_i VALUES - GOAT MILK PATHWAY - ADULT

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	1.57E+03	1.57E+03	1.57E+03	1.57E+03	1.57E+03	1.57E+03
CR 51	0.0	0.0	2.85E+03	1.71E+03	6.28E+02	3.79E+03	7.17E+05
MN 54	0.0	7.51E+05	1.43E+05	0.0	2.24E+05	0.0	2.30E+06
FE 55	2.37E+06	1.64E+06	3.82E+05	0.0	0.0	9.13E+05	9.39E+05
FE 59	3.09E+06	7.25E+06	2.78E+06	0.0	0.0	2.03E+06	2.42E+07
CO 58	0.0	4.39E+05	9.83E+05	0.0	0.0	0.0	8.89E+06
CO 60	0.0	1.46E+06	3.21E+06	0.0	0.0	0.0	2.73E+07
ZN 65	1.39E+08	4.43E+08	2.00E+08	0.0	2.96E+08	0.0	2.79E+08
SR 89	2.42E+09	0.0	6.93E+07	0.0	0.0	0.0	3.87E+08
SR 90	7.64E+10	0.0	1.87E+10	0.0	0.0	0.0	2.21E+09
ZR 95	8.85E+01	2.84E+01	1.92E+01	0.0	4.46E+01	0.0	9.00E+04
MO 99	0.0	2.78E+06	5.30E+05	0.0	6.31E+06	0.0	6.45E+06
SB 124	2.42E+06	4.57E+04	9.59E+05	5.87E+03	0.0	1.88E+06	6.87E+07
I 131	1.63E+08	2.33E+08	1.33E+08	7.63E+10	3.99E+08	0.0	6.14E+07
I 133	2.16E+06	3.76E+06	1.15E+06	5.53E+08	6.56E+06	0.0	3.38E+06
CS 134	1.25E+10	2.96E+10	2.42E+10	0.0	9.59E+09	3.18E+09	5.19E+08
CS 136	7.00E+08	2.76E+09	1.99E+09	0.0	1.54E+09	2.11E+08	3.14E+08
CS 137	1.67E+10	2.28E+10	1.50E+10	0.0	7.76E+09	2.58E+09	4.42E+08
BA 140	2.87E+06	3.61E+03	1.88E+05	0.0	1.23E+03	2.07E+03	5.92E+06
CE 141	4.79E+02	3.24E+02	3.67E+01	0.0	1.50E+02	0.0	1.24E+06
CE 144	3.17E+04	1.33E+04	1.70E+03	0.0	7.86E+03	0.0	1.07E+07

TABLE 3.1-23
 (1 of 1)

TABLE 3.1-24
 (1 of 1)
 R_i VALUES - GOAT MILK PATHWAY - TEENAGER

NUCLIDE	BONE	LIVER	T.BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	204E+03	2.04E+03	2.04E+03	2.04E+03	2.04E+03	2.04E+03
CR 51	0.0	0.0	4.98E+03	2.77E+03	1.09E+03	7.11E+03	8.37E+05
MN 54	0.0	1.25E+06	2.48E+05	0.0	3.73E+05	0.0	2.57E+06
FE 55	4.20E+06	2.98E+06	6.95E+05	0.0	0.0	1.89E+06	1.29E+06
FE 59	5.39E+06	1.26E+07	4.85E+06	0.0	0.0	3.96E+06	2.97E+07
CO 58	0.0	7.39E+05	1.70E+06	0.0	0.0	0.0	1.02E+07
CO 60	0.0	2.47E+06	5.56E+06	0.0	0.0	0.0	3.21E+07
ZN 65	2.14E+08	7.42E+08	3.46E+08	0.0	4.75E+08	0.0	3.14E+08
SR 89	4.45E+09	0.0	1.28E+08	0.0	0.0	0.0	5.30E+08
SR 90	1.08E+11	0.0	2.67E+10	0.0	0.0	0.0	3.03E+09
ZR 95	1.55E+02	4.88E+01	3.36E+01	0.0	7.18E+01	0.0	1.13E+05
MO 99	0.0	5.03E+06	9.59E+05	0.0	1.15E+07	0.0	9.00E+06
SB 124	4.31E+06	7.95E+04	1.68E+06	9.79E+03	0.0	3.77E+06	8.70E+07
I 131	2.95E+08	4.13E+08	2.22E+08	1.21E+11	7.12E+08	0.0	8.18E+07
I 133	3.95E+06	6.70E+06	2.04E+06	9.35E+08	1.17E+07	0.0	5.07E+06
CS 134	2.16E+10	5.09E+10	2.36E+10	0.0	1.62E+10	6.17E+09	6.33E+08
CS 136	1.19E+09	4.69E+09	3.15E+09	0.0	2.55E+09	4.03E+08	3.78E+08
CS 137	3.03E+10	4.03E+10	1.40E+10	0.0	1.37E+10	5.33E+09	5.73E+08
BA 140	5.19E+06	6.35E+03	3.34E+05	0.0	2.15E+03	4.27E+03	8.00E+06
CE 141	8.77E+02	5.86E+02	6.73E+01	0.0	2.76E+02	0.0	1.68E+06
CE 144	5.83E+04	2.41E+04	3.14E+03	0.0	1.44E+04	0.0	1.47E+07

TABLE 3.1-24
 (1 of 1)

TABLE 3.1-25
 (1 of 1)
 R_i VALUES - GOAT MILK PATHWAY - CHILD

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	3.23E+03	3.23E+03	3.23E+03	3.23E+03	3.23E+03	3.23E+03
CR 51	0.0	0.0	1.02E+04	5.64E+03	1.54E+03	1.03E+04	5.39E+05
MN 54	0.0	1.87E+06	4.99E+05	0.0	5.25E+05	0.0	1.57E+06
FE 55	1.05E+07	5.59E+06	1.73E+06	0.0	0.0	3.16E+06	1.04E+06
FE 59	1.25E+07	2.02E+07	1.01E+07	0.0	0.0	5.86E+06	2.10E+07
CO 58	0.0	1.13E+06	3.45E+06	0.0	0.0	0.0	6.58E+06
CO 60	0.0	3.83E+06	1.13E+07	0.0	0.0	0.0	2.12E+07
ZN 65	4.19E+08	1.12E+09	6.95E+08	0.0	7.04E+08	0.0	1.96E+08
SR 89	1.10E+10	0.0	3.15E+08	0.0	0.0	0.0	4.27E+08
SR 90	1.82E+11	0.0	4.62E+10	0.0	0.0	0.0	2.46E+09
ZR 95	3.60E+02	7.91E+01	7.04E+01	0.0	1.13E+02	0.0	8.25E+04
MO 99	0.0	9.15E+06	2.26E+06	0.0	1.95E+07	0.0	7.57E+06
SB 124	1.02E+07	1.32E+05	3.58E+06	2.25E+04	0.0	5.67E+06	6.38E+07
I 131	7.16E+08	7.20E+08	4.09E+08	2.38E+11	1.18E+09	0.0	6.41E+07
I 133	9.59E+06	1.19E+07	4.49E+06	2.20E+09	1.98E+07	0.0	4.78E+06
CS 134	4.99E+10	8.18E+10	1.73E+10	0.0	2.54E+10	9.10E+09	4.41E+08
CS 136	2.69E+09	7.40E+09	4.79E+09	0.0	3.94E+09	5.88E+08	2.60E+08
CS 137	7.30E+10	6.98E+10	1.03E+10	0.0	2.28E+10	8.19E+09	4.37E+08
BA 140	1.25E+07	1.10E+04	7.31E+05	0.0	3.57E+03	6.54E+03	6.34E+06
CE 141	2.16E+03	1.08E+03	1.60E+02	0.0	4.72E+02	0.0	1.34E+06
CE 144	1.44E+05	4.51E+04	7.68E+03	0.0	2.50E+04	0.0	1.18E+07

TABLE 3.1-25
 (1 of 1)

TABLE 3.1-26
(1 of 1)
R_i VALUES - GOAT MILK PATHWAY - INFANT

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	4.90E+03	4.90E+03	4.90E+03	4.90E+03	4.90E+03	4.90E+03
CR 51	0.0	0.0	1.61E+04	1.05E+04	2.29E+03	2.04E+04	4.69E+05
MN 54	0.0	3.48E+06	7.89E+05	0.0	7.72E+05	0.0	1.28E+06
FE 55	1.27E+07	8.24E+06	2.20E+06	0.0	0.0	4.03E+06	1.05E+06
FE 59	2.33E+07	4.07E+07	1.60E+07	0.0	0.0	1.20E+07	1.95E+07
CO 58	0.0	2.26E+06	5.63E+06	0.0	0.0	0.0	5.62E+06
CO 60	0.0	7.82E+06	1.85E+07	0.0	0.0	0.0	1.86E+07
ZN 65	5.63E+08	1.93E+09	8.91E+08	0.0	9.36E+08	0.0	1.63E+09
SR 89	2.10E+10	0.0	6.01E+08	0.0	0.0	0.0	4.31E+08
SR 90	1.98E+11	0.0	5.05E+10	0.0	0.0	0.0	2.48E+09
ZR 95	6.39E+02	1.56E+02	1.10E+02	0.0	1.68E+02	0.0	7.75E+04
MO 99	0.0	2.34E+07	4.56E+06	0.0	3.49E+07	0.0	7.70E+06
SB 124	1.97E+07	2.90E+05	6.10E+06	5.22E+04	0.0	1.23E+07	6.07E+07
I 131	1.49E+09	1.76E+09	7.74E+08	5.79E+11	2.06E+09	0.0	6.29E+07
I 133	2.03E+07	2.95E+07	8.64E+06	5.36E+09	3.47E+07	0.0	4.99E+06
CS 134	8.03E+10	1.50E+11	1.51E+10	0.0	3.86E+10	1.58E+10	4.07E+08
CS 136	5.26E+09	1.55E+10	5.77E+09	0.0	6.16E+09	1.26E+09	2.35E+08
CS 137	1.16E+11	1.36E+11	9.66E+09	0.0	3.66E+10	1.48E+10	4.26E+08
BA 140	2.58E+07	2.58E+04	1.33E+06	0.0	6.12E+03	1.58E+04	6.33E+06
CE 141	4.28E+03	2.61E+03	3.07E+02	0.0	8.05E+02	0.0	1.35E+06
CE 144	2.06E+05	8.44E+04	1.15E+04	0.0	3.41E+04	0.0	1.18E+07

TABLE 3.1-26
(1 of 1)

TABLE 3.1-27
 (1 of 1)
 R_i VALUES - INHALATION PATHWAY - ADULT

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	1.26E+03	1.26E+03	1.26E+03	1.26E+03	1.26E+03	1.26E+03
CR 51	0.0	0.0	9.99E+01	5.94E+01	2.28E+01	5.94E+04	3.32E+03
MN 54	0.0	3.95E+04	6.29E+03	0.0	9.83E+03	1.40E+06	7.72E+04
FE 55	2.45E+04	1.69E+04	3.94E+03	0.0	0.0	7.20E+04	6.02E+03
FE 59	1.17E+04	2.77E+04	1.05E+04	0.0	0.0	1.01E+06	1.88E+05
CO 58	0.0	1.58E+03	2.07E+03	0.0	0.0	9.27E+05	1.06E+05
CO 60	0.0	1.15E+04	1.48E+04	0.0	0.0	5.96E+06	2.84E+05
ZN 65	3.24E+04	1.03E+05	4.65E+04	0.0	6.89E+04	8.63E+05	5.34E+04
SR 89	3.04E+05	0.0	8.71E+03	0.0	0.0	1.40E+06	3.49E+05
SR 90	9.91E+07	0.0	6.09E+06	0.0	0.0	9.59E+06	7.21E+05
ZR 95	1.07E+05	3.44E+04	2.32E+04	0.0	5.41E+04	1.77E+06	1.50E+05
MO 99	0.0	1.21E+02	2.30E+01	0.0	2.92E+02	9.13E+04	2.48E+05
SB 124	3.12E+04	5.88E+02	1.24E+04	7.54E+01	0.0	2.48E+06	4.06E+05
I 131	2.52E+04	3.57E+04	2.05E+04	1.19E+07	6.12E+04	0.0	6.27E+03
I 133	8.63E+03	1.48E+04	4.51E+03	2.15E+06	2.58E+04	0.0	8.87E+03
CS 134	3.72E+05	8.47E+05	7.27E+05	0.0	2.87E+05	9.75E+04	1.04E+04
CS 136	3.90E+04	1.46E+05	1.10E+05	0.0	8.55E+04	1.20E+04	1.17E+04
CS 137	4.78E+05	6.20E+05	4.27E+05	0.0	2.22E+05	7.51E+04	8.39E+03
BA 140	3.90E+04	4.90E+01	2.56E+03	0.0	1.67E+01	1.27E+06	2.18E+05
CE 141	1.99E+04	1.35E+04	1.53E+03	0.0	6.25E+03	3.61E+05	1.20E+05
CE 144	3.43E+06	1.43E+06	1.84E+05	0.0	8.47E+05	7.76E+06	8.15E+05

TABLE 3.1-27
 (1 of 1)

TABLE 3.1-28
 (1 of 1)
 R_i VALUES - INHALATION PATHWAY - TEENAGER

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	1.27E+03	1.27E+03	1.27E+03	1.27E+03	1.27E+03	1.27E+03
CR 51	0.0	0.0	1.35E+02	7.49E+01	3.07E+01	2.09E+04	3.00E+03
MN 54	0.0	5.10E+04	8.39E+03	0.0	1.27E+04	1.98E+06	6.67E+04
FE 55	3.34E+04	2.38E+04	5.54E+03	0.0	0.0	1.24E+05	6.38E+03
FE 59	1.59E+04	3.69E+04	1.43E+04	0.0	0.0	1.53E+06	1.78E+05
CO 58	0.0	2.07E+03	2.77E+03	0.0	0.0	1.34E+06	9.51E+04
CO 60	0.0	1.51E+04	1.98E+04	0.0	0.0	8.71E+06	2.59E+05
ZN 65	3.85E+04	1.33E+05	6.23E+04	0.0	8.63E+04	1.24E+06	4.66E+04
SR 89	4.34E+05	0.0	1.25E+04	0.0	0.0	2.41E+06	3.71E+05
SR 90	1.08E+08	0.0	6.67E+06	0.0	0.0	1.65E+07	7.64E+05
ZR 95	1.45E+05	4.58E+04	3.15E+04	0.0	6.73E+04	2.68E+06	1.49E+05
MO 99	0.0	1.69E+02	3.23E+01	0.0	4.12E+02	1.54E+05	2.69E+05
SB 124	4.30E+04	7.92E+02	1.68E+04	9.75E+01	0.0	3.84E+06	3.98E+05
I 131	3.54E+04	4.90E+04	2.64E+04	1.46E+07	8.39E+04	0.0	6.48E+03
I 133	1.21E+04	2.05E+04	6.21E+03	2.92E+06	3.59E+04	0.0	1.03E+04
CS 134	5.02E+05	1.13E+06	5.48E+05	0.0	3.75E+05	1.46E+05	9.75E+03
CS 136	5.14E+04	1.93E+05	1.37E+05	0.0	1.10E+05	1.77E+04	1.09E+04
CS 137	6.69E+05	8.47E+05	3.11E+05	0.0	3.04E+05	1.21E+05	8.47E+03
BA 140	5.46E+04	6.69E+01	3.51E+03	0.0	2.28E+01	2.03E+06	2.28E+05
CE 141	2.84E+04	1.89E+04	2.16E+03	0.0	8.87E+03	6.13E+05	1.26E+05
CE 144	4.88E+06	2.02E+06	2.62E+05	0.0	1.21E+06	1.33E+07	8.63E+05

TABLE 3.1-28
 (1 of 1)

TABLE 3.1-29
 (1 of 1)
 R_i VALUES - INHALATION PATHWAY - CHILD

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	1.12E+03	1.12E+03	1.12E+03	1.12E+03	1.12E+03	1.12E+03
CR 51	0.0	0.0	1.54E+02	8.53E+01	2.43E+01	1.70E+04	1.08E+03
MN 54	0.0	4.29E+04	9.50E+03	0.0	1.00E+04	1.57E+06	2.29E+04
FE 55	4.73E+04	2.51E+04	7.76E+03	0.0	0.0	1.11E+05	2.86E+03
FE 59	2.07E+04	3.34E+04	1.67E+04	0.0	0.0	1.27E+06	7.06E+04
CO 58	0.0	1.77E+03	3.16E+03	0.0	0.0	1.10E+06	3.43E+04
CO 60	0.0	1.31E+04	2.26E+04	0.0	0.0	7.06E+06	9.61E+04
ZN 65	4.25E+04	1.13E+05	7.02E+04	0.0	7.13E+04	9.94E+05	1.63E+04
SR 89	5.99E+05	0.0	1.72E+04	0.0	0.0	2.15E+06	1.67E+05
SR 90	1.01E+08	0.0	6.43E+06	0.0	0.0	1.47E+07	3.43E+05
ZR 95	1.90E+05	4.17E+04	3.69E+04	0.0	5.95E+04	2.23E+06	6.10E+04
MO 99	0.0	1.73E+02	4.26E+01	0.0	3.93E+02	1.36E+05	1.27E+05
SB 124	5.73E+04	7.39E+02	2.00E+04	1.26E+02	0.0	3.24E+06	1.64E+05
I 131	4.80E+04	4.80E+04	2.72E+04	1.62E+07	7.87E+04	0.0	2.84E+03
I 133	1.66E+04	2.03E+04	7.68E+03	3.84E+06	3.37E+04	0.0	5.47E+03
CS 134	6.50E+05	1.01E+06	2.24E+05	0.0	3.30E+05	1.21E+05	3.84E+03
CS 136	6.50E+04	1.71E+05	1.16E+05	0.0	9.53E+04	1.45E+04	4.17E+03
CS 137	9.05E+05	8.24E+05	1.28E+05	0.0	2.82E+05	1.04E+05	3.61E+03
BA 140	7.39E+04	6.47E+01	4.32E+03	0.0	2.11E+01	1.74E+06	1.02E+05
CE 141	3.92E+04	1.95E+04	2.89E+03	0.0	8.53E+03	5.43E+05	5.65E+04
CE 144	6.76E+06	2.11E+06	3.61E+05	0.0	1.17E+06	1.19E+07	3.88E+05

TABLE 3.1-29
 (1 of 1)

TABLE 3.1-30
 (1 of 1)
 R_i VALUES - INHALATION PATHWAY - INFANT

NUCLIDE	BONE	LIVER	T. BODY	THYROID	KIDNEY	LUNG	GI-LLI
H 3	0.0	6.46E+02	6.46E+02	6.46E+02	6.46E+02	6.46E+02	6.46E+02
CR 51	0.0	0.0	8.93E+01	5.75E+01	1.32E+01	1.28E+04	3.56E+02
MN 54	0.0	2.53E+04	4.98E+03	0.0	4.98E+03	9.98E+05	7.05E+03
FE 55	1.97E+04	1.17E+04	3.33E+03	0.0	0.0	8.68E+04	1.09E+03
FE 59	1.35E+04	2.35E+04	9.46E+03	0.0	0.0	1.01E+06	2.47E+04
CO 58	0.0	1.22E+03	1.82E+03	0.0	0.0	7.76E+05	1.11E+04
CO 60	0.0	8.01E+03	1.18E+04	0.0	0.0	4.50E+06	3.19E+04
ZN 65	1.93E+04	6.25E+04	3.10E+04	0.0	3.24E+04	6.46E+05	5.13E+04
SR 89	3.97E+05	0.0	1.14E+04	0.0	0.0	2.03E+06	6.39E+04
SR 90	4.08E+07	0.0	2.59E+06	0.0	0.0	1.12E+07	1.31E+05
ZR 95	1.15E+05	2.78E+04	2.03E+04	0.0	3.10E+04	1.75E+06	2.17E+04
MO 99	0.0	1.65E+02	3.24E+01	0.0	2.65E+02	1.35E+05	4.88E+04
SB 124	3.79E+04	5.55E+02	1.20E+04	1.00E+02	0.0	2.64E+06	5.90E+04
I 131	3.79E+04	4.43E+04	1.96E+04	1.48E+07	5.17E+04	0.0	1.06E+03
I 133	1.32E+04	1.92E+04	5.59E+03	3.55E+06	2.24E+04	0.0	2.15E+03
CS 134	3.96E+05	7.02E+05	7.44E+04	0.0	1.90E+05	7.95E+04	1.33E+03
CS 136	4.82E+04	1.34E+05	5.28E+04	0.0	5.63E+04	1.17E+04	1.43E+03
CS 137	5.48E+05	6.11E+05	4.54E+04	0.0	1.72E+05	7.12E+04	1.33E+03
BA 140	5.59E+04	5.59E+01	2.89E+03	0.0	1.34E+01	1.59E+06	3.83E+04
CE 141	2.77E+04	1.66E+04	1.99E+03	0.0	5.24E+03	5.16E+05	2.15E+04
CE 144	3.19E+06	1.21E+06	1.76E+05	0.0	5.37E+05	9.83E+06	1.48E+05

TABLE 3.1-30
 (1 of 1)

OCONEE

January 1, 2000

Subject: Offsite Dose Calculation Manual (ODCM)
Oconee Nuclear Station Section - Revision 40

The General Office Radiation Protection Staff is transmitting to you this date Revision 40 of the Oconee Offsite Dose Calculation Manual. As this revision only affects Oconee Nuclear Station, the approval of other station managers is not required. A list of affected pages is given below. Please insert this letter with the attached Justification section in front of the January 1, 1999, Revision 39 letter.

REMOVE THESE PAGES

Figure A1.0-2 (four pages)
Table A4.0-7
Table A4.0-8
Figure A4.0-1 (page 9 of 9)
A21

INSERT THESE PAGES

Figure A1.0-2 (four pages)
A4.0-7
Table A4.0-8
Figure A4.0-1 (page 9 of 9)
A21

Effective Date: 1/1/00



L. E. Haynes, Technical Manager
Radiation Protection

Effective Date: 1/1/00



J. S. Forbes, Manager
Oconee Nuclear Station

If you have any questions concerning Revision 40, please call Caryl Ingram at (704) 382-4496.



Caryl D. Ingram, Senior Engineer
Radiation Protection
Nuclear Services Division

JUSTIFICATION FOR REVISION 40

(page 1 of 1)

Figure A1.0-2 (four pages)

Monitor designations updated to reflect current design. Monitor changes were due to recent modifications to the plant radiation monitoring system. RIA-49A on each of the 3 Units was added during the modification. Units 1&2 RIA-32 replaced 1 RIA-51 and 2 RIA-51, and Unit 3 RIA-32 replaced 3 RIA-51. RIA-56 on all 3 Units monitors the Unit Vent directly, rather than through an off-line process as had been indicated in the previous figures. The Interim Radwaste Facility ventilation system exhaust is monitored by a flow rate measuring device, rather than a flow totalizer as had been indicated in the previous figure.

Table A4.0-7

Revised the maximum meat location dispersion factors and deposition factors based on the 1999 land use census.

Table A4.0-8

Revised table based on the 1999 land use census.

Figure A4.0-1 (page 9 of 9)

Revised the maximum meat location dispersion factors and deposition factors based on the 1999 land use census.

Page A-21

Updated the name for Duke Power's environmental laboratory to EnRad. Revised the Selected Licensee Commitment reference and the land use census dates.

APPENDIX A

OCONEE NUCLEAR STATION
SITE SPECIFIC INFORMATION

APPENDIX A

TABLE OF CONTENTS

	<u>PAGE</u>
A1.0 <u>OCONEE NUCLEAR STATION RADWASTE SYSTEMS</u>	A-1
A2.0 <u>RELEASE RATE CALCULATION</u>	A-3
A3.0 <u>RADIATION MONITOR SETPOINTS</u>	A-9
A4.0 <u>DOSE CALCULATIONS</u>	A-16
A5.0 <u>RADIOLOGICAL ENVIRONMENTAL MONITORING</u>	A-21

A1.0 OCONEE NUCLEAR STATION RADWASTE SYSTEMS

A1.1 LIQUID RADWASTE PROCESSING

The liquid radwaste system at Oconee Nuclear Station (ONS) is used to collect and treat fluid chemical and radiochemical by-products of unit operation. The systems produce effluents which can be reused in the plant or discharged in small, dilute quantities to the environment. The means of treatment vary with waste type and desired product in the various systems:

- A) Filtration - waste sources are filtered prior to processing as necessary.
- B) Ion Exchange - ion exchange is used to remove radioactive ions from solution. Also, ion exchange is normally used in removing cations (cobalt, manganese) and anions (chloride, fluoride) from evaporator feed and/or distillates in order to purify the distillates for reuse as makeup water. Distillate from the Waste Evaporator System or the Waste and Recycle Evaporator can be treated by this method.
- C) Gas Stripping - removal of gaseous radioactive fission products is accomplished in Evaporators and the venting of atmospheric holdup tanks.
- D) Distillation - production of pure water from the waste by boiling it away from the contaminated solution which originally contained it is accomplished by both evaporators. Proper control of the process will yield water which can be reused for makeup. Polishing of this product can be achieved by ion exchange as indicated above.
- E) Concentration - in all Evaporators, radioactivity and dissolved chemicals are concentrated as water is boiled away. In the case of the Waste Evaporator, the volume of water containing waste chemicals and radionuclides is reduced so that the waste may be more easily and economically solidified and shipped for burial. In the case of the VR dryer, all water is removed and the dry salts are solidified for burial.

Figure A1.0-1 is a schematic representation of the liquid radwaste system at Oconee.

A1.2 GASEOUS WASTE PROCESSING

The purpose of the gaseous waste disposal system is to:

- (1) Maintain a non-oxidizing cover gas of nitrogen in tanks and equipment that contain potentially radioactive gas,
- (2) Hold up radioactive gas for decay, and
- (3) Release gases (radioactive or non-radioactive) to the atmosphere under controlled conditions.


During power operation of the facilities, radioactive materials released to the atmosphere in gaseous effluents include low concentrations of fission product noble gases (krypton and xenon), halogens (mostly iodines), tritium contained in water vapor and particulate material including both fission products and activated corrosion products.

The primary source of gaseous radioactive wastes is from the degassing of the primary coolant during letdown of the cooling water into the various holding tanks. Additional sources of gaseous waste activity include the auxiliary building exhaust, spent fuel area exhaust, the discharge from the steam jet air ejectors, purging and venting of the reactor containment building.

All components that can contain potentially radioactive gases are vented to a vent header. The vent gases are subsequently drawn from this vent header by one of four waste gas compressors or a waste gas exhauster. The waste gas compressor discharges through a waste gas separator to one of seven waste gas tanks. The waste gas tanks and the waste gas exhauster discharge to the unit vent after passing through a filter bank consisting of a prefilter, an absolute filter, and a charcoal filter.


Radioactive gases may be released inside the reactor containment building when components of the primary system are opened to the building atmosphere for operational reasons or where minor leaks occur in the primary system. Prior to access, the reactor containment atmosphere will be monitored for activity and, when necessary, purged through prefilters, high-efficiency particulate air (HEPA) filters and charcoal adsorbers and released to atmosphere through the unit vent. The purge equipment is sized for a flow rate of 50,000 cfm providing approximately 1.5 air changes per hour in the reactor building. Units 1, 2 & 3 have a separate vent stack from each reactor building.

The gaseous waste handling and treatment systems for the Oconee Nuclear Station are shown schematically in Fig. A1.0-2.




GASEOUS WASTE SYSTEM
 OCONEE NUCLEAR STATION
 FIGURE A1.0-2
 PAGE 1 OF 4

REVISION 40
 1/1/00



GASEOUS WASTE SYSTEM
 OCONEE NUCLEAR STATION
 FIGURE A1.0-2
 PAGE 2 OF 4


REVISION 40
 1/1/00




GASEOUS WASTE SYSTEM
 OCONEE NUCLEAR STATION
 FIGURE A1.0-2
 PAGE 3 OF 4

REVISION 40
 1/1/00


HOT MACHINE SHOP



INTERIM RADWASTE FACILITY



RADWASTE BUILDING



A2.0 RELEASE RATE CALCULATION

Generic release rate methodology is presented in Section 1.0; this methodology with Oconee-specific input data will be used to calculate release rates from Oconee Nuclear Station.

A2.1 LIQUID RELEASE RATE CALCULATIONS

There are two potential release points at Oconee, the liquid radwaste effluent line to the Keowee Hydroelectric Unit Tailrace and the #3 Chemical Treatment Pond effluent line to the Keowee River.

A2.1.1 Liquid Radwaste Effluent Line To The Keowee Hydroelectric Unit Tailrace

To simplify calculations for the liquid radwaste effluent line, it is assumed that no activity above background is present in the #3 Chemical Treatment Pond effluent. This assumption shall be confirmed by radiation monitoring and/or the sampling of the pond's radioactive inputs, and by periodic analysis of the composite sample collected at the #3 Chemical Treatment Pond discharge. For the liquid radwaste effluent line the following calculation shall be performed to determine a discharge flow, in gpm:

$$f \leq F \div \left[\sigma \sum_{i=1}^n \frac{C_i}{(10 \times EC_i)} \right]$$

where:

f = the undiluted effluent flow, in gpm.

C_i = the concentration of radionuclide, 'i', in undiluted effluent as determined by laboratory analyses, in $\mu\text{Ci/ml}$.

EC_i = the concentration of radionuclide, 'i', from 10CFR20, Appendix B, Table 2, Column 2. If radionuclide, 'i', is a dissolved noble gas, the EC_i = $1.0\text{E-}5 \mu\text{Ci/ml}$.

F = the dilution flow available, in gpm

typical flow rates are:

3.41E+04 gpm (based on a leakage rate of 38 cfs, plus the Keowee Hydro Fire Protection - LWR mixing line whose flow rate is 38 cfs)

2.9E+6 gpm (based on one hydro unit operating at 50% power, 6600 cfs)

σ = the recirculation factor at equilibrium is 1.0. (See Section 1.1)

A2.1.2 #3 Chemical Treatment Pond Effluent Line

The #3 Chemical Treatment Pond effluent is the release point for station effluents that are normally considered to be non-radioactive; that is, the pond's effluent will not normally contain measurable activity above background. It is assumed that no activity is present in the effluent until indicated by radiation monitoring measurements on the pond's inputs and/or by periodic analyses of the composite sample collected at the pond's discharge point. Inputs to this pond include the plant's yard drain system, the decant water from the Powdex system, the discharge from the Turbine Building Sump system, and Radwaste Facility monitor tanks whose contents have been determined to be below background. Inputs that have radiation monitors associated with them will be set to assure that Selected Licensee Commitment 16.11-1.1 will not be exceeded.

The #3 Chemical Treatment Pond may also be the discharge path for large volumes of slightly contaminated water following a primary-secondary leak so long as administrative procedures are implemented to assure that release rate calculations similiar to that used in Section A2.1.1 are performed, that all detectable radionuclides will be accounted for, and that no station limits will be exceeded.

A2.1.3 Low Pressure Service Water Effluent Line

The Low Pressure Service water effluent is normally considered nonradioactive; that is, it is unlikely the effluent will contain measurable activity above background. It is assumed that no activity is present in the effluent until indicated by radiation monitoring measurements. Radiation monitoring alarm setpoints, in conjunction with administrative controls, assure that release limits are not exceeded.

A2.2 GASEOUS RELEASE RATE CALCULATIONS FOR SEMI-ELEVATED RELEASE POINTS

The unit vents are the release points for waste gas decay tanks, containment building purges, containment building vents, the condenser air ejector, and auxiliary building ventilation. The unit vent is treated as a semi-elevated release point. The applicable dispersion and deposition parameters are provided in Tables A4.0-1a and A4.0-1b respectively.

The condenser air ejector effluent is normally considered nonradioactive; that is, it is unlikely the effluent will contain measureable activity above background. It is assumed that no activity is present in the effluent until indicated by radiation monitoring measurements and by analyses of periodic samples collected from this source. Radiation monitoring alarm/trip setpoints in conjunction with administrative controls assure that release limits are not exceeded; see section on radiation monitoring setpoints.

The following calculations, when solved for flowrate, are the release rates for noble gases and for radioiodines, particulates and other radionuclides with half-lives greater than 8 days; the most conservative of release rates calculated in A2.2.1 and A2.2.2 shall control the release rates for a single release point.

A2.2.1 Release rate limit for noble gases:

$$\sum_i K_i [(\overline{X/Q})\tilde{Q}_i] < 500 \text{ mrem/yr, and}$$

$$\sum_i (L_i + 1.1 M_i) [(\overline{X/Q})\tilde{Q}_i] < 3000 \text{ mrem/yr}$$

where the terms are defined below.

A2.2.2 Release rate limit for all radioiodines and radioactive materials in particulate form and radionuclides other than noble gases:

$$\sum_i P_i [W \tilde{Q}_i] < 1500 \text{ mrem/yr}$$

where:

K_i = The total body dose factor due to gamma emissions for each identified noble gas radionuclide, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1.

L_i = The skin dose factor due to beta emissions for each identified noble gas radionuclide, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1.

M_i = The air dose factor due to gamma emissions for each identified noble gas radionuclide, in mrad/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1 (unit conversion constant of 1.1 mrem/mrad converts air dose to skin dose).

P_i = The dose parameter for radionuclides other than noble gases for the inhalation pathway, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ and for the food and ground plane pathways in $\text{m}^2 \cdot (\text{mrem}/\text{yr})$ per $\mu\text{Ci}/\text{sec}$ from Table 1.2-2. The dose factors are based on the critical individual organ and most restrictive age group (child or infant).

\bar{Q}_i = The release rate of radionuclides, i, in gaseous effluent from all release points at the site, in $\mu\text{Ci}/\text{sec}$.

\bar{X}/\bar{Q} = $1.672\text{E}-6 \text{ sec}/\text{m}^3$. The highest calculated annual average relative concentration for any area at or beyond the unrestricted area boundary. The location is the SW sector @ 1.0 mile for semi-elevated releases.

W = The highest calculated annual average dispersion or deposition parameter for estimating the maximum dose rate to an individual from the total inhalation, food and ground pathways resulting from semi-elevated releases:

W = $1.672\text{E}-6 \text{ sec}/\text{m}^3$, for the inhalation pathway. The location is the SW sector @ 1.0 mile.

W = $1.295\text{E}-08 \text{ 1}/\text{m}^2$, for the food and ground plane pathways. The location is the NE sector @ 1.0 mile.

$$\bar{Q}_i = k_1 C_i f \div k_2 = 4.72\text{E}+02 C_i f$$

where:

C_i = the concentration of radionuclide, i, in undiluted gaseous effluent, in $\mu\text{Ci}/\text{ml}$.

f = the undiluted effluent flow, in cfm

k_1 = conversion factor, $2.83\text{E}+04 \text{ ml}/\text{ft}^3$

k_2 = conversion factor, $6.0\text{E}+01 \text{ sec}/\text{min}$

A2.3 GASEOUS RELEASE RATE CALCULATIONS FOR GROUND LEVEL RELEASE POINTS

Hot Machine Shop Building ventilation exhaust, Radwaste Facility Exhaust, and Auxiliary Boiler releases are treated as ground-level release points. The applicable dispersion and deposition parameters are provided in Tables A4.0-2a and A4.0-2b respectively.

It is assumed that no activity is present in effluent from these sources until indicated by radiation monitoring measurements and by analyses of periodic samples collected from these sources. Radiation monitoring alarm/trip setpoints in conjunction with administrative controls assure that release limits are not exceeded; see section on radiation monitoring setpoints.

The following calculations, when solved for flowrate, are the release rates for noble gases and for radioiodines, particulates and other radionuclides with half-lives greater than 8 days; the most conservative of release rates calculated in A2.3.1 and A2.3.2 shall control the release rates for a single release point.

A2.3.1 Release rate limit for noble gases:

$$\sum_i K_i [(X/Q)Q_i] < 500 \text{ mrem/yr, and}$$

$$\sum_i (L_i + 1.1 M_i) [(X/Q)Q_i] < 3000 \text{ mrem/yr}$$

where the terms are defined below:

A2.3.2 Release rate limit for all radioiodines and radioactive materials in particulate form and radionuclides other than noble gases:

$$\sum_i P_i [W Q_i] < 1500 \text{ mrem/yr}$$

where:

K_i = The total body dose factor due to gamma emissions for each identified noble gas radionuclide, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1.

L_i = The skin dose factor due to beta emissions for each identified noble gas radionuclide, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1.

M_i = The air dose factor due to gamma emissions for each identified noble gas radionuclide, in mrad/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1 (unit conversion constant of 1.1 mrem/mrad converts air dose to skin dose).

P_i = The dose parameter for radionuclides other than noble gases for the inhalation pathway, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ and for the food and ground plane pathways in $\text{m}^2 \cdot (\text{mrem/yr})$ per $\mu\text{Ci}/\text{sec}$ from Table 1.2-2. The dose factors are based on the critical individual organ and most restrictive age group (child or infant).

\bar{Q}_i = The release rate of radionuclides, i , in gaseous effluent from all release points at the site, in $\mu\text{Ci}/\text{sec}$.

\bar{X}/\bar{Q} = $7.308\text{E-}6 \text{ sec}/\text{m}^3$. The highest calculated annual average relative concentration for any area at or beyond the unrestricted area boundary. The location is the SE sector @ 1.0 mile for ground-level releases.

W = The highest calculated annual average dispersion or deposition parameter for estimating the maximum dose rate to an individual from the total inhalation, food and ground plane pathways resulting from ground level releases:

$W = 7.308\text{E-}6 \text{ sec}/\text{m}^3$, for the inhalation pathway. The location is the SE sector @ 1.0 mile.

$W = 2.259\text{E-}8 \text{ 1}/\text{m}^2$, for the food and ground plane pathways. The location is the NE sector @ 1.0 mile.

$$\bar{Q}_i = k_1 C_i f + k_2 = 4.72\text{E+}02 C_i f$$

where:

C_i = the concentration of radionuclide, i , in undiluted gaseous effluent, in $\mu\text{Ci}/\text{ml}$.

f = the undiluted effluent flow, in cfm

k_1 = conversion factor, $2.83\text{E+}04 \text{ ml}/\text{ft}^3$

k_2 = conversion factor, $6.0\text{E+}01 \text{ sec}/\text{min}$

A3.0 RADIATION MONITOR SETPOINTS

Using the generic calculations presented in Section 2.0, final radiation monitoring setpoints are calculated for monitoring as required by the Selected Licensee Commitments.

All final effluent radiation monitors for Oconee are off-line. These monitors alarm on low flow; the minimum flow alarm level for the liquid monitors is 3 gallons per minute and for all gas monitors, except in the Radwaste Facility, is 7 standard cubic feet per minute. These monitors measure the activity in the liquid or gas volume exposed to the detector and are independent of flow rate if a minimum flow rate is assured. The Radwaste Facility gas monitors have a minimum flow alarm level of 2 standard cubic feet per minute and adjusts flow rate as the line flow changes.

Radiation monitoring setpoints calculated in the following sections are expressed in activity concentrations; in reality the monitor readout is in counts per minute, except for the Radwaste Facility gas monitor where its readout is in ($\mu\text{Ci/ml}$). The relationship between concentration and counts per minute shall be established by station procedure using the following relationship: Station radiation monitor setpoint procedures which correlate concentration and counts per minute shall be based on the formula below and will be determined using the monitor's correlation graph. The correlation graph shows concentration ($\mu\text{Ci/ml}$) vs. monitor reading (cpm) based on empirical data.

$$c = \frac{r}{2.22 \times 10^6 e v}$$

where:

c = the gross activity, in $\mu\text{Ci/ml}$
r = the count rate, in cpm
 2.22×10^6 = the disintegration per minute per μCi
e = the counting efficiency, cpm/dpm
v = the volume of fluid exposed to the detector, in ml.

A3.1 LIQUID RADIATION MONITORS

A3.1.1 Liquid Radwaste Effluent Line To The Keowee Hydroelectric Unit Tailrace

As described in Section A2.1.1 of this manual on release rate calculations for the waste liquid effluent, the release is controlled by limiting the flow rate of effluent from the station. Although the release rate is flow rate controlled, the radiation monitor setpoint shall be set to terminate the release if the effluent activity should exceed that used to calculate the release rate. Also, a radiation monitor setpoint shall be set to alarm if the effluent activity should exceed that determined by laboratory analyses.

A3.1.2 Turbine Building Sump Discharge Line

As described in Section A2.1.2 of this manual on release rate calculations for the turbine building sump effluent, the effluent is normally considered nonradioactive; that is, it is unlikely the effluent will contain measurable activity above background. It is assumed that no activity is present in the effluent until indicated by radiation monitoring and by routine analysis of the composite sample collected at the #3 Chemical Treatment Pond. Since the system discharges automatically, the maximum system concentration, which also is the radiation monitor setpoint, is calculated to assure compliance with release limits.

A typical setpoint is calculated as follows:

$$c \leq \frac{10 \times EC \times F}{\sigma f} = 2.0E-4 \mu\text{Ci/ml}$$

where:

- c = the gross activity in undiluted effluent, in $\mu\text{Ci/ml}$.
- f = the flow rate of undiluted effluent which may vary from 0-750 gpm, but is assumed to be 750 gpm.
- EC = $9.0E-07 \mu\text{Ci/ml}$, the EC for Cs-134, which is the lowest effluent concentration value for any detectable radionuclide that is not known to be absent from the TBS effluent.***
- σ = 1 (See Section A2.1.1)
- F = the flow may vary from 38 to 6,600 cfs, but is conservatively estimated at 38 cfs ($1.7E+04$ gpm), the minimum flow available.

A3.1.3 Radwaste Facility Effluent Line To CTP #3

As described in Section A2.1.2 of this manual on release rate calculations, the Radwaste Facility Effluent is normally considered non-radioactive; that is, it is unlikely the effluent will contain measurable activity above background. It is assumed that no activity is present in the effluent until indicated by radiation monitoring and/or by routine analyses of the composite sample collected at the discharge of the #3 Chemical Treatment Pond. In order to assure that no activity is unknowingly discharged into the pond, the inputs to the Radwaste Facility Effluent Line are released in discrete batches where each batch is sampled for activity prior to release.

*** The justification for this assumption is provided in 10 CFR 20, Appendix B, Note 2. A review of past liquid effluent release data shows that Cs-134 has the lowest effluent concentration value for any detectable radionuclide in the effluent. An annual review of the effluent release data will be performed to assure that this assumption remains valid.

A3.1.4 Low Pressure Service Water Discharge Line

As described in Section A2.1.3 of this manual on release rate calculations for the Low Pressure Service water effluent, the effluent is normally considered nonradioactive; that is, it is unlikely the effluent will contain measurable activity above background. It is assumed that no activity is present in the effluent until indicated by radiation monitoring equipment. Since the system discharges automatically, the maximum system concentration which is also the radiation monitor setpoint, is calculated to assure compliance with release limits.

A typical monitor setpoint is calculated as follows:

$$C \leq \frac{EC \times 10 \times F}{\sigma f} = 1.04E-3 \mu\text{Ci/ml}$$

where:

C = the gross activity in undiluted effluent, in $\mu\text{Ci/ml}$.

f = the flow rate of undiluted effluent which may vary from 0 to 10,500 gpm but is assumed to be 10,500 gpm.

EC = $9.0E-07 \mu\text{Ci/ml}$, the EC for Cs-134, which is the lowest effluent concentration value for any detectable radionuclide that is not known to be absent from the LPSW effluent. ***

σ = recirculation factor for Lake Keowee, 1.02.

F = the flow rate of the condensate cooling water is based on having seven CCW pumps in operation, $1.24E+06$ gpm. Should the number of operating pumps decrease, the setpoint must be recalculated.

*** The justification for this assumption is provided in 10 CFR 20, Appendix B, Note 2. A review of past liquid effluent release data shows that Cs-134 has the lowest effluent concentration value for any detectable radionuclide in the effluent. An annual review of the effluent release data will be performed to assure that this assumption remains valid.

A3.2 GASEOUS RADIATION MONITOR SETPOINTS FOR SEMI-ELEVATED RELEASE POINTS

The following equation shall be used to calculate final effluent noble gas radiation monitor setpoints based on Xe-133:

$$K(\overline{X/Q})\overline{Q} < 500 \text{ mrem (See Section A2.2.1)}$$

$$\overline{Q} = 4.72E+2 \text{ Cf (See Section A2.2.2)}$$

$$(K)(\overline{X/Q})(472)(C)(f) < 500$$

$$C < \frac{500}{(206)(1.672E-6)(472)} \div f$$

$$C < 3.08E+3/f$$

where:

C = the gross activity in undiluted effluent, in $\mu\text{Ci/ml}$

f = the flow from the tank or building and varies for various release sources, in cfm

K = from Table 1.2-1 for Xe-133, $2.06E+2$ mrem/yr per $\mu\text{Ci/m}^3$

$\overline{X/Q}$ = $1.672E-6$ sec/ m^3 , as defined in section A2.2.2.

A3.2.1 Gaseous Radwaste Effluent Line - Waste Gas Decay Tanks

As described in Section 2.2, the release is controlled by limiting the flow rate of the effluent from the station. Although the release rate is flow rate controlled, the radiation monitor setpoint shall be set to terminate the release if the effluent activity should exceed that determined by laboratory analyses and that used to calculate the release rate. A typical radiation monitor setpoint may be calculated as follows:

$$C < 3.08E+3/f = 1.03E+02 \mu\text{Ci/ml}$$

where:

f = 30 cfm

A3.2.2 Unit Vent

As stated in Section A2.2, the unit vent is the release point for waste gas decay tanks, containment building purges, containment building vents, the condenser air ejector, and auxiliary building ventilation. Since all of these releases are through the unit vent, the radiation monitor on the unit vent may be used to assure that station release limits are not exceeded. Depending on the stack flow, a typical radiation monitor setpoint may be calculated as follows:

$$C < 3.08E+3/f = 3.24E-2 \mu\text{Ci/ml}$$

where:

$$f = 45,000 \text{ cfm (auxiliary building)} + 50,000 \text{ cfm (containment purge)} = 95,000 \text{ cfm}$$

or

$$C < 3.08E+3/f = 6.84E-2 \mu\text{Ci/ml}$$

where:

$$f = 45,000 \text{ cfm (auxiliary building ventilation)}$$

A3.3 GASEOUS RADIATION MONITOR SETPOINTS FOR GROUND-LEVEL RELEASE POINTS

The following equation shall be used to calculate final effluent noble gas radiation monitor setpoints based on Xe-133:

$$K(\bar{X}/\bar{Q})\bar{Q}_i < 500 \text{ mrem (See Section A2.2.1)}$$

$$\bar{Q}_i = 4.72\text{E}+2 \text{ C}_i f \text{ (See Section A2.2.2)}$$

$$(K)(\bar{X}/\bar{Q})(472)(C_i)(f) < 500$$

$$C < \frac{500}{(206)(7.308\text{E}-6)(472)} \div f$$

$$C < 7.04\text{E}+2/f$$

where:

- C = the gross activity in undiluted effluent, in $\mu\text{Ci}/\text{ml}$
- f = the flow from the tank or building and varies for various release sources, in cfm
- K = from Table 1.2-1 for Xe-133, $2.06\text{E}+2$ mrem/yr per $\mu\text{Ci}/\text{m}^3$
- \bar{X}/\bar{Q} = $7.308\text{E}-6$ sec/ m^3 , as defined in section A2.3.2.

A3.3.1 Interim Radwaste Building Ventilation Exhaust

Ventilation exhaust from the Interim Radwaste Building is considered a separate release point. This exhaust is normally considered non-radioactive; that is, it is possible but unlikely that the effluent will contain measurable activity above background. Since the exhaust is continuous, a maximum concentration of gases in the exhaust, which also is the radiation monitor setpoint, is calculated to assure compliance with release limits. A typical radiation monitor setpoint may be calculated as follows:

$$C < 7.04\text{E}+2/f = 4.79\text{E}-2 \mu\text{Ci}/\text{ml}$$

where:

$$f = 1.47\text{E}+04 \text{ cfm}$$

A3.3.1 Hot Machine Shop Building Ventilation Exhaust

Ventilation exhaust from the Hot Machine Shop is considered to be a separate release point. This filtered exhaust is sampled and analyzed for particulates and radioiodines to assure that the effluent released has not exceeded station release limits. Since it is assumed that no noble gases will be generated by machine shop work, no provision for monitoring noble gas releases are provided.

A3.3.2 Contaminated Oil Burning In Auxiliary Boiler

Contaminated oil may be burned in the auxiliary boiler which is not released through the unit vent and is considered a separate release point. The contaminated oil is filtered, mixed, and sampled to determine the total activity to be released and the allowable release (burn) rate.

By Selected Licensee Commitments, releases from the auxiliary boiler from incineration of contaminated oil must meet the instantaneous release rate for iodines and particulates given in Section A2.2.2. Also, the total dose due to these releases must be less than 0.1% of the allowable yearly dose from particulate gaseous effluents.

Doses from incineration of contaminated oil are calculated for all organs and all pathways using either the models provided in Section 3.1.2.2 of this manual or the RETDAS computer program. Cumulative doses are calculated quarterly at a minimum.

All the activity in the contaminated oil is assumed to be released during incineration and the total is added to the station's quarterly and annual release records.

A3.3.3 Radwaste Facility Ventilation and Process Gas Exhaust

The ventilation and process gas exhaust from the Radwaste Facility is considered a separate release point. This exhaust is sampled continuously for iodine and particulates and noble gases. This data is used in calculations to assure that the effluents released have not exceeded station release limits. A typical radiation monitor setpoint may be calculated as follows:

$$C < 7.04E+2/f = 5.43E-03 \mu\text{Ci/ml}$$

where:

f = 129,700 cfm, The total combined ventilation and process gas exhaust flow.

A4.0 DOSE CALCULATIONS

A4.1 FREQUENCY OF CALCULATIONS

Dose contributions to the maximum exposed individual shall be calculated at least every 31 days, quarterly, and annually using the methodology in the generic information sections or the RETDAS computer program. One of these methods shall also be used for any special reports.

Station long-term historical and dose projection calculations are periodically performed to determine the station's status with respect to meeting annual ALARA goals specified in the Oconee Nuclear Station Selected Licensing Commitment Manual. Such calculations are used to verify that adequate margin remains during a report period to allow normal station and radwaste system operation, including anticipated operational occurrences, for the remainder of the report period without exceeding applicable goals. Station dose projections can be performed using generic methodology or the RETDAS computer code.

Fuel cycle dose calculations shall be performed annually or as required by special reports. Dose contributions shall be calculated using the methodology in the appropriate generic information sections or the RETDAS computer program.

A4.2 DOSE MODELS FOR MAXIMUM EXPOSED INDIVIDUAL

A4.2.1 Liquid Effluents

Generic methodology for calculating liquid pathway exposures to the maximum exposed individual is presented in Section 3.1.1. Oconee site specific parameters to be used in the generic methodology are presented as follows:

A_{aoi} = Tables A4.0-3 through A4.0-6

F_{η} = $f/(F + f)$ (0.0067 for projections)

where:

F_{η} = Near field dilution factor, dimensionless

f = Oconee average liquid radwaste flow, cfs (7.34 default for projections based on 1990-94 average radwaste flow)

F = Oconee average dilution flow for period of interest, cfs (1091 default for projections based on 1990-94 Keowee Hydro average flow)

A4.2.2 Gaseous Effluents

A4.2.2.1 Noble Gases

Gamma Air and Beta Air Dose

Generic methodology for calculating noble gas airborne pathway gamma air (D_γ) and beta air (D_β) doses is presented in Section 3.1.2.1. Oconee site specific parameters to be used in the generic methodology are presented as follows:

Semi-elevated Releases

$(\bar{X}/\bar{Q}) = 1.672\text{E-}6 \text{ sec/m}^3$. The highest calculated annual average relative concentration for any area at or beyond the unrestricted area boundary. The location is the SW sector @ 1.0 mile for semi-elevated releases.

Ground Level Releases

$(\bar{X}/\bar{Q}) = 7.308\text{E-}6 \text{ sec/m}^3$. The highest calculated annual average relative concentration for any area at or beyond the unrestricted area boundary. The location is the SE sector @ 1.0 mile for ground level releases.

A4.2.2.2 Radioiodines, Particulate, and Other Radionuclides with $T_{1/2} > 8$ Days

Generic methodology for calculating airborne pathway maximum organ (D_{mo}) exposures to the maximum exposed individual is presented in Section 3.1.2.2. The vegetable garden pathway is assumed to exist at all locations offsite for dose calculation purposes. External exposure from deposited ground contamination and inhalation exposure pathways, and internal exposure from food pathways, which include the meat and milk pathways, are analyzed only at locations where site surveys have verified that meat producing animals, or cow and goat milk producing animals exist, however. Therefore, the location of the maximum individual may vary depending on the mixture and levels of radionuclides released during a period of time. Additionally, the critical (or limiting) age group and organ will vary based on the location (i.e., combination of dose pathways contributing dose) and mixture/level of radionuclide releases during the release period.

Performing calculations separately for semi-elevated and ground level release types and for all potential maximum locations, age groups and organs assures that a maximum location is identified and that a conservative estimate is obtained for maximum offsite dose impact to any organ or age group. Oconee site specific meteorological dispersion (X/Q) and deposition (D/Q) parameters and applicable terrestrial/food pathways for the potential maximum locations to be analyzed using generic methodology are presented in Table A4.0-7.

An alternative method for estimating offsite dose involves performing calculations for all offsite locations and comparing the combined semi-elevated and ground level release dose totals for each location to determine the maximum organ exposure. Table A4.0-8 provides site survey data indicating the applicable food pathways to be considered for each offsite location.

As discussed in Section 3.3.5, more than one nuclear power station site may contribute to the doses to be considered in accordance with 40CFR190. The fuel cycle dose assessments for Oconee Nuclear Station only include liquid and gaseous dose contributions from Oconee Nuclear Station since no other uranium fuel cycle facility contributes significantly to Oconee's maximum exposed individual. For this dose assessment, the total body and maximum organ dose contributions to the maximum exposed individual from Oconee's liquid and gaseous releases are estimated using the following calculations:

$$D_{tb}(T) = D_{tb}(l) + D_{tb}(g_c) + D_{tb}(g_g)$$

$$D_{mo}(T) = D_{mo}(l) + D_{mo}(g_c) + D_{mo}(g_g)$$

where:

- $D_{tb}(T)$ = Total estimated fuel cycle total body dose commitment resulting from the combined liquid and gaseous effluents from Oconee during the calendar year of interest, in mrem.
- $D_{tb}(l)$ = Estimated fuel cycle total body dose contribution resulting from Oconee liquid effluents during the calendar year of interest, in mrem.
- $D_{tb}(g_c)$ = Estimated fuel cycle total body dose contribution resulting from Oconee gaseous effluents released from semi-elevated release points during the calendar year of interest, in mrem.
- $D_{tb}(g_g)$ = Estimated fuel cycle total body dose contribution resulting from Oconee gaseous effluents released from ground level release points during the calendar year of interest, in mrem.
- $D_{mo}(T)$ = Total estimated fuel cycle maximum organ dose commitment resulting from the combined liquid and gaseous effluents from Oconee during the calendar year of interest, in mrem.
- $D_{mo}(l)$ = Estimated fuel cycle maximum organ dose contribution resulting from Oconee liquid effluents during the calendar year of interest, in mrem.
- $D_{mo}(g_c)$ = Estimated fuel cycle maximum organ dose contribution resulting from Oconee gaseous effluents released from semi-elevated release points during the calendar year of interest, in mrem.
- $D_{mo}(g_g)$ = Estimated fuel cycle maximum organ dose contribution resulting from Oconee gaseous effluents released from ground level release points during the calendar year of interest, in mrem.

A4.3.1 LIQUID EFFLUENTS

Liquid pathway dose estimates are calculated using generic methodology or the RETDAS computer program. The values for $D_{tb}(l)$ and $D_{mo}(l)$ liquid pathway dose contributions are calculated based on the methodology, values and assumptions presented in Section A4.2.1.

A4.3.2 GASEOUS EFFLUENTS

Total Body

The methodology for calculating noble gas airborne pathway total body exposures to the maximum individual, $D_{tb}(g_e)$ and $D_{tb}(g_g)$, is derived from Section 3.1.2.1 generic methodology for gamma air and beta air dose calculations as follows:

$$D_{tb} = 3.17E-8 \sum_i K_i [(X/Q)Q_i] \text{ mrem/yr}$$

Generic methodology parameters K_i are described and provided in Section 1.2.1. Oconee site specific parameters for semi-elevated and ground level X/Q values are $1.672E-6$ and $7.308E-6$, respectively, as described in Section A4.2.2.1 for Oconee gamma air and beta air dose calculations.

Maximum Organ

Airborne pathway maximum organ dose estimates are calculated using generic methodology or the RETDAS computer program. The values for $D_{mo}(g_e)$ and $D_{mo}(g_g)$ airborne pathway dose contributions are calculated based on the methodology, presented in Section A4.2.2.2. The maximum organ dose is established by calculating doses to all organs for each potential maximum offsite location identified in Table A4.0-7. Calculations must be performed separately for semi-elevated and ground level gaseous release types and for all potential maximum locations, age groups and organs in order to assure that the maximum location, organ and age group is indeed analyzed and identified. A conservative estimate (i.e., overestimate) of the fuel cycle maximum organ dose is obtained by 1) performing liquid pathway calculations for each age group and organ, 2) performing gaseous pathway calculations for each age group and organ for all potential maximum exposure locations (see Table A4.0-7) 3) adding the exposure values for each airborne release type (i.e., semi-elevated and ground level) to the same organ dose resulting from liquid releases, 4) comparing total organ dose values for each potential limiting gaseous dose location and determining the maximum organ dose values for each age group, and airborne pathway components are added for all organs and determining maximum organ dose values calculated or each potential limiting gaseous dose location age group, and 5) comparing maximum total doses for each organ and age group and determining the maximum (or limiting) organ and age group. A worksheet is presented in Figure A4.0-1.

An alternative method for estimating fuel cycle maximum organ dose involves performing calculations for all offsite locations and comparing the combined liquid, semi-elevated and ground level release dose totals for each location to determine the maximum organ exposure. Table A4.0-8 provides site survey data indicating the applicable food pathways to be considered for each offsite location.

TABLE A4.0-1A
 OCONEE NUCLEAR STATION
 (1 OF 2)

DISPERSION PARAMETER ($\overline{X/Q}$) FOR SEMI-ELEVATED LONG TERM RELEASES > 500 HR/YR OR > 125 HR/QTR
 (SEC/M3)

SECTOR	DISTANCE TO THE CONTROL LOCATION, IN MILES									
	0-0.5	0.5-1.0	1.0-1.5	1.5-2.0	2.0-2.5	2.5-3.0	3.0-3.5	3.5-4.0	4.0-4.5	4.5-5.0
N			5.220E-07	2.650E-07	1.594E-07	1.069E-07	7.719E-08	7.321E-08	5.665E-08	4.542E-08
NNE			8.379E-07	4.734E-07	2.690E-07	2.003E-07	1.385E-07	1.091E-07	8.379E-08	6.676E-08
NE			9.503E-07	6.350E-07	3.962E-07	2.535E-07	1.847E-07	1.497E-07	1.157E-07	9.246E-08
ENE			8.116E-07	4.856E-07	2.919E-07	2.196E-07	1.619E-07	1.239E-07	9.609E-08	7.720E-08
E			5.950E-07	3.202E-07	2.015E-07	2.270E-07	1.745E-07	1.292E-07	1.024E-07	8.308E-08
ESE			4.531E-07	3.300E-07	3.623E-07	4.020E-07	2.822E-07	2.109E-07	1.688E-07	1.405E-07
SE			7.505E-07	4.573E-07	5.490E-07	5.110E-07	3.560E-07	2.648E-07	2.063E-07	1.665E-07
SSE			1.419E-06	7.428E-07	4.527E-07	3.489E-07	2.866E-07	2.131E-07	1.659E-07	1.337E-07
S			1.170E-06	6.099E-07	3.701E-07	2.496E-07	1.810E-07	1.552E-07	1.218E-07	9.867E-08
SSW			1.214E-06	6.327E-07	3.564E-07	2.301E-07	1.621E-07	1.213E-07	9.481E-08	7.660E-08
SW			1.672E-06	7.285E-07	4.057E-07	2.720E-07	1.891E-07	1.400E-07	1.085E-07	8.708E-08
WSW			1.558E-06	6.820E-07	3.804E-07	2.438E-07	1.708E-07	1.271E-07	1.010E-07	8.114E-08
W			1.193E-06	5.214E-07	2.909E-07	1.867E-07	1.372E-07	1.032E-07	8.326E-08	6.654E-08
WNW			4.658E-07	2.480E-07	1.760E-07	1.482E-07	1.024E-07	7.695E-08	5.943E-08	4.796E-08
NW			4.831E-07	2.524E-07	1.965E-07	1.291E-07	9.959E-08	7.356E-08	5.682E-08	4.566E-08
NNW			5.375E-07	2.769E-07	2.128E-07	1.394E-07	1.072E-07	7.913E-08	6.110E-08	4.907E-08

REVISION 35
 1/1/95

TABLE A4.0-1A
(2 OF 2)

OCONEE NUCLEAR STATION

The values presented in this table were generated by using the computer program XOQDOQ (NUREG/CR-2919) which implements NRC Regulatory Guide 1.111 (1977), and by using the following assumptions:

1. Data Collection Period, 1988 to 1992.
2. Semi-Elevated Releases.
3. Open Terrain Recirculation Correction Factors.
4. No Decay, Undepleted
5. Vent and Building Parameters:

Release Height (meters) = 60.70	Rep. Wind Height (meters) = 60.7
Diameter (meters) = 1.80	Building Height (meters) = 58.0
Exit Velocity (meters) = 11.10	Bldg. Min. X-Sec. Area (sq. m.) = 2296.0
	Heat Emission Rate (cal/s) = 0.0

6. At the Release Height:

<u>Vent Release Mode</u>	<u>Wind Speed (meters/sec)</u>
Elevated	Less Than 2.220
Mixed	Between 2.220 and 11.100
Ground Level	Above 11.100

7. At the Measured Wind Speed (10.0 meters):

<u>Vent Release Mode</u>	<u>Wind Speed (meters/sec)</u>	
	<u>Stable Conditions</u>	<u>Unstable/Neutral Conditions</u>
Elevated	Less Than 0.901	Less Than 1.414
Mixed	Between 0.901 and 4.505	Between 1.414 and 7.072
Ground Level	Above 4.505	Above 7.072

TABLE A4.0-1B
 OCONEE NUCLEAR STATION
 (1 OF 2)

DEPOSITION PARAMETER ($\overline{D/Q}$) FOR SEMI-ELEVATED LONG TERM RELEASES > 500 HR/YR OR > 125 HR/QTR
 (1/M2)

SECTOR	DISTANCE TO THE CONTROL LOCATION, IN MILES									
	0-0.5	0.5-1.0	1.0-1.5	1.5-2.0	2.0-2.5	2.5-3.0	3.0-3.5	3.5-4.0	4.0-4.5	4.5-5.0
N			2.890E-09	1.184E-09	6.225E-10	3.812E-10	2.586E-10	3.380E-10	2.510E-10	1.943E-10
NNE			9.113E-09	3.989E-09	2.013E-09	1.248E-09	8.235E-10	8.997E-10	6.667E-10	5.138E-10
NE			1.295E-08	5.666E-09	2.919E-09	1.729E-09	1.145E-09	1.224E-09	9.140E-10	7.067E-10
ENE			7.899E-09	3.385E-09	1.756E-09	1.095E-09	9.819E-10	7.671E-10	5.749E-10	4.466E-10
E			4.454E-09	1.775E-09	9.252E-10	7.164E-10	7.491E-10	5.267E-10	3.981E-10	3.125E-10
ESE			4.361E-09	1.838E-09	1.086E-09	1.322E-09	8.696E-10	6.161E-10	5.153E-10	4.139E-10
SE			3.397E-09	1.385E-09	8.341E-10	1.649E-09	1.080E-09	7.595E-10	5.629E-10	4.340E-10
SSE			3.333E-09	1.323E-09	6.920E-10	4.404E-10	7.307E-10	5.202E-10	3.922E-10	3.091E-10
S			3.192E-09	1.256E-09	6.530E-10	4.020E-10	2.788E-10	2.177E-10	1.759E-10	1.501E-10
SSW			5.190E-09	1.972E-09	9.849E-10	5.895E-10	3.928E-10	2.842E-10	2.192E-10	1.778E-10
SW			1.205E-08	4.399E-09	2.193E-09	1.299E-09	8.521E-10	6.028E-10	4.518E-10	3.546E-10
WSW			1.047E-08	3.824E-09	1.908E-09	1.127E-09	7.422E-10	5.277E-10	3.980E-10	3.145E-10
W			5.577E-09	2.044E-09	1.025E-09	6.094E-10	4.134E-10	3.405E-10	3.962E-10	3.052E-10
WNW			2.185E-09	9.042E-10	5.220E-10	6.464E-10	4.227E-10	3.188E-10	2.360E-10	1.868E-10
NW			2.097E-09	8.759E-10	5.225E-10	3.196E-10	4.521E-10	3.178E-10	2.353E-10	1.812E-10
NNW			2.461E-09	1.028E-09	6.219E-10	3.765E-10	5.128E-10	3.604E-10	2.667E-10	2.054E-10

REVISION 35
 1/1/95

TABLE A4.0-1B
(2 OF 2)

OCONEE NUCLEAR STATION

The values presented in this table were generated by using the computer program XOQDOQ (NUREG/CR-2919) which implements NRC Regulatory Guide 1.111 (1977), and by using the following assumptions:

1. Data Collection Period, 1988 to 1992.
2. Semi-Elevated Releases.
3. Open Terrain Recirculation Correction Factors.
4. No Decay, Undepleted
5. Vent and Building Parameters:

Release Height (meters) = 60.70	Rep. Wind Height (meters) = 60.7
Diameter (meters) = 1.80	Building Height (meters) = 58.0
Exit Velocity (meters) = 11.10	Bldg. Min. X-Sec. Area (sq. m.) = 2296.0
	Heat Emission Rate (cal/s) = 0.0

6. At the Release Height:

<u>Vent Release Mode</u>	<u>Wind Speed (meters/sec)</u>
Elevated	Less Than 2.220
Mixed	Between 2.220 and 11.100
Ground Level	Above 11.100

7. At the Measured Wind Speed (10.0 meters):

<u>Vent Release Mode</u>	<u>Wind Speed (meters/sec)</u>	
	<u>Stable Conditions</u>	<u>Unstable/Neutral Conditions</u>
Elevated	Less Than 0.901	Less Than 1.414
Mixed	Between 0.901 and 4.505	Between 1.414 and 7.072
Ground Level	Above 4.505	Above 7.072

TABLE A4.0-2A
 OCONEE NUCLEAR STATION
 (1 OF 2)

DISPERSION PARAMETER ($\overline{X/Q}$) FOR GROUND LEVEL, LONG TERM RELEASES > 500 HR/YR OR > 125 HR/QTR
 (SEC/M3)

SECTOR	DISTANCE TO THE CONTROL LOCATION, IN MILES									
	0-0.5	0.5-1.0	1.0-1.5	1.5-2.0	2.0-2.5	2.5-3.0	3.0-3.5	3.5-4.0	4.0-4.5	4.5-5.0
N			2.115E-06	8.389E-07	4.495E-07	2.822E-07	1.952E-07	1.443E-07	1.117E-07	8.961E-08
NNE			2.898E-06	1.137E-06	6.047E-07	3.775E-07	2.602E-07	1.916E-07	1.480E-07	1.184E-07
NE			3.886E-06	1.529E-06	8.158E-07	5.108E-07	3.529E-07	2.604E-07	2.015E-07	1.616E-07
ENE			3.226E-06	1.277E-06	6.848E-07	4.305E-07	2.983E-07	2.207E-07	1.711E-07	1.374E-07
E			3.522E-06	1.410E-06	7.658E-07	4.866E-07	3.400E-07	2.534E-07	1.977E-07	1.596E-07
ESE			5.964E-06	2.407E-06	1.321E-06	8.459E-07	5.950E-07	4.457E-07	3.493E-07	2.832E-07
SE			7.308E-06	2.972E-06	1.631E-06	1.044E-06	7.342E-07	5.497E-07	4.307E-07	3.490E-07
SSE			6.604E-06	2.657E-06	1.440E-06	9.117E-07	6.354E-07	4.723E-07	3.676E-07	2.962E-07
S			5.278E-06	2.121E-06	1.146E-06	7.237E-07	5.032E-07	3.734E-07	2.901E-07	2.335E-07
SSW			3.986E-06	1.589E-06	8.536E-07	5.370E-07	3.721E-07	2.753E-07	2.135E-07	1.714E-07
SW			4.108E-06	1.620E-06	8.628E-07	5.390E-07	3.715E-07	2.735E-07	2.112E-07	1.689E-07
WSW			3.804E-06	1.503E-06	8.018E-07	5.015E-07	3.460E-07	2.549E-07	1.970E-07	1.577E-07
W			2.978E-06	1.186E-06	6.361E-07	3.995E-07	2.765E-07	2.043E-07	1.583E-07	1.270E-07
WNW			2.201E-06	8.791E-07	4.726E-07	2.974E-07	2.062E-07	1.526E-07	1.183E-07	9.502E-08
NW			2.104E-06	8.385E-07	4.499E-07	2.826E-07	1.957E-07	1.447E-07	1.121E-07	8.991E-08
NNW			2.221E-06	8.860E-07	4.755E-07	2.988E-07	2.069E-07	1.529E-07	1.185E-07	9.508E-08

REVISION 38
 1/1/98

TABLE A4.0-2A
(2 OF 2)

OCONEE NUCLEAR STATION

The values presented in this table were generated by using the computer program XOQDOQ (NUREG/CR-2919) which implements NRC Regulatory Guide 1.111 (1977), and by using the following assumptions:

1. Data Collection Period, 1988 to 1992.
2. Ground Level Releases.
3. Open Terrain Recirculation Correction Factors.
4. No Decay, Undepleted
5. Vent and Building Parameters:

Release Height (meters)	=	10.00	Rep. Wind Height (meters)	=	10.0
Diameter (meters)	=	0.00	Building Height (meters)	=	58.0
Exit Velocity (meters)	=	0.00	Bldg. Min. X-Sec. Area (sq. m.)	=	2296.0
			Heat Emission Rate (cal/s)	=	0.0

TABLE A4.0-2B
 OCONEE NUCLEAR STATION
 (1 OF 2)

DEPOSITION PARAMETER ($\overline{D/Q}$) FOR GROUND LEVEL, LONG TERM RELEASES > 500 HR/YR OR > 125 HR/QTR
 (1/M2)

SECTOR	DISTANCE TO THE CONTROL LOCATION, IN MILES									
	0-0.5	0.5-1.0	1.0-1.5	1.5-2.0	2.0-2.5	2.5-3.0	3.0-3.5	3.5-4.0	4.0-4.5	4.5-5.0
N			6.916E-09	2.484E-09	1.232E-09	7.255E-10	4.750E-10	3.342E-10	2.477E-10	1.909E-10
NNE			1.642E-08	5.897E-09	2.924E-09	1.722E-09	1.128E-09	7.934E-10	5.880E-10	4.531E-10
NE			2.259E-08	8.114E-09	4.024E-09	2.369E-09	1.551E-09	1.092E-09	8.090E-10	6.235E-10
ENE			1.428E-08	5.130E-09	2.544E-09	1.498E-09	9.810E-10	6.902E-10	5.115E-10	3.942E-10
E			9.899E-09	3.556E-09	1.763E-09	1.038E-09	6.798E-10	4.784E-10	3.545E-10	2.732E-10
ESE			1.336E-08	4.798E-09	2.379E-09	1.401E-09	9.174E-10	6.455E-10	4.784E-10	3.686E-10
SE			1.401E-08	5.034E-09	2.496E-09	1.470E-09	9.625E-10	6.772E-10	5.019E-10	3.868E-10
SSE			1.226E-08	4.404E-09	2.184E-09	1.286E-09	8.420E-10	5.925E-10	4.391E-10	3.384E-10
S			1.008E-08	3.620E-09	1.795E-09	1.057E-09	6.922E-10	4.871E-10	3.610E-10	2.782E-10
SSW			9.941E-09	3.571E-09	1.771E-09	1.043E-09	6.828E-10	4.804E-10	3.560E-10	2.744E-10
SW			1.717E-08	6.169E-09	3.059E-09	1.801E-09	1.180E-09	8.300E-10	6.151E-10	4.740E-10
WSW			1.574E-08	5.655E-09	2.804E-09	1.651E-09	1.081E-09	7.608E-10	5.638E-10	4.345E-10
W			9.988E-09	3.588E-09	1.779E-09	1.048E-09	6.860E-10	4.827E-10	3.577E-10	2.757E-10
WNW			5.953E-09	2.138E-09	1.060E-09	6.244E-10	4.088E-10	2.877E-10	2.132E-10	1.643E-10
NW			5.891E-09	2.116E-09	1.049E-09	6.179E-10	4.046E-10	2.847E-10	2.110E-10	1.626E-10
NNW			6.672E-09	2.397E-09	1.188E-09	6.998E-10	4.582E-10	3.224E-10	2.390E-10	1.841E-10

REVISION 35
 1/1/95

TABLE A4.0-2B
(2 OF 2)

OCONEE NUCLEAR STATION

The values presented in this table were generated by using the computer program XOQDOQ (NUREG/CR-2919) which implements NRC Regulatory Guide 1.111 (1977), and by using the following assumptions:

1. Data Collection Period, 1988 to 1992.
2. Ground Level Releases.
3. Open Terrain Recirculation Correction Factors.
4. No Decay, Undepleted
5. Vent and Building Parameters:

Release Height (meters) = 10.00	Rep. Wind Height (meters) = 10.0
Diameter (meters) = 0.00	Building Height (meters) = 58.0
Exit Velocity (meters) = 0.00	Bldg. Min. X-Sec. Area (sq. m.) = 2296.0
	Heat Emission Rate (cal/s) = 0.0

TABLE A4.0-3
(1 OF 2)

OCONEE NUCLEAR STATION
LIQUID EFFLUENT DOSE - ADULT PARAMETERS
A(I) MREM/HR PER UCI/ML

RADIONUCLIDE		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
1	H 3	0.0	2.27E-01	2.27E-01	2.27E-01	2.27E-01	2.27E-01	2.27E-01
11	NA 24	1.35E+02	1.35E+02	1.35E+02	1.35E+02	1.35E+02	1.35E+02	1.35E+02
24	CR 51	0.0	0.0	1.24E+00	7.42E-01	2.74E-01	1.65E+00	3.12E+02
25	MN 54	0.0	4.37E+03	8.33E+02	0.0	1.30E+03	0.0	1.34E+04
25	MN 56	0.0	1.69E-01	3.00E-02	0.0	2.14E-01	0.0	5.39E+00
26	FE 55	6.58E+02	4.55E+02	1.06E+02	0.0	0.0	2.54E+02	2.61E+02
26	FE 59	1.02E+03	2.40E+03	9.22E+02	0.0	0.0	6.72E+02	8.01E+03
27	CO 58	0.0	8.83E+01	1.98E+02	0.0	0.0	0.0	1.79E+03
27	CO 60	0.0	2.56E+02	5.65E+02	0.0	0.0	0.0	4.81E+03
28	NI 63	3.11E+04	2.16E+03	1.04E+03	0.0	0.0	0.0	4.50E+02
28	NI 65	1.72E-01	2.23E-02	1.02E-02	0.0	0.0	0.0	5.67E-01
29	CU 64	0.0	2.68E+00	1.26E+00	0.0	6.76E+00	0.0	2.29E+02
30	ZN 65	2.31E+04	7.35E+04	3.32E+04	0.0	4.92E+04	0.0	4.63E+04
30	ZN 69	1.20E-06	2.30E-06	1.60E-07	0.0	1.50E-06	0.0	3.46E-07
35	BR 83	0.0	0.0	3.86E-02	0.0	0.0	0.0	5.55E-02
35	BR 85	0.0	0.0	0.0	0.0	0.0	0.0	0.0
37	RB 86	0.0	9.74E+04	4.54E+04	0.0	0.0	0.0	1.92E+04
37	RB 88	0.0	3.66E-16	1.94E-16	0.0	0.0	0.0	5.06E-27
37	RB 89	0.0	2.09E-18	1.47E-18	0.0	0.0	0.0	1.22E-31
38	SR 89	2.18E+04	0.0	6.26E+02	0.0	0.0	0.0	3.50E+03
38	SR 90	2.76E+05	0.0	7.40E+04	0.0	0.0	0.0	1.57E+04
38	SR 91	7.05E+01	0.0	2.85E+00	0.0	0.0	0.0	3.36E+02
38	SR 92	3.35E-01	0.0	1.45E-02	0.0	0.0	0.0	6.65E+00
39	Y 90	4.44E-01	0.0	1.19E-02	0.0	0.0	0.0	4.71E+03
39	Y 91M	4.20E-11	0.0	1.63E-12	0.0	0.0	0.0	1.23E-10
39	Y 91	8.34E+00	0.0	2.23E-01	0.0	0.0	0.0	4.59E+03
39	Y 92	4.69E-04	0.0	1.37E-05	0.0	0.0	0.0	8.21E+00
39	Y 93	3.08E-02	0.0	8.51E-04	0.0	0.0	0.0	9.77E+02
40	ZR 95	2.38E-01	7.63E-02	5.16E-02	0.0	1.20E-01	0.0	2.42E+02
40	ZR 97	4.97E-03	1.00E-03	4.58E-04	0.0	1.51E-03	0.0	3.10E+02
41	NB 95	4.38E+02	2.44E+02	1.31E+02	0.0	2.41E+02	0.0	1.48E+06
42	MO 99	0.0	8.02E+01	1.53E+01	0.0	1.82E+02	0.0	1.86E+02
43	TC 99M	5.59E-04	1.58E-03	2.01E-02	0.0	2.40E-02	7.74E-04	9.35E-01
43	TC 101	1.13E-21	1.63E-21	1.60E-20	0.0	2.93E-20	8.32E-22	4.89E-33
44	RU 103	4.35E+00	0.0	1.88E+00	0.0	1.66E+01	0.0	5.08E+02
44	RU 105	8.69E-03	0.0	3.43E-03	0.0	1.12E-01	0.0	5.32E+00
44	RU 106	6.57E+01	0.0	8.32E+00	0.0	1.27E+02	0.0	4.25E+03
47	AG 110M	8.80E-01	8.14E-01	4.83E-01	0.0	1.60E+00	0.0	3.32E+02
52	TE 125M	2.54E+03	9.19E+02	3.40E+02	7.63E+02	1.03E+04	0.0	1.01E+04
52	TE 127M	6.44E+03	2.30E+03	7.85E+02	1.65E+03	2.62E+04	0.0	2.16E+04
52	TE 127	1.78E+01	6.38E+00	3.84E+00	1.32E+01	7.24E+01	0.0	1.40E+03
52	TE 129M	1.08E+04	4.02E+03	1.71E+03	3.71E+03	4.50E+04	0.0	5.43E+04
52	TE 129	1.80E-05	6.75E-06	4.37E-06	1.38E-05	7.55E-05	0.0	1.36E-05
52	TE 131M	9.51E+02	4.65E+02	3.88E+02	7.37E+02	4.71E+03	0.0	4.62E+04
52	TE 131	3.68E-13	1.54E-13	1.16E-13	3.03E-13	1.61E-12	0.0	5.21E-14
52	TE 132	1.95E+03	1.26E+03	1.18E+03	1.39E+03	1.22E+04	0.0	5.97E+04
53	I 130	7.06E+00	2.08E+01	8.21E+00	1.76E+03	3.25E+01	0.0	1.79E+01
53	I 131	1.37E+02	1.96E+02	1.12E+02	6.43E+04	3.36E+02	0.0	5.17E+01
53	I 132	5.32E-03	1.42E-02	4.98E-03	4.98E-01	2.27E-02	0.0	2.67E-03
53	I 133	2.29E+01	3.99E+01	1.22E+01	5.86E+03	6.96E+01	0.0	3.59E+01
53	I 135	1.28E+00	3.34E+00	1.23E+00	2.21E+02	5.36E+00	0.0	3.78E+00
55	CS 134	1.49E+06	3.54E+06	2.89E+06	0.0	1.15E+06	3.80E+05	6.19E+04
55	CS 136	1.48E+05	5.84E+05	4.20E+05	0.0	3.25E+05	4.45E+04	6.63E+04
55	CS 137	1.91E+06	2.61E+06	1.71E+06	0.0	8.86E+05	2.94E+05	5.05E+04
55	CS 138	1.37E-10	2.70E-10	1.34E-10	0.0	1.99E-10	1.96E-11	1.15E-15
56	BA 139	7.09E-06	5.05E-09	2.08E-07	0.0	4.72E-09	2.87E-09	1.26E-05
56	BA 140	1.84E+02	2.32E-01	1.21E+01	0.0	7.87E-02	1.33E-01	3.80E+02
56	BA 141	5.44E-16	4.12E-19	1.84E-17	0.0	3.83E-19	2.34E-19	2.57E-25
56	BA 142	9.69E-25	9.96E-28	6.09E-26	0.0	8.41E-28	5.64E-28	1.36E-42
57	LA 140	9.90E-02	4.99E-02	1.32E-02	0.0	0.0	0.0	3.66E+03
57	LA 142	1.61E-07	7.32E-08	1.82E-08	0.0	0.0	0.0	5.35E-04
58	CE 141	2.20E-02	1.49E-02	1.69E-03	0.0	6.91E-03	0.0	5.69E+01
58	CE 143	2.40E-03	1.78E+00	1.97E-04	0.0	7.82E-04	0.0	6.64E+01
58	CE 144	1.17E+00	4.89E-01	6.28E-02	0.0	2.90E-01	0.0	3.95E+02
59	PR 143	5.23E-01	2.10E-01	2.59E-02	0.0	1.21E-01	0.0	2.29E+03
59	PR 144	7.04E-20	2.92E-20	3.58E-21	0.0	1.65E-20	0.0	1.01E-26
60	ND 147	3.54E-01	4.09E-01	2.45E-02	0.0	2.39E-01	0.0	1.96E+03
74	H 187	1.48E+02	1.23E+02	4.31E+01	0.0	0.0	0.0	4.04E+04
93	NP 239	2.12E-02	2.09E-03	1.15E-03	0.0	6.52E-03	0.0	4.28E+02

Table A4.0-3
(2 of 2)

Oconee Nuclear Station
Liquid Effluent Dose - Adult Parameters
 A_{aoi} mrem/hr per $\mu\text{Ci/ml}$

From Generic Section 3.1.1:

A_{aoi} = the site related ingestion dose commitment factor for an individual of age group, "a", to organ, "o", for each identified principal gamma and beta emitter, "i", in mrem/hr per $\mu\text{Ci/ml}$

$$A_{aoi} = 1.14E+05 (U_{aw}\sigma_w/D_w \exp(-\lambda_i t_w) + U_{af}\sigma_f BF_i \exp(-\lambda_i t_f)) DF_{aoi}$$

where:

$$1.14E+05 = 10^6 \text{ pCi}/\mu\text{Ci} \times 10^3 \text{ ml/kg} \div 8760 \text{ hr/yr}$$

U_{aw} = Water consumption by age group, l/yr

infant	330
child	510
teen	510
adult	730

σ_w, σ_f = Recirculation factors at equilibrium for the water and fish pathways respectively; these factors account for the fraction of discharged water reused by the station

$\sigma_w = 1.00$ $\sigma_f = 1.00$

D_w = Dilution factor from the near field area to the potable water intake = 10000 (essentially no drinking water pathway)

U_{af} = Fish consumption by age group, kg/yr

infant	---
child	6.9
teen	16
adult	21

BF_i = Bioaccumulation factor for radionuclide, "i", in fish, pCi/kg per pCi/l, from Table 3.1-1

DF_{aoi} = Dose conversion factor for age group, "a", in organ, "o", for radionuclide, "i", in mrem/pCi, from Tables 3.1-2, 3.1-3, 3.1-4, and 3.1-5, respectively

λ_i = radiological decay constant for isotope, i, in 1/hr

t_w, t_f = transport time for the drinking water and fish pathways, hr

$t_w = 12$ hours $t_f = 24$ hours

Sample Calculation for Adult, I-131, Thyroid:

$$A(a, \text{thy}, \text{I-131}) = 1.14E5 (730 \cdot 1.0 / 1.0E4 \cdot \exp(-3.59E-3 \cdot 12) + 21 \cdot 1.0 \cdot 15 \cdot \exp(-3.59E-3 \cdot 24)) \cdot 1.95E-3 = 6.43E4 \text{ mr/hr per } \mu\text{Ci/ml}$$

TABLE A4.0-4
(1 OF 2)

O'CONNOR NUCLEAR STATION
LIQUID EFFLUENT DOSE - TEEN PARAMETERS
A(I) MREM/HR PER UCI/ML

RADIONUCLIDE		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
1 H	3	0.0	1.75E-01	1.75E-01	1.75E-01	1.75E-01	1.75E-01	1.75E-01
11 NA	24	1.39E+02	1.39E+02	1.39E+02	1.39E+02	1.39E+02	1.39E+02	1.39E+02
24 CR	51	0.0	0.0	1.28E+00	7.12E-01	2.81E-01	1.83E+00	2.15E+02
25 MN	54	0.0	4.30E+03	8.52E+02	0.0	1.28E+03	0.0	8.81E+03
25 MN	56	0.0	1.77E-01	3.15E-02	0.0	2.24E-01	0.0	1.16E+01
26 FE	55	6.89E+02	4.89E+02	1.14E+02	0.0	0.0	3.10E+02	2.11E+02
26 FE	59	1.05E+03	2.46E+03	9.50E+02	0.0	0.0	7.76E+02	5.82E+03
27 CO	58	0.0	8.78E+01	2.02E+02	0.0	0.0	0.0	1.21E+03
27 CO	60	0.0	2.56E+02	5.77E+02	0.0	0.0	0.0	3.34E+03
28 NI	63	3.23E+04	2.28E+03	1.09E+03	0.0	0.0	0.0	3.63E+02
28 NI	65	1.86E-01	2.37E-02	1.08E-02	0.0	0.0	0.0	1.29E+00
29 CU	64	0.0	2.82E+00	1.33E+00	0.0	7.14E+00	0.0	2.19E+02
30 ZN	65	2.10E+04	7.28E+04	3.39E+04	0.0	4.66E+04	0.0	3.08E+04
30 ZN	69	1.31E-06	2.49E-06	1.74E-07	0.0	1.63E-06	0.0	4.59E-06
35 BR	83	0.0	0.0	4.19E-02	0.0	0.0	0.0	0.0
35 BR	85	0.0	0.0	0.0	0.0	0.0	0.0	0.0
37 RB	86	0.0	1.05E+05	4.92E+04	0.0	0.0	0.0	0.0
37 RB	88	0.0	3.60E-16	1.92E-16	0.0	0.0	0.0	1.55E+04
37 RB	89	0.0	2.01E-18	1.42E-18	0.0	0.0	0.0	3.08E-23
38 SR	89	2.38E+04	0.0	6.80E+02	0.0	0.0	0.0	3.07E-27
38 SR	90	2.45E+05	0.0	6.57E+04	0.0	0.0	0.0	2.83E+03
38 SR	91	7.65E+01	0.0	3.04E+00	0.0	0.0	0.0	1.28E+04
38 SR	92	3.62E-01	0.0	1.55E-02	0.0	0.0	0.0	3.47E+02
39 Y	90	4.82E-01	0.0	1.30E-02	0.0	0.0	0.0	9.23E+00
39 Y	91M	4.25E-11	0.0	1.63E-12	0.0	0.0	0.0	3.98E+03
39 Y	91	9.06E+00	0.0	2.43E-01	0.0	0.0	0.0	2.01E-09
39 Y	92	5.11E-04	0.0	1.48E-05	0.0	0.0	0.0	3.71E+03
39 Y	93	3.35E-02	0.0	9.20E-04	0.0	0.0	0.0	1.40E+01
40 ZR	95	2.46E-01	7.75E-02	5.33E-02	0.0	1.14E-01	0.0	1.02E+03
40 ZR	97	5.34E-03	1.06E-03	4.86E-04	0.0	1.60E-03	0.0	1.79E+02
41 NB	95	4.41E+02	2.45E+02	1.35E+02	0.0	2.37E+02	0.0	2.86E+02
42 MO	99	0.0	8.55E+01	1.63E+01	0.0	1.96E+02	0.0	1.05E+06
43 TC	99M	5.73E-04	1.60E-03	2.07E-02	0.0	2.38E-02	8.87E-04	1.53E+02
43 TC	101	1.12E-21	1.59E-21	1.56E-20	0.0	2.88E-20	9.70E-22	1.05E+00
44 RU	103	4.57E+00	0.0	1.95E+00	0.0	1.61E+01	0.0	2.72E-28
44 RU	105	9.37E-03	0.0	3.64E-03	0.0	1.18E-01	0.0	3.82E+02
44 RU	106	7.14E+01	0.0	9.00E+00	0.0	1.38E+02	0.0	7.57E+00
47 AG	110M	8.59E-01	8.13E-01	4.94E-01	0.0	1.55E+00	0.0	3.42E+03
52 TE	125M	2.76E+03	9.95E+02	3.69E+02	7.71E+02	0.0	0.0	2.28E+02
52 TE	127M	7.01E+03	2.49E+03	8.34E+02	1.67E+03	2.84E+04	0.0	2.28E+02
52 TE	127	1.94E+01	6.89E+00	4.18E+00	1.34E+01	7.88E+01	0.0	8.15E+03
52 TE	129M	1.16E+04	4.32E+03	1.84E+03	3.76E+03	4.87E+04	0.0	1.75E+04
52 TE	129	1.95E-05	7.27E-06	4.74E-06	1.39E-05	8.18E-05	0.0	1.50E+03
52 TE	131M	1.02E+03	4.90E+02	4.09E+02	7.37E+02	5.11E+03	0.0	4.37E+04
52 TE	131	3.64E-13	1.50E-13	1.14E-13	2.81E-13	1.59E-12	0.0	1.07E-04
52 TE	132	2.06E+03	1.30E+03	1.23E+03	1.37E+03	1.25E+04	0.0	3.93E+04
53 I	130	7.32E+00	2.12E+01	8.46E+00	1.73E+03	3.26E+01	0.0	2.99E-14
53 I	131	1.47E+02	2.06E+02	1.10E+02	6.00E+04	3.54E+02	0.0	4.13E+04
53 I	132	5.56E-03	1.46E-02	5.23E-03	4.91E-01	2.29E-02	0.0	1.63E+01
53 I	133	2.47E+01	4.20E+01	1.28E+01	5.86E+03	7.36E+01	0.0	4.07E+01
53 I	135	1.34E+00	3.45E+00	1.28E+00	2.22E+02	5.45E+00	0.0	6.34E-03
55 CS	134	1.53E+06	3.59E+06	1.67E+06	0.0	1.14E+06	4.36E+05	3.18E+01
55 CS	136	1.49E+05	5.85E+05	3.93E+05	0.0	3.18E+05	5.02E+04	3.82E+00
55 CS	137	2.04E+06	2.72E+06	9.47E+05	0.0	9.25E+05	3.59E+05	4.46E+04
55 CS	138	1.39E-10	2.67E-10	1.33E-10	0.0	1.97E-10	2.29E-11	4.71E+04
56 BA	139	7.57E-06	5.33E-09	2.21E-07	0.0	5.02E-09	3.67E-09	3.87E+04
56 BA	140	1.96E+02	2.41E-01	1.27E+01	0.0	8.16E-02	1.62E-01	1.21E-13
56 BA	141	5.42E-16	4.05E-19	1.81E-17	0.0	3.76E-19	2.77E-19	6.75E-05
56 BA	142	9.50E-25	9.50E-28	5.85E-26	0.0	8.04E-28	6.32E-28	3.03E+02
57 LA	140	1.05E-01	5.16E-02	1.37E-02	0.0	0.0	0.0	1.15E-21
57 LA	142	1.71E-07	7.60E-08	1.89E-08	0.0	0.0	0.0	2.92E-36
58 CE	141	2.38E-02	1.59E-02	1.83E-03	0.0	7.49E-03	0.0	2.96E+03
58 CE	143	2.61E-03	1.90E+00	2.12E-04	0.0	8.50E-04	0.0	2.31E-03
58 CE	144	1.27E+00	5.26E-01	6.83E-02	0.0	3.14E-01	0.0	4.55E+01
59 PR	143	5.68E-01	2.27E-01	2.83E-02	0.0	1.32E-01	0.0	5.70E+01
59 PR	144	7.02E-20	2.87E-20	3.56E-21	0.0	1.65E-20	0.0	3.19E+02
60 ND	147	4.02E-01	4.37E-01	2.62E-02	0.0	2.57E-01	0.0	1.87E+03
74 M	187	1.59E+02	1.30E+02	4.55E+01	0.0	0.0	0.0	7.74E-23
93 NP	239	2.39E-02	2.26E-03	1.25E-03	0.0	7.09E-03	0.0	1.58E+03
								3.52E+04
								3.63E+02

Table A4.0-4
(2 of 2)

Oconee Nuclear Station
Liquid Effluent Dose - Teen Parameters
A_{aoi} mrem/hr per μCi/ml

From Generic Section 3.1.1:

A_{aoi} = the site related ingestion dose commitment factor for an individual of age group, "a", to organ, "o", for each identified principal gamma and beta emitter, "i", in mrem/hr per μCi/ml

$$A_{aoi} = 1.14E+05 (U_{aw}\sigma_w/D_w \exp(-\lambda_i t_w) + U_{af}\sigma_f B F_i \exp(-\lambda_i t_f)) D F_{aoi}$$

where:

$$1.14E+05 = 10^6 \text{ pCi}/\mu\text{Ci} \times 10^3 \text{ ml}/\text{kg} \div 8760 \text{ hr}/\text{yr}$$

U_{aw} = Water consumption by age group, l/yr

infant	330
child	510
teen	510
adult	730

σ_w, σ_f = Recirculation factors at equilibrium for the water and fish pathways respectively; these factors account for the fraction of discharged water reused by the station
σ_w = 1.00 σ_f = 1.00

D_w = Dilution factor from the near field area to the potable water intake = 10000 (essentially no drinking water pathway)

U_{af} = Fish consumption by age group, kg/yr

infant	---
child	6.9
teen	16
adult	21

B_{f_i} = Bioaccumulation factor for radionuclide, "i", in fish, pCi/kg per pCi/l, from Table 3.1-1

D_{F_{aoi}} = Dose conversion factor for age group, "a", in organ, "o", for radionuclide, "i", in mrem/pCi, from Tables 3.1-2, 3.1-3, 3.1-4, and 3.1-5, respectively

λ_i = radiological decay constant for isotope, i, in 1/hr

t_w, t_f = transport time for the drinking water and fish pathways, hr
t_w = 12 hours t_f = 24 hours

Sample Calculation for Teen, I-131, Thyroid:

$$A(t, \text{thy}, \text{I-131}) = 1.14E5 (510 \cdot 1.0 / 1.0E4 \cdot \exp(-3.59E-3 \cdot 12) + 16 \cdot 1.0 \cdot 15 \cdot \exp(-3.59E-3 \cdot 24)) \cdot 2.39E-3 = 6.00E4 \text{ mr/hr per } \mu\text{Ci/ml}$$

TABLE A4.0-5
(1 OF 2)

OCONEE NUCLEAR STATION
LIQUID EFFLUENT DOSE - CHILD PARAMETERS
A(I) MREM/HR PER UCI/ML

RADIOISOTOPE		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
1	H 3	0.0	1.45E-01	1.45E-01	1.45E-01	1.45E-01	1.45E-01	1.45E-01
11	NA 24	1.51E+02	1.51E+02	1.51E+02	1.51E+02	1.51E+02	1.51E+02	1.51E+02
24	CR 51	0.0	0.0	1.37E+00	7.58E-01	2.07E-01	1.38E+00	7.24E+01
25	MN 54	0.0	3.36E+03	8.95E+02	0.0	9.42E+02	0.0	2.82E+03
25	MN 56	0.0	1.61E-01	3.64E-02	0.0	1.95E-01	0.0	2.34E+01
26	FE 55	9.04E+02	4.80E+02	1.49E+02	0.0	0.0	2.71E+02	8.88E+01
26	FE 59	1.28E+03	2.07E+03	1.03E+03	0.0	0.0	5.99E+02	2.15E+03
27	CO 58	0.0	7.01E+01	2.15E+02	0.0	0.0	0.0	4.09E+02
27	CO 60	0.0	2.08E+02	6.13E+02	0.0	0.0	0.0	1.15E+03
28	NI 63	4.23E+04	2.27E+03	1.44E+03	0.0	0.0	0.0	1.53E+02
28	NI 65	2.38E-01	2.24E-02	1.31E-02	0.0	0.0	0.0	2.74E+00
29	CU 64	0.0	2.59E+00	1.57E+00	0.0	6.26E+00	0.0	1.22E+02
30	ZN 65	2.15E+04	5.73E+04	3.56E+04	0.0	3.61E+04	0.0	1.01E+04
30	ZN 69	1.70E-06	2.46E-06	2.27E-07	0.0	1.49E-06	0.0	1.55E-04
35	BR 83	0.0	0.0	5.39E-02	0.0	0.0	0.0	0.0
35	BR 85	0.0	0.0	0.0	0.0	0.0	0.0	0.0
37	RB 86	0.0	1.02E+05	6.25E+04	0.0	0.0	0.0	6.53E+03
37	RB 88	0.0	8.03E-16	5.58E-16	0.0	0.0	0.0	3.94E-17
37	RB 89	0.0	4.27E-18	3.79E-18	0.0	0.0	0.0	3.72E-20
38	SR 89	3.07E+04	0.0	8.78E+02	0.0	0.0	0.0	1.19E+03
38	SR 90	2.67E+05	0.0	7.15E+04	0.0	0.0	0.0	5.40E+03
38	SR 91	9.81E+01	0.0	3.70E+00	0.0	0.0	0.0	2.17E+02
38	SR 92	4.64E-01	0.0	1.86E-02	0.0	0.0	0.0	8.79E+00
39	Y 90	6.24E-01	0.0	1.67E-02	0.0	0.0	0.0	1.78E+03
39	Y 91M	1.08E-10	0.0	3.93E-12	0.0	0.0	0.0	2.11E-07
39	Y 91	1.17E+01	0.0	3.13E-01	0.0	0.0	0.0	1.56E+03
39	Y 92	6.57E-04	0.0	1.88E-05	0.0	0.0	0.0	1.90E+01
39	Y 93	4.31E-02	0.0	1.18E-03	0.0	0.0	0.0	6.42E+02
40	ZR 95	2.99E-01	6.56E-02	5.84E-02	0.0	9.39E-02	0.0	6.85E+01
40	ZR 97	6.80E-03	9.83E-04	5.80E-04	0.0	1.41E-03	0.0	1.49E+02
41	NB 95	5.21E+02	2.03E+02	1.45E+02	0.0	1.90E+02	0.0	3.75E+05
42	MO 99	0.0	8.14E+01	2.01E+01	0.0	1.74E+02	0.0	6.73E+01
43	TC 99M	6.87E-04	1.35E-03	2.23E-02	0.0	1.96E-02	6.84E-04	7.67E-01
43	TC 101	3.33E-21	3.48E-21	4.41E-20	0.0	5.94E-20	1.84E-21	1.11E-20
44	RU 103	5.65E+00	0.0	2.17E+00	0.0	1.42E+01	0.0	1.46E+02
44	RU 105	1.20E-02	0.0	4.35E-03	0.0	1.05E-01	0.0	7.83E+00
44	RU 106	9.19E+01	0.0	1.15E+01	0.0	1.24E+02	0.0	1.43E+03
47	AG 110M	9.76E-01	6.59E-01	5.27E-01	0.0	1.23E+00	0.0	7.84E+01
52	TE 125M	3.54E+03	9.61E+02	4.73E+02	9.95E+02	0.0	0.0	3.42E+03
52	TE 127M	9.04E+03	2.43E+03	1.07E+03	2.16E+03	2.58E+04	0.0	7.32E+03
52	TE 127	2.50E+01	6.74E+00	5.36E+00	1.73E+01	7.11E+01	0.0	9.77E+02
52	TE 129M	1.50E+04	4.19E+03	2.33E+03	4.84E+03	4.41E+04	0.0	1.83E+04
52	TE 129	2.55E-05	7.12E-06	6.05E-06	1.82E-05	7.46E-05	0.0	1.59E-03
52	TE 131M	1.30E+03	4.50E+02	4.79E+02	9.25E+02	4.35E+03	0.0	1.82E+04
52	TE 131	1.08E-12	3.30E-13	3.22E-13	8.28E-13	3.27E-12	0.0	5.69E-12
52	TE 132	2.57E+03	1.14E+03	1.37E+03	1.66E+03	1.06E+04	0.0	1.14E+04
53	I 130	8.96E+00	1.81E+01	9.33E+00	1.99E+03	2.71E+01	0.0	8.47E+00
53	I 131	1.86E+02	1.87E+02	1.06E+02	6.19E+04	3.08E+02	0.0	1.67E+01
53	I 132	6.95E-03	1.28E-02	5.87E-03	5.93E-01	1.96E-02	0.0	1.50E-02
53	I 133	3.14E+01	3.89E+01	1.47E+01	7.22E+03	6.48E+01	0.0	1.57E+01
53	I 135	1.66E+00	2.99E+00	1.41E+00	2.65E+02	4.58E+00	0.0	2.28E+00
55	CS 134	1.84E+06	3.02E+06	6.37E+05	0.0	9.35E+05	3.36E+05	1.63E+04
55	CS 136	1.75E+05	4.82E+05	3.12E+05	0.0	2.57E+05	3.83E+04	1.69E+04
55	CS 137	2.57E+06	2.46E+06	3.63E+05	0.0	8.02E+05	2.89E+05	1.54E+04
55	CS 138	3.21E-10	4.46E-10	2.83E-10	0.0	3.14E-10	3.38E-11	2.05E-10
56	BA 139	1.30E-05	6.92E-09	3.76E-07	0.0	6.04E-09	4.07E-09	7.48E-04
56	BA 140	2.48E+02	2.17E-01	1.45E+01	0.0	7.08E-02	1.30E-01	1.26E+02
56	BA 141	1.62E-15	9.05E-19	5.26E-17	0.0	7.83E-19	5.31E-18	9.21E-16
56	BA 142	2.78E-24	2.00E-27	1.55E-25	0.0	1.62E-27	1.18E-27	3.62E-26
57	LA 140	1.31E-01	4.59E-02	1.55E-02	0.0	0.0	0.0	1.28E+03
57	LA 142	2.24E-07	7.14E-08	2.24E-08	0.0	0.0	0.0	1.41E-02
58	CE 141	3.08E-02	1.54E-02	2.28E-03	0.0	6.73E-03	0.0	1.92E+01
58	CE 143	3.36E-03	1.82E+00	2.64E-04	0.0	7.64E-04	0.0	2.67E+01
58	CE 144	1.64E+00	5.15E-01	8.77E-02	0.0	2.85E-01	0.0	1.34E+02
59	PR 143	7.35E-01	2.21E-01	3.65E-02	0.0	1.19E-01	0.0	7.93E+02
59	PR 144	2.11E-19	6.52E-20	1.06E-20	0.0	3.45E-20	0.0	1.40E-16
60	ND 147	5.16E-01	4.18E-01	3.23E-02	0.0	2.29E-01	0.0	6.62E+02
74	W 187	2.02E+02	1.20E+02	5.37E+01	0.0	0.0	0.0	1.68E+04
93	NP 239	3.08E-02	2.21E-03	1.56E-03	0.0	6.40E-03	0.0	1.64E+02

Table A4.0-5
(2 of 2)

Oconee Nuclear Station
Liquid Effluent Dose - Child Parameters
 A_{aoi} mrem/hr per $\mu\text{Ci/ml}$

From Generic Section 3.1.1:

A_{aoi} = the site related ingestion dose commitment factor for an individual of age group, "a", to organ, "o", for each identified principal gamma and beta emitter, "i", in mrem/hr per $\mu\text{Ci/ml}$

$A_{aoi} = 1.14\text{E}+05 (U_{aw}\sigma_w/D_w \exp(-\lambda_i t_w) + U_{af}\sigma_f B F_i \exp(-\lambda_i t_f)) D F_{aoi}$

where:

$1.14\text{E}+05 = 10^6 \text{ pCi}/\mu\text{Ci} \times 10^3 \text{ ml/kg} \div 8760 \text{ hr/yr}$

U_{aw} = Water consumption by age group, l/yr

infant	330
child	510
teen	510
adult	730

σ_w, σ_f = Recirculation factors at equilibrium for the water and fish pathways respectively; these factors account for the fraction of discharged water reused by the station
 $\sigma_w = 1.00$ $\sigma_f = 1.00$

D_w = Dilution factor from the near field area to the potable water intake = 10000 (essentially no drinking water pathway)

U_{af} = Fish consumption by age group, kg/yr

infant	---
child	6.9
teen	16
adult	21

$B F_i$ = Bioaccumulation factor for radionuclide, "i", in fish, pCi/kg per pCi/l, from Table 3.1-1

$D F_{aoi}$ = Dose conversion factor for age group, "a", in organ, "o", for radionuclide, "i", in mrem/pCi, from Tables 3.1-2, 3.1-3, 3.1-4, and 3.1-5, respectively

λ_i = radiological decay constant for isotope, i, in 1/hr

t_w, t_f = transport time for the drinking water and fish pathways, hr
 $t_w = 12 \text{ hours}$ $t_f = 24 \text{ hours}$

Sample Calculation for Child, I-131, Thyroid:

$A(c, \text{thy}, \text{I-131}) = 1.14\text{E}5 (510 \cdot 1.0 / 1.0\text{E}4 \cdot \exp(-3.59\text{E}-3 \cdot 12) + 6.9 \cdot 1.0 \cdot 15 \cdot \exp(-3.59\text{E}-3 \cdot 24)) 5.72\text{E}-3 = 6.19\text{E}4 \text{ mr/hr per } \mu\text{Ci/ml}$

TABLE A4.0-6
(1 OF 2)

OCONEE NUCLEAR STATION
LIQUID EFFLUENT DOSE - INFANT PARAMETERS
A(I) MREM/HR PER UCI/ML

RADIONUCLIDE		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
1 H 3		0.0	1.16E-03	1.16E-03	1.16E-03	1.16E-03	1.16E-03	1.16E-03
11 NA 24		2.19E-02	2.19E-02	2.19E-02	2.19E-02	2.19E-02	2.19E-02	2.19E-02
24 CR 51		0.0	0.0	5.24E-05	3.42E-05	7.47E-06	6.65E-05	1.53E-03
25 MN 54		0.0	7.48E-02	1.69E-02	0.0	1.66E-02	0.0	2.75E-02
25 MN 56		0.0	1.21E-04	2.08E-05	0.0	1.04E-04	0.0	1.09E-02
26 FE 55		5.23E-02	3.38E-02	9.03E-03	0.0	0.0	1.65E-02	4.29E-03
26 FE 59		1.15E-01	2.01E-01	7.91E-02	0.0	0.0	5.94E-02	9.59E-02
27 CO 58		0.0	1.35E-02	3.36E-02	0.0	0.0	0.0	3.36E-02
27 CO 60		0.0	4.06E-02	9.59E-02	0.0	0.0	0.0	9.67E-02
28 NI 63		2.39E+00	1.47E-01	8.28E-02	0.0	0.0	0.0	7.34E-03
28 NI 65		6.52E-04	7.38E-05	3.36E-05	0.0	0.0	0.0	5.62E-03
29 CU 64		0.0	1.19E-03	5.50E-04	0.0	2.01E-03	0.0	2.44E-02
30 ZN 65		6.91E-02	2.37E-01	1.09E-01	0.0	1.15E-01	0.0	2.00E-01
30 ZN 69		5.45E-08	9.82E-08	7.31E-09	0.0	4.08E-08	0.0	8.01E-06
35 BR 83		0.0	0.0	4.22E-05	0.0	0.0	0.0	0.0
35 BR 85		0.0	0.0	0.0	0.0	0.0	0.0	0.0
37 RB 86		0.0	6.28E-01	3.10E-01	0.0	0.0	0.0	1.61E-02
37 RB 88		0.0	1.36E-15	7.46E-16	0.0	0.0	0.0	1.33E-15
37 RB 89		0.0	6.75E-18	4.65E-18	0.0	0.0	0.0	2.30E-18
38 SR 89		9.38E+00	0.0	2.69E-01	0.0	0.0	0.0	1.93E-01
38 SR 90		4.70E+01	0.0	1.27E+01	0.0	0.0	0.0	8.69E-01
38 SR 91		7.83E-02	0.0	2.83E-03	0.0	0.0	0.0	9.27E-02
38 SR 92		3.36E-03	0.0	1.25E-04	0.0	0.0	0.0	3.63E-02
39 Y 90		2.87E-04	0.0	7.70E-06	0.0	0.0	0.0	3.97E-01
39 Y 91M		1.30E-10	0.0	4.41E-12	0.0	0.0	0.0	4.32E-07
39 Y 91		4.23E-03	0.0	1.13E-04	0.0	0.0	0.0	3.03E-01
39 Y 92		2.77E-06	0.0	7.78E-08	0.0	0.0	0.0	5.28E-02
39 Y 93		4.01E-05	0.0	1.09E-06	0.0	0.0	0.0	3.17E-01
40 ZR 95		7.71E-04	1.88E-04	1.33E-04	0.0	2.02E-04	0.0	9.35E-02
40 ZR 97		3.40E-05	5.84E-06	2.67E-06	0.0	5.89E-06	0.0	3.72E-01
41 NB 95		1.56E-04	6.44E-05	3.73E-05	0.0	4.62E-05	0.0	5.44E-02
42 MO 99		0.0	1.13E-01	2.20E-02	0.0	1.68E-01	0.0	3.71E-02
43 TC 99M		1.81E-06	3.74E-06	4.82E-05	0.0	4.02E-05	1.95E-06	1.09E-03
43 TC 101		4.57E-21	5.75E-21	5.69E-20	0.0	6.84E-20	3.14E-21	9.78E-19
44 RU 103		5.52E-03	0.0	1.85E-03	0.0	1.15E-02	0.0	6.71E-02
44 RU 105		7.85E-05	0.0	2.64E-05	0.0	5.77E-04	0.0	3.12E-02
44 RU 106		9.06E-02	0.0	1.13E-02	0.0	1.07E-01	0.0	6.88E-01
47 AG 110M		3.74E-03	2.73E-03	1.81E-03	0.0	3.91E-03	0.0	1.42E-01
52 TE 125M		8.71E-02	2.91E-02	1.18E-02	2.93E-02	0.0	0.0	4.15E-02
52 TE 127M		2.19E-01	7.28E-02	2.66E-02	6.34E-02	5.40E-01	0.0	8.85E-02
52 TE 127		1.55E-03	5.18E-04	3.32E-04	1.26E-03	3.77E-03	0.0	3.24E-02
52 TE 129M		3.72E-01	1.28E-01	5.73E-02	1.43E-01	9.31E-01	0.0	2.22E-01
52 TE 129		8.21E-07	2.83E-07	1.92E-07	6.88E-07	2.04E-06	0.0	6.56E-05
52 TE 131M		4.33E-02	1.74E-02	1.44E-02	3.54E-02	1.20E-01	0.0	2.94E-01
52 TE 131		1.49E-12	5.49E-13	4.17E-13	1.33E-12	3.80E-12	0.0	6.00E-11
52 TE 132		7.04E-02	3.48E-02	3.25E-02	5.14E-02	2.18E-01	0.0	1.29E-01
53 I 130		1.15E-02	2.53E-02	1.02E-02	2.84E+00	2.78E-02	0.0	5.43E-03
53 I 131		1.29E-01	1.52E-01	6.70E-02	5.01E+01	1.78E-01	0.0	5.44E-03
53 I 132		1.68E-04	3.41E-04	1.21E-04	1.60E-02	3.80E-04	0.0	2.76E-04
53 I 133		3.15E-02	4.59E-02	1.34E-02	8.35E+00	5.40E-02	0.0	7.77E-03
53 I 135		3.88E-03	7.71E-03	2.81E-03	6.92E-01	8.60E-03	0.0	2.79E-03
55 CS 134		1.42E+00	2.64E+00	2.67E-01	0.0	6.81E-01	2.79E-01	7.18E-03
55 CS 136		1.68E-01	4.95E-01	1.85E-01	0.0	1.97E-01	4.03E-02	7.51E-03
55 CS 137		1.96E+00	2.30E+00	1.63E-01	0.0	6.17E-01	2.50E-01	7.19E-03
55 CS 138		3.47E-10	5.65E-10	2.74E-10	0.0	2.82E-10	4.40E-11	9.03E-10
56 BA 139		7.83E-06	5.19E-09	2.27E-07	0.0	3.12E-09	3.15E-09	4.96E-04
56 BA 140		6.26E-01	6.26E-04	3.23E-02	0.0	1.49E-04	3.84E-04	1.54E-01
56 BA 141		2.22E-15	1.52E-18	7.00E-17	0.0	9.14E-19	9.25E-19	2.71E-14
56 BA 142		3.78E-24	3.15E-27	1.86E-25	0.0	1.81E-27	1.90E-27	1.56E-23
57 LA 140		6.46E-05	2.55E-05	6.55E-06	0.0	0.0	0.0	2.99E-01
57 LA 142		1.87E-08	6.86E-09	1.64E-09	0.0	0.0	0.0	1.17E-03
58 CE 141		2.93E-04	1.79E-04	2.10E-05	0.0	5.51E-05	0.0	9.23E-02
58 CE 143		4.33E-05	2.87E-02	3.28E-06	0.0	8.37E-06	0.0	1.68E-01
58 CE 144		1.12E-02	4.58E-03	6.27E-04	0.0	1.85E-03	0.0	6.43E-01
59 PR 143		2.98E-04	1.11E-04	1.48E-05	0.0	4.14E-05	0.0	1.57E-01
59 PR 144		2.90E-19	1.12E-19	1.46E-20	0.0	4.06E-20	0.0	5.21E-15
60 ND 147		2.02E-04	2.07E-04	1.27E-05	0.0	7.99E-05	0.0	1.31E-01
74 W 187		2.40E-03	1.67E-03	5.77E-04	0.0	0.0	0.0	9.80E-02
93 NP 239		3.61E-05	3.23E-06	1.82E-06	0.0	6.43E-06	0.0	9.32E-02

Table A4.0-6
(2 of 2)

Oconee Nuclear Station
Liquid Effluent Dose - Infant Parameters
A_{oi} mrem/hr per μCi/ml

From Generic Section 3.1.1:

A_{oi} = the site related ingestion dose commitment factor for an individual of age group, "a", to organ, "o", for each identified principal gamma and beta emitter, "i", in mrem/hr per μCi/ml

$$A_{oi} = 1.14E+05 (U_{aw}\sigma_w/D_w \exp(-\lambda_i t_w) + U_{af}\sigma_f B_{fi} \exp(-\lambda_i t_f)) DF_{aoi}$$

where:

$$1.14E+05 = 10^6 \text{ pCi}/\mu\text{Ci} \times 10^3 \text{ ml}/\text{kg} \div 8760 \text{ hr}/\text{yr}$$

U_{aw} = Water consumption by age group, l/yr

infant	330
child	510
teen	510
adult	730

σ_w, σ_f = Recirculation factors at equilibrium for the water and fish pathways respectively; these factors account for the fraction of discharged water reused by the station
σ_w = 1.00 σ_f = 1.00

D_w = Dilution factor from the near field area to the potable water intake = 10000 (essentially no drinking water pathway)

U_{af} = Fish consumption by age group, kg/yr

infant	---
child	6.9
teen	16
adult	21

B_{fi} = Bioaccumulation factor for radionuclide, "i", in fish, pCi/kg per pCi/l, from Table 3.1-1

DF_{aoi} = Dose conversion factor for age group, "a", in organ, "o", for radionuclide, "i", in mrem/pCi, from Tables 3.1-2, 3.1-3, 3.1-4, and 3.1-5, respectively

λ_i = radiological decay constant for isotope, i, in 1/hr

t_w, t_f = transport time for the drinking water and fish pathways, hr
t_w = 12 hours t_f = 24 hours

Sample Calculation for Infant, I-131, Thyroid:

$$A(i, \text{thy}, I-131) = 1.14E5 (330 \cdot 1.0 / 1.0E4 \cdot \exp(-3.59E-3 \cdot 12) + 0 \cdot 1.0 \cdot 15 \cdot \exp(-3.59E-3 \cdot 24)) \cdot 1.39E-2 = 5.01E1 \text{ mr/hr per } \mu\text{Ci/ml}$$

Table A4.0-7 - Meteorological Parameter and Applicable Pathways
 Potential Worst-Case Offsite Locations for
 Analyzing Offsite Doses from Particulate, Iodine
 and Other Radionuclides

Semi-Elevated Release Worst-Case Locations

	<u>(X/O)</u>	<u>(D/O)</u>
	sec/m ³	1/m ²
(1) Inhalation, 1.0 mi, SW	1.672E-6	1.205E-8
(2) Garden, 1.0 mi, NE	9.503E-7	1.295E-8
(3) Meat Animal, 1.9 mi, NE	6.350E-7	5.666E-9
(4) Milk Animal, 4.5 mi, WNW	4.796E-8	1.868E-10
(5) Combination, 1.0 mi, NE	9.503E-7	1.295E-8

Ground Level Release Worst-Case Locations

	<u>(X/O)</u>	<u>(D/O)</u>
	sec/m ³	1/m ²
(1) Inhalation, 1.0 mi, SE	7.308E-6	1.401E-8
(2) Garden, 1.0 mi, NE	3.886E-6	2.259E-8
(3) Meat Animal, 1.9 mi, NE	1.529E-6	8.114E-9
(4) Milk Animal, 4.5 mi, WNW	9.502E-8	1.643E-10
(5) Combination, 1.0 mi, NE	3.886E-6	2.259E-8

TABLE A4.0-8

PATHWAY APPLICABILITY FOR ALL LOCATIONS BASED ON SITE SURVEY*

OCONEE NUCLEAR STATION
(1 of 1)

Distance to the control location in miles

SECTOR 0-0.5 0.5-1.0 1.0-1.5 1.5-2.0 2.0-2.5 2.5-3.0 3.0-3.5 3.5-4.0 4.0-4.5 4.5-5.0

N	X	X	V	V	V	VI	VI	VI	VIM	VIMG
NNE	X	X	V	V	VI	VI	VIM	VIM	VIM	VIMG
NE	X	X	VI	VIM	VIM	VIM	VIM	VIM	VIM	VIMG
ENE	X	X	VI	VI	VI	VI	VI	VIM	VIM	VIMG
E	X	X	VI	VI	VIM	VIM	VIM	VIM	VIM	VIMG
ESE	X	X	V	VI	VIM	VIM	VIM	VIM	VIM	VIMG
SE	X	X	VI	VI	VI	VI	VI	VI	VI	VIMG
SSE	X	X	V	VI	VI	VI	VI	VI	VI	VIMG
S	X	X	V	VI	VI	VI	VI	VI	VI	VIMG
SSW	X	X	VI	VI	VI	VI	VI	VI	VI	VIMG
SW	X	X	VI	VI	VI	VI	VI	VI	VI	VIMG
WSW	X	X	V	VI	VI	VI	VI	VIM	VIM	VIMG
W	X	X	V	VI	VI	VI	VI	VIM	VIM	VIMG
WNW	X	X	VI	VI	VIM	VIM	VIM	VIM	VIM	VIMG
NW	X	X	VI	VI	VI	VI	VI	VI	VIM	VIMG
NNW	X	X	VI	VI	VI	VI	VI	VI	VI	VIMG

PATHWAYS: X - None V - VEGETABLE M - MEAT G - GOAT MILK C - COW MILK I - INHALATION/GROUND

* The land use census identifies the nearest inhalation/ground, meat, and milk pathways to the site. The vegetable pathway is assumed to exist in each sector for dose calculation purposes. Locations beyond the nearest pathway are assumed to contain that pathway for dose calculation purposes.

Rev. 40
1/1/00

Figure A4.0-1 - Fuel Cycle Dose Calculation Worksheet For Organ Doses

Adult Age Group

Liquid Pathway Organ Doses $D_{a,o}(l_o)$

Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
------	-------	--------	---------	--------	------	--------

Airborne Pathway Organ Doses $D_{a,o}(g_e)$ and $D_{a,o}(g_g)$ - Particulate, Iodine and Other Radionuclides with $T_{1/2} > 8$ Days

Location 1 - Worst-case Inhalation Location [1]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location [2]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-case Meat Animal Location [3]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Locations 4 and 5 - Worst-case Milk/Combination Location [4]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Adult Organ Maximums**

Total	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
	_____	_____	_____	_____	_____	_____	_____

Figure A4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet For Organ Doses

Teen Age Group

Liquid Pathway Organ Doses $D_{a,o}(l_o)$

Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
------	-------	--------	---------	--------	------	--------

Airborne Pathway Organ Doses $D_{a,o}(g_e)$ and $D_{a,o}(g_g)$ - Particulate, Iodine and Other Radionuclides with T 1/2 > 8 Days

Location 1 - Worst-case Inhalation Location [1]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location [2]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-case Meat Animal Location [3]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Locations 4 and 5 - Worst-case Milk/Combination Location [4]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Teen Organ Maximums**

Total	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
	_____	_____	_____	_____	_____	_____	_____

Figure A4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet For Organ Doses

Child Age Group

Liquid Pathway Organ Doses $D_{a,o}(l_o)$

Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
_____	_____	_____	_____	_____	_____	_____

Airborne Pathway Organ Doses $D_{a,o}(g_e)$ and $D_{a,o}(g_g)$ - Particulate, Iodine and Other Radionuclides with T 1/2 > 8 Days

Location 1 - Worst-case Inhalation Location [1]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location [2]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-case Meat Animal Location [3]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Locations 4 and 5 - Worst-case Milk/Combination Location [4]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Child Organ Maximums**

Total	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
	_____	_____	_____	_____	_____	_____	_____

Figure A4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet For Organ Doses

Infant Age Group

Liquid Pathway Organ Doses $D_{a,o}(l_o)$

Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
_____	_____	_____	_____	_____	_____	_____

Airborne Pathway Organ Doses $D_{a,o}(g_e)$ and $D_{a,o}(g_g)$ - Particulate, Iodine and Other Radionuclides with $T_{1/2} > 8$ Days

Location 1 - Worst-case Inhalation Location [1]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location [2]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-case Meat Animal Location [3]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Locations 4 and 5 - Worst-case Milk/Combination Location [4]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Infant Organ Maximums**

Total	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
	_____	_____	_____	_____	_____	_____	_____

Figure A4.0-1 - Fuel Cycle Dose Calculation Worksheet For Organ Doses

Adult Age Group

Liquid Pathway Organ Doses $D_{a,o}(l_o)$

Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
------	-------	--------	---------	--------	------	--------

Airborne Pathway Organ Doses $D_{a,o}(g_e)$ and $D_{a,o}(g_g)$ - Particulate, Iodine and Other Radionuclides with $T_{1/2} > 8$ Days

Location 1 - Worst-case Inhalation Location [1]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location [2]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-case Meat Animal Location [3]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Locations 4 and 5 - Worst-case Milk/Combination Location [4]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Adult Organ Maximums**

Total	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
	_____	_____	_____	_____	_____	_____	_____

Figure A4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet For Organ Doses

Teen Age Group

Liquid Pathway Organ Doses $D_{a,o}(l_o)$

Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
------	-------	--------	---------	--------	------	--------

Airborne Pathway Organ Doses $D_{a,o}(g_e)$ and $D_{a,o}(g_g)$ - Particulate, Iodine and Other Radionuclides with $T_{1/2} > 8$ Days

Location 1 - Worst-case Inhalation Location [1]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location [2]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-case Meat Animal Location [3]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Locations 4 and 5 - Worst-case Milk/Combination Location [4]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Teen Organ Maximums**

Total	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
	_____	_____	_____	_____	_____	_____	_____

Figure A4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet For Organ Doses

Child Age Group

Liquid Pathway Organ Doses $D_{a,o}(l_o)$

Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
------	-------	--------	---------	--------	------	--------

Airborne Pathway Organ Doses $D_{a,o}(g_e)$ and $D_{a,o}(g_g)$ - Particulate, Iodine and Other Radionuclides with $T_{1/2} > 8$ Days

Location 1 - Worst-case Inhalation Location [1]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location [2]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-case Meat Animal Location [3]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Locations 4 and 5 - Worst-case Milk/Combination Location [4]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Child Organ Maximums**

Total	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
	_____	_____	_____	_____	_____	_____	_____

Figure A4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet For Organ Doses

Infant Age Group

Liquid Pathway Organ Doses $D_{a,o}(l_o)$

Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
------	-------	--------	---------	--------	------	--------

Airborne Pathway Organ Doses $D_{a,o}(g_e)$ and $D_{a,o}(g_g)$ - Particulate, Iodine and Other Radionuclides with $T_{1/2} > 8$ Days

Location 1 - Worst-case Inhalation Location [1]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location [2]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-case Meat Animal Location [3]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Locations 4 and 5 - Worst-case Milk/Combination Location [4]

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
S-Elev	_____	_____	_____	_____	_____	_____	_____
Ground	_____	_____	_____	_____	_____	_____	_____
Total*	_____	_____	_____	_____	_____	_____	_____

Infant Organ Maximums**

Total	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
	_____	_____	_____	_____	_____	_____	_____

Figure A4.0-1 (Cont.d) - Fuel Cycle Dose Calculation Worksheet for Organ Doses

All Age Groups

Maximum Organ Dose ***

Organ = _____
Age Group = _____
Dose = _____ mrem/yr

Meteorological Parameters Used to Evaluate Airborne Pathway Doses:

- [1] Semi-elevated evaluation location for Inhalation is 1.0 mi, SW
 $\overline{X/Q} = 1.672E-06 \text{ sec/m}^3$, $\overline{D/Q} = 1.205E-08 \text{ 1/m}^2$
Ground Level evaluation location for Inhalation is 1.0 mi, SE
 $\overline{X/Q} = 7.308E-06 \text{ sec/m}^3$, $\overline{D/Q} = 1.401E-08 \text{ 1/m}^2$
- [2] Semi-elevated evaluation location for the Garden is 1.0 mi, NE
 $\overline{X/Q} = 9.503E-07 \text{ sec/m}^3$, $\overline{D/Q} = 1.295E-08 \text{ 1/m}^2$
Ground Level evaluation location for the Garden is 1.0 mi, NE
 $\overline{X/Q} = 3.886E-06 \text{ sec/m}^3$, $\overline{D/Q} = 2.259E-08 \text{ 1/m}^2$
- [3] Semi-elevated evaluation location for Meat Animal is 1.9 mi, NE
 $\overline{X/Q} = 6.350E-07 \text{ sec/m}^3$, $\overline{D/Q} = 5.666E-09 \text{ 1/m}^2$
Ground Level evaluation location for Meat Animal is 1.9 mi, NE
 $\overline{X/Q} = 1.529E-06 \text{ sec/m}^3$, $\overline{D/Q} = 8.114E-09 \text{ 1/m}^2$
- [4] Semi-elevated evaluation location for Milk is 4.5 mi, WNW
 $\overline{X/Q} = 4.796E-08 \text{ sec/m}^3$, $\overline{D/Q} = 1.868E-10 \text{ 1/m}^2$
Ground Level evaluation location for Milk is 4.5 mi, WNW
 $\overline{X/Q} = 9.502E-08 \text{ sec/m}^3$, $\overline{D/Q} = 1.643E-10 \text{ 1/m}^2$
- [5] Semi-elevated evaluation location for Combination is 1.0 mi, NE
 $\overline{X/Q} = 9.503E-07 \text{ sec/m}^3$, $\overline{D/Q} = 1.295E-08 \text{ 1/m}^2$
Ground Level evaluation location for Combination is 1.0 mi, NE
 $\overline{X/Q} = 3.886E-06 \text{ sec/m}^3$, $\overline{D/Q} = 2.259E-08 \text{ 1/m}^2$

Notes:

- * Fuel cycle dose for age group a and organ o at analyzed limiting food pathway locations ($D_{a,o}(l_o) + D_{a,o}(g_e) + D_{a,o}(g_g)$).
- ** Limiting dose estimates for each organ for age group a (maximums of "Total*" values calculated for Locations 1 through 5).
- *** Limiting dose estimate for any organ or age group (maximum of "Total" value calculated for any age group)

A5.0 RADIOLOGICAL ENVIRONMENTAL MONITORING

The radiological environmental monitoring program shall be conducted in accordance with Selected Licensee Commitment 16.11.6.

The monitoring program locations and analyses are given in Tables A5.0-1 through A5.0-3 and Figure A5.0-1.

Site specific characteristics make ground water sampling and food product sampling unnecessary. Ground water recharge is from precipitation and the ground water gradient is toward the effluent discharge area; therefore, contamination of ground water from liquid effluents is highly improbable. However, some ground water sampling is performed to verify this.

Duke Power's EnRad Laboratories participates in an interlaboratory comparison program. This program is described in the Annual Environmental Operating Report.

The land use census data is used to identify the location with the highest possible dose for a particular ingestion pathway (milk, meat, etc.). Environmental monitoring measurements taken from these locations are then used to perform dose calculations that serve as a verification of the dose calculations that are performed for technical specification and licensee commitment (i.e., Compliance) purposes.

The dates of the land use census that were used to identify the controlling receptor sample locations were 09/02/99 - 09/14/99.

The 1999 land use census did not identify any locations where environmental monitoring samples are required but were not available for collection.

TABLE A5.0-1
(1 of 1)

OCONEE RADIOLOGICAL MONITORING PROGRAM SAMPLING LOCATIONS
(TLD LOCATIONS)

SAMPLING LOCATION DESCRIPTION *			SAMPLING LOCATION DESCRIPTION *		
020	SITE BOUNDARY	(0.1 MILES N)	040	4-5 MILE RADIUS	(4.5 MILES E)
021	SITE BOUNDARY	(0.3 MILES NNE)	041	4-5 MILE RADIUS	(4.0 MILES ESE)
022	SITE BOUNDARY	(0.5 MILES NE)	042	4-5 MILE RADIUS	(5.0 MILES SE)
023	SITE BOUNDARY	(0.9 MILES ENE)	043	4-5 MILE RADIUS	(4.0 MILES SSE)
024	SITE BOUNDARY	(0.8 MILES E)	044	4-5 MILE RADIUS	(4.0 MILES S)
025	SITE BOUNDARY	(0.4 MILES ESE)	045	4-5 MILE RADIUS	(5.0 MILES SSW)
026	SITE BOUNDARY	(0.3 MILES SE)	046	4-5 MILE RADIUS	(4.5 MILES SW)
027	SITE BOUNDARY	(0.4 MILES SSE)	047	4-5 MILE RADIUS	(4.0 MILES WSW)
028	SITE BOUNDARY	(0.5 MILES S)	048	4-5 MILE RADIUS	(4.0 MILES W)
029	SITE BOUNDARY	(0.6 MILES SSW)	049	4-5 MILE RADIUS	(4.0 MILES WNW)
030	SITE BOUNDARY	(0.4 MILES SW)	050	4-5 MILE RADIUS	(4.0 MILES NW)
031	SITE BOUNDARY	(0.3 MILES WSW)	051	4-5 MILE RADIUS	(4.5 MILES NNW)
032	SITE BOUNDARY	(0.2 MILES WNW)	052	SPECIAL INTEREST	(12.0 MILES ENE)
033	SITE BOUNDARY	(0.2 MILES WNW)	053	SPECIAL INTEREST	(11.0 MILES E)
034	SITE BOUNDARY	(0.2 MILES NW)	054	SPECIAL INTEREST	(9.5 MILES ESE)
035	SITE BOUNDARY	(0.2 MILES NNW)	055	SPECIAL INTEREST	(9.5 MILES SSE)
036	4-5 MILE RADIUS	(4.0 MILES N)	056	SPECIAL INTEREST	(8.4 MILES SSW)
037	4-5 MILE RADIUS	(4.5 MILES NNE)	057	SPECIAL INTEREST	(9.0 MILES SW)
038	4-5 MILE RADIUS	(4.0 MILES NE)	058	SPECIAL INTEREST	(9.4 MILES WSW)
039	4-5 MILE RADIUS	(4.0 MILES ENE)	059	SPECIAL INTEREST	(9.2 MILES NW)
			076	SITE BOUNDARY	(0.2 MILES W)
			081	SPECIAL INTEREST	(9.8 MILES SE)

* All sampling locations are collected quarterly

TABLE A5.0-2
(1 OF 1)
OCONEE RADIOLOGICAL MONITORING PROGRAM SAMPLING LOCATIONS
(OTHER SAMPLING LOCATIONS)


CODE:		Air Radioiodines and Particulates	Surface Water	Drinking Water	Shoreline Sediment	Milk	Fish	Broadleaf Vegetation
W - Weekly								
SM - Semimonthly								
M - Monthly								
SA - Semiannually								
----- <u>SAMPLING LOCATION DESCRIPTION</u> -----								
060	New Greenville Water Intake Rd. (2.6 miles NNE) *	W		M			SA	M
062	Lake Keowee/Hydro Intake (0.8 mile ENE) (CONTROL)		M					
063	Lake Hartwell - Hwy 183 Bridge (0.8 mile ESE) (000.7)		M		SA		SA	
064	Seneca (6.7 miles SSW) (004.1) (CONTROL)			M				
066	Anderson (19.0 miles SSE) (012)			M				
067	Lawrence Ramsey Bridge, Hwy 27 (4.2 miles SSE) (005.2)				SA		SA	
068	High Falls County Park (2.0 miles W) (CONTROL)				SA			
069	Orr's Dairy (4.5 miles WNW) (002.1)					SM		
071	Clemson Dairy (10.3 miles SSE) (006.3)					SM		
074	Keowee Key Resort (2.3 miles NNW)	W						
077	Skimmer Wall (1.0 mile SW)	W						M
078	Recreation Site (0.6 mile WSW)	W						
079	Keowee Dam (0.5 mile NE)	W						M
080	Martin's Dairy (19.0 miles SSE) (CONTROL)					SM		
081	DP Clemson Operations Center (9.8 miles SE) (CONTROL)	W						M

* Control for Fish only

TABLE A5.0-3
(1 of 1)

OCONEE RADIOLOGICAL MONITORING PROGRAM ANALYSES

<u>SAMPLE MEDIUM</u>	<u>ANALYSIS SCHEDULE</u>	<u>ANALYSES</u>				
		<u>GAMMA ISOTOPIC</u>	<u>TRITIUM</u>	<u>LOW LEVEL I-131</u>	<u>GROSS BETA</u>	<u>TLD</u>
1. Air Radioiodine	Weekly	X				
2. Air Particulates	Weekly Quarterly Composite	X			X	
3. Direct Radiation	Quarterly					X
4. Surface Water	Monthly Quarterly Composite	X		X		
5. Drinking Water	Monthly Quarterly Composite	X		X	X	
6. Shoreline Sediment	Semiannually	X				
7. Milk	Semimonthly	X		X		
8. Fish	Semiannually	X				
9. Broadleaf Vegetation	Monthly	X				



• TLD LOCATIONS
 X ONSITE SAMPLE LOCATIONS
 RADIOLOGICAL MONITORING PROGRAM LOCATIONS
 OCONEE NUCLEAR STATION
 FIGURE A5.0-1
 (2 of 2)
 Revision 39
 1/1/99

MCGUIRE

January 1, 2000

Subject: Offsite Dose Calculation Manual (ODCM)
McGuire Nuclear Station Section - Revision 41

The General Office Radiation Protection Staff is transmitting to you this date Revision 41 of the McGuire Offsite Dose Calculation Manual. As this revision only affects McGuire Nuclear Station, the approval of other station managers is not required. A list of affected pages is given below. Please insert this letter with the attached Justification section in front of the January 1, 1999 Revision 40 letter.

REMOVE THESE PAGES

Table B4.0-7
Table B4.0-8
Figure B4.0-1 (page 1 of 10)
B-17
Table B5.0-2
Figure B5.0-1 (page 1 of 2)

INSERT THESE PAGES

Table B4.0-7
Table B4.0-8
Figure B4.0-1 (page 1 of 10)
B-17
Table B5.0-2
Figure B5.0-1 (page 1 of 2)

Effective Date: 1/1/00

Effective Date: 1/1/00



L. E. Haynes, Technical Manager
Radiation Protection



D. M. Jamil, Manager
McGuire Nuclear Station

If you have any questions concerning Revision 41, please call Caryl Ingram at (704) 382-4496.



Caryl D. Ingram, Senior Engineer
Radiation Protection
Nuclear Services Division

JUSTIFICATION FOR REVISION 41

(page 1 of 1)

Table B4.0-7

Revised the maximum meat location, maximum milk location, and maximum combination location, dispersion factors, and deposition factors based on the 1999 land use census.

Table B4.0-8

Revised table based on the 1999 land use census.

Figure B4.0-1 (page 1 of 10)

Revised the maximum meat location, maximum milk location, and maximum combination location, dispersion factors, and deposition factors based on the 1999 land use census.

Page B-17

Updated the name for Duke Power's environmental laboratory to EnRad. Revised land use census dates.

Table B5.0-2

Added North Mecklenburg Drinking Water Site #101. The site began operation in 1999.

Figure B5.0-1 (page 1 of 2)

Added North Mecklenburg Drinking Water Site #101.

APPENDIX B
MCGUIRE NUCLEAR STATION
SITE SPECIFIC INFORMATION

APPENDIX B - TABLE OF CONTENTS

	<u>Page</u>
B1.0 <u>MCGUIRE NUCLEAR STATION RADWASTE SYSTEMS</u>	B-1
B2.0 <u>RELEASE RATE CALCULATION</u>	B-4
B3.0 <u>RADIATION MONITOR SETPOINTS</u>	B-8
B4.0 <u>DOSE CALCULATIONS</u>	B-13
B5.0 <u>RADIOLOGICAL ENVIRONMENTAL MONITORING</u>	B-17

TABLE B1.0-1
ABBREVIATIONS

Systems:

CM - Condensate Cooling
KC - Component Cooling
NB - Boron Recycle
NC - Reactor Coolant
WC - Conventional Waste Water Treatment
WG - Waste Gas
WL - Liquid Waste
WM - Liquid Waste Monitor and Disposal

Terms:

BA - Boric Acid Tank
RC - Condenser Cooling Water
CDT - Chemical Drain Tank
ECST - Evaporator Concentrates Storage Tank
FDT - Floor Drain Tank
FWST - Fueling Water Storage Tank (formerly Refueling Water Storage Tank)
LHST - Laundry and Hot Shower Tank
MST - Mixing and Settling Tank
NCDT - Reactor Coolant Drain Tank
RBT - Resin Batching Tank
RHT - Recycle Holdup Tank
RMT - Recycle Monitor Tank
RMWST - Reactor Makeup Water Storage Tank
SRST - Spent Resin Storage Tank
VUCDT - Ventilation Unit Condensate Drain Tank
WDT - Waste Drain Tank
WEFT - Waste Evaporator Feed Tank
WMT - Waste Monitor Tank

TABLE B1.0-1

B1.0 MCGUIRE NUCLEAR STATION RADWASTE SYSTEMS

B1.1 LIQUID RADWASTE PROCESSING

The liquid radwaste system at McGuire Nuclear Station (MNS) is used to collect and treat fluid chemical and radiochemical by-products of unit operation. The system produces effluents which can be reused in the plant or discharged in small, dilute quantities to the environment. The means of treatment vary with waste type and desired product in the various systems:

- A) Filtration - Waste sources are filtered during processing. In some cases, such as the Floor Drain Tank (FDT) Subsystem of the Liquid Waste (WL) System, filtration may be the only treatment required.
- B) Adsorption - Adsorption of halides and organic chemicals by activated charcoal (Carbon Filter) may be used in treating waste in the Laundry and Hot Shower Tank (LHST). The carbon filter is designed to remove organophosphates and free chlorine. Activated charcoal need not be used when these chemicals are not present (e.g., phosphate detergents are not used at the station). Ion exchange resin or other media may be used in the carbon filter vessel as desired.
- C) Ion Exchange - Ion exchange is used to remove radioactive cations from solution, as in the case of either LHST or FDT waste in the WL System after removal of organics by carbon filtration (adsorption). Ion exchange is also used in removing both cations (cobalt, manganese) and anions (chloride, fluoride) from evaporator distillates in order to purify the distillates for reuse as makeup water. Distillate from the Waste Evaporator in the WL System and the Boron Recycle Evaporator in the Boron Recycle System (NB) can be treated by this method, as well as FDT, LHST waste, and reactor bleed.
- D) Gas Stripping - Removal of gaseous radioactive fission products is accomplished in both the WL Evaporator and the NB Evaporator.
- E) Distillation - Production of pure water from the waste by boiling it away from the contaminated solution which originally contained it is accomplished by both evaporators. Proper control of the process will yield water which can be reused for makeup. Polishing of this product can be achieved by ion exchange as pointed out above.
- F) Concentration - In both the WL and NB Evaporators, dissolved chemicals are concentrated in the lower shell as water is boiled away. In the case of the WL Evaporator, the volume of water containing waste chemicals and radioactive cations is reduced so that the waste may be more easily and cheaply solidified and shipped for burial. In the NB Evaporator, the dilute boron is normally concentrated to 4% so that it may be reused for makeup to the reactor coolant system.

Figure B1.0-1 is a schematic representation of the liquid radwaste system at McGuire.




FIGURE B1.0-1
 MCGUIRE NUCLEAR STATION
 LIQUID RADWASTE SYSTEM
 REVISION 28 1/1/80

B1.2 GASEOUS RADWASTE SYSTEMS

The gaseous waste disposal system for McGuire is designed with the capability of processing the fission-product gases from contaminated reactor coolant fluids resulting from operation. The design base for the system shown schematically in Fig. B1.0-2 is the retention, through the plant lifetime, of all the gaseous fission products to be discharged from the reactor coolant system to the chemical and volume control system and other plant systems to eliminate the need for intentional discharge of radioactive gases from the waste gas holdup tanks. Actual system operation is aimed at maximizing storage time for decay prior to infrequent releases. Unavoidable sources of low-level radioactive gaseous discharge to the environment will be from periodic purging operations of the containment, from the auxiliary building ventilation system, and through the secondary system air ejector. With respect to the former, the potential contamination is expected to arise from non-recyclable reactor coolant leakage. With respect to the air ejector, the potential source of contamination will be from leakage of the reactor coolant to the secondary system through defects in steam generator tubes. The gaseous waste disposal system includes two waste gas compressors, two catalytic hydrogen recombiners, six gas decay storage tanks for use during normal power generation, and two gas decay storage tanks for use during shutdown and startup operations.

B1.2.1 Gas Collection System

The gas collection system combines the waste hydrogen and fission gases from the volume control tanks, the boron recycle and liquid waste gas stripper evaporators, and other sources produced during normal operation or the gas collected during the shutdown degasification (high percentage of nitrogen) and cycles it through the catalytic recombiners to convert the hydrogen to water. After the water vapor is removed, the resulting gas stream is transferred from the recombiner into the gas decay tanks, where the accumulated activity may be contained in six approximately equal parts. From the decay tanks, the gas flows back to the compressor suction to complete the loop circuit.

B1.2.2 Containment and Auxiliary Building Ventilation

Nonrecyclable reactor coolant leakage occurring either inside the containment or inside the auxiliary building will generate gaseous activity. Gases resulting from leakage inside the containment will be contained until the containment is purged. The containment atmosphere will be circulated through a charcoal adsorber and a particulate filter prior to release to the atmosphere.

Gases resulting from leakage inside the auxiliary building are released, without further decay, to the atmosphere via the auxiliary building ventilation system. The ventilation exhaust from potentially contaminated areas in the auxiliary building is passed through charcoal adsorbers to reduce releases to the atmosphere upon a radiation monitor alarm.


B1.2.3 Secondary Systems

The gases removed from the secondary system by the air ejectors are discharged to the unit vent. If the secondary system contains activity, the steam generator blowdown may be either discharged directly to the RC system or through demineralizers to reduce activity levels.

Gland leak-off steam, which represents a minor source of activity, is routed to the gland condenser. The non-condensable gases are exhausted to the unit vent; the condensables are condensed and drained to the condensate storage tank.

Figure B1.0-2 is a schematic representation of the gaseous radwaste system at McGuire.

UNIT 1



* FUEL HANDLING AREA IS NORMALLY UNFILTERED. UPON A RADIATION ALARM BY EMF-42, THE EXHAUST WILL BE DIVERTED TO THE FILTER MODE.

** POTENTIALLY CONTAMINATED AREAS OF THE AUXILIARY BUILDING ARE NORMALLY UNFILTERED. UPON A RADIATION ALARM BY EMF-41, THE EXHAUST WILL BE DIVERTED TO THE FILTERED MODE.

FIGURE B1.0-2
McGUIRE NUCLEAR STATION
GASEOUS RADWASTE SYSTEM
PAGE 1 OF 3

REVISION 39
1/1/98

N89121A

UNIT 2





FIGURE B1.0-2
McGUIRE NUCLEAR STATION
GASEOUS RADWASTE SYSTEM
PAGE 2 OF 3


REVISION 39
1/1/98

N89121B


WASTE MANAGEMENT FACILITY



WASTE HANDLING AREA



UNIT 2 STAGING BUILDING



LEGEND
P = PREFILTER
A = CHARCOAL
ABSORBER

B2.0 RELEASE RATE CALCULATION

Generic release rate calculations are presented in Section 1.0; this methodology with McGuire-specific input data will be used to calculate release rates from McGuire Nuclear Station.

B2.1 LIQUID RELEASE RATE CALCULATIONS

There are three potential release points at McGuire. Two of these release points, the waste liquid effluent line and the containment ventilation unit condensate effluent line, discharge into the condenser cooling water system; the third release point, the Turbine Building sump, can either be discharged into the condenser cooling water system or into the conventional waste water treatment system.

B2.1.1 Waste Liquid Effluent Line

For releases made via the waste liquid effluent line, the following calculation shall be performed to determine discharge flow, in gpm:

$$f \leq F \div \left(\sigma \sum_i \frac{C_i}{(10 \times EC_i)} \right)$$

where:

f = the undiluted effluent flow, in gpm.

F = the dilution flow available depending on the number (1-8) of condenser cooling water (RC) pumps in service, in gpm.

where:

$F = (2.50E+05 \text{ gpm/pump}) \times (\text{Number of RC pumps in service})$

$\sigma = \text{The most restrictive recirculation factor at equilibrium, (dimensionless)}$

$$\sigma = 1 + \frac{Q_R}{Q_H} = 1 + \frac{3740}{2976} = 2.26$$

where:

Q_R = average dilution flow (3740 cfs)

Q_H = average flow past Cowans Ford Dam (2976 cfs)

C_i = the concentration of radionuclide, "i", in undiluted effluent as determined by laboratory analyses, in $\mu\text{Ci/ml}$.

EC_i = the concentration of radionuclide, "i", from 10CFR20, Appendix B, Table 2, Column 2. If radionuclide, "i", is a dissolved noble gas, the $EC_i = 1.00E-05 \mu\text{Ci/ml}$.

See section B3.1.1 on radiation monitoring alarm/trip setpoints.

B2.1.2 Containment Ventilation Unit Condensate Effluent Line

The containment ventilation unit condensate effluent line normally contains measurable activity above background and administrative controls have been implemented to assure that release limits are not exceeded; see section B3.1.2 on radiation monitoring alarm/trip setpoints.

B2.1.3 Conventional Waste Water Treatment System Effluent Line

The conventional waste water treatment system effluent is normally considered nonradioactive; that is, it is unlikely the effluent will contain measurable activity above background. It is assumed that no activity is present in the effluent until indicated by radiation monitoring measurements and by periodic analyses of the composite sample collected on that line. Radiation monitoring alarm/trip setpoints assure that release limits are not exceeded; see section B3.1.3 on radiation monitoring alarm/trip setpoints.

B2.1.4 Turbine Building Sump Discharge Line

Normally the discharge from the Turbine Building sump is considered non-radioactive; that is, it is unlikely the effluent will contain measurable activity above background, and will flow into the conventional waste water treatment system. It is assumed that no activity is present in the effluent until indicated by radiation monitoring measurements. If measurable activity is present in the effluent, sump discharge will be terminated and an alarm activated. At this time the discharge may be routed to the floor drain tank for processing or routed directly to the condenser cooling water (RC) flow; rather than the conventional waste water treatment system; administrative controls shall be implemented to assure that release limits are not exceeded; see section B3.1.4 on radiation monitoring alarm/setpoints.

B2.2 GASEOUS RELEASE RATE CALCULATIONS

The unit vent is the release point for waste gas decay tanks, containment building purges, the condenser air ejector, and auxiliary building ventilation. The condenser air ejector effluent is normally considered nonradioactive; that is, it is unlikely the effluent will contain measurable activity above background. It is assumed that no activity is present in the condenser air ejector effluent until indicated by radiation monitoring measurements and by analyses of periodic samples collected on that line. Radiation monitoring alarm/trip setpoints in conjunction with administrative controls assure that release limits are not exceeded; see section B3.0 on radiation monitoring setpoints.

The following calculations, when solved for flowrate, are the release rates for noble gases and for radioiodines, particulates and other radionuclides with half-lives greater than 8 days; the most conservative of release rates calculated in B2.2.1 and B2.2.2 shall limit the release rate for a single release point.

B2.2.1 Noble Gases

$$\sum_i (K_i [(\bar{X}/Q)\tilde{Q}_i]) < 500 \text{ mrem/yr, and}$$

$$\sum_i (L_i + 1.1 M_i) [(\bar{X}/Q)\tilde{Q}_i] < 3000 \text{ mrem/yr}$$

where the terms are defined below.

B2.2.2 Radioiodines, Particulates, and Others

$$\sum_i P_i [W \tilde{Q}_i] < 1500 \text{ mrem/yr}$$

where:

- K_i = The total body dose factor due to gamma emissions for each identified noble gas radionuclide, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1.
- L_i = The skin dose factor due to beta emissions for each identified noble gas radionuclide, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1.
- M_i = The air dose factor due to gamma emissions for each identified noble gas radionuclide, in mrad/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1 (unit conversion constant of 1.1 mrem/mrad converts air dose to skin dose).
- P_i = The dose parameter for radionuclides other than noble gases for the inhalation pathway, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ and for the food and ground plane pathways, in $\text{m}^2 \cdot (\text{mrem}/\text{yr})$ per $\mu\text{Ci}/\text{sec}$ from Table 1.2-2. The dose factors are based on the critical individual organ and most restrictive age group (child or infant).
- \tilde{Q}_i = The release rate of radionuclides, i , in gaseous effluent from all release points at the site, in $\mu\text{Ci}/\text{sec}$.
- \bar{X}/Q = $7.611\text{E}-5 \text{ sec}/\text{m}^3$. The highest calculated annual average relative concentration (dispersion parameter) for any area at or beyond the unrestricted area boundary. The location is the NNE sector @ 0.5 mile.
- W = The highest calculated annual average dispersion or deposition parameter for estimating the maximum dose rate to an individual from the total inhalation, food and ground plane pathways:
 - $W = 7.611\text{E}-5 \text{ sec}/\text{m}^3$, for the inhalation pathway. The location is the NNE sector @ 0.5 mile.
 - $W = 1.403\text{E}-7 \text{ 1}/\text{meter}^2$, for the food and ground plane pathways. The location is the NNE sector @ 0.5 mile.

$$\tilde{Q}_i = k_1 C_i f \div k_2 = 4.72E+02 C_i f$$

where:

C_i = the concentration of radionuclide, i , in undiluted gaseous effluent,
in $\mu\text{Ci/ml}$.

f = the undiluted effluent flow, in cfm

k_1 = conversion factor, $2.83E4 \text{ ml/ft}^3$

k_2 = conversion factor, $6E1 \text{ sec/min}$

B3.0 RADIATION MONITOR SETPOINTS

Using the generic calculations presented in Section 2.0, final effluent radiation monitoring setpoints are calculated for monitoring as required by the Technical Specifications.

All radiation monitors for McGuire are off-line except EMF-50 (Waste Gas System) which is in-line. These monitors alarm on low flow; the minimum flow alarm level for both the liquid monitors and the gas monitors is based on the manufacturer's recommendations. These monitors measure the activity in the liquid or gas volume exposed to the detector and are independent of flow rate if a minimum flow rate is assured.

Radiation monitoring setpoints calculated in the following sections are expressed in activity concentrations; in reality the monitor readout is in counts per minute. Station radiation monitor setpoint procedures which correlate concentration and counts per minute shall be based on the following relationship:

$$c = \frac{r}{2.22 \times 10^6 e V}$$

where:

c = the gross activity, in $\mu\text{Ci/ml}$
r = the count rate, in cpm
 2.22×10^6 = the disintegration per minute per μCi
e = the counting efficiency, cpm/dpm
V = the volume of fluid exposed to the detector, in ml.

B3.1 LIQUID RADIATION MONITORS

B3.1.1 Waste Liquid Effluent Line

As described in Section B2.1.1 on release rate calculations for the waste liquid effluent, the release is controlled by limiting the flow rate of effluent from the station. Although the release rate is flow rate controlled, the radiation monitor setpoint shall be set to terminate the release if the effluent activity should exceed that determined by laboratory analysis and that used to calculate the release rate. When releases are not being made, a radiation monitor setpoint shall be calculated to assure that release limits are not exceeded. A typical setpoint is calculated as follows:

$$c \leq \frac{10 \times EC \times F}{\sigma f} = 9.96\text{E-}3 \mu\text{Ci/ml}$$

where:

c = the gross activity in undiluted effluent, in $\mu\text{Ci/ml}$
f = the flow from the tank may vary from 0-120 gpm but, for this calculation, is assumed to be 100 gpm.

EC = 9.0E-07 μ Ci/ml, the EC for Cs-134, which is the lowest effluent concentration value for any detectable radionuclide that is not known to be absent from the liquid effluent. ***

σ = 2.26 (See Section B2.1.1)

F = the dilution flow is based on having only one condenser cooling water pump in service or 2.5E+5 gpm. Should the number of pumps in service increase, the setpoint may be recalculated.

B3.1.2 Containment Ventilation Unit Condensate Effluent Line

As described in Section B2.1.2 on release rate calculations for the containment ventilation unit condensate effluent, it is probable that the effluent will contain measurable activity above background. Since the tank contents can be discharged automatically, a maximum tank concentration, which also is the radiation monitor setpoint, is calculated to assure that release limits are not exceeded. A typical monitor setpoint and maximum tank concentration is calculated as follows:

$$c \leq \frac{10 \times EC \times F}{\sigma f} = 1.66E-2 \mu\text{Ci/ml}$$

where:

c = the gross activity in undiluted effluent, in μ Ci/ml

f = the flow from the tank may vary from 0-120 gpm but, for this calculation, is assumed to be the procedural limit of 60 gpm

EC = 9.0E-07 μ Ci/ml, the EC for Cs-134, which is the lowest effluent concentration value for any detectable radionuclide that is not known to be absent from the liquid effluent. ***

σ = 2.26 (See Section B2.1.1)

F = the dilution flow is based on having only one condenser cooling pump in service or 2.5E+5 gpm. Should the number of pumps in service increase, the setpoint may be recalculated.

The above calculation will determine the maximum setpoint for this release point; releases and/or setpoints may be administratively controlled to assure that release limits are not exceeded since more than one release source may be released to the condenser cooling water.

B3.1.3 Conventional Waste Water Treatment System Discharge Line

As described in Section B2.1.3 on release rate calculations for the conventional waste water treatment system effluent, the effluent is normally considered non-radioactive; that is, it is unlikely the effluent will contain measurable activity above background. It is assumed that no activity is present in the effluent until indicated by radiation monitoring and by routine analysis of the composite sample collected on that line. Since the system discharges automatically, the maximum system concentration, which also is the radiation monitor setpoint, is calculated so that release limits are not exceeded. A typical monitor setpoint and maximum effluent concentration is calculated as follows:

*** The justification for this assumption is provided in 10 CFR 20, Appendix B, Note 2. A review of past liquid effluent release data shows that Cs-134 has the lowest effluent concentration value for any detectable radionuclide in the effluent. An annual review of the effluent release data will be performed to assure that this assumption remains valid.

$$c \leq \frac{10 \times EC \times (F \times 0.1)}{\sigma f} = 2.63E-05 \text{ } \mu\text{Ci/ml}$$

where:

- c = the gross activity in undiluted effluent, in $\mu\text{Ci/ml}$
- f = the flow rate of undiluted effluent which may vary from 0-6700 gpm, but is assumed to be 6700 gpm
- EC = $9.0E-07 \text{ } \mu\text{Ci/ml}$, the EC for Cs-134, which is the lowest effluent concentration value for any detectable radionuclide that is not known to be absent from the liquid effluent ***
- F = the flow past Cowan's Ford Dam may vary from 80 to 50,000 cfs, but is conservatively estimated at 436 cfs ($1.96E+05 \text{ gpm}$), the historic minimum flow measured from Cowan's Ford Dam
- σ = 1 [The Conventional Waste Water System discharge line is located downstream of Cowan's Ford Dam and, therefore, has no reconcentration (recirculation) factor associated with it.]

B3.1.4 Turbine Building Sump Discharge Line to the Condenser Cooling Water (RC)

As described in Section B2.1.4 on release rate calculations for the Turbine Building sump effluent, it is possible that the effluent will contain measurable activity above background. Since the sump contents can be discharged automatically to the RC, a maximum sump concentration, which also is the radiation monitor setpoint, is calculated to assure that release limits are not exceeded. A typical monitor setpoint and maximum sump concentration is calculated as follows:

$$c \leq \frac{10 \times EC \times F}{\sigma f} = 4.98E-04 \text{ } \mu\text{Ci/ml}$$

where:

- c = the gross activity in undiluted effluent, in $\mu\text{Ci/ml}$
- f = the flow rate of undiluted effluent which may vary from 0-2000 gpm, but is assumed to be 2000 gpm (maximum pump capacity is 2000 gpm, but procedurally MNS restricts the maximum flow to 1340 gpm)
- EC = $9.0E-07 \text{ } \mu\text{Ci/ml}$, the EC for Cs-134, which is the lowest effluent concentration value for any detectable radionuclide that is not known to be absent from the liquid effluent ***
- σ = 2.26 (See Section B2.1.1)
- F = the dilution flow is based on having only one condenser cooling pump in service or $2.5E+5 \text{ gpm}$. Should the number (1-8) of pumps in service increase, the setpoint may be recalculated.

The above calculation will determine the maximum setpoint for this release point; releases and/or setpoints may be administratively controlled to assure that release limits are not exceeded since more than one release source may be released to the condenser cooling water.

*** The justification for this assumption is provided in 10 CFR 20, Appendix B, Note 2. A review of past liquid effluent release data shows that Cs-134 has the lowest effluent concentration value for any detectable radionuclide in the effluent. An annual review of the effluent release data will be performed to assure that this assumption remains valid.

B3.2 GAS MONITORS

The following equation shall be used to calculate final effluent noble gas radiation monitor setpoints based on Xe-133:

$$K(\overline{X/Q}) \tilde{Q}_i < 500 \quad (\text{See Section B2.2.1})$$

$$\tilde{Q}_i = 4.72E+2 C_i f \quad (\text{See Section B2.2.2})$$

$$C_i < 6.75E+01/f$$

where:

C_i = the gross activity in undiluted effluent, in $\mu\text{Ci/ml}$

f = the flow from the tank or building and varies for various release sources, in cfm

K = from Table 1.2-1 for Xe-133, $2.06E+2$ mrem/yr per $\mu\text{Ci/m}^3$

$\overline{X/Q}$ = $7.611E-5$ sec/ m^3 , as defined in Section B2.2.2.

Only typical example setpoint calculations are provided below. Station setpoints are calculated based on actual observed system flow rates.

B3.2.1 Unit Vent

As stated in Section B2.2, the unit vent is the release point for the waste gas system, containment purge ventilation system, the containment air release and addition system, the condenser air ejector, and auxiliary building ventilation. Since all of these releases are through the unit vent, the radiation monitor on the unit vent may be used to assure that station release limits are not exceeded.

For release from the containment air release and addition system and the containment purge ventilation system, a typical radiation monitor setpoint may be calculated as follows:

$$C_i < 6.75E+01/f = 2.92E-03 \mu\text{Ci/ml}$$

where:

$f = 23,100$ cfm (containment purge)

For release from the containment air release and addition system, the waste gas decay tanks, the condenser air ejectors, and the auxiliary building ventilation system, a typical radiation monitor setpoint may be calculated as follows:

$$C_i < 6.75E+01/f = 4.74E-04 \mu\text{Ci/ml}$$

where:

$f = 142,500$ cfm (auxiliary ventilation systems)

B3.2.2 Waste Management Facility (EMF-52)

Ventilation exhaust from the Waste Management Facility is not released through the unit vent and is considered a separate release point. This exhaust is normally considered non-radioactive; that is, it is possible but unlikely that the effluent will contain measurable activity above background. Since the exhaust is continuous, a maximum concentration of gases in the exhaust, which is also the radiation monitor setpoint, is calculated to assure compliance with release limits. A typical radiation monitor setpoint may be calculated as follows:

$$C < 6.75E+01/f = 8.04E-03$$

where:

$$f = 8,400 \text{ cfm}$$

B3.2.3 Waste Handling Area (EMF-53)

Ventilation exhaust from the Waste Handling Area is not released through the unit vent and is considered a separate release point. This exhaust is normally considered non-radioactive; that is, it is possible but unlikely that the effluent will contain measurable activity above background. Since the exhaust is continuous, a maximum concentration of gases in the exhaust, which is also the radiation monitor setpoint, is calculated to assure compliance with release limits. A typical radiation monitor setpoint may be calculated as follows:

$$C < 6.75E+01/f = 6.75E-04$$

where:

$$f = 100,000 \text{ cfm}$$

B3.2.4 Unit 2 Staging Building (2EMF-59)

Ventilation exhaust from the Unit 2 Staging Building is not released through the unit vent and is considered a separate release point. This exhaust is normally considered non-radioactive; that is, it is possible but unlikely that the effluent will contain measurable activity above background. Since the exhaust is continuous, a maximum concentration of gases in the exhaust, which is also the radiation monitor setpoint, is calculated to assure compliance with release limits. A typical radiation monitor setpoint may be calculated as follows:

$$C < 6.75E+01/f = 9.93E-03$$

where:

$$f = 6,800 \text{ cfm}$$

B4.0 DOSE CALCULATIONS

B4.1 FREQUENCY OF CALCULATIONS

Dose contributions to the maximum individual shall be calculated at least every 31 days, quarterly, and annually using the methodology in the generic information sections or the RETDAS program. One of these methods shall also be used for any special reports.

Station long-term historical and dose projection calculations are periodically performed to determine the station's status with respect to meeting annual ALARA goals specified in the McGuire Nuclear Station Selected Licensing Commitment Manual. Such calculations are used to verify that adequate margin remains during a report period to allow normal station and radwaste system operation, including anticipated operational occurrences, for the remainder of the report period without exceeding applicable goals. Station dose projections can be performed using generic methodology or the RETDAS computer code.

Fuel cycle dose calculations shall be performed annually or as required by special reports. Dose contributions shall be calculated using the methodology in the appropriate generic information sections or the RETDAS computer program.

B4.2 DOSE MODELS FOR MAXIMUM EXPOSED INDIVIDUAL

B4.2.1 Liquid Effluents

Generic methodology for calculating liquid pathway exposures to the maximum individual is presented in Section 3.1.1. McGuire site specific parameters to be used in the generic methodology are presented as follows:

- A_{aoi} = Tables B4.0-3 through B4.0-6
- F_η = f/(F + f) (0.029 default for projections)

where:

- F_η = Near field dilution factor, dimensionless
- f = McGuire average liquid radwaste flow, gpm (100 default for projections).
- F = McGuire average dilution flow for period of interest, gpm (3.3E+03 default for projections - based on 1985 - 1990 worst-case projections).

B4.2.2 Gaseous Effluents

B4.2.2.1 Noble Gases

Gamma Air and Beta Air Dose

Generic methodology for calculating noble gas airborne pathway gamma air (D_γ) and beta air (D_β) doses is presented in Section 3.1.2.1. McGuire site specific parameters to be used in the generic methodology are presented as follows:

$(\overline{X/Q}) = 7.611E-5 \text{ sec/m}^3$. The highest calculated annual average relative concentration for any area at or beyond the restricted area boundary. The location is the NNE sector @ 0.5 mile.

B4.2.2.2 Radioiodines, Particulates, and Other Radionuclides with $T_{1/2} > 8 \text{ Days}$

Generic methodology for calculating airborne pathway maximum organ (D_{MO}) exposures to the maximum individual is presented in Section 3.1.2.2. External exposure from deposited ground contamination and inhalation exposure pathways, and internal exposure from food pathways (i.e., vegetable, meat and milk) are analyzed at locations where site surveys have verified residents, vegetable gardens, meat producing animals, or cow/goat milk producing animals exist. Therefore, the location of the maximum individual may vary depending on the mixture and levels of radionuclides released during a period of time. Additionally, the critical (or limiting) age group and organ will vary based on the location (i.e., combination of dose pathways contributing dose) and mixture/level of radionuclide releases during the release period.

Performing calculations separately for all potential maximum locations, age groups and organs assures that a maximum location is identified, and that a conservative estimate is obtained for maximum offsite dose impact to any organ or age group. McGuire site specific meteorological dispersion (X/Q) and deposition (D/Q) parameters and applicable terrestrial/food pathways for the potential maximum locations to be analyzed using generic methodology are presented in Table B4.0-7.

B4.3 FUEL CYCLE CALCULATIONS

As discussed in Section 3.3.5, more than one nuclear power station site may contribute to the doses to be considered in accordance with 40CFR190. The fuel cycle dose assessments for McGuire Nuclear Station only include liquid and gaseous dose contributions from McGuire Nuclear Station since no other uranium fuel cycle facility contributes significantly to McGuire's maximum exposed individual. For this dose assessment, the total body and maximum organ dose contributions to the maximum exposed individual from McGuire's liquid and gaseous effluents are estimated using the following calculations:

$$D_{WB}(T) = D_{WB}(l) + D_{WB}(g)$$

$$D_{MO}(T) = D_{MO}(l) + D_{MO}(g)$$

where:

$D_{WB}(T)$ = Total estimated fuel cycle whole body dose commitment resulting from the combined liquid and gaseous effluents of McGuire during the calendar year of interest, in mrem.

$D_{MO}(T)$ = Total estimated fuel cycle maximum organ dose commitment resulting from the combined liquid and gaseous effluents of McGuire during the calendar year of interest, in mrem.

A fuel cycle dose calculation worksheet is provided in Figure B4.0-1.

B4.3.1 LIQUID EFFLUENTS

Liquid pathway dose estimates are calculated using generic methodology or the RETDAS computer program. The values for $D_{WB}(l)$ and $D_{MO}(l)$ liquid pathway dose contributions are calculated based on the methodology, values and assumptions presented in Section B4.2.1.

B4.3.2 GASEOUS EFFLUENTS

Total Body

The methodology for calculating noble gas airborne pathway whole body exposures to the maximum individual, $D_{WB}(g)$, is derived from Section 3.1.2.1 generic methodology for gamma air and beta air dose calculations as follows:

$$D_{WB}(g) = 3.17E-8 \sum_{i=1}^{\text{---}} K_i [(X/Q)Q_i] \text{ mrem/yr}$$

Generic methodology parameters K_i are described in Section 1.2.1. The McGuire site specific parameter X/Q value is $7.611E-5 \text{ sec/m}^3$ as described in Section B4.2.2.1 for McGuire gamma air and beta air dose calculations.

Maximum Organ

Airborne pathway maximum organ dose estimates are calculated using generic methodology or the RETDAS computer program. The maximum organ dose is established by calculating doses to all organs for each potential maximum offsite location identified in Table B4.0-7. A conservative estimate (i.e., overestimate) of the fuel cycle maximum organ dose is obtained by:

- 1) determining the locations with the highest exposure releases for each organ;
- 2) adding the highest exposure value for the airborne release to the same organ dose resulting from liquid releases; and
- 3) comparing values obtained when the liquid and airborne pathway components are added for all organs and age groups to determine the maximum (or limiting) organ and age group.

TABLE B4.0-1
 MCGUIRE NUCLEAR STATION
 (1 OF 2)

DISPERSION PARAMETER $(\overline{X/Q})$ FOR LONG TERM RELEASES > 500 HR/YR OR > 125 HR/QTR
 (SEC/M3)

SECTOR	DISTANCE TO THE CONTROL LOCATION, IN MILES									
	0-0.5	0.5-1.0	1.0-1.5	1.5-2.0	2.0-2.5	2.5-3.0	3.0-3.5	3.5-4.0	4.0-4.5	4.5-5.0
N		4.795E-05	1.220E-05	5.144E-06	2.879E-06	1.871E-06	1.333E-06	1.009E-06	7.985E-07	6.529E-07
NNE		7.611E-05	1.910E-05	8.103E-06	4.553E-06	2.968E-06	2.118E-06	1.607E-06	1.274E-06	1.043E-06
NE		5.330E-05	1.329E-05	5.662E-06	3.191E-06	2.084E-06	1.490E-06	1.132E-06	8.978E-07	7.357E-07
ENE		2.950E-05	7.487E-06	3.166E-06	1.776E-06	1.155E-06	8.237E-07	6.243E-07	4.943E-07	4.044E-07
E		1.742E-05	4.506E-06	1.884E-06	1.049E-06	6.787E-07	4.818E-07	3.638E-07	2.872E-07	2.344E-07
ESE		1.206E-05	3.143E-06	1.303E-06	7.209E-07	4.646E-07	3.288E-07	2.476E-07	1.951E-07	1.589E-07
SE		7.697E-06	2.011E-06	8.234E-07	4.521E-07	2.897E-07	2.040E-07	1.531E-07	1.202E-07	9.763E-08
SSE		6.179E-06	1.613E-06	6.504E-07	3.533E-07	2.246E-07	1.572E-07	1.173E-07	9.173E-08	7.421E-08
S		6.262E-06	1.581E-06	6.263E-07	3.363E-07	2.120E-07	1.475E-07	1.095E-07	8.525E-08	6.872E-08
SSW		7.346E-06	1.836E-06	7.234E-07	3.872E-07	2.435E-07	1.690E-07	1.253E-07	9.745E-08	7.847E-08
SW		8.606E-06	2.206E-06	8.483E-07	4.456E-07	2.759E-07	1.890E-07	1.386E-07	1.066E-07	8.508E-08
WSW		6.424E-06	1.671E-06	6.526E-07	3.466E-07	2.165E-07	1.493E-07	1.101E-07	8.519E-08	6.829E-08
W		3.523E-06	9.147E-07	3.697E-07	2.012E-07	1.281E-07	8.973E-08	6.705E-08	5.245E-08	4.247E-08
WNW		4.063E-06	1.071E-06	4.351E-07	2.376E-07	1.516E-07	1.064E-07	7.963E-08	6.238E-08	5.056E-08
NW		5.543E-06	1.448E-06	5.898E-07	3.226E-07	2.061E-07	1.448E-07	1.085E-07	8.504E-08	6.898E-08
NNW		1.053E-05	2.735E-06	1.131E-06	6.250E-07	4.024E-07	2.845E-07	2.141E-07	1.686E-07	1.372E-07

REVISION 39
 1/1/98

TABLE B4.0-1
(2 OF 2)

McGUIRE NUCLEAR STATION

The values presented in this table were generated by using the computer program XOQDOQ (NUREG/CR-2919) which implements NRC Regulatory Guide 1.111 (1977), and by using the following assumptions:

1. Data Collection Period, 1988 to 1992.
2. Ground Level Releases.
3. Open Terrain Recirculation Correction Factors.
4. No Decay, Undepleted
5. Vent and Building Parameters:

Release Height (meters) = 40.20	Rep. Wind Height (meters) = 10.0
Diameter (meters) = 0.00	Building Height (meters) = 43.1
Exit Velocity (meters) = 0.00	Bldg. Min. X-Sec. Area (sq. m.) = 1616.0
	Heat Emission Rate (cal/s) = 0.0

TABLE B4.0-2
 MCGUIRE NUCLEAR STATION
 (1 OF 2)

DEPOSITION PARAMETER ($\overline{D/Q}$) FOR LONG TERM RELEASES > 500 HR/YR OR > 125 HR/QTR
 (1/M2)

SECTOR	DISTANCE TO THE CONTROL LOCATION, IN MILES									
	0-0.5	0.5-1.0	1.0-1.5	1.5-2.0	2.0-2.5	2.5-3.0	3.0-3.5	3.5-4.0	4.0-4.5	4.5-5.0
N		1.031E-07	2.516E-08	9.037E-09	4.482E-09	2.639E-09	1.728E-09	1.216E-09	9.011E-10	6.944E-10
NNE		1.403E-07	3.424E-08	1.230E-08	6.100E-09	3.592E-09	2.352E-09	1.655E-09	1.226E-09	9.451E-10
NE		7.027E-08	1.715E-08	6.161E-09	3.055E-09	1.799E-09	1.178E-09	8.289E-10	6.143E-10	4.734E-10
ENE		3.893E-08	9.504E-09	3.414E-09	1.693E-09	9.969E-10	6.527E-10	4.593E-10	3.404E-10	2.623E-10
E		3.024E-08	7.381E-09	2.651E-09	1.315E-09	7.742E-10	5.069E-10	3.567E-10	2.643E-10	2.037E-10
ESE		3.299E-08	8.052E-09	2.892E-09	1.434E-09	8.445E-10	5.530E-10	3.891E-10	2.884E-10	2.222E-10
SE		2.733E-08	6.673E-09	2.397E-09	1.189E-09	6.999E-10	4.583E-10	3.225E-10	2.390E-10	1.842E-10
SSE		2.765E-08	6.749E-09	2.424E-09	1.202E-09	7.079E-10	4.635E-10	3.262E-10	2.417E-10	1.863E-10
S		4.360E-08	1.064E-08	3.823E-09	1.896E-09	1.116E-09	7.309E-10	5.143E-10	3.811E-10	2.937E-10
SSW		6.929E-08	1.691E-08	6.075E-09	3.013E-09	1.774E-09	1.162E-09	8.174E-10	6.058E-10	4.668E-10
SW		8.605E-08	2.100E-08	7.545E-09	3.742E-09	2.203E-09	1.443E-09	1.015E-09	7.523E-10	5.797E-10
WSW		4.562E-08	1.114E-08	4.000E-09	1.984E-09	1.168E-09	7.648E-10	5.382E-10	3.988E-10	3.073E-10
W		1.268E-08	3.094E-09	1.112E-09	5.512E-10	3.246E-10	2.125E-10	1.495E-10	1.108E-10	8.541E-11
WNW		1.213E-08	2.962E-09	1.064E-09	5.276E-10	3.107E-10	2.034E-10	1.431E-10	1.061E-10	8.175E-11
NW		1.785E-08	4.358E-09	1.565E-09	7.763E-10	4.571E-10	2.993E-10	2.106E-10	1.561E-10	1.203E-10
NNW		2.520E-08	6.152E-09	2.210E-09	1.096E-09	6.453E-10	4.225E-10	2.973E-10	2.203E-10	1.698E-10

TABLE B4.0-2
(2 OF 2)

McGUIRE NUCLEAR STATION

The values presented in this table were generated by using the computer program XOQDOQ (NUREG/CR-2919) which implements NRC Regulatory Guide 1.111 (1977), and by using the following assumptions:

1. Data Collection Period, 1988 to 1992.
2. Ground Level Releases.
3. Open Terrain Recirculation Correction Factors.
4. No Decay, Undepleted
5. Vent and Building Parameters:

Release Height (meters) = 40.20	Rep. Wind Height (meters) = 10.0
Diameter (meters) = 0.00	Building Height (meters) = 43.1
Exit Velocity (meters) = 0.00	Bldg. Min. X-Sec. Area (sq. m.) = 1616.0
	Heat Emission Rate (cal/s) = 0.0

TABLE B4.0-3
(1 OF 2)

MCGUIRE NUCLEAR STATION
LIQUID EFFLUENT DOSE - ADULT PARAMETERS
A(I) MREM/HR PER UCI/ML

RADIONUCLIDE		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
1	H 3	0.0	1.15E+01	1.15E+01	1.15E+01	1.15E+01	1.15E+01	1.15E+01
11	NA 24	4.07E+02	4.07E+02	4.07E+02	4.07E+02	4.07E+02	4.07E+02	4.07E+02
24	CR 51	0.0	0.0	3.08E+00	1.84E+00	6.79E-01	4.09E+00	7.75E+02
25	MN 54	0.0	1.03E+04	1.97E+03	0.0	3.08E+03	0.0	3.17E+04
25	MN 56	0.0	8.54E-01	1.51E-01	0.0	1.08E+00	0.0	2.73E+01
26	FE 55	1.78E+03	1.23E+03	2.86E+02	0.0	0.0	6.84E+02	7.04E+02
26	FE 59	2.76E+03	6.49E+03	2.49E+03	0.0	0.0	1.81E+03	2.16E+04
27	CO 58	0.0	2.77E+02	6.22E+02	0.0	0.0	0.0	5.62E+03
27	CO 60	0.0	8.03E+02	1.77E+03	0.0	0.0	0.0	1.51E+04
28	NI 63	8.40E+04	5.82E+03	2.82E+03	0.0	0.0	0.0	1.21E+03
28	NI 65	2.43E+00	3.16E-01	1.44E-01	0.0	0.0	0.0	8.01E+00
29	CU 64	0.0	1.06E+01	4.97E+00	0.0	2.67E+01	0.0	9.03E+02
30	ZN 65	5.27E+04	1.68E+05	7.58E+04	0.0	1.12E+05	0.0	1.06E+05
30	ZN 69	1.71E-04	3.26E-04	2.27E-05	0.0	2.12E-04	0.0	4.90E-05
35	BR 83	0.0	0.0	2.17E-01	0.0	0.0	0.0	3.13E-01
35	BR 85	0.0	0.0	5.52E-77	0.0	0.0	0.0	0.0
37	RB 86	0.0	2.22E+05	1.04E+05	0.0	0.0	0.0	4.38E+04
37	RB 88	0.0	4.61E-12	2.45E-12	0.0	0.0	0.0	6.37E-23
37	RB 89	0.0	2.64E-14	1.86E-14	0.0	0.0	0.0	1.53E-27
38	SR 89	8.14E+04	0.0	2.34E+03	0.0	0.0	0.0	1.31E+04
38	SR 90	1.03E+06	0.0	2.75E+05	0.0	0.0	0.0	5.85E+04
38	SR 91	4.07E+02	0.0	1.64E+01	0.0	0.0	0.0	1.94E+03
38	SR 92	1.13E+01	0.0	4.87E-01	0.0	0.0	0.0	2.23E+02
39	Y 90	1.89E+00	0.0	5.07E-02	0.0	0.0	0.0	2.00E+04
39	Y 91M	4.05E-07	0.0	1.57E-08	0.0	0.0	0.0	1.19E-06
39	Y 91	3.35E+01	0.0	8.97E-01	0.0	0.0	0.0	1.85E+04
39	Y 92	9.58E-03	0.0	2.80E-04	0.0	0.0	0.0	1.68E+02
39	Y 93	1.93E-01	0.0	5.32E-03	0.0	0.0	0.0	6.11E+03
40	ZR 95	3.71E+00	1.19E+00	8.05E-01	0.0	1.87E+00	0.0	3.77E+03
40	ZR 97	1.19E-01	2.40E-02	1.10E-02	0.0	3.62E-02	0.0	7.43E+03
41	NB 95	9.91E+02	5.51E+02	2.96E+02	0.0	5.45E+02	0.0	3.34E+06
42	MO 99	0.0	5.80E+02	1.10E+02	0.0	1.31E+03	0.0	1.34E+03
43	TC 99M	7.76E-03	2.19E-02	2.79E-01	0.0	3.33E-01	1.07E-02	1.30E+01
43	TC 101	1.42E-17	2.05E-17	2.01E-16	0.0	3.69E-16	1.05E-17	6.17E-29
44	RU 103	2.91E+01	0.0	1.25E+01	0.0	1.11E+02	0.0	3.39E+03
44	RU 105	2.67E-01	0.0	1.06E-01	0.0	3.45E+00	0.0	1.63E+02
44	RU 106	4.37E+02	0.0	5.52E+01	0.0	8.43E+02	0.0	2.83E+04
47	AG 100M	1.87E+01	1.73E+01	1.03E+01	0.0	3.41E+01	0.0	7.07E+03
52	TE 125M	6.01E+03	2.18E+03	8.05E+02	1.81E+03	2.44E+04	0.0	2.40E+04
52	TE 127M	1.53E+04	5.46E+03	1.86E+03	3.90E+03	6.20E+04	0.0	5.12E+04
52	TE 127	4.49E+01	1.61E+01	9.71E+00	3.33E+01	1.83E+02	0.0	3.54E+03
52	TE 129M	2.56E+04	9.54E+03	4.05E+03	8.78E+03	1.07E+05	0.0	1.29E+05
52	TE 129	2.57E-03	9.66E-04	6.26E-04	1.97E-03	1.08E-02	0.0	1.94E-03
52	TE 131M	2.29E+03	1.12E+03	9.32E+02	1.77E+03	1.13E+04	0.0	1.11E+05
52	TE 131	4.63E-09	1.94E-09	1.46E-09	3.81E-09	2.03E-08	0.0	6.56E-10
52	TE 132	4.65E+03	3.01E+03	2.82E+03	3.32E+03	2.90E+04	0.0	1.42E+05
53	I 130	5.63E+01	1.66E+02	6.56E+01	1.41E+04	2.59E+02	0.0	1.43E+02
53	I 131	7.28E+02	1.04E+03	5.96E+02	3.41E+05	1.78E+03	0.0	2.75E+02
53	I 132	5.84E-01	1.56E+00	5.47E-01	5.47E+01	2.49E+00	0.0	2.94E-01
53	I 133	1.52E+02	2.64E+02	8.04E+01	3.88E+04	4.60E+02	0.0	2.37E+02
53	I 135	1.60E+01	4.20E+01	1.55E+01	2.77E+03	6.74E+01	0.0	4.74E+01
55	CS 134	6.79E+05	1.62E+06	1.32E+06	0.0	5.23E+05	1.74E+05	2.83E+04
55	CS 136	6.75E+04	2.66E+05	1.92E+05	0.0	1.48E+05	2.03E+04	3.03E+04
55	CS 137	8.71E+05	1.19E+06	7.80E+05	0.0	4.04E+05	1.34E+05	2.31E+04
55	CS 138	1.11E-06	2.19E-06	1.09E-06	0.0	1.61E-06	1.09E-07	9.36E-12
56	BA 139	2.40E-02	1.71E-05	7.04E-04	0.0	1.60E-05	9.72E-06	4.26E-02
56	BA 140	2.49E+03	3.13E+00	1.63E+02	0.0	1.06E+00	1.79E+00	5.12E+03
56	BA 141	6.86E-12	5.19E-15	2.32E-13	0.0	4.82E-15	2.94E-15	3.23E-21
56	BA 142	1.22E-20	1.25E-23	7.68E-22	0.0	1.06E-23	7.11E-24	1.72E-38
57	LA 140	4.37E-01	2.20E-01	5.82E-02	0.0	0.0	0.0	1.62E+04
57	LA 142	6.10E-05	2.77E-05	6.91E-06	0.0	0.0	0.0	2.02E-01
58	CE 141	1.02E+00	6.90E-01	7.83E-02	0.0	3.21E-01	0.0	2.64E+03
58	CE 143	1.04E-01	1.04E+02	1.15E-02	0.0	4.56E-02	0.0	3.87E+03
58	CE 144	5.37E+01	2.25E+01	2.89E+00	0.0	1.33E+01	0.0	1.82E+04
59	PR 143	2.12E+00	8.51E-01	1.05E-01	0.0	4.92E-01	0.0	9.30E+03
59	PR 144	8.87E-16	3.68E-16	4.51E-17	0.0	2.08E-16	0.0	1.28E-22
60	ND 147	1.44E+00	1.66E+00	9.95E-02	0.0	9.72E-01	0.0	7.98E+03
74	W 187	3.41E+02	2.85E+02	9.97E+01	0.0	0.0	0.0	9.34E+04
93	NP 239	1.56E-01	1.53E-02	8.44E-03	0.0	4.78E-02	0.0	3.14E+03

Table B4.0-3
(2 of 2)

McGuire Nuclear Station
Liquid Effluent Dose - Adult Parameters
A_{aoi} mrem/hr per μCi/ml

From Generic Section 3.1.1:

A_{aoi} = the site related ingestion dose commitment factor for an individual of age group, "a", to organ, "o", for each identified principal gamma and beta emitter, "i", in mrem/hr per μCi/ml

$$A_{aoi} = 1.14E+05 (U_{aw}\sigma_w/D_w \exp(-\lambda_i t_w) + U_{af}\sigma_f BF_i \exp(-\lambda_i t_f)) DF_{aoi}$$

where:

$$1.14E+05 = 10^6 \text{ pCi}/\mu\text{Ci} \times 10^3 \text{ ml/kg} \div 8760 \text{ hr/yr}$$

U_{aw} = Water consumption by age group, l/yr

infant	330
child	510
teen	510
adult	730

σ_w, σ_f = Recirculation factors at equilibrium for the water and fish pathways respectively; these factors account for the fraction of discharged water reused by the station

σ_w = 1.26 σ_f = 2.26

D_w = Dilution factor from the near field area to the potable water intake = 1.0

U_{af} = Fish consumption by age group, kg/yr

infant	---
child	6.9
teen	16
adult	21

BF_i = Bioaccumulation factor for radionuclide, "i", in fish, pCi/kg per pCi/l, from Table 3.1-1

DF_{aoi} = Dose conversion factor for age group, "a", in organ, "o", for radionuclide, "i", in mrem/pCi, from Tables 3.1-2, 3.1-3, 3.1-4, and 3.1-5, respectively

λ_i = radiological decay constant for isotope, i, in 1/hr

t_w, t_f = transport time for the drinking water and fish pathways, hr

t_w = 12 hours t_f = 24 hours

Sample Calculation for Adult, I-131, Thyroid:

$$A(a,thy,I-131) = 1.14E5 (730*1.26/1.0*\exp(-3.59E-3*12) + 21*2.26*15*\exp(-3.59E-3*24)) 1.95E-3 = 3.41E5 \text{ mr/hr per } \mu\text{Ci/ml}$$

TABLE B4.0-4
(1 OF 2)

MCGUIRE NUCLEAR STATION
LIQUID EFFLUENT DOSE - TEEN PARAMETERS
A(I) MREM/HR PER UCI/ML

RADIONUCLIDE		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
1	H 3	0.0	8.16E+00	8.16E+00	8.16E+00	8.16E+00	8.16E+00	8.16E+00
11	NA 24	4.11E+02	4.11E+02	4.11E+02	4.11E+02	4.11E+02	4.11E+02	4.11E+02
24	CR 51	0.0	0.0	3.16E+00	1.75E+00	6.91E-01	4.50E+00	5.30E+02
25	MN 54	0.0	1.01E+04	2.01E+03	0.0	3.02E+03	0.0	2.08E+04
25	MN 56	0.0	8.53E-01	1.52E-01	0.0	1.08E+00	0.0	5.61E+01
26	FE 55	1.83E+03	1.30E+03	3.03E+02	0.0	0.0	8.25E+02	5.63E+02
26	FE 59	2.81E+03	6.56E+03	2.53E+03	0.0	0.0	2.07E+03	1.55E+04
27	CO 58	0.0	2.69E+02	6.20E+02	0.0	0.0	0.0	3.71E+03
27	CO 60	0.0	7.85E+02	1.77E+03	0.0	0.0	0.0	1.02E+04
28	NI 63	8.59E+04	6.07E+03	2.91E+03	0.0	0.0	0.0	9.66E+02
28	NI 65	2.44E+00	3.12E-01	1.42E-01	0.0	0.0	0.0	1.69E+01
29	CU 64	0.0	1.07E+01	5.05E+00	0.0	2.72E+01	0.0	8.33E+02
30	ZN 65	4.78E+04	1.66E+05	7.74E+04	0.0	1.06E+05	0.0	7.03E+04
30	ZN 69	1.70E-04	3.24E-04	2.27E-05	0.0	2.12E-04	0.0	5.98E-04
35	BR 83	0.0	0.0	2.25E-01	0.0	0.0	0.0	0.0
35	BR 85	0.0	0.0	5.50E-77	0.0	0.0	0.0	0.0
37	RB 86	0.0	2.39E+05	1.12E+05	0.0	0.0	0.0	3.54E+04
37	RB 88	0.0	4.54E-12	2.42E-12	0.0	0.0	0.0	3.89E-19
37	RB 89	0.0	2.53E-14	1.79E-14	0.0	0.0	0.0	3.87E-23
38	SR 89	8.57E+04	0.0	2.45E+03	0.0	0.0	0.0	1.02E+04
38	SR 90	8.82E+05	0.0	2.36E+05	0.0	0.0	0.0	4.59E+04
38	SR 91	4.19E+02	0.0	1.67E+01	0.0	0.0	0.0	1.90E+03
38	SR 92	1.12E+01	0.0	4.78E-01	0.0	0.0	0.0	2.86E+02
39	Y 90	1.97E+00	0.0	5.31E-02	0.0	0.0	0.0	1.63E+04
39	Y 91M	4.02E-07	0.0	1.54E-08	0.0	0.0	0.0	1.90E-05
39	Y 91	3.51E+01	0.0	9.41E-01	0.0	0.0	0.0	1.44E+04
39	Y 92	9.68E-03	0.0	2.80E-04	0.0	0.0	0.0	2.66E+02
39	Y 93	1.99E-01	0.0	5.45E-03	0.0	0.0	0.0	6.07E+03
40	ZR 95	3.56E+00	1.12E+00	7.72E-01	0.0	1.65E+00	0.0	2.59E+03
40	ZR 97	1.18E-01	2.34E-02	1.08E-02	0.0	3.54E-02	0.0	6.33E+03
41	NB 95	9.97E+02	5.53E+02	3.05E+02	0.0	5.36E+02	0.0	2.37E+06
42	MO 99	0.0	5.83E+02	1.11E+02	0.0	1.33E+03	0.0	1.04E+03
43	TC 99M	7.40E-03	2.06E-02	2.67E-01	0.0	3.07E-01	1.15E-02	1.35E+01
43	TC 101	1.41E-17	2.01E-17	1.97E-16	0.0	3.63E-16	1.22E-17	3.43E-24
44	RU 103	2.88E+01	0.0	1.23E+01	0.0	1.02E+02	0.0	2.41E+03
44	RU 105	2.66E-01	0.0	1.03E-01	0.0	3.36E+00	0.0	2.15E+02
44	RU 106	4.48E+02	0.0	5.65E+01	0.0	8.64E+02	0.0	2.15E+04
47	AG 100M	1.69E+01	1.60E+01	9.75E+00	0.0	3.06E+01	0.0	4.50E+03
52	TE 125M	6.52E+03	2.35E+03	8.72E+02	1.82E+03	0.0	0.0	1.92E+04
52	TE 127M	1.65E+04	5.87E+03	1.97E+03	3.94E+03	6.71E+04	0.0	4.12E+04
52	TE 127	4.87E+01	1.73E+01	1.05E+01	3.36E+01	1.97E+02	0.0	3.76E+03
52	TE 129M	2.75E+04	1.02E+04	4.35E+03	8.88E+03	1.15E+05	0.0	1.03E+05
52	TE 129	2.57E-03	9.56E-04	6.24E-04	1.83E-03	1.08E-02	0.0	1.40E-02
52	TE 131M	2.45E+03	1.17E+03	9.78E+02	1.76E+03	1.22E+04	0.0	9.41E+04
52	TE 131	4.59E-09	1.89E-09	1.43E-09	3.53E-09	2.01E-08	0.0	3.76E-10
52	TE 132	4.88E+03	3.09E+03	2.91E+03	3.26E+03	2.97E+04	0.0	9.79E+04
53	I 130	5.50E+01	1.59E+02	6.36E+01	1.30E+04	2.45E+02	0.0	1.22E+02
53	I 131	7.42E+02	1.04E+03	5.58E+02	3.03E+05	1.79E+03	0.0	2.06E+02
53	I 132	5.62E-01	1.47E+00	5.28E-01	4.96E+01	2.32E+00	0.0	6.41E-01
53	I 133	1.55E+02	2.62E+02	8.00E+01	3.66E+04	4.60E+02	0.0	1.98E+02
53	I 135	1.57E+01	4.04E+01	1.50E+01	2.60E+03	6.38E+01	0.0	4.47E+01
55	CS 134	6.96E+05	1.64E+06	7.60E+05	0.0	5.20E+05	1.99E+05	2.04E+04
55	CS 136	6.78E+04	2.67E+05	1.79E+05	0.0	1.45E+05	2.29E+04	2.15E+04
55	CS 137	9.32E+05	1.24E+06	4.32E+05	0.0	4.22E+05	1.64E+05	1.76E+04
55	CS 138	1.09E-06	2.10E-06	1.05E-06	0.0	1.55E-06	1.80E-07	9.51E-10
56	BA 139	2.41E-02	1.69E-05	7.01E-04	0.0	1.60E-05	1.17E-05	2.15E-01
56	BA 140	2.47E+03	3.02E+00	1.59E+02	0.0	1.03E+00	2.03E+00	3.81E+03
56	BA 141	6.83E-12	5.10E-15	2.28E-13	0.0	4.73E-15	3.49E-15	1.46E-17
56	BA 142	1.20E-20	1.20E-23	7.37E-22	0.0	1.01E-23	7.97E-24	3.67E-32
57	LA 140	4.45E-01	2.18E-01	5.81E-02	0.0	0.0	0.0	1.25E+04
57	LA 142	5.96E-05	2.65E-05	6.59E-06	0.0	0.0	0.0	8.06E-01
58	CE 141	1.02E+00	6.79E-01	7.80E-02	0.0	3.20E-01	0.0	1.94E+03
58	CE 143	1.40E-01	1.02E+02	1.14E-02	0.0	4.56E-02	0.0	3.06E+03
58	CE 144	5.38E+01	2.23E+01	2.89E+00	0.0	1.33E+01	0.0	1.35E+04
59	PR 143	2.22E+00	8.86E-01	1.10E-01	0.0	5.15E-01	0.0	7.30E+03
59	PR 144	8.85E-16	3.62E-16	4.49E-17	0.0	2.08E-16	0.0	9.75E-19
60	ND 147	1.57E+00	1.71E+00	1.03E-01	0.0	1.01E+00	0.0	6.18E+03
74	W 187	3.68E+02	3.00E+02	1.05E+02	0.0	0.0	0.0	8.11E+04
93	NP 239	1.65E-01	1.56E-02	8.66E-03	0.0	4.90E-02	0.0	2.51E+03

Table B4.0-4
(2 of 2)

McGuire Nuclear Station
Liquid Effluent Dose - Teen Parameters
 A_{aoi} mrem/hr per $\mu\text{Ci/ml}$

From Generic Section 3.1.1:

A_{aoi} = the site related ingestion dose commitment factor for an individual of age group, "a", to organ, "o", for each identified principal gamma and beta emitter, "i", in mrem/hr per $\mu\text{Ci/ml}$

$$A_{aoi} = 1.14E+05 (U_{aw}\sigma_w/D_w \exp(-\lambda_i t_w) + U_{af}\sigma_f BF_i \exp(-\lambda_i t_f)) DF_{aoi}$$

where:

$$1.14E+05 = 10^6 \text{ pCi}/\mu\text{Ci} \times 10^3 \text{ ml/kg} \div 8760 \text{ hr/yr}$$

U_{aw} = Water consumption by age group, l/yr

infant	330
child	510
teen	510
adult	730

σ_w, σ_f = Recirculation factors at equilibrium for the water and fish pathways respectively; these factors account for the fraction of discharged water reused by the station
 $\sigma_w = 1.26$ $\sigma_f = 2.26$

D_w = Dilution factor from the near field area to the potable water intake = 1.0

U_{af} = Fish consumption by age group, kg/yr

infant	---
child	6.9
teen	16
adult	21

BF_i = Bioaccumulation factor for radionuclide, "i", in fish, pCi/kg per pCi/l, from Table 3.1-1

DF_{aoi} = Dose conversion factor for age group, "a", in organ, "o", for radionuclide, "i", in mrem/pCi, from Tables 3.1-2, 3.1-3, 3.1-4, and 3.1-5, respectively

λ_i = radiological decay constant for isotope, i, in 1/hr

t_w, t_f = transport time for the drinking water and fish pathways, hr
 $t_w = 12$ hours $t_f = 24$ hours

Sample Calculation for Teen, I-131, Thyroid:

$$A(t, \text{thy}, \text{I-131}) = 1.14E5 (510 \cdot 1.26 / 1.0 \cdot \exp(-3.59E-3 \cdot 12) + 16 \cdot 2.26 \cdot 15 \cdot \exp(-3.59E-3 \cdot 24)) \cdot 2.39E-3 = 3.03E5 \text{ mr/hr per } \mu\text{Ci/ml}$$

TABLE B4.0-5
(1 OF 2)

MCGUIRE NUCLEAR STATION
LIQUID EFFLUENT DOSE - CHILD PARAMETERS
A(I) MREM/HR PER UCI/ML

RADIONUCLIDE		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
1	H 3	0.0	1.52E+01	1.52E+01	1.52E+01	1.52E+01	1.52E+01	1.52E+01
11	NA 24	5.86E+02	5.86E+02	5.86E+02	5.86E+02	5.86E+02	5.86E+02	5.86E+02
24	CR 51	0.0	0.0	3.73E+00	2.07E+00	5.66E-01	3.78E+00	1.98E+02
25	MN 54	0.0	8.37E+03	2.23E+03	0.0	2.35E+03	0.0	7.03E+03
25	MN 56	0.0	1.32E+00	2.99E-01	0.0	1.60E+00	0.0	1.92E+02
26	FE 55	2.89E+03	1.53E+03	4.74E+02	0.0	0.0	8.66E+02	2.83E+02
26	FE 59	4.09E+03	6.61E+03	3.29E+03	0.0	0.0	1.92E+03	6.89E+03
27	CO 58	0.0	2.90E+02	8.87E+02	0.0	0.0	0.0	1.69E+03
27	CO 60	0.0	8.57E+02	2.53E+03	0.0	0.0	0.0	4.75E+03
28	NI 63	1.35E+05	7.23E+03	4.59E+03	0.0	0.0	0.0	4.87E+02
28	NI 65	6.53E+00	6.15E-01	3.59E-01	0.0	0.0	0.0	7.53E+01
29	CU 64	0.0	1.52E+01	9.16E+00	0.0	3.66E+01	0.0	7.12E+02
30	ZN 65	4.96E+04	1.32E+05	8.21E+04	0.0	8.32E+04	0.0	2.32E+04
30	ZN 69	5.02E-04	7.26E-04	6.71E-05	0.0	4.40E-04	0.0	4.58E-02
35	BR 83	0.0	0.0	5.09E-01	0.0	0.0	0.0	0.0
35	BR 85	0.0	0.0	1.64E-76	0.0	0.0	0.0	0.0
37	RB 86	0.0	2.34E+05	1.44E+05	0.0	0.0	0.0	1.51E+04
37	RB 88	0.0	1.01E-11	7.03E-12	0.0	0.0	0.0	4.96E-13
37	RB 89	0.0	5.38E-14	4.78E-14	0.0	0.0	0.0	4.69E-16
38	SR 89	1.65E+05	0.0	4.73E+03	0.0	0.0	0.0	6.41E+03
38	SR 90	1.43E+06	0.0	3.84E+05	0.0	0.0	0.0	2.90E+04
38	SR 91	9.53E+02	0.0	3.60E+01	0.0	0.0	0.0	2.10E+03
38	SR 92	3.18E+01	0.0	1.28E+00	0.0	0.0	0.0	6.03E+02
39	Y 90	4.05E+00	0.0	1.09E-01	0.0	0.0	0.0	1.15E+04
39	Y 91M	1.19E-06	0.0	4.33E-08	0.0	0.0	0.0	2.33E-03
39	Y 91	7.03E+01	0.0	1.88E+00	0.0	0.0	0.0	9.36E+03
39	Y 92	2.68E-02	0.0	7.68E-04	0.0	0.0	0.0	7.76E+02
39	Y 93	4.63E-01	0.0	1.27E-02	0.0	0.0	0.0	6.91E+03
40	ZR 95	9.13E+00	2.01E+00	1.79E+00	0.0	2.87E+00	0.0	2.09E+03
40	ZR 97	3.28E-01	4.74E-02	2.80E-02	0.0	6.81E-02	0.0	7.18E+03
41	NB 95	1.18E+03	4.59E+02	3.28E+02	0.0	4.31E+02	0.0	8.48E+05
42	MO 99	0.0	1.04E+03	2.58E+02	0.0	2.23E+03	0.0	8.62E+02
43	TC 99M	1.85E-02	3.63E-02	6.02E-01	0.0	5.28E-01	1.84E-02	2.07E+01
43	TC 101	4.19E-17	4.39E-17	5.56E-16	0.0	7.48E-16	2.32E-17	1.39E-16
44	RU 103	6.58E+01	0.0	2.53E+01	0.0	1.66E+02	0.0	1.70E+03
44	RU 105	7.52E-01	0.0	2.73E-01	0.0	6.61E+00	0.0	4.91E+02
44	RU 106	1.06E+03	0.0	1.33E+02	0.0	1.44E+03	0.0	1.65E+04
47	AG 100M	4.16E+01	2.81E+01	2.25E+01	0.0	5.24E+01	0.0	3.34E+03
52	TE 125M	8.84E+03	2.40E+03	1.18E+03	2.48E+03	0.0	0.0	8.53E+03
52	TE 127M	2.25E+04	6.07E+03	2.67E+03	5.39E+03	6.42E+04	0.0	1.82E+04
52	TE 127	7.07E+01	1.91E+01	1.52E+01	4.89E+01	2.01E+02	0.0	2.76E+03
52	TE 129M	3.75E+04	1.05E+04	5.81E+03	1.21E+04	1.10E+05	0.0	4.57E+04
52	TE 129	7.60E-03	2.12E-03	1.80E-03	5.42E-03	2.22E-02	0.0	4.73E-01
52	TE 131M	3.34E+03	1.15E+03	1.23E+03	2.37E+03	1.12E+04	0.0	4.68E+04
52	TE 131	1.36E-08	4.16E-09	4.06E-09	1.04E-08	4.13E-08	0.0	7.17E-08
52	TE 132	6.47E+03	2.86E+03	3.46E+03	4.17E+03	2.66E+04	0.0	2.88E+04
53	I 130	1.29E+02	2.61E+02	1.35E+02	2.88E+04	3.90E+02	0.0	1.22E+02
53	I 131	1.63E+03	1.64E+03	9.30E+02	5.41E+05	2.69E+03	0.0	1.46E+02
53	I 132	1.59E+00	2.92E+00	1.34E+00	1.36E+02	4.48E+00	0.0	3.44E+00
53	I 133	3.62E+02	4.47E+02	1.69E+02	8.31E+04	7.46E+02	0.0	1.80E+02
53	I 135	4.01E+01	7.21E+01	3.41E+01	6.39E+03	1.11E+02	0.0	5.49E+01
55	CS 134	8.48E+05	1.39E+06	2.94E+05	0.0	4.31E+05	1.55E+05	7.50E+03
55	CS 136	8.09E+04	2.22E+05	1.44E+05	0.0	1.18E+05	1.77E+04	7.82E+03
55	CS 137	1.19E+06	1.14E+06	1.68E+05	0.0	3.70E+05	1.33E+05	7.11E+03
55	CS 138	3.21E-06	4.46E-06	2.83E-06	0.0	3.14E-06	3.38E-07	2.05E-06
56	BA 139	7.17E-02	3.83E-05	2.08E-03	0.0	3.34E-05	2.25E-05	4.14E+00
56	BA 140	6.48E+03	5.68E+00	3.78E+02	0.0	1.85E+00	3.39E+00	3.29E+03
56	BA 141	2.04E-11	1.14E-14	6.62E-13	0.0	9.86E-15	6.70E-14	1.16E-11
56	BA 142	3.50E-20	2.52E-23	1.95E-21	0.0	2.04E-23	1.48E-23	4.56E-22
57	LA 140	8.99E-01	3.14E-01	1.06E-01	0.0	0.0	0.0	8.76E+03
57	LA 142	1.74E-04	5.54E-05	1.74E-05	0.0	0.0	0.0	1.10E+01
58	CE 141	2.95E+00	1.47E+00	2.18E-01	0.0	6.44E-01	0.0	1.83E+03
58	CE 143	4.06E-01	2.20E+02	3.19E-02	0.0	9.23E-02	0.0	3.22E+03
58	CE 144	1.56E+02	4.89E+01	8.32E+00	0.0	2.71E+01	0.0	1.27E+04
59	PR 143	4.47E+00	1.34E+00	2.22E-01	0.0	7.26E-01	0.0	4.82E+03
59	PR 144	2.65E-15	8.21E-16	1.34E-16	0.0	4.34E-16	0.0	1.77E-12
60	ND 147	3.15E+00	2.55E+00	1.97E-01	0.0	1.40E+00	0.0	4.04E+03
74	W 187	4.79E+02	2.83E+02	1.27E+02	0.0	0.0	0.0	3.98E+04
93	NP 239	4.02E-01	2.88E-02	2.03E-02	0.0	8.34E-02	0.0	2.13E+03

Table B4.0-5
(2 of 2)

McGuire Nuclear Station
Liquid Effluent Dose - Child Parameters
 A_{aoi} mrem/hr per $\mu\text{Ci/ml}$

From Generic Section 3.1.1:

A_{aoi} = the site related ingestion dose commitment factor for an individual of age group, "a", to organ, "o", for each identified principal gamma and beta emitter, "i", in mrem/hr per $\mu\text{Ci/ml}$

$$A_{aoi} = 1.14E+05 (U_{aw}\sigma_w/D_w \exp(-\lambda_i t_w) + U_{af}\sigma_f BF_i \exp(-\lambda_i t_f)) DF_{aoi}$$

where:

$$1.14E+05 = 10^6 \text{ pCi}/\mu\text{Ci} \times 10^3 \text{ ml/kg} \div 8760 \text{ hr/yr}$$

U_{aw} = Water consumption by age group, l/yr

infant	330
child	510
teen	510
adult	730

σ_w, σ_f = Recirculation factors at equilibrium for the water and fish pathways respectively; these factors account for the fraction of discharged water reused by the station

$\sigma_w = 1.26$ $\sigma_f = 2.26$

D_w = Dilution factor from the near field area to the potable water intake = 1.0

U_{af} = Fish consumption by age group, kg/yr

infant	---
child	6.9
teen	16
adult	21

BF_i = Bioaccumulation factor for radionuclide, "i", in fish, pCi/kg per pCi/l, from Table 3.1-1

DF_{aoi} = Dose conversion factor for age group, "a", in organ, "o", for radionuclide, "i", in mrem/pCi, from Tables 3.1-2, 3.1-3, 3.1-4, and 3.1-5, respectively

λ_i = radiological decay constant for isotope, i, in 1/hr

t_w, t_f = transport time for the drinking water and fish pathways, hr

$t_w = 12$ hours $t_f = 24$ hours

Sample Calculation for Child, I-131, Thyroid:

$$A(c, \text{thy}, \text{I-131}) = 1.14E5 (510 \cdot 1.26 / 1.0 \cdot \exp(-3.59E-3 \cdot 12) + 6.9 \cdot 2.26 \cdot 15 \cdot \exp(-3.59E-3 \cdot 24)) \cdot 5.72E-3 = 5.41E5 \text{ mr/hr per } \mu\text{Ci/ml}$$

TABLE B4.0-6
(1 OF 2)

MCGUIRE NUCLEAR STATION
LIQUID EFFLUENT DOSE - INFANT PARAMETERS
A(I) MREM/HR PER UCI/ML

RADIONUCLIDE		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
1	H 3	0.0	1.46E+01	1.46E+01	1.46E+01	1.46E+01	1.46E+01	1.46E+01
11	NA 24	2.75E+02	2.75E+02	2.75E+02	2.75E+02	2.75E+02	2.75E+02	2.75E+02
24	CR 51	0.0	0.0	6.60E-01	4.31E-01	9.41E-02	8.38E-01	1.92E+01
25	MN 54	0.0	9.42E+02	2.14E+02	0.0	2.09E+02	0.0	3.46E+02
25	MN 56	0.0	1.52E+00	2.62E-01	0.0	1.31E+00	0.0	1.38E+02
26	FE 55	6.59E+02	4.26E+02	1.14E+02	0.0	0.0	2.08E+02	5.40E+01
26	FE 59	1.45E+03	2.53E+03	9.97E+02	0.0	0.0	7.48E+02	1.21E+03
27	CO 58	0.0	1.70E+02	4.24E+02	0.0	0.0	0.0	4.23E+02
27	CO 60	0.0	5.12E+02	1.21E+03	0.0	0.0	0.0	1.22E+03
28	NI 63	3.01E+04	1.86E+03	1.04E+03	0.0	0.0	0.0	9.24E+01
28	NI 65	8.21E+00	9.30E-01	4.23E-01	0.0	0.0	0.0	7.08E+01
29	CU 64	0.0	1.50E+01	6.93E+00	0.0	2.53E+01	0.0	3.07E+02
30	ZN 65	8.71E+02	2.99E+03	1.38E+03	0.0	1.45E+03	0.0	2.52E+03
30	ZN 69	6.87E-04	1.24E-03	9.21E-05	0.0	5.14E-04	0.0	1.01E-01
35	BR 83	0.0	0.0	5.31E-01	0.0	0.0	0.0	0.0
35	BR 85	0.0	0.0	2.26E-76	0.0	0.0	0.0	0.0
37	RB 86	0.0	7.91E+03	3.91E+03	0.0	0.0	0.0	2.02E+02
37	RB 88	0.0	1.72E-11	9.40E-12	0.0	0.0	0.0	1.67E-11
37	RB 89	0.0	8.51E-14	5.86E-14	0.0	0.0	0.0	2.90E-14
38	SR 89	1.18E+05	0.0	3.39E+03	0.0	0.0	0.0	2.43E+03
38	SR 90	5.92E+05	0.0	1.60E+05	0.0	0.0	0.0	1.09E+04
38	SR 91	9.86E+02	0.0	3.57E+01	0.0	0.0	0.0	1.17E+03
38	SR 92	4.24E+01	0.0	1.57E+00	0.0	0.0	0.0	4.57E+02
39	Y 90	3.62E+00	0.0	9.70E-02	0.0	0.0	0.0	5.00E+03
39	Y 91M	1.63E-06	0.0	5.56E-08	0.0	0.0	0.0	5.44E-03
39	Y 91	5.32E+01	0.0	1.42E+00	0.0	0.0	0.0	3.82E+03
39	Y 92	3.49E-02	0.0	9.80E-04	0.0	0.0	0.0	6.66E+02
39	Y 93	5.05E-01	0.0	1.37E-02	0.0	0.0	0.0	3.99E+03
40	ZR 95	9.71E+00	2.37E+00	1.68E+00	0.0	2.55E+00	0.0	1.18E+03
40	ZR 97	4.29E-01	7.36E-02	3.36E-02	0.0	7.42E-02	0.0	4.69E+03
41	NB 95	1.97E+00	8.12E-01	4.69E-01	0.0	5.82E-01	0.0	6.85E+02
42	MO 99	0.0	1.42E+03	2.77E+02	0.0	2.12E+03	0.0	4.68E+02
43	TC 99M	2.28E-02	4.71E-02	6.07E-01	0.0	5.07E-01	2.46E-02	1.37E+01
43	TC 101	5.75E-17	7.25E-17	7.17E-16	0.0	8.62E-16	3.95E-17	1.23E-14
44	RU 103	6.95E+01	0.0	2.33E+01	0.0	1.45E+02	0.0	8.46E+02
44	RU 105	9.89E-01	0.0	3.33E-01	0.0	7.27E+00	0.0	3.93E+02
44	RU 106	1.14E+03	0.0	1.43E+02	0.0	1.35E+03	0.0	8.67E+03
47	AG 100M	4.71E+01	3.44E+01	2.28E+01	0.0	4.92E+01	0.0	1.78E+03
52	TE 125M	1.10E+03	3.67E+02	1.48E+02	3.69E+02	0.0	0.0	5.23E+02
52	TE 127M	2.76E+03	9.17E+02	3.35E+02	7.99E+02	6.80E+03	0.0	1.12E+03
52	TE 127	1.95E+01	6.52E+00	4.19E+00	1.58E+01	4.75E+01	0.0	4.09E+02
52	TE 129M	4.69E+03	1.61E+03	7.22E+02	1.80E+03	1.17E+04	0.0	2.80E+03
52	TE 129	1.03E-02	3.57E-03	2.41E-03	8.67E-03	2.58E-02	0.0	8.27E-01
52	TE 131M	5.46E+02	2.20E+02	1.81E+02	4.45E+02	1.51E+03	0.0	3.70E+03
52	TE 131	1.87E-08	6.91E-09	5.25E-09	1.67E-08	4.79E-08	0.0	7.56E-07
52	TE 132	8.87E+02	4.39E+02	4.10E+02	6.48E+02	2.74E+03	0.0	1.62E+03
53	I 130	1.45E+02	3.19E+02	1.28E+02	3.58E+04	3.50E+02	0.0	6.84E+01
53	I 131	1.63E+03	1.92E+03	8.44E+02	6.31E+05	2.24E+03	0.0	6.86E+01
53	I 132	2.12E+00	4.30E+00	1.53E+00	2.01E+02	4.79E+00	0.0	3.48E+00
53	I 133	3.97E+02	5.79E+02	1.69E+02	1.05E+05	6.80E+02	0.0	9.79E+01
53	I 135	4.89E+01	9.72E+01	3.54E+01	8.71E+03	1.08E+02	0.0	3.52E+01
55	CS 134	1.79E+04	3.33E+04	3.36E+03	0.0	8.58E+03	3.52E+03	9.05E+01
55	CS 136	2.12E+03	6.23E+03	2.33E+03	0.0	2.48E+03	5.08E+02	9.46E+01
55	CS 137	2.47E+04	2.90E+04	2.05E+03	0.0	7.77E+03	3.15E+03	9.05E+01
55	CS 138	4.38E-06	7.12E-06	3.45E-06	0.0	3.55E-06	5.54E-07	1.14E-05
56	BA 139	9.87E-02	6.54E-05	2.86E-03	0.0	3.93E-05	3.96E-05	6.25E+00
56	BA 140	7.89E+03	7.89E+00	4.06E+02	0.0	1.87E+00	4.84E+00	1.94E+03
56	BA 141	2.80E-11	1.92E-14	8.82E-13	0.0	1.15E-14	1.17E-14	3.42E-10
56	BA 142	4.77E-20	3.96E-23	2.35E-21	0.0	2.28E-23	2.40E-23	1.97E-19
57	LA 140	8.14E-01	3.21E-01	8.25E-02	0.0	0.0	0.0	3.77E+03
57	LA 142	2.36E-04	8.65E-05	2.07E-05	0.0	0.0	0.0	1.47E+01
58	CE 141	3.69E+00	2.25E+00	2.65E-01	0.0	6.94E-01	0.0	1.16E+03
58	CE 143	5.46E-01	3.62E+02	4.13E-02	0.0	1.05E-01	0.0	2.11E+03
58	CE 144	1.41E+02	5.78E+01	7.91E+00	0.0	2.33E+01	0.0	8.10E+03
59	PR 143	3.76E+00	1.40E+00	1.86E-01	0.0	5.22E-01	0.0	1.98E+03
59	PR 144	3.65E-15	1.41E-15	1.84E-16	0.0	5.11E-16	0.0	6.56E-11
60	ND 147	2.54E+00	2.61E+00	1.60E-01	0.0	1.01E+00	0.0	1.65E+03
74	W 187	3.02E+01	2.10E+01	7.26E+00	0.0	0.0	0.0	1.24E+03
93	NP 239	4.54E-01	4.06E-02	2.30E-02	0.0	8.10E-02	0.0	1.17E+03

Table B4.0-6
(2 of 2)

McGuire Nuclear Station
Liquid Effluent Dose - Infant Parameters
 A_{aoi} mrem/hr per $\mu\text{Ci/ml}$

From Generic Section 3.1.1:

A_{aoi} = the site related ingestion dose commitment factor for an individual of age group, "a", to organ, "o", for each identified principal gamma and beta emitter, "i", in mrem/hr per $\mu\text{Ci/ml}$

$$A_{aoi} = 1.14E+05 (U_{aw}\sigma_w/D_w \exp(-\lambda_i t_w) + U_{af}\sigma_f BF_i \exp(-\lambda_i t_f)) DF_{aoi}$$

where:

$$1.14E+05 = 10^6 \text{ pCi}/\mu\text{Ci} \times 10^3 \text{ ml/kg} \div 8760 \text{ hr/yr}$$

U_{aw} = Water consumption by age group, l/yr

infant	330
child	510
teen	510
adult	730

σ_w, σ_f = Recirculation factors at equilibrium for the water and fish pathways respectively; these factors account for the fraction of discharged water reused by the station

$\sigma_w = 1.26$ $\sigma_f = 2.26$

D_w = Dilution factor from the near field area to the potable water intake = 1.0

U_{af} = Fish consumption by age group, kg/yr

infant	---
child	6.9
teen	16
adult	21

BF_i = Bioaccumulation factor for radionuclide, "i", in fish, pCi/kg per pCi/l, from Table 3.1-1

DF_{aoi} = Dose conversion factor for age group, "a", in organ, "o", for radionuclide, "i", in mrem/pCi, from Tables 3.1-2, 3.1-3, 3.1-4, and 3.1-5, respectively

λ_i = radiological decay constant for isotope, i, in 1/hr

t_w, t_f = transport time for the drinking water and fish pathways, hr

$t_w = 12$ hours $t_f = 24$ hours

Sample Calculation for Infant, I-131, Thyroid:

$$A(i, \text{thy}, \text{I-131}) = 1.14E5 (330 \cdot 1.26 / 1.0 \cdot \exp(-3.59E-3 \cdot 12) + 0 \cdot 2.26 \cdot 15 \cdot \exp(-3.59E-3 \cdot 24)) \cdot 1.39E-2 = 6.31E5 \text{ mr/hr per } \mu\text{Ci/ml}$$

Table B4.0-7 - Meteorological Parameter and Applicable Pathways
 for Potential Worst-Case Offsite Locations for Analyzing
 Offsite Doses From Particulates, Iodine and Other
 Radionuclides

Ground Level Release Worst-Case Locations

	$\overline{(X/Q)}$	$\overline{(D/Q)}$
	sec/m ³	1/m ²
(1) Inhalation, 0.56 mi, ENE	2.950E-05	3.893E-08
(2) Garden, 0.48 mi, E	1.742E-05	3.024E-08
(3) Meat Animal, 1.30 mi, ESE	3.143E-06	8.052E-09
(4) Milk Animal, 2.76 mi, SSE	2.246E-07	7.079E-10
(5) Combination, 0.48 mi, E	1.742E-05	3.024E-08

TABLE B4.0-8

PATHWAY APPLICABILITY FOR ALL LOCATIONS BASED ON SITE SURVEY*
 MCGUIRE NUCLEAR STATION
 (1 of 1)

SECTOR	Distance to the control location in miles									
	0-0.5	0.5-1.0	1.0-1.5	1.5-2.0	2.0-2.5	2.5-3.0	3.0-3.5	3.5-4.0	4.0-4.5	4.5-5.0
N	X	X	X	X	X	VI	VI	VI	VI	VIMG
NNE	X	X	I	VI	VI	VI	VI	VI	VI	VIMG
NE	X	X	I	I	VI	VI	VI	VI	VI	VIMG
ENE	X	I	I	I	I	VI	VI	VIM	VIM	VIMG
E	X	VI	VI	VI	VIC	VIC	VIC	VIC	VIC	VIMG
ESE	X	VI	VIM	VIM	VIM	VIM	VIMC	VIMC	VIMC	VIMG
SE	X	X	VI	VI	VIM	VIM	VIM	VIM	VIM	VIMG
SSE	X	X	VIM	VIM	VIM	VIMC	VIMC	VIMC	VIMC	VIMG
S	X	X	X	I	I	I	VIM	VIM	VIM	VIMG
SSW	X	X	X	X	X	VIM	VIM	VIM	VIM	VIMG
SW	X	X	X	VI	VI	VI	VI	VI	VI	VIMG
WSW	X	X	VI	VI	VI	VI	VI	VIM	VIM	VIMG
W	X	X	VI	VI	VI	VI	VIM	VIM	VIM	VIMG
WNW	X	I	VI	VIMG						
NW	X	I	VI	VI	VI	VI	VI	VIM	VIM	VIMG
NNW	X	X	X	VI	VI	VI	VI	VIM	VIM	VIMG

PATHWAYS: X - None V - VEGETABLE M - MEAT G - GOAT MILK C - COW MILK I - INHALATION/GROUND

* The land use census identifies nearest pathways to the site. Locations beyond the nearest pathway are assumed to contain that pathway for dose calculation purposes.

Figure B4.0-1 - Fuel Cycle Dose Calculation Worksheet For
Potential Worst-Case Offsite Locations

Ground Level Release Worst-Case Locations

	$(\overline{X/Q})$	$(\overline{D/Q})$
	sec/m ³	1/m ²
(1) Inhalation, 0.56 mi, ENE	2.950E-05	3.893E-08
(2) Garden, 0.48 mi, E	1.742E-05	3.024E-08
(3) Meat Animal, 1.30 mi, ESE	3.143E-06	8.052E-09
(4) Milk Animal, 2.76 mi, SSE	2.246E-07	7.079E-10
(5) Combination, 0.48 mi, E	1.742E-05	3.024E-08

Figure B4.0-1
(1 of 10)

Revision 41
1/1/00

Figure B4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for Organ Doses

Adult Age Group

Location 1 - Worst-Case Inhalation/Ground Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-Case Meat Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 4 - Worst-Case Milk Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Figure B4.0-1
(2 of 10)

Figure B4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for
Organ Doses

Location S_1 - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
$D_{a,o}(l)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(g)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(T)$	_____	_____	_____	_____	_____	_____	_____

Location S_2 - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
$D_{a,o}(l)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(g)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(T)$	_____	_____	_____	_____	_____	_____	_____

Location S_N - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
$D_{a,o}(l)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(g)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(T)$	_____	_____	_____	_____	_____	_____	_____

Adult Organ Maximums**

Maximum Total

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
$D_{a,o}(T_{max})$	_____	_____	_____	_____	_____	_____	_____

Figure B4.0-1
(3 of 10)

Figure B4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for Organ Doses

Teen Age Group

Location 1 - Worst-Case Inhalation/Ground Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-Case Meat Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 4 - Worst-Case Milk Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Figure B4.0-1
(4 of 10)

Figure B4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for
Organ Doses

Location 5₁ - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 5₂ - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 5_N - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Teen Organ Maximums**

Maximum Total

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (T _{max})	_____	_____	_____	_____	_____	_____	_____

Figure B4.0-1
(5 of 10)

Figure B4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for Organ Doses

Child Age Group

Location 1 - Worst-Case Inhalation/Ground Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-Case Meat Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 4 - Worst-Case Milk Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Figure B4.0-1
(6 of 10)

Figure B4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for Organ Doses

Location 5₁ - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 5₂ - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 5_N - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Child Organ Maximums**

Maximum Total

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (T _{max})	_____	_____	_____	_____	_____	_____	_____

Figure B4.0-1
(7 of 10)

Figure B4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for Organ Doses

Infant Age Group

Location 1 - Worst-Case Inhalation/Ground Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-Case Meat Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 4 - Worst-Case Milk Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Figure B4.0-1
(8 of 10)

Figure B4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for
Organ Doses

Location 5₁ - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 5₂ - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 5_N - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Infant Organ Maximums**

Maximum Total

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (T _{max})	_____	_____	_____	_____	_____	_____	_____

Figure B4.0-1
(9 of 10)

All Age Groups

Maximum Organ Dose ***

Organ = XXXXXXXXXXXX
Age Group = XXXXXXXXXXXX
Dose = x.xE-xx mrem/yr

Notes:

- * Fuel cycle dose for each age group, a, and organ, o, at analyzed limiting food pathway locations.
 $D_{a,o}(T) = D_{a,o}(l) + D_{a,o}(g)$
- ** Limiting dose estimates for each organ for age group, a, (maximums of dose values calculated for Locations 1 through 5.)
- *** Limiting dose estimate for any organ or age group (maximum of dose values calculated for any age group)

B5.0 RADIOLOGICAL ENVIRONMENTAL MONITORING

The radiological environmental monitoring program shall be conducted in accordance with Selected Licensee Commitment Manual Section 16.11-13. The monitoring program locations and analyses are given in Tables B5.0-1 through B5.0-3 and Figure B5.0-1. Site specific characteristics make groundwater sampling unnecessary. Groundwater recharge is from Lake Norman and local precipitation. The groundwater gradient flows directly to the Catawba River; therefore, contamination of groundwater from liquid effluents is highly improbable. Additionally, two site boundary TLD locations in the N and NNW sectors do not exist since the required locations are over water. However, special interest TLD's have been placed in these sectors on the discharge canal at 0.2 miles.

Duke Power's EnRad Laboratories participates in an interlaboratory comparison program. This program is described in the Annual Environmental Operating Report.

The land-use census data is used to identify the location with the highest possible dose for a particular ingestion pathway (vegetable, milk, meat, etc.). Environmental monitoring measurements taken from these locations are then used to perform dose calculations that serve as a verification of the dose calculations that are performed for technical specification and licensee commitment (i.e., Compliance) purposes.

The dates of the land-use census that were used to identify the controlling receptor sample locations were 06/16/99 - 06/18/99.

The 1999 land-use census did not identify any locations where environmental monitoring samples are required but were not available for collection.

TABLE B5.0-1
 (1 of 1)
 MCGUIRE RADIOLOGICAL MONITORING PROGRAM SAMPLING LOCATIONS
 (TLD LOCATIONS)

SAMPLING LOCATION DESCRIPTION * SAMPLING LOCATION DESCRIPTION *

143	SITE BOUNDARY	(0.3 MILES NW)	167	4-5 MILE RADIUS	(4.9 MILES SW)
144	SITE BOUNDARY	(0.5 MILES NNE)	168	4-5 MILE RADIUS	(4.6 MILES WSW)
145	SITE BOUNDARY	(0.5 MILES NE)	169	4-5 MILE RADIUS	(4.0 MILES W)
146	SITE BOUNDARY	(0.4 MILES ENE)	170	4-5 MILE RADIUS	(4.3 MILES WNW)
147	SITE BOUNDARY	(0.4 MILES E)	171	4-5 MILE RADIUS	(4.0 MILES NW)
148	SITE BOUNDARY	(0.5 MILES ESE)	172	4-5 MILE RADIUS	(5.7 MILES NNW)
149	SITE BOUNDARY	(0.5 MILES SE)	173	SPECIAL INTEREST	(8.4 MILES NNW)
151	SITE BOUNDARY	(0.4 MILES S)	174	SPECIAL INTEREST	(8.8 MILES WNW)
152	SITE BOUNDARY	(0.4 MILES SSW)	175	CONTROL	(15.5 MILES WNW)
153	SITE BOUNDARY	(0.5 MILES SW)	176	SPECIAL INTEREST	(11.0 MILES SW)
154	SITE BOUNDARY	(0.5 MILES W)	177	SPECIAL INTEREST	(8.8 MILES S)
156	SITE BOUNDARY	(0.5 MILES WNW)	178	SPECIAL INTEREST	(9.3 MILES SE)
157	4-5 MILE RADIUS	(4.7 MILES N)	179	SPECIAL INTEREST	(10.6 MILES ESE)
158	4-5 MILE RADIUS	(4.3 MILES NNE)	180	SPECIAL INTEREST	(12.7 MILES NNE)
159	4-5 MILE RADIUS	(5.0 MILES NE)	181	SPECIAL INTEREST	(7.0 MILES NE)
160	4-5 MILE RADIUS	(4.9 MILES ENE)	182	SPECIAL INTEREST	(6.2 MILES NE)
161	4-5 MILE RADIUS	(4.7 MILES E)	183	SPECIAL INTEREST	(5.8 MILES S)
162	4-5 MILE RADIUS	(4.5 MILES ESE)	186	SPECIAL INTEREST	(0.2 MILES NNW)
163	4-5 MILE RADIUS	(4.9 MILES SE)	187	SPECIAL INTEREST	(0.2 MILES N)
164	4-5 MILE RADIUS	(4.6 MILES SSE)	189	SITE BOUNDARY	(0.4 MILES SSE)
165	4-5 MILE RADIUS	(5.1 MILES S)	190	SITE BOUNDARY	(0.4 MILES WSW)
166	4-5 MILE RADIUS	(5.3 MILES SSW)	191	SPECIAL INTEREST	(2.8 MILES NNE)
			196	SPECIAL INTEREST	(1.0 MILES S)
			197	SPECIAL INTEREST	(1.1 MILES S)
			198	SPECIAL INTEREST	(1.3 MILES S)
			199	SPECIAL INTEREST	(1.5 MILES S)

* All TLD samples are collected quarterly.

TABLE B5.0-2
(1 of 1)
MCGUIRE RADIOLOGICAL MONITORING PROGRAM SAMPLING LOCATIONS

CODE:		Control Locations	Air Radioiodines and Particulates	Surface Water	Drinking Water	Shoreline Sediment	Food Products	Fish	Milk	Broadleaf Vegetation
SAMPLING LOCATION DESCRIPTION										
101	North Mecklenburg Water Supply (3.3 mi E)				BW					
119	Mt. Holly Municipal Water Supply (7.4 mi SSW)				BW					
120	Site Boundary (0.5 mi NNE)		W							M ^b
121	Site Boundary (0.5 mi NE)		W							
125	Site Boundary (0.4 mi SW)		W							M ^b
128	Discharge Canal Bridge (0.4 mi NE)			BW						
129	Discharge Canal Entrance to Lake Norman (0.5 mi ENE)					SA		SA		
130	Hwy. 73 Bridge Downstream (0.5 mi SW)					SA				
131	Cowans Ford Dam (0.6 mi WNW)			BW						
132	Charlotte Municipal Water Supply (11.2 mi SSE)				BW					
133	Cornelius (6.2 mi NE)		W							
134	East Lincoln Middle (8.8 mi WNW) X		W							M ^b
135	Plant Marshall Intake Canal (11.9 mi N)	X		BW						
136	Mooreville Municipal Water Supply (12.7 mi NNE)	X			BW					
137	Pinnacle Access Area (12.0 mi N)	X				SA		SA		
138	Henry Cook Dairy (3.1 mi ESE)									SM
139	William Cook Dairy (2.5 mi E)									SM
140	Kidd Dairy-Cows (2.8 mi SSE)									SM
141	Lynch Dairy-Cows (14.8 mi WNW)	X								SM
188	Garden (2.8 mi N)							M ^a		
192	Peninsula (2.8 mi NNE)		W							
193	Site Boundary (0.2 mi N)									M ^b
194	Lincoln County Water Supply (6.7 mi NNW)				BW					
195	Fishing Access Road (0.2 mi N)		W							

(a) during harvest season
(b) when available

TABLE B5.0-3
(1 of 1)
MCGUIRE RADIOLOGICAL MONITORING PROGRAM ANALYSES

SAMPLE MEDIUM	ANALYSIS SCHEDULE	ANALYSES				
		GAMMA ISOTOPIC	TRITIUM	LOW LEVEL I-131	GROSS BETA	TLD
1. Air Radioiodines	Weekly	X				
2. Air Particulates	Weekly Quarterly	X			X	
3. Direct Radiation	Quarterly					X
4. Surface Water	Monthly Composite Quarterly Composite	X	X			
5. Drinking Water	Monthly Composite Quarterly Composite	X	X		X	
6. Shoreline Sediment	Semiannually	X				
7. Milk	Semimonthly	X		X		
8. Fish	Semiannually	X				
9. Broadleaf Vegetation	Monthly	X				
10. Food Products	Monthly (a)	X				

(a) during harvest season

135 ▲ PLANT MARSHALL

137 ▲ PINNACLE ACCESS
136 ▲ MOORESVILLE WATER TREATMENT PLANT

● 180



LEGEND

- PRIMITIVE OR UNIMPROVED ROAD
- GRADED AND DRAINED ROAD
- SOIL, GRAVEL OR STONE SURFACED ROAD
- HARD SURFACED ROAD
- 4 LANE UNDIVIDED HIGHWAY
- DIVIDED HIGHWAY
- HIGHWAY WITH FRONTAGE ROADS
- FULL CONTROL ACCESS
- FEDERAL AID INTERSTATE ROAD
- FEDERAL AID PRIMARY ROAD
- FEDERAL AID SECONDARY ROAD
- FEDERAL AID URBAN
- NON-SYSTEM ROAD
- PROJECTED LOCATION
- INTERSECTION DISTANCE
- TRAFFIC CIRCLE
- HIGHWAY INTERCHANGE
- DETAILED HIGHWAY INTERCHANGE
- INTERSTATE HIGHWAY
- U.S. NUMBERED HIGHWAY
- NC NUMBERED HIGHWAY
- SECONDARY ROAD NUMBER
- UNDERGROUND CABLE
- RAILROAD, ANY NUMBER OF TRACKS USED BY SINGLE OPERATING COMPANY
- RAILROAD, ANY NUMBER OF TRACKS USED BY MORE THAN ONE OPERATING COMPANY ON SAME OR ADJACENT RIGHTS-OF-WAY
- RAILROAD STATION
- GRADE CROSSING
- UNDERPASS
- OVERPASS
- RAILROAD TUNNEL
- ARMY, NAVY OR MARINE CORPS FIELD
- COASTAL OR MUNICIPAL AIRPORT
- MARKED AUXILIARY FIELD
- HANGAR ON FIELD "H" SYMBOL
- DOCK, PIER OR LANDING
- FIRE OR TOLL FERRY
- LIGHT, NAUTICAL
- LIGHTHOUSE
- COAST GUARD STATION
- CANAL
- NARROW STREAM
- WIDE STREAM
- DAM WITH LOCK
- DAM
- RESERVOIR, POND OR LAKE
- PROMINENT PEAK, NUMERALS INDICATE ELEVATION
- ROAD THROUGH MOUNTAIN PASS
- HIGHWAY BRIDGE, OVER 20 FT
- DRAW SPAN ON BRIDGE
- HIGHWAY TUNNEL
- FORD
- STATE LINE
- COUNTY LINE
- CITY LIMITS
- RESERVATION OR PARK BOUNDARY
- INSET AREA
- DELIMITED AREA, POPULATION EST.
- COUNTY SEAT
- OTHER TOWNS AND VILLAGES
- TRIANGULATION STATION
- INCORPORATED CITY OR VILLAGE, GENERALIZED
- SCHOOL
- CHURCH
- CHURCH WITH CEMETERY
- CEMETERY
- HOSPITAL
- CORRECTIONAL OR PENAL INST.
- HIGHWAY GARAGE, OR MAINT. YARD
- HIGHWAY DIV. OR DIST. OFFICE
- WEIGHT STATION
- PATROL STATION
- REST AREA
- MONUMENT - SMALL HISTORICAL SITE

SCALE OF MILES



● TLD LOCATIONS

▲ ALL OTHER SAMPLING LOCATIONS

**MCGUIRE NUCLEAR STATION
MONITORING PROGRAM LOCATIONS**

FIGURE B5.0-1


(1 OF 2)


Revision 41
1/1/00

132 ▲ CHARLOTTE WATER WORKS

▲ 141

● 175





● TLD LOCATIONS
 ▲ OTHER SAMPLING LOCATIONS

Figure B5.0-1
 (2 of 2)
 Revision 38
 1/1/97

CATAWBA

January 1, 2000

Subject: Offsite Dose Calculation Manual (ODCM)
Catawba Nuclear Station Section - Revision 42

The General Office Radiation Protection Staff is transmitting to you this date Revision 42 of the Catawba Offsite Dose Calculation Manual. As this revision only affects Catawba Nuclear Station, the approval of other station managers is not required. A list of affected pages is given below. Please insert this letter with the attached Justification section in front of the January 1, 1999, Revision 41 letter.

REMOVE THESE PAGES

Figure C1.0-1
Figure C1.0-2 (two pages)
Table C4.0-7
Table C4.0-8
Figure C4.0-1 (page 1 of 10)
C-15
Table C5.0-2
Table C5.0-3

INSERT THESE PAGES

Figure C1.0-1
Figure C1.0-2 (two pages)
Table C4.0-7
Table C4.0-8
Figure C4.0-1 (page 1 of 10)
C-15
Table C5.0-2
Table C5.0-3

Effective Date: 1/1/00

Effective Date: 1/1/00



L. E. Haynes, Technical Manager
Radiation Protection



R. A. Jones, Manager
Catawba Nuclear Station

If you have any questions concerning Revision 42, please call Caryl Ingram at (704) 382-4496.



Caryl D. Ingram, Senior Engineer
Radiation Protection
Nuclear Services Division

JUSTIFICATION FOR REVISION 42

(page 1 of 1)

Figure C1.0-1

Removed EMF 44 and EMF 34 from the figure. The monitors are no longer used for any process control functions.

Figure C1.0-2 (two pages)

Removed EMF 34 from the figure.

Table C4.0-7

Revised the maximum garden, meat animal, milk animal, and combination locations and their corresponding dispersion and deposition factors based on the 1999 land use census.

Table C4.0-8

Revised table based on the 1999 land use census.

Figure C4.0-1 (1 of 10)

Revised the maximum garden, meat animal, milk animal, and combination locations and their corresponding dispersion and deposition factors based on the 1999 land use census.

Page C-15

Updated the name for Duke Power's environmental laboratory to EnRad. Revised land use census dates.

Table C5.0-2

Added sampling location #222, "Site Boundary (0.7m N)"

Table C5.0-3

Removed Low Level I-131 analysis for surface water, drinking water, and groundwater.

APPENDIX C
CATAWBA NUCLEAR STATION
SITE SPECIFIC INFORMATION

APPENDIX C - TABLE OF CONTENTS

		<u>Page</u>
C1.0	<u>CATAWBA NUCLEAR STATION RADWASTE SYSTEMS</u>	C-1
C2.0	<u>RELEASE RATE CALCULATION</u>	C-3
C3.0	<u>RADIATION MONITOR SETPOINTS</u>	C-7
C4.0	<u>DOSE CALCULATIONS</u>	C-11
C5.0	<u>RADIOLOGICAL ENVIRONMENTAL MONITORING</u>	C-15

C1.0 CATAWBA NUCLEAR STATION RADWASTE SYSTEMS

C1.1 LIQUID RADWASTE PROCESSING

The liquid radwaste system at Catawba Nuclear Station (CNS) is used to collect and treat fluid chemical and radiochemical by-products of unit operation. The system produces effluents which can be reused in the plant or discharged in small, dilute quantities to the environment. The means of treatment vary with waste type and desired product in the various systems:

- A) Filtration - All waste sources are filtered during processing. In some cases, such as the Laundry and Hot Shower Tank (LHST) Subsystem of the Liquid Waste (WL) System, filtration may be the only treatment required.
- B) Adsorption - Adsorption of halides and organic chemicals by activated charcoal (Carbon Filtration) can be used as needed for the waste streams in the WL System.
- C) Ion Exchange - Ion exchange is used to remove radioactive cations (cobalt, manganese) and anions (iodine) from the waste streams. This process can be used on all waste streams as needed.
- D) Gas Stripping - The fluids processed in the WL System does not contain entrained fission gases. Those fluids that are processed for recycle, however, do contain entrained fission gases. Removal of these gaseous radioactive fission products is accomplished in both the NB and WL Evaporators. These gases are stored in the Waste Gas Holdup System for decay prior to release.
- E) Distillation and Concentration - Evaporation is used to process recyclable liquids for reuse in the primary systems. However, the evaporators can be used to process non-recyclable fluids in an emergency situation. In this case, the distillate would be recycled to the primary systems while the concentrates would be solidified and routed to an approved low-level waste disposal site.

Figure C1.0-1 is a schematic representation of the liquid radwaste system at Catawba.




FIGURE C1.0-1 REV 42 1/1/00
 CATAWBA NUCLEAR STATION
 LIQUID RADWASTE SYSTEM

Table C1.0-1
ABBREVIATIONS

Systems:

CM - Condensate System
KC - Component Cooling
NB - Boron Recycle
RL - Low Pressure Service Water
RN - Nuclear Service Water System
WC - Conventional Waste Water Treatment
WL - Liquid Waste Recycle
WP - Turbine Building Sump
WS - Nuclear Solid Waste Disposal

Tanks:

BA - Boric Acid Tank
FDT - Floor Drain Tank
LHST - Laundry and Hot Shower Tank
MST - Mixing and Settling Tank
NCDT - Reactor Coolant Drain Tank
RHT - Recycle Holdup Tank
RMT - Recycle Monitor Tank
RMWST - Reactor Makeup Water Storage Tank
SGDT - Steam Generator Drain Tank
VUCDT - Ventilation Unit Condensate Drain Tank
WDT - Waste Drain Tank
WEFT - Waste Evaporator Feed Tank
WMT - Waste Monitor Tank

Table C1.0-1

C1.2 GASEOUS RADWASTE SYSTEMS

The gaseous waste disposal system for Catawba is designed with the capability of processing the fission-product gases from contaminated reactor coolant fluids resulting from operation. The system shown schematically in Fig. C1.0-2 is designed to allow for the retention and subsequent decay of the gaseous fission products generated from the reactor coolant system via the chemical and volume control system and/or the boron recycle system in order to limit the need for intentional discharge of high level radioactive gases from the waste gas holdup tanks. Sources of low-level radioactive gaseous discharge to the environment include periodic purging operations of the containment, the auxiliary building ventilation system, the secondary system air ejector and decayed WG Tanks. With respect to purging operations, the potential contamination is expected to arise from uncollectible reactor coolant leakage. With respect to the air ejector, the potential source of contamination will be from leakage of the reactor coolant to the secondary system through defects in steam generator tubes. The gaseous waste disposal system includes two waste gas compressors, two catalytic hydrogen recombiners, six gas decay storage tanks for use during normal power generation, and two gas decay storage tanks for use during shutdown and startup operations, and for pressure relief.

C1.2.1 Gas Collection System

The gas collection system combines the waste hydrogen and fission gases from the volume control tanks and that from the boron recycle gas stripper evaporator produced during normal operation with the gas collected during the shutdown degasification (high percentage of nitrogen) and cycle it through the catalytic recombiners converting all the hydrogen to water. After the water is removed, the resulting gas stream is transferred from the recombiner into the gas decay tanks, where the accumulated activity may be contained. From the decay tanks the gas will flow back to the compressor suction to complete the circuit.

C1.2.2 Containment and Auxiliary Building Ventilation

Nonrecyclable reactor coolant leakage occurring either inside the containment or inside the auxiliary building will generate gaseous activity. Gases resulting from leakage inside the containment will be contained until the containment air is released through the VQ or VP system. The containment atmosphere will be discharged through a charcoal adsorber and a particulate filter prior to release to the atmosphere.


Gases resulting from leakage inside the auxiliary building are released, without further decay, to the atmosphere via the auxiliary building ventilation system. The ventilation exhaust from potentially contaminated areas in the auxiliary building is normally unfiltered. However, on a radiation monitor alarm, the exhaust is passed through charcoal adsorbers to reduce releases to the atmosphere.

C1.2.3 Secondary Systems

Normally, condensate flow and steam generator blowdown will go parallel through 4 of the 5 condensate polishing demineralizers to remove activity and harmful ions from the water. Noncondensable gases will be taken from the secondary system by the condenser steam air ejector and are passed through a radiation monitor to the unit vent.

Figure C1.0-2 is a schematic representation of the gaseous radwaste system at Catawba.

UNITS 1 & 2




*FUEL HANDLING AREA IS NORMALLY UNFILTERED. UPON A RADIATION ALARM BY EMF-42, THE EXHAUST WILL BE DIVERTED TO THE FILTER MODE.

**POTENTIALLY CONTAMINATED AREAS OF THE AUXILIARY BUILDING ARE NORMALLY UNFILTERED. UPON A RADIATION ALARM BY EMF-41, THE EXHAUST WILL BE DIVERTED TO THE FILTERED MODE.

FIGURE C1.0-2
CATAWBA NUCLEAR STATION
GASEOUS RADWASTE SYSTEM
PAGE 1 OF 2

REVISION 42
1/1/00

AUXILIARY MONITOR TANK BUILDING



GASEOUS WASTE SYSTEM
CATAWBA NUCLEAR STATION
FIGURE C1.0-2
PAGE 2 OF 2

C2.0 RELEASE RATE CALCULATION

Generic release rate methodology is presented in Section 1.0; this methodology with Catawba-specific input data will be used to calculate release rates for Catawba Nuclear Station.

C2.1 LIQUID RELEASE RATE CALCULATIONS

There are two potential liquid release points at Catawba. They are:

1. Liquid Waste Effluent Discharge Line (WL)
2. Conventional Waste Water Treatment System Effluent Line (WC)

C2.1.1 Liquid Waste Effluent Discharge Line (WL)

There are three low-pressure service water pumps with a minimum flow rate of 19,000 gpm each and four nuclear service water pumps with a minimum flow rate of 9,000 gpm each which provide the required dilution water needed for a release. The LPSW system flow rate monitor has a variable setpoint which terminates the release by closing an isolation valve should the dilution flow fall below the setpoint. Releases can either be made via EMF-49 which uses isolation valve 1WL124, or EMF-57 which uses isolation valve 1WLX28. The following is a typical equation which can be used to calculate a discharge flow, in gpm.

$$f \leq F_{RL} \div \left[\sigma \sum_i \frac{C_i}{(10 \times EC_i)} \right]$$

where:

- f = the undiluted effluent flow, in gpm.
- F_{RL} = actual low pressure service water flowrate, in gpm.
- σ = the recirculation factor at equilibrium (dimensionless), 1.0.
- C_i = the concentration of radionuclide, i, in undiluted effluent as determined by laboratory analyses, in $\mu\text{Ci/ml}$.
- EC_i = the concentration of radionuclide, i, from 10CFR20, Appendix B, Table 2, Column 2. If radionuclide, i, is a dissolved noble gas, the $EC_i = 2.0\text{E-}05 \mu\text{Ci/ml}$.

C2.1.2 Conventional Waste Water Treatment System Effluent Line (WC)

The conventional waste water treatment system effluent is potentially radioactive; that is, it is possible the effluent will contain measurable activity above background. It is assumed that no activity is present in the effluent until indicated by periodic analysis of the composite sample collected on that line. The water sources listed below that are normally discharged via the conventional waste water treatment system and/or the Turbine Building Sump (TBS) will be diverted if they will cause the WC discharge to exceed administrative limits designed to ensure that station release limits will not be exceeded.

a. Auxiliary Feedwater Sump Pumps and Floor Drain Sump Pump Line

Normally the discharge line coming from these sumps will discharge into the TBS, but if activity is detected above its monitor's setpoint, the discharge flow will automatically be routed to the floor drain tank for processing and later be discharged through the liquid waste effluent line. Subsequent radioactive releases may be allowed to discharge into the TBS if administratively controlled to assure that release limits are not exceeded.

b. Steam Generator Blowdown Line

Normally the discharge from the Steam Generator Blowdown will be pumped to the TBS, but if activity is detected above its monitor's setpoint, each blowdown flow control valve, the atmospheric vent, and the valve to the TBS will close, thus terminating the discharge. Blowdown can only be continued by venting the steam to "D" heater and pumping the liquid to the condensate system.

c. Turbine Building Sump Discharge Line

Normally the discharge from the TBS will go into the conventional waste water treatment system, but if activity is detected above its monitor's setpoint, the sump pumps A, B, and C will stop and an alarm actuated. The TBS discharge line can then either be routed to the steam generator drain tanks for processing, or allowed to continue being discharged via the circuit with proper administrative controls implemented to assure that release limits are not exceeded.

$$f \leq (F_{CR} \times 0.1) \div \left[\sigma \sum \frac{C}{(10 \times EC)} \right]$$

where:

f = the undiluted effluent flow, in gpm.

F_{CR} = Catawba River flow, at cove beyond WC outflow point, in gpm.

0.1 = conservative factor due to no spargers in use to split flow output to river.

σ = the recirculation factor at equilibrium (dimensionless), 1.0.

C = the gross activity in the in undiluted effluent, in μCi/ml.

EC = 9.0E-07 μCi/ml, the EC value for Cs-134, which is the lowest effluent concentration value for any detectable radionuclide that is not known to be absent from the liquid effluent.

C2.2 GASEOUS RELEASE RATE CALCULATIONS

The unit vent is the release point for waste gas decay tanks, containment air releases, the condenser air ejector, and auxiliary building ventilation. The condenser air ejector effluent is normally considered nonradioactive; that is, it is unlikely the effluent will contain measurable activity above background. It is assumed that no activity is present in the effluent until indicated by radiation monitoring measurements and/or by analyses of periodic samples collected on that line. Radiation monitoring alarm/trip setpoints in conjunction with administrative controls assure that release limits are not exceeded; see section C.3.0 on radiation monitoring setpoints.

The Auxiliary Monitor Tank Building (AMTB) ventilation system and lab hoods are exhausted directly through a vent on the AMTB. The process areas of the AMTB ventilation pass through particulate and charcoal filters. The effluent is normally considered nonradioactive; however, the potential for release of radioactive effluents remains with certain job evolutions that may take place in the AMTB.

The following calculations, when solved for flowrate, are the release rates for noble gases and for radioiodines, particulates and other radionuclides with half-lives greater than 8 days; the most conservative of release rates calculated in C2.2.1 and C2.2.2 shall control the release rate for a single release point. 98% of the controlling release rate calculated is apportioned to the unit vent and 2% is apportioned to the AMTB vent (assuring simultaneous releases from both points do not exceed the controlling release rate for a single point).

C2.2.1 Noble Gases

$$\sum_i K_i [(\bar{X}/Q)\bar{Q}_i] < 500 \text{ mrem/yr, and}$$

$$\sum_i (L_i + 1.1 M_i) [(\bar{X}/Q)\bar{Q}_i] < 3000 \text{ mrem/yr}$$

where the terms are defined below.

C2.2.2 Radioiodines, Particulates, and Other Radionuclides With T 1/2 > 8 Days

$$\sum_i P_i [W \bar{Q}_i] < 1500 \text{ mrem/yr}$$

where:

- K_i = The total body dose factor due to gamma emissions for each identified noble gas radionuclide, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1.
- L_i = The skin dose factor due to beta emissions for each identified noble gas radionuclide, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1.
- M_i = The air dose factor due to gamma emissions for each identified noble gas radionuclide, in mrad/yr per $\mu\text{Ci}/\text{m}^3$ from Table 1.2-1 (unit conversion constant of 1.1 mrem/mrad converts air dose to skin dose).
- P_i = The dose parameter for radionuclides other than noble gases for the inhalation pathway, in mrem/yr per $\mu\text{Ci}/\text{m}^3$ and for the food and ground plane pathways in $\text{m}^2 \cdot (\text{mrem}/\text{yr})$ per $\mu\text{Ci}/\text{sec}$ from Table 1.2-2. The dose factors are based on the critical individual organ and most restrictive age group (child or infant).
- \bar{Q}_i = The release rate of radionuclides, i, in gaseous effluent from all release points at the site, in $\mu\text{Ci}/\text{sec}$.

$(\bar{X}/\bar{Q}) = 3.510E-05 \text{ sec/m}^3$. The highest calculated annual average relative concentration (dispersion parameter) for any area at or beyond the unrestricted area boundary. The location is the NNE sector @ 0.5 mile.

W = The highest calculated annual average dispersion or deposition parameter for estimating the maximum dose rate to an individual from the total inhalation, food and ground plane pathways:

W = $3.510E-05 \text{ sec/m}^3$, for the inhalation pathway. The location is the NNE sector @ 0.5 mile.

W = $1.078E-07 \text{ 1/meter}^2$, for the food and ground plane pathways. The location is the NNE sector @ 0.5 mile.

$$\tilde{Q}_i = k_1 C_i f \div k_2 = 4.72E+2 C_i f$$

where:

C_i = the concentration of radionuclide, i, in undiluted gaseous effluent, in $\mu\text{Ci/ml}$.

f = the undiluted effluent flow, in cfm

k_1 = conversion factor, $2.83E4 \text{ ml/ft}^3$

k_2 = conversion factor, 60 sec/min

C3.0 RADIATION MONITOR SETPOINTS

Using the generic calculations presented in Section 2.0, final effluent radiation monitoring setpoints are calculated for monitoring as required by the Technical Specifications.

All radiation monitors for Catawba are off-line except EMF-50 (Waste Gas System) which is in-line. These monitors alarm on low flow; the minimum flow alarm level for both the liquid monitors and the gas monitors is based on the manufacturer's recommendations except EMF-50. These monitors measure the activity in the liquid or gas volume exposed to the detector. Liquid monitors are independent of flow rate if a minimum flow rate is assured. Gaseous monitors are dependent on pressure or vacuum. Particulate monitors are dependent on flow rates.

Radiation monitoring setpoints calculated in the following sections are expressed in activity concentrations; in reality the monitor readout is in counts per minute. Station radiation monitor setpoint procedures which correlate concentration and counts per minute shall be based on the following relationship:

$$c = \frac{r}{2.22 \times 10^6 e V}$$

where:

c = the gross activity, in $\mu\text{Ci/ml}$
r = the count rate, in cpm
 2.22×10^6 = the disintegration per minute per μCi
e = the counting efficiency, cpm/dpm
V = the volume of fluid exposed to the detector, in ml.

For those occurrences when simultaneous releases of radioactive material must be made, monitor setpoints will be adjusted downward in accordance with Station Procedures to insure that instantaneous concentrations will not be exceeded.

C3.1 LIQUID RADIATION MONITORS

C3.1.1 Waste Liquid Effluent Line - EMF 49 and EMF 57

As described in Section C2.1.1 on release rate calculations for the waste liquid effluent, the release is controlled by limiting the flow rate of effluent from the station. Although the release rate is flow rate controlled, the radiation monitor setpoint shall be set to terminate the release if the effluent activity should exceed that determined by laboratory analyses and used to calculate the release rate. A typical radiation monitor setpoint may be calculated as follows:

$$c \leq \frac{10 \times EC \times F}{\text{of}} \leq 2.52\text{E-}03 \mu\text{Ci/ml}$$

where:

c = the gross activity in undiluted effluent, in $\mu\text{Ci/ml}$
f = the flow from the tank may vary from 0-100 gpm but, for this calculation, is assumed to be 100 gpm.

EC = $9.0E-07$ $\mu\text{Ci/ml}$, the EC for Cs-134, which is the lowest effluent concentration value for any detectable radionuclide that is not known to be absent from the liquid effluent. ***

σ = the recirculation factor at equilibrium (dimensionless), 1.0.

F = the dilution flow may vary as described in section C2.1.1, but is conservatively estimated at 28,000 gpm, the minimum flow available.

Normally, discharges from the WL system will be limited to either EMF-49 or EMF-57. Simultaneous releases may occur, however, if proper station procedures are followed to insure that instantaneous concentration limits will not be exceeded.

C3.1.2 Section Deleted 1/1/92 Revision 34

C3.1.3 Auxiliary Feedwater Sump Pumps and Floor Drain Sump Pump - EMF 52

As described in Section C2.1.2 on release rate calculations for the auxiliary feedwater sump pumps and floor drain sump pump effluents, it is possible that the effluent will contain measurable activity above background. It is assumed that the effluent activity is less than the monitors setpoint until indicated by a radiation alarm. Since the sumps are discharged automatically, the radiation monitor setpoint will initially be set at $1.0E-06$ $\mu\text{Ci/ml}$ (the monitor's minimum practical setpoint) plus background to assure that no activity is unknowingly discharged into the Turbine Building sump. The setpoint may be changed after initial detection to allow positive control of effluent releases using the guidance given in Section C3.1.5.

C3.1.4 Steam Generator Blowdown Line - EMF 34

As described in Section C2.1.2 on Release Rate Calculations for the Steam Generator Blowdown, it is possible that the effluent will contain measurable activity above its monitor's setpoint. It is assumed that no activity is present in the effluent until indicated by radiation monitoring. Since the Steam Generator Blowdown line is discharged automatically, the radiation monitor setpoint will be initially set at $1.0E-06$ $\mu\text{Ci/ml}$ (the monitor's minimum practical setpoint) plus background to assure no activity is unknowingly discharged into the Turbine Building sump. The setpoint may be changed after detection to allow positive control of effluent releases using the guidance given in Section C3.1.5.

*** The justification for this assumption is provided in 10 CFR 20, Appendix B, Note 2. A review of past liquid effluent release data shows that Cs-134 has the lowest effluent concentration value for any detectable radionuclide in the effluent. An annual review of the effluent release data will be performed to assure that this assumption remains valid.

C3.1.5 Turbine Building Sump Discharge Line - EMF 31

As described in Section C2.1.2 on release rate calculations for the turbine building sumps, it is possible that the effluent will contain measurable activity above its monitor setpoint. Since the sump contents are discharged automatically, the radiation monitor setpoint will be initially set at 1.0E-06 $\mu\text{Ci/ml}$ (the monitor's minimum practical setpoint) plus background to assure that no activity is unknowingly discharged into the WC system. Should radioactive effluent releases need to be made from the TBS via the WC system a typical monitor setpoint may be calculated as follows:

$$c \leq \frac{10 \times EC}{\sigma} \leq 9.00\text{E-}06 \mu\text{Ci/ml}$$

where:

c = the gross activity in undiluted effluent, in $\mu\text{Ci/ml}$

EC = 9.0E-07 $\mu\text{Ci/ml}$, the EC for Cs-134, which is the lowest effluent concentration value for any detectable radionuclide that is not known to be absent from the liquid effluent. ***

σ = the recirculation factor at equilibrium (dimensionless), 1.0.

*** The justification for this assumption is provided in 10 CFR 20, Appendix B, Note 2. A review of past liquid effluent release data shows that Cs-134 has the lowest effluent concentration value for any detectable radionuclide in the effluent. An annual review of the effluent release data will be performed to assure that this assumption remains valid.

C3.2 GAS MONITORS

The following equation shall be used to calculate noble gas radiation monitor setpoints based on Xe-133 (Historical data shows that Xe-133 is the predominant isotope):

$$K(\overline{X/Q}) \tilde{Q}_i < 500 \quad (\text{see Section C2.2.1})$$

$$\tilde{Q}_i = 4.72E+02 C_i f \quad (\text{see Section C2.2.2})$$

$$C_i < 146/f$$

where:

C_i = the gross activity in undiluted effluent, in $\mu\text{Ci/ml}$

f = the flow from the tank or building sources, in cfm

K = from Table 1.2-1 for Xe-133, $2.06E+2$ mrem/yr per $\mu\text{Ci/m}^3$

$\overline{X/Q}$ = $3.510E-05$ sec/ m^3 , as defined in Section C.2.2.2

As stated in Section C2.2, the unit vent is the release point for the containment purge ventilation system, the containment air release and addition system, the condenser air ejector, and auxiliary building ventilation. The Auxiliary Monitor Tank Building (AMTB) vent is the release point for the AMTB ventilation. 98% of the single point controlling release rate is apportioned to the unit vent and 2% is apportioned to the AMTB vent.

For releases from the containment purge ventilation system, a typical radiation monitor setpoint may be calculated as follows:

$$C_i < .98(146/f) = 8.16E-04$$

where:

$$f = 150,000 \text{ cfm (auxiliary building ventilation)} + 26,000 \text{ cfm (containment purge)} = 176,000 \text{ cfm}$$

For releases from the AMTB ventilation a typical radiation monitor setpoint may be calculated as follows:

$$C_i < .02(146/f) = 2.66E-04$$

where:

$$f = 11,000 \text{ cfm (AMTB ventilation)}$$

For release from the containment air release and addition system, the waste gas decay tanks, the condenser air ejectors, and the auxiliary building ventilation, a typical radiation monitor setpoint may be calculated as follows:

$$C_i < 146/f = 9.77E-04$$

where:

$$f = 150,000 \text{ cfm (auxiliary building ventilation)}$$

C4.0 DOSE CALCULATIONS

C4.1 FREQUENCY OF CALCULATIONS

Dose contributions to the maximum individual shall be calculated at least every 31 days, quarterly, and annually using the methodology in the generic information sections or the RETDAS computer program. One of these methods shall also be used for any special reports.

Station long-term historical and dose projection calculations are periodically performed to determine the station's status with respect to meeting annual ALARA goals specified in the Catawba Nuclear Station Selected Licensing Commitment Manual. Such calculations are used to verify that adequate margin remains during a report period to allow normal stations and radwaste system operation, including anticipated operational occurrences, for the remainder of the report period without exceeding applicable goals. Station dose projections can be performed using generic methodology or the RETDAS computer program.

Fuel cycle dose calculations shall be performed annually or as required by special reports. Dose contributions shall be calculated using the methodology in the appropriate generic information sections or the RETDAS computer program.

C4.2 DOSE MODELS FOR MAXIMUM EXPOSED INDIVIDUAL

C4.2.1 Liquid Effluents

Generic methodology for calculating liquid pathway exposures to the maximum individual is presented in Section 3.1.1. Catawba site specific parameters to be used in the generic methodology are presented as follows:

A_{soi} = Tables C4.0-3 through C4.0-6

F_n = $f / (F + f)$ (0.006 default for projections)

where:

F_n = Near field dilution factor, dimensionless

f = Catawba average liquid radwaste flow, cfs (0.65 default for projections)

F = Catawba average dilution flow for period of interest, cfs (105 default for projections)

C4.2.2 Gaseous Effluents

C4.2.2.1 Noble Gases

Gamma Air and Beta Air Dose

Generic methodology for calculating noble gas airborne pathway gamma air (D_γ) and beta air (D_β) doses is presented in Section 3.1.2.1. Catawba site specific parameters to be used in the generic methodology are presented as follows:

(X/Q) = $3.510E-05 \text{ sec/m}^3$. The highest calculated annual average relative concentration for any area at or beyond the unrestricted area boundary. The location is the NNE sector @ 0.5 mile.

C4.2.2.2 Radioiodines, Particulates, and Other Radionuclides with $T_{1/2} > 8$ days

Generic methodology for calculating airborne pathway maximum organ (D_{mo}) exposures to the maximum individual is presented in Section 3.1.2.2. External exposure from deposited ground contamination and inhalation exposure pathways, and internal exposure from food pathways (i.e., vegetable, meat and milk) are analyzed at locations where site surveys have verified residents, vegetable gardens, meat producing animals, or cow/goat milk producing animals exist. Therefore, the location of the maximum individual may vary depending on the mixture and levels of radionuclides released during a period of time. Additionally, the critical (or limiting) age group and organ will vary based on the location (i.e., combination of dose pathways contributing dose) and mixture/level of radionuclide releases during the release period.

Performing calculations separately for all potential maximum locations, age groups and organs assures that a maximum location is identified, and that a conservative estimate is obtained for maximum offsite dose impact to any organ or age group. Catawba site specific meteorological dispersion (X/Q) and deposition (D/Q) parameters and applicable terrestrial/food pathways for the potential maximum locations to be analyzed using generic methodology are presented in Table C4.0-7.

C4.3 FUEL CYCLE CALCULATIONS

As discussed in Section 3.3.5, more than one nuclear power station site may contribute to the doses to be considered in accordance with 40CFR190. The fuel cycle dose assessments for Catawba Nuclear Station only include liquid and gaseous dose contributions from Catawba Nuclear Station since no other uranium fuel cycle facility contributes significantly to Catawba's maximum exposed individual. For this dose assessment, the total body and maximum organ dose contributions to the maximum exposed individual from Catawba liquid and gaseous effluents are estimated using the following calculations:

$$D_{WB}(T) = D_{WB}(l) + D_{WB}(g)$$

$$D_{MO}(T) = D_{MO}(l) + D_{MO}(g)$$

where:

$D_{WB}(T)$ = Total estimated fuel cycle whole body dose commitment resulting from the combined liquid and gaseous effluents of Catawba during the calendar year of interest, in mrem.

$D_{MO}(T)$ = Total estimated fuel cycle maximum organ dose commitment resulting from the combined liquid and gaseous effluents of Catawba during the calendar year of interest, in mrem.

A fuel cycle dose calculation worksheet is provided in Figure C.4.0-1.

C4.3.1 Liquid Effluents

Liquid pathway dose estimates are calculated using generic methodology or the RETDAS computer program. The values for $D_{WB}(l)$ and $D_{MO}(l)$ liquid pathway dose contributions are calculated based on the methodology, values and assumptions presented in Section C4.2.1.

C4.3.2 Gaseous Effluents

Total Body

The methodology for calculating noble gas airborne pathway whole body exposures to the maximum individual, $D_{WB}(g)$, is derived from Section 3.1.2.1 generic methodology for gamma air and beta air dose calculations as follows:

$$D_{WB}(g) = 3.17E-8 \sum_i K_i [(X/Q)Q_i] \text{ mrem/yr}$$

Generic methodology parameters K_i are described in Section 1.2.1. The Catawba site specific parameter X/Q value is $3.510E-05 \text{ sec/m}^3$ as described in Section C4.2.2.1 for Catawba gamma air and beta air dose calculations.

Maximum Organ

Airborne pathway maximum organ dose estimates are calculated using generic methodology or the RETDAS computer program. The maximum organ dose is established by calculating doses to all organs for each potential maximum offsite location identified in Table C4.0-7. A conservative estimate (i.e., overestimate) of the fuel cycle maximum organ dose is obtained by:

- 1) determining the locations with the highest exposure releases for each organ;
- 2) adding the highest exposure value for the airborne release to the same organ dose resulting from liquid releases; and
- 3) comparing values obtained when the liquid and airborne pathway components are added for all organs and age groups to determine the maximum (or limiting) organ and age group.

TABLE C4.0-1

CATAWBA NUCLEAR STATION
(1 OF 2)DISPERSION PARAMETER ($\overline{X/Q}$) FOR LONG TERM RELEASES > 500 HR/YR OR > 125 HR/QTR
(SEC/M3)

DISTANCE TO THE CONTROL LOCATION, IN MILES

SECTOR	0-0.5	0.5-1.0	1.0-1.5	1.5-2.0	2.0-2.5	2.5-3.0	3.0-3.5	3.5-4.0	4.0-4.5	4.5-5.0
N		2.959E-05	7.879E-06	3.222E-06	1.768E-06	1.133E-06	7.978E-07	5.987E-07	4.701E-07	3.818E-07
NNE		3.510E-05	9.342E-06	3.814E-06	2.091E-06	1.338E-06	9.420E-07	7.066E-07	5.546E-07	4.503E-07
NE		2.927E-05	7.738E-06	3.166E-06	1.738E-06	1.114E-06	7.848E-07	5.891E-07	4.627E-07	3.759E-07
ENE		2.208E-05	5.813E-06	2.406E-06	1.330E-06	8.573E-07	6.065E-07	4.568E-07	3.598E-07	2.931E-07
E		1.858E-05	4.895E-06	2.032E-06	1.126E-06	7.266E-07	5.147E-07	3.880E-07	3.059E-07	2.493E-07
ESE		1.962E-05	5.223E-06	2.163E-06	1.197E-06	7.712E-07	5.457E-07	4.110E-07	3.238E-07	2.637E-07
SE		1.965E-05	5.167E-06	2.151E-06	1.194E-06	7.717E-07	5.471E-07	4.128E-07	3.257E-07	2.656E-07
SSE		2.561E-05	6.751E-06	2.798E-06	1.548E-06	9.982E-07	7.064E-07	5.323E-07	4.194E-07	3.416E-07
S		1.552E-05	4.101E-06	1.642E-06	8.878E-07	5.624E-07	3.926E-07	2.924E-07	2.282E-07	1.843E-07
SSW		8.747E-06	2.267E-06	8.761E-07	4.621E-07	2.872E-07	1.973E-07	1.450E-07	1.118E-07	8.939E-08
SW		5.071E-06	1.328E-06	5.087E-07	2.666E-07	1.648E-07	1.127E-07	8.249E-08	6.340E-08	5.052E-08
WSW		3.265E-06	8.730E-07	3.413E-07	1.815E-07	1.135E-07	7.839E-08	5.786E-08	4.479E-08	3.592E-08
W		2.024E-06	5.307E-07	2.058E-07	1.088E-07	6.771E-08	4.657E-08	3.426E-08	2.644E-08	2.115E-08
WNW		3.468E-06	9.193E-07	3.595E-07	1.913E-07	1.197E-07	8.267E-08	6.104E-08	4.727E-08	3.793E-08
NW		6.249E-06	1.680E-06	6.638E-07	3.558E-07	2.239E-07	1.555E-07	1.153E-07	8.959E-08	7.212E-08
NNW		1.406E-05	3.723E-06	1.508E-06	8.221E-07	5.242E-07	3.678E-07	2.752E-07	2.155E-07	1.747E-07

TABLE C4.0-1
(2 OF 2)

CATAWBA NUCLEAR STATION

The values presented in this table were generated by using the computer program XOQDOQ (NUREG/CR-2919) which implements NRC Regulatory Guide 1.111 (1977), and by using the following assumptions:

1. Data Collection Period, 1988 to 1992.
2. Ground Level Releases.
3. Open Terrain Recirculation Correction Factors.
4. No Decay, Undepleted
5. Vent and Building Parameters:

Release Height (meters)	= 38.00	Rep. Wind Height (meters)	= 10.0
Diameter (meters)	= 0.00	Building Height (meters)	= 41.0
Exit Velocity (meters)	= 0.00	Bldg. Min. X-Sec. Area (sq. m.)	= 1616.0
		Heat Emission Rate (cal/s)	= 0.0

TABLE C4.0-2
 CATAWBA NUCLEAR STATION
 (1 OF 2)

DEPOSITION PARAMETER ($\overline{D/Q}$) FOR LONG TERM RELEASES > 500 HR/YR OR > 125 HR/QTR
 (1/M2)

SECTOR	DISTANCE TO THE CONTROL LOCATION, IN MILES									
	0-0.5	0.5-1.0	1.0-1.5	1.5-2.0	2.0-2.5	2.5-3.0	3.0-3.5	3.5-4.0	4.0-4.5	4.5-5.0
N	8.799E-08	2.148E-08	7.715E-09	3.826E-09	2.253E-09	1.475E-09	1.038E-09	7.693E-10	5.928E-10	
NNE	1.078E-07	2.630E-08	9.448E-09	4.686E-09	2.759E-09	1.807E-09	1.271E-09	9.421E-10	7.260E-10	
NE	7.653E-08	1.868E-08	6.710E-09	3.328E-09	1.960E-09	1.283E-09	9.028E-10	6.691E-10	5.156E-10	
ENE	4.135E-08	1.009E-08	3.626E-09	1.798E-09	1.059E-09	6.933E-10	4.878E-10	3.615E-10	2.786E-10	
E	3.246E-08	7.924E-09	2.846E-09	1.411E-09	8.311E-10	5.442E-10	3.829E-10	2.838E-10	2.187E-10	
ESE	3.810E-08	9.301E-09	3.341E-09	1.657E-09	9.755E-10	6.388E-10	4.495E-10	3.331E-10	2.567E-10	
SE	3.799E-08	9.274E-09	3.331E-09	1.652E-09	9.727E-10	6.369E-10	4.482E-10	3.321E-10	2.560E-10	
SSE	7.019E-08	1.713E-08	6.154E-09	3.052E-09	1.797E-09	1.177E-09	8.280E-10	6.136E-10	4.729E-10	
S	7.881E-08	1.924E-08	6.910E-09	3.427E-09	2.018E-09	1.321E-09	9.297E-10	6.890E-10	5.310E-10	
SSW	6.787E-08	1.657E-08	5.951E-09	2.951E-09	1.738E-09	1.138E-09	8.007E-10	5.934E-10	4.573E-10	
SW	3.877E-08	9.464E-09	3.399E-09	1.686E-09	9.926E-10	6.500E-10	4.573E-10	3.389E-10	2.612E-10	
WSW	1.476E-08	3.604E-09	1.295E-09	6.420E-10	3.780E-10	2.475E-10	1.742E-10	1.291E-10	9.947E-11	
W	7.895E-09	1.927E-09	6.922E-10	3.433E-10	2.021E-10	1.324E-10	9.313E-11	6.902E-11	5.319E-11	
WNW	1.087E-08	2.654E-09	9.534E-10	4.728E-10	2.784E-10	1.823E-10	1.283E-10	9.507E-11	7.326E-11	
NW	2.319E-08	5.661E-09	2.033E-09	1.008E-09	5.938E-10	3.888E-10	2.736E-10	2.027E-10	1.562E-10	
NNW	4.863E-08	1.187E-08	4.264E-09	2.114E-09	1.245E-09	8.152E-10	5.736E-10	4.251E-10	3.276E-10	

TABLE C4.0-2
(2 OF 2)

CATAWBA NUCLEAR STATION

The values presented in this table were generated by using the computer program XOQDOQ (NUREG/CR-2919) which implements NRC Regulatory Guide 1.111 (1977), and by using the following assumptions:

1. Data Collection Period, 1988 to 1992.
2. Ground Level Releases.
3. Open Terrain Recirculation Correction Factors.
4. No Decay, Undepleted
5. Vent and Building Parameters:

Release Height (meters)	= 38.00	Rep. Wind Height (meters)	= 10.0
Diameter (meters)	= 0.00	Building Height (meters)	= 41.0
Exit Velocity (meters)	= 0.00	Bldg. Min. X-Sec. Area (sq. m.)	= 1616.0
		Heat Emission Rate (cal/s)	= 0.0

TABLE C4.0-3
(1 OF 2)

CATAMBA NUCLEAR STATION
LIQUID EFFLUENT DOSE - ADULT PARAMETERS
A(I) MREM/HR PER UCI/ML

RADIONUCLIDE	BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
1 H 3	0.0	4.28E-01	4.28E-01	4.28E-01	4.28E-01	4.28E-01	4.28E-01
11 NA 24	1.37E+02	1.37E+02	1.37E+02	1.37E+02	1.37E+02	1.37E+02	1.37E+02
24 CR 51	0.0	0.0	1.25E+00	7.45E-01	2.75E-01	1.66E+00	3.14E+02
25 MN 54	0.0	4.38E+03	8.35E+02	0.0	1.30E+03	0.0	1.34E+04
25 MN 56	0.0	1.78E-01	3.15E-02	0.0	2.25E-01	0.0	5.67E+00
26 FE 55	6.63E+02	4.58E+02	1.07E+02	0.0	0.0	2.56E+02	2.63E+02
26 FE 59	1.03E+03	2.42E+03	9.29E+02	0.0	0.0	6.77E+02	8.08E+03
27 CO 58	0.0	8.97E+01	2.01E+02	0.0	0.0	0.0	1.82E+03
27 CO 60	0.0	2.60E+02	5.74E+02	0.0	0.0	0.0	4.89E+03
28 NI 63	3.14E+04	2.17E+03	1.05E+03	0.0	0.0	0.0	4.54E+02
28 NI 65	2.09E-01	2.72E-02	1.24E-02	0.0	0.0	0.0	6.89E-01
29 CU 64	0.0	2.76E+00	1.30E+00	0.0	6.97E+00	0.0	2.36E+02
30 ZN 65	2.31E+04	7.36E+04	3.32E+04	0.0	4.92E+04	0.0	4.63E+04
30 ZN 69	4.26E-06	8.15E-06	5.67E-07	0.0	5.29E-06	0.0	1.22E-06
35 BR 83	0.0	0.0	4.09E-02	0.0	0.0	0.0	5.89E-02
35 BR 85	0.0	0.0	1.01E-78	0.0	0.0	0.0	0.0
37 RB 86	0.0	9.74E+04	4.54E+04	0.0	0.0	0.0	1.92E+04
37 RB 88	0.0	8.43E-14	4.47E-14	0.0	0.0	0.0	1.16E-24
37 RB 89	0.0	4.82E-16	3.39E-16	0.0	0.0	0.0	2.80E-29
38 SR 89	2.24E+04	0.0	6.43E+02	0.0	0.0	0.0	3.59E+03
38 SR 90	2.83E+05	0.0	7.59E+04	0.0	0.0	0.0	1.61E+04
38 SR 91	7.50E+01	0.0	3.03E+00	0.0	0.0	0.0	3.57E+02
38 SR 92	5.27E-01	0.0	2.28E-02	0.0	0.0	0.0	1.04E+01
39 Y 90	4.60E-01	0.0	1.24E-02	0.0	0.0	0.0	4.88E+03
39 Y 91M	7.42E-09	0.0	2.87E-10	0.0	0.0	0.0	2.18E-08
39 Y 91	8.61E+00	0.0	2.30E-01	0.0	0.0	0.0	4.74E+03
39 Y 92	6.24E-04	0.0	1.82E-05	0.0	0.0	0.0	1.09E+01
39 Y 93	3.30E-02	0.0	9.13E-04	0.0	0.0	0.0	1.05E+03
40 ZR 95	2.96E-01	9.48E-02	6.42E-02	0.0	1.49E-01	0.0	3.00E+02
40 ZR 97	6.93E-03	1.40E-03	6.39E-04	0.0	2.11E-03	0.0	4.33E+02
41 NB 95	4.38E+02	2.44E+02	1.31E+02	0.0	2.41E+02	0.0	1.48E+06
42 MO 99	0.0	8.75E+01	1.66E+01	0.0	1.98E+02	0.0	2.03E+02
43 TC 99M	6.78E-04	1.91E-03	2.44E-02	0.0	2.91E-02	9.38E-04	1.13E+00
43 TC 101	2.60E-19	3.75E-19	3.68E-18	0.0	6.76E-18	1.92E-19	1.13E-30
44 RU 103	4.70E+00	0.0	2.03E+00	0.0	1.79E+01	0.0	5.49E+02
44 RU 105	1.32E-02	0.0	5.21E-03	0.0	1.71E-01	0.0	8.08E+00
44 RU 106	7.10E+01	0.0	8.98E+00	0.0	1.37E+02	0.0	4.59E+03
47 AG 110M	1.18E+00	1.10E+00	6.51E-01	0.0	2.16E+00	0.0	4.47E+02
52 TE 125M	2.54E+03	9.21E+02	3.40E+02	7.64E+02	1.03E+04	0.0	1.01E+04
52 TE 127M	6.45E+03	2.31E+03	7.87E+02	1.65E+03	2.62E+04	0.0	2.16E+04
52 TE 127	1.79E+01	6.41E+00	3.86E+00	1.32E+01	7.27E+01	0.0	1.41E+03
52 TE 129M	1.08E+04	4.03E+03	1.71E+03	3.71E+03	4.51E+04	0.0	5.44E+04
52 TE 129	6.40E-05	2.41E-05	1.56E-05	4.91E-05	2.69E-04	0.0	4.83E-05
52 TE 131M	9.54E+02	4.66E+02	3.89E+02	7.39E+02	4.73E+03	0.0	4.63E+04
52 TE 131	8.48E-11	3.54E-11	2.68E-11	6.97E-11	3.71E-10	0.0	1.20E-11
52 TE 132	1.96E+03	1.26E+03	1.19E+03	1.40E+03	1.22E+04	0.0	5.98E+04
53 I 130	7.79E+00	2.30E+01	9.07E+00	1.95E+03	3.59E+01	0.0	1.98E+01
53 I 131	1.45E+02	2.07E+02	1.19E+02	6.78E+04	3.55E+02	0.0	5.46E+01
53 I 132	1.57E-02	4.21E-02	1.47E-02	1.47E+00	6.71E-02	0.0	7.91E-03
53 I 133	2.48E+01	4.31E+01	1.31E+01	6.33E+03	7.51E+01	0.0	3.87E+01
53 I 135	1.52E+00	3.97E+00	1.47E+00	2.62E+02	6.37E+00	0.0	4.49E+00
55 CS 134	2.98E+05	7.08E+05	5.79E+05	0.0	2.29E+05	7.61E+04	1.24E+04
55 CS 136	2.96E+04	1.17E+05	8.41E+04	0.0	6.50E+04	8.90E+03	1.33E+04
55 CS 137	3.82E+05	5.22E+05	3.42E+05	0.0	1.77E+05	5.89E+04	1.01E+04
55 CS 138	2.03E-08	4.02E-08	1.99E-08	0.0	2.95E-08	2.91E-09	1.71E-13
56 BA 139	4.45E-04	3.17E-07	1.30E-05	0.0	2.96E-07	1.80E-07	7.88E-04
56 BA 140	2.22E+02	2.79E-01	1.45E+01	0.0	9.48E-02	1.60E-01	4.57E+02
56 BA 141	1.25E-13	9.48E-17	4.24E-15	0.0	8.82E-17	5.38E-17	5.91E-23
56 BA 142	2.23E-22	2.29E-25	1.40E-23	0.0	1.94E-25	1.30E-25	3.14E-40
57 LA 140	1.03E-01	5.19E-02	1.37E-02	0.0	0.0	0.0	3.81E+03
57 LA 142	1.26E-06	5.75E-07	1.43E-07	0.0	0.0	0.0	4.20E-03
58 CE 141	3.97E-02	2.68E-02	3.04E-03	0.0	1.25E-02	0.0	1.03E+02
58 CE 143	4.85E-03	3.59E+00	3.97E-04	0.0	1.58E-03	0.0	1.34E+02
58 CE 144	2.10E+00	8.78E-01	1.13E-01	0.0	5.21E-01	0.0	7.10E+02
59 PR 143	5.40E-01	2.17E-01	2.68E-02	0.0	1.25E-01	0.0	2.37E+03
59 PR 144	1.62E-17	6.73E-18	8.24E-19	0.0	3.80E-18	0.0	2.33E-24
60 ND 147	3.65E-01	4.22E-01	2.53E-02	0.0	2.47E-01	0.0	2.03E+03
74 W 187	1.48E+02	1.23E+02	4.32E+01	0.0	0.0	0.0	4.04E+04
93 NP 239	2.32E-02	2.28E-03	1.26E-03	0.0	7.12E-03	0.0	4.68E+02

Table C4.0-3
(2 of 2)

Catawba Nuclear Station
Liquid Effluent Dose - Adult Parameters
A_{aoi} mrem/hr per μCi/ml

From Generic Section 3.1.1:

A_{aoi} = the site related ingestion dose commitment factor for an individual of age group, "a", to organ, "o", for each identified principal gamma and beta emitter, "i", in mrem/hr per μCi/ml

$$A_{aoi} = 1.14E+05 (U_{aw}\sigma_w/D_w \exp(-\lambda_i t_w) + U_{af}\sigma_f B F_i \exp(-\lambda_i t_f)) D F_{aoi}$$

where:

$$1.14E+05 = 10^6 \text{ pCi}/\mu\text{Ci} \times 10^3 \text{ ml/kg} \div 8760 \text{ hr/yr}$$

U_{aw} = Water consumption by age group, l/yr

infant	330
child	510
teen	510
adult	730

σ_w, σ_f = Recirculation factors at equilibrium for the water and fish pathways respectively; these factors account for the fraction of discharged water reused by the station

σ_w = 1.00 σ_f = 1.00

D_w = Dilution factor from the near field area to the potable water intake = 43.4 (4453 cfs + 105 cfs)/(105 cfs)
(Avg Wylie Dam Flow + Avg Radwaste Flow)/(Avg Radwaste Flow)

U_{af} = Fish consumption by age group, kg/yr

infant	---
child	6.9
teen	16
adult	21

B_{F_i} = Bioaccumulation factor for radionuclide, "i", in fish, pCi/kg per pCi/l, from Table 3.1-1

D_{F_{aoi}} = Dose conversion factor for age group, "a", in organ, "o", for radionuclide, "i", in mrem/pCi, from Tables 3.1-2, 3.1-3, 3.1-4, and 3.1-5, respectively

λ_i = radiological decay constant for isotope, i, in 1/hr

t_w, t_f = transport time for the drinking water and fish pathways, hr
t_w = 12 hours t_f = 24 hours

Sample Calculation for Adult, I-131, Thyroid:

$$A(a, \text{thy}, \text{I-131}) = 1.14E5 (730 \cdot 1.0 / 43.4 \cdot \exp(-3.59E-3 \cdot 12) + 21 \cdot 1.0 \cdot 15 \cdot \exp(-3.59E-3 \cdot 24)) \cdot 1.95E-3 = 6.78E4 \text{ mr/hr per } \mu\text{Ci/ml}$$

TABLE C4.0-4
(1 OF 2)

CATAWBA NUCLEAR STATION
LIQUID EFFLUENT DOSE - TEEN PARAMETERS
A(I) MREM/HR PER UCI/ML

RADIONUCLIDE		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
1	H 3	0.0	3.16E-01	3.16E-01	3.16E-01	3.16E-01	3.16E-01	3.16E-01
11	NA 24	1.41E+02	1.41E+02	1.41E+02	1.41E+02	1.41E+02	1.41E+02	1.41E+02
24	CR 51	0.0	0.0	1.29E+00	7.14E-01	2.82E-01	1.84E+00	2.16E+02
25	MN 54	0.0	4.30E+03	8.53E+02	0.0	1.28E+03	0.0	8.82E+03
25	MN 56	0.0	1.85E-01	3.29E-02	0.0	2.34E-01	0.0	1.22E+01
26	FE 55	6.94E+02	4.92E+02	1.15E+02	0.0	0.0	3.12E+02	2.13E+02
26	FE 59	1.06E+03	2.48E+03	9.57E+02	0.0	0.0	7.82E+02	5.86E+03
27	CO 58	0.0	8.91E+01	2.05E+02	0.0	0.0	2.05E+02	1.23E+03
27	CO 60	0.0	2.60E+02	5.86E+02	0.0	0.0	0.0	3.39E+03
28	NI 63	3.25E+04	2.30E+03	1.10E+03	0.0	0.0	0.0	3.66E+02
28	NI 65	2.23E-01	2.84E-02	1.30E-02	0.0	0.0	0.0	1.54E+00
29	CU 64	0.0	2.90E+00	1.36E+00	0.0	7.34E+00	0.0	2.25E+02
30	ZN 65	2.10E+04	7.28E+04	3.40E+04	0.0	4.66E+04	0.0	3.08E+04
30	ZN 69	4.35E-06	8.29E-06	5.81E-07	0.0	5.42E-06	0.0	1.53E-05
35	BR 83	0.0	0.0	4.43E-02	0.0	0.0	0.0	0.0
35	BR 85	0.0	0.0	1.01E-78	0.0	0.0	0.0	0.0
37	RB 86	0.0	1.05E+05	4.92E+04	0.0	0.0	0.0	1.55E+04
37	RB 88	0.0	8.29E-14	4.42E-14	0.0	0.0	0.0	7.11E-21
37	RB 89	0.0	4.62E-16	3.27E-16	0.0	0.0	0.0	7.09E-25
38	SR 89	2.43E+04	0.0	6.97E+02	0.0	0.0	0.0	2.90E+03
38	SR 90	2.51E+05	0.0	6.73E+04	0.0	0.0	0.0	1.31E+04
38	SR 91	8.09E+01	0.0	3.22E+00	0.0	0.0	0.0	3.67E+02
38	SR 92	5.52E-01	0.0	2.35E-02	0.0	0.0	0.0	1.41E+01
39	Y 90	4.98E-01	0.0	1.34E-02	0.0	0.0	0.0	4.11E+03
39	Y 91M	7.36E-09	0.0	2.81E-10	0.0	0.0	0.0	3.47E-07
39	Y 91	9.33E+00	0.0	2.50E-01	0.0	0.0	0.0	3.82E+03
39	Y 92	6.66E-04	0.0	1.93E-05	0.0	0.0	0.0	1.83E+01
39	Y 93	3.58E-02	0.0	9.81E-04	0.0	0.0	0.0	1.09E+03
40	ZR 95	3.00E-01	9.47E-02	6.51E-02	0.0	1.39E-01	0.0	2.19E+02
40	ZR 97	7.27E-03	1.44E-03	6.62E-04	0.0	2.18E-03	0.0	3.89E+02
41	NB 95	4.41E+02	2.45E+02	1.35E+02	0.0	2.37E+02	0.0	1.05E+06
42	MO 99	0.0	9.26E+01	1.77E+01	0.0	2.12E+02	0.0	1.66E+02
43	TC 99M	6.84E-04	1.91E-03	2.47E-02	0.0	2.84E-02	1.06E-03	1.25E+00
43	TC 101	2.58E-19	3.67E-19	3.60E-18	0.0	6.63E-18	2.23E-19	6.27E-26
44	RU 103	4.91E+00	0.0	2.10E+00	0.0	1.73E+01	0.0	4.10E+02
44	RU 105	1.38E-02	0.0	5.37E-03	0.0	1.74E-01	0.0	1.12E+01
44	RU 106	7.66E+01	0.0	9.65E+00	0.0	1.48E+02	0.0	3.67E+03
47	AG 110M	1.13E+00	1.07E+00	6.52E-01	0.0	2.04E+00	0.0	3.01E+02
52	TE 125M	2.77E+03	9.97E+02	3.70E+02	7.73E+02	0.0	0.0	8.16E+03
52	TE 127M	7.02E+03	2.49E+03	8.35E+02	1.67E+03	2.85E+04	0.0	1.75E+04
52	TE 127	1.95E+01	6.92E+00	4.20E+00	1.35E+01	7.91E+01	0.0	1.51E+03
52	TE 129M	1.17E+04	4.33E+03	1.85E+03	3.77E+03	4.88E+04	0.0	4.38E+04
52	TE 129	6.54E-05	2.44E-05	1.59E-05	4.67E-05	2.75E-04	0.0	3.58E-04
52	TE 131M	1.02E+03	4.91E+02	4.10E+02	7.39E+02	5.12E+03	0.0	3.94E+04
52	TE 131	8.39E-11	3.46E-11	2.62E-11	6.46E-11	3.67E-10	0.0	6.88E-12
52	TE 132	2.06E+03	1.31E+03	1.23E+03	1.38E+03	1.25E+04	0.0	4.14E+04
53	I 130	8.02E+00	2.32E+01	9.27E+00	1.89E+03	3.58E+01	0.0	1.78E+01
53	I 131	1.54E+02	2.16E+02	1.16E+02	6.31E+04	3.72E+02	0.0	4.27E+01
53	I 132	1.56E-02	4.07E-02	1.46E-02	1.37E+00	6.42E-02	0.0	1.78E-02
53	I 133	2.65E+01	4.50E+01	1.37E+01	6.28E+03	7.89E+01	0.0	3.41E+01
53	I 135	1.57E+00	4.04E+00	1.50E+00	2.60E+02	6.38E+00	0.0	4.48E+00
55	CS 134	3.05E+05	7.18E+05	3.33E+05	0.0	2.28E+05	8.71E+04	8.93E+03
55	CS 136	2.97E+04	1.17E+05	7.86E+04	0.0	6.37E+04	1.00E+04	9.42E+03
55	CS 137	4.09E+05	5.44E+05	1.89E+05	0.0	1.85E+05	7.19E+04	7.74E+03
55	CS 138	2.00E-08	3.84E-08	1.92E-08	0.0	2.83E-08	3.29E-09	1.74E-11
56	BA 139	4.46E-04	3.14E-07	1.30E-05	0.0	2.96E-07	2.16E-07	3.98E-03
56	BA 140	2.33E+02	2.86E-01	1.50E+01	0.0	9.69E-02	1.92E-01	3.60E+02
56	BA 141	1.25E-13	9.32E-17	4.17E-15	0.0	8.65E-17	6.38E-17	2.66E-19
56	BA 142	2.19E-22	2.19E-25	1.35E-23	0.0	1.85E-25	1.46E-25	6.72E-34
57	LA 140	1.09E-01	5.35E-02	1.42E-02	0.0	0.0	0.0	3.07E+03
57	LA 142	1.25E-06	5.55E-07	1.38E-07	0.0	0.0	0.0	1.69E-02
58	CE 141	4.14E-02	3.76E-02	3.17E-03	0.0	1.30E-02	0.0	7.90E+01
58	CE 143	5.04E-03	3.67E+00	4.10E-04	0.0	1.65E-03	0.0	1.10E+02
58	CE 144	2.20E+00	9.09E-01	1.18E-01	0.0	5.43E-01	0.0	5.53E+02
59	PR 143	5.85E-01	2.33E-01	2.91E-02	0.0	1.36E-01	0.0	1.92E+03
59	PR 144	1.62E-17	6.62E-18	8.20E-19	0.0	3.80E-18	0.0	1.78E-20
60	ND 147	4.14E-01	4.50E-01	2.70E-02	0.0	2.64E-01	0.0	1.62E+03
74	W 187	1.60E+02	1.30E+02	4.56E+01	0.0	0.0	0.0	3.52E+04
93	NP 239	2.60E-02	2.45E-03	1.36E-03	0.0	7.69E-03	0.0	3.94E+02

Table C4.0-4
(2 of 2)

Catawba Nuclear Station
Liquid Effluent Dose - Teen Parameters
A_{aoi} mrem/hr per μCi/ml

From Generic Section 3.1.1:

A_{aoi} = the site related ingestion dose commitment factor for an individual of age group, "a", to organ, "o", for each identified principal gamma and beta emitter, "i", in mrem/hr per μCi/ml

$$A_{aoi} = 1.14E+05 (U_{aw}\sigma_w/D_w \exp(-\lambda_i t_w) + U_{af}\sigma_f B F_i \exp(-\lambda_i t_f)) D F_{aoi}$$

where:

$$1.14E+05 = 10^6 \text{ pCi}/\mu\text{Ci} \times 10^3 \text{ ml/kg} \div 8760 \text{ hr/yr}$$

U_{aw} = Water consumption by age group, l/yr

infant	330
child	510
teen	510
adult	730

σ_w, σ_f = Recirculation factors at equilibrium for the water and fish pathways respectively; these factors account for the fraction of discharged water reused by the station

σ_w = 1.00 σ_f = 1.00

D_w = Dilution factor from the near field area to the potable water intake = 43.4 (4453 cfs + 105 cfs)/(105 cfs)
(Avg Wylie Dam Flow + Avg Radwaste Flow)/(Avg Radwaste Flow)

U_{af} = Fish consumption by age group, kg/yr

infant	---
child	6.9
teen	16
adult	21

B_{F_i} = Bioaccumulation factor for radionuclide, "i", in fish, pCi/kg per pCi/l, from Table 3.1-1

D_{F_{aoi}} = Dose conversion factor for age group, "a", in organ, "o", for radionuclide, "i", in mrem/pCi, from Tables 3.1-2, 3.1-3, 3.1-4, and 3.1-5, respectively

λ_i = radiological decay constant for isotope, i, in 1/hr

t_w, t_f = transport time for the drinking water and fish pathways, hr
t_w = 12 hours t_f = 24 hours

Sample Calculation for Teen, I-131, Thyroid:

$$A(t, \text{thy}, \text{I-131}) = 1.14E5 (510 \cdot 1.0 / 43.4 \cdot \exp(-3.59E-3 \cdot 12) + 16 \cdot 1.0 \cdot 15 \cdot \exp(-3.59E-3 \cdot 24)) \cdot 2.39E-3 = 6.31E4 \text{ mr/hr per } \mu\text{Ci/ml}$$

TABLE C4.0-5
(1 OF 2)

CATAWBA NUCLEAR STATION
LIQUID EFFLUENT DOSE - CHILD PARAMETERS
A(I) MREM/HR PER UCI/ML

RADIONUCLIDE		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
1	H 3	0.0	4.16E-01	4.16E-01	4.16E-01	4.16E-01	4.16E-01	4.16E-01
11	NA 24	1.55E+02	1.55E+02	1.55E+02	1.55E+02	1.55E+02	1.55E+02	1.55E+02
24	CR 51	0.0	0.0	1.38E+00	7.64E-01	2.09E-01	1.40E+00	7.30E+01
25	MN 54	0.0	3.37E+03	8.99E+02	0.0	9.46E+02	0.0	2.83E+03
25	MN 56	0.0	1.79E-01	4.03E-02	0.0	2.16E-01	0.0	2.59E+01
26	FE 55	9.19E+02	4.88E+02	1.51E+02	0.0	0.0	2.76E+02	9.03E+01
26	FE 59	1.30E+03	2.10E+03	1.05E+03	0.0	0.0	6.10E+02	2.19E+03
27	CO 58	0.0	7.25E+01	2.22E+02	0.0	0.0	0.0	4.23E+02
27	CO 60	0.0	2.15E+02	6.34E+02	0.0	0.0	0.0	1.19E+03
28	NI 63	4.30E+04	2.30E+03	1.46E+03	0.0	0.0	0.0	1.55E+02
28	NI 65	3.47E-01	3.27E-02	1.91E-02	0.0	0.0	0.0	4.00E+00
29	CU 64	0.0	2.76E+09	1.67E+00	0.0	6.67E+00	0.0	1.30E+02
30	ZN 65	2.15E+04	5.73E+04	3.56E+04	0.0	3.61E+04	0.0	1.01E+04
30	ZN 69	1.08E-05	1.56E-05	1.44E-06	0.0	9.45E-06	0.0	9.82E-04
35	BR 83	0.0	0.0	6.10E-02	0.0	0.0	0.0	0.0
35	BR 85	0.0	0.0	3.01E-78	0.0	0.0	0.0	0.0
37	RB 86	0.0	1.02E+05	6.25E+04	0.0	0.0	0.0	6.54E+03
37	RB 88	0.0	1.85E-13	1.28E-13	0.0	0.0	0.0	9.07E-15
37	RB 89	0.0	9.83E-16	8.74E-16	0.0	0.0	0.0	8.57E-18
38	SR 89	3.25E+04	0.0	9.28E+02	0.0	0.0	0.0	1.26E+03
38	SR 90	2.82E+05	0.0	7.56E+04	0.0	0.0	0.0	5.71E+03
38	SR 91	1.11E+02	0.0	4.21E+00	0.0	0.0	0.0	2.46E+02
38	SR 92	1.02E+00	0.0	4.11E-02	0.0	0.0	0.0	1.94E+01
39	Y 90	6.72E-01	0.0	1.80E-02	0.0	0.0	0.0	1.91E+03
39	Y 91M	2.18E-08	0.0	7.92E-10	0.0	0.0	0.0	4.26E-05
39	Y 91	1.25E+01	0.0	3.34E-01	0.0	0.0	0.0	1.67E+03
39	Y 92	1.12E-03	0.0	3.20E-05	0.0	0.0	0.0	3.23E+01
39	Y 93	4.97E-02	0.0	1.37E-03	0.0	0.0	0.0	7.42E+02
40	ZR 95	4.52E-01	9.95E-02	8.85E-02	0.0	1.42E-01	0.0	1.04E+02
40	ZR 97	1.25E-02	1.81E-03	1.07E-03	0.0	2.59E-03	0.0	2.74E+02
41	NB 95	5.21E+02	2.03E+02	1.45E+02	0.0	1.90E+02	0.0	3.75E+05
42	MO 99	0.0	9.70E+01	2.40E+01	0.0	2.07E+02	0.0	8.02E+01
43	TC 99M	9.96E-04	1.95E-03	3.24E-02	0.0	2.84E-02	9.92E-04	1.11E+00
43	TC 101	7.66E-19	8.02E-19	1.02E-17	0.0	1.37E-17	4.24E-19	2.55E-18
44	RU 103	6.62E+00	0.0	2.54E+00	0.0	1.67E+01	0.0	1.71E+02
44	RU 105	2.52E-02	0.0	9.14E-03	0.0	2.21E-01	0.0	1.64E+01
44	RU 106	1.08E+02	0.0	1.34E+01	0.0	1.45E+02	0.0	1.67E+03
47	AG 110M	1.69E+00	1.14E+00	9.14E-01	0.0	2.13E+00	0.0	1.36E+02
52	TE 125M	3.56E+03	9.65E+02	4.75E+02	9.99E+02	0.0	0.0	3.43E+03
52	TE 127M	9.07E+03	2.44E+03	1.08E+03	2.17E+03	2.59E+04	0.0	7.35E+03
52	TE 127	2.53E+01	6.81E+00	5.42E+00	1.75E+01	7.18E+01	0.0	9.87E+02
52	TE 129M	1.51E+04	4.21E+03	2.34E+03	4.86E+03	4.43E+04	0.0	1.84E+04
52	TE 129	1.63E-04	4.54E-05	3.86E-05	1.16E-04	4.76E-04	0.0	1.01E-02
52	TE 131M	1.31E+03	4.52E+02	4.81E+02	9.30E+02	4.38E+03	0.0	1.84E+04
52	TE 131	2.49E-10	7.60E-11	7.42E-11	1.91E-10	7.54E-10	0.0	1.31E-09
52	TE 132	2.58E+03	1.14E+03	1.38E+03	1.66E+03	1.06E+04	0.0	1.15E+04
53	I 130	1.09E+01	2.21E+01	1.14E+01	2.44E+03	3.31E+01	0.0	1.03E+01
53	I 131	2.08E+02	2.09E+02	1.19E+02	6.93E+04	3.44E+02	0.0	1.86E+01
53	I 132	3.57E-02	6.55E-02	3.01E-02	3.04E+00	1.00E-01	0.0	7.71E-02
53	I 133	3.67E+01	4.54E+01	1.72E+01	8.44E+03	7.57E+01	0.0	1.83E+01
53	I 135	2.32E+00	4.18E+00	1.98E+00	3.70E+02	6.40E+00	0.0	3.18E+00
55	CS 134	3.68E+05	6.04E+05	1.27E+05	0.0	1.87E+05	6.72E+04	3.26E+03
55	CS 136	3.51E+04	9.65E+04	6.24E+04	0.0	5.14E+04	7.66E+03	3.39E+03
55	CS 137	5.15E+05	4.93E+05	7.27E+04	0.0	1.61E+05	5.78E+04	3.09E+03
55	CS 138	5.87E-08	8.16E-08	5.17E-08	0.0	5.74E-08	6.18E-09	3.76E-08
56	BA 139	1.32E-03	7.03E-07	3.82E-05	0.0	6.14E-07	4.14E-07	7.61E-02
56	BA 140	3.56E+02	3.12E-01	2.08E+01	0.0	1.02E-01	1.86E-01	1.80E+02
56	BA 141	3.72E-13	2.08E-16	1.21E-14	0.0	1.80E-16	1.22E-15	2.12E-13
56	BA 142	6.40E-22	4.60E-25	3.57E-23	0.0	3.73E-25	2.71E-25	8.35E-24
57	LA 140	1.42E-01	4.98E-02	1.68E-02	0.0	0.0	0.0	1.39E+03
57	LA 142	3.38E-06	1.08E-06	3.37E-07	0.0	0.0	0.0	2.14E-01
58	CE 141	8.32E-02	4.15E-02	6.16E-03	0.0	1.82E-02	0.0	5.18E+01
58	CE 143	1.06E-02	5.75E+00	8.34E-04	0.0	2.41E-03	0.0	8.43E+01
58	CE 144	4.42E+00	1.38E+00	2.36E-01	0.0	7.66E-01	0.0	3.61E+02
59	PR 143	7.86E-01	2.36E-01	3.90E-02	0.0	1.28E-01	0.0	8.48E+02
59	PR 144	4.85E-17	1.50E-17	2.44E-18	0.0	7.94E-18	0.0	3.23E-14
60	ND 147	5.52E-01	4.47E-01	3.46E-02	0.0	2.45E-01	0.0	7.08E+02
74	W 187	2.02E+02	1.20E+02	5.38E+01	0.0	0.0	0.0	1.68E+04
93	NP 239	3.69E-02	2.65E-03	1.86E-03	0.0	7.65E-03	0.0	1.96E+02

Table C4.0-5
(2 of 2)

Catawba Nuclear Station
Liquid Effluent Dose - Child Parameters
A_{aoi} mrem/hr per μCi/ml

From Generic Section 3.1.1:

A_{aoi} = the site related ingestion dose commitment factor for an individual of age group, "a", to organ, "o", for each identified principal gamma and beta emitter, "i", in mrem/hr per μCi/ml

$$A_{aoi} = 1.14E+05 (U_{aw}\sigma_w/D_w \exp(-\lambda_i t_w) + U_{af}\sigma_f B F_i \exp(-\lambda_i t_f)) D F_{aoi}$$

where:

$$1.14E+05 = 10^6 \text{ pCi}/\mu\text{Ci} \times 10^3 \text{ ml}/\text{kg} \div 8760 \text{ hr}/\text{yr}$$

U_{aw} = Water consumption by age group, l/yr

infant	330
child	510
teen	510
adult	730

σ_w, σ_f = Recirculation factors at equilibrium for the water and fish pathways respectively; these factors account for the fraction of discharged water reused by the station

σ_w = 1.00 σ_f = 1.00

D_w = Dilution factor from the near field area to the potable water intake = 43.4 (4453 cfs + 105 cfs)/(105 cfs)
(Avg Wylie Dam Flow + Avg Radwaste Flow)/(Avg Radwaste Flow)

U_{af} = Fish consumption by age group, kg/yr

infant	---
child	6.9
teen	16
adult	21

B_{F_i} = Bioaccumulation factor for radionuclide, "i", in fish, pCi/kg per pCi/l, from Table 3.1-1

D_{F_{aoi}} = Dose conversion factor for age group, "a", in organ, "o", for radionuclide, "i", in mrem/pCi, from Tables 3.1-2, 3.1-3, 3.1-4, and 3.1-5, respectively

λ_i = radiological decay constant for isotope, i, in 1/hr

t_w, t_f = transport time for the drinking water and fish pathways, hr
t_w = 12 hours t_f = 24 hours

Sample Calculation for Child, I-131, Thyroid:

$$A(c, \text{thy}, \text{I-131}) = 1.14E5 (510 \cdot 1.0 / 43.4 \cdot \exp(-3.59E-3 \cdot 12)) + 6.9 \cdot 1.0 \cdot 15 \cdot \exp(-3.59E-3 \cdot 24) \cdot 5.72E-3 = 6.93E4 \text{ mr}/\text{hr per } \mu\text{Ci}/\text{ml}$$

TABLE C4.0-6
(1 OF 2)

CATAWBA NUCLEAR STATION
LIQUID EFFLUENT DOSE - INFANT PARAMETERS
A(I) MREM/HR PER UCI/ML

RADIONUCLIDE		BONE	LIVER	TOTAL BODY	THYROID	KIDNEY	LUNG	GI-LLI
1	H 3	0.0	2.67E-01	2.67E-01	2.67E-01	2.67E-01	2.67E-01	2.67E-01
11	NA 24	5.04E+00	5.04E+00	5.04E+00	5.04E+00	5.04E+00	5.04E+00	5.04E+00
24	CR 51	0.0	0.0	1.21E-02	7.88E-03	1.72E-03	1.53E-02	3.52E-01
25	MN 54	0.0	1.72E+01	3.91E+00	0.0	3.82E+00	0.0	6.33E+00
25	MN 56	0.0	2.78E-02	4.79E-03	0.0	2.39E-02	0.0	2.52E+00
26	FE 55	1.20E+01	7.78E+00	2.08E+00	0.0	0.0	3.80E+00	9.88E-01
26	FE 59	2.65E+01	4.63E+01	1.82E+01	0.0	0.0	1.37E+01	2.21E+01
27	CO 58	0.0	3.11E+00	7.75E+00	0.0	0.0	0.0	7.74E+00
27	CO 60	0.0	9.36E+00	2.21E+01	0.0	0.0	0.0	2.23E+01
28	NI 63	5.50E+02	3.40E+01	1.91E+01	0.0	0.0	0.0	1.69E+00
28	NI 65	1.50E-01	1.70E-02	7.73E-03	0.0	0.0	0.0	1.29E+00
29	CU 64	0.0	2.74E-01	1.27E-01	0.0	4.63E-01	0.0	5.62E+00
30	ZN 65	1.59E+01	5.46E+01	2.52E+01	0.0	2.65E+01	0.0	4.61E+01
30	ZN 69	1.26E-05	2.26E-05	1.68E-06	0.0	9.40E-06	0.0	1.85E-03
35	BR 83	0.0	0.0	9.72E-03	0.0	0.0	0.0	0.0
35	BR 85	0.0	0.0	4.14E-78	0.0	0.0	0.0	0.0
37	RB 86	0.0	1.45E+02	7.15E+01	0.0	0.0	0.0	3.70E+00
37	RB 88	0.0	3.14E-13	1.72E-13	0.0	0.0	0.0	3.05E-13
37	RB 89	0.0	1.56E-15	1.07E-15	0.0	0.0	0.0	5.30E-16
38	SR 89	2.16E+03	0.0	6.20E+01	0.0	0.0	0.0	4.44E+01
38	SR 90	1.08E+04	0.0	2.92E+03	0.0	0.0	0.0	2.00E+02
38	SR 91	1.80E+01	0.0	6.53E-01	0.0	0.0	0.0	2.13E+01
38	SR 92	7.75E-01	0.0	2.88E-02	0.0	0.0	0.0	8.35E+00
39	Y 90	6.62E-02	0.0	1.77E-03	0.0	0.0	0.0	9.14E+01
39	Y 91M	2.99E-08	0.0	1.02E-09	0.0	0.0	0.0	9.95E-05
39	Y 91	9.74E-01	0.0	2.59E-02	0.0	0.0	0.0	6.98E+01
39	Y 92	6.38E-04	0.0	1.79E-05	0.0	0.0	0.0	1.22E+01
39	Y 93	9.23E-03	0.0	2.51E-04	0.0	0.0	0.0	7.29E+01
40	ZR 95	1.78E-01	4.33E-02	3.07E-02	0.0	4.66E-02	0.0	2.16E+01
40	ZR 97	7.84E-03	1.35E-03	6.14E-04	0.0	1.36E-03	0.0	8.58E+01
41	NB 95	3.60E-02	1.48E-02	8.58E-03	0.0	1.06E-02	0.0	1.25E+01
42	MO 99	0.0	2.60E+01	5.07E+00	0.0	3.88E+01	0.0	8.56E+00
43	TC 99M	4.18E-04	8.62E-04	1.11E-02	0.0	9.27E-03	4.50E-04	2.50E-01
43	TC 101	1.05E-18	1.33E-18	1.31E-17	0.0	1.58E-17	7.23E-19	2.25E-16
44	RU 103	1.27E+00	0.0	4.25E-01	0.0	2.65E+00	0.0	1.55E+01
44	RU 105	1.81E-02	0.0	6.09E-03	0.0	1.33E-01	0.0	7.19E+00
44	RU 106	2.09E+01	0.0	2.61E+00	0.0	2.47E+01	0.0	1.58E+02
47	AG 110M	8.62E-01	6.29E-01	4.16E-01	0.0	9.00E-01	0.0	3.26E+01
52	TE 125M	2.01E+01	6.71E+00	2.71E+00	6.76E+00	0.0	0.0	9.56E+00
52	TE 127M	5.05E+01	1.68E+01	6.12E+00	1.46E+01	1.24E+02	0.0	2.04E+01
52	TE 127	3.56E-01	1.19E-01	7.65E-02	2.90E-01	8.69E-01	0.0	7.48E+00
52	TE 129M	8.58E+01	2.94E+01	1.32E+01	3.29E+01	2.14E+02	0.0	5.12E+01
52	TE 129	1.89E-04	6.52E-05	4.42E-05	1.59E-04	4.71E-04	0.0	1.51E-02
52	TE 131M	9.98E+00	4.02E+00	3.32E+00	8.15E+00	2.77E+01	0.0	6.77E+01
52	TE 131	3.42E-10	1.26E-10	9.61E-11	3.05E-10	8.75E-10	0.0	1.38E-08
52	TE 132	1.62E+01	8.03E+00	7.49E+00	1.18E+01	5.02E+01	0.0	2.97E+01
53	I 130	2.65E+00	5.83E+00	2.34E+00	6.54E+02	6.41E+00	0.0	1.25E+00
53	I 131	2.98E+01	3.51E+01	1.54E+01	1.15E+04	4.10E+01	0.0	1.25E+00
53	I 132	3.87E-02	7.86E-02	2.80E-02	3.68E+00	8.77E-02	0.0	6.36E-02
53	I 133	7.27E+00	1.06E+01	3.10E+00	1.92E+03	1.24E+01	0.0	1.79E+00
53	I 135	8.94E-01	1.78E+00	6.48E-01	1.59E+02	1.98E+00	0.0	6.43E-01
55	CS 134	3.27E+02	6.09E+02	6.15E+01	0.0	1.57E+02	6.43E+01	1.65E+00
55	CS 136	3.87E+01	1.14E+02	4.25E+01	0.0	4.54E+01	9.29E+00	1.73E+00
55	CS 137	4.52E+02	5.30E+02	3.75E+01	0.0	1.42E+02	5.76E+01	1.66E+00
55	CS 138	8.01E-08	1.30E-07	6.31E-08	0.0	6.49E-08	1.01E-08	2.08E-07
56	BA 139	1.80E-03	1.20E-06	5.22E-05	0.0	7.19E-07	7.25E-07	1.14E-01
56	BA 140	1.44E+02	1.44E-01	7.43E+00	0.0	3.43E-02	8.86E-02	3.54E+01
56	BA 141	5.12E-13	3.50E-16	1.61E-14	0.0	2.11E-16	2.13E-16	6.25E-12
56	BA 142	8.72E-22	7.25E-25	4.29E-23	0.0	4.17E-25	4.39E-25	3.60E-21
57	LA 140	1.49E-02	5.87E-03	1.51E-03	0.0	0.0	0.0	6.89E+01
57	LA 142	4.31E-06	1.58E-06	3.79E-07	0.0	0.0	0.0	2.69E-01
58	CE 141	6.75E-02	4.12E-02	4.85E-03	0.0	1.27E-02	0.0	2.13E+01
58	CE 143	9.98E-03	6.62E+00	7.55E-04	0.0	1.93E-03	0.0	3.86E+01
58	CE 144	2.58E+00	1.06E+00	1.45E-01	0.0	4.27E-01	0.0	1.48E+02
59	PR 143	6.87E-02	2.57E-02	3.41E-03	0.0	9.55E-03	0.0	3.63E+01
59	PR 144	6.67E-17	2.58E-17	3.36E-18	0.0	9.35E-18	0.0	1.20E-12
60	ND 147	4.65E-02	4.77E-02	2.92E-03	0.0	1.84E-02	0.0	3.02E+01
74	W 187	5.53E-01	3.84E-01	1.33E-01	0.0	0.0	0.0	2.26E+01
93	NP 239	8.31E-03	7.43E-04	4.20E-04	0.0	1.48E-03	0.0	2.15E+01

Table C4.0-6
(2 of 2)

Catawba Nuclear Station
Liquid Effluent Dose - Infant Parameters
 $A_{a oi}$ mrem/hr per $\mu\text{Ci/ml}$

From Generic Section 3.1.1:

$A_{a oi}$ = the site related ingestion dose commitment factor for an individual of age group, "a", to organ, "o", for each identified principal gamma and beta emitter, "i", in mrem/hr per $\mu\text{Ci/ml}$

$$A_{a oi} = 1.14E+05 (U_{aw}\sigma_w/D_w \exp(-\lambda_i t_w) + U_{af}\sigma_f B F_i \exp(-\lambda_i t_f)) D F_{a oi}$$

where:

$$1.14E+05 = 10^6 \text{ pCi}/\mu\text{Ci} \times 10^3 \text{ ml/kg} \div 8760 \text{ hr/yr}$$

U_{aw} = Water consumption by age group, l/yr

infant	330
child	510
teen	510
adult	730

σ_w, σ_f = Recirculation factors at equilibrium for the water and fish pathways respectively; these factors account for the fraction of discharged water reused by the station

$\sigma_w = 1.00$ $\sigma_f = 1.00$

D_w = Dilution factor from the near field area to the potable water intake = $43.4 (4453 \text{ cfs} + 105 \text{ cfs}) / (105 \text{ cfs})$
(Avg Wylie Dam Flow + Avg Radwaste Flow) / (Avg Radwaste Flow)

U_{af} = Fish consumption by age group, kg/yr

infant	---
child	6.9
teen	16
adult	21

$B F_i$ = Bioaccumulation factor for radionuclide, "i", in fish, pCi/kg per pCi/l, from Table 3.1-1

$D F_{a oi}$ = Dose conversion factor for age group, "a", in organ, "o", for radionuclide, "i", in mrem/pCi, from Tables 3.1-2, 3.1-3, 3.1-4, and 3.1-5, respectively

λ_i = radiological decay constant for isotope, i, in 1/hr

t_w, t_f = transport time for the drinking water and fish pathways, hr
 $t_w = 12$ hours $t_f = 24$ hours

Sample Calculation for Infant, I-131, Thyroid:

$$A(i, \text{thy}, \text{I-131}) = 1.14E5 (330 * 1.0 / 43.4 * \exp(-3.59E-3 * 12) + 0 * 1.0 * 15 * \exp(-3.59E-3 * 24)) 1.39E-2 = 1.15E4 \text{ mr/hr per } \mu\text{Ci/ml}$$

Table C4.0-7 - Meteorological Parameter and Applicable Pathways
 for Potential Worst-Case Offsite Locations for Analyzing
 Offsite Doses From Particulates, Iodine and Other
 Radionuclides

Ground Level Release Worst-Case Locations

	(\bar{X}/\bar{Q})	(\bar{D}/\bar{Q})
	sec/m ³	1/m ²
(1) Inhalation, 0.66 mi, NNE	3.510E-05	1.078E-07
(2) Garden, 0.65 mi, NE	2.927E-05	7.653E-08
(3) Meat Animal, 1.10 mi, WNW	9.193E-07	2.654E-09
(4) Milk Animal, 5.0 mi, NNE	4.503E-07	7.260E-10
(5) Combination, 0.65 mi, NE	2.927E-05	7.653E-08

Table C4.0-7
 (1 of 1)

TABLE C4.0-8

PATHWAY APPLICABILITY FOR ALL LOCATIONS BASED ON SITE SURVEY*
 CATAWBA NUCLEAR STATION
 (1 of 1)

SECTOR	Distance to the control location in miles									
	0-0.5	0.5-1.0	1.0-1.5	1.5-2.0	2.0-2.5	2.5-3.0	3.0-3.5	3.5-4.0	4.0-4.5	4.5-5.0
N	X	I	I	VI	VI	VI	VI	VI	VI	VIMG
NNE	X	I	I	VI	VI	VI	VI	VI	VI	VIMG
NE	X	VI	VIMG							
ENE	X	VI	VIM	VIMG						
E	X	VI	VIMG							
ESE	X	I	I	I	I	I	I	VI	VI	VIMG
SE	X	I	I	VI	VI	VI	VI	VI	VI	VIMG
SSE	X	I	I	VI	VI	VI	VI	VI	VI	VIMG
S	X	VI	VIM	VIMG						
SSW	X	VI	VI	VI	VI	VI	VIM	VIM	VIM	VIMG
SW	X	VI	VI	VI	VI	VIM	VIM	VIM	VIM	VIMG
WSW	X	I	I	I	VI	VIM	VIM	VIM	VIM	VIMG
W	X	VI	VIMG							
WNW	X	X	VIM	VIMG						
NW	X	X	VI	VI	VIM	VIM	VIM	VIM	VIM	VIMG
NNW	X	X	I	I	VIM	VIM	VIM	VIM	VIM	VIMG

PATHWAYS: X - None V - VEGETABLE M - MEAT G - GOAT MILK C - COW MILK I - INHALATION/GROUND

* The land use census identifies nearest pathways to the site. Locations beyond the nearest pathway are assumed to contain that pathway for dose calculation purposes.

Figure C4.0-1 - Fuel Cycle Dose Calculation Worksheet for Potential Worst-Case Offsite Locations

Ground Level Release Worst-Case Locations

	$(\overline{X/Q})$	$(\overline{D/Q})$
	sec/m ³	1/m ²
(1) Inhalation, 0.66 mi, NNE	3.510E-05	1.078E-07
(2) Garden, 0.65 mi, NE	2.927E-05	7.653E-08
(3) Meat Animal, 1.10 mi, WNW	9.193E-07	2.654E-09
(4) Milk Animal, 5.0 MI, NNE	4.503E-07	7.260E-10
(5) Combination, 0.65 mi, NE	2.927E-05	7.653E-08

Figure C4.0-1
(1 of 10)

Figure C4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for
Organ Doses

Adult Age Group

Location 1 - Worst-Case Inhalation/Ground Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-Case Meat Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 4 - Worst-Case Milk Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Figure C4.0-1
(2 of 10)

Figure C4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for
Organ Doses

Location S_1 - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
$D_{a,o}(l)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(g)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(T)$	_____	_____	_____	_____	_____	_____	_____

Location S_2 - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
$D_{a,o}(l)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(g)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(T)$	_____	_____	_____	_____	_____	_____	_____

Location S_N - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
$D_{a,o}(l)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(g)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(T)$	_____	_____	_____	_____	_____	_____	_____

Adult Organ Maximums**

Maximum Total

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
$D_{a,o}(T_{max})$	_____	_____	_____	_____	_____	_____	_____

Figure C4.0-1
(3 of 10)

Figure C4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for Organ Doses

Teen Age Group

Location 1 - Worst-Case Inhalation/Ground Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-Case Meat Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 4 - Worst-Case Milk Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Figure C4.0-1
(4 of 10)

Figure C4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for Organ Doses

Location 5₁ - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 5₂ - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 5_N - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Teen Organ Maximums**

Maximum Total

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (T _{max})	_____	_____	_____	_____	_____	_____	_____

Figure C4.0-1
(5 of 10)

Figure C4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for Organ Doses

Child Age Group

Location 1 - Worst-Case Inhalation/Ground Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-Case Meat Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 4 - Worst-Case Milk Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Figure C4.0-1
(6 of 10)

Figure C4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for Organ Doses

Location S_1 - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
$D_{a,o}(l)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(g)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(T)$	_____	_____	_____	_____	_____	_____	_____

Location S_2 - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
$D_{a,o}(l)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(g)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(T)$	_____	_____	_____	_____	_____	_____	_____

Location S_N - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
$D_{a,o}(l)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(g)$	_____	_____	_____	_____	_____	_____	_____
$D_{a,o}(T)$	_____	_____	_____	_____	_____	_____	_____

Child Organ Maximums**

Maximum Total

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
$D_{a,o}(T_{max})$	_____	_____	_____	_____	_____	_____	_____

Figure C4.0-1
(7 of 10)

Figure C4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for
Organ Doses

Infant Age Group

Location 1 - Worst-Case Inhalation/Ground Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 2 - Worst-Case Vegetable Garden Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 3 - Worst-Case Meat Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 4 - Worst-Case Milk Animal Location *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Figure C4.0-1
(8 of 10)

Figure C4.0-1 (Cont'd) - Fuel Cycle Dose Calculation Worksheet for
Organ Doses

Location 5₁ - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 5₂ - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Location 5_N - Worst-Case Combination 1,2...N Location(s) *

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (l)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (g)	_____	_____	_____	_____	_____	_____	_____
D _{a,o} (T)	_____	_____	_____	_____	_____	_____	_____

Infant Organ Maximums**

Maximum Total

	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-LLI
D _{a,o} (T _{max})	_____	_____	_____	_____	_____	_____	_____

Figure C4.0-1
(9 of 10)

Figure C4.0-1 - Fuel Cycle Dose Calculation Worksheet For
(Cont'd) Food Pathway Organ Doses

All Age Groups

Maximum Organ Dose ***

Organ = XXXXXXXXXXXX
Age Group = XXXXXXXXXXXX
Dose = x.xE-xx mrem/yr

Notes:

- * Fuel cycle dose for each age group, a, and organ, o, at analyzed limiting food pathway locations.
 $D_{a,o}(T) = D_{a,o}(l) + D_{a,o}(g)$
- ** Limiting dose estimates for each organ for age group, a, (maximums of dose values calculated for Locations 1 through 5.)
- *** Limiting dose estimate for any organ or age group (maximum of dose values calculated for any age group)

C5.0 Radiological Environmental Monitoring

The Radiological Environmental Monitoring Program shall be conducted in accordance with Selected Licensee Commitment Manual Section 16.11-13.

The monitoring program locations and analyses are given in Tables C5.0-1 through C5.0-3 and Figure C5.0-1.

Duke Power's EnRad Laboratories participates in an interlaboratory comparison program. This program is described in the Annual Environmental Operating Report.

The land-use census data is used to identify the location with the highest possible dose for a particular ingestion pathway (vegetable, milk, meat, etc.). Environmental monitoring measurements taken from these locations are then used to perform dose calculations that serve as a verification of the dose calculations that are performed for technical specification and licensee commitment (i.e., Compliance) purposes.

The land use census that was used to identify the controlling receptor locations was conducted during July 14, 1999 - July 16, 1999.

The 1999 Land Use Census identified no locations where Radiological Environmental Monitoring Program samples are required to be collected but are unavailable for collection.

TABLE C5.0-1
 (1 of 1)
 CATAWBA RADIOLOGICAL MONITORING PROGRAM SAMPLING LOCATIONS
 (TLD LOCATIONS)

SAMPLING LOCATION DESCRIPTION			SAMPLING LOCATION DESCRIPTION		
200	Liberty Hill Road	(0.6M NNE)	232	4-5 MILE RADIUS	(4.1M NE)
201	Bluebird Lane	(0.5M NE)	233	4-5 MILE RADIUS	(3.9M ENE)
203	SITE BOUNDARY	(0.4M ESE)	234	4-5 MILE RADIUS	(4.5M E)
204	SITE BOUNDARY	(0.5M SSW)	235	4-5 MILE RADIUS	(3.9M ESE)
205	Overlook	(0.3M SW)	236	4-5 MILE RADIUS	(4.3M SE)
206	SITE BOUNDARY	(0.7M WNW)	237	4-5 MILE RADIUS	(4.8M SSE)
207	SITE BOUNDARY	(0.9M NNW)	238	4-5 MILE RADIUS	(4.0M S)
212	SPECIAL INTEREST	(3.3M E)	239	4-5 MILE RADIUS	(4.5M SSW)
217	CONTROL	(10.3M SSE)	240	4-5 MILE RADIUS	(4.1M SW)
222	SITE BOUNDARY	(0.7M N)	241	4-5 MILE RADIUS	(4.6M WSW)
223	SITE BOUNDARY	(0.6M E)	242	4-5 MILE RADIUS	(4.6M W)
225	SITE BOUNDARY	(0.7M SE)	243	4-5 MILE RADIUS	(4.4M WNW)
226	Discharge Bridge	(0.5M S)	244	4-5 MILE RADIUS	(4.0M NW)
227	SITE BOUNDARY	(0.5M WSW)	245	4-5 MILE RADIUS	(4.1M NNW)
228	SITE BOUNDARY	(0.6M W)	246	SPECIAL INTEREST	(7.8M ENE)
229	SITE BOUNDARY	(0.8M NW)	247	CONTROL	(7.3M ESE)
230	4-5 MILE RADIUS	(4.4M N)	248	SPECIAL INTEREST	(6.6M S)
231	4-5 MILE RADIUS	(4.2M NNE)	249	SPECIAL INTEREST	(8.1M S)
255	SITE BOUNDARY	(0.6M ENE)	250	SPECIAL INTEREST	(10.4M WSW)
256	SITE BOUNDARY	(0.6M SSE)	251	CONTROL	(9.7M WNW)

TABLE C5.0-2

(1 of 1)

CATAWBA RADIOLOGICAL MONITORING PROGRAM SAMPLING LOCATIONS
(OTHER SAMPLING LOCATIONS)

CODE:		Air Radioiodines and Particulates	Surface Water	Drinking Water	Shoreline Sediment	Milk	Fish	Broadleaf Vegetation	Groundwater	Food Products
W - Weekly	SM - Semimonthly									
BW - Biweekly	Q - Quarterly									
M - Monthly	SA - Semiannually									
Sampling Location Description										
200	Liberty Hill Road (0.6m NNE)	W						M		
201	Bluebird Lane (0.5m NE)	W						M		
205	Overlook (0.3m SW)	W								
208	Discharge Canal (0.5m S)		BW		SA		SA			
209	Wood Dairy (6.0m SSW)					SM				
210	Ebenezer Access (2.3m SE)				SA					
211	Wylie Dam (4.0m ESE)		BW							
212	Tega Cay (3.3m E)	W								
214	Rock Hill Water Supply (7.3m SE)			BW						
215	River Pointe - Hwy 49 (4.2m NNE) Control		BW		SA					
216	Hwy 49 Bridge (4.0m NNE) Control						SA			
217	Rock Hill Substation (10.3m SSE) Control	W						M		
218	Belmont Water Supply (13.4m NNE) Control			BW						
219	Pursley Dairy (5.7m SW)					SM				
221	Oates Dairy (14.5m NW) Control					SM				
222	Site Boundary (0.7m N)							M		
226	Discharge Bridge (0.5m S)							M		
252	Residence (0.7m SW)								O	
253	Cloninger Irrigated Garden (Downstream within 5 mile radius)									M ^(a)
254	Residence (0.8m N)								O	


(a) during harvest season

Revision 42
1/1/00

TABLE C5.0-3
(1 of 1)
CATAWBA RADIOLOGICAL MONITORING PROGRAM ANALYSES


<u>SAMPLE MEDIUM</u>	<u>ANALYSIS SCHEDULE</u>	<u>ANALYSIS</u>				
		<u>GAMMA ISOTOPIC</u>	<u>TRITIUM</u>	<u>LOW LEVEL I-131</u>	<u>GROSS BETA</u>	<u>TLD</u>
1. Air Radioiodine	Weekly	X				
2. Air Particulates	Weekly Quarterly	X			X	
3. Direct Radiation	Quarterly					X
4. Surface Water	Monthly Composite Quarterly Composite	X	X		X	
5. Drinking Water	Monthly Composite Quarterly Composite	X	X		X	
6. Shoreline Sediment	Semiannually	X				
7. Milk	Semimonthly	X		X		
8. Fish	Semiannually	X				
9. Broadleaf Vegetation	Monthly	X				
10. Groundwater	Quarterly	X	X			
11. Food Products	Monthly (a)	X				

(a) during harvest season




- LEGEND**
- PRIMITIVE OR UNIMPROVED ROAD
 - GRADED AND DRAINED ROAD
 - SOIL, GRAVEL OR STONE SURFACED ROAD
 - HARD SURFACED ROAD
 - 2 LANE UNDIVIDED HIGHWAY
 - DIVIDED HIGHWAY
 - HIGHWAY WITH FRONTAGE ROADS
 - FULL CONTROL ACCESS
 - FEDERAL AID INTERSTATE ROAD
 - FEDERAL AID PRIMARY ROAD
 - FEDERAL AID SECONDARY ROAD
 - FEDERAL AID URBAN
 - NON-SYSTEM ROAD
 - PROJECTED LOCATION
 - INTERSECTION DISTANCE
 - TRAFFIC CIRCLE
 - HIGHWAY INTERCHANGE
 - DETAILED HIGHWAY INTERCHANGE
 - INTERSTATE HIGHWAY
 - U.S. NUMBERED HIGHWAY
 - N.C. NUMBERED HIGHWAY
 - SECONDARY ROAD NUMBER
 - UNDERGROUND CABLE
 - RAILROAD, ANY NUMBER OF TRACKS USED BY SINGLE OPERATING COMPANY
 - RAILROAD, ANY NUMBER OF TRACKS USED BY MORE THAN ONE OPERATING COMPANY ON SAME OR ADJACENT RIGHTS-OF-WAY
 - RAILROAD STATION
 - GRADE CROSSING
 - UNDERPASS
 - OVERPASS
 - RAILROAD TUNNEL
 - ARMY, NAVY OR MARINE CORPS FIELD
 - COMM. OR MUNICIPAL AIRPORT
 - MARKED AUXILIARY FIELD
 - HANGAR ON FIELD "B" IN SYMBOL
 - DOCK, PIER OR LANDING
 - FERRY OR TOLL FERRY
 - LIGHT, NAUTICAL
 - LIGHTHOUSE
 - COAST GUARD STATION
 - CANAL
 - NARROW STREAM
 - WIDE STREAM
 - DAM WITH LOCK
 - DAM
 - RESERVOIR, POND OR LAKE
 - PROMINENT PEAK, NUMERALS INDICATE ELEVATION
 - ROAD THROUGH MOUNTAIN PASS
 - HIGHWAY BRIDGE, OVER 20 FT.
 - DRAW SPAN ON BRIDGE
 - HIGHWAY TUNNEL
 - FORD
 - STATE LINE
 - COUNTY LINE
 - CITY LIMITS
 - RESERVATION OR PARK BOUNDARY
 - INSET AREA
 - DELIMITED AREA, POPULATION EST.
 - COUNTY SEAT
 - OTHER TOWNS AND VILLAGES
 - TRIANGULATION STATION
 - INCORPORATED CITY OR VILLAGE, UNINCORPORATED
 - SCHOOL
 - CHURCH
 - CHURCH WITH CEMETERY
 - CEMETERY
 - HOSPITAL
 - CORRECTIONAL OR PENAL INSTN.
 - HIGHWAY GARAGE, OR MAINT. YARD
 - HIGHWAY DIV. OR DIST. OFFICE
 - WEIGHT STATION
 - PATROL STATION
 - REB. AREA
 - MONUMENT—SMALL HISTORICAL SITE

● TLD LOCATIONS
 ▲ ALL OTHER LOCATIONS



CATAWBA NUCLEAR STATION
MONITORING PROGRAM LOCATIONS
FIGURE C5.0-1
(1 OF 2)
 Revision 36
 1/1/94



MONITORING PROGRAM LOCATION:
 FIGURE C5.0-1
 (2 OF 2)

REVISION 25
 1/1/80

• TLD LOCATIONS
 x ALL OTHER LOCATIONS

1" = 400' 0" 800' 1600' FEET



1" = 100' 0" 200' 400' METERS



CATAWBA NUCLEAR STATION