

February 11, 2000

Mr. John B. Cotton
Vice President, TMI Unit 1
AmerGen Energy Company, LLC
P.O. Box 480
Middletown, PA 17057

SUBJECT: TMI-1 - COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 99-02,
"LABORATORY TESTING OF NUCLEAR-GRADE ACTIVATED CHARCOAL"
(TAC NO. MA5855)

Dear Mr. Cotton:

On June 3, 1999, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 99-02, "Laboratory Testing of Nuclear-grade Activated Charcoal," to all holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

The purpose of the GL was to:

- (1) Alert addressees that the NRC has determined that testing nuclear-grade activated charcoal to standards other than American Society for Testing and Materials (ASTM) D3803-1989, "Standard Test Method for Nuclear-Grade Activated Carbon," does not provide assurance for complying with the current licensing basis as it relates to the dose limits of General Design Criterion (GDC) 19 of Appendix A to Part 50 of Title 10 of the *Code of Federal Regulations* (10 CFR) and Subpart A of 10 CFR Part 100.
- (2) Request that all addressees determine whether their Technical Specifications (TS) reference ASTM D3803-1989 for charcoal filter laboratory testing. Addressees whose TS do not reference ASTM D3803-1989 should either amend their TS to reference ASTM D3803-1989 or propose an alternative test protocol and provide the information discussed in the requested actions.
- (3) Alert addressees to the staff's intent to exercise enforcement discretion under certain conditions.
- (4) Request that all addressees send the NRC written responses on the implementation of the actions requested in this GL.

In GL 99-02, the NRC staff established the following four groups of plants:

- (1) plants in compliance with their TS that test in accordance with ASTM D3803-1989
- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided a letter dated November 30, 1999, for Three Mile Island Nuclear Station, Unit 1. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL. The NRC staff has reviewed your response and has concluded that you have provided requested information and a TS change request in accordance with the GL. In addition, you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, we consider GL 99-02 to be closed for your facility and this completes our effort under TAC No. MA5855. The TS change will be reviewed as a separate, plant-specific action under TAC No. MA7288. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me at (301) 415-1402.

Sincerely,

/RA/

Timothy G. Colburn, Sr. Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-289

cc: See next page

In GL 99-02, the NRC staff established the following four groups of plants:

- (1) plants in compliance with their TS that test in accordance with ASTM D3803-1989
- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided a letter dated November 30, 1999, for Three Mile Island Nuclear Station, Unit 1. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL. The NRC staff has reviewed your response and has concluded that you have provided requested information and a TS change request in accordance with the GL. In addition, you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, we consider GL 99-02 to be closed for your facility and this completes our effort under TAC No. MA5855. The TS change will be reviewed as a separate, plant-specific action under TAC No. MA7288. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me at (301) 415-1402.

Sincerely,
/RA/
 Timothy G. Colburn, Sr. Project Manager, Section 1
 Project Directorate I
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket No. 50-289

cc: See next page

DISTRIBUTION:

- File Center
- PUBLIC
- PDI-1 R/F
- EAdensam (e-mail)
- MGamberoni (A)
- TColburn
- EWeiss
- BMozafari
- MO'Brien
- JSegala
- JHannon
- OGC
- ACRS
- MOprendeck, RGN-I

DOCUMENT NAME:G:/PDI-1/TMI-1/LTRa5855.wpd

TO RECEIVE A COPY, WRITE A "E" IN THE BOX.

OFFICE	PDI-1\PM	E	PDI-1\LA	E	LPM		SPLB\SC		PDI-1\SC(A)	E
NAME	TColburn:lcc		MO'Brien		BMozafari		EWeiss		MGamberoni	
DATE	2/3/00		2/3/00		2/3/00		2/8/00		2/8/00	

Three Mile Island Nuclear Station, Unit No. 1

cc:

Robert Fraile
Plant Manager
AmerGen Energy Company, LLC
P. O. Box 480
Middletown, PA 17057

Michael Ross
Director, Work Management, TMI-1
AmerGen Energy Company, LLC
P.O. Box 480
Middletown, PA 17057

James A. Hutton
Director - Licensing
PECO Energy Company
955 Chesterbrook Blvd., 62A-1
Wayne, PA 19087-5691

Edwin C. Fuhrer
Manager, TMI Regulatory Affairs
AmerGen Energy Company, LLC
P.O. Box 480
Middletown, PA 17057

Edward J. Cullen, Jr., Esquire
PECO Energy Company
2301 Market Street
S23-1
Philadelphia, PA 19103

Chairman
Board of County Commissioners
of Dauphin County
Dauphin County Courthouse
Harrisburg, PA 17120

Chairman
Board of Supervisors
of Londonderry Township
R.D. #1, Geyers Church Road
Middletown, PA 17057

Wayne L. Schmidt
Senior Resident Inspector (TMI-1)
U.S. Nuclear Regulatory Commission
P.O. Box 219
Middletown, PA 17057

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Robert B. Borsum

B&W Nuclear Technologies
Suite 525
1700 Rockville Pike
Rockville, MD 20852

David J. Allard, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P.O. Box 2063
Harrisburg, PA 17120

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Peter W. Eselgroth, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406