

February 14, 2000

Mr. Eliot Protsch
President
IES Utilities Inc.
200 First Street, SE
P.O. Box 351
Cedar Rapids, IA 52406-0351

SUBJECT: COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 99-02,
"LABORATORY TESTING OF NUCLEAR-GRADE ACTIVATED CHARCOAL" -
DUANE ARNOLD ENERGY CENTER, (TAC NO. MA5790)

Dear Mr. Protsch:

On June 3, 1999, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 99-02, "Laboratory Testing of Nuclear-grade Activated Charcoal," to all holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

The purpose of the GL was to:

- (1) Alert addressees that the NRC has determined that testing nuclear-grade activated charcoal to standards other than American Society for Testing and Materials (ASTM) D3803-1989, "Standard Test Method for Nuclear-Grade Activated Carbon," does not provide assurance for complying with the current licensing basis as it relates to the dose limits of General Design Criterion (GDC) 19 of Appendix A to Part 50 of Title 10 of the *Code of Federal Regulations* (10 CFR) and Subpart A of 10 CFR Part 100.
- (2) Request that all addressees determine whether their Technical Specifications (TS) reference ASTM D3803-1989 for charcoal filter laboratory testing. Addressees whose TS do not reference ASTM D3803-1989 should either amend their TS to reference ASTM D3803-1989, or propose an alternative test protocol and provide the information discussed in the requested actions.
- (3) Alert addressees to the staff's intent to exercise enforcement discretion under certain conditions.
- (4) Request that all addressees send the NRC written responses on the implementation of the actions requested in this GL.

In GL 99-02, the NRC staff established the following four groups of plants:

- (1) plants in compliance with their TS that test in accordance with ASTM D3803-1989

E. Protsch

- 2 -

- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided a letter dated November 10, 1999, for the Duane Arnold Energy Center. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL. The NRC staff has reviewed your response and has concluded that you have provided requested information and a TS change request in accordance with the GL. In addition, you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, we consider GL 99-02 to be closed for your facility. The TS change will be reviewed as a separate, plant-specific action under TAC No. MA7269. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact Brenda Mozafari at (301) 415-2020.

Sincerely,

/RA/

Brenda L. Mozafari, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-331

cc: See next page

E. Protsch

- 2 -

- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided a letter dated November 10, 1999, for the Duane Arnold Energy Center. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL. The NRC staff has reviewed your response and has concluded that you have provided requested information and a TS change request in accordance with the GL. In addition, you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, we consider GL 99-02 to be closed for your facility. The TS change will be reviewed as a separate, plant-specific action under TAC No. MA7269. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact Brenda Mozafari at (301) 415-2020.

Sincerely,
/RA/
 Brenda L. Mozafari, Project Manager, Section 1
 Project Directorate III
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket No. 50-331

cc: See next page

DISTRIBUTION:

File Center	OGC	JSegala
PUBLIC	ACRS	JHannon
PDIII-1 Reading	BMozafari	GGrant, RIII

C:\MA5790LTR.wpd

To RECEIVE A COPY OF THIS DOCUMENT, WRITE A "C" IN THE BOX *See previous concurrence

OFFICE	PDIII-1/PM	C	SPLB/SC*		PDIII-1/LA	C	PDIII-1/SC	
NAME	BMozafari		EWeiss		THarris		CCraig	
DATE	2/9/00		2/8/00		2/9/00		2/9/00	

OFFICIAL RECORD COPY

Duane Arnold Energy Center

cc:

Al Gutterman
Morgan, Lewis, & Bockius LLP
1800 M Street, N. W.
Washington, DC 20036-5869

Chairman, Linn County
Board of Supervisors
Cedar Rapids, IA 52406

IES Utilities Inc.
ATTN: Richard L. Anderson
Plant Manager, Nuclear
3277 DAEC Road
Palo, IA 52324

David L. Wilson
Vice President, Nuclear
Duane Arnold Energy Center
3277 DAEC Road
Palo, IA 52324

Ken Peveler
Manager, Nuclear Licensing
Duane Arnold Energy Center
3277 DAEC Road
Palo, IA 52324

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
Rural Route #1
Palo, IA 52324

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, IL 60532-4531

Daniel McGhee
Utilities Division
Iowa Department of Commerce
Lucas Office Building, 5th floor
Des Moines, IA 50319