

February 10, 2000

Mr. William R. McCollum, Jr.
Vice President, Oconee Site
Duke Energy Corporation
7800 Rochester Highway
Seneca, SC 29672

SUBJECT: OCONEE NUCLEAR STATION, UNITS 1, 2 AND 3 RE: COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 99-02, "LABORATORY TESTING OF NUCLEAR-GRADE ACTIVATED CHARCOAL" (TAC NOS. MA5819, MA5820 AND MA5821)

Dear Mr. McCollum:

On June 3, 1999, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 99-02, "Laboratory Testing of Nuclear-grade Activated Charcoal," to all holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

The purpose of the GL was to:

- (1) Alert addressees that the NRC has determined that testing nuclear-grade activated charcoal to standards other than American Society for Testing and Materials (ASTM) D3803-1989, "Standard Test Method for Nuclear-Grade Activated Carbon," does not provide assurance for complying with the current licensing basis as it relates to the dose limits of General Design Criterion (GDC) 19 of Appendix A to Part 50 of Title 10 of the *Code of Federal Regulations* (10 CFR) and Subpart A of 10 CFR Part 100.
- (2) Request that all addressees determine whether their Technical Specifications (TS) reference ASTM D3803-1989 for charcoal filter laboratory testing. Addressees whose TS do not reference ASTM D3803-1989 should either amend their TS to reference ASTM D3803-1989 or propose an alternative test protocol and provide the information discussed in the requested actions.
- (3) Alert addressees to the staff's intent to exercise enforcement discretion under certain conditions.
- (4) Request that all addressees send the NRC written responses to this generic letter relating to implementation of the requested actions.

In GL 99-02, the NRC staff established the following four groups of plants:

- (1) Plants in compliance with their TS that test in accordance with ASTM D3803-1989.
- (2) Plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989.

- (3) Plants not in compliance with their TS that test in accordance with ASTM D3803-1989.
- (4) Plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989.

In response to GL 99-02, you provided a letter dated November 30, 1999, for Oconee Nuclear Station, Units 1, 2 and 3. This submittal indicated that Oconee is a Group 1 plant. We have reviewed your response and have concluded that all requested information has been provided; therefore, we consider GL 99-02 to be closed for your facility. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me at 301-415-1472.

Sincerely,

/RA/

David LaBarge, Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270 and 50-287

cc: See next page

- (3) Plants not in compliance with their TS that test in accordance with ASTM D3803-1989.
- (4) Plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989.

In response to GL 99-02, you provided a letter dated November 30, 1999, for Oconee Nuclear Station, Units 1, 2 and 3. This submittal indicated that Oconee is a Group 1 plant. We have reviewed your response and have concluded that all requested information has been provided; therefore, we consider GL 99-02 to be closed for your facility. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me at 301-415-1472.

Sincerely,

/RA/

David LaBarge, Project Manager, Section 1
 Project Directorate II
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270 and 50-287

cc: See next page

DISTRIBUTION:

File Center
 PUBLIC
 PDII-1 R/F
 REmch
 CHawes
 DLaBarge
 BMozafari
 JSegala
 JHannon

TO RECEIVE A COPY, WRITE A "C" IN THE BOX.

OFFICE	PDII-1:PM	PDII-1:LA	LPM	SC: SPLB	PDII-1:SC
NAME	DLaBarge:cn	CHawes	BMozafari	JSegala	REmch
DATE	12/22/99	12/22/99	12/22/99	02/09/00	02/09/00

DOCUMENT NAME: g:\pdii-1\oconee\oco5819.wpd

OFFICIAL RECORD COPY

Oconee Nuclear Station

cc:

Ms. Lisa F. Vaughn
Legal Department (PBO5E)
Duke Energy Corporation
422 South Church Street
Charlotte, North Carolina 28201-1006

Anne W. Cottingham, Esquire
Winston and Strawn
1400 L Street, NW
Washington, DC 20005

Mr. Rick N. Edwards
Framatome Technologies
Suite 525
1700 Rockville Pike
Rockville, Maryland 20852-1631

Manager, LIS
NUS Corporation
2650 McCormick Drive, 3rd Floor
Clearwater, Florida 34619-1035

Senior Resident Inspector
U. S. Nuclear Regulatory
Commission
7812B Rochester Highway
Seneca, South Carolina 29672

Virgil R. Autry, Director
Division of Radioactive Waste Management
Bureau of Land and Waste Management
Department of Health and Environmental
Control
2600 Bull Street
Columbia, South Carolina 29201-1708

Mr. L. E. Nicholson
Compliance Manager
Duke Energy Corporation
Oconee Nuclear Site
7800 Rochester Highway
Seneca, South Carolina 29672

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

L. A. Keller
Manager - Nuclear Regulatory
Licensing
Duke Energy Corporation
526 South Church Street
Charlotte, North Carolina 28201-1006

Mr. Richard M. Fry, Director
Division of Radiation Protection
North Carolina Department of
Environment, Health, and
Natural Resources
3825 Barrett Drive
Raleigh, North Carolina 27609-7721

Mr. Steven P. Shaver
Senior Sales Engineer
Westinghouse Electric Company
5929 Carnegie Blvd.
Suite 500
Charlotte, North Carolina 28209