

January 12, 2000

RECORDED
Template = NRR-056

Mr. Robert P. Powers, Senior Vice President
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

SUBJECT: DONALD C. COOK - CORRECTION TO AMENDMENTS
(TAC NOS. MA6473 AND MA6474)

The U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 236 to Facility Operating License No. DPR-58 and Amendment No. 218 to Facility Operating License No. DPR-74 for the Donald C. Cook Nuclear Plant, Units 1 and 2. Page 2 of the amendments and Page 13 of the Safety Evaluation (SE) were inadvertently dated December 28, 1999, and should have read December 23, 1999. Please replace these pages with the enclosed corrected copy.

We are sorry for any inconvenience this may have caused.

Sincerely,

Original Signed By:

John F. Stang, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

Enclosure: As stated

cc w/encls: See next page

FILE CENTER COPY

DISTRIBUTION:

File Center WBeckner
PUBLIC GHill(2)
PD 3-1 r/f AVegel, RIII
OGC ACRS

DOCUMENT NAME: G:\PDIII-1\Harris\corltrdcook.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PD3-1	E	LA:PD3-1	SC:PD3-1	C
NAME	JStang		THarris JFA	CCraig	
DATE	01/11/00		01/17/00	01/11/00	

DF01

Donald C. Cook Nuclear Plant, Units 1 and 2

cc:

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, MI 48913

Township Supervisor
Lake Township Hall
P.O. Box 818
Bridgman, MI 49106

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
7700 Red Arrow Highway
Stevensville, MI 49127

David W. Jenkins, Esquire
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Mayor, City of Bridgman
P.O. Box 366
Bridgman, MI 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, MI 48909

Drinking Water and Radiological
Protection Division
Michigan Department of
Environmental Quality
3423 N. Martin Luther King Jr Blvd
P.O. Box 30630, CPH Mailroom
Lansing, MI 48909-8130

Robert C. Godley
Director, Regulatory Affairs
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106


David A. Lochbaum
Union of Concerned Scientists
1616 P Street NW, Suite 310
Washington, DC 20036-1495

A. Christopher Bakken, Site Vice President
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Michael W. Rencheck
Vice President, Nuclear Engineering
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

2. Accordingly, the license is amended to authorize revision of the Updated Final Safety Analysis (UFSAR) and Emergency Operating Procedures (EOPs) as set forth in the application for amendment by the licensee, dated September 17, 1999, and as supplemented November 10, 1999, and November 19, 1999, and as evaluated in the staff Safety Evaluation attached to this amendment. The licensee shall update the UFSAR and change the EOPs to allow credit for the negative reactivity provided by the insertion of the rod cluster control assemblies into the reactor core following a design basis loss-of-coolant accident as authorized by this license amendment and in accordance with 10 CFR 50.71(e).
3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION




Claudia M. Craig, Chief, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications Bases

Date of Issuance: December 23, 1999

2. Accordingly, the license is amended to authorize revision of the Updated Final Safety Analysis (UFSAR) and Emergency Operating Procedures (EOPs) as set forth in the application for amendment by the licensee, dated September 17, 1999, and as supplemented November 10, 1999 and November 19, 1999, and as evaluated in the staff Safety Evaluation attached to this amendment. The licensee shall update the UFSAR and change the EOPs to allow credit for the negative reactivity provided by the insertion of the rod cluster control assemblies into the reactor core following a design basis loss-of-coolant accident as authorized by this license amendment and in accordance with 10 CFR 50.71(e).
3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Claudia M. Craig, Chief, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications Bases

Date of Issuance: December 23, 1999

5.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Michigan State official was notified of the proposed issuance of the amendments. The State official had no comments.

6.0 ENVIRONMENTAL CONSIDERATION

These amendments change the requirements with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 or change the surveillance requirements. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration and there has been no public comment on such finding (64 FR 56531). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

7.0 CONCLUSION

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: M. Mitchell
J. Rajan
M. Chatterton

Date: December 23, 1999