



**Pacific Gas and
Electric Company**

Lawrence F. Womack
Vice President
Nuclear Technical Services

Diablo Canyon Power Plant
P.O. Box 56
Avila Beach, CA 93424

805.545.6000

December 31, 1999

PG&E Letter DCL-99-169

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Docket No. 50-275, OL-DPR-80

Docket No. 50-323, OL-DPR-82

Diablo Canyon Units 1 and 2

Withdrawal of License Amendment Request 99-01, "Unreviewed Safety Question -
Spurious Operation of the Safety Injection System at Power"

Dear Commissioners and Staff:

The purpose of this letter is to withdraw License Amendment Request (LAR) 99-01, "Unreviewed Safety Question - Spurious Operation of the Safety Injection System at Power," submitted by PG&E Letter DCL-99-071, dated May 21, 1999. LAR 99-01 requested NRC review and approval of a revised analysis for the spurious operation of the safety injection (SI) system at power event crediting automatic actuation of the Class 1 power operated relief valves (PORVs), instead of the pressurizer safety valves (PSVs), to limit reactor coolant system pressure. No credit is taken in the current Final Safety Analysis Report Update for automatic operation of the PORVs, which function to limit undesirable opening of the PSVs, since part of the automatic actuation circuitry is Instrument Class II.

After discussions with the NRC staff regarding the proposed LAR, PG&E has decided to pursue other options to resolve the issues relating to the spurious operation of the SI system at power event.

Sincerely,

Lawrence F. Womack

*Accol
1/0*

cc: Edgar Bailey, DHS
Steven D. Bloom
Ellis W. Merschoff
David L. Proulx
Diablo Distribution